



3S Ash Pond Liner Damage - Will County

Rebecca Maddox to: Sarah Kamm, Margaret Ruane
Cc: Maria Race, William Naglosky

06/26/2012 03:31 PM

Marge and/or Sarah -

Please see the attached photos. The south east section of the HDPE liner on our 3S ash pond is extremely damaged. The felt lining and the HDPE is completely torn up. I think this has been buried under some of the ash for a bit and I just noticed it today as I went to check on another item. Could have occurred during the clean-out of the pond many months ago. We had some real fears this was going to be an issue going forward w/ LaFarge and the clean-out process. Can you follow-up with LaFarge on this? I do not know how we should proceed with this or what type of repairs we could even do. I will forward the photos onto our consultant who engineered the pond for some suggestions. 2S pond is currently not in service and needs to be cleaned out by LaFarge so we cannot switch back. 2S is completely full of ash.



Liner 4.JPG Liner 1.JPG Liner 2.JPG Liner 3.JPG

Beckie Maddox
Environmental Specialist
Will County Station
815-372-4589 - office
815-355-5819 - cell

This transmittal contains privileged and confidential information belonging to the sender. This information is intended only for use of the individual or entity named above. If the reader of this message is not the intended recipient or the employee or agent responsible for delivering the message to the intended recipient, you are hereby notified that any disclosure, dissemination, copying, or distribution of this communication is strictly prohibited.

Comp. Ex. 307

MWG13-15_14177



MWG13-15_14178



MWG13-15_14179



MWG13-15_14180



MWG13-15_14181

