

RECEIVED  
CLERK'S OFFICE

JAN 11 2001

STATE OF ILLINOIS  
Pollution Control Board

BEFORE THE ILLINOIS POLLUTION CONTROL BOARD

IN THE MATTER OF: )

PROPOSED NEW 35 III. ADM. CODE 217, SUBPART U, )  
NOx CONTROL AND TRADING PROGRAM FOR )  
SPECIFIED NOx GENERATING UNITS, SUBPART X, )  
VOLUNTARY NOx EMISSIONS REDUCTION PROGRAM, )  
AND AMENDMENTS TO 35 III. ADM CODE 211 )

R01-17  
(Rulemaking-  
Air)

*P.C.#3*

NOTICE OF FILING

TO: Ms. Dorothy M. Gunn  
Clerk of the Board  
Illinois Pollution Control Board  
James R. Thompson Center  
100 West Randolph Street  
Suite 11-500  
Chicago, IL 60601  
(VIA Certified U.S. MAIL)

Bobb A. Beauchamp, Esq  
Hearing Officer  
Illinois Pollution Control Board  
James R. Thompson Center  
100 West Randolph Street  
Suite 11-500  
Chicago, IL 60601  
(VIA FAX)

PLEASE TAKE NOTICE that I have filed today with the Office of the Illinois Pollution Control Board comments on behalf of the University of Illinois, a copy of which is herewith served upon you.

Respectfully submitted,

OFFICE FOR PLANNING AND BUDGETING  
UNIVERSITY OF ILLINOIS

By:

*Lyle D. Wachtel*  
Lyle D. Wachtel, P.E.

Dated: January 8, 2001

Lyle D. Wachtel, P.E.  
Director, Office for Planning and Budgeting  
338 Henry Administration Building  
506 South Wright Street  
Urbana, IL 61801  
(217) 333-0375

The University, in support of seeking relief to the continuous emissions requirements of the current NOx SIP Call, offers the following comments to the Board for their thoughtful consideration.

In September 1961, The Babcock and Wilcox Company (B & W), a manufacturer of stoker boilers, responded to a bid solicited by the Board of Trustees of the University of Illinois. This proposal was to furnish a 150 Mlb/Hr coal fired steam boiler for the Urbana campus of the University of Illinois. B & W also provided as an alternate bid, a 200 Mlb/Hr coal fired steam boiler. These ratings were based on continuous operation.

The University selected the larger alternate and the boiler was installed at the Abbott power plant in 1962. As part of the installation, an owner's manual that documented the boilers specifications was provided. Four pages of this manual have been copied and are attached for reference as Exhibit A.

On page two of Exhibit A, two ratings are referenced for the boiler operation: a two hour maximum peak rating of 220 Mlb/Hr and a continuous rating of 200 Mlb/Hr. Using the continuous rating, the rating that the boiler was designed to operate over the long term, the specifications indicate that a fuel quantity of 21,200 lbs of coal/hour (Exhibit A, page 3, line 9) was the maximum rate of fuel input. Furthermore, based on the coal available from a mine in Vermillion County, Illinois, with a heat content of 11,500 BTU/lb (Exhibit A, page 4, line 50), the total heat input of the boiler was designed for 243.8 million BTU/Hr (21,200 lb/Hr X 11,500 BTU/lb). This heat input is less than

the 250 million BTU required for inventory classification under the current NOx SIP Call.


The Title V permit submitted to the Agency by the University was in error by including the peak rating of the boiler as a nameplate operation and not the continuous rating as provided in the specifications. If the Agency desires, the University will submit corrected documents reflecting this oversight to better reflect the true continuous heat input of boiler #7.

Note that the Vermillion County mine, that produced coal specified for boiler #7 in 1962, has since closed. The coal available for use at Abbott for the past ten years has been limited to two suppliers based in Illinois. Attached for reference as Exhibit B (existing coal supplier) and Exhibit C (previous coal supplier) are the coal analyses of the two suppliers competing for the University business. In both cases, the heat content is less than 11,500 BTU/lb (Exhibit B 10,597 BTU/lb – Exhibit C 11,074 BTU/lb) originally specified by the boiler manufacturer. Consequently, based on the boiler input rate and because of the boiler grate size and fire box dimensions, this lower quality coal will never provide enough heat input to exceed the 250 million BTU/Hr threshold provided under the current NOx SIP Call.

It is unfortunate the University did not correct this oversight prior to the NOx SIP Call, but it is the expressed desire of the University to have this rating corrected in the Agency's inventory prior to finalization of this rule. The University believes that as long

as the NOx budget of the State is not affected, then this adjustment could be possible pursuant to the precedent set and described under the rule revision found in the Federal Register (Dec. 21, 2000, Volume 65, Number 246). The Board has heard testimony of another entity requesting additions to the inventory and this adjustment provides an opportunity to accommodate this entity.

Respectfully submitted,  
UNIVERSITY OF ILLINOIS

By:   
Lyle D. Wachtel, P.E.  
Director  
Office for Planning and Budgeting

Dated: January 8, 2001

Lyle D. Wachtel, P.E.  
Director, Office for Planning and Budgeting  
338 Henry Administration Building  
506 South Wright Street  
Urbana, IL 61801  
(217) 333-0375

# INSTRUCTIONS

BLR - 7

EXHIBIT A

for the

## CARE AND OPERATION

of

# BABCOCK & WILCOX EQUIPMENT

FURNISHED ON CONTRACT

113-0104

S-10104

for

UNIVERSITY OF ILLINOIS

ABBOTT POWER PLANT

CHAMPAIGN, ILLINOIS



THE BABCOCK & WILCOX COMPANY  
161 EAST 42nd STREET, NEW YORK 17, N.Y.

B

#7

DESCRIPTION OF UNIT

MAXIMUM CONTINUOUS HIGH PRESSURE STEAM OUTPUT

LB/HR:	200,000
2 HR. PEAK	220,000

STEAM CONDITIONS AT SUPERHEATER OUTLET

TEMPERATURE, F:	760
PRESSURE, PSI:	875

DESIGN PRESSURE, PSI.

BOILER:	975
ECONOMIZER:	1,050

HEATING SURFACE, SQ. FT.

BOILER:	14,114
FURNACE:	2,160
SUPERHEATER:	3,671
ECONOMIZER:	6,600

APPROXIMATE WATER HOLDING CAPACITY  
IN POUNDS PER UNIT

NORMAL:	98,400
HYDROSTATIC:	124,200

DESCRIPTION OF UNIT

STEAM, ACTUAL, M LB/HR		200	220		
TYPE OF FUEL		Coal	Coal		
RATE AND LOAD DURATION, HR		Cont.	2 Hr. Pk.		
FURNACE LIBERATION, KB/CU FT-HR					
EXCESS AIR LEAVING BOILER %		25	25		
BURNERS, NO. IN USE PER FURNACE					
QUANTITIES M LB/HR	CONTINUOUS BLOWDOWN	0	0		
	FUEL	21.2			
	FLUE GAS LEAVING BOILER	243.5			
	AIR LEAVING A H **	189.5			
PRESSURES LB/SQ IN	STEAM AT S H OUTLET	875	875		
	MIN OPER IN BOILER DRUM	907			
	DROP, DRUM TO S H OUTLET	32			
	DROP THRU ECON	55			
TEMPERATURES F	SUPERHEATED STEAM	760	762		
	FLUE GAS LEAVING BLR	681			
	FLUE GAS LEAVING ECON	489			
	FLUE GAS LEAVING A H	350			
	WATER ENTERING ECON	380	388		
	WATER ENTERING BLR	458			
	AIR ENTERING A H	700	700		
	AIR LEAVING A H	293			
DRAFT LOSSES IN. OF WATER	FURNACE	0.1			
	BOILER AND SUPERHEATER	0.8			
	ECONOMIZER	1.6			
	AIR HEATER	2.0			
	DUST COLLECTOR	2.5			
	FLUES	1.2			
	NET DRAFT LOSS	8.2	9.9		
AIR RESIS. IN. OF WATER	STOKER AND WINDBOX	1.7			
	DUCTS	1.5			
	AIR HEATER & STM. A.H.	0.7			
	NET RESISTANCE	3.9	4.7		
HEAT LOSSES %	DRY GAS	5.4			
	H <sub>2</sub> AND H <sub>2</sub> O IN FUEL	5.4			
	MOISTURE IN AIR	0.2			
	UNBURNED COMBUSTIBLE *	3.5			
	RADIATION	0.6			
	UNACCOUNTED FOR	1.5			
	TOTAL HEAT LOSS	16.8			
EFFICIENCY OF UNIT, %		83.2	82.6		
* Based on cinder returns from boiler hoppers and cinder trap only.					
** Based on 85% of furnace air through air heater.					
MAX ALLOWABLE BOILER CONC, PPM		1500			
SOLIDS IN STEAM PPM		1			
PULVERIZER	NO. IN USE PER FURNACE				
	AIR TEMP TO PULV, F				
	TOTAL POWER, KW HR/TON				
	% THRU NO. 200 U.S. SIEVE				
	% THRU NO. 50 U.S. SIEVE				


EXPECTED PERFORMANCE

<b>SOURCE</b>	SAMPLES			
	ANALYSES Customers Specifications			
<b>SOLID</b>	<b>KIND</b>			
	<b>A.S.T.M.</b>	<b>CLASS</b>		
		<b>GROUP</b>		
	<b>SOURCE</b>	<b>MINE</b>		
		<b>SEAM</b>		
		<b>DISTRICT</b>		
		<b>COUNTY</b> Vermilion		
		<b>STATE</b> Illinois		
	<b>SIZE</b> 1 1/4			
	<b>GRINDABILITY</b>			
	<b>SURFACE MOIST., %</b>			
	<b>PROX ANAL %</b>	<b>MOISTURE</b> 12.6		
		<b>VOL MATTER</b> 40.5		
		<b>FIXED CARBON</b> 38.3		
		<b>ASH</b> 8.6		
<b>TOTAL</b> 100.0				
<b>ASH TEMP F</b>	-			
	<b>REDUCING</b>		<b>OXIDIZING</b>	
	<b>INITIAL DEFORMATION</b>			
	<b>SOFTENING</b>		2020	
<b>LIQUID</b>				
<b>LIQUID</b>	<b>KIND</b>			
	<b>GRAVITY, DEG. A.P.I.</b>			
<b>GASEOUS</b>	<b>KIND</b>			
	<b>SP GR REL TO AIR</b>			
<b>ULTIMATE ANALYSES</b>	<b>FUEL</b>	Coal		
	<b>% BY</b>	Wt.		
	<b>ASH</b>	8.6		
	<b>S</b>	2.5		
	<b>H<sub>2</sub></b>	4.53		
	<b>C</b>	63.00		
	<b>CH<sub>4</sub></b>			
	<b>C<sub>2</sub>H<sub>4</sub></b>			
	<b>C<sub>2</sub>H<sub>6</sub></b>			
	<b>CO</b>			
	<b>CO<sub>2</sub></b>			
	<b>SO<sub>2</sub></b>			
	<b>H<sub>2</sub>O</b>	12.6		
	<b>N<sub>2</sub></b>	1.0		
	<b>O<sub>2</sub></b>	7.45		
	<b>TOTAL</b>	100.00		
	<b>BTU/LB</b>	11,500		
	<b>BTU/CU FT AT</b>			
	<b>60 F, 30 IN. HG</b>			

**FUEL ANALYSIS**



EXHIBIT B



Lah No. 2000-00482-001  
 Date Rec'd. 4/04/2000  
 Date Sampled 3/31/2000 to 3/31/2000  
 Sampled By CLIENT

Page: 1 of 1  
 Date: 04/21/2000 08:48:25

Sample ID: 20000048201

TURRIS COAL COMPANY  
 P.O. BOX 21  
 ELKHART, IL 62634

P.O.# 652-8801

ATTN: TIM LAZOEN

Remark: TURRIS STOKER COAL 03/31/2000

		As		Dry				Weight %	
		Received		Basis		Received		As	Dry
<b>PROXIMATE ANALYSIS</b>									
% Moisture	D3302	16.68		*****					
% Ash	D3174	9.01		10.81					
% Volatile	D3175	34.03		40.84					
% Fixed Carbon	D3172	40.29		48.35					
BTU	D1989	10597		12719					
MAF-BTU	D1989		14261						
Total Sulfur	D4239	3.20		3.84					
<b>SULFUR FORMS</b>									
% Pyritic	D2492	1.30		1.56					
% Sulfate	D2492	0.02		0.02					
% Organic	D2492	1.88		2.26					
% Total Sulfur	D4239	3.20		3.84					
<b>WATER SOLUBLE</b>									
% Na2O	ASME1974	0.132		0.158					
% K2O	ASME1974	0.003		0.003					
% Chlorine	ASME1974	*****		*****					
Alkalies as Na2O	ASME197	0.22		0.26					
<b>FUSION TEMP. OF ASH D1857</b>									
F.D.		Reducing		Oxidizing					
H=1/2W		1955		2340					
Fluid		1970		2375					
		2000		2440					
		2205		2610					
<b>GRINDABILITY INDEX D409</b>									
GRIND INDEX UNCONDITIONED		59 @	2.15 % Moist.						
		***** @	***** % Moist.						
<b>FREE SWELLING INDEX D720</b>									
		2.5							
<b>Apparent Specific Gravity of Coal ModIC7113</b>									
		*****							
<b>Equilibrium Moisture D1412</b>									
		13.11							

		As		Dry				Weight %	
		Received		Basis		Received		As	Dry
<b>ULTIMATE ANALYSIS</b>									
% Moisture	D3302	16.68		*****					
% Carbon	D5373	58.47		70.18					
% Hydrogen	D5373	3.98		4.78					
% Nitrogen	D5373	1.05		1.26					
% Chlorine	D2361	0.21		0.25					
% Sulfur	D4239	3.20		3.84					
% Ash	D3174	9.01		10.81					
% Oxygen (Diff.)	D3176	7.40		8.88					
<b>MINERAL ANALYSIS D6349</b>									
% Ignited									
Phos. Pentoxide, P2O5				0.06					
Silica, SiO2				52.42					
Ferric Oxide, Fe2O3				21.40					
Alumina, Al2O3				13.78					
Titania, TiO2				0.74					
Lime, CaO				3.62					
Magnesia, MgO				0.55					
Sulfur Trioxide, SO3				3.76					
Potassium Oxide, K2O				1.34					
Sodium Oxide, Na2O				1.50					
Barium Oxide, BaO				0.03					
Strontium Oxide, SrO				0.03					
Manganese Dioxide, MnO2				0.06					
Undetermined				0.71					
Type of Ash	ASME1974			Bituminous					
Silica Value	ASME1974			67.21					
T250 Deg	B&W			2385					
Base/Acid Ratio	ASME1974			0.42					
lb Ash/mm BTU				*****					
lb SO2/mm BTU				6.03					
Fouling Index	ASME1974			0.63					
Slagging Index	ASME1974			1.61					

Respectfully Submitted,

*Al Merritt*

The analyses, opinions or interpretations contained in this report have been prepared at the client's direction, are based upon observation of materials provided by the client and express the best judgement of Standard Laboratories, Inc. Standard Laboratories, Inc. makes no other representation or warranty, expressed or implied, regarding this report. This Certificate of Analysis may not be reproduced except in full, without the written approval of Standard Laboratories, Inc. (Inventor)

Lab No. 2000-00482-001  
 Date Rec'd. 4/04/2000  
 Date Sampled 3/31/2000 to 3/31/2000  
 Sampled By CLIENT

Page: 1 of 1  
 Date: 04/18/2000 13:08:16

Sample ID: 20000048201

TURRIS COAL COMPANY  
 P.O. BOX 21  
 ELKHART, IL 62634

P.O.# 652-8801

ATTN: TIM LAZOEN

Remark: TURRIS STOKER COAL 03/31/2000

TRACE ELEMENT	DRY BASIS	RESULTS	METHOD
ANTIMONY	SB PPM	0.48	ASTM PS52 - GFAA
ARSENIC	AS PPM	1.6	ASTM PS52 - ICP-AES
BARIUM	BA PPM	23	ASTM PS52 - ICP-AES
BERYLLIUM	BE PPM	2.8	ASTM PS52 - ICP-AES
BORON	B PPM	NA	HCL BOMB - ICP-AES
BROMINE	BR PPM	NA	BOMB-ISE
CADMIUM	CD PPM	0.17	ASTM PS52 - GFAA
CHLORINE	CL PPM	NA	ASTM D2361-95 MOD
CHROMIUM	CR PPM	11	ASTM PS52 - ICP-AES
COBALT	CO PPM	2.4	ASTM PS52 - ICP-AES
COPPER	CU PPM	5	ASTM PS52 - ICP-AES
FLUORINE	F PPM	NA	ASTM D3761 - ISE
IRON	FE PPM	NA	ASTM PS52 - ICP-AES
LEAD	PB PPM	2	ASTM PS52 - ICP-AES
LITHIUM	LI PPM	4.2	ASTM PS52 - ICP-AES
MAGNESIUM	MG PPM	NA	ASTM PS52 - ICP-AES
MANGANESE	MN PPM	37	ASTM PS52 - ICP-AES
MERCURY	HG PPM	0.07	ASTM D3684-94 - FICVAA
MOLYBDENUM	MO PPM	3.2	ASTM PS52 - ICP-AES
NICKEL	NI PPM	7	ASTM PS52 - ICP-AES
SELENIUM	SE PPM	1.6	ASTM D3684 - GFAA
SILVER	AG PPM	0.06	ASTM PS52 - ICP-AES
STRONTIUM	SR PPM	23	ASTM PS52 - ICP-AES
THALLIUM	TL PPM	NA	ASTM PS52 - GFAA
TIN	SN PPM	0.4	ASTM PS52 - ICP-AES
URANIUM	U PPM	NA	ASTM PS52 - ICP-AES
VANADIUM	V PPM	19	ASTM PS52 - ICP-AES
ZINC	ZN PPM	13	ASTM PS52 - ICP-AES
ZIRCONIUM	ZR PPM	12.5	ASTM PS52 - ICP-AES

NA = NOT ANALYZED

Respectfully Submitted,




EXHIBIT C



**COMMERCIAL TESTING & ENGINEERING CO.**

GENERAL OFFICES: 1918 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARO, ILLINOIS 60148 • (312) 953-9300

Since 1928

Member of the SGS Group (Société Générale de Surveillance)

August 16, 1995

FREEMAN COAL SALES, INC.  
1999 WABASH AVENUE  
SUITE 200-C  
SPRINGFIELD IL 62704  
ATTN: CHUCK SMITH

PLEASE ADDRESS ALL CORRESPONDENCE  
P.O. BOX 752, HENDERSON, KY 42  
TELEPHONE: (502) 827-1  
FAX: (502) 828-0

Sample identification by  
Freeman Coal Sales

Crown III Mine  
Stoker  
Semi-Annual  
5 Day Composite  
1st Half 1995  
P. O. #F 910346  
Release #83-05184

Kind of sample Coal  
reported to us

Sample taken at Crown III Mine

Sample taken by Freeman Coal Sales

Date sampled -----

Date received July 31, 1995

Post-it® Fax Note	7671	Date	7/31/95	# of pages	2
To	Dandancy	From	Lisa Duffey		
Co./Dept	Hot I	Co.	Freeman Coal Sales		
Phone #		Phone #			
Fax #		Fax #			

**Analysis Report**

PROXIMATE ANALYSIS

As Received    Dry Basis

% Moisture	13.86	XXXXX
% Ash	8.42	9.77
% Volatile	36.82	42.75
% Fixed Carbon	40.90	47.48
	100.00	100.00
Btu/lb	11074	12856
% Sulfur	3.43	3.98
NAF Btu		14248
Alk. as Sodium Oxide	0.27	0.31

ULTIMATE ANALYSIS

As Received    Dry Basis

% Moisture	13.86	XXXXX
% Carbon	60.63	70.38
% Hydrogen	4.42	5.13
% Nitrogen	0.99	1.15
% Sulfur	3.43	3.98
% Ash	8.42	9.77
% Oxygen(diff)	8.25	9.59
	100.00	100.00
% Chlorine	0.09	0.10

FORMS OF SULFUR

% Pyritic	0.96	1.11
% Sulfate	0.01	0.01
% Organic(diff)	2.46	2.86

WATER SOLUBLE ALK.

% Sodium oxide	0.093	0.108
% Potassium oxide	0.003	0.004

% EQUILIBRIUM MOISTURE = 13.8  
FREE SWELLING INDEX = 3.0

FUSION TEMPERATURE OF ASH, (°F)

	<u>Reducing</u>	<u>Oxidizing</u>
Initial Deformation (IT)	1990	2330
Softening (ST)	2080	2390
→ Hemispherical (HT)	2140	2420
Fluid (FT)	2280	2490

Respectfully submitted,

COMMERCIAL TESTING & ENGINEERING CO. KB

*Lisa Duffey*  
Manager, Henderson Laboratory



**COMMERCIAL TESTING & ENGINEERING CO.**

GENERAL OFFICES: 1919 SOUTH HIGHLAND AVE., SUITE 210-B, LOMBARD, ILLINOIS 60148 • (312) 953-8300

SINCE 1898

Member of the SGS Group (Société Générale de Surveillance)

August 16, 1995

PLEASE ADDRESS ALL CORRESPONDENCE TO:  
P.O. BOX 752, HENDERSON, KY 424  
TELEPHONE: (502) 827-1111  
FAX: (502) 826-07

FREEMAN COAL SALES, INC.  
1999 WABASH AVENUE  
SUITE 200-C  
SPRINGFIELD IL 62704  
ATTN: CHUCK SMITH

Sample identification by  
Freeman Coal Sales

Crown III Mine  
Stoker  
Semi-Annual  
5 Day Composite  
1st Half 1995  
P. O. #F 910346  
Release #83-05184

Kind of sample Coal  
reported to us

Sample taken at Crown III Mine

Sample taken by Freeman Coal Sales

Date sampled -----

Date received July 31, 1995

Analysis Report No. 63-88548

ANALYSIS OF ASH

WEIGHT %, IGNITED BASIS

Silicon dioxide	52.80
Aluminum oxide	18.02
Titanium dioxide	0.88
Iron oxide	17.00
Calcium oxide	2.76
Magnesium oxide	0.78
Potassium oxide	3.27
Sodium oxide	1.72
Sulfur trioxide	3.01
Phosphorus pentoxide	0.16
Strontium oxide	0.03
Barium oxide	0.08
Manganese oxide	0.05
Undetermined	0.44
	<u>100.00</u>

Silica Value = 71.99  
Base:Acid Ratio = 0.34  
T<sub>850</sub> Temperature = 2489 °F

Type of Ash = BITUMINOUS  
Fouling Index = 0.58  
Slagging Index = 1.35

Respectfully submitted,  
COMMERCIAL TESTING & ENGINEERING CO.

Manager, Henderson Laboratory