



3. Copper concentrations at the raw water intake to the water treatment plant shall not exceed 1.0 mg/l at any time.
4. Copper concentrations in the reservoir shall be measured before and after each treatment with copper sulfate and the results reported to the Agency on a monthly basis.

IT IS SO ORDERED.

Mr. Odell abstains.

I, Christan L. Moffett, Clerk of the Illinois Pollution Control Board, hereby certify the above Opinion and Order were adopted on the 6<sup>th</sup> day of September, 1973 by a vote of

3-0

  
\_\_\_\_\_  
Christan L. Moffett, Clerk  
Illinois Pollution Control Board