



Amy  
 Hanrahan/Bolingbrook/EMG/  
 EIX  
 04/09/2013 03:45 PM

To William Gaynor/Powerton/EMG/EIX@EME  
 Christopher Lux/Waukegan/EMG/EIX@EME, Jeffrey  
 Kickert/Powerton/EMG/EIX@EME, Joseph  
 Heredia/Powerton/EMG/EIX@EME, Mark  
 bcc  
 Subject Re: Powerton Secondary Ash Basin Future Cleaning

Periodic cleaning is an ongoing requirement of the CCA, we will need to come up with a way to clean it out on an ongoing basis

Amy Hanrahan  
 Midwest Generation  
 Edison Mission Energy  
  
 Office 630.771.7863  
 Cell 630.335.5694  
 Fax 949.225.0813

William Gaynor Amy, In the future will Powerton be required to cl... 04/09/2013 03:42:22 PM

From: William Gaynor/Powerton/EMG/EIX  
 To: Amy Hanrahan/Bolingbrook/EMG/EIX@EME  
 Cc: Christopher Lux/Waukegan/EMG/EIX@EME, Joseph\_Heredia/Powerton/EMG/EIX, Mark  
 Kelly/Powerton/EMG/EIX@EME, Jeffrey Kickert/Powerton/EMG/EIX@EME  
 Date: 04/09/2013 03:42 PM  
 Subject: Powerton Secondary Ash Basin Future Cleaning

Amy,

In the future will Powerton be required to clean the Secondary Ash Basin? If we do have to clean the basin periodically in the future, NRT expressed concern about the water infiltration we are currently experiencing. The concern is about possibility of the new liner floating up from the bottom and becoming damage during cleaning. NRT is suggesting that we consider installing a warning layer, if periodic clean is mandated. The cost of installing a warning layer is estimated between \$100,000 to \$150,000.

Thanks,  
 Bill

Bill Gaynor  
 Station Project Manager  
 Powerton Generating Station  
 13082 East Manito Road  
 Pekin, IL 61554-8587  
 Office: 309.477.5437  
 Cell: 309.824.2999  
 wgaynor@mwgen.com