

Richmond, Maria

From: Maddox, Rebecca
Sent: Wednesday, July 28, 2010 11:27 AM
To: CN=Raymond Wolan/OU=WillCounty/OU=EMG/O=EIX@EME
Cc: Miller, Daryl
Subject: Re: ponds

Categories: Folder: Rebecca Maddox ARCHIVED\~SENT

Thanks Ray for looking into the ponds. That was my fear as well that the water on the east end of the pond was getting close to the edge. I don't want them to start removing material today because I want to discuss with everyone and see with my own eyes. Gary Schweers left me a message so I will call him back and see if I can meet him at the ponds tomorrow to discuss. If they want to start moving material around in 3S that's fine, but I don't want anything removed to dewater. But here are my thoughts:

1. They can put the material they can get out of 2S and put it in the area south of the contractor parking lot. We used that area last year to dewater the material from 3S. The water from that should make its way eventually to the south area runoff but I need to review some flow path drawings tomorrow. We would need to have them install silt fencing around the material since I have a feeling that material will be there for a while until it dewateres - like it was last year.

2. We have to make repairs on 2S weir before the pond goes back into service. We need to get the area around the weir cleaned enough so Mabco can get in there and make the repairs to the steel. This was a budgeted project that needs to get completed before 2S goes back into service. There are numerous breaks within the weir that is compromising the effectiveness of it.

3. LaFarge is well aware of the liner in 3S and this was discussed last year. I'll have to talk with Marge on this but they should be able to clean it out with equipment that they currently have without damaging the liner. This has been a bone of contention w/ them on how they were going to clean this out.

I'll be back tomorrow and we can discuss.

Beckie Maddox
Environmental Specialist
Will County Station
815-372-4589 - office
815-355-5819 - cell

This transmittal contains privileged and confidential information belonging to the sender. This information is intended only for use of the individual or entity named above. If the reader of this message is not the intended recipient or the employee or agent responsible for delivering the message to the intended recipient, you are hereby notified that any disclosure, dissemination, copying, or distribution of this communication is strictly prohibited.

Raymond
Wolan/WillCounty/EMG/EIX
07/28/2010 11:05 AM

To Rebecca Maddox/WillCounty/EMG/EIX@EME, Daryl
Miller/WillCounty/MWGEN@EME
cc
Subject ponds

2 South pond is not empty yet and it has a couple feet of water back in it. 3 South pond is over filled to the point the water and material is running to the east and we are only about 8" from overflowing the pond on the east side.

here is what mineral solutions would like to do, 1. rent a wide track machine to get on the 3 S Pond so they can cut a trench to the SW corner and bide some time the 2s pond to get it emptied. Beckie they want take the material from 2s pond and pile it on our property until it dewater, then we can have 2s pond back. they are telling me they don't have a machine to be able to clean 3S pond so I don't know what we will do if they can't empty that pond.