

ILLINOIS POLLUTION CONTROL BOARD
July 8, 2021

MIDWEST GENERATION, LLC,)	
)	
Petitioner,)	
)	
v.)	PCB 20-38
)	PCB 20-39
ILLINOIS ENVIRONMENTAL)	(Thermal Demonstration)
PROTECTION AGENCY,)	(Consolidated)
)	
Respondent.)	

OPINION AND ORDER OF THE BOARD (by C.M. Santos):

This case concerns discharges to the Upper Dresden Island Pool of the Lower Des Plaines River from two electric generating facilities located in Joliet, Will County, and owned by Midwest Generation, LLC - Joliet 9 Generating Station (Joliet 9) and Joliet 29 Generating Station (Joliet 29) (collectively, Stations). The Stations, which are located near one another on opposite banks of the Upper Dresden Island Pool, withdraw water to cool and condense steam from the generating process before discharging wastewater under a National Pollutant Discharge Elimination System permit issued by the Illinois Environmental Protection Agency.

On December 30, 2019, Midwest Generation, LLC filed two petitions for relief from thermal effluent limitations based on the Board’s water quality standards for temperature in 35 Ill. Adm. Code 302.408(c)-(h), (i) and 302.211(b)-(d). The first petition addresses discharges from Joliet 9, and the second from Joliet 29. Midwest Generation, LLC requests “alternative thermal effluent limitations” as allowed under the federal Clean Water Act (33 U.S.C. § 1326(a)) and Board regulations (35 Ill. Adm. Code 106.1100 – 106.1180, 304.141(c)).

Based on the record before it, the Board finds that the demonstrations satisfy the legal standards for the requested relief. First, the proposed alternative thermal effluent limitations will assure the protection and propagation of a balanced indigenous community of shellfish, fish, and wildlife in and on the UDIP near Joliet 9 and Joliet 29, and the Des Plaines River extending five miles downstream from the I-55 Bridge. Second, for the discharges from Joliet 9 and Joliet 29, the applicable thermal effluent limitations are more stringent than necessary to assure the protection and propagation of that community. Therefore, the Board grants Midwest Generation, LLC alternative thermal effluent limitations. The Board directs the Illinois Environmental Protection Agency to include these alternative thermal effluent limitations in the NPDES permits for Joliet 9 and Joliet 29.

GUIDE TO THE BOARD’S OPINION

Below, the Board first lists abbreviations and acronyms used in this opinion at pages 2-4. It then provides the procedural background at pages 4-7, followed by the factual background at

pages 7-40. Next, the Board addresses the legal background relevant to Midwest Generation, LLC's request, including statutory and regulatory authorities, at pages 40-42. The Board then presents the temperature water quality standards at pages 42-46, the proposed alternative thermal effluent limitations at pages 47-58, and the burden of proof at page 58.

The opinion then turns to the Board's discussion, which is divided between two primary issues. First, the opinion at pages 58-126 addresses whether Midwest Generation, LLC has demonstrated that its proposed alternative thermal effluent limitations will assure the protection and propagation of balanced, indigenous communities. In this first part of the discussion, the Board:

- Summarizes Master Rationale at page 60;
- Reviews biotic categories at pages 60-81;
- Reviews retrospective demonstration at pages 81-84;
- Reviews predictive demonstration at pages 84-90;
- Analyzes biotic category criteria at pages 90-122; and
- Analyzes Master Rationale at pages 122-26.

In these sections, the Board's analysis is based on draft guidance for demonstrations under Section 316(a) of the Clean Water Act (33 U.S.C. § 1326(a)). This guidance, prepared by the United States Environmental Protection Agency, is entitled Interagency 316(a) Technical Guidance Manual and Guide for Thermal Effects Section of Nuclear Facilities Environmental Impact Statements (DRAFT), May 1, 1977. Midwest Generation, LLC requests relief under authorities including Section 316(a) of the Clean Water Act. The Board also considers the guidance as a useful and instructive guide to analyzing the petition. *See* 35 Ill. Adm. Code 106.1120(e).

In the second part of its discussion at pages 126-29, the Board addresses whether Midwest Generation, LLC has demonstrated that the effluent limitations based on the applicable thermal water quality standards are more stringent than necessary. This discussion includes the Board's analysis of:

- Numeric temperature water quality standards under Section 302.408(h) at pages 126-27;
- "Excursion" hours under Section 302.408(f) at pages 127-28;
- Minimum zone of passage left by the thermal mixing zone under Section 302.102(b)(8) at page 128; and
- Narrative temperature water quality standards of Sections 302.408(c), (d), and (e) at pages 128-29.

The Board then reaches its conclusions at pages 129-30 and issues its order at pages 130-32.

ABBREVIATIONS AND ACRONYMS USED IN THIS OPINION

ACRCC

Asian Carp Regional Coordination Committee

AEL	Alternate Effluent Limits
ANS	Aquatic Nuisance Species
ATEL	Alternative Thermal Effluent Limits
BIC	Balanced Indigenous Community
CAWS	Chicago Area Waterway System
cfs	cubic feet per second
cfu	colony forming unit
CSO	Combined Sewer Overflow
CSSC	Chicago Sanitary and Ship Canal
CTM	Critical Thermal Maximum
CWA	Clean Water Act
DAF	Design Average Flow
DELT	Deformities, Erosions, Lesions, Tumors
DO	Dissolved Oxygen
DSP	Detailed Study Plan
EA	EA Engineering, Science, and Technology, Inc. (before December 12, 2014) and EA Engineering, Science, and Technology, Inc., PBC (on and after December 12, 2014)
EAV	Emergent Aquatic Vegetation
EPA	Environmental Protection Agency
EPT	Ephemeroptera (mayflies), Plecoptera (stoneflies), and Trichoptera (caddisflies)
Five-Mile Stretch	Portion of the Lower Des Plaines River between the I-55 Bridge and Kankakee River Confluence
GLMRIS	Great Lakes and Mississippi River Interbasin Study
IDNR	Illinois Department of Natural Resources
IEPA	Illinois Environmental Protection Agency
INHS	Illinois Natural History Survey
IWBmod	Modified Index of Well-Being
LDB	Left Descending Bank
LDPR	Lower Des Plaines River
MG or MWG	Midwest Generation, LLC
MGD	Million Gallons per Day
MIKE3	Three-Dimensional Thermodynamic Mathematical Model
MW	Megawatt
MWAT	Maximum Weekly Average Temperature
MWRDGC	Metropolitan Water Reclamation District of Greater Chicago
NPDES	National Pollutant Discharge Elimination System
PAH	Polycyclic Aromatic Hydrocarbon
PCB	Polychlorinated biphenyls
POTW	Publicly-Owned Treatment Works
QHEI	Qualitative Habitat Evaluation Index
RDB	Right Descending Bank
RIS	Representative Important Species
RM	River Mile
SAV	Submerged Aquatic Vegetation

TLWQS	Time-Limited Water Quality Standard
TOC	Total Organic Carbon
TSS	Total Suspended Solids
UAA	Use Attainability Analysis
UDIP	Upper Dresden Island Pool
UIW	Upper Illinois Waterway
USACE	U.S. Army Corps of Engineers
USEPA	United States Environmental Protection Agency
USEPA 316(a) Manual	<u>Interagency 316(a) Technical Guidance Manual and Guide for Thermal Effects Section of Nuclear Facilities Environmental Impact Statements (DRAFT), May 1, 1977</u>
USGS	United States Geological Survey
Wr	Relative Weight
Ws	Standard Weight
ZOP	Zone of Passage

PROCEDURAL BACKGROUND

Pre-Petition Communications

Early Screening Information

Before filing a petition for ATELS, a petitioner must submit early screening information to IEPA. 35 Ill. Adm. Code 106.1115(a). Within 30 days after submitting the information, the petitioner must consult with IEPA on that information. 35 Ill. Adm. Code 106.1115(b).

Within six months after the Board adopted regulations for alternate thermal standards, MG completed early screening. Pet. at 4, citing 35 Ill. Adm. Code 106.1115; *see* Procedural Rules for Alternative Thermal Effluent Limitations under Section 316(a) of the Clean Water Act: Proposed New Ill. Adm. Code Part 106, Subpart K and Amended Section 304.141(c), R 13-20 (Feb. 20, 2014) (adopting Subpart K regulations for ATELS).

Detailed Study Plan (DSP)

“Within 60 days after the early screening information is submitted under Section 106.1115, the petitioner must submit to the Agency a detailed plan of study that the petitioner will undertake to support its alternative thermal effluent limitation demonstration.” 35 Ill. Adm. Code 106.1120(a).

MG submitted to IEPA and IDNR a DSP dated December 3, 2015, for the two stations. Pet. at 4, 15, citing 35 Ill. Adm. Code 106.1120; Exh. A at 1-2; *see* Exhs. D, E. In a letter dated March 3, 2016, IEPA approved the DSPs from MG. Pet. at 4, 15, citing Exh. A at 1-2, Exh. B; *see* 35 Ill. Adm. Code 106.1120(f) (90-day response deadline); Rec. at 10.

In an email dated March 7, 2016, IDNR “raised questions regarding the plan.” Pet. at 15; *see* Exh. C at 2-3. MG and IDNR discussed these questions on April 19, 2016. Pet. at 15. MG

responded to IDNR's comments on June 7, 2016. Exh. C1. In an email dated June 8, 2016, IDNR responded that "[w]e have no further concerns and look forward to the study results and opportunity for further comment in the 316(a) process." Exh. C at 1; *see* Exh. A at 1-2.

The DSPs included sampling the Stations' receiving waters during calendar years 2016, 2017, and 2018. Pet. at 4; *see* Pet. at 10. MG states that the DSPs extend over a longer period of time than similar studies because the Stations converted from coal to natural gas and to operate only during peak electrical demand. Pet. at 4-5, citing Exh. D at 25; Exh. E at 25.

Completed Demonstration

MG provided IEPA a draft of its demonstration report on October 3, 2019. Pet. at 16. MG addressed and incorporated into its final demonstration all comments received from IEPA. *Id.*; *see* Exh. A.

MG provided a copy of the revised demonstration to USEPA. Pet. at 6. As of the December 30, 2019 date on which MG filed its petitions with the Board, USEPA had not provided comments or questions. *Id.*

The Board asked MG whether USEPA had later responded. If MG received a written response, the Board asked MG to submit it into the record. Board Questions at 1. MG responded that it had had no contact with USEPA since filing its petition. MG Resps. at 4.

Petition to the Board

On December 30, 2019, MG filed two petitions for ATELS, one for Joliet 9 and one for Joliet 29. *See* 35 Ill. Adm. Code 106.1125.

The following documents accompanied MG's petitions:

- Exhibit A: Joliet Generating Stations 9 and 29 § 316(a) Demonstration
 - Appendix A: Description of the Lower Des Plaines River
 - Exhibit A-1: Joliet Station 9 NPDES Permit IL 0002216
 - Exhibit A-2: Joliet Station 29 NPDES Permit IL 0064254
 - Appendix B: Information Supporting Representative Important Species Rationale: Biothermal Assessment Predictive Demonstration
 - Appendix C: Information Supporting Biotic Category Rationales: Protection of Balanced Indigenous Community – Retrospective Demonstration
 - Appendix D: Station Operations and Hydrothermal Analysis
 - Exhibit D-1a: Description of the Joliet Station 9 and 29 Near-Field Thermal Compliance Models
 - Exhibit D-1b: Description of the Joliet Station 9 and 29 Far-Field (I-55) Thermal Compliance Model
 - Exhibit D-2a: Downstream Discharge Thermal Compliance Assessment
 - Exhibit D-2b: Downstream Discharger Thermal Compliance Modeling Assessment

- Appendix E: Data Collection Programs
 Appendix F: 2016 Upper Illinois Waterway Fisheries Investigation RM 274.4-296.0
 Appendix G: 2017 Upper Illinois Waterway Fisheries Investigation RM 274.4-296.0
 Appendix H: 2018 Upper Illinois Waterway Fisheries Investigation RM 274.4-296.0
 Appendix I: Previously Conducted Joliet Station 9 and 29 Thermal Plume Surveys and Associated Documentation
 Appendix J: Summary of Upper Dresden Island Pool Fisheries Data Collected Following Operational Changes at Joliet Stations 9 and 29, 2017-2018
 Appendix K: Habitat and Submerged Aquatic Vegetation (SAV) Survey of the Lower Des Plaines River Joliet, IL
 Appendix L: 2017-2018 Benthic Macroinvertebrate Assessment of the Des Plaines River Joliet, IL
- Exhibit B: Correspondence from IEPA to MG dated March 3, 2016
 Exhibit C: Email correspondence from IDNR
 Exhibit C1: IDNR response dated June 7, 2016
 Exhibit D: Detailed Study Plan for § 316(a) Demonstration to Support Application for Alternative Thermal Limits at the Joliet #9 Generating Station
 Exhibit E: Detailed Study Plan for § 316(a) Demonstration to Support Application for Alternative Thermal Limits at the Joliet #29 Generating Station
 Exhibit F: IEPA Construction Permit for Joliet #29 issued May 9, 2017
 Exhibit G: History of Plant Shutdowns (Units 6, 7, 8)
 Exhibit H: Planned and Projected Shutdowns (Units 6, 7, 8)
 Exhibit I: Modification of NPDES Permit No. IL0064254 dated February 19, 2016 (Joliet #29)
 Exhibit J: NPDES Permit No. IL0002216 issued September 30, 2014 (Joliet #9)

Notice of Filing and Hearing

“Within 14 days after the filing of the petition, the petitioner must publish notice of the filing of the petition by advertisement in a newspaper of general circulation in the county where the facility is located.” 35 Ill. Adm. Code 106.1135(a). The notice must state that “[a]ny person may cause a public hearing to be held in the above-described proceeding by filing a hearing request with the Illinois Pollution Control Board within 21 days after the date of the publication of this notice.” 35 Ill. Adm. Code 106.1135(b).

“Within 30 days after the filing of the petition, the petitioner must file a certificate of publication with the Clerk of the Board.” 35 Ill. Adm. Code 106.1140. On January 23, 2020, MG filed two certificates of publication stating that *The Herald-News* of Joliet published notices of filing the petitions on January 9, 2020. The Board did not receive a request to hold a hearing.

On February 6, 2020, the Board accepted MG’s petitions. In its order, the Board stated that it had “not determined whether it will hold a hearing.” *See* 35 Ill. Adm. Code 106.1155(a).

In the same order, the Board found that “consolidating these two proceedings serves ‘the interest of convenient, expeditious, and complete determination of claims’ and will not result in material prejudice to any party.” *See* 35 Ill. Adm. Code 104.406; Gautschy’s Corner v. IEPA,

PCB 18-56, 18-60 (cons.) (Feb. 8, 2018). On its own motion, the Board consolidated the two proceedings for hearing.

IEPA Recommendation

IEPA's recommendation was due 45 days after filing the petition by February 13, 2020. Midwest Generation, LLC v. IEPA, PCB 20-38, 20-39, slip op. at 1 ((Feb. 6, 2020), citing 35 Ill. Adm. Code 106.1145. On February 13, 2020, IEPA filed a motion to extend its deadline to March 30, 2020. On February 18, 2020, the hearing officer granted the motion. On March 30, 2020, IEPA filed a motion to extend its deadline to April 30, 2020. On the same date, the hearing officer granted the motion.

On April 29, 2020, IEPA filed its recommendation (IEPA Rec.) that the Board grant the requested ATEs for discharges from both Joliet Station 9 and Joliet Station 29 subject to certain conditions. On May 20, 2020, the Board received responses to the recommendation from MG (MG Resp.), ExxonMobil Oil Corporation (ExxonMobil) (ExxonMobil Resp.), and INEOS Joliet, Inc. (INEOS) (INEOS Resp.).

On June 3, 2020, IEPA filed a motion for leave to file a reply, which included its reply (IEPA Reply). On June 25, 2020, the hearing officer granted the motion.

Board Questions to MG

In its order accepting the petitions for hearing, the Board stated that it had "not determined whether the contents of the petition are sufficient." *See* 35 Ill. Adm. Code 106.1155(a). The Board added that it "may submit questions to MG through a Board or hearing officer order."

Through a hearing officer order on August 10, 2020, the Board requested responses to 15 questions, with one directed to IEPA (Board Questions). On September 9, 2020, the Board received responses from both MG (MG Resps.) and IEPA (IEPA Resps.).

FACTUAL BACKGROUND

Location of Stations

Joliet 9 (Unit 6) is located at 1601 South Patterson Road in Joliet on the eastern bank of the UDIP at RM 284.9. Exh. A at 2-1; App. A at A-1; App. C at C-2; App. D at D-1; *see* App. A, Figure A-2.

Joliet 29 (Units 7 & 8) is located 1800 Channahon Road in Joliet on the western bank of the UDIP at RM 284.6. Exh. A at 2-1; App. A at A-1; App. C at C-2; App. D at D-1; *see* App. A, Figure A-2.

Generating Capacity and Fuel Used

Joliet 9

“Joliet 9 (Unit 6) is a single-unit gas-fired steam electric generating facility.” Pet. at 8. In 1965, it began service as a coal-fired station. In 2016, it converted to natural gas. *Id.*; see App. A at A-1; App. C at C-3; App. D at D-1, D-3. Conversion did not change the Station’s original design output of 341 MW. Pet. at 8; see Exh. A at 2-3; App. D at D-1; see also 35 Ill. Adm. Code 106.1130(a)(1), (2).

Joliet 29

“Joliet 29 (Units 7 & 8) is a two-unit gas-fired steam electric generating facility.” Pet. at 8. Unit 7 began commercial service in 1965 and Unit 8 in 1966. *Id.* Both began service as a coal-fired station but were converted in 2016 to natural gas. *Id.*; see App. A at A-1; App. C at C-3; App. D at D-1, D-3. Conversion did not change the Station’s original design output of 1,150 MW, 572 MW for Unit 7 and 578 MW for Unit 8. Pet. at 8; see Exh. A at 2-4; App. D at D-1; see also 35 Ill. Adm. Code 106.1130(a)(1), (2).

Load Factor

MG notes that the three units at Joliet 9 and 29 have capacity to produce approximately 140 mmBtu/year. Pet. at 9, n.8; see Exh. F at 6 (construction permit). However, MG states that its permit restricts the three units at the Stations to about 70 million MMBtu/year. Pet. at 9. MG adds that, to comply with its permit, it “must run them on a capacity factor of 50% or below.” *Id.*

Joliet 9

For the last four years, the load factor of Joliet 9 (Unit 6) has been 49 percent in 2015, 8.4 percent in 2016, 1.7 percent in 2017, and 0.2 percent in 2018. Pet. at 9. For the first 11 months of 2019, the load factor was 0.1 percent. *Id.*, n.7; see 35 Ill. Adm. Code 106.1130(a)(4).

For the next five years, MG projects the following load factor of Joliet 9 (Unit 6): 5.5 percent in 2020, 2.9 percent in 2021, 1.3 percent in 2022, 0.5 percent in 2023, and 0.2 percent in 2024. Pet. at 9; see 35 Ill. Adm. Code 106.1130(a)(5).

Joliet 29

For the last four years, the load factor of Joliet 29 (Unit 7) has been 58 percent in 2015, 22 percent in 2016, 4.3 percent in 2017, and 6.4 percent in 2018. Pet. at 9. For the first 11 months of 2019, the load factor was 16 percent. *Id.*, n.7; see 35 Ill. Adm. Code 106.1130(a)(4).

For the last four years, the load factor of Joliet 29 (Unit 8) has been 58 percent in 2015, 12 percent in 2016, 2.5 percent in 2017, and 6.8 percent in 2018. Pet. at 9. For the first 11 months of 2019, the load factor was 16 percent. *Id.*, n.7; see 35 Ill. Adm. Code 106.1130(a)(4).

For the next five years, MG projects the following load factor of Joliet 29 (Unit 7): 20 percent in 2020, 16 percent in 2021, 10 percent in 2022, 5 percent in 2023, and 5 percent in 2024. Pet. at 9; *see* 35 Ill. Adm. Code 106.1130(a)(5).

For the next five years, MG projects the following load factor of Joliet 29 (Unit 8): 19 percent in 2020, 13 percent in 2021, 6 percent in 2022, 3 percent in 2023, and 3 percent in 2024. Pet. at 9; *see* 35 Ill. Adm. Code 106.1130(a)(5).

Estimated Retirement

Joliet 9

For Joliet 9, MG estimates a retirement date of 2030. Pet. at 10. The Board asked whether MG plans to replace it at that time. Board Questions at 1, citing 35 Ill. Adm. Code 106.1130(a)(6). MG responded that, “[w]hile market conditions will be evaluated closer to 2030, there is not current plan to replace Joliet 9 with an additional unit upon Joliet 9’s retirement.” MG Resps. at 1.

Joliet 29

MG clarified that it leases Unit 7 and 8 from another company and does not own them. Pet. at 10. It stated that the lease expires in 2030 and that it “is unable to speculate whether the units would be in operation beyond that date.” *Id.*; *see* 35 Ill. Adm. Code 106.1130(a)(6).

Shutdowns

Joliet 9

Between March 14, 2015, and October 2, 2019, MG reports that Unit 6 experienced 12 emergency shutdowns totaling 28 days. Exh. G at 1. It also reports 12 planned shutdowns totaling 240 days. *Id.*; *see* 35 Ill. Adm. Code 106.1130(a)(7), (8). MG emphasizes that these totals do not include days on which the unit was available “but did not operate due to market conditions.” Pet. at 10.

Between January 25, 2020, and November 5, 2023, MG plans or projects four shutdowns totaling 117 days for Unit 6. Exh. H; *see* 35 Ill. Adm. Code 106.1130(a)(9). MG emphasizes that this total does not include days on which the unit will be available “but will not operate due to market conditions.” Pet. at 10.

Joliet 29

Between January 9, 2015 and November 22, 2019, MG reports that Unit 7 experienced nine emergency shutdowns totaling 20 days. Exh. G at 2. It also reports 25 planned shutdowns totaling 238 days. *Id.*; *see* 35 Ill. Adm. Code 106.1130(a)(7), (8).

Between February 28, 2015 and November 22, 2019, MG reports that Unit 8 experienced eight emergency shutdowns totaling 26 days. Exh. G at 3. It also reports 15 planned shutdowns totaling 208 days. *Id.*; see 35 Ill. Adm. Code 106.1130(a)(7), (8). MG emphasizes that these totals do not include days on which the units were available “but did not operate due to market conditions.” Pet. at 10.

Between March 16, 2020, and December 10, 2023, MG plans or projects five shutdowns totaling 218 days for Unit 7. Exh. H; see 35 Ill. Adm. Code 106.1130(a)(9).

Between February 3, 2020, and November 15, 2023, MG plans or projects four shutdowns totaling 87 days for Unit 8. Exh. H; see 35 Ill. Adm. Code 106.1130(a)(9). MG emphasizes that these totals do not include days on which the units will be available “but will not operate due to market conditions.” Pet. at 10.

Cooling System and Heat Dissipation

Joliet 9

Joliet 9 operates in open-cycle cooling mode and uses a once-through circulating water system for condenser cooling. Pet. at 10; App. D at D-5; see 35 Ill. Adm. Code 106.113-(b)(1). Two circulating water pumps and two low-pressure service water pumps withdraw cooling water from the UDIP through a single intake structure. Pet. at 10; App. D at D-5. Joliet 9 withdraws cooling water at a design rate of approximately 375 MGD. Pet. at 10; see Exh. A at 2-3; App. A at A-1; Exh. C at C-2; Exh. D at D-1, D-3, D-5; Rec. at 2.

MG reports that “[t]here is a partially submerged sunken barge located at the face of the Station’s cooling water intake structure.” The barge protects the system’s intake from blockage caused by barge tows waiting to traverse an upstream dam, and the barge also prevents debris from entering. Pet. at 10. The station’s screenhouse includes “two 10-ft wide traveling screens in each of two bays, with one bay for each circulating water pump. . . . Screen wash from the traveling screens flows into one trash basket.” App. D at D-5. Bar racks in front of the traveling screens prevent large debris from entering.

The Station discharges circulating water to the UDIP through a discharge canal. Pet. at 11; Exh. A at 2-3. The Station maintains condenser tubes through dehumidification, which “involves isolating and drying individual intake water boxes with residual heat.” Pet. at 11. The Station “does not have any supplemental cooling systems.” *Id.*; see App. D at D-6 – D-7.

Joliet 9 discharges wastewater according to its NPDES permit. Pet. at 11, citing Exh. I. The permit designates thermal discharge as Outfall 001. Pet. at 11; see Exh. I at 2.

Joliet 29

Joliet 29 operates in open-cycle cooling mode. Pet. at 11; Exh. A. at 2-4. The station withdraws cooling water through a single structure at the head of an intake canal, the mouth of which is “equipped with a fixed boom structure to deflect large floating debris.” Pet. at 11. “The

combined design flow rate for both Joliet 29 units is 1,325 MGD, based on the operation of four circulating water pumps and four service water pumps.” *Id.*; *see* Pet. at 11; Rec. at 2; App. A at A-1; App. C at C-2; App. D at D-1, D-3, D-5.

The Station discharges circulating water to the UDIP through a discharge canal. Pet. at 11; Exh. A at 2-4. Under its permit, the station maintains condenser tubes “through the use of chlorination/dechlorination to prevent biofouling.” Exh. A at 2-4. The station has recently also used dehumidification. *Id.*; App. D at D-4

“Joliet 29 is equipped with 24 supplemental cooling towers, which were installed in 1999.” Pet. at 11; Exh. A at 2-4; App. D at D-3. Tower pumps withdraw water from the discharge canal for cooling before returning it to the canal. Pet. at 11. The towers are designed to cool approximately one-third of the station’s total design discharge flow, so they are considered “helper” towers and not a closed-cycle cooling system. *Id.*; *see* 35 Ill. Adm. Code 106.1130(b)(1). “The purpose of the helper towers is to minimize potential thermal impacts to the river ecosystem” and maintain compliance with thermal standards while maintaining MG’s ability to generate power during warm weather demand. Pet. at 11-12; Exh. A at 2-4; App. D at D-3 – D-4, D-7 – D-8.

Joliet 29 discharges wastewater according to its NPDES permit. Pet. at 12, citing Exh. J. The permit designates the thermal discharge as Outfall 001. Pet. at 12; *see* Exh. J at 2; App. D at D-4.

Thermal Compliance History

MG reports that “[e]ach of the Joliet Stations has complied with the existing thermal discharge limitations and conditions in their respective NPDES Permits for the last five years.” Pet. at 14, citing Exh. I at 11-12, Exh. J at 11 (permits); *see* 35 Ill. Adm. Code 106.1130(c).

Thermal Plume Mapping

Station Operation and Discharge

The Stations most recently conducted thermal plume mapping in 2017. Field studies included one summer survey in July 2017 and two winter surveys in February and December 2017. App. D at D-14. The data obtained developed a site-specific three-dimensional model to examine the Stations’ thermal plumes under various operating and meteorological conditions. *Id.*, citing App. B.

Mapping used hourly station operating data from 2012 to 2017, which includes both earlier base load operating conditions and current peaking operation. App. D at D-14. Data employed in the mapping includes monthly frequency distributions of intake and discharge temperatures for summer (Tables D-1a, D-1b), winter (Tables D-1c, D-1d), and transitional months (Tables D-1e, D-1f). Data also included monthly frequency distributions for discharge flow and power production for summer (Tables D-2a, D-2b), winter (Tables D-2c, D-2d) and transitional months (Tables D-2e, D-2f).

Summer.

Joliet 9. Because Unit 6 at Joliet 9 does not have supplemental cooling, it has regularly been derated to comply with thermal limits under AS 96-10 at the I-55 Bridge. App D at D-14. Derating Joliet 9 allows Joliet 29 to comply at higher operating levels by using its supplemental cooling towers. *Id.* at D-14 – D-15. Summer discharge temperatures are lower than if Joliet 9 operated at consistently high levels. *Id.* at D-15.

The demonstration argues that Joliet 9 discharge data represent “measured end-of-pipe temperatures and therefore provide conservative estimates of compliance point temperatures under most conditions.” App. D at D-14.

Discharge Temperatures. For 2012-2017, mean summer discharge temperatures were all below 90 °F with highest monthly means in July and August. App. D at D-15, citing Table D-1a; *see* Pet. at 12.

In July, median discharge temperatures were 84.6°F with upper 10th percentile temperatures at or above 92.9 °F. App. D at D-15. The maximum measured July discharge temperature was 100.0°F. *Id.*; Pet. at 12. For August, upper 10th percentile discharge temperatures were at or above 92.7 °F with a maximum measured temperature of 98.1 °F. App. D at D-15.

The Board noted that MG’s proposed near-field temperature limit for July and August is 93 °F. The Board asked MG to comment how often it expects discharge temperatures above this proposed limit and on the availability of excursion hours. Board Questions at 1.

MG stressed that these discharge temperatures are end-of-pipe temperatures. “Because compliance with the Proposed Near Field limit is determined at the edge of the allowed mixing zone, these end-of-pipe temperatures do not determine compliance and do not require the use of excursion hours to maintain compliance.” MG Resps. at 1. MG states that, because it uses near-field thermal models to calculate edge-of-mixing-zone compliance temperatures, it could not provide a full range of expected compliance temperatures. *Id.* at 2. However, MG argues that historical compliance records and its demonstration show that the Stations will be able to consistently meet its proposed ATELS with excursion hours for periods presenting adverse compliance conditions. *Id.* MG adds that, if extreme conditions bring it close to exhausting its requested excursion hours, it “will take the necessary measures to remain in compliance with the maximum proposed summer AELs.” *Id.*

For June and September, upper 10th percentile temperatures were at or above 86.4 °F and 90.0 °F, respectively, with measured maximum temperatures of 96.2 °F and 97.8 °F, respectively. App D. at D-15; Pet. at 12.

Discharge Flows. For 2012-2017, summer discharge flows “were at or close to the maximum 579 cfs (375 MGD) over 50% of the time.” App. D at D-15, citing Table D-2a.

The demonstration reports that, under coal-fired operation, “the summer circulating water flow rate was kept essentially constant at the maximum rate, aside from intermittent pump issues and short-term outages.” App. D at D-15. Since converting to natural gas, the circulating water system “can remain idle for weeks or months at a time.” *Id.*

Summer Power Production. For 2012-2017, Unit 6 operated at or over 90% of capacity or 303 MW for 10% of the time during the summer. App. D at D-16, citing Table D-2a. Median summer operating levels ranged from 0% to 43% of total capacity, or 145 MW. *Id.*

The demonstration reports that, since converting to natural gas, operating levels “have been much lower than in the past and can be expected to remain below historical levels on a sustained basis.” App. D at D-16. During high demand periods with hot weather and low river flows, the Stations will run at high levels and discharge at the same high temperatures. *Id.* “[T]he historical data provide a reasonably reliable representation of future discharge temperatures under adverse compliance conditions.” *Id.*

Discharge Temperature Over 90 °F. For 2012-2017, the number of July hours with discharge temperatures exceeding 90 °F was more than 300 during 2012 and 2013, more than 200 in 2015, and more than 100 in 2014 and 2015. App. D at D-16, citing Table D-3a. July discharge temperatures exceeded 93 °F for more than 200 hours in 2012, 199 hours in 2013, and from 0 to 73 hours from 2014 to 2017. *Id.*

In August, the number of hours with discharge temperatures exceeding 90 °F exceeded 300 in 2013 and 2015, exceeded 100 during 2012 and 2014, and was 31 in 2016. App. D at D-17, citing Table D-3a. August discharge temperatures exceeded 93 °F for 177 hours in 2013, 190 hours in 2015, and from 0 to 77 hours in 2012, 2014, 2016, and 2017. *Id.* September discharge temperatures exceeded 93 °F from 0 to 15.7% of hours. App. D at D-17.

Although there are fewer discharges at higher temperatures, discharge temperatures at Joliet 9 exceeded 95 °F up to 12.5% of the time in August and 10.2% in July. Temperatures exceeded 96 °F for up to 5.5% of the time and 98 °F for up to 1.5% of the time during the same period. App. D at D-17, citing Table D-3a. The demonstration attributes these lower percentages to “the significant unit deratings which were taken during critical periods when the unit was operated on coal under more baseload conditions.” App. D at D-17. When summer months do not show higher discharge temperatures, they reflect “cooler summer weather, along with increased average river flow conditions, which both generally correspond with decreased power production and resultingly lower discharge temperatures.” *Id.*

Joliet 29. The demonstration notes that narrative descriptions of discharge temperatures do not account for the use of supplemental cooling towers. Pet. at 13, n.9.

Discharge Temperatures. For 2012-2017, mean summer discharge temperatures were all below 90 °F with highest monthly means in of 86.9 °F in July and 85.6 °F in August. App. D at D-15, citing Table D-1b; *see* Pet. at 13.

Joliet 29 observed the highest discharge temperatures in July with a median temperature of 86.6 °F and upper 10th percentile temperatures at or above 97.4 °F. App. D at D-15, citing Table D-1; *see* Pet. at 13. For August, the median discharge temperature was 85.6 °F and upper 10th percentile temperatures were at or above 93.9 °F. *Id.* Maximum measured temperatures for July and August were 105.5 °F and 105.0 °F, respectively. *Id.*

For June and September, the upper 10th percentile temperatures were at or above 90.2 °F and 91.7 °F, respectively. App. D at D-15, Table D-1b. For those two months, maximum measured temperatures were 102.3 °F and 103.5 °F, respectively. *Id.*; *see* Pet. at 13.

Discharge Flows. For 2012-2017, discharge flows “were at or close to the normal operating rate of 1,537 cfs (994 MGD), representing the use of three of the four circulating water pumps for over 60% of the time during the summer.” App. D at D-16, Table D-2b. Approximately 1% of the time, operation occurred at the design flow rate of 2,050 cfs (1,325 MGD). *Id.*

The demonstration states that when the Station was coal-fired, “the summer circulating water flow rate was essentially 1,537 cfs during the summer, aside from intermittent pump rotations and short-term outages.” App. D at D-16, Table D-2b. Since converting to gas, the system “can remain idle for weeks or months at a time.” *Id.*

Summer Power Production. For 2012-2017, Units 7 & 8 had maximum load capacity of 1116 MW. App. D at D-16. Median summer operating levels ranged from 45-52% of total capacity, or 479-579 MW. *Id.*, Table D-2b. The units operated at or greater than 90% capacity or 1004 MW for an average of slightly less than 15% of the time and at or greater than 95% capacity approximately 5% of the time. *Id.*

The demonstration reports that, since converting to natural gas, operating levels “have been much lower than in the past and can be expected to remain below historical levels on a sustained basis.” App. D at D-16. During high demand periods with hot weather and low river flows, the Stations will run at high levels and discharge at the same high temperatures. *Id.* “[T]he historical data provide a reasonably reliable representation of future discharge temperatures under adverse compliance conditions.” *Id.*

Discharge Temperatures Over 90 °F. For 2012-2017, the number of July hours with discharge temperatures exceeding 90 °F was more than 700 during 2012 and more than 400 in 2013, and ranged from 142 to 238 in 2014 to 2016. App. D at D-16, citing Table D-3d. The number of July hours with discharge temperatures exceeding 93 °F ranged from 647 hours in 2012 to 0 hours in 2017. *Id.* July hours with discharge temperatures exceeding 96 °F ranged from 466 hours in 2012 to 0 hours in 2014 and 2017. *Id.* Maximum discharge temperatures of 105.5 °F and 105.0 °F were observed in July and August of 2012, respectively, a period of drought and heat during which the Stations operated under a provisional variance. App. D at D-17, n.9, Table D1-b

After 2012, discharge temperatures still exceeded 93 °F as much as 36.8% of the time in July 2013, approximately 23% of the time in August and September of 2013 and 16.4% of the

time in July 2016 after conversion to gas. App. D at D-18, Table D-3d. In September, discharge temperatures exceeded 93 °F from 0 hours to nearly 23% of hours in the month depending on the year. *Id.*

Discharge temperatures exceeded 96 °F up to 62.6% of hours in July and 22.7% of hours in August of 2012. App. D at D-18, Table D-3d. They exceeded 96 °F up to 17.2% of hours in July and 9% of hours in August of 2013. Discharge temperatures exceeded 98 °F 48.8% of the time in July 2012 and from 0-10.1% in July of other years. *Id.*

Use of Supplemental Cooling Towers. Joliet 29 normally operates its cooling towers “whenever discharge temperatures are expected to exceed 93 °F for an extended period of time.” App. D at D-18. By mixing plant discharge with cooling tower effluent, discharge temperatures are lower than the end-of-pipe value. *Id.*

The demonstration argues that end-of-pipe temperatures “provide conservative estimates of compliance point temperatures under most conditions.” Pet. at 13. Because mechanical issues and adverse dew points can have negative effects on cooling tower operations, “it is not excessively conservative to look at end-of-pipe temperatures as a valid means of assessing potential thermal impact under unfavorable conditions.” *Id.*; see App. D at D-18.

Summer Discharge Summary. The demonstration argues that, with fluctuating river flows, the Stations’ historical discharge data indicate that neither will consistently be able to meet the thermal water quality standards for the UDIP and Five-Mile Stretch, “even with the small allotment of excursion time allowed up to a maximum of 93 °F.” App. D at D-18 – D-19.

Winter.

Joliet 9. The demonstration argues that Joliet 9 discharge data represent “measured end-of-pipe temperatures and therefore provide conservative estimates of compliance point temperatures under most conditions.” App. D at D-19. It adds that ranges of discharge temperatures reflect “non-seasonal weather conditions, low LDPR flow, and higher winter power demand.” *Id.*; Pet. at 13.

Discharge Temperatures. For 2012-2017, mean winter discharge temperatures were all below 60 °F. App. D at D-19, Table D-1c. The highest mean discharge temperatures were in the months of February (50.8 °F) and March (53.6 °F). *Id.*; Pet. at 12.

During December and March, discharge temperatures exceeded 60 °F more than 10% of the time, with maximum temperatures of 80.8 °F and 70.0 °F, respectively. App. D at D-19, Table D-1c; Pet. at 12-13.

The Board noted that the proposed December and March far-field temperature limit is 65 °F and near-field temperature limit is 70 °F. The Board asked MG to comment on how often it expects discharge temperatures above the proposed limits and on the availability of excursion hours. Board Questions at 1.

MG responded that these maximum temperatures are end-of-pipe temperatures, which do not necessarily indicate temperatures at the edge of the mixing zone or far-field temperatures. MG Resps. at 2. MG argues that both Stations will be able to meet the proposed near-field winter limits, which include excursion hours. *Id.* at 2-3. It also expects to meet the far-field ATEL of 65 °F most of the time with a requested period of excursion hours to cover limited periods during unseasonable conditions that may limit downstream cooling. *Id.* at 3. If it comes close to exhausting its requested excursion hours, MG states that it will take “whatever measures necessary to remain in compliance with the maximum proposed winter Near-Field and Far-Field AELs.” *Id.* at 3.

In the cooler months of January and February, discharge temperatures exceeded 60 °F for up to 5% of the time, with maximum temperatures of 68.6 °F and 68.2 °F, respectively. App. D at D-19, Table D-1c; Pet. at 12-13.

Discharge Flows. Because of maintenance operations and lower historic power production, cooling water flow rates are “somewhat lower than during the summer.” App. D at D-20, Table D-2c. The Station maintains a cooling water flow rate less than the design maximum of 579 cfs “approximately 50% of the time in December and March, and 20-30% of the time in January and February.” *Id.* Under peaking operation, if Unit 6 is not running, then “there is generally no cooling water flow.” App. D at D-20. In unseasonable weather conditions, however, the Station may operate all available circulating water pumps to meet power demand. *Id.*

Winter Power Production. “Under gas peaking operations, the unit has not, to date, been run for more than a few days at a time during the winter months.” App. D at D-20, n.10. For 2012-2017, maximum winter load was 334 MW. *Id.*, Table D-2c. Median operating levels ranged from 0% to 46% of total capacity (155 MW). *Id.* Power production was at or above 75% capacity (251 MW) for up to 20% of the time and at or above 90% of capacity (301 MW) for up to 10% of the time. *Id.*

Discharge Temperatures Over 60 °F. For 2012-2017, all four winter months had discharge temperatures exceeding 60 °F, and temperatures exceeding 70 °F for 69 hours in December 2012 and 27 hours in December 2013. App. D at D-21, Table D-3b. Discharge temperatures exceeded 60 °F for more than 400 hours during December and March of 2012 and for more than 300 hours during December 2013. *Id.*

For 2012-2017, discharge temperatures exceeded 63 °F from 0% to 44.2% of the time in December and from 0% to 45.2% of the time in March. App. D at D-21, Table D-3b. During the colder months of January and February, discharge temperatures have exceeded 63 °F up to 9.1% and 10.1% of the time, respectively. *Id.* During a period of unusual winter warmth in February 2017, discharge temperatures exceeded 67 °F for five hours. *Id.* Discharge temperatures have exceeded 68 °F from 0% to 16.1% of the time in December and 0% to 13.1% of the time in March. *Id.*

Joliet 29. The demonstration states that winter discharge temperatures do not reflect the use of supplemental cooling towers, which are not designed to operate in winter. App. D at D-

19; *see* Pet. at 13, n.9. The demonstration argues that discharge data represent “measured end-of-pipe temperatures and therefore provide conservative estimates of compliance point temperatures under most conditions.” App. D at D-19.

Discharge Temperatures. For 2012-2017, mean winter discharge temperatures were all below 60°F, “with the highest monthly means in December (51.1 °F) and March (54.1 °F). App. D at D-19, Table D-1d; Pet. at 13. Discharge temperature were above 60 °F up to 15% of the time during those two months, with maximum temperatures of 80.5 °F and 69.1 °F, respectively. App. D at D-19, Table D-1d; Pet at 13-14. During the colder months of January and February, discharge temperatures exceeded 60 °F up to 1% of the time with maximum measure temperatures of 67.5 °F and 64.6 °F, respectively. App. D at D-19, Table D-1d; Pet. at 14. The range of winter discharge temperatures reflects “a combination of non-seasonal weather conditions, low UDIP/LDPR flow, and higher winter power demand.” App. D at D-19; *see* Pet. at 14.

Discharge Flows. Because of maintenance operations and lower historic power production, cooling water flow rates are “somewhat lower than during the summer.” App. D at D-20, Table D-2d. When it operates, Joliet 29 generally uses three of four circulating water winter pumps, with a total flow of 1,537 cfs. *Id.* The Station has maintained this flow approximately 60% of the time during winter months. *Id.* “Higher flows have been related primarily to pump switching, which occurs infrequently. Lower flows occurred under single-unit operation, or during plant maintenance activities.” App. D at D-20.

Winter Power Production. For 2012-2017, maximum winter load was 1101 MW. Median operating levels ranged from 30% (330 MW) to 56% (620 MW) of total two-unit capacity. App. D at D-21. Production was at or above 75% of capacity (826 MW) up to 25% of the time. Units 7 & 8 were operated at up to 90% capacity for up to 10% of the time. App. D at D-20 – D-21, Table D-2d.

Discharge Temperatures Over 60 °F. Discharge temperatures exceeded 60 °F for more than 400 hours in March 2012 and December 2014. App. D at D-21, Table D-3e. For 2012-2017, temperatures exceeded 63 °F from 0% to 33.9% of the time in December and from 0% to 39.3% of the time in March. *Id.* Discharge temperatures have exceeded 68 °F from 0% to 8.3% of the time in December and from 0% to 2.3% of the time in March. *Id.* at D-21 – D-22, Table D-3e.

During the colder months of January and February, discharge temperatures have exceeded 63 °F for up to 2.7% and 0.6% of the time, respectively. App. D at D-22, Table D-3e. During a period of unusual winter warmth in February 2017, discharge temperatures exceeded 60 °F for nine hours. *Id.* The demonstration argues that “discharge temperatures would have been higher, but operational issues prevented Unit 8 from running at full load during this period.” App. D at D-22, n.12.

Winter Discharge Summary. The demonstration states that winter flows in the UDIP/LDPR “are often chronically low, which could potentially limit the amount of dilution flow available for dissipation of discharge temperatures,” limiting the Stations’ ability to comply

with the UDIP winter thermal limits. App. D at D-22. It argues that historical temperature data indicate that discharges from the Stations “would be unable to consistently meet the UDIP numeric winter limit of 60 °F, nor the 63 °F maximum.” *Id.* It adds that the available excursion hours would not be sufficient to support winter operations, “especially if unseasonable weather patterns and/or low flow conditions persisted during any given year.” *Id.*

Transitional Months

For 2012-2017, the transitional months of April-May and October-November experienced significant discharge temperature fluctuations. App. D at D-23, Tables D-3c, D-3f. Joliet 9 discharge temperatures greater than 90 °F for 19 hours with a maximum temperature of 93.6 °F in October 2013. App. D at D-23, Tables D-1e, D-3c. Joliet 29 had discharge temperatures greater than 90 °F for 42 hours with a maximum temperature of 92.3 °F. App. D at D-23, Tables D-1f, D-3f.

The demonstration suggests that these data indicate that the Stations’ thermal discharges could meet UDIP thermal limits for transitional months most of the time. App. D at D-23. However, MG proposed “near-field thermal AELs that, for some months, are more stringent than the UDIP limits for this period.” *Id.* (emphasis in original). The demonstration argues that this provides “a more seasonally-based and gradual transition between the summer and winter months” and addresses the purpose of narrative standards regarding abnormal temperature changes. *Id.*

Thermal Plume Surveys

The demonstration includes thermal plume surveys performed on February 23, 2017; July 13, 2017; and December 14, 2017. App. D at D-24. The units were placed into operation at least two days before each survey to obtain representative thermal plumes. *Id.* at D-29. Data collected during a 2012 survey supplemented the summer data. *Id.*, citing App. I; *see* App. D at D-24, n.15. “Each thermal survey consisted of mapping the plume by continuously recording near-surface temperatures along a transect grid and by performing a series of vertical temperature profiles.” App. D at D-24 – D-25.

Mapping

The sampling grid included 25 transects within the UDIP ranging from 3,350 upstream from the Stations near the Brandon Road Lock & Dam to 33,350 feet downstream from them at the I-55 Bridge. App. D at D-25; Figures D-3a – D-3c. The surveys re-established the 14 original near-field locations and extended the far-field area with nine additional downstream transects. *Id.* at D-26. The surveys established vertical profiling stations that are evenly spaced along each of the transects based on channel width. *Id.* They included additional transects and vertical stations in each of the discharge canals. *Id.*

Bathymetric Survey

On September 7-8, 2017, a survey collected bathymetric data along each of the 25 study transects. App. D at D-27, citing Figure D-6 (bathymetric contour map). The survey collected depth soundings and measured physical characteristics of the water column to determine sound velocity. Sound velocity is a product of water density and is employed to correct raw soundings. Once reviewed and corrected, this data was used to develop the hydrothermal model. App. D at D-27 - D-28.

February 23, 2017

Survey Conditions. LDPR flows during the February 23, 2017 survey ranged from 1,656 to 8,580 cfs, “from approximately the 20th percentile to slightly below the 99th percentile.” App. D at D-28 – D-29, citing Figure D-7a; *see* Table D-4b. The demonstration characterizes flow fluctuations of this nature as “typical of the LDPR.” App. D at D-29, citing *id.* at D-23 – D-24 (River Conditions).

Station Operations. “Intake temperatures during the study ranged from 50.4 °F to 53.9 °F at Joliet 9 and between 49.7 °F and 50.5 °F at Joliet 29.” App. D at D-29, citing Table D-5a, D-5b. Power production at Joliet 9 ranged from 115 MW up to 240 MW before completely shutting down. *Id.* “The Joliet 9 intake/discharge flow was constant at 290 cfs during the survey,” representing a single circulating water pump. The highest discharge temperature at the point of discharge was 67.4 °F with a mean of 66.3°F. *Id.*

At Joliet 29, intake temperatures ranged from 49.7 °F to 50.5 °F. App. D at D-29, citing Table D-5b. Power production at Joliet 29 ranged up to 390 MW during the survey period before shutting down. *Id.* Flow at Joliet 29 decreased from 1,537 cfs to 1,025 cfs during the survey period before all circulating water pumps cycled off. *Id.* The highest discharge temperature at the point of discharge was 59.0 °F with a mean of 58.2 °F. *Id.*

Although Joliet 29 does not customarily use its supplemental cooling towers during the winter, fourteen of the towers were in service during the February 23, 2017 survey. App. D at D-29. The demonstration explains that the survey occurred “at the end of a string of six consecutive dates with record-breaking warm air temperatures.” *Id.* at D-30. The demonstration argues that operating the towers helped maintain compliance with far-field temperature standards. *Id.* However, using the towers “did not result in any significant decrease in effective discharge temperature (a calculated value which assumes complete mixing of the cooling tower flow with the non-cooled discharge flow).” *Id.*

Plume Survey Results. At the Joliet 9 discharge canal, the plume temperature was as high as 67 °F, with elevated temperatures continuing to the -1720, 1/5 transect point (63.1 °F to 66.5 °F). App. D at D-31 – D-32, citing Table D-6. On the RDB at transect -1720 4/5, the survey found cooler temperatures ranging from approximately 61 °F in the surface layers to 51.7 °F at the bottom (12 ft.). *Id.* Downstream, the plume remained closer to the LDB, where surface temperatures ranged from 60 °F to 65.1 °F in the top three feet and from 52.1 °F to 52.7 °F at the bottom. *Id.* At the -750, 4/5 transect point, the RDB had cooler and relatively consistent

temperature from top to bottom ranging from 54.5 °F to 53.9 °F range, respectively. *Id.* The plume remained laterally distributed within the top five to six feet through the -250 ft transect, with some heat dissipation observed. *Id.* The 63 °F isotherm of approximately 19 acres was all within the -250ft transect boundary, marking the theoretical edge of Joliet 9's 26-acre mixing zone. All water temperatures were at or below 61.2 °F near the surface, with decreasing temperatures as depth increased. App. D at D-32; *see* Figure D-8a.

From Joliet 29, the discharge enters the river just below the 250ft transect. Because Joliet 29 used 14 cooling towers on this date, its discharge temperature was slightly cooler than the receiving water. This plume of cooler water pushed the warmer water against the LDB. App. D at D-32. Surface temperatures exceeded 60 °F over approximately 35 acres, with subsurface temperatures approximately 2-3 °F cooler. *Id.*, *see* Figure D-8a; Table D-6. At the 2,000 ft transect, the edge of a 26-acre mixing zone, “more complete mixing was observed, with maximum surface temperatures ranging from 57.8 °F on the LDB to 59.1 °F on the RDB, and corresponding bottom temperatures of 56.7 °F to 56.1 °F, respectively. *Id.* Beyond the 2,750 ft transect, river surface temperatures were better mixed. *Id.* Thermal plume depth was variable from transect to transect, which may result from low flow conditions in the waterway. This low flow can cause pooling and slow plume dispersion and downstream travel, which can affect overall heat dissipation. The demonstration also noted that prevailing weather conditions were extremely unseasonable, with a high local air temperature of 65 °F. *Id.* The plume became horizontally and vertically mixed at the 15,000 ft transect, where temperatures ranged from 56.3 °F at the bottom and 55.8 °F at the surface. “These temperatures were similar to ambient temperatures observed at the -3,350 ft transect.” *Id.*; *see* Figure D-5a.

At the I-55 Bridge at the 33,350 foot transect, the study showed full mixing, with temperatures ranging from 54.3 °F to 54.7 °F. App. D at D-32; *see* Table D-6.

July 13, 2017

Survey Conditions. LDPR flows during the July 13, 2017 survey ranged from 3,371 cfs to 6,996 cfs, from approximately the 50th to the 85th percentile. App. D at D-28 – D-29, citing Figure D-7b. The demonstration characterizes this flow fluctuation as typical of a summer day. App. D at D-29, citing Table D-4a.

Station Operations. “Intake temperatures during the survey ranged from 75.2 °F to 77 °F at Joliet 9.” App. D at D-30, citing Table D-7a. Power production at Joliet 9 ranged from 133 MW to 312 MW before dropping to 220 MW. *Id.* The Joliet 9 discharge flow was constant at 579 cfs during the survey. *Id.* The highest discharge temperature at the point of discharge was 87.9 °F with a mean of 87.2 °F. *Id.*

At Joliet 29, intake temperatures ranged from 75.1 °F to 75.7 °F. App. D at D-30, citing Table D-7b. Power production at Joliet 29 ranged from 314 MW to as high as 999 MW before dropping to 662 MW. *Id.* Flow at Joliet 29 was constant at 1,537 cfs during the survey. *Id.* The highest discharge temperature at the point of discharge was 92 °F with a mean of 90.9 °F. *Id.*

During the July 13, 2017 survey, cooling towers were not in use because “they were not deemed necessary to maintain compliance with the existing near- or far-field thermal standards.” App. D at D-30. The demonstration argues that “[p]erforming the thermal surveys without tower use also provided the opportunity to assess heat dissipation in the waterway solely based on ambient conditions.” *Id.*

Plume Survey Results. From Joliet 9, the maximum discharge temperature measure was 87.9 °F. Adjacent to the discharge canal at the -1,720 ft transect, the plume temperature was 86.8 °F, with cooler surface temperatures on the RDB. App. D at D-34; Table D-8. Downstream at the -750 ft transect, the plume moved across the river, with surface temperatures at the RDB at 85.1 °F and the LDB at 78.6 °F. *Id.* Near the 250 ft transect, the plume began to spread more evenly. *Id.* The 250 ft transect is considered to be the approximate hypothetical edge of a 26-acre mixing zone.

The Joliet 29 discharge was measured at 88.7 °F just upstream of the discharge canal confluence with the UDIP. App. D at D-34; Table D-8. At the 750 ft transect, the thermal plume was still discernable, with temperatures ranging from 87.8 °F on the RDB to 86.0 °F on the LDB. *Id.* Lower depth temperatures were in the 77.0 °F to 81.5 °F range, except at the LDB, where temperatures approached 86.0 °F. *Id.* “The 2,000 ft transect corresponds to the approximate edge of the hypothetical 26-acre mixing zone for the Joliet 29 discharge.” App. D at D-34. At depths down to eight feet temperatures ranged from 84.3 °F to 87.0 °F. *Id.*; *see* Table D-8. The temperatures below eight feet ranged from 78.2 °F to 84.3 °F, with the highest temperatures along the RDB. *Id.* At the 15,000 ft transect, the plume became mixed horizontally and vertically with temperatures ranging from 79.2 °F to 81.7 °F. *Id.*

At the I-55 Bridge at the 33,350 foot transect, the study showed temperatures ranging from 78.9 °F to 79.1 °F. App. D at D-35; *see* Table D-8. “These temperatures do not reflect any upstream thermal influence.” App. D at D-35.

December 14, 2017

Survey Conditions. LDPR flows during the December 14, 2017 survey ranged from 235 cfs to 3,946 cfs, from below the 1st percentile to approximately the 85th percentile. App. D at D-29, citing Table D-4b; *see* Figure D-7c.

Station Operations. “Intake temperatures during the study ranged from 37.1 °F to 39.2 °F at Joliet 9” with a mean of 37.9 °F. App. D at D-30, citing Table D-9a. Power production at Joliet 9 ranged from 135 MW to 250 MW. *Id.* The Joliet 9 discharge flow was constant at 579 cfs during the survey. *Id.*; *see* Figure D-7c. The highest discharge temperature at the point of discharge was 49.6 °F with a mean of 47.3 °F. App. D at D-30, citing Table D-9a.

At Joliet 29, intake temperatures ranged from 37.7 °F to 38.9 °F with a mean of 38.3 °F. App. D at D-30 – D-31, citing Table D-9b. Power production at Joliet 29 ranged from 815 MW to 1024 MW. *Id.* Flow at Joliet 29 was constant at 1,537 cfs during the survey. *Id.* The highest discharge temperature at the point of discharge was 52.3 °F with a mean of 50.6 °F. *Id.*

During the December 14, 2017 survey, cooling towers were not in use because “they were not deemed necessary to maintain compliance with the existing near- or far-field thermal standards.” App. D at D-30. The demonstration argues that “[p]erforming the thermal surveys without tower use also provided the opportunity to assess heat dissipation in the waterway solely based on ambient conditions.” *Id.*

Plume Survey Results. For Joliet 9, the study observed the plume recirculating with warmer water upstream towards the -3,350 ft transect. App. D at D-36, citing Figure D-8c. The 1/4 vertical showed a temperature of 45.1 °F at the surface and 38.9 °F at the bottom. The bottom temperature was similar to the surface temperature observed at the -4,620 ft transect, an upstream monitoring location. *Id.* “When the Joliet 9 plume enters the river at the -1,720 ft transect, the surface layers will move both upstream and downstream when river flow is low.” App. D at D-36. At the -1,720 ft transect, the plume surface had lateral temperature differences attributable to the Joliet 9 discharge. App. D at D-37, citing Table D-10. Temperatures near 50 °F were observed on the RDB, whereas the LDB was between 52.9 °F at the surface and 52.4 °F at a depth of three feet. *Id.* “The surface plume stretched laterally across the entire river width from the -1,720 ft through the -750 ft transect, but dissipated rapidly by the -250 ft transect.” App. D at D-37.

At Joliet 29, the study measured discharge temperatures of 50.3-50.5°F, which is similar to temperatures near the discharge point because of the influence of the Joliet 9 thermal discharge. App. D at D-37, citing Table D-10. The study found similar temperatures at the 250 ft transect, where the Joliet 29 discharge meets the UDIP. At the 750ft transect, the water column was fully mixed at approximately 50 °F. *Id.*

With slight stratification, the entire river channel remained at approximately 50 °F through the 5,500 ft transect. *Id.* Differences likely resulted from “both complex mixing processes within the LDPR, as well as the impact of upstream lock and dam operations.” App. D at D-37. The study observed the same stratification pattern downstream at the 10,800 ft and 15,000 ft transects. *Id.*, see Table D-10. Farther downstream, “the water column was essentially of uniform temperature.” App. D at D-37.

At the I-55 Bridge, the study found uniform water temperatures of 40.3 °F-40.4 °F at the 1/2 and 3/4 width, and less than 0.5 °F cooler on the LDB.

Data Collection Programs

In the 1990s, a number of biological and physiochemical studies developed in cooperation with the UIW Task Force and examined areas including the UDIP near the Stations. App. E at E-1. Since the 1990s, additional studies have been sponsored by MG or as part of the efforts of the ACRCC and other agencies. *Id.* The demonstration summarizes data collection programs conducted near the Stations.

Hydrographic Surveys

Hydrographic data have been collected and used to operate the Stations and in studies to evaluate their effects on the LDPR. App. E at E-2, citing App. D. USACE and USGS, which operate gauges on the CSSC and LDPR, have been the primary sources of this data. *Id.* “Depending on the station, data for stage, elevation, and/or discharge, as well as select parameters such as temperature and velocity are available.” *Id.*

Temperature Monitoring

Numerous thermal studies have been conducted near the Stations.

From 1977-2011, MWRDGC monitored water quality at 49 fixed locations along a 133-mile stretch of the UIW, including eight locations in the Dresden Island Pool, four of them upstream from the I-55 Bridge. App. E at E-3. MWRDGC performed monitoring three times per year before discontinuing it beyond its immediate service area in 2011. *Id.*, citing App. C.

In 1996, the Board ordered a study of the UIW as part of a variance issued to MG’s predecessor as owner of the Stations. App. E at E-3. In 2002, studies conducted on MG’s behalf obtained “information concerning near-field thermal plume characteristics for each generating facility under a variety of summer operating, river flow, and meteorological conditions.” *Id.* The surveys included surface plume measurements. *Id.* at E-3 – E-4, citing App. I.

In 2012, surveys on behalf of MG examined thermal plumes near the Stations. App. E at E-4, citing App. I. Based on its DSP, MG performed a summer thermal plume survey on July 13, 2017, and two winter surveys on February 23, 2017, and December 14, 2017. App. E at E-4. The collected data were used to construct and calibrate a hydrodynamic model and develop MG’s proposal. *Id.*, citing App. D.

Finally, the Stations maintain “a continuous record of intake and discharge temperatures” and other operational data under their NPDES permits. The collected data support its approved near-field thermal compliance model. App. E at E-4, citing App. D

Nutrient Data

Since 1977, MWRDGC has collected and analyzed samples from the entire UIW. App. E at E-5. Monitored parameters include nutrients described below. *Id.*; *see infra* at 33-34.

Phytoplankton and Periphyton Communities

In 1991 and 1993, MG’s predecessor as owner of the Stations collected phytoplankton and periphyton samples as part of a UIW study. The Board required a study to address a variance granted to the predecessor. App. E at E-7. “The study objectives were to assess the algal community system-wide, evaluate the effects of power generating stations along the waterway, and to characterize the importance of tributary inputs to the algal community.” *Id.* at E-7 – E-8.

Since 2002, MWRDGC has annually monitored phytoplankton productivity near the Stations to monitor the community assemblage. App. E at E-8.

The ACRCC conducted monthly plankton sampling at six sites along the Illinois Waterway from 2009-2010 and at 12 additional sites from 2011-2013. App. E at E-8. The ACRCC also conducted weekly sampling for chlorophyll *a*, zooplankton, and phosphorus in 2017 and 2018. Monitoring sought to assess productivity by measuring concentrations of chlorophyll *a*, zooplankton, and phosphorus to locate areas where Asian Carp were most likely. *Id.* In addition, annual monitoring sought to identify relationships between the abundance of Asian Carp and the three variables. *Id.*

Zooplankton

The demonstration reports that “[l]imited zooplankton sampling has been conducted within the UIW.” App. E at E-9; *see* Exh. A at 6-4. Because zooplankton have a high reproductive capacity and short generation times, the category is considered to have low potential for impact from thermal discharges. App. E at E-9. Also, testing has shown that “zooplankton typically have relatively high thermal tolerance levels.” *Id.*

Zooplankton sampling was conducted in the Dresden Island Pool from 1972 to 1975 and in 1981 to “characterize the spatial and temporal distribution of the community.” App. E at E-9. Also, in 2009-2010 and 2011-2014, ACRCC conducted plankton sampling to assess composition of the community before and after occurrence of Asian Carp and to document the ecosystem’s response before and after Asian Carp removal activities. *Id.*

Benthos

The demonstration reports that there have been only limited studies of benthic macroinvertebrates near the Stations since the mid-1990s. App. E at E-11. Because the Stations’ discharges result in buoyant thermal plumes, “habitat for benthic macroinvertebrates has minimal exposure to the warmest portions of the plumes that occur in the immediate vicinity of the stations.” *Id.*

MG’s predecessor investigated benthic macroinvertebrate communities in the UIW in 1993 and 1994. App. E at E-11. The first investigation sought to characterize the communities, and the second sought “to identify potential relationships between invertebrate community composition and selected water, sediment, and habitat parameters.” *Id.* Both included sampling locations directly upstream and downstream from the Stations. *Id.*

In 2017 and 2018, the demonstration sampled the benthic macroinvertebrate communities at 12 locations near the Stations “to determine/compare the composition, distribution, and abundance of the benthic community among segments.” App. E at E-11, citing App. L.

Macrophytes

From 1992 to 1995, macrophyte sampling sought to determine the location and extent of these communities and investigate factors that may limit their establishment and growth. App. E at E-14. “These aquatic communities were assessed using aerial photography with field reconnaissance and ground truthing.” *Id.*

MG conducted additional studies to supplement the earlier UIW studies. App. E at E-14, citing App. K. These studies included QHEI assessments and a survey of submerged aquatic vegetation and habitat in the UDIP during peak growing season. App. E. at E-14.

Ichthyoplankton

In 1994, MG’s predecessor as owner of the Stations studied early life stages of fish in the UIW. App. E at E-16. “The goal of the study was to determine what portion of the fish community in the Illinois River drainage was using this physically limited and impacted subunit in the system as a spawning or nursery area as well as when and where those uses occur.” *Id.*

In 2004 and 2005, both Stations conducted entrainment studies. In 2016, Joliet 9 conducted an entrainment study to evaluate technology for USEPA regulations. App. E at E-17. In 2017, MG reported UDIP water quality, hydrology, and fisheries data to assess whether entrainment data from 2004 and 2005 reflected current conditions. *Id.* IEPA approved the report. *Id.*

Since 2010, INHS on behalf of ACRCC has collected larval fish from 12 sites in the Illinois Waterway. App. E at E-17. These studies help to show the distribution of Asian Carp eggs and larvae “and factors contributing to Asian Carp recruitment.” *Id.*

Impingement

From July 2004 to August 2005, an impingement mortality study was conducted at both Stations. App. E at E-18. From April 2004 through April 2006, a two-year impingement study was conducted at Joliet 29. *Id.* During the same period, 52 weekly impingement samples were collected at Joliet 9 intake and “10 concurrent sampling events were conducted at Joliet Stations 9 and 29.” *Id.*, citing Apps. A, B.

Ecological Setting

The Stations discharge treated wastewater to the UDIP under the terms of their respective NDPES permits. The Board’s regulations designate the UDIP as the “Lower Des Plaines River from the Brandon Road Lock and Dam to the Interstate 55 bridge.” 35 Ill. Adm. Code 303.230(a); *see* Pet. at 3, n.4; App. A at A-1. Although the UDIP ends at the bridge, the Stations’ thermal influence can extend beyond it into the Five-Mile Stretch. Pet. at 1. Although not designated in the Board’s regulations, the Five-Mile Stretch is the segment of the LDPR running from the I-55 Bridge at RM 277.9 to the head of the Illinois River formed by the confluence of the Des Plaines and Kankakee Rivers at RM 273.0. *Id.* at 3, n.5.

In 2015, the Board adopted new thermal water quality standards with an effective date of July 1, 2018. Pet. at 1-2, citing Water Quality Standards and Effluent Limitations for the Chicago Area Waterway System (CAWS) and the Lower Des Plaines River: Proposed Amendments to 35 Ill. Adm. Code 301, 302, 303 and 304, R08-9(D) (June 18, 2015). While those thermal standards are based on standards for General Use waters, the Board designated the UDIP as “Upper Dresden Island Pool Aquatic Life Use Waters.” 35 Ill. Adm. Code 303.230(a); see Pet. at 2; Rec. at 2. During consideration of the 2018 thermal standards, MG stated that the Joliet Stations could not consistently meet the proposed standards and would avoid violations only by shutting down or derating. Pet. at 2.

The Five-Mile Stretch is not addressed by the Board’s 2018 thermal standards. Pet. at 3. MG asserts that, although Board regulations assign different uses to the UDIP and Five-Mile Stretch, “there is little meaningful difference between the two adjacent waterbodies, and MG addresses a single biological community inhabiting both segments.” Pet. at 2, n.2; App. B at B-1, n.1; MG Resps at 7.

MG argues that the Board in 1996 “found ‘adequate proof’ that the impact of the Joliet Stations on water temperatures past the I-55 Bridge did not cause nor could be reasonably expected to cause significant ecological damage to the waters of the Five-Mile Stretch.” Pet. at 3, citing Petition of Commonwealth Edison Company for Adjusted Standard from 35 Ill. Adm. Code 302.211(d) and (e), AS 96-10 (Oct. 3, 1996). The Board adopted alternate thermal standards applicable at the I-55 Bridge which “have been incorporated as far-field temperature limits in all NPDES limits for the Joliet Stations issued since 1996.” Pet. at 3.

Human Uses

Surrounding Land Use. Land surrounding Joliet Stations 9 and 29 is “dominated by industrial and commercial properties that have taken advantage of proximity to the river system for the transport of commodities, as well as industrial water usage.” Exh. A at A-34. Commercial shipping uses the UDIP and Five-Mile Stretch to connect the Great Lakes and Mississippi River Basin. The water has been channelized for barge traffic, and USACE maintains navigational depth. *Id.*

The UDIP and Five-Mile Stretch are also receiving waters for industrial discharges. Review of major NPDES facilities with individual permits shows 12 major permittees discharging into the UDIP or Five-Mile Stretch near the Stations, including upstream and indirect dischargers to the LDPR. Exh. A at A-35 (citation omitted).

Recreational Uses. The UDIP near the Stations is designated as an Incidental Contact Recreational Use Water. Recreational use “is limited to activities in which human contact with the water is incidental and the probability of ingesting appreciable quantities of water is minimal.” Exh. A at A-34, citing 35 Ill. Adm. Code 303.225.

Heavy Metal Contaminants. Contaminant levels in river water and sediments are affected by “[l]and use practices, floods, other natural events, spills, and other human caused incidents within the watershed.” Exh. A at A-35. “Typical sources of heavy metals released to

the UDIP/Five-Mile Stretch over time include municipal wastewater-treatment plants, manufacturing industries, and past agricultural activities.” Exh. A at A-37. Sediment collected near the Brandon Road Lock & Dam from 2008 to 2011 “contained high levels of cadmium, chromium, iron, lead, manganese, arsenic, and mercury as well as one PCB contaminant, Aroclor 1242.” *Id.* at A-35 – A-36 (citation omitted); *see id.* (Table A-2: 303(d) list); App. C at C-7.

Organic Contaminants. The UDIP/Five-Mile Stretch also “receives a variety of organic wastes, some of which are detrimental to human health and aquatic organisms.” Exh. A. at A-36. Although historical data show improved nutrient concentrations over time, “nutrient levels remain of concern in the waterway system.” *Id.* (citation omitted).

ANS Dispersal Barrier. Construction of an ANS dispersal barrier system and the migration of Asian Carp from the Illinois River have generated intensive sampling in the IWS including the UDIP. App. A at A-39. Because species in the by-catch could be affected, “sampling pressure likely has localized impacts on the UDIP fish community.” *Id.* at A-40. Plans for additional activities to control ANS “will almost certainly result in additional changes and stresses to the waterway near the Joliet Station that have nothing to do with their thermal discharges.” *Id.* at A-41.

Contaminant Concentrations in Sediments. A 2008 sediment study collected 35 samples from the Dresden Island Pool and lower Brandon Pool. Chemical analysis showed that both had “high concentrations of metals and tested organic constituents.” Data indicated that sediment quality in these areas “would overall be characterized as poor.” App. A at A-43, A-49, citing Figure A-6 (sampling locations); App. C at C-7.

MWRDGC conducted sediment chemical analysis for 11 trace metals between 2004 and 2011. App. A at A-43, citing Tables A-9, A-10 (UDIP data). Also, some of the highest levels nationally of PAHs “were detected in sediment near Chicago.” App. A at A-44. Frequent barge traffic re-suspends fine sediments. *Id.*; App. C at C-8.

The demonstration states that “movement of metals from the sediments into the water column is mediated principally by pH, which is not affected by temperature. Therefore, the Joliet Stations thermal discharges do not cause the release of heavy metals from the sediments.” App. C at C-9.

Contaminant Concentrations in Animal Tissue. “Many pesticides and other synthetic organic compounds (SOC), particularly those with low solubility, show a tendency to bioaccumulate in organisms.” App. A at A-44 (citation omitted). The demonstration states that “[t]he Joliet Station thermal discharges are not associated with presence of these contaminants or their bioaccumulation in animal tissue.” *Id.* at A-45.

Hydrodynamics

Hydrology. The Brandon Road Lock & Dam at RM 286 is directly upstream from the Joliet Stations. It “controls both the flow and navigational traffic entering the Dresden Island Pool of the LDPR.” Exh. A at 2-2; *see* App. A, Figure A-2 (Location of Joliet Generating

Stations #9 and #29 in the Dresden Island Pool); App. D at D-1. “Since the upstream Brandon Pool is only five river miles long and accepts drainage from the much larger Lockport Pool (total length of 36.2 river miles), flows in the UDIP/Five-Mile Stretch are largely controlled and manipulated by operation of the LCW [Lockport Controlling Works] in order to prevent flooding and also to maintain navigational depth.” Exh. A at 2-2; App. A at A-1; App. D at D-1 – D-2

River Flow. “The UDIP is a natural waterway that, in the early 20th century, was heavily modified and channelized to accommodate barge traffic.” Pet. at 3. “The main body of the UDIP near the Joliet Stations has depths ranging from 16-20 feet.” App. A at A-4. UDIP/Five-Mile Stretch flow derives primarily from three sources: “discharge from Chicago area storm drains and wastewater treatment plants, regulated flow diversion from Lake Michigan, and runoff from its 1,500 square mile drainage area.” Exh. A at 2-2; App. A at A-2. “Twelve major waterways contribute to the UDIP/Five-Mile Stretch,” and the CSSC drainage area “is the largest of any of the tributaries.” *Id.* CSSC base flow is dominated by treated and partially treated effluents from MWRDGC wastewater reclamation plants and 408 CSO points that ultimately discharge to the UDIP/Five-Mile Stretch. Exh. A at 2-2; App. A at A-3; *see* Pet. at 3.

Mean annual flow in the UDIP at the Brandon Road Lock & Dam near the Stations is 3,494 cfs. Exh. A at 2-2; *see id.*, Table A-1 (Monthly Mean River Flow at Brandon Road Lock and Dam 2012-2018); App. A at A-4. For summer months, median LDPR flow ranged from 2,390 cfs to 3,373 cfs. App. D at D-24, citing Table D-4a. For winter months, median LDPR flow ranged from 2,187 cfs to 3,278 cfs. *Id.* at D-24, citing Table D-4b. Because of year-round fluctuations for flood control and navigation, the demonstration argues that “[t]here is no seasonal, steady-state flow condition in the LDPR.” *Id.* at D-24, citing Figures D-2a-d (flow fluctuations 2012-2018)

“The 7-day 10-year low flow for this portion of the LDPR is 1,493 cfs.” Exh. A at 2-2 – 2-3; App. A at A-4; *see* Rec. at 2. “This low flow is largely based on design flow of three upstream POTWs discharging into the upstream CAWS, which essentially dictates base flow, especially in winter. *Id.*; *see* App. C at C-9. Because of upstream manipulations and regular flow fluctuation, the demonstration argues that a 7Q10 value “is not wholly applicable to the UDIP/LDPR.” App. D at D-24, n.14.

MG notes that its Will County Generating Station at RM 296 is “[t]he only potentially significant thermal discharger” upstream of the Joliet Stations. App. C at C-9. MG argues that, “[b]ased on the current single-unit operation of the Will County Station” and the demonstration submitted in support of its alternative thermal effluent limitations, “there is no significant upstream thermal effects anticipated for either Joliet Station, based on average weather and river conditions.” *Id.* at C-10.

MG notes three thermal dischargers downstream on the UDIP: Flint Hills Resources, now INEOS, at RM 280.3, Stepan Chemical at RM 280, and the ExxonMobil Joliet Refinery at RM 278.2. App. C at C-10. MG asserts that “[a]ll three have an insignificant impact on the thermal regime of the UDIP, whether assessed individually or collectively.” *Id.*, citing App. D.

Anthropogenic Freshwater Sources. “The MWRDGC owns and controls the upstream CAWS canal system, and works cooperatively with the USACE to adjust waterway levels to accommodate stormwater flows and prevent localized flooding.” App. A at A-5. The CAWS also drains millions of gallons of stormwater runoff and treated wastewater effluent daily. *Id.*

“A small component of CSSC flow is contributed, typically during the summer months, in the form of a diversion from Lake Michigan.” App. A at A-5, citing 615 ILCS 50 (Level of Lake Michigan Act). The diversion includes three components. First, “[d]omestic water supply is used to serve communities and industries.” App. A at A-6. Second, direct diversion provides a safe depth for navigation, and “[d]iscretionary diversion is used to improve water quality.” *Id.* For 2015, average direct diversion was 348.5 cfs. *Id.* Finally, “[s]tormwater runoff is water that has been diverted from the original Lake Michigan watershed (673 square miles) by the reversal of the Chicago and Calumet Rivers.” *Id.* For 2015, average stormwater runoff diversion into the CAW was 859.9 cfs. *Id.*

When significant precipitation is predicted, MWRDGC may direct USACE to lower the level of the Lockport Pool to accommodate stormwater runoff and CSO. App. A at A-6. This increases flows downstream in the UDIP. When precipitation ends, USACE stops flow at the Lockport Lock & Dam to restore the Lockport Pool level. “During these periods, there is little or no flow in the downstream waterway for extended periods of time,” which may affect water quality. *Id.*

Wastewater Treatment Plant Discharges. MWRDGC provides sewage treatment and wastewater service to areas surrounding Chicago. App. A at A-7. Three of MWRDGC’s sewage treatment plants – O’Brien, Calumet, and Stickney – “are the largest contributors of flow to the CSSC, and via the CSSC to the LDPR.” *Id.* The Stickney Plant has a DAF of 1,200 MGD. Under low flow conditions, it “contributes from 70% to 100% of the base-flow of the CSSC, which is the primary source water for the UDIP.” App. C at C-9 (citation omitted). Also, the City of Joliet has a municipal wastewater treatment plant, which discharges into the UDIP just upstream from the Joliet 9 intake. App. A at A-7.

In addition, both Joliet Stations have an on-site sewage treatment plant that discharges to the UDIP. App. A at A-7. The system at Joliet 9 has a DAF of 0.01 MGD, and the system at Joliet 29 has a DAF of 0.04 MGD. *Id.* Both stations discharge under an NPDES permit. *See id.*, n.7.

Combined Sewer Overflows. “MWRDGC owns 35 CSO outfalls located on the CAWS. The City of Chicago, along with the 51 satellite communities, own a total of 408 CSO outfalls which discharge directly or indirectly into the CAWS.” App. A at A-8; *see* App. A, Figure A-3 (Number of Combined Sewer Overflow (CSO) Events in the Chicago Area Waterway System, 2007-2018).

Water Quality

As a result of historical and current industrial and navigational uses, POTW effluents, CSOs, and upstream stormwater runoff, there are many sources of pollutants in the Dresden Pool

of the LDPR. App. A at A-14. While main channel areas “are relatively scoured by barge traffic,” shallow shoreline and backwater and side channel areas accumulate sediments. Sediments have accumulated legacy pollutants that may affect water quality if re-suspended by navigational traffic. *Id.*

Segments near the Joliet Stations have for many years been listed by the State as impaired waters due to Arsenic, Copper, Methoxychlor, DDT, PCBs, TSS, Phosphorus (Total), Mercury, Fecal Coliform, sedimentation/siltation, and flow regime alterations. App. A at A-14. “The sources of these various impairments have been identified as one or more of the following: Industrial Point Source Discharge, Municipal Point Source Discharge, Urban Runoff/Storm Sewers, Contaminated Sediment, Impacts from Hydrostructure Flow Regulation/Modification, Atmospheric Deposition, CSOs, and Unknown Sources.” *Id.* Impairments have decreased over time, but PCB and mercury contamination persist in the LDPR. *Id.*; *see id.* at Table A-2 (Illinois 303(d) List Information for the Lower Des Plaines River Segments near the Joliet Stations).

Stations’ Discharges

Joliet 9. Joliet 9 generates wastewater from “once-through condenser cooling, conditioning boiler feed water, backwashing the condenser cooling water intake screens, sanitary, non-chemical cleaning of plant equipment, low volume wastewater, and precipitation which contacts the site.” App. A at A-14. Operation results in

an average discharge of 45.0 MGD of condenser cooling water and house service water from outfall 001, 0.02 MGD of reverse osmosis reject from outfall A01, 0.02 MGD of sewage treatment plant flow from outfall B01, and intermittent discharge of boiler blowdown from outfall C01, 0.89 MGD of roof and yard area runoff from outfall 003, an intermittent discharge of runoff from the former coal pile from [outfall] 004, and an intermittent discharge of quarry discharge from outfall 005. *Id.*

Permitted discharges enter the UDIP. *Id.*; *see id.*, Exh. A-1 (Joliet 9 NPDES permit).

Joliet 29. Joliet 29 generates wastewater from “once-through condenser cooling, conditioning boiler feed water, backwashing the condenser cooling water intake screens, sanitary, non-chemical cleaning of plant equipment, low volume wastewater, and precipitation which contacts the site.” App. A at A-15. Operations result in

an average discharge of 362.4 MGD of condenser cooling water and house service water from outfall 001; 0.08 MGD of reverse osmosis reject tributary to outfall A01; an intermittent discharge of plant drains, former coal pile and west area basin emergency overflow from outfall B01; an intermittent discharge of boiler blowdown from outfall C01; 0.04 MGD of sanitary from outfall D01; an intermittent discharge of pond 3 effluent from outfall G01; an intermittent discharge of cooling tower area runoff from outfall H01; an intermittent discharge of gas side non-chemical metal cleaning wastes from outfall J01; an intermittent

discharge of junction tower area runoff from [outfall] 002; and an intermittent discharge of vegetated former fill area runoff from outfall 003. *Id.*

Permitted discharges enter the UDIP. *Id.*; *see id.*, Exh. A-2 (Joliet 29 NPDES permit).

Water Temperature

Near the Joliet Stations, mean monthly water temperature “has remained relatively consistent over the past six years, with the only notable departure occurring during the abnormally warm weather/low flow periods of 2012.” App. A at A-20, citing Tables A-3a, A-3b; Figures A-4a, A-4b (intake temperatures).¹

Intake temperatures on the two banks of the river vary slightly because of localized factors. App. A at A-20. “Mean summer intake temperatures for the two Joliet Stations have ranged from 73.7 ° F to 79 ° F. *Id.*, n.15, citing App. D, Tables D-1a, D1-b. Maximum intake temperature was 95.4 ° F at Joliet 9 in July and August 2012 and 92.5 ° F at Joliet 29 in July 2012. Minimum intake temperature was 32.0 ° F at Joliet 9 in January 2014 and 31.2 ° F at Joliet 29 in February 2012. App. A at A-20.

Special Condition 4D of the Stations’ NPDES permits provides that, when it appears that discharges “have the reasonable potential to cause water temperatures at the I-55 Bridge to exceed” specified values, “the permittee shall determine whether, and the extent to which, station operations must be restricted . . . The permittee shall make such a determination based upon the outputs of a predictive model reasonably suited for such a purpose and which has been submitted to the Agency.” App. A, Exh. A-1 at 12, Exh. A-2 at 11-12. From 2012 to 2018, temperatures at the I-55 Bridge “have been, on average 3 °F higher than the corresponding Joliet 29 intake temperature, and ranged from 8.7 °F warmer to 2.1 °F cooler, depending upon the combination of weather, flow, and Joliet Station operating conditions.” App. A at A-21, citing Table A-4.

Dissolved Oxygen

DO concentrations were measured in the UDIP at seven locations from 1977-2011. “Over that time, the mean DO concentration ranged from 6.6 mg/L to 7.9 mg/L, depending on the season.” App. A at A-22, citing Tables A-6a, A-6b. All measured concentrations complied with applicable water quality standards. App. A at A-22, citing 35 Ill. Adm. Code 302.405(b).

Since 1997, MG has monitored DO concentration at the I-55 Bridge. Between 2012 and 2017, “all hourly mean DO measurements met applicable water quality standards,” except one hourly measurement in August 2014 of 3.68 mg/L. App. A at A-23. “In 2018 hourly mean DO concentrations ranged from 4.07 mg/L to 14.41 mg/L.” *Id.* at A-22.

¹ In its response to Board questions, MG reported that the header in the second table in Figure A-4b should read “Joliet Station 29 Maximum Monthly Intake Temperature 2012-2018” and provided a corrected Figure A-4b as Attachment 1. MG Resps. at 4.

Since 1994, adult fisheries monitoring has also measured DO, both between the Brandon Road Lock & Dam and the I-55 Bridge and in the Five-Mile Stretch. App. A at A-23, citing Tables A-5a, A-5b. The lowest minimum DO and highest maximum DO were recorded in areas characterized as sloughs, “which have shallower depths and are more heavily influenced by solar radiation.” App. A at A-23. “There is no indication that the operation of the Joliet Stations has any influence on these slough areas.” *Id.*

The Stations’ NPDES permit requirements had included DO monitoring at intake and discharge. From August 2014 to mid-August 2018, minimum DO levels “were all well over 6.0 mg/L, while the averages were all above 9.0 mg/L. Most importantly, there was no significant difference between the measured intake and discharge DO levels for any sampling date.” App. A at A-23, citing Figures A-5a, A-5b. Based on these DO monitoring results, MG discontinued this monitoring with IEPA’s approval. App. A at A-23 – A-24.

Based on available monitoring data, the demonstration concludes that “the Joliet Stations operations have not been shown to negatively impact DO levels in the UDIP or Five-Mile Stretch.” App. A at A-24.

Fecal Coliform

In the CSSC upstream from the Stations, pathogens “reach the water directly in urban and suburban areas from wastewater treatment plant effluents, CSOs, sewage dumped overboard from recreational boats, pet waste, litter, and garbage.” App. A at A-24. “Due to frequent CSOs in the upstream CAWS, as well as smaller contributions from local sources, the UDIP near the Joliet Stations has been designated as Incidental Contact Recreation Waters.” *Id.*, citing 35 Ill. Adm. Code 303.225(h). Based on this use designation, “UDIP Water Quality Standards do not include a fecal coliform limit.” App. A at A-24, citing 35 Ill. Adm. Code 302.406.

MWRDGC monitored fecal coliform levels in the Dresden Island Pool from 1977 to 2011. Average concentration of fecal coliform ranged from 514 cfu/100mL in the spring to 3,993 cfu/100mL in the summer. App. A at A-25, citing Tables A-6a, A-6b.

“The major source of fecal coliform loading to the system continues to come from multiple CSOs from the upstream Chicago metropolitan area, as well as local POTW CSO discharges.” App. A at A-25. The Stations’ permitted on-site sewage treatment plants have DAFs of 0.01 MGD at Unit 6 and 0.04 at Units 7 & 8. *Id.* The demonstration concludes that “Joliet Station operations have not been shown to impact the levels of fecal coliform in the LDPR.” *Id.*

Mercury

MWRDGC monitored mercury concentrations at seven locations in the Dresden Island Pool in the spring, summer, and fall from 1977 to 2011. “During that time, the average concentration of total mercury ranged from 0.15 µg/L in the spring and fall to 0.18 µg/L in the summer. App. A at A-26, citing Table A-6a. IEPA has identified the segments of the LDPR adjacent to the Stations as impaired for mercury. App. A at A-26.

The Stations have monitored mercury in several of their permitted outfalls. Data collected since 2014 indicate that intake water from the UDIP likely contributes to detectable levels of mercury in the Station's discharge. App. A at A-26. Concentrations are generally higher for cooling water outfalls than internal outfalls. *Id.*, citing Tables A-7a, A-7b.

Based on this information, the demonstration concludes that "Joliet Station 9 and 29 operations have not been shown to have an impact on mercury concentration in the UDIP or Five-Mile Stretch in the past, nor is any adverse impact expected under current or future operating conditions." App. A at A-26.

Nutrients

The UIW has numerous point and nonpoint sources of nutrients, including agricultural runoff. MWRDGC's monitoring program has measured nutrient concentrations in the UDIP and Five-Mile Stretch. App. A at A-26.

Total Nitrogen. MWRDGC monitored nitrate nitrogen concentrations in the Dresden Island Pool from 1977 to 1990 and 1992 to 2011, and it monitored total Kjeldahl nitrogen during many of those years. App. A at A-27; *id.*, n.27; *see id.*, Table A-6a (mean concentrations).

The Stations do not routinely use nitrogen-based products in their processes, and any use of those products has been approved by IEPA. App. A at A-27. Both Stations have implemented site-specific Stormwater Pollution Prevention Plans addressing potential runoff. *Id.*; *see* Exh. A-1 at 16-20; Exh. A-2 at 15-19.

Based on these factors, the demonstration concludes that "Joliet Station 9 and 29 operations have not been shown to impact the levels of total nitrogen found in the UDIP or Five-Mile Stretch." App. A at A-27

Total Phosphorus. Wastewater treatment plants and urban and agricultural nonpoint sources are generally the major contributors of phosphorus. App. A at A-28. From 2002 through 2010, Illinois identified phosphorus as a cause of impairment in the Five-Mile Stretch. Improved wastewater treatment practices and reduced use of phosphorus-based products resulted in removing phosphorus from the list of impairments for that segment. App. C at C-5.

MWRDGC monitored total phosphorus in the Dresden Island Pool from 1977 to 2011 and found concentrations ranging from 0.69 mg/L in the spring and 0.90 mg/L in the fall. App. A at A-28, citing Table A-6a, A-6b. However, no phosphorus water quality limits now apply to the UDIP. App. A at A-28. Phosphorus discharges are chiefly regulated by effluent limitations directed at municipal and domestic wastewater treatment facilities. *Id.* On-site sewage treatment plants at the Stations have DAF "below the threshold of concern (>1 MGD) for any significant phosphorus discharge." *Id.* Neither Station uses phosphorus-based additives, other than those approved by IEPA with no significant presence in discharges. *Id.*

Based on these factors, the demonstration concludes that "the operation of the Joliet Stations 9 and 29 does not have any impact on the overall phosphorus concentrations in the

UDIP or Five-Mile Stretch, which remain primarily influenced by upstream POTW effluent discharges.” App. A at A-28.

Ammonia. In the CAWS, common sources of ammonia include “fertilizer application and run-off, treated and untreated municipal treatment works discharges, and industrial effluents. App. A at A-29. MWRDGC monitored ammonia nitrate levels from 1977 to 2011. *Id.* “[A]mmonia nitrogen decreased from approximately 2.0 mg/L – 2.8 mg/L in the spring and fall of 1977, respectively, to less than 1.0 mg/L in the spring, summer, and fall for years 1995-2011. *Id.* at A-27, citing Tables A-6a, A-6b. These concentrations are consistently below the applicable limit of 15 mg/L. *Id.*, citing 35 Ill. Adm. Code 302.412(b).

While the Stations sometimes use ammonia-based additives, IEPA has approved these uses. App. A at A-29.

Based on these factors, the demonstration concludes that operation of the Joliet Station is “unlikely to have any impact on the level of ammonia nitrate in the UDIP or Five-Mile Stretch.” App. A at A-29.

PCBs

“IEPA has identified PCB concentration in fish tissue as impairing fish consumption” in the LDPR from the Brandon Road Lock & Dam to the confluence with the Kankakee River. App. A at A-20. The LDPR “has a long-standing fish-consumption advisory related to PCB and related to contamination due to legacy bottom contaminants.” *Id.*; *see* App. C at C-7 – C-8.

The demonstration states that “[t]here is no PCB-containing equipment located at either of the Joliet Station properties and operations have not been show to impact the levels of PCBs in the UDIP or the Five-Mile Stretch.” App. A at A-29; *see* App. A at A-45.

Silver

MWRDGC monitored silver concentrations from 1977 to 2011. Annual mean concentrations measured 0.003 mg/L for spring, summer, and fall. App. A at A-30, citing Table A-6a. MWRDGC also calculated location-specific means in the Dresden Island Pool for 2008 – 2011. App. A at A-30, citing Table A-6b. “All silver levels have remained consistently at or below detection levels.” App. A at A-30. MG also performs semi-annual metals monitoring under Special Condition 15 of the Stations’ NPDES permits. App. A at A-30; *see* Exh. A-1 at 15; Exh. A-2 at 14-15.

Based on these factors, the demonstration concludes that “station operations have not been shown to impact the levels of silver found in the UDIP or Five-Mile Stretch.” App. A at A-30.

Other Metals

Other common metals can occur naturally and from industrial and municipal effluents: arsenic, cadmium, chromium, copper, lead, nickel, selenium, and zinc. App. A at A-30. “There is no current aquatic life impairment identified in the UDIP/Five-Mile Stretch near the Joliet Stations for metals other than mercury.” *Id.*

MWRDGC monitored several of these metals from 1977 to 2011. App. A at A-30 – A-31; citing Table A-6b. The Stations have also monitored total metals as required by Special Condition 15 of their permit. App. A at A-31 (water quality comparisons); *see* Table A-8b; Exh. A-1 at 15; Exh. A-2 at 14-15.

Based on the results from this monitoring, the demonstration concludes that “Joliet Station operations have not influenced the levels of metals found in the UDIP or Five-Mile Stretch.” App. A at A-31.

pH

Based on MWRDGC monitoring data from 1977 to 2011, “mean pH in the Dresden Island Pool has ranged from 7.3 in the spring to 7.4 in the summer and fall.” App. A at A-32, citing Table A-6a. The demonstration also includes location-specific means for the Dresden Pool. App. A at A-32, citing Table A-6b. “All of these values fall within the accepted water quality range on 7 to 9 pH units.” App. A at A-32, citing 35 Ill. Adm. Code 302.404 (pH).

The demonstration concludes that the Stations’ required monitoring has shown no violations of pH limits and that they “have not impacted pH levels in the waterway.” App. A at A-32.

TOC

MWRDGC monitoring data from 1983 and 1985-94 show that mean concentrations of TOC in the Dresden Island Pool ranged from 8 mg/L in the summer to 11 mg/L in the spring. App. A at A-32, citing Table A-6a.

The demonstration states that “TOC is not an environmental pollutant and at the levels observed, has had no adverse impact on the aquatic community in the UDIP or Five-Mile Stretch.” App. A at A-32. MG adds that “[t]he Joliet Stations have not affected TOC levels in the Dresden Island Pool of the LDPR.” *Id.*

Specific Conductance

For 2012-2018, mean specific conductance at nine sampling locations upstream from the I-55 bridge ranged from 849 $\mu\text{S}/\text{cm}$ to 913 $\mu\text{S}/\text{cm}$ depending on location, season, and flow. App. A at A-32, citing Table A-5a. At four sites downstream from the I-55 Bridge to the confluence of the Kankakee River, specific conductance ranged from 904 $\mu\text{S}/\text{cm}$ to 1,002 $\mu\text{S}/\text{cm}$. App. A at A-32, citing Table A-5b.

From 1977-2011, MWRDGC measured specific conductance in the Dresden Island Pool. It averaged 762 $\mu\text{S}/\text{cm}$ in the summer and 1,091 $\mu\text{S}/\text{cm}$ in the spring. App. A at A-32. For 2008-2011, specific conductance at monitoring locations upstream from the I-55 Bridge averaged 906 $\mu\text{S}/\text{cm}$, while locations downstream from it averaged 872 $\mu\text{S}/\text{cm}$. *Id.* at A-33, citing Table A-6b

The demonstration states that “Joliet Station operations have not been shown to affect specific conductance levels in the UDIP or Five-Mile Stretch.” App. A at A-33.

Water Transparency

Based on MWRDGC monitoring in the Dresden Island Pool from 1977 to 2011, “mean TSS concentrations ranged from 22 mg/L in the summer to 30 m/L in the spring.” App. A at A-33, citing Tables A-6a, A-6b. MG also measured water transparency based on Secchi disk measurements. App. A at A-33, citing Table A-5b.

The Stations’ NPDES permits include TSS limitations “to prevent adverse changes in water transparency.” App. A at A-33; *see* Exhs. A-1, A-2. “To date there have been no exceedances of the TSS limit, showing that Joliet Stations operation has not had adverse impact on TSS levels, and therefore water transparency, in the UDIP or Five-Mile Stretch.” *Id.*

Aquatic Habitats

From 1993 to 1995, a comprehensive UIW study included extensive habitat surveys of the UDIP and Lower Dresden Island Pool. App. A at A-46. The surveys used QHEI to evaluate habitat quality. *Id.*; App. E at E-6. QHEI corresponds to physical factors “that affect fish communities and which are generally important to other aquatic life.” App. C at C-13. QHEI scores are “based on six interrelated factors: substrate, instream cover, channel morphology, riparian and bank condition, pool and riffle quality, and gradient.” *Id.* Narrative ratings assigned to numeric QHEI scores are as follows:

Narrative Rating	QHEI Range	
	Headwaters	Larger Streams
Excellent	> 70	> 75
Good	55 to 69	60 to 74
Fair	43 to 54	45 to 59
Poor	30 to 42	30 to 44
Very Poor	< 30	0

Id.

A 2003 study surveyed the entire Dresden Pool at 0.5-mile intervals, and a 2008 study provided QHEI data for both banks of the UDIP near the Joliet Stations. App. A at A-46; *see* App. E at E-6. Both studies were performed as part of the Use Attainability Analysis for the LDPR. App. A at A-46, citing Water Quality Standards and Effluent Limitations for the Chicago Area Waterway System (CAWS) and the Lower Des Plaines River: Proposed Amendments to 35 Ill. Adm. Code 301, 302, 303 and 304, R 08-9.

Surveys generally showed that habitat upstream of Brandon Road Lock & Dam was poor. Although habitat improves downstream from it, “scores were still typically in the ‘fair’ to ‘poor’ range.” App. A at A-46, citing App. K, Exh. C-3 (QHEI scores); App. E at E-6. QHEI scores obtained from 2016 to 2018 at long-term electrofishing locations were consistent with previous scores. App. A at A-46. Based on these results, the demonstration concludes that “aquatic habitat conditions have remained relatively unchanged since the initial QHEI assessments were made in the mid-1990s to the mid-2000s.” *Id.*, citing App. K; App. E at E-7.

Habitat Types

The UDIP near the Stations “is a modified, impounded waterway that continues to be subject to upstream anthropogenic influences.” App. A at A-47. The UDIP’s habitat is 79% main channel and main channel border, “areas where the effects of barge transport and industrial and municipal discharges are especially dominant.” *Id.* Habitat quality near the Stations is largely considered fair to poor due to: “1) the lack of functional riffle/run habitat; 2) sparse amounts of clean, hard substrates (*i.e.*, gravel, cobble, and boulder); 3) excessive siltation, particularly in the shallow littoral zone areas; 4) channelization; 5) poor riparian and floodplain quality; and 6) a general lack of instream cover, except for macrophytes in the shallow littoral zone area.” *Id.*, citing App. K, Exhs. C-1 (habitat map), C-2 (aquatic and riparian habitat), C-3 (QHEI survey results).

While habitat variety is greater in the UDIP than in the CSSC, UDIP habitats are subject to stressors including commercial navigation and flood control management. App. A at A-47. For example, frequent barge traffic can generate significant local turbulence, and flood control can affect water levels and flows. *Id.* at A-47 – A-48.

Substrates

“Silt over bedrock or hardpan substrates characterize the majority of the main channel area.” App. A at A-4. Unnatural stream flow dynamics have deposited homogeneous silt sediment through much of the UIW, which “can result in unfavorable conditions for macroinvertebrate and fish populations.” App. A at A-48. While finer substrate supports macrophyte production, providing habitat and food for aquatic and semi-aquatic animals, excessively dense vegetation has limited habitat and affected water quality. *Id.* “There is limited instream cover or rooted aquatic vegetation in the immediate vicinity of the Joliet Stations.” *Id.* at A-4. In addition, regular barge traffic disturbs the bottom substrate and re-suspends sediments, which can adversely affect aquatic communities. *Id.* at A-48. Substrate characteristics continue to limit habitat suitability in the UDIP and Five-Mile Stretch. *Id.*

Aquatic Life.

Aquatic Macrophytes

A 1992-1995 study of aquatic macrophytes on a 53-mile stretch of the UIW from Upper Lockport Pool “yielded 34 distinct aquatic macrophytes, most of which are common and relatively pollution-tolerant.” App. A at A-49; *see* App. E at E-14. A more limited 2017 survey

along the banks of the UDIP from the Brandon Road Dam tailwater to the I-55 Bridge recovered eight species. App. A at A-50, citing App. K. The demonstration states that the areas of the historically highest diversity and density were outside the area of the 2017 study. App. A at A-50.

The demonstration notes that areas in the Dresden Island Pool have experienced macrophyte proliferation. App. A at A-50, citing App. K; *see* App. E at E-14. This has hampered sampling efforts and reduced the fisheries monitoring at several locations in the Five-Mile Stretch. *Id.*, citing App. H, §§ 2, 4. However, the demonstration argues that “[t]his excess growth is not caused by upstream power plant operations, but is likely the result of a combination of nutrients and high productivity in shallow off-channel areas.” App. A at A-50.

Phytoplankton and Periphyton

Near the Joliet Stations, the phytoplankton community and densities “reflect the overall assemblage of the CAWS.” App. A at A-50. Studies indicated that the community “was low for species diversity and evenness.” *Id.*; *see* App. E at E-7 – E-8. “Morisita’s index (a similarity index comparing intake and discharge data) indicated that the community upstream of the stations was closely related to that of the discharge.” App. A at A-50 – A-51. The demonstration argues that these factors indicate that the stations have not adversely affected the plankton community. *Id.* at A-51.

Zooplankton

Zooplankton sampling near the stations has been limited. *See* Exh. A at 6-4; App. E at E-9. The demonstration asserts that thermal discharges are not expected to affect zooplankton adversely because they have evolved tolerances, are rapidly transported by currents, and have high reproductive capacities. App. A at A-51.

Benthic Invertebrates

Surveys of the UDIP and Five-Mile Stretch have shown a community consisting “primarily of environmentally tolerant to, at best, facultative taxa.” App. A at A-51. Studies from 1993-94 concluded that habitat condition, sedimentation, and water quality issues other than temperature influenced community composition. *Id.*; *see* App. E at E-11. Studies conducted in 2000 “showed a dominance of tolerant taxa in the Dresden Pool.” App. A at A-52. Results of a 2017-18 assessment “were generally consistent with historic results in the sense that the community continues to be dominated by a tolerant and/or facultative fauna.” *Id.*, citing App. L; *see* App. E at E-11.

Mussels

The demonstration argues that “there is minimal suitable habitat for mussels in the parts of the UDIP influenced by the Joliet Stations’ thermal plume.” App. A at A-53. State agencies reviewed the Stations’ DSP and generally agreed that “significant mussel populations do not

exist in the UDIP.” *Id.* at A-52. Even if present, the buoyant thermal plume would not be expected to have a negative effect on them. *Id.* at A-53.

Sampling in the LDPR in 1994 and 2000 found a small number of mussel species, including invasive species. App. A at A-52; App. E at E-12. The demonstration argues that neither habitat nor the mussel assemblage has appreciably changed over time. App. A at A-52. However, a 2017 survey conducted just downstream from the Stations yielded 275 mussels representing eight species. App. A at A-53 – A-54; App. E at E-13. The survey did not collect live or relic shells of any threatened or endangered state or federal listed species. App. A at A-54; App. E at E-13. The demonstration argues that these data support the conclusion that additional surveys are not necessary because the Stations’ operations had not affected mussels in the UDIP or the LDPR as a whole and were not likely to do so in the future. App. A at A-54.

Fish

The fish community in the UIW has been monitored since 1994. App. A at A-54, *see* App. E at E-14 – E-16. Habitat in the UDIP and Five-Mile Stretch “supports a community of tolerant and moderately tolerant species.” App. A at A-54; *see id.* at A-61 – A-62. “[I]ntolerant species continue to account for a small percentage of the assemblage.” App. A at A-62. IWBmod scores for the fish community below the Brandon Road Lock & Dam have consistently rated as fair. *Id.* at A-55, *see* App. C, Figure C-16. Recent monitoring results show that the fish community has remained comparable to earlier years when the Stations ran in a more base-load manner, suggesting that the community “is largely unaffected by the overall thermal regime of the waterway.” App. E at E-16. The demonstration argues that “[t]he past, present and expected future fisheries assemblage is driven by the prevailing habitat and water quality conditions of this artificially controlled waterway.” App. A at A-54; *see id.* at A-61, A-62.

Birds

The bird population near the Joliet Stations includes numerous resident and migratory species. App. A at A-56 – A-57. Several state-listed species are commonly found in areas near the Stations. *Id.* at A-57. However, the demonstration argues that “[t]here is no reason to suspect that any of these species would be negatively impacted by the Joliet Stations’ operations or the proposed thermal AELs.” *Id.*

Threatened and Endangered Species

Federally-listed threatened and endangered species for Will County include no fish and one endangered mussel species. App. A at A-57; *see id.*, Table A-11; App. C at C-27. However, the demonstration argues that habitat near the Stations is not conducive to mussel species. App. A at A-57. The most recent mussel survey of the UDIP “encountered no federally or state-listed threatened or endangered mussels.” *Id.* at A-58. The federal list includes mammals and plants, but the demonstration asserts that “[t]hese species are not expected to be affected by operation of the Joliet Stations or their thermal discharge.” *Id.*; App. C at C-27.

While state-listed threatened and endangered species for Will County include 11 fish and six mussel species, the demonstration argues that the LDPR habitat is not conducive to mussels. App. A at A-58; *see id.*, Table A-12; App. C at C-27. Long-term fisheries monitoring has collected state-listed species. App. A at A-58, citing App. C, Table C-7. Since 2012, the state-threatened Banded Killifish has been collected in the UDIP and Five-Mile Stretch. App. A at A-58. Total catch of Banded Killifish has steadily increased since 2012, with a reduction in 2018. *Id.* at A-58 – A-59; *see* App. C, Table C-7. The demonstration argues that this suggests the Stations’ thermal discharges do not adversely affect this species. App. A at A-59. It notes that, in a separate proceeding, IDNR found that thermal discharges to the CSSC were not likely to have an adverse effect on the Banded Killifish. *Id.*, citing Midwest Generation v. IEPA, PCB 18-58 (Apr. 2, 2018).

In addition to fish and mussel species, five reptile and two amphibian species are listed for Will County. App. A at A-59 – A-60. However, “[t]here are no expected adverse impacts expected for any of these species as the result of current or expected future Joliet Station operations.” *Id.* at A-60.

Other Wildlife

A 2013 assessment of the area near the Stations found degraded terrestrial wildlife communities. “The area near the Joliet Stations has very little vegetation and high levels of human use.” However, the demonstration argues that none of the species noted in the area “would be expected to be impacted by the Joliet Station 9 and/or Joliet Station 29 thermal discharges.” App. A at A-60.

LEGAL BACKGROUND

It is unlawful for any person to discharge a pollutant from a point source into waters of the United States without a permit under the CWA. 33 U.S.C. § 1311(a). Because heat is a pollutant (33 U.S.C. § 1362(6)), heated discharges require a permit. In general, discharge limitations in a permit are technology-based or water-quality based. 33 U.S.C. § 1311(b). Technology-based effluent limits generally are developed for an industry and reflect the “best available technology economically achievable.” 33 U.S.C. § 1311(b)(2)(A); *see, e.g.*, 40 C.F.R. Parts 405–471.

Water quality-based effluent limits ensure that water quality standards are met regardless of technology or economics considered in establishing technology-based limits. Water quality-based effluent limits are defined as “any more stringent limitation, including those necessary to meet water quality standards, treatment standards, or schedules of compliance, established pursuant to any State law or regulations . . . or any other Federal law or regulation, or required to implement any applicable water quality standard.” 33 U.S.C. § 1311(b)(1)(C).

Thus, if a discharge from a point source interferes with attainment or maintenance of a water quality standard, an effluent limitation is established for that discharge, regardless of any other technology-based standard. 33 U.S.C. §§ 1311(b)(1)(C), 1312(a); *see also* 35 Ill. Adm. Code 304.105 (Violation of Water Quality Standards). Water quality standards are set under

authority provided in Section 303 of the CWA (33 U.S.C. § 1313). Illinois law authorizes the Board to adopt water quality standards, including thermal standards. 415 ILCS 5/13 (2018). The Board adopted water quality temperature standards for the CAWS at 35 Ill. Adm. Code 302.408.

Since adoption of the CWA in 1972, Section 316(a) has allowed a point source with a thermal discharge to obtain relief from otherwise applicable thermal effluent limitations. Specifically, CWA Section 316(a) provides that,

[w]ith respect to any point source otherwise subject to the provisions of section 1311 of this title or section 1316 of this title, whenever the owner or operator of any such source, after opportunity for public hearing, can demonstrate to the satisfaction of the Administrator (or, if appropriate, the State) that any effluent limitation proposed for the control of the thermal component of any discharge from such source will require effluent limitations more stringent than necessary to assure the protection and propagation of a balanced, indigenous population of shellfish, fish, and wildlife in and on the body of water into which the discharge is to be made, the Administrator (or, if appropriate, the State) may impose an effluent limitation under such sections for such plant, with respect to the thermal component of such discharge (taking into account the interaction of such thermal component with other pollutants), that will assure the protection and propagation of a balanced, indigenous population of shellfish, fish, and wildlife in and on that body of water. 33 U.S.C. § 1326 (Thermal Discharges).

Accordingly, Section 304.141(c) of the Board’s rules provides that:

[t]he standards of this Chapter shall apply to thermal discharges unless, after public notice and opportunity for public hearing, in accordance with section 316 of the CWA, and applicable federal regulations, and procedures in 35 Ill. Adm. Code 106.Subpart K, the Board has determined that different standards shall apply to a particular thermal discharge. 35 Ill. Adm. Code 304.141(c).

Therefore, under Section 316(a) of the CWA and 35 Ill. Adm. Code 304.141(c), the Board may establish “alternative thermal effluent limitations” based on a demonstration that the alternate limits will assure the protection and propagation of a balanced, indigenous population of shellfish, fish, and wildlife in the receiving water. Part 106, Subpart K of the Board’s rules provides for review of a petition for an alternative thermal effluent limitation. 35 Ill. Adm. Code 106.1100–106.1180. Establishing alternative thermal effluent limitations is not a change in the water quality standard.

In 1977, USEPA issued a draft manual on demonstrations under CWA Section 316(a). This “USEPA 316(a) Manual” provides that it “is intended to be used as a general guidance and as a starting point for discussions,” and that delegated state agencies “are not rigidly bound by the contents of this document.” USEPA 316(a) Manual at 8–9. This USEPA guidance remains a draft. Nevertheless, the Board has found that the “decision criteria” in the USEPA 316(a) Manual are a useful guide for the Board’s analysis, and the Board has followed the guidance’s decision-making outline. Exelon Generation LLC v. IEPA, PCB 14-123, slip op. at 2 (Sept. 18,

2014). Further, Section 106.1120 of the Board’s rules requires a petitioner seeking alternative thermal effluent relief to consider guidance published by USEPA in making its demonstration. *See* 35 Ill. Adm. Code 106.1120(e). In 1979, USEPA promulgated rules implementing CWA Section 316(a) which are codified at 40 C.F.R. 125.Subpart H.

TEMPERATURE WATER QUALITY STANDARDS

Background

Under Illinois’ use designations, the UDIP “was formerly designated as a Secondary Contact and Indigenous Aquatic Life Water.” Pet. at 16, citing 35 Ill. Adm. Code 303; App. A at A-16; App. D at D-9. Regulations for this designation “were less stringent than the General Use water quality standards that applied to most waters of the state.” Pet. at 16; Exh. A at 3-1; *see* 35 Ill. Adm. Code 303.201; App. D at D-9.

In 2007, IEPA presented UAAs to the Board. IEPA argued that these analyses showed the UDIP “had attained, or had the potential to attain, higher designated recreational and aquatic life uses “under the CAA than the secondary contact designation. Pet. at 17; *see* App. A at A-16. In the rulemaking based on the UUAAs, the Board redesignated the UDIP to a “UDIP Water” use:

Lower Des Plaines River from the Brandon Road Lock and Dam to the Interstate 55 bridge is designated as the Upper Dresden Island Pool Aquatic Life Use. These waters are capable of maintaining, and shall have quality sufficient to protect, aquatic-life populations consisting of individuals of tolerant, intermediately tolerant, and intolerant types that are adaptive to the unique flow conditions necessary to maintain navigational use and upstream flood control functions of the waterway system. Such aquatic life may include, but is not limited to, largemouth bass, bluntnose minnow, channel catfish, orangespotted sunfish, smallmouth bass, shorthead redhorse, and spottail shiner. 35 Ill. Adm. Code 303.230(a); *see* Water Quality Standards and Effluent Limitations for the Chicago Area Waterway System (CAWS) and the Lower Des Plaines River: Proposed Amendments to 35 Ill. Adm. Code 301, 302, 303 and 304, PCB 08-9(C); Exh. A at 3-1 – 3-2; App. A at A-17; App. D at D-9 – D-10.

Temperature Standards

The Board adopted thermal standards for the UDIP in 35 Ill. Adm. Code 302.408, the relevant provisions of which are:

* * *

- b) The temperature standards in subsections (c) through (i) will become applicable beginning July 1, 2018. Starting July 1, 2015, the waters designated at 35 Ill. Adm. Code 303 as Chicago Area Waterway System Aquatic Life Use A, Chicago Area Waterway System and Brandon Pool Aquatic Life Use B, and Upper Dresden Island Pool Aquatic Life Use will not exceed temperature (STORET number (°F) 00011 and (°C) 00010) of 34°C (93°F) more than 5% of the time, or 37.8°C (100°F) at any time.

- c) There shall be no abnormal temperature changes that may adversely affect aquatic life unless caused by natural conditions.
- d) The normal daily and seasonal temperature fluctuations that existed before the addition of heat due to other than natural causes shall be maintained.
- e) The maximum temperature rise above natural temperatures shall not exceed 2.8°C (5°F).
- f) Water temperature at representative locations in the main river shall not exceed the maximum limits in the applicable table in subsections (g), (h), and (i) during more than one percent of the hours in the 12-month period ending with any month. Moreover, at no time shall the water temperature exceed the maximum limits in the applicable table that follows by more than 1.7°C (3.0°F).

* * *

- i) Water temperature for the Upper Dresden Island Pool Aquatic Life Use waters, as defined in 35 Ill. Adm. Code 303.230, shall not exceed the limits in the following table in accordance with subsection (f):

Months	Daily Maximum (°F)
January	60
February	60
March	60
April	90
May	90
June	90
July	90
August	90
September	90
October	90
November	90
December	60

35 Ill. Adm. Code 302.408; *see* Pet. at 18-19; Exh. A at 3-2 – 3-3; App. A at A-19 – A-20; App. D at D-10 – D-11.

General Use temperature standards apply to the Five-Mile Stretch downstream of the I-55 Bridge. However, under a 1996 Board order modified in 2000, the Stations are subject to adjusted thermal limits at the I-55 Bridge. Exh. A at 3-3, citing Petition of Commonwealth Edison for Adjusted Standard from 35 Ill. Adm. Code 302.211(d) and (e), AS 96-10; *see* App. A at A-21; App. A, Exh. A-1 at 12, Exh. A-2 at 11.

The relevant provisions of the General Use temperature standards in 35 Ill. Adm. Code 302.211 are as follows:

* * *

- b) There shall be no abnormal temperature changes that may adversely affect aquatic life unless caused by natural conditions.
- c) The normal daily and seasonal temperature fluctuations which existed before the addition of heat due to other than natural causes shall be maintained.
- d) The maximum temperature rise above natural temperatures shall not exceed 2.8 °C (5 °F).
- e) In addition, the water temperature at representative locations in the main river shall not exceed the maximum limits in the following table during more than one percent of the hours in the 12-month period ending with any month. Moreover, at no time shall the water temperature at such locations exceed the maximum limits in the following table by more than 1.7 °C (3 °F).

Months	Daily Maximum (°F)
January	60
February	60
March	60
April	90
May	90
June	90
July	90
August	90
September	90
October	90
November	90
December	60

The relevant portions of the modified adjusted standard (Petition of Commonwealth Edison for Adjusted Standard from 35 Ill. Adm. Code 302.211(d) and (e), AS 96-10) are as follows:

* * *

- 2. The alternate thermal standards shall apply at the I-55 Bridge as limitations for discharges from the above listed generating stations [including Joliet].
- 3. In lieu of the requirements of 35 Ill. Adm. Code 302.211(d) and (e), the following standards will apply:

Months	Daily Maximum (°F)
January	60
February	60
March	65
April (1-15)	73
April (16-30)	80
May (1-15)	85
May (16-31)	90
June (1-15)	90
June (16-30)	91
July	91
August	91
September	90
October	85
November	75
December	65

4. The standards may be exceeded by no more than 3 degrees Fahrenheit during 2% of the hours in the 12-month period ending December 31, except at no time shall Midwest's generating stations cause the water temperature at the I-55 Bridge to exceed 93 degrees Fahrenheit.
5. Midwest's generating stations continue to be subject to the Secondary Contact Standards at the point of discharge.

Request for Regulatory Relief

While the Board concluded that waters designated UDIP Use should have the same thermal water quality standards as General Use waters, it recognized that some dischargers may need to seek relief from those thermal standards. Pet. at 17. The Board delayed the effective date of the thermal standard three years to 2018. *Id.* at 2, 17-18, citing Water Quality Standards and Effluent Limitations for the Chicago Area Waterway System (CAWS) and the Lower Des Plaines River: Proposed Amendments to 35 Ill. Adm. Code 301, 302, 303 and 304, PCB 08-9(D), slip op. at 77 (Mar. 19, 2015).

On July 21, 2015, MG petitioned the Board for a variance from the new thermal water quality standards. Midwest Generation v. IEPA, PCB 16-19; see 415 ILCS 5/35 (2018). Before those standards became effective, Public Act 99-937, effective February 24, 2017, authorized the Board to issue TLWQS. See 415 ILCS 5/38.5 (2018). If a discharger applies for a TLWQS from a water quality standard, then under specified conditions the standard will be stayed while the Board decides the petition. When the thermal standards became applicable in 2018, MG's discharges were subject to a stay because of its variance petition. See 415 ILCS 5/38(b) (2018). That variance petition was converted into a TLWQS petition by operation of law. See 415 ILCS

5/38.5(c) (2018). On the date MG filed its petition in this case, that stay remained in effect. Pet. at 19, n.11; *see* App. D at D-11; Exh. A at 3-2, n.4.

Compliance with Thermal Limits

Near-Field

The Joliet Stations measure compliance with near-field thermal limits with an IEPA-approved site-specific model. The model uses “real-time station operating data and 24-hour antecedent flow to calculate fully mixed temperatures in the main body of the waterway.” Exh. A at 3-3; *see* App. D at D-12. Model results “have been demonstrated to be equivalent to the approximate edge of the allowed 26-acre mixing zone for each station.” Exh. A at 3-3 – 3-4., citing App. D, Exh. D-1a.

MG states that the Joliet Stations comply with the interim thermal standards at 35 Ill. Adm. Code 302.408(b). Pet. at 20; *see* Exh. A at 3-3. MG’s modeling demonstrates that the Stations could meet the winter standards “under typical winter weather and canal flow conditions.” Pet. at 20. During extreme summer weather, however, MG argues that historical data and its modeling shows that the Stations’ discharges could not consistently meet the summer limits in the UDIP. *Id.*; *see* Exh. A at 3-6. “The results also show that these discharges would not consistently meet the General Use Standard’s summer numeric limit of 90 °F nor the 93 °F maximum limit in the Five-Mile Stretch.” Pet. at 20.

MG characterizes the number of allowable excursion hours as “small.” Pet. at 20. MG argues that they “are entirely insufficient to support Joliet Station 9 or 29 operations during both the summer and winter months, especially if unseasonal weather patterns and/or low flow conditions persisted during any given year.” *Id.*

Citing historical operating and flow data, MG expects “that a 75% or greater zone of passage under the proposed maximum thermal AELs would continue to be available in the UDIP near Joliet Stations 9 and 29, even under the worst-case modeled conditions.” Pet. at 20. While erratic flows may cause the dilution ratio to drop below 3:1, MG argues that its demonstration “shows that the Joliet Stations would be able to comply with the lower 50% zone-of-passage requirement during that time.” *Id.* MG concludes that thermal discharges from the stations would meet existing zone of passage requirements. *Id.*

Far Field

The Stations measure far-field compliance with thermal limits through “real-time monitoring equipment maintained by the Joliet Stations at the I-55 Bridge location.” Exh. A at 3-4, citing App. D, Exh. D1-b; *see* App. A at A-21. MG states that, under a 1996 Board order modified in 2000, the Stations are subject to adjusted alternate thermal limits at the I-55 Bridge. Exh. A at 3-3, citing Petition of Commonwealth Edison for Adjusted Standard from 35 Ill. Adm. Code 302.211(d) and (e), AS 96-10; *see* App. A at A-21; App. A, Exh. A-1 at 12, Exh. A-2 at 11. MG argues that “[t]he Joliet Stations’ thermal discharges have consistently complied with these limitations, including during their long history as base-load facilities.” Exh. A at 3-3.

PROPOSED ALTERNATIVE THERMAL EFFLUENT LIMITATIONS

Proposed UDIP Standards and Comparisons

MG's petition includes a table comparing prior secondary contact standards, standards that took effect on July 1, 2018, and its proposed alternate limits:

Month	Prior Secondary Contact Standards & Interim 35 Ill. Adm. Code 302.408(b) Standards	2018 UDIP Use Thermal Standards (Applicable July 1, 2018)	Proposed UDIP Thermal ATELS
	Daily Maximum (°F)	Daily Maximum (°F)	Daily Maximum (°F)
January	93	60	65
February	93	60	65
March	93	60	70
April	93	90	80
May	93	90	85
June	93	90	93
July	93	90	93
August	93	90	93
September	93	90	93
October	93	90	90
November	93	90	85
December	93	60	70
Excursion Hours	Shall not exceed 93 °F more than 5% of the time, or 100°F at any time	Shall not exceed maximum limits during more than 1% of the hours in the 12-month period ending with any month; at no time shall water temperature exceed the maximum limits by more than 3.0 °F	Daily maximum not to be exceeded by more than 5% of the time in a calendar year; at no time shall water temperature exceed the maximum limits by more than 3 °F

Pet. at 32; Exh. A at 3-12; App. B at B-48; *see* MG Resps. at 8 (clarifying Pet. at 21).

MG's proposed standards for the Joliet Stations "would be effective at the edge of their allowed 26-acre mixing zones." Exh. A at 3-12; *see* App. B at B-48. MG would measure compliance

through the existing near-field compliance model. Exh. A at 3-12, citing App. D, Exh. D-1a; *see* Exh. A at 3-15; App. D at D-12. Far-field ATELS apply at the I-55 Bridge, and MG “will continue to rely on its Far-Field Thermal Compliance Model, as necessary, to ensure continuing compliance.” MG Resps. at 8, citing Pet. at 13, 14, 32; Exh. A at 3-4, 3-15; App. D, Exh. D-1b.

MG reports that far-field compliance temperatures will continue to be based on a calibrated real-time temperature monitoring system installed at the I-55 Bridge. This differs from near-field compliance, which will be a calculated value based on the output of each Station’s Near-Field Compliance Model. MG Resps. at 8. MG acknowledges that, to clarify reporting and assessing compliance under the proposed ATELS, it will be necessary to include separate requirements for the Near-Field and Far-Field. *Id.* The Stations’ NPDES permits already detail this in Special Condition 4, which MG indicated could be modified as part of implementation. *Id.* Consequently, MG “does not believe that these details need to be included in the language of the AELs.” *Id.*

MG notes that the UDIP Use standards include the following narrative requirements:

- c) There shall be no abnormal temperature changes that may adversely affect aquatic life unless caused by natural conditions.
- d) The normal daily and seasonal temperature fluctuations that existed before the addition of heat due to other than natural causes shall be maintained.
- e) The maximum temperature rise above natural temperatures shall not exceed 2.8 °C (5 °F). 35 Ill. Adm. Code 302.408(c), (d), (e).

MG cites a recent Board order granting its petition for ATELS for its Will County Generating Station. MG argues that the Board found it generally appropriate to grant ATELS when the applicant proposed standards more stringent than “historical thermal standards that were shown to be protective of the waterway’s BIC.” Pet. at 23, citing Midwest Generation v. IEPA, PCB 18-58, slip op. at 67 (Nov. 7, 2019). MG asserts that the UDIP has been adequately protected by standards including only numeric criteria. Pet. at 22. MG argues that its proposed ATELS “are more stringent than the prior Secondary Contact and Indigenous Aquatic Life limits and logically should also not result in appreciable harm.” *Id.* It argues that its demonstration shows that its proposed numeric standards will continue to protect the UDIP. *Id.* Based on these factors, MG’s proposed standards do not include narrative criteria. *Id.*; *see id.* at 30, 32; Exh. A at 3-9, 3-10; App. B at B-49.

MG also notes that the 2018 standards provide that water temperatures shall at no time exceed the daily maximum limit by more than “3.0 °F.” Pet. at 21, n.12, citing 35 Ill. Adm. Code 302.408(f). However, the general use water quality standards limit this maximum excursion to “3 °F.” Pet. at 21, n.12, citing 35 Ill. Adm. Code 302.211(e). MG argues that, because the 2018 thermal standards intended to be consistent with the General Use thermal standards, it proposes a maximum excursion temperature of “3 °.” Pet. at 21, n.12; *see* App. B at B-49. MG adds that the Board granted ATELS for the Will County Generating Station that

include an excursion limit of “3 °F.” Pet at 22, n.12; *see* Midwest Generation v. IEPA, PCB 18-58, slip op. at 74 (Nov. 21, 2019).

MG states that its proposed ATELS limit the use of excursion hours based on the calendar year instead of the 12-month rolling average in the 2018 thermal standards. Pet. at 22, n.13; *see* 35 Ill. Adm. Code 302.408(f). MG argues that this is consistent with ATELS recently approved by the Board. Pet. at 22, n.13, citing Midwest Generation v. IEPA, PCB 18-58, slip op. at 74 (Nov. 21, 2019); Exelon Generation v. IEPA, PCB 14-123, slip op. at 48, 54 (Sept. 18, 2014).

Based on its review of historical operating and flow data, MG concludes that its proposed ATELS would maintain a 75% zone of passage in the UDIP near the Joliet Stations even under the worst-case modeled conditions. Exh. A at 3-10. MG stresses that, when erratic or low flow causes the dilution ratio to fall below 3:1, the mixing zone regulations allow a 50% zone of passage. *Id.*, citing 35 Ill. Adm. Code 302.102(b)(8). MG concludes that discharges under its proposed ATELS would meet these zone of passage requirements. Exh. A at 3-10; *see* App. B at B-48.

Proposed Standards and Comparisons for Five-Mile Stretch

In 1996, Commonwealth Edison, MG’s predecessor as owner, petitioned the Board to adjust standards for thermal discharges from the Joliet Stations. Pet. at 23. The Board granted the requested relief. *Id.*; *see* Petition of Commonwealth Edison Co, for Adjusted Standard from 35 Ill. Adm. Code 302.211(d) and (e), AS 96-10, slip op. at 7 (Oct. 3, 1996).

MG’s petition includes a table comparing general use thermal standards under 35 Ill. Adm. Code 302.211(e), standards under AS 96-10, and its proposed alternate limits:

Month	General Use Thermal Standard (35 Ill. Admin Code 302.211(e)) (°F)	Existing I-55/AS 96-10 Limit (°F)	Proposed Far-Field Alternative Effluent Limit (°F)
January	60	60	60
February	60	60	60
March	60	65	65
April 1-15	90	73	73
April 16-30	90	80	
May 1-15	90	85	85
May 16-31	90	90	
June 1-15	90	90	90
June 16-30	90	91	
July	90	91	91
August	90	91	91
September	90	90	90
October	90	85	85
November	90	75	75

December	60	65	65
Excursion Hours	Water temperature at representative locations in the main river shall not exceed the maximum limits during more than 1% of the hours in the 12-month period ending with any month. Moreover, at no time shall the water temperature exceed the maximum by more than 1.7 °C (3.0 °F)	These standards are in lieu of the requirements of 35 Ill. Adm. Code 302.211(c), (d) and (e) and may be exceeded by no more than 3 °F during 2% of the hours in the 12-month period ending December 31, except that at no time shall the MWGen Joliet 9 and/or Joliet 29 plants cause the temperature at the I-55 Bridge to exceed 93 °F	These standards are in lieu of the requirements of 35 Ill. Adm. Code 302.211(c), (d) and (e) and may be exceeded by no more than 3 °F during 2% of the hours in the 12-month period ending December 31, except that at no time shall the MWGen Joliet 9 and/or Joliet 29 plants cause the temperature at the I-55 Bridge to exceed 93 °F

Pet. at 24; *see id.* at 32; Exh. A at 3-13; Exh. D at D-12 – D-13. MG states that its proposed ATELS would effectively “replace both the existing AS 96-10 limits and the Stations’ obligation to comply with the existing General Use thermal standards that would otherwise be effective at and below the I-55 Bridge.” Pet. at 24-25, citing 45 Ill. Adm. Code 302.211(b), (c), (d), (e); *see* Exh. A at 3-4, 3-13.

MG would determine compliance with the proposed far-field limits “through the use of real-time monitoring equipment maintained by the Joliet Stations at the I-55 Bridge location, and [compliance] is assured through the continued use of the Far-Field Thermal Compliance Model.” Exh. A. at 3-4, citing App. A, Exh. A-1 at 12 (Special Condition 4D), Exh. A-2 at 11 (Special Condition 4D); *see* App. D at D-13, citing Exh. D-1b. The model “relies on the use of assimilative flow fluctuations in its predictions of downstream temperature.” Exh. A at 3-16.

MG asserts that the Five-Mile Stretch has been adequately protected by standards including only numeric criteria. Pet. at 22; *see* Exh. A at 3-7. MG argues that its proposed ATELS “are more stringent than the prior Secondary Contact and Indigenous Aquatic Life limits and logically should also not result in appreciable harm.” Pet at 22. It argues that its demonstration shows that proposed numeric standards will continue to protect the UDIP. *Id.* Based on these factors, MG’s proposed far-field standards do not include narrative criteria. *See id.* at 33; Exh. A at 3-10 – 3-11.

MG notes that the current AS 96-10 standards allow temperatures up to 3 °F higher than the applicable limit for up to 2% of the hours in a calendar year. The standards also establish that the temperature at the I-55 Bridge must not exceed 93 °F at any time. Exh. A at 3-4; *see* Rec. at 4-5.

Dischargers Downstream from Stations

MG analyzed “whether there would be any potential thermal influence from the operation of the Joliet Stations under the proposed AELs on the ability of three identified downstream thermal dischargers to comply with the UDIP thermal standards.” Exh. A at 3-16; *see* App. D at D-47.

ExxonMobil

ExxonMobil discharges at RM 278.2, approximately 0.2 miles upstream from the I-55 Bridge. App. D at D-47, Exh. D-2a at 10; *see* ExxonMobil Resp. at 2. Its single combined outfall includes Outfall 001 with a DAF of 4.32 MGD (6.68 cfs), Outfall 002 with a DAF of 10.5 MGD (16.24 cfs) and Outfall 003 of intermittent stormwater discharges. App. D, Exh. D-2a at 10. From 2012 to 2017, summer maximum flow was 38.2 cfs and winter maximum flow was 39.4 cfs. *Id.*

ExxonMobil’s Joliet Refinery withdraws water from the LDPR at the mouth of Jackson Slough, which “has essentially no upstream flow from its watershed except during major storm events.” App. D, Exh. D-2a at 7; *see* Figure D-1. Based on the location of the intake, the demonstration asserts that factors other than the Joliet Stations’ operation can influence intake water temperature. App. D, Exh. D-2a at 10. The demonstration argues that Jackson Slough temperature data indicate that intake temperature does not depend solely on river temperature and is subject to localized influences that do not have a known effect on discharge temperatures. *Id.*

Because ExxonMobil’s discharge volume is 1.5% of 7Q10 low-flow conditions and a much lower percentage of volume during more typical conditions, MG argues that “it is unlikely that facility thermal compliance with the current UDIP thermal standards would be limited by upstream temperatures.” App. D, Exh. D-2a at 8; *see* Exh. D-2b at 8-10, 18-19. However, if upstream ambient water temperatures exceed applicable standards, ExxonMobil would not be allowed a mixing zone. App. D, Exh. D-2a at 9. Historical temperature data indicate that “[t]his is not expected to be a frequent occurrence.” *Id.*; *see* Exh. D-2b at 11 (Maximum Recorded Discharge Temperature Scenario).

The demonstration also considered maximum measured discharge temperatures and modeled worst-case ambient river temperatures to consider the potential to exceed narrative standards. “The result was that there was no combination of circumstances found that would result in non-compliance with these narrative provisions (Section 302.408(c), (d), and (e)).” App. D, Exh. D-2a at 9.

INEOS

INEOS, formerly Flint Hills Resources, withdraws water from an on-site well and discharges at RM 280.3 “into a semi-backwater area adjacent to the main channel.” App. D, Exh. D-2a at 1; *see* Figure D-1. Its single outfall has a DAF of 2.318 MGD (3.6 cfs) with an

average flow from January 2012 to January 2017 of 1.24 MGD (1.92 cfs). App. D, Exh. D-2a at 1.

MG argued that, due to the low volume of this discharge in relation to the LDPR, unless the upstream ambient temperature exceeds the thermal water quality standard, INEOS' "thermal discharge can be expected to remain in compliance with the existing UDIP numeric and narrative thermal water quality criteria, with no reasonable potential to exceed." *Id.*; see App. D, Exh. D-2b at 1-4, 14-15.

However, INEOS' discharge may not meet the UDIP numeric limit if the upstream ambient water temperature exceeds the applicable limit. In that case, INEOS "would not be allowed a mixing zone." App. D, Exh. D-2a at 2. Based on historical river temperatures at the Stations' discharges and the I-55 Bridge, "[t]his is not expected to be a frequent occurrence." *Id.*

Stepan

Stepan withdraws water from an on-site well and discharges at RM 280 "into a shallow backwater area at the upstream extent of Treats Island." App. D, Exh. D-2a at 4; see Figure D-1. Its single outfall has a DAF of 1.36 cfs. From 2012 to 2017, it had a summer maximum flow of 2.02 cfs and winter maximum flow of 1.7 cfs. App. D, Exh. D-2a at 4.

Because of the small volume of Stepan's discharge, the demonstration expects the LDPR to have sufficient assimilative capacity to meet UDIP numeric limits if it has a mixing zone. App. D, Exh. D-2a at 5. However, Stepan's NPDES permit does not allow mixing. *Id.* "Since Stepan must meet the applicable thermal water quality standards at the end-of-pipe, and its source water is from a well, rather than the LDPR, upstream Joliet Station operations have no impact or influence on Stepan's ability to meet these standards." *Id.*

Also, the demonstration argues that it is "highly unlikely" that Stepan's discharge would increase the temperature of the main body of the river by 5 °F or more or alter normal temperature cycles. App. D, Exh. D-2a at 5. Consequently, "the narrative portions of the UDIP limitations (Section 302.408(c), (d), and (e)) should continue to be met." *Id.*; see App. D, Exh. D-2b at 5-7, 16-17.

Based on these factors, the demonstration concludes that "Stepan would not be subject to proposed coverage or further consideration under MWGen's proposed thermal AELs, since they will continue to be solely responsible for their own discharge temperature (end-of-pipe) compliance." App. D, Exh. D-2a at 5.

Modeling

MG obtained input data from the three downstream dischargers and incorporated it into its modeling. App. D at D-47. "[N]one of the subsequent model calibration/validation runs that included thermal contributions from the downstream dischargers showed any discernable influence from them on the modeled water temperatures in the UDIP of the LDPR." *Id.* MG acknowledged that the model does not provide the level of detail required to capture thermal

discharges of very small magnitude. *Id.* However, the demonstration reports that the small volume contributed by the three downstream dischargers “did not translate into any distinctly measurable thermal signature once mixed with the flow in the waterway.” *Id.*

Results showed that under extreme conditions expected approximately once per decade, “two of the three downstream dischargers could experience compliance concerns.” Exh. A at 3-16. Specifically, when the Stations operate at higher sustained loads under extreme weather and flow conditions, the ability of those two sources to comply with the UDIP summer thermal limit of 90 °F or winter limit of 60 °F may be affected by the Stations’ upstream discharges. App. D at D-86, citing App. D, Figures D-13b, D-17b; Tables D-12n, D-12o, D-18n, D-18o.

MG argues that the results “provide a basis from which to determine whether, and to what extent, upstream river temperatures influenced by the Joliet Stations’ discharges may negatively impact ongoing compliance with the UDIP thermal limits by one or more of the downstream dischargers.” App. D at D-47 – D-48.

Discussion

In its recommendation, IEPA stated that MG accounted for downstream thermal discharges by ExxonMobil, INEOS, and Stepan. Rec. at 5. IEPA recommended that “each of these thermal dischargers be allowed to take advantage of the AELs adopted by the Board.” *Id.* at 10. IEPA reported that USEPA considers it “appropriate to include downstream dischargers in the relief requested as long as the dischargers were considered in the Demonstration Report.” *Id.* at 11.

MG states that it has accounted for the interaction of its thermal discharges and the cumulative effect of other thermal sources. MG Resp. at 4, citing 40 CFR § 125.73(a), 125.73(c)(1)(i). It argues that its demonstration shows the Stations “can operate under the proposed thermal ATELS without causing other dischargers to violate the thermal standards set in their permits.” *Id.*

MG notes IEPA’s recommendation that downstream dischargers be allowed to take advantage of ATELS adopted by the Board. MG Resp. at 4; *see* Rec. at 10. MG “does not object” to allowing the downstream dischargers to take advantage of its demonstration that proposed ATELS would not harm the BIC. MG Resp. at 5. However, if the volume or temperature of the downstream discharges increases, it may reduce the current assimilative capacity of the UDIP and Five-Mile Stretch. *Id.* MG argues that a change of this nature could require the Stations to reduce production with significant financial consequences. *Id.*

MG favors addressing the other dischargers separately so that, “in the event there are any contested issues relating to any downstream discharger’s AEL relief, it will not jeopardize or delay” its own request. *Id.* at 6. MG expects that the downstream dischargers would be able to file petitions for ATELS relying on MG’s demonstration “with few or no modifications.” *Id.* It argues that IEPA’s recommendation in this case “should reassure the downstream dischargers that they will face few obstacles in pursuing this relief.” *Id.*

Both ExxonMobil and INEOS note that MG's demonstration considered downstream dischargers including their facilities. ExxonMobil Resp. at 3; INEOS Resp. at 3; *see* Exh. A at 3-16; App. B at B-25 – B-28, App. Cat C-9 – C-10; App. D at D-46 – D-48, Exh. D-2a. Both stress IEPA's recommendation to allow downstream thermal dischargers to take advantage of thermal ATELS adopted by the Board. ExxonMobil Resp. at 3, INEOS Resp. at 3, citing Rec. at 10, 11. Both request that the Board, as part of its disposition in this proceeding, find that they are "entitled to the same alternative thermal effluent limitations as allowed to Midwest Generation, and order that Illinois EPA may include those alternative thermal effluent limitations in NPDES permits. ExxonMobil Resp. at 5, INEOS Resp. at 5.

In its reply, IEPA does not object to MG's request to limit relief for the downstream dischargers to historical practices. IEPA Reply at 3. However, IEPA "sees no need for those dischargers to file separate Subpart K petitions." *Id.* IEPA asserts that "the Board could successfully condition Petitioner's thermal AEL for regulatory relief for the downstream dischargers." *Id.*

The Board asked IEPA to comment on whether the Board's rules allow it to extend relief to other downstream thermal dischargers when those dischargers have not filed petitions seeking ATELS. Board Questions at 7. If so, the Board asked IEPA to provide specific language addressing downstream dischargers. *Id.*

IEPA responded that it does not believe the Board rules preclude "extending relief to other downstream dischargers when the dischargers have not filed petitions." IEPA Resps. at 1. IEPA proposed the following language to address downstream dischargers identified in MG's petition:

Pursuant to 35 Ill. Adm. Code 106.1160(d)(1)(A), Petitioner demonstrated that due to the size and thermal loads, the discharges of Stepan Chemical (IL0002453), INEOS (Formally Flint Hills Resources) (IL0001643), and ExxonMobil Oil Corporation (IL0002861), will be able to meet the applicable water quality standard except in those circumstances where the ambient temperature is at or above the applicable water quality standard and allowed mixing is not available. Stepan Chemical (IL0002453), INEOS (Formally Flint Hills Resources) (IL0001643), and ExxonMobil Oil Corporation (IL0002861) are hereby granted the thermal relief and are eligible for allowed mixing for temperature with the following conditions:

1. Thermal loadings shall be commensurate with historical loadings. Any expansion of existing thermal loadings shall not be subject to the Alternate Thermal Effluent Limitations.
2. Each NPDES permit shall include an effluent temperature monitoring requirement. *Id.*

MG's Demonstration sought to determine whether operating the Stations under the proposed ATELS would influence compliance by three downstream dischargers. While under

rare and extreme conditions, two of the three may experience compliance concerns, MG asserts that the Stations could operate under the proposed ATELS without causing other dischargers to violate their thermal standards.

However, MG suggests that downstream dischargers may influence its ability to comply with the requested ATELS. If downstream discharges increase in either volume or temperature or both, then the Stations may be required to reduce operations to avoid compliance concerns of their own. MG favors addressing these downstream dischargers separately so that there is an opportunity to address any contested issues of this general nature.

Board Finding

The Board finds considerable procedural and substantive support for MG's position that downstream dischargers should be addressed separately. The record does not indicate that the downstream dischargers provided public notice of a request for ATELS or an opportunity for public hearing on a request. Also, MG questions the effect the downstream dischargers may have on the Stations' compliance. While IEPA may be correct that Board rules do not preclude providing relief to dischargers who have not filed a petition, this record lacks sufficient information for the Board to consider a request by the three additional downstream dischargers in this proceeding.

IEPA's view that any additional proceedings would not be an efficient use of resources may be correct. However, the Board must make its decisions on the record, and this record leaves questions about the impact of the three downstream dischargers on MG's ATELS. The Board notes that MG expects that the three downstream dischargers could rely on its demonstration with few modifications to receive ATELS for their own discharges. IEPA has proposed a condition to accommodate the downstream dischargers by limiting relief to thermal loadings consistent with historical discharges. However, the proposed condition lacks precision and certainty, and the record does not now provide the Board with sufficient information to clarify it. For these reasons, the Board declines to include the proposed conditions regarding downstream dischargers in the ATELS for MG.

MG's Response to Board's Proposed Revisions

The Board asked MG to comment on suggested revisions to its proposed ATELS, "which are based on the Board's order in PCB 18-58 and reflect IEPA's recommendations except for the condition concerning downstream dischargers." Board Questions at 9.

1. Temperature
 - a. Instead of thermal effluent limitations based on the General Use thermal water quality standards contained in 35 Ill. Adm. Code 302.211 and the Upper Dresden Island Pool (UDIP) Use thermal water quality standards provisions contained in 35 Ill. Adm. Code 302.408 (c)-(f), and (i), the following daily maximum temperature effluent limitations apply to Joliet Stations 9 and 29:

Month	Daily Maximum Near- Field (UDIP) (°F)	Daily Maximum Far- Field (Five- Mile Stretch) (°F)
January	65	60
February	65	60
March	70	65
April	80	73
May	85	85
June	93	90
July	93	91
August	93	91
September	93	90
October	90	85
November	85	75
December	70	65

- b. Instead of the water temperature requirements of 35 Ill. Adm. Code 302.408(c), (d), (e), (f) and (i) applicable to UDIP, effluent temperatures must not exceed the near-field daily maximum temperature limitations in paragraph (1)(a) during more than 5% of the hours (438 hours) in a calendar year. Moreover, the effluent temperature must never exceed the daily maximum near-field temperature limitations in paragraph (1)(a) by more than 3 °F.
- c. Instead of the water temperature requirements of 35 Ill. Adm. Code 302.211 applicable to the Five-Mile Stretch, effluent temperatures must not exceed the daily maximum far-field temperature limitations in paragraph (1)(a) during more than 2% of the hours (175 hours) in a calendar year. Moreover, the effluent temperature must never exceed the daily maximum far-field temperature limitations in paragraph (1)(a) by more than 3 °F.
- d. The alternative near-field thermal effluent limitations in paragraphs (1)(a) apply at the edge of the 26-acre mixing zone allowed in each of the Joliet Generating Stations' National Pollutant Discharge Elimination System (NPDES) permits.
- e. The alternative far-field thermal effluent limitations in paragraph (1)(a) apply at the I-55 Bridge (River Mile 277.9). For purposes of this order, the "Five-Mile Stretch" is the segment of the Lower Des Plaines River starting from the I-55 Bridge (River Mile 277.9) to the Illinois River (River Mile 273.0).

2. Midwest Generation will continue to operate its Joliet 29 Generating Station Cooling Towers to minimize the use of excursion hours when possible.
3. Compliance. Midwest Generation must demonstrate compliance with paragraph (1) by modeling that is approved by the Illinois Environmental Protection Agency (IEPA) as a condition of the Joliet Stations' NPDES permit.
4. NPDES Permit. IEPA must expeditiously modify Midwest Generation, LLC's NPDES permits for the Joliet Generating Stations to make the permits consistent with this opinion and order.

MG responded that these suggested revisions “are generally acceptable,” although it proposed further revisions intended “to ensure that the language and intended meaning of the proposed ATEL is consistent, comprehensive, and clear.” MG Resps. at 9. MG also proposed to re-designate the subsections under “Temperature” to maintain alphabetical order. *Id.*

First, MG suggested that subsections (1)(d) and (1)(e) both strike the word “temperature” from the phrase “thermal effluent temperature limitations.” MG Resps. at 9. MG argues that this revision is consistent with subsection (1)(a). Also, it suggests that the word “temperature” is redundant. Finally, it suggests that it may unduly limit those two subsections, which address not only numeric values but also other thermal limits. *Id.*

Second, MG agrees with revising subsection (1)(d) by adding a reference to subsection (1)(b). MG Resps. at 9. It explains that both subsections (1)(a) and (1)(b) contain near-field thermal effluent limitations addressed in subsection (1)(d). *Id.* For the same reason relating to the far-field limits, MG would also revise subsection (1)(e) to refer to subsection (1)(c). *Id.*

Third, MG suggests revising subsection (1)(d) relating to mixing zones. MG Resps. at 9. It argues that this clarifies “that each of the two Joliet Stations’ thermal discharges has its own 26-acre mixing zone and therefore the near-field ATEL thermal effluent limitations” apply at the edge of each Station’s mixing zone. *Id.*

Fourth, MG revises subsection (1)(e) to accommodate “the possibility that this AEL will appear in contexts outside of just the Board’s order.” MG Resps. at 10.

Fifth, MG proposed to revise section (2) to clarify when cooling towers will operate. MG Resps. at 10. It argues that the revision provides that MG will “continue its prior practice of minimizing the use of excursion hours through its operation of the Joliet 29 cooling towers but recognizes that these cooling towers cannot be, and are not, operated at all times.” *Id.*

NPDES Permit Modification

MG requests that, if the Board grants its requested relief, it should exercise its authority under 35 Ill. Adm. Code 106.1170 “to order the IEPA to expeditiously modify the Joliet Stations’ NPDES permits consistent with the new AELs.” Pet. at 34, citing Midwest Generation v. IEPA, PCB 18-58, slip op. at 75 (Nov. 7, 2019); see 35 Ill. Adm. Code 106.1170(a) (Opinion

and Order). MG argues that “[t]his modification should include removing the Special Conditions related to AS 96-10, which are effectively superseded” by the proposed far-field ATELS. Pet. at 34.

BURDEN OF PROOF

MG bears the burden of proof. 35 Ill. Adm. Code 106.1160(a). MG must demonstrate that the otherwise applicable thermal effluent limitations based on temperature water quality standards (35 Ill. Adm. Code 302.408(c)–(e), (h)) are “more stringent than necessary to assure the protection and propagation of a balanced, indigenous community of shellfish, fish, and wildlife in and on the body of water into which the discharge is to be made.” 35 Ill. Adm. Code 106.1160(b); *see* 40 C.F.R. § 125.73(a); Pet. at 7.

MG must also demonstrate that the requested alternative thermal effluent limitations, “considering the cumulative impact of its thermal discharge, together with all other significant impacts on the species affected, will assure the protection and propagation of a balanced indigenous community of shellfish, fish, and wildlife in and on the body of water into which the discharge is to be made.” 35 Ill. Adm. Code 106.1160(c); *see* 40 C.F.R. § 125.73(a); Pet. at 7.

An existing discharger may base its demonstration on the absence of prior appreciable harm instead of using “predictive” studies. 35 Ill. Adm. Code 106.1160(d). This “retrospective” demonstration must show either:

- A) That no appreciable harm has resulted from the normal component of the discharge, taking into account the interaction of such thermal component with other pollutants and the additive effect of other thermal sources to a balanced, indigenous community . . . ; or
- B) That despite the occurrence of such previous harm, the desired alternative thermal effluent limitation (or appropriate modifications thereof) will nevertheless assure the protection and propagation of a balanced, indigenous community 35 Ill. Adm. Code 106.1160(d)(1)(A), (B); *see* 40 C.F.R. § 125.73(c).

In determining whether prior appreciable harm has occurred, the Board considers “the length of time during which the petitioner has been discharging and the nature of the discharge.” 35 Ill. Adm. Code 106.1160(d)(2).

EA, MG’s consultant, prepared the Section 316(a) Demonstration based on both predictive and retrospective studies.

BOARD DISCUSSION

MG proposes alternative thermal effluent limitations to increase the daily maximum numeric temperature limits and excursion hours in its NPDES Permit in lieu of the UDIP Aquatic Life Use Waters standards at 35 Ill. Adm. Code 302.408 (c)-(f), and (i) (near field), and

the General Use standards at 35 Ill. Adm. Code 302.211 (b)-(d) that apply to the Five-Mile Stretch. While the proposed UDIP/Near-Field thermal ATEL would apply to UDIP waters from the edge of each Station's respective 26-acre mixing zone, the General Use Standard/Far-Field ATEL would apply within the Five-Mile Stretch.

MG must demonstrate that the thermal effluent limitations applicable to the heated effluent from the Joliet stations are more stringent than necessary to assure the protection and propagation of a balanced, indigenous population of shellfish, fish, and wildlife in the UDIP and the Five-Mile Stretch. The demonstration must also show that the proposed alternative thermal effluent limitations will assure the protection and propagation of this balanced, indigenous population. *See* 33 U.S.C. § 1326(a); 35 Ill. Adm. Code 106.1160; 40 C.F.R. § 125.73. The USEPA 316(a) Manual provides the components for this demonstration.

A petitioner must provide a master rationale supported by a biotic category rationale, which demonstrates that decision criteria specific to each of the six biotic categories are satisfied. The first step in the biotic category rationale is an early screening process that identifies the biotic community in the area affected by the discharge. Based on this early screening process, the petitioner selects any one or combination of four types of demonstrations to support its biotic category rationale: "Type I" (Retrospective/Absence of Prior Appreciable Harm); "Type II" (Predictive/Representative Important Species); "Type III" (Low Potential Impact); and "Other Type III" (Biological, Engineering, and Other Data). These demonstrations are synthesized into a master rationale for the proposed alternative thermal effluent limitations to support the conclusion that each biotic category's criteria are satisfied.

Below, the Board first decides whether MG has shown that the proposed alternative thermal effluent limitations will assure the protection and propagation of the balanced, indigenous community. 35 Ill. Adm. Code 106.1160(c); *see also* 33 U.S.C. § 1326(a). This involves reviewing whether MG's Section 316(a) demonstration identifies the balanced, indigenous community and shows that the proposed alternatives will assure the protection and propagation of that community. Then, the Board decides whether effluent limits based on its numeric temperature limits, excursion hour limits, and narrative temperature limits (Sections 302.211 (b)-(d) and 302.408(c)-(f) and (i) are more stringent than necessary to assure the protection and propagation of the balanced, indigenous community in the UDIP and the Five-Mile Stretch. 35 Ill. Adm. Code 106.1160(b); *see also* 33 U.S.C. § 1326(a).

Proposed ATELS Assure the Protection and Propagation of the Balanced Indigenous Community

The proposed ATELS must "assure the protection and propagation of a balanced, indigenous community [BIC] of shellfish, fish, and wildlife in and on the body of water into which the discharge is made." USEPA 316(a) Manual at 52; *see* Exh. A at 4-1.

The CWA uses the phrase "balanced, indigenous population" and the federal regulations define the phrase "balanced, indigenous community." These phrases have come to be synonymous and mean:

a biotic community typically characterized by diversity, the capacity to sustain itself through cyclic seasonal changes, presence of necessary food chain species, and a lack of domination by pollution tolerant species. Such a community may include historically non-native species introduced in connection with a program of wildlife management and species whose presence or abundance results from substantial, irreversible environmental modifications. Normally, however, such a community will not include species whose presence or abundance is attributable to the introduction of pollutants that will be eliminated by compliance by all sources with section 301(b)(2) of the CWA; and may not include species whose presence or abundance is attributable to alternative thermal effluent limitations imposed under this Subpart or to regulatory relief, granted by the Board, from otherwise applicable thermal limitations or standards under 35 Ill. Adm. Code 301 through 312. 35 Ill. Adm. Code 106.1110; *see* 40 C.F.R. § 125.71(c); Exh. A at 4-1; USEPA 316(a) Manual at 74.

Master Rationale

The demonstration's Master Rationale "should form a convincing argument that the balanced, indigenous community will be protected." USEPA 316(a) Manual at 52. The rationale should summarize the ecosystem as projected by the six Biotic Category Rationales and the resource zones impacted. *Id.* It should also summarize "why the information in the rationales, along with the predictions in the RIS Rationale, the engineering and hydrological data, and other key facts, suggest that the balanced indigenous community will be protected." USEPA 316(a) Manual at 52; *see id.* at 72.

An applicant for ATELS may use predictive methods, and, in the case of existing facilities, may "demonstrate the absence of prior appreciable harm." Exh. A at 4-1. MG uses both – a retrospective evaluation (App. C) and a predictive demonstration (App. B) based on hydrothermal surveys and modeling of the Stations' thermal discharges (App. D). Exh. A at 4-1. Based on these studies, MG asserts that the thermal discharges from the Joliet Stations have not caused prior appreciable harm to the BIC, and that the proposed ATEL will assure the protection and propagation of the balanced, indigenous community in the UDIP and the Five-Mile Stretch. 35 Ill. Adm. Code 106.1160(c), (d). The Board reviews the supporting material for the Master Rationale, beginning with biotic category identification.

Biotic Category Identification

A CWA Section 316(a) demonstration begins with the early screening process to identify the balanced, indigenous population of aquatic life in the receiving water. USEPA 316(a) Manual at 18, 34.

Because biotic communities may contain numerous species, USEPA suggests assessing thermal impacts on a community-by-community basis. The USEPA 316(a) Manual identifies six categories of biotic communities: (1) habitat formers; (2) phytoplankton; (3) zooplankton; (4) macroinvertebrates and shellfish; (5) fish; and (6) other vertebrate wildlife. USEPA 316(a) Manual at 18–32.

After completing the early screening process and the preliminary assessment of the additional work needed in each of the six biotic categories, the petitioner chooses the most appropriate type of demonstration for the site. USEPA 316(a) Manual at 34. A demonstration describes the impact of the thermal discharge on each biotic category. *Id.* at 16. A successful demonstration must show that each biotic category meets either the decision criteria for a site that is a low potential impact area or the decision criteria for a site that is not a low potential impact area. *Id.* at 18–32. Below, the Board reviews the six biotic categories assessed by MG.

Habitat Formers (Aquatic Vegetation). Habitat formers are the plants providing cover, foraging, spawning, or nursery habitat for fish and shellfish. USEPA 316(a) Manual at 76–77. The USEPA 316(a) Manual states that habitat formers play a role “unquestionably unique and essential to the propagation and well-being of fish, shellfish, and wildlife.” *Id.* at 57. These organisms may be vulnerable to the temperature, velocity, or turbidity of a heated discharge and may also be damaged by biocides present in the discharge. *Id.*

The demonstration for this category must show that the site is a low potential impact area, or, if not, show that it meets the following criteria:

1. The heated discharge will not result in any deterioration of the habitat formers community or that no appreciable harm to the balanced indigenous population will result from such deteriorations.
2. The heated discharge will not have an adverse impact on threatened or endangered species as a result of impact upon habitat formers. USEPA 316(a) Manual at 22.

The USEPA 316(a) Manual lists information that an applicant should provide for areas that do not qualify as low impact areas in this category. *Id.* at 22-23.

QHEI Scores. Habitats in the UIW have been evaluated using the QHEI, which determines “the quality of biota that can reasonably be expected in various waterbodies.” App. C at C-13. “The QHEI is based on six interrelated metrics: substrate, instream cover, channel morphology, riparian and bank condition, pool and riffle quality, and gradient.” *Id.* Narrative ranges correspond to QHEI scores as follows:

Narrative Rating	QHEI Range	
	Headwaters	Larger Streams
Excellent	> 70	> 75
Good	55 to 69	60 to 74
Fair	43 to 54	45 to 59
Poor	30 to 42	30 to 44
Very Poor	< 30	0

App. C at C-13.

1993/1994 Habitat Evaluation. A study performed in 1993-1994 used the QHEI to assess the extent to which habitat limits aquatic biota in the UIW. App. C at C-13. QHEI scores

varied based on mesohabitat type. *Id.* Mean QHEI scores were lowest in the main channel and main channel border habitats and the Five-Mile Stretch, where they are the dominant mesohabitat types. *Id.*; see App B. at B-39. “Tailwater habitat is not influenced by the discharges under normal operations, nor are the backwater habitats upstream and downstream of the Joliet discharges.” App. B at B-39.

“[T]he highest QHEI score was found at the single tailwater area found in the entire Dresden Pool (Brandon Road Lock and Dam tailwater), which comprises only approximately 5% of all habitat types found in the pool.” App. C at C-13. Over the entire Dresden Pool, the mean QHEI score was 51, at the lower end of the 45 to 59 range of the fair rating.” *Id.*

The demonstration attributed lower QHEI scores to a lack of riffle/run habitat; lack of clean, hard substrates such as gravel and cobble; areas of excessive siltation; channelization; poor riparian and floodplain areas; and lack of instream cover. App. C at C-13; see Exh. A at 6-3. “[T]he lower Dresden Island Pool ranked slightly higher, because it has a greater percentage of slough (23.1%) and tributary mouth (20.3%) habitats.” App. C at C-13. However, its mean QHEI value of 56.6 was still in the fair range. *Id.*

2016 Habitat Evaluation. Beginning in 2016, a habitat assessment evaluated habitat changes since the mid-1990s. App. C at C-14, citing App. K. QHEI scores remained in the poor and fair ranges, “except for the Brandon Road Lock and Dam tailwater area that makes up approximately 5% of the UDIP area.” *Id.*, citing App. K. The demonstration states that new QHEI and other habitat-related information show that “there have been no significant changes in habitat quality in the UDIP.” App. C at C-14. It argues that the continued low QHEI scores result from many of the same factors noted in the 1993-1994 evaluation and that “[n]one of the habitat limitations are related to the operation of Joliet Stations 9 or 29 or their thermal discharges.” *Id.* at C-15.

2017 Macrophyte Survey. “Macrophytes are aquatic plants growing in or near water that are characterized as emergent (upright portions above the water surface), submergent (growing underwater), or floating (either rooted or non-rooted vegetation).” App. K at K-1. “Macrophytes provide cover for fish and substrate for aquatic invertebrates.” *Id.* The depth, density, diversity and types of macrophytes indicate the health of a waterbody. *Id.*; see App. K, Table K-2 (SAV Status and Ecological Importance).

The survey observed and recorded a total of eight species of Submerged Aquatic Vegetation (SAV). App. K. at K-3. Species were recorded in order of dominance and included wild celery (*Vallisneria americana*), coontail (*Ceratophyllum demersum*), Eurasian watermilfoil (*Myriophyllum spicatum*), sago pondweed (*Potamogeton pectinatus*), water stargrass (*Heteranthera dubia*), Canadian waterweed (*Elodea canadensis*), curly pondweed (*Potamogeton crispus*) and longleaf pondweed (*Potamogeton nodosus*). *Id.* Six of the eight species of SAV observed are considered native to the Des Plaines River and not nuisance species, but Eurasian watermilfoil and curly pondweed are introduced SAV species. *Id.* at K-4; see App. C at C-15 – C-16. Most species of SAV observed provide important ecological benefits. App. K at K-4; see App. K, Table K-2.

The survey also examined the shoreline riparian buffer to document overhanging vegetation, which can provide bird habitat or shading for fish species. App. K at K-5. Overhanging species included box elder (*Acer negundo*), silver maple (*Acer saccharinum*), dogwood species (*Cornus spp.*), catalpa (*Catalpa speciosa*), bush honeysuckle species (*Lonicera spp.*), Osage orange (*Maclura pomifera*), elm species (*Ulmus spp.*), willow species, (*Salix spp.*) elderberry (*Sambucus canadensis*), and sumac species (*Rhus spp.*). *Id.*; see App. C at C-17. Where present, the herbaceous understory of the shoreline riparian buffer included the following species: Canada thistle (*Cirsium arevense*), Canadian woodnettle (*Laportea canadensis*), tall coneflower (*Rudbeckia laciniata*), wingstem (*Verbesina alternifolia*), and swamp vervain (*Verbena hastata*). *Id.*

The survey showed that, while Emergent Aquatic Vegetation (EAV) area has declined, Emergent Wetland Vegetation (EWV) has expanded. App. C at C-17. Also, some species had replaced others. For example, “narrowleaf cattail was more common in the 1990s while broad-leaved cattail was more common in 2017.” *Id.* However, the demonstration argues that “these changes are unrelated to Joliet Station 9 and 29 thermal discharges. Rather, they signify successional changes that have occurred in shallow, near-shore areas over the past twenty-plus years that are related to a lack of disturbance as well as the deposition of detrital material and fine sediment.” *Id.*

Habitat Quality. While much of the habitat studied rated “fair” to “poor,” approximately 6% of the study area was considered as potentially productive fish habitat. App. K at K-6, citing App. K, Figure C-3 (QHEI Survey Results); see Exh. A at 6-3. The survey found that water depth had the greatest influence on SAV. App. K at K-6. At sampling stations where the survey recovered SAV, water depth ranged from 1.0 to 7.6 feet. Only two sampling stations less than 6.0 feet deep recorded no SAV; conversely, no stations greater than 8.0 feet deep recorded SAV. *Id.*

Of stations with SAV present, 51% were dominated by a silt substrate, 26% by sand, 18% by gravel, 3% by clay, and 2% by boulder substrate. App. K. at K-6, see Figure K-5 (Dominant Substrate). During the survey, 9 of the 17 transects recovered SAV at 100% of the sampling stations that were less than 8.0 feet deep. App. K. at 6, see Table K-6 (Depth and Substrate). The remaining 8 transects recovered SAV from at least 67% of sampling stations less than 8.0 feet deep. *Id.* Only 10 of 140 sampled stations that were less than 8.0 feet deep did not recover SAV. *Id.* At most of these stations, gravel, cobble, or hardpan substrate were present. *Id.* “These substrates may preclude SAV growth and establishment.” App. K at K-6.

SAV, EAV, and EWV enhance aquatic and riparian habitat in some portions of the project area. In other segments, “particularly near the head of Treats Island, SAV may attain such high density as to be limiting habitat potential.” App. K at K-7, citing Exh. C; Figure C-2. In addition, most of the survey area is deep and dredge-maintained Main Channel, which is generally less productive. App. K at K-7. Also, QHEI scores show that, except for a few locations during some years, most areas rate fair to poor. App. K. citing Exh. C; Figure C-3. Even in areas rated good, such as the Brandon Dam tailrace or Treats Island backwater/side channel, QHEI scores have regularly rated fair. The Brandon Dam tailrace is subject to rapid fluctuations in water level and velocity due to lock operation, upstream hydro-peaking

operations, and storm event planning. “These factors almost certainly limit the potential of even the best areas within the UDIP.” App. K at K-7; *see* Exh. A at 6-3.

Summary. Based on the above, MG’s consultant, EA, concludes that the thermal discharges from the Joliet Stations “do not affect the quality of aquatic habitat in the UDIP/Five-Mile Stretch and have not caused appreciable harm to the habitat former community. The distribution and abundance of habitat formers and habitat quality in this anthropogenically-influenced impounded waterway are dictated primarily by dominance of main channel/main channel border habitat and subsequent lack of appropriate conditions for development of a greater diversity of habitat former types. Due to these ongoing constraints, this community would be substantively the same regardless of the operation of the Joliet Stations’ cooling water discharges with the proposed near-field and far-field thermal AELs.” Exh. A at 6-3 – 6-4.

Phytoplankton. Phytoplankton are microscopic plants, such as algae, transported by river current. USEPA 316(a) Manual at 78. Phytoplankton are a food source for zooplankton and fish. *Id.* at 55.

The demonstration for this category must show that the site is a low potential impact area, or, if not, show that it meets the following criteria:

1. A shift towards nuisance species of phytoplankton is not likely to occur;
2. There is little likelihood that the discharge will alter the indigenous community from a detrital to a phytoplankton-based system; and
3. Appreciable harm to the balanced indigenous population is not likely to occur as a result of phytoplankton community changes caused by the heated discharge. USEPA 316(a) Manual at 18.

The USEPA 316(a) Manual lists information that an applicant should provide for areas that do not qualify as low impact areas in this category. *Id.* at 20.

Background. In the 1960s and 1970s, studies on the effect of power plants on phytoplankton showed that adverse effects from power plant thermal discharges are rare. App. C at C-10. If they occurred, the effects were limited to a small area in the immediate vicinity of the discharge. These effects “were limited to periods of maximum discharge temperatures during the summer and during those hours when the circulating water was chlorinated to control biofouling of the condensers.” *Id.*

Population. The phytoplankton community and density near the Joliet Stations are similar to “the overall assemblage in the LDPR and the inputs from the CSSC and upstream tributaries.” App. C at C-11. On the Shannon-Weaver diversity indices, the entire UIW scored low for both diversity and evenness. *Id.* “Upstream (CSSC) locations had the sparsest phytoplankton density” while the highest density was found in the sample from the Joliet 29 discharge. *Id.* “[T]otal density was not low in portions of the waterway which have more extensive habitats for the development of both periphyton and phytoplankton.” *Id.*

“Mean diversity and evenness values were both slightly higher at the intakes than at the discharges (2.58/0.78 vs. 2.51/0.75).” App. C at C-11. Comparing similarity between both intake and discharge samples using Morisita’s Index “indicated that the community upstream of the Joliet Stations was closely related to that of the discharges.” *Id.* These results indicate that “there is no adverse impact from the operation of the Stations on the plankton community.” *Id.*

Species Composition. “Phytoplankton samples collected in 1993 from the Des Plaines River upstream of the Joliet Stations at RM 290.2, and at the Joliet Station 29 intake (RM 285.2) and discharge (RM 284.5) contained 69 taxa.” App. C at C-11. Most taxa occurred at only one of the three sampled locations. *Id.* “Eleven taxa occurred at all three locations and collectively composed 39% to 45% of the phytoplankton at the three sampling locations.” *Id.* “Overall, only four taxa (*Chroococcus minimus*, *Lygnbya contoria*, *Cyclotella menghiniana*, and *Melosira granualta*) accounted for more than 5.0% of the total densities.” *Id.*

“By sampling area, the relative abundance of blue-green algae (Cyanophyta) was much higher upstream of the stations and in the discharge than at the intake, and diatom taxa (Bacillariophyta) were much higher upstream and at the intake than at the discharge.” App. C at C-11. “The relative abundance of green algae (Chlorophyta) was greatest at the intake and discharge sampling locations.” *Id.* There were minor spatial differences for the other three major taxonomic groups. *Id.*

Food Source for Asian Carp. Asian carp consume phytoplankton, zooplankton, and macroinvertebrates voraciously. App. C at C-12. Asian carp “grow quickly and are highly adapted for feeding on these communities, allowing them to outcompete native species and quickly grow too large for most native predators.” *Id.* Limited phytoplankton densities in the upper portions of the UIW may slow the upstream migration of Asian carp due to low chlorophyll a concentrations. *Id.*; see App. E at E-8. Measured chlorophyll a in the UDIP has ranged from 5 µg/L from 2004 through 2011 while locations downstream with large numbers of Asian carp typically have chlorophyll a levels greater than 20 µg/L. App. C at C-12, citing Table C-1; see App. E at E-8.

Summary. Based on studies including ongoing monitoring of invasive species, MG concludes that “the Joliet Station 9 and 29 thermal discharges have not caused any appreciable harm to the phytoplankton community of the LDPR.” App. C at C-12.

Zooplankton and Meroplankton. Zooplankton are “[a]nimal microorganisms living unattached in water.” USEPA 316(a) Manual at 79. Zooplankton refer to small crustacea such as daphnia and cyclops; single-celled animals such as protozoa; and the planktonic life stage of many important species of fish and wildlife. *Id.* at 56, 79. Zooplankton are the primary food source for larval fish and shellfish. *Id.* at 56. Some species are planktonic throughout their life, while others termed “meroplankton” are planktonic only during a portion of their life cycles. *Id.* “If a heated discharge kills or prevents development of the meroplankton, fewer adult fish and shellfish will be produced each year.” *Id.*

The demonstration for this category must show that the site is a low potential impact area, or, if not, show that it meets the following criteria:

1. Changes in the zooplankton and meroplankton community in the primary study area that may be caused by the heated discharges will not result in appreciable harm to the balanced indigenous fish and shellfish population.
2. The heated discharge is not likely to alter the standing crop, relative abundance, with respect to natural population fluctuations in the far field study area from those values typical of the receiving water body segment prior to plant operation.
3. The thermal plume does not constitute a lethal barrier to the free movement (drift) of zooplankton and meroplankton. USEPA 316(a) Manual at 20.

The USEPA 316(a) Manual lists information that an applicant should provide for areas that do not qualify as low impact areas in this category. *Id.* at 21. MG's demonstration addressed zooplankton generally.

Background. “Zooplankton generally are not expected to be adversely impacted by thermal discharges.” App. C at C-18. They have broad physiological tolerances and behavior that allow them to survive in unstable environmental conditions. *Id.* Because zooplankton are rapidly transported and dispersed by currents, it is not likely that any organism would spend a significant amount of time in the discharge zone. *Id.* Zooplankton also have short generation times and high reproductive capacities, which allows populations to readily offset losses. *Id.* Consequently, even when transported through thermal plumes, it is unlikely that any meaningful change in growth or reproduction of zooplankton will occur. *Id.* at C-19; *see* Exh. A at 6-4.

Studies. Studies of power plant thermal discharges in the 1970s and 1980s support the conclusion that zooplankton represent a low potential impact biotic category. App. C at C-18. Studies showed that any effects on zooplankton populations “were limited to a small area in the immediate vicinity of the discharge, occurring with maximum discharge temperatures in the summer and during those hours when the circulating water was chlorinated to control biofouling.” *Id.*

Limited zooplankton sampling has been conducted near the Joliet Stations. App. C at C-19; *see* Exh. A at 6-4; App. E. at E-9. At a single location in the Dresden Pool, the ACRCC performed zooplankton sampling at a single location. “The zooplankton species assemblage was dominated by rotifers and overall abundance of the four groups assessed was sparse.” App. C at C-19.

Summary. The demonstration argues that “[t]he zooplankton assemblage in the LDPR is primarily determined by the dominance of main channel habitat, limited backwater sources, short residence times, and the physical-chemical limitations of the waterway.” App. C at C-19; *see* Exh. A at 6-5. It further argues that there is no evidence to conclude that the Stations’ discharges “have had any measurable effect on the downstream zooplankton assemblage.” *Id.*

Macroinvertebrates and Shellfish. Macroinvertebrates,² including shellfish,³ are an important part of “aquatic food webs” and provide a source of bait for sport and commercial fishing. USEPA 316(a) Manual at 58; *see* App. C at C-19. Thermal discharges may have numerous effects on macroinvertebrates, including reproduction and survival. USEPA 316(a) Manual at 59.

The demonstration for this category may show that the site is a low potential impact area for this category. USEPA 316(a) Manual at 23, 25. If it does not, it must meet the following decision criteria:

1. Standing Crop. Reductions in the standing crop of shellfish and macroinvertebrates may be cause for denial of a 316(a) waiver unless the applicant can show that such reduction caused no appreciable harm to balanced indigenous populations within the water body segment.
2. Community Structure. Reductions in the components of diversity may be a cause for the denial of a 316(a) waiver unless the applicant can show that the critical functions . . . of the macroinvertebrate fauna are being maintained in the water body segment as they existed prior to the introduction of heat. . . .
3. Drift. The discharge of cooling water equal to 30% or more of the 7-day, 10-year flow of a river or stream would be cause for concern and possible rejection of a 316(a) waiver unless the applicant can show that:
 1. Invertebrates do not serve as a major forage for fisheries,
 2. Food is not a factor limiting fish production in the water body segment, or
 3. Drifting invertebrate fauna is not harmed by passage through the thermal plume.
4. Critical Functions (Estuaries). Areas which serve as spawning and nursery sites for important shellfish and/or macroinvertebrate fauna are considered as zero allowable impact areas and will be excluded from consideration for the discharge of waste heat. Plants sited in locations

² “Macroinvertebrates” may be considered synonymous with “aquatic macroinvertebrates,” which are “those invertebrates that are large enough to be retained by a U.S. Standard No. 30 sieve (0.595-mm openings) and generally can be seen by the unaided eye.” USEPA 316(a) Manual at 73, 77.

³ “Shellfish” are “[a]ll mollusks and crustaceans (such as oysters, clams, shrimp, crayfish, and crabs) which, in the course of their life cycle, constitute important components of the benthic, planktonic, or nektonic fauna in fresh and salt water.” USEPA 316(a) Manual at 79.

which would impact these critical functions will not be eligible for a 316(a) waiver. Most estuaries will fall into this category. USEPA 316(a) Manual at 24.

The USEPA 316(a) Manual lists information that an applicant should provide for areas that do not qualify as low impact areas in this category. *Id.* at 25-28.

Benthic Macroinvertebrates. The demonstration argues that a combination of factors unrelated to the Stations' operations has led to conditions favoring "a tolerant to facultative benthic macroinvertebrate community." App. L at L-10; *see* App. C at C-20. These factors include "the prevalence of maintained deep-draft main channel habitat, lack of coarse substrate, limited-to-nonexistent riffle/run habitat, frequent fluctuating flows and water levels, legacy sediment contamination, barge traffic, disruption of near shore habitat, and upstream urban inputs and influence." App. L at L-10. The demonstration argues that this characterization is supported by "the lack of meaningful temporal and spatial trends among the variety of completed and documented assessments." *Id.*; *see* Exh. A at 6-7.

A 1993 study sampled 13 locations within the upper Dresden Pool, including two locations just upstream of the Stations' discharges and one location within the Joliet 29's discharge. App. C at C-20; *see* App. E at E-11. QHEI scores suggested that habitat factors - including tailwater habitat with limited improved substrate characteristics and multiple current velocity regimes as well as macrophyte beds providing instream cover - contributed to a similar or higher quality community near the Stations compared to upstream. App. C at C-20.

A 1994 survey collected samples at locations upstream, downstream, and within the discharges of the Stations. App. C at C-20; *see* App. E at E-11. Densities ranged from 558/m² to 1573/m², and taxa richness ranged from 22 to 28. App. C at C-20. Community metrics suggested a fair to poor benthic community. *Id.* QHEI scores were generally higher in and upstream from the Joliet 29 discharge "primarily due to the presence of very limited coarse substrate and higher current velocity." *Id.* Community metrics generally trended higher downstream from Joliet 29, indicating a higher quality benthic community, "which suggests that the coarse substrate and higher current velocity in the Brandon Road Dam tailwater have little positive effect on the quality of the benthic community at these sampling locations." *Id.* at C-20 - C-21.

In 2000 studies performed by MWRDGC, the trichopteran *Cynellus fraternus* accounted for 34% of observed taxa in the Dresden Pool. App. C at C-21. Oligochaeta were the next most dominant taxa at 20%. *Id.*

Although the demonstration cites thermal plume studies to argue that the benthic macroinvertebrate community is primarily outside the influence of the Stations' thermal plumes, additional benthic surveys took place in 2017 and 2018 in the UDIP upstream from, downstream from, and in the vicinity of the Stations' discharges. App. C at C-20, citing App. L; *see* Exh. A at 6-6; App. E at E-11.

The studies found 85 total taxa including 14 Ephemeroptera (mayflies), Plecoptera (stoneflies), and Trichoptera (caddisflies) taxa known as EPT taxa, which are considered to be less tolerant of environmental stressors. App. C at C-21, citing App. L, Table 1. More tolerant midges and aquatic worms make up 48 of the 85 total taxa observed and make up more than 75% of the fauna each year. App. C at C-21, citing App. L, Table 2. The demonstration reports that there were no obvious compositional changes from upstream to downstream as midges and worms consistently dominated at each sampling transect in both years and for 2017-2018 combined. App. C at C-21, citing App. L, Table 4; *see* Exh. A at 6-6.

Nonetheless, “specific dominant taxa varied by transect with five different taxa accounting for the highest density among the six transects sampled in 2017 and 2018 combined.” App. C at C-21, citing App. L, Table 5; *see* Exh. A at 6-6. Total taxa richness was highest at the furthest upstream locations on Transect 1 and lowest at Transect 4, the nearest locations downstream of the Stations’ mixing zones. App. C at C-21. However, less tolerant EPT taxa were similar among the four upstream transects and higher downstream at Transects 5 and 6. App. C at C-21, citing App. L, Table 5. These same longitudinal patterns largely repeated in individual years. “[I]ndividual taxa dominance varied by location, total taxa was similar among transects, and EPT richness was higher downstream of the Joliet stations than upstream.” App. C at C-21, citing App. L, Tables 6 and 7.

Freshwater Mussels. The demonstration argues that it would be extremely unlikely for mussels to be present in the immediate vicinities of the discharge areas. The demonstration attributes this primarily to the high water velocities and scouring, as well as elevated overall water temperatures, which have existed since the Stations began operating. App. C at C-22; *see* Exh. A at 6-7 – 6-8. Though the demonstration acknowledges that there is limited information on current mussel distribution in the LDPR, the available evidence indicates that potential habitat in the UDIP for mussels is poor in quality. App. C at C-23; *see* App. E at E-12.

Based on earlier surveys, there were no known significant mussel source waters between the Brandon Road tailwater and the confluence of the Kankakee River and the LDPR. App. C at C-24. Because mussels are long-lived species that do not move around and require long periods to establish themselves, the demonstration argues that 2008 data should be considered representative of the current population, particularly because the physical habitat has not changed. *Id.*; *see* Exh. A at 6-8.

In 2009 and 2011, basin-wide surveys formed part of the GLMRIS and evaluated mussel populations in the Des Plaines River. App. C at C-25; *see* Exh. A at 6-8; App. E at E-12. The surveys found only 18 of the 38 historically known species and no federally listed mussel species. *Id.* “Additionally, reproduction was not observed at any of the sites surveyed.” App. C at C-25.

A 2017 survey of the Des Plaines River found a total of 275 freshwater mussels representing eight species. App. C at C-26. No threatened or endangered species were found. *Id.* “Many of the transects exhibited unsuitable substrate for the state-listed mussel species known to inhabit the region.” *Id.*

Summary. The demonstration argues that a persistent benthic macroinvertebrate community through the previous assessments suggests that a factor more systemic than thermal discharges limits the community. App. L. at L-10; *see* Exh. A at 6-9. The demonstration concludes that these data demonstrate that “the thermal discharges of Joliet Stations 9 and 29 have had no significant adverse effect on the UDIP or Five-Mile Stretch benthic macroinvertebrate assemblages.” App. C at C-22; *see* Exh. A at 6-9.

Fish. “The discharge of waste heat can affect fish populations in many ways.” USEPA 316(a) Manual at 60. The applicant for alternative thermal effluent limitations must characterize the indigenous fish community to identify habitat use and provide baseline information on the fish community. *Id.*

The demonstration for this category may show that the site is a low potential impact area for this category. USEPA 316(a) Manual at 28. The USEPA 316(a) Manual lists conditions that must be met to determine that a discharge is in a low-impact area for fishes. *Id.* at 29. If not, it must demonstrate that “fish communities will not suffer appreciable harm from:

1. Cold shock;
2. Excess heat;
3. Reduced reproductive success or growth;
4. Exclusion from unacceptably large areas; or
5. Blockage of migration.” *Id.* at 28-29.

The USEPA 316(a) Manual lists information that an applicant should provide for areas that do not qualify as low impact areas in this category. *Id.* at 29-32.

Background. Since 1977, MG or its predecessor as owner of the Stations has continued annual fisheries monitoring. App. E at E-15. In 1993 and 1994, MG’s predecessor conducted a series of studies to assess the fish community along a 53-mile segment of the UIW including the entire UDIP. *Id.* at E-14. In addition to fish distribution and abundance, the studies assessed “fish age and growth, condition, movement, reproductive success, food habits, and incidence of disease or anomalies.” *Id.* at E-14 – E-15.

From 1994 to 2018, either MG or its predecessor has annually monitored the fish community in the UDIP with a standardized methodology. App. E at E-15. These studies seek “to document changes in the fish community in response to the two Joliet Stations’ operations.” *Id.*, citing Apps. F (2016), G (2017), H (2018). MG also prepared a report of the UDIP fish community under reduced operation as peaking facilities fueled by natural gas. App. E at E-15 – E-16, citing App. J; *see* Exh. A at 6-14. The demonstration argues that the 2017-2018 analysis “did not show a substantive improvement of the UDIP fishery during reduced operations to the Joliet Stations and resultant decrease in thermal loading.” Exh. A at 6-14. It further argues that a fish community that has been stable since 1997 indicates that “the historical heat load under

more base-loaded Joliet Station operations has not influenced the overall well-being of the UDIP fish community.” *Id.* at 6-15.

Also, since 2010 the ACRCC has overseen fisheries monitoring by the INHS and IDNR below the Electric Dispersal Barrier. App. E at E-15. While chiefly performed to monitor Asian Carp, monitoring also obtains information on other species. *Id.*

Criterion (1): Cold Shock. “Cold shock occurs when fish become acclimated to an elevated waterway temperature during winter months, but a sudden termination of the heat source causes a rapid drop in temperatures that can, in extreme circumstances, result in fish kills.” Pet. at 29; *see* App. B at B-44. Four factors are significant in evaluating the potential for cold shock:

1. the length of time fish have resided at the elevated temperatures in the plume,
2. the difference between discharge and ambient temperatures,
3. the rate of temperature decrease, and
4. the absolute magnitude of the lower temperature. App. B at B-44; *see* Pet. at 29.

“At ambient temperatures exceeding 45 °F, cold shock typically does not occur, regardless of the magnitude of the change.” Pet. at 29; *see* App. B at B-44. Ambient winter temperatures near the Stations are normally between 40.6 °F and 48.1 °F because much of their flow consists of treated wastewater discharged upstream. App. B at B-44; Pet. at 29. Also, the Stations’ thermal plumes do not experience an extremely rapid change in temperature after operations shut down. *Id.* The demonstration concludes that the Stations have not historically caused cold shock in the UDIP and that cold shock is not expected to be a concern in the future. *Id.*

The Board asked MG to comment on how often winter water temperatures fall below 45 °F and on the temperature drop below that level that would be significant enough to cause cold shock. Board Questions at 1.

MG responded that ambient winter water temperatures in the LDPR were at or below 45 °F approximately 60% of the time. It added that they were at or above 40 °F 80 to 85% of the time. MG Resps. at 3, citing App. D, Tables D-1c, D-1d. MG stresses that upstream temperatures lower than 40 °F were infrequent because POTW effluent consistently maintains winter temperatures within the 40-45 °F range. MG Resps. at 3.

MG argues that, with ambient temperatures in the range of 40-45 °F, “a temperature drop of 27 °F (*i.e.*, a weekly average fully mixed discharge temperature of 67-72 °F) would not cause cold shock mortality even if a unit were to shut down suddenly.” MG Resps. at 3-4 (citations omitted). It adds that this drop is “far below” the maximum design temperature change for the Stations’ condensers. *Id.* at 4.

MG states that the Stations “continue to discharge heated effluent for several hours following a shut down, thereby allowing for a more gradual transition back to ambient temperatures.” MG Resps. at 4. Since converting to natural gas, the Stations have not and are not generally expected to run continuously at length during the winter, which would allow aquatic life to acclimate to higher temperatures. *Id.* These factors limit the potential for cold shock to occur in the UDIP due to the operation of the Joliet Stations. *Id.* MG adds that there have been no known cold shock incidents in the UDIP/Five Mile Stretch since the Joliet Stations began operating as peaker plants, and there weren’t any such incidents documented in the past when the Stations operated in a more base-loaded manner. *Id.*

Criterion (2): Excess Heat. “Aquatic organisms are not exposed to constant elevated temperatures but experience thermal reductions during summer evenings as air temperatures decline.” App. B at B-38. Also, compared to thermal mortality test protocols providing well-mixed and constant temperature, natural habitats provide a range of temperatures. In addition, organisms are capable of avoiding stressful temperatures. *Id.*

“At ambient/acclimation temperatures above 31.1 °C (88 °F), acute mortality is not predicted for the RIS until temperatures in the thermal discharges exceed about 35 °C (95 °F).” App. B at B-37, citing Figures B-2 – B-10 (diagrams of thermal parameter data). Worse-case modeled temperatures below this level were predicted at the 250 foot transect at the theoretical edge of Joliet 9 mixing zone and at the 2,000 foot transect at the theoretical edge of the Joliet 29 mixing zone. App. B at B-37, citing App. D, Tables D-12a-p. Consequently, the demonstration predicts no acute or chronic mortality for any of the RIS. App. B at B-37. Even at both transects, there is a zone of passage in the lower water column. Based on avoidance temperatures, the RIS can be expected to avoid near-field acute or chronic water temperatures. *Id.* at B-37 – B-38. “Also, the assumption that ambient temperatures are representative of acclimation temperatures is conservative and could predict higher potential for thermal mortality than would actually be observed.” *Id.* at B-38. Fish in the discharge “may be acclimated to temperatures higher than the upstream ambient.” *Id.*

Criterion (3): Reproductive Success or Growth.

Spawning. Entrainment samples collected at the Stations included ichthyoplankton from April through August. App. B at B-41, citing App. C at C-28 – C-29. Mean water temperatures during those months ranged from about 62 °F to 82 °F in 2004, 56 °F to 88 °F in 2005, and 53 °F to 85 °F in 2016. App. B at B-41. For RIS, reported upper spawning temperatures range from 63.6 °F to 84.7 °F. *Id.* Average intake temperatures upstream from the Stations have been within these spawning temperatures except for White Sucker, which have been collected infrequently in the UDIP. *Id.*, citing App. C. Measured discharge temperatures and worst-case modeled temperatures have exceeded these spawning temperatures, although they “exaggerate actual temperatures found outside the allowable mixing zones.” App. B at B-41.

The only RIS likely to spawn after June are Channel Catfish and Bluegill. App. B at B-42. Their reported upper range for spawning is about 84-85 °F. Under the two typical summers temperature scenarios, models showed downstream transects slightly warmer for part of the day and cooler at other times. *Id.*, citing App. D, Figures D-16b, D-16c. Under the worst-case

temperature scenario, downstream temperatures would exceed 84 °F at all downstream transects but with cooler temperatures during off-peak periods. App. B at B-42, citing App. D, Figure D-16c. The demonstration argues that Channel Catfish and Bluegill could continue spawning into July in areas upstream of the Stations and downstream during period of lower temperatures. App. B at B-42.

Growth. For Common Carp, Channel Catfish, Bluegill, and Largemouth Bass, available upper zero growth temperatures exceed 93 °F. App. B at B-43, citing Table B-7a; *see* Table B-9 (temperature ranges for growth). Under average conditions, the demonstration argues that temperatures in the Stations' thermal plumes are unlikely to affect or halt growth for the RIS. App. B at B-43. Under the worst-case scenario, temperatures exceed 93 °F near the surface in the discharge zones and downstream. Under the two typical summer scenarios, it would do so only occasionally in the discharge zone. *Id.* The demonstration concludes that temperatures in the plumes “are not expected to adversely affect normal patterns of growth as long as high temperature periods are of limited duration.” *Id.*

Criterion (4): Exclusion from Unacceptably Large Areas. Although ability to avoid stressful temperatures may minimize potential fish mortality, it could result in avoiding habitats that may be affected by the thermal plume. App. B at B-39. The demonstration includes avoidance endpoints for Gizzard Shad, Channel Catfish, Bluegill, and Largemouth Bass. *Id.*, citing Table B-6 (avoidance temperatures), Figures B-2, B-7, B-8, B-9. Under the modeled worst-case scenario at ambient/acclimation temperatures of 80 °F to 95 °F, RIS with avoidance temperatures would not avoid areas at the edge of the mixing zones. App. B at B-39. Under the two typical summer scenarios, avoidance temperatures for these RIS “are typically higher than the highest plume cross-section temperature” at the edge of the mixing zones. *Id.*, citing App. D, Tables D-14f, D-14i, D-16f, D-16i. The demonstration argues that RIS for which avoidance data are not available generally have thermal endpoints similar to RIS for which they are available and would not be expected to avoid large areas of available habitat. App. B at B-39.

Criterion (5): Blockage of Migration. Because RIS would not be expected to avoid large areas of habitat, “it is unlikely that the thermal plumes would interfere with the migration and localized movement patterns (*e.g.*, diel and seasonal onshore/offshore, upstream/downstream, or spawning) of the fish community in the UDIP or the Five-Mile Stretch.” App. B at B-40. Under the worst-case summer scenario, the 250 foot transect provides a 97% zone of passage for temperatures at or below 96 °F. *Id.*, citing Table B-7a. Under the two typical summer conditions, temperatures at transects downstream of the 250 ft transect will not limit upstream/downstream movements “as 66% to 100% of the water column are projected to be below known avoidance temperatures.” App. B. at B-40. Under the worst-case winter scenario, “85% to 100% of the water column from 250 ft transect downstream were greater than 60 °F.” *Id.*, citing Table B-8a.

Threatened and Endangered Species. Fisheries monitoring has collected state-listed species. App. C at C-27, citing Tables C-6, C-7. A single River Redhorse was collected upstream below the Brandon Lock and Dam in 1994 and 2003. App. C at C-27. One Greater Redhorse was collected in 2010 at a far-field location. *Id.* The Pallid Shiner was first collected in 2000 and consistently through 2015. *Id.*

State-threatened Banded Killifish have been collected from the UDIP and Five-Mile Stretch every year since 2012. Twenty-two were collected in 2014, 52 in 2015, and 196 in 2016, most at downstream and far-field locations. App. C at C-28.

The demonstration states that factors contributing to the recent occurrence and expansion of the Banded Killifish population are not known, but its success near the Stations is likely due to the increased density of aquatic plants in the system. *Id.* However, the demonstration reports that Pallid Shiner catches have declined since 2003 and 2004 “because expansion of aquatic macrophytes has reduced sampling efficiency in the Five-Mile Stretch.” Exh. A at 4-9, citing Apps. F, G.

The Board asked MG to “comment in detail on how sampling efficiency has been affected by aquatic macrophytes.” Board Questions at 1.

MG first stressed that catches of the Pallid Shiner in the UDIP have in most years ranged from none to three with unusually high collections of them in 2003 and 2004. MG Resps. at 5. MG continued that dense aquatic plant growth may in some sampling locations make it difficult for biologists to get into the sampling areas and collect fish. This limits the effectiveness of sampling by restricting the overall sampling area or reducing sampling efficiency. *Id.*

The Board also asked MG to “summarize the sampling data to show whether the numbers for Pallid Shiner show an upward or downward trend since it was first caught in the study area.” Board Questions at 1. MG included the requested numbers from Appendix C, Table C-7. It argues that the data “indicate a slight increase in the number of Pallid Shiner collected in the UDIP and the Five-Mile Stretch study areas in 2017 and 2018. MG Resps. at 6

Federally-listed species for Will County include no fish species and one mussel species for which the UDIP does not provide suitable habitat. App. C at C-27. It also includes a number of other species such as mammals and plants that are “not expected to be affected by the operation of the Joliet Stations. *Id.*

Ichthyoplankton. Entrainment studies conducted at the Stations collected a total of 58 taxa. App. C at C-28, citing Tables C-8, C-9; *see* App. E at E-17. Ichthyoplankton composition was consistent with the fish community in the UDIP. App. C at C-28; *see* Exh. A at 6-10.

Juvenile and Adult Fish.

Species Composition. Surveys in the UDIP and Five-Mile Stretch documented the occurrence of 78 native and 10 non-native species. App. C at C-29, citing App. C, Table C-2; *see* Exh. A at 6-12. Three of the ten RIS (Gizzard Shad, Bluntnose Minnow, and Bluegill) accounted for 59% of the total catch. App. C at C-29. “Twenty-six species were collected each year including seven of the ten RIS: Gizzard Shad, Common Carp, Bluntnose Minnow, Channel Catfish, Bluegill, Largemouth Bass, and Freshwater Drum.” *Id.* “Common Carp and Goldfish were the only non-native species collected all or most years.” *Id.*

Distribution and Abundance. Statistical comparisons of 12 electrofishing catch parameters showed differences among four sampling areas. App. C at C-31, citing App. C, Table C-12. “Catch parameters in the mixing zone were statistically lower than the upstream area except for Native Fish, Bluntnose Minnow, and Channel Catfish.” App. C at C-31. However, 11 of the 12 parameters had statistically higher values downstream than in the mixing zone, which indicates that the Stations’ discharges have limited influence. App. C at C-31, citing App. C, Table C-12.

MG argued that “available or preferred habitat likely plays a more important role in fish distribution in this waterway than temperature.” App. C at C-31, citing App. K, Exhs. C-2 (habitat maps), C-3 (QHEI survey results).

Interyear Comparisons. MG compared electrofishing data to determine whether the Stations “have had an adverse impact on the fish community.” App. C at C-31. The comparison focused on the difference between 2016 and all other years because the Stations’ 2016 overall heat load “was the lowest of the previous 21 years.” *Id.* at C-32.

Total. Among all years, total catch rates “were statistically similar to the 2016 rate in the upstream and downstream sampling areas, and nearly all years in the mixing zone and far-field areas.” App. C at C-32, citing App. C, Figure C-6 (total catch rates), Table C-12 (statistical comparisons). “Overall, total catch rates were stable during the 22 years monitored.” App. C at C-32, citing App. C, Figures C-7 (native), C-8 (non-native), C-9 (Common Carp).

Gizzard Shad. “[U]pstream rates were similar among years except that the highest upstream rate in 2012 was significantly higher than in 1994 when the lowest rate was recorded.” App. C at C-33, citing App. C, Figure C-10 (gizzard shad catch rates), Table C-12. “[D]ownstream rates were statistically similar except for 1998 when that rate was higher than in 1994, 2009, and 2013. Similar differences were apparent for the downstream catch rates where rates in 1994, 2008, 2015, and 2016 were lower than in 1998.” App. C at C-33. “Inter-year differences were not significant most years in the three sampling areas with non-significant ANOVA results and there were no significant differences in the mixing zone where water temperatures were highest.” *Id.*, citing App. C, Figure C-10.

Common Carp. “Declining catch rates, especially in the upstream sampling area, resulted in significantly lower catches in 2016 compared to 11 years between 1994 and 2008.” App. C at C-33, citing App. C, Figure C-9 (Common Carp catch rates). In 2006, 2007, and 2009-2016, upstream catches of Common Carp “were lower, but statistically similar among years.” App. C at C-33. “Fewer differences were evident for the mixing zone where only the 1994 rate was higher than in 2016 and all other years were statistically similar.” *Id.* Before 2002, downstream catches “were significantly higher than in 2016 and declined after 2001.” *Id.* “Catches from 2002 through 2016 were lower, but statistically similar among years.” *Id.*

Bluntnose Minnow. Catch rates have been statistically different among years at each of the four sampling areas. App. C at C-33, citing App. C, Figure C-11 (bluntnose minnow catch rates); Table C-12. “Its 2016 catch rate from the upstream sampling area was significantly lower than the high rates found in both 2003 and 2009, whereas catch rates in the mixing zone were

similar among most years except 1994, 2000, 2011, and 2013 when rates were statistically lower than the highest rate in 2009.” App. C at C-33. Downstream, rates were “similar among years except for the higher rate in 2009, which was statistically higher than in 1994, 1995, and 1997.” *Id.* Far-field rates “were lower in 2016 than rates for 10 other years including six from 2005 through 2010.” *Id.* The demonstration argues that “Bluntnose Minnow catches varied more than other RIS because of schooling behavior and annual fluctuations in recruitment. *Id.*, citing App. C, Figure C-11.

Channel Catfish. “[C]atch rates from the upstream and mixing zone sampling areas were statistically similar among all years.” App. C at C-33. For downstream catches, analyses showed that catch rates in 2016 were similar to all other years. *Id.*, citing App. C, Figure C-12 (channel catfish catch rates), Table C-12. Far-field catch rates “were statistically similar among all years except that that rates in 2003 and 2004 were higher than in 1994 and 1995.” App. C at C-34. The demonstration argues that “catch rates were more consistent than the other RIS, with higher rates in the mixing zone most years suggesting attraction to the warmer water from the Joliet Stations, but mixing zone rates were statistically similar to the upstream rates.” *Id.*, citing App. C, Figure C-12.

Bluegill. Catch rates have generally increased since 1994, particularly in downstream and far-field areas. App. C at C-34, citing App. C, Figure C-13 (bluegill catch rates). In 2016, “upstream and downstream rates were statistically similar to rates from 15 of the 21 previous years and significantly higher than in 1994 and/or 1995.” App. C at C-34. The 2016 mixing zone rate was higher than years with the lowest rates (1994-1999) and the 2016 far-field rate was higher than in 1994, 1995, and 1997. *Id.*, citing App. C, Table C-12. Overall, Bluegill catch rates have increased since 1995 but were highly variable in the far-field and to a lesser extent downstream. In comparison, the upstream and mixing zone rates were both much lower but increased from 2011-2013. App. C at C-34, citing App. C, Figure C-13.

Largemouth Bass. Catch rates generally follow the trend for Bluegill, with increased catch rates after 1997. App. C at C-34, citing App. C, Figure C-14 (largemouth bass catch rates). In 2016, the catch rate “was significantly higher than the 1994 and 1995 rates from each of the four sampling areas.” App. C at C-34, citing App. C, Table C-12. “Overall, Largemouth Bass catch rates increased and were variable in the far-field and to a lesser extent in the downstream sampling area.” App. C at C-34, citing App. C, Figure C-14. Upstream and mixing zone catch rates were lower, but they “followed the same annual trend as the two downstream sampling areas with higher rates after 2012.” App. C at C-34.

Freshwater Drum. Upstream catch rates before 2005 were significantly higher than in 2016, but rates were statistically similar in 1999, 2001, and 2006 – 2016. App. C at C-34, citing App. C, Table C-12. “Overall, Freshwater Drum rates in the mixing zone, downstream, and far-field sampling areas were relatively stable compared to the upstream rates that peaked in 2000 and declined through 2016.” App. C at C-35, citing App. C, Figure C-15 (freshwater drum catch rates).

IWBmod. The demonstration applied the IWB, which uses the number of fish, weight, and diversity evaluation criteria, to electrofishing data as an indicator of fish health in the four

sampling areas. App. C at C-35; *see* Exh. A at 6-13. IWBmod “is sensitive to an array of environmental disturbances, particularly those that result in shifts in community composition without large reductions in species richness, numbers, and/or biomass. App. C at C-35. IWBmod classifies streams or stream segments as: Exceptional = ≥ 9.6 ; Very Good = 9.1-9.5; Good = 8.5-9.0; Marginally Good = 8.0-8.4; Fair = 6.4-7.9; Poor = 5.0-6.3; and Very Poor = < 5.0 . *Id.*

“IWBmod scores in the Joliet Stations study area ranged from 7.79 to 8.09 during the 22 study years and nearly 90% of the means in the upstream, downstream, and far-field sampling areas were in the fair range.” App. C at C-35, citing App. C, Table C-12. In most years, “the fish communities in the upstream, far-field, and downstream sampling areas would be considered fair.” App. C at C-35. Nearly 70% of the mixing zone means were in the poor range.” *Id.*, citing App. C, Figure C-16; *see* Exh. A at -13. The demonstration argues that “[t]hose lower scores had no apparent effect on the far field and downstream trends.” App. C at C-35. “Overall, IWBmod followed similar annual trends in each sampling area and were consistent among years.” *Id.*; *see* Exh. A at 6-13

Native Species Richness. “The mean number of native species collected in the four sampling areas was higher in the upstream sampling area than in the mixing zone and downstream sampling areas.” App. C at C-36, citing App. C, Figure C-17. For the four areas, annual means were statistically similar most years. App. C at C-36, citing App. C, Table C-12. The demonstration argues that “[d]ifferences in mean species richness reflect the influence of incidental species because seven of the 10 RIS were collected from each sampling areas, as were 67 species/taxa.” App. C at C-36, citing App. C, Table C-3.

Fish Condition. The demonstration used *Wr* and incidence of DELT anomalies to evaluate the condition of fish in the four sampling areas associated with the Stations. App. C at C-35; *see* Exh. A at 6-13.

Wr. “*Wr* is the ratio of the actual weight of a fish to what a healthy fish of the same length would weigh.” App. C at C-37. “A *Wr* range of 90-100 is a typical objective for most fish species. When mean *Wr* values are well below 90, problems may exist in food and feeding relationships.” *Id.*

“Mean *Wr* for the four sampling areas combined ranged from 82.4 (Longnose Gar) to 110.5 (Bluegill).” App. C at C-37. All but three species had mean *Wr* exceeding 90, and the mean for 14 species exceeded 100. *Id.*, citing App. C, Table C-14. “Of the seven RIS for which *Wr* could be calculated, Gizzard Shad and White Sucker were the only RIS with mean *Wr* less than 100.” App. C at C-37. “Overall, *Wr* for the RIS that were collected each year, approached or exceeded the goal of 90 or greater.” App. C at C-37, citing App. C, Figure C-18. The demonstration argues that “the RIS had consistently good *Wr* throughout the 22 study years at each of the four sampling areas.” App. C at C-37.

Wr Interyear Comparisons. The demonstration included inter-year analyses for “11 species that had sufficient sample sizes in 2016 and in four or more of the previous study years.” App. C at C-38. Although inter-year differences for seven species “were often significant, mean

Wr values were consistently greater than or equal to 96, and usually greater than 100.” *Id.* at C-39, citing App. C, Table C-17. The demonstration argues that “[t]his indicates that when significant inter-year differences occurred, they were due primarily to the extent in which *Wr* values exceeded the optimal value of 100 and not to suboptimal fish condition.” App. C at C-39.

Wr Summary. Analyzing fish condition shows significant longitudinal and inter-year differences in *Wr* values; “however, because 82% of the inter-year means were greater or equal to 90, it is apparent that the significant differences were due primarily to the extent in which *Wr* values exceeded the optimal value of 100 and not to suboptimal fish condition.” App. C at C-39, citing App. C, Table C-14; *see* Exh. A at 6-13. “Over the past 22 study years, 18% of inter-year mean *Wr* values were low enough (i.e., less than 90) to suggest that there may have been a health, food availability, and/or feeding relationship problem.” App. C at C-39, citing App. C, Table C-17. However, the demonstration argues that values below 90 “may be an artifact associated with their *Wr* equations not being appropriate for Midwestern populations.” App. C at C-39.

DELT Anomalies. “Higher incidence of DELT anomalies is a good indication of stress that may be caused by sublethal stresses, intermittent stresses, and chemically contaminated substrates.” App. C at C-40 (citation omitted); *see* Exh. A at 6-13. Surveys examined nearly 200,000 fish, and 9,354 of them (4.9% of the electrofishing catch) exhibited DELT anomalies. App. C at C-39, citing App. C, Table C-15. Among RIS, affliction rates were highest for Channel Catfish (83%), Freshwater Drum (39%), and Common Carp (37%). Rates were intermediate for White Sucker (15%) and Largemouth Bass (12%), or much lower for Gizzard Shad (<1.0%) and Bluegill (1.1%). *Id.*; *see* Exh. A at 6-13.

The demonstration argues that “higher affliction rates for bottom feeders suggest that the contaminated substrates within the study area are likely responsible for many of the DELTs observed on these species.” App. C at C-39 (citations omitted); *see* App. C at C-40; Exh. A at 6-13. It further argued that “incidence rates were noticeably lower for other common taxa.” App. C at C-39, citing App. C, Table C-15. “For example, at the family level cyprinids (excluding Common Carp and Bluntnose Minnow) and centrarchids (excluding Bluegill and Largemouth Bass) had very low incidence rates (0.3% and 1.8%, respectively) compared to the suckers (32%) and ictalurids (excluding Channel Catfish (17%).” App. C at C-39.

DELT Longitudinal Comparisons. Longitudinal patterns for rates of DELT anomalies were relatively similar among the 22 years that were compared. Rates “typically exhibited stepwise decreases” from the upstream sampling area to the Five-Mile Stretch. App. C at C-40, citing App. C, Table C-16. “Annual mean incidence rates decreased from 15.6% in the upstream sampling area to 3.0% in the far-field.” App. C at C-40.

“RIS with the lowest affliction rated (Gizzard Shad, Bluntnose Minnow, and Bluegill) had low mean rates in each of the four sampling areas.” App. C at C-40, citing App. C, Table C-15. “RIS with higher affliction rates (Common Carp, Channel Catfish, and Freshwater Drum) had higher rates in the upstream sampling areas.” *Id.*

“Overall, affliction rates for all taxa combined were highest in the upstream sampling area (13%), intermediate in the mixing zone and downstream sampling areas (9% and 4%, respectively), and lowest in far-field sampling area (2.5%).” App. C at C-40.

DELT Interyear Comparisons. Inter-year comparisons reveal that affliction rates for upstream and downstream segments “were higher in 1994 and 1995 than most subsequent years.” App. C at C-40, citing App. C, Figure C-19, Table C-16.

DELT Summary. DELT incidence “rates for the upstream, mixing zone, and downstream sampling areas have always been in the poor range,” while far-field rates “have been in the fair category during 16 of the past 22 years.” App. C at C-41. The demonstration argues that “disproportionately higher rates of affliction for bottom feeders suggest that the contaminated substrates within the study area are likely responsible for many of the DELTs observed on these species.” *Id.*

Invasive Species. The demonstration reports that, “[s]ince 2010, 16 non-native species have been captured accounting for 15% of total fish caught and 22% of the total species found upstream of the Electric Barrier on the CSSC.” App. C at C-18. However, the demonstration argues that the Stations’ “operations have not been responsible for these non-native introductions or their spread through the UIW. Operation of Joliet Stations 9 and 29 under the proposed near or far-field thermal AELs will not have any influence on the presence of ANS in the future.” *Id.*

Summary. MG assert that the data and supporting record demonstrate that the proposed ATEL are supportive of seasonal cycles of spawning and reproduction of the fish community in the UDIP/LDPR. Exh. A at 6-16. Further, the thermal plumes of Joliet Stations 9 and 29 do not reduce the important life history functions of the fish in the affected waterways when compared with areas upstream and downstream of the stations. *Id.* Given the the physical characteristics of the waterway and its available habitat, MG maintains that the fish community is supported and is not excluded from a significant portion of the UDIP. Additionally, MG notes that an “adequate zone of passage existed near the two Joliet Station thermal plumes under prior thermal limits, and will continue to exist under the proposed near-field thermal AELs.” *Id.* MG concludes that the operation of the Joliet Stations under the proposed near-field or far-field thermal ATELS would not result in adverse effects on the fish community in the UDIP or LDPR below the I-55 Bridge.

Other Vertebrate Wildlife. “Other vertebrate wildlife” includes birds (such as ducks and geese), mammals, and reptiles, but not fish. USEPA 316(a) Manual at 32, 77.

The demonstration for this category must show that “the site is one of low potential impact for other vertebrates.” USEPA 316(a) Manual at 32. If not, the demonstration must show that “other wildlife community components will not suffer appreciable harm or will actually benefit from the heated discharge.” *Id.*

Background. As a result of habitat fragmentation, hydrologic and geomorphic alterations, and urbanization and industrial use, “there is very little available habitat for a fully integrated wildlife community near the Joliet Stations.” App. C at C-41; *see* Exh. A at 6-16.

Nearby areas that have not industrialized consist largely of bottomland forest. App. C at C-41. Terrestrial wildlife in those areas is limited mostly to mammals such as White-tailed Deer (*Odocoileus virginianus*), Striped Skunks (*Mephitis mephitis*), and Raccoons (*Procyon lotor*). Other animals that have been documented but rarely seen in the area include Virginia Opossum (*Didelphis virginiana*), Muskrat (*Ondatra zibethicus*), North American Beaver (*Castor canadensis*), and American Mink (*Mustela vison*). *Id.*

Migratory Bird Species. Despite habitat fragmentation and industrialization, “the UIW is still utilized by resident and migratory bird species.” App. C at C-41; *see* Exh. A at 6-16 – 6-17. IDNR conducted surveys in 2014 and 2015 to identify migratory bird species utilizing the Des Plaines River, which included Canada Goose (*Branta canadensis*), Mallard (*Anas platyrhynchos*), Common Golden Eye (*Bucephala clangula*), Bufflehead (*Bucephala ableola*), and American Coot (*Fulica americana*). App. C at C-41. Also, “Bald eagles have been observed along the UIW and near the Joliet Stations.” *Id.* The demonstration argues that these bird species do not have “direct or indirect interaction with station operations or related site activities.” *Id.*; *see* Exh. A at 6-16 – 6-17. The thermal plumes do not attract large numbers of birds during spring or fall migration and do not attract over-wintering populations. Exh. A at 6-17. Also, “there is no unique or critical nesting, rearing, or feeding habitat for waterfowl in the immediate vicinity of the Joliet Stations.” *Id.*

Other Species. Urbanization and industrialization have also affected amphibian and reptile species. App. C at C-42; *see* Exh. A at 6-16. While there are no federally listed threatened or endangered species in Will County, there are several state-listed species, including the Four-Toed Salamander (*Hemidactylium scutatum*), Common Mudpuppy (*Necturus maculosus*), Ornate Box Turtle (*Terrapene ornata ornata*), Kirtland’s Snake (*Clonophis kirtlandii*), Eastern Massasauga (*Sistrurus catenatus*), Spotted Turtle (*Clemmys guttata*), and Blanding’s Turtle (*Emydoidea blandingii*). *Id.* Because “[m]any of these species are found in deciduous forests, prairies, or near streams with connecting wetlands,” the demonstration argues that they are not likely to be “found near the thermal discharge of the Joliet Stations, in the main river channel, or in the industrialized properties surrounding the UDIP and Five-Mile Stretch.” *Id.*

Summary. MG concluded that “[a]ctivity of vertebrate wildlife found in the area has not been affected by the thermal limits that Joliet Stations 9 and 29 have operated under since the Secondary Contact Standards were enacted in 1972 and are not expected to be affected by the proposed near or far-field thermal AELs in the future.” App. C at C-42.

Aquatic Nuisance Species (ANS). ANS are invasive organisms, “which are introduced into new habitats and produce harmful impacts on natural resources in the ecosystems into which they are introduced.” App. C at C-17. More than 180 non-native species have been introduced into the Great Lakes region,” and “[m]ore ANS are expected to be introduced in the Lake Michigan and the UIW over time.” *Id.* (citation omitted).

MG concludes that the Stations’ operations “have not been responsible for these non-native introductions or their spread through the UIW. Operation of Joliet 9 and 29 under the

proposed near or far-field thermal AELs will not have any influence on the presence of ANS in the future.” App. C at C-18.

CWA 316(a) Demonstration

MWG must demonstrate that its requested alternative thermal effluent limitations will assure the protection and propagation of the balanced, indigenous population in the UDIP and the Five-Mile Stretch. MWG’s 316(a) Demonstration has two components: a retrospective evaluation to demonstrate that the Stations’ operations have not caused appreciable harm to the BIC; and a prospective predictive demonstration for representative important species to evaluate the potential effects of future operation of the Stations under the proposed limitations. App. C at C-1; *see* App. B.

MG argues that “[b]oth evaluations demonstrate that the proposed ATELs will assure the protection and propagation of a balanced, indigenous community of shellfish, fish, and wildlife,” meeting the standard for granting ATELs under the CWA and the Board’s regulations. App. C at C-1. MG states that its demonstrations generally follow the USEPA 316(a) Manual. *Id.*

Type I Demonstration (Retrospective/Absence of Prior Appreciable Harm)

MG argues that “[t]he retrospective assessment shows that there have been no substantial changes in abundance of nuisance species or in the physical and biological components of the UDIP/Five-Mile Stretch during the past 24 years of biological monitoring data collected in these waterways.” Pet. at 30. MG states that, for much of that 24-year period, the UDIP was subject to standards “significantly less stringent” than the 2018 standard and its proposal. *Id.* MG adds that, during this time, “both the UDIP and the Five-Mile Stretch were subject to significantly more thermal loading from upstream sources,” such as the Crawford and Fisk Generating Stations that have been inactive since 2012 and the Will County Generating Station that has reduced its generating capacity. *Id.* Finally, MG notes that the Stations have converted from base load to “peaker” operation, resulting in lengthy periods offline and “a dramatic drop in annual thermal loading.” *Id.*; *see* App. E at E-15.

MG collected biological monitoring data during “peaker” operations at the Station. MG reports that electrofishing results in 2017 and 2018 “are consistent with findings from the pre-peaker historical studies (conducted between 1994 and 2016).” Pet. at 26. MG argues that this indicates that “mean summertime water temperatures have not influenced catch results within the UDIP on a consistent basis among the past 24 years.” *Id.*; *see* App. E at E-15 - E-16. MG also argues that winter electrofishing results further indicate that “water temperature is not the primary limiting factor to the UDIP fish community.” Pet. at 26, citing Exh. A at 6-15 – 6-17.

MG reports that it conducted its retrospective evaluation in two parts. First, it analyzed the condition of each biotic category “by comparing available information on its abundance and species composition to what would be expected based on existing habitat, flow, and chemical characteristics of the UDIP and Five-Mile Stretch.” Pet. at 25; *see* App. C at C-2; *see also* Rec. at 5. MG states that its DSP focused on the fish community. It argued that this focus “is practical and is based on the reasonable assumption that significant disruption at lower trophic

levels will be reflected in the fish community that relies on those biotic communities for food.” Pet. at 25; *see* App. C at C-3. MG stresses that its demonstration summarized data on all of the biotic categories. *Supra* at 60-81, Pet. at 25; *see* Exh. A at 4-1; App. C at C-2. Second, the demonstration analyzed long-term trends on the abundance for the biotic categories “to determine whether a change in population abundance has occurred that can be attributed to the operation of the Joliet Stations.” Pet. at 25; *see* App. C at C-2; *see also* Rec. at 5-6. MG also studied the water quality changes affected by factors other than excess heat.

Water Quality Changes. Factors other than excess heat can influence water quality and the biological function of aquatic systems. App. C at C-3. “These factors may interact with other pollutants in the water body, interact with the heat and chemical discharges, or interact with other uses of the water body.” *Id.* MG’s demonstration addresses factors that may influence water quality in connection with the Stations’ heated discharges.

Nutrients. MG’s demonstration argues that “[p]lower plants are not significant sources of nutrients.” App. C at C-3. However, “[o]rganic carbon, phosphorus, and nitrogen are elements most often associated with nutrient richness,” and the demonstration addresses each of them. *Id.*

Organic Carbon. Although MG reports that limited organic carbon data is available for the LDPR, the demonstration states that it “is not identified by IEPA as a cause of impairment for the LDPR.” App. C at C-3. The demonstration reports that dissolved carbon is generally “unavailable to aquatic organisms other than bacteria.” *Id.* While the Stations’ thermal discharges “may increase bacterial growth rates,” their operating history does not indicate any harm caused by this interaction under previous less stringent standards. *Id.* The demonstration argues that “[t]here is no reason to expect” that the Station’s thermal discharges under the proposed ATELS “would cause a harmful or detrimental reaction.” *Id.* at C-4.

Total Phosphorus. Until 2010, phosphorus had been identified as a cause of impairment in the segment including the Five-Mile Stretch. App. C at C-5. However, decreasing phosphorus levels since 2010 attributed to improved wastewater treatment resulted in removing phosphorus from the impairment listing for that segment. *Id.*, citing App. A, Table A-2 (303(d) list).

In the segment adjacent to the Stations, “there have not been any identified water quality impairments due to phosphorus.” App. C at C-5. The demonstration adds that phosphorus-containing additives used in the Stations’ operations “have been pre-approved for use by IEPA and have no reasonable potential of having any adverse impact on the receiving water at the final discharge concentrations.” *Id.*

The demonstration acknowledges that “[t]he most likely result of an interaction between the thermal plume and phosphorus would be an increase in the rate of algal growth during warm periods.” App. C at C-6. However, it argues “there have been no observed or documented incidences of increased algal abundance” near the Stations. *Id.* It also argues that “this would be a localized effect.” *Id.* The demonstration concludes that, since there has been no evidence of an interaction between phosphorus and the Stations’ thermal discharges in the past, there is no reason to expect that the heat discharged under the proposed ATELS would cause one. *Id.*

Total Nitrogen. The demonstration argues that between 2008 and 2011 levels of nitrogen decreased or remained stable in the Dresden Pool. App. C at C-6, citing App. A, Table A-6. It also argues that “[t]otal nitrogen has not been listed as an impairment for the LDPR in IEPA’s reports.” App. C at C-6, citing App. A, Table A-2 (303(d) list). The demonstration adds that nitrogen-containing additives used in the Stations’ operations “have been pre-approved for use by IEPA and have no reasonable potential of having any adverse impact on the receiving water at the final discharge concentrations.” App. C at C-6.

Biocides. Power plants generally apply some type of biocide “[t]o control biofouling organisms in cooling water systems.” App. C at C-6. Joliet 9 “does not use biocides, or any other chemical processes, to minimize biofouling of its condenser cooling system.” *Id.* Joliet 29 uses sodium hypochlorite to control biofouling in its condensers, but that use “is limited to only two hours per unit per day when the station is in operation.” *Id.* at C-7. The Station’s final effluent must be de-chlorinated, and its NPDES permit limits total residual chlorine concentration to 0.5 mg/L whenever biocides are used. *Id.* The demonstration reports that “[t]his limit has never been exceeded by the station.” *Id.*

Heavy Metals. A Use Attainability Analysis for the LDPR showed that sediment contamination is prevalent. App. C at C-8. A 2008 sediment study in the Dresden Island Pool and the lower portion of the Brandon pool showed “high concentrations of metals.” *Id.* The demonstration states that “movement of metals from the sediments into the water column is mediated principally by pH, which is not affected by temperature.” *Id.* at C-9. It argues that discharges from the Stations “do not cause the release of heavy metals from the sediments.” *Id.* The thermal plume is chiefly at the surface and does not interact with sediments. *Id.* The demonstration concludes that “[t]here has not been and should not be any potential for interactive impacts between the two thermal plumes, heavy metals and the biotic community.” *Id.*

Potability, Odor, and Aesthetics. The demonstration states that the LDPR has not been and is not now considered impaired for aesthetic reasons. App. C at C-9. It argues that factors such as upstream POTW discharges may sporadically affect its aesthetic quality. *Id.* However, because the proposed ATEs are more stringent than thermal limits that were in place for decades, the demonstration concludes that “there is no reason to expect that future thermal discharges from the Joliet Stations will have any negative effect on potability, odors or aesthetics of the LDPR.” *Id.*

Other Thermal Discharges. Based on average weather and river conditions, the demonstration reports that “there is no significant upstream thermal effects anticipated for either Joliet Station.” App. C at C-10. Although there are three downstream thermal dischargers, each has “an insignificant impact on the thermal regime of the UDIP, whether individually or collectively.” *Id.*, citing App. D.

Summary. The demonstration concludes that “[t]here is no evidence of harmful interactions” between the Stations’ thermal discharges and other pollutants or other thermal discharges. App. C at C-10. It also concludes that “[t]here is also no evidence suggesting that operation under the proposed near or far-field thermal AELs for the two Joliet Stations would cause such interactions.” *Id.*

Conclusions

MG argues that the demonstration includes no evidence showing that operating the Stations under previous thermal limits caused appreciable harm to the BIC in the UDIP or the Five-Mile Stretch. Exh. A at 3-4; *see* App. C at C-1; Exh. F. at 4-15 (fish). It argues that “[t]his was true for the period prior to the conversion of both stations from base-loaded, coal fired unit to gas-fired peaking units in mid-2016.” Exh. A at 3-4; *see* Pet. at 26. MG stresses that, even with this reduced thermal loading, “the waterway continues to be dominated by tolerant and highly tolerant species.” Pet. at 30. MG argues that, because temperature is not limiting or harming the BIC, it will be adequately protected by the proposed ATELS. *Id.* MG further argues that the 2018 numeric standards and narrative standards at 35 Ill. Adm. Code 302.211 “are more stringent than necessary.” *Id.*

Type II Demonstration (Predictive/Representative Important Species)

A Type II Predictive Demonstration must show that RIS “will not suffer appreciable harm from the heated discharge.” USEPA 316(a) Manual at 35. MG’s consultant used quantitative hydrothermal modeling to predict thermal conditions under various operating and ambient flow conditions (Appendix D), integrated with metrics of thermal requirements and tolerance limits identified in scientific literature for selected aquatic species representative of the BIC. Exh. B at B-2. Further, the predictive demonstration relied on hydrodynamic modeling and predictive analysis, along with historical data, integrated with RIS life history requirements to develop proposed seasonally-based near- and far-field thermal ATELS for Joliet Stations 9 and 29 that are protective of the BIC of the UDIP/Five-Mile Stretch. Exh. B at B-2.

MG argues that its predictive demonstration “provides reasonable assurance that the proposed numeric ATELS will allow for the protection and propagation of the UDIP/Five-Mile Stretch BIC.” Pet. at 30. It further argues that the proposed standards “are designed to maintain temperatures that are consistent with normal patterns of growth for aquatic life in the UDIP/Five-Mile Stretch.” *Id.* at 31.

Hydrothermal Model

The predictive demonstration used quantitative hydrothermal modeling. App. B at B-2; *see* Pet. at 26, 28. MIKE3 model outputs characterize and predict “hydrothermal conditions under both typical and worst-case scenarios based on real-world data.” Pet. at 26, citing App. D. The assessment compared the predicted thermal plumes “to available biothermal metric data related to survival, avoidance, spawning, and growth of fish.” Pet. at 26-27; *see* Exh. A at 3-5; App. B at B-2, B-17 – B-18.

Stressing the limitations of modeling and the Stations’ operating history and existing data, the demonstration argues that “the model results should mostly serve to supplement the Joliet Stations’ existing data and provide supplemental information for sets of conditions that may not have been fully captured in prior field studies.” App. D at D-40.

Model Development. The Danish Hydraulics Institute’s MIKE3 model used “[b]athymetric mapping, three-dimensional field surveys of water temperature and flow, and meteorological conditions to predict the configuration and temperature distribution of the Stations’ thermal discharges under various conditions.” App. B at B-3; *see* Pet. at 28; Exh. A at 2-5; App. D at D-39.

Model Domain and Mesh Generation. The model contained 3,711 cells, each of which was divided into eight layers of variable thickness. App. B at B-3, citing App. D, at D-40, Figures D-9a, D-9b. Variable depths allowed the model “to capture the stratification of the water column as demonstrated by the measured field data.” App. B at B-3; App. D at D-40. Near the Stations’ discharges and other areas of interest, the model increased grid complexity “to aid in accuracy.” App. D at D-40. As distance from the discharges increased, cell size increased “to optimize the number of model cells for shorter model simulation time.” *Id.*

The demonstration addresses the physical parameters used to establish model boundaries and develop the model.

Model Input/Output Parameters. Specific sources provided data for model simulations. First, the model used “[h]ourly Joliet Station 9 and Joliet 29 operational data.” App. D at D-43. Second, it used “[h]istorical hourly weather history and observations from the Joliet Regional Airport.” *Id.* Third, as the upstream boundary condition, it used flow and elevation data from the Brandon Road Lock & Dam, and as the downstream boundary condition, elevation data from the Dresden Island Lock & Dam. *Id.* Finally, the model “[a]ssumed steady-state maximum seasonal flow and temperature data from each of the three downstream dischargers.” *Id.*; *see id.* at D-47.

The model generated output for 16 transects along the UDIP from the Stations to the I-55 Bridge. App. D at D-43 – D-44.

River Bathymetry. The demonstration reports that UDIP bathymetric data was collected in 2017. App. D at D-41, Figure D-6 (map). From the Stations to the I-55 Bridge, “[t]he entire reach is channelized for commercial barge traffic and maintained by routine USACE dredging.” *Id.* at D-41.

Local Meteorological Data. The model used parameters including “air temperature, relative humidity, cloud cover, solar radiation, and wind speed and direction” to calculate surface heat exchange. App. D at D-42.

Downstream Thermal Dischargers. The model also included data from three downstream dischargers: Stepan Chemical, Flint Hills Resources and ExxonMobil. App. D at D-41 – D-42; *see id.* at D-46. “IEPA requested that any potential thermal influence from the Stations on the three downstream thermal dischargers be identified and, if necessary, addressed as part of the proposed thermal AELs.” App. D at D-46. IEPA sought to determine whether their compliance with thermal limits would be affected by MG’s proposed thermal ATELS. *Id.* at D-47. MG obtained data from them to incorporate into the MIKE3 model. *Id.* However, modeling that included their thermal discharges did not show any “discernable influence from

them on the modeled water temperatures in the UDIP.” *Id.* The demonstration argues that “[t]he small volume of discharge flow contributed by each of the three thermal dischargers therefore did not translate into any distinctly measurable thermal signature once mixed with the flow in the waterway.” *Id.*

Instead, the demonstration includes a compliance analysis for each of them “to determine whether, and to what extent upstream river temperatures influenced by Joliet Stations’ discharges may negatively impact ongoing compliance with the UDIP thermal limits.” App. D at D-48; *see id.*, Exhs. D-2a, D-2b. If so, the demonstration considered whether the three downstream dischargers should have “conditional coverage” under the proposed ATELS. App. D at D-48.

Model Calibration and Validation.

Summer Model. The demonstration calibrated the summer model with data from a July 13, 2017 thermal plume survey. App. D at D-44, citing App. D, Table D-8 (vertical measurements). Calibrated results showed “good agreement (within 1 °C)” between modeled and measured temperatures.” App. D at D-44, citing App. D, Figure D-10a.

The summer model was also calibrated with data from a July 17, 2012 thermal plume survey. App. D at D-45, citing App. I. Results showed “good agreement (within 1 °C/1.8 °F)” between modeled and measured temperatures. App. D at D-45, citing App. D, Figure D-10b.

Winter Model. The demonstration calibrated the winter model with data from a February 23, 2017 thermal plume survey. App. D at D-45, citing App. D, Table D-6. Calibrated results “showed good agreement (within 1 °C/1.8 °F)” between modeled and measured temperatures. App. D at D-46, citing App. D, Figure D-11a.

The winter model was also calibrated with data from a December 14, 2017 thermal plume survey. App. D at D-46; *see* App. D, Table D-10. Calibrated results showed “good agreement (within 1.5 °C/2.7 °F)” between modeled and measured temperatures. App. D at D-46, citing App. D, Figure D-11b.

Conditions Evaluated

The USACE monitors UDIP/LDPR flow and elevation at the Brandon Road Lock & Dam, which is immediately upstream from the Stations. App. D at D-23; *see* App. D, Tables D-4a, D-4b, D-4c (frequency distribution of flows). USACE also monitors flow and elevations of the entire Dresden Pool at the Dresden Island Lock & Dam, which is approximately 13.5 miles downstream from the Stations. *Id.* The demonstration argues that these flow data “do not adequately reflect the magnitude and frequency of the flow fluctuations characteristic of this waterway that are due to upstream manipulations for flood control and the maintenance of adequate navigational depth.” App. D at D-24; citing *id.*, Figures D-2a-d (flow fluctuations). The demonstration further argues that “[t]here is no seasonal, steady-state flow condition in the LDPR, which makes spatial and temporal predictive modeling of water temperature distributions challenging.” App. D at D-24.

Summer Worst-Case.

Scenario Development. The demonstration intended “to develop model input to represent the combination of ‘worst-case’ thermal compliance conditions that may be expected to occur at the Joliet Stations in the future, based on past conditions and with consideration of recent changes in upstream heat inputs.” App. B at B-25; *see* App. D at D-48; *id.* n.24. The “summer worst case” model scenario reflects “25th percentile low flow (2012-2017) and weather conditions similar to those encountered during 2012, combined with 75th percentile projected July megawatt load conditions for both Joliet Station.” App. D at D-48; *see* Exh. A at 4-2; App. B at B-3. “Use of the Joliet 29 cooling towers was also incorporated.” Exh. A at 4-2.

Meteorological Data. The demonstration determined that “early July 2012 weather conditions were closely represented by the 95th percentile July (2012-2017) weather records.” App. B at B-25. Using the 95th percentile July data reflects “the widespread heat wave and drought conditions prevalent over the entire Midwest, including the Chicago area, during this period.” *Id.*; App. D at D-49.

Ambient River Temperature. After reviewing the Stations’ intake temperature data for July 2012, the demonstration determined that “local recirculation of the discharge to the intake had occurred, resulting in artificially increased temperatures under extended high unit loads and low river flow conditions.” App. D at D-49. The demonstration notes that the Joliet Stations are no longer operated as base-load units, so they would not be run as they were in 2012 “even under extreme weather conditions with high load demand.” *Id.* Also, the Fisk and Crawford Stations were permanently closed in 2012, and the Will County Station has been indefinitely idled since 2015, reducing maximum potential heat contributions to the upper waterway and upstream temperatures from July 2012 conditions. *Id.* Based on these factors, the demonstration concluded that “subtracting 3 °F from the average hourly July P95 Joliet 9 and 29 intake temperatures would provide the necessary adjustment to reflect values that would be expected during an extreme summer period during current and future modeled conditions.” *Id.*

River Flow. Noting that LDPR flow continuously fluctuates, the demonstration argues that using changing flow inputs would make three-dimensional modeling of the entire waterway “extremely challenging.” App. D at D-50. The demonstration selected a constant flow value to limit flow variability and represent typical worst-case conditions. *Id.* The demonstration chose the 25th percentile July low flow (2,338 cfs) “as a valid representation of the river condition expected during a hot, dry summer.” *Id.*; *see id.*, Table D-4 (flow). The demonstration argues that actual average LDPR flow for July 1-7, 2012, was 2,314 cfs, confirming this flow value. *Id.* at D-50.

Plant Operational Data. The demonstration based the Stations’ load values on 2019-2021 projections by MG. App. D at D-50. It considered 75% July loads appropriate based on analysis and “review of historical load cycle data during similar weather and river conditions.” *Id.*, citing *id.*, Figure D-12a (loads). While the demonstration compared 75th and 95th percentile future load projections, it states that “[l]oads up to the 95th percentile may or may not be possible under all sets of adverse weather and flow conditions, and would need to be assessed based on continuing compliance assessments under such conditions.” *Id.* at D-50. The

demonstration concluded that “the 75th percentile load cycle would best reflect how the Joliet Stations would actually be expected to operate. . . .” *Id.*

The demonstration also established hourly discharge temperatures for the Stations for the 75th percentile July load projections. App. D at D-51, citing *id.*, Figure D-12c. Finally, the demonstration maintained a 24-hour load cycle for both Stations “with lower loads in the overnight hours.” App. D at D-51. It argued that “[t]his would be the expected type of unit operation under high load demand periods which typically occur during summer heat wave/drought conditions.” *Id.*

Intake and Discharge Flows. The demonstration set intake and discharge flows at Joliet 9 at 579 cfs (375 MGD), which reflects two-pump operation. App. D at D-51. It set Joliet 29 flows at 1,537 cfs (994 MGD). This reflects three-pump operation, which has been standard when the Station uses cooling towers. *Id.*

Use of Joliet 29 Cooling Towers. The demonstration developed model input data “with the assumption that the Joliet 29 supplemental cooling towers would be in use during the entire run time, with an average cooling effect on the end-of-pipe discharge temperature of 7 °C.” App. D at D-51. The demonstration based this value on cooling tower operating data from July 2012. *Id.* The model also assumed that 22 of the 24 towers would operate at any given time based on the average number of towers in service in July 2012. *Id.*; see Exh. A at 4-2.

Input Parameters. Based on the analyses and assumptions in the preceding subsections, the final model input variables for the “summer worst-case” scenario were selected. App. D at D-51; see *id.*, Table D-11 (model data).

Summer Typical Median Flow and Typical Low Flow. Both “summer typical” scenarios “were based on the 75th percentile values for intake temperature and corresponding 75th percentile weather parameters for the month of July from the 2012-2017 period of record, along with the 75th percentile projected load cycles for all three Joliet units for the month of July (2019-2021).” App. D at D-59; see Exh. A at 4-2; App. B at B-3, B-19, B-29.

Scenario Development.

River Flow. For the median flow scenario, the model used flow of 3,373 cfs, median July flow summer from 2012 to 2017. App. D at D-59; see App. D, Table D-4a (frequency distribution of hourly river flow); App. B at B-29.

For the low-flow scenario, the model used 2,720 cfs, the 50th percentile August flow from 2012 to 2017. App. D at D-59; see *id.*, Table D-4a; App. B at B-29. The demonstration states that “August has historically been a low flow summer month with concurrently higher load demand.” App. D at D-59.

Plant Operational Data. For both summer typical scenarios, the model used intake and discharge flows of 579 cfs for Joliet 9. App. D at D-59. For Joliet 29, the intake and discharge flow rate was 1,537 cfs with a cooling tower benefit of 7 °F. *Id.* For both stations, the model

used 75th percentile hourly measured intake temperatures from July 2012-2017. *Id.* The model based the loads for both Stations on 75th percentile future load projections with corresponding discharge temperatures based on the analysis performed for the “summer worst-case” scenario. *Id.* at 59-60

Meteorological Data. Both scenarios used “75th percentile of hourly values for air temperature and relative humidity.” App. D at D-60. Both also used a constant wind speed of eight mph based on averages July 2012-2017 for Joliet. *Id.*

Input Parameters. Based on the analyses and assumptions in the preceding subsections, the final model input variables for the “summer typical” scenario were selected. App. D at D-60; *see id.*, Tables D-13, D-15 (model data).

Winter Worst-Case

Scenario Development. The demonstration used the MIKE3 model “to assess the impact of expected Joliet Stations operations under the unseasonably high air temperatures and low flows” that occurred from December through March in 2012 to 2017. App. D at D-69; *see Exh. A* at 4-3; App. B at B-4, B-33.

River Flow. The “winter worst-case” scenario is based on 25th percentile low flow. App. D at D-69; *see App. D*, Table D-4b (flow). In the four winter months, the 25th percentile flow ranged from 1,653 cfs to 2,518 cfs. App. B at B-20. The demonstration argued that “low-flow conditions are driven primarily by upstream publicly-owned treatment works (POTW) flows (up to 100%) during this time of year.” *Id.*; *see Exh. A* at 3-7.

Meteorological Data. From the four winter months, the demonstrations first identified the high monthly air temperature readings for 2012-2017. App. D at D-69. Within those months, it then identified the maximum temperature dates:

Selected Date(s)	Daily High Air Temperature (°F)	Daily Low Air Temperature (°F)
31 January 2012	58	43
20-21 March 2012	84	61
12-13 December 2015	64	56
18 February 2017	70	36

Id. at D-69 – D-70; *see App. B* at B-32. The model then used “an average of the hourly air temperatures and relative humidity readings” for these six dates. App. D at D-70. The model also used a constant wind speed of 7 mph, “the average wind speed over the six identified winter dates.” *Id.* Based on average monthly values, “cloud cover for the winter condition was set at a constant 56%.” *Id.*

Ambient River Temperature. The model used 95th percentile intake temperature for 2012-2017 to represent ambient water temperature. App. D at D-70; *see id.*, Tables D-1c, D-1d (frequency distribution of intake temperatures).

Plant Operational Data. While the model used current winter hourly load projections, those projections do not show Joliet 9 “operating at any time during the months of December through March from 2019 through 2021. Therefore, the winter model runs were performed without operation of Joliet Station 9.” App. D at D-71, citing *id.*, Figure D-12b; *see* Exh. A at 3-8, 4-3 n.12. Operational data from 2012-2017 “showed that the overall heat contribution of Joliet Station 9 during the winter months is limited.” Exh. A at 4-3 n.12. The model used a 95th percentile load “as a surrogate for the Joliet 9 load.” *Id.*; *see* App. B at B-32; App. D at D-69.

To develop representative winter operating conditions, the model used the same analysis as the summer models. App. D at D-71, citing App. D, Figure D-12c.

Joliet 29 Cooling Towers. At Joliet 29, “cooling towers are not designed for winter operation, and were therefore not incorporated into any of the winter model scenarios.” App. D at D-70.

Model Input Data. Based on the analyses and assumptions in the preceding subsections, the final model input variables for the “winter worst-case” scenario were selected. App. D at D-71; *see id.*, Table D-17 (model data).

Winter Typical Median Flow. For the “winter typical/medial flow” scenario, the model “used median river flow, 75th percentile projected winter load, intake temperatures, and weather parameters (air temperature and relative humidity)” for December-March in 2012-2017. App. D at D-76; *see* App. B at B-4, B-20, B-33. The demonstration considered these conditions “to be most reflective of a typical set of winter operating conditions for the Joliet Stations.” App. D at D-76.; *see* App. D, Tables D-4b, D-19.

Winter Typical Low Flow. This scenario “used the 25th percentile low flow average for the months of December through March for the UDIP/LDPR.” App. D at D-78. The demonstration states that “[l]ow flow conditions are common in the UDIP/LDPR during the winter months when there is no upstream Lake Michigan diversion, lesser POTW flows, and little or no precipitation that results in run-off.” All other parameters were unchanged from the “winter typical – median” scenario. *Id.* at D-79; *see id.*, Tables D-4b, D-21.

Biothermal Metrics Evaluated

The predictive demonstration matches hydrothermal modeling of the Station’s thermal discharges to thermal response metrics for the RIS. App. B at B-4. The demonstration used data from scientific literature to determine thermal sensitivity of each of the RIS. *Id.* It evaluated potential effects of the discharges for five thermal effects:

1. Temperature requirements for survival of juveniles and adults;
2. Avoidance temperatures;
3. Temperature requirements for early development;

4. Optimum temperature for performance and growth; and
5. Thermal shock tolerance.

Id.; see USPE 316(a) Manual at 43-44. The demonstration examined the four biothermal metrics summarized in the following subsections.

Spawning Temperature Range. Spawning for many aquatic species is closely tied to water temperature. App. B at B-5. Data on spawning temperatures are generally based on field observations of spawning activity and physical condition in a species' geographic range. *Id.* Where adequate documented data exists, the demonstration plotted thermal effects to indicate the reported temperature range for spawning based on the spawning period near the Stations. *Id.*

Optimum Temperature for Growth. "Water temperature plays a significant role in the growth of aquatic species." App. B at B-5. For most temperate freshwater fish species, "growth is minimal during the winter and peaks between spring and fall." *Id.* Because aquatic organisms often prefer temperatures within their optimum growth range, "preferred temperatures can be used as a surrogate for the optimum range of growth and performance." *Id.* Outside an optimum range, growth can occur at a slower rate." *Id.*

Temperature Avoidance. Many aquatic species "actively avoid potentially stressful temperatures, both high and low, depending on their acclimation conditions." App. B at B-5. While this minimizes exposure to temperatures that could result in mortality, avoidance "may preclude access to critical habitat located within a thermal discharge plume." *Id.*

Chronic Thermal Mortality. As water temperature increases, aquatic organisms exhibit "responses including avoidance, impaired growth and reduced feeding, impaired swimming ability, loss of equilibrium, and mortality." App. B at B-7. Acclimation history affects these responses, and it is important to evaluate laboratory studies of thermal effects with reference to acclimation history. *Id.* The demonstration argues that "it is unusual to observe mortality related to elevated water temperatures because of the ability of many organisms to avoid potentially lethal temperatures." *Id.*

Mortality data associated with temperature can be qualified by rate of temperature increase or duration of exposure. App. B at B-6. "CTM is estimated with tests where organisms are subjected to a controlled rate of temperature increase over time . . . until loss of equilibrium." *Id.* "The tolerance limit for 95 percent of test organisms (TL95) measures the temperature at which 95 percent of the organisms survive for the exposure period." *Id.* "[L]ethal dose to 50 percent of the test organisms (LD50) measures the temperature causing mortality to 50 percent of the test organisms." *Id.*

Representative Important Species Selection

A CWA Section 316(a) Type II Predictive Demonstration must identify the representative important species for further study. "Representative important species" are

defined as “species that are representative, in terms of their biological needs, of a balanced, indigenous community of shellfish, fish, and wildlife in the body of water into which a discharge of heat is made.” 35 Ill. Adm. Code 106.1110; *see also* 40 C.F.R. § 125.71(b). Because it is not economically feasible to study each species in detail, a few are selected as representative important species for more detailed study. *See* Exh. A at 4-3, 5-1; App. B at B-7, citing App. B, Figure B-1, Tables B-1, B-2, B-3.

The USEPA 316(a) Manual lists these seven considerations for selecting representative important species:

1. Species mentioned in state water quality standards;
2. Species identified in consultation with other governmental agencies;
3. Threatened or endangered species;
4. Thermally sensitive species;
5. Commercially or recreationally valuable species;
6. Far-field and indirect effects on entire water body; and
7. Critical to structure and function of ecological system. USEPA 316(a) Manual at 36-39; *see* Exh. B at B-8; Pet. at 28.

MG’s predictive analysis considered additional factors in selecting RIS:

1. Numerical dominance or prominence in the BIC;
2. Their role in energy transfer through the aquatic food chain as important forage or predator species;
3. Important links between primary producers, primary consumers, and secondary consumers;
4. Similarity of their food, habitat, and life history requirements to groups of other species utilizing aquatic habitat near the Joliet Stations;
5. Non-native and potential nuisance species; and
6. Species with unique or critical habitat or life history stages near the thermal discharge. App. B at B-8.

Representative important species are selected from any combination of these three biotic categories: shellfish; fish; and habitat formers. USEPA 316(a) Manual at 36. However, the demonstration selected only fish species as RIS. App. B at B-8 - B-9. The demonstration argues that “fish represent the top of the food chain, are important to the public because of their

recreational and/or commercial value, and because their overall well-being shows that the lower trophic levels are supporting the trophic levels occupied by the RIS.” *Id.* at B-8 – B-9; *see* Pet. at 25. The demonstration did not select lower trophic levels as RIS because studies historically have shown only localized thermal effects that did not result in harm and also because of a “general lack of thermal endpoint data.” App. B at B-9.

In preparing a CWA Section 316(a) demonstration and underlying studies, petitioners must consult federal and state agencies to ensure that studies address appropriate wildlife. To this end, the Board’s rules require that a petitioner serve a copy of its petition on both IEPA and IDNR, as well as inform IEPA of its proposed representative important species list and supporting data and information. *See* 35 Ill. Adm. Code 106.1115(a)(4), 106.1120(b)(5), 106.1125. In addition, the USEPA 316(a) Manual advises that the permitting authority:

[C]heck with the Regional Director of the [U.S. Fish and Wildlife Service] and representatives of the [National Marine Fisheries Service] and States to make sure the study plan includes appropriate consideration of threatened or endangered species as well as other fish and wildlife resources. USEPA 316(a) Manual at 15.

The demonstration reports that IEPA and IDNR approved the RIS “after notice to and review by USEPA Region 5.” Exh. A at 5-1.

The USEPA 316(a) Manual elaborates on the most thermally sensitive species, stating that they

should be identified and their importance should be given special consideration, since such species (or species groups) might be most readily eliminated from the community if effluent limitations allowed existing water temperatures to be altered. Consideration of the most sensitive species will best involve a total aquatic community viewpoint. USEPA 316(a) Manual at 37.

The applicant must collect thermal effects data for each representative important species, including:

1. high temperature survival for juveniles and adults;
2. thermal shock tolerance;
3. optimum temperature for growth;
4. minimum and maximum temperatures for early development;
5. normal spawning dates and temperatures; and
6. any special temperature requirements for reproduction. USEPA 316(a) Manual at 43–45.

The demonstration selected as RIS are addressed in the following subsections. *See* App. B at B-9.

Gizzard Shad. The gizzard shad is an important forage species near the Stations and a prolific warmwater species found throughout the Illinois River drainage and the state. App. B at B-11. Near the Stations from 1994 to 2016, “[i]t was the most or second most abundant species collected during 20 of the 22 years surveyed.” *Id.* at B-12. Electrofishing and seine catches averaged 2,062 Gizzard Shad with a range of 393 to 6,591. *Id.* While this varies widely, “annual catches have not exhibited any long-term trends.” *Id.*

“Spawning occurs in open water from about late April through June.” *Id.* Samples found peak densities of yolk-sac larvae in May where temperatures were between 55.3 °F and 73.3 °F. App. B at B-11. Post yolk-sac larvae were most abundant in late June when temperatures ranged from 73.1 °F to 87.2 °F. *Id.*

Common Carp. Common Carp is a non-native warmwater species introduced to Lake Michigan in the nineteenth century. App. B at B-12. At high numbers, it “is considered a nuisance species, particularly during spawning season when they can be responsible for high turbidity levels as they thrash about in shallow weed beds and over silty substrates.” *Id.* Near the Stations from 1994 to 2016, “[i]t was collected during each survey year and was the eighth most abundant species collected overall.” *Id.* Catches of Common Carp peaked in the 1990s and have with few exceptions declined since 1997. *Id.*, citing Table B-3.

Common Carp spawn in shallow weedy areas in the spring and early summer where their adhesive eggs are broadcast over debris and vegetation. App. B at B-12. During entrainment sampling, early life states of the Common Carp accounted for 20% of the ichthyoplankton collected at Joliet 29 in 2004 and 2005 and 16% at Joliet 9 in 2016. *Id.*

Bluntnose Minnow. The Bluntnose Minnow is a native forage species occurring throughout Illinois. App. B at B-12. They are nest builders that provide parental care. *Id.* Near the Stations from 1994 to 2016, “[i]t was collected each survey year and was the most abundant species overall.” *Id.* at B-13. Catches “were lowest in the 1990s, peaked in 2003, and have been abundant since, but catches have been variable.” *Id.*, citing Table B-3.

“Spawning occurs in gravel or sandy shoals from about May into August.” App. B. at B-12. Early life stages of the Bluntnose Minnow are rarely collected in ichthyoplankton samples around the Stations. *Id.*

River Redhorse. The River Redhorse is a native river species in the sucker family that is distributed widely in the eastern U.S. App. B at B-13. It is listed as threatened in Illinois and included as an RIS for that reason. *Id.* Only two River Redhorse have been collected from the Stations’ study area, one in 1994 and one in 2003. *Id.*

River Redhorse normally spawn in April and May. They prefer riffle and run habitats with clean coarse substrates, particularly for spawning. App. B at B-13. It would not be

expected for them to be prevalent in the UDIP or the Five-Mile Stretch, which consist of slow water currents and predominantly soft, fine substrates. *Id.*

The demonstration selected Golden Redhorse as surrogate species. App. B at B-13. It was collected in each of the 22 survey years and was the most abundant redhorse, species. Near the Stations from 1994 to 2016, annual catches averaged 27 with a range of two to 101. *Id.* at B-13 – B-14.

White Sucker. The White Sucker is a demersal warmwater species widely distributed through Illinois and Lake Michigan. App. B at B-14. It prefers sand and coarse substrates in small creeks and rivers but may be found in habitats with silt and fine sediment. *Id.* White Sucker occurred in 19 of the 22 survey years with an average catch of 13 and a maximum of 160. *Id.*, citing Table B-3. Although it is not common near the Stations, the thermal assessment includes it “because it is relatively sensitive to increases above ambient temperatures in the summer.” App. B at B-14.

“Spawning occurs during April and May over gravel substrate in riffles and pools.” App. B at B-14. During entrainment studies at Joliet 29, two White Sucker yolk-sac larvae and three post yolk-sac larvae were collected. *Id.* When they were found, water temperatures were between 55.3 °F and 66.0 °F. *Id.*

Banded Killifish. Banded Killifish is a state-listed native species that is normally found in clean water with vegetation and substrates of sand or organic debris free of silt. App. B at B-14. Banded Killifish were not collected in surveys of the UIW until 2012. It has been found near the Stations every year from 2012 to 2016. *Id.*, citing Table B-3. The 2016 catch “was nine times higher than prior annual catches.” App. B at B-14. The demonstration considers increased density of aquatic plants as a likely cause of this increase. *Id.* at B-15.

Spawning occurs in late spring through early summer when temperatures are about 73 °F. App. B at B-15. While 2004 and 2005 entrainment studies were performed before Banded Killifish were first found near the Stations, low numbers were entrained in 2016 at Joliet 9. *Id.*

Channel Catfish. Channel Catfish is a common native sport and food fish found throughout Illinois. App. B at B-15. They are usually found in the greatest abundance in fast-flowing, medium to large rivers with sand and gravel-substrates, but they tolerate the range of habitats near the Joliet Stations. *Id.* From 1994 to 2016 near the Stations, Channel Catfish have been collected each year with an average catch of 148 and a maximum of 280. *Id.*, citing Table B-3. It was “the most abundant of five catfish species collected.” App. B at B-15.

Spawning typically occurs in June and July. App. B at B-15. Because of its nesting behavior, Channel Catfish do not commonly appear in ichthyoplankton surveys. *Id.* However, in the week before early life stages are first observed, water temperatures were between 74.7 °F and 84.6 °F. *Id.*

Largemouth Bass. Largemouth Bass is a popular recreational fish species that uses a variety of habitats. App. B at B-16. From 1994 to 2016 near the Stations, it occurred every year

with an average catch of 596 and a maximum of 1,771. *Id.* Catch rates suggest increasing abundance since 2000. *Id.*, citing Table B-3.

Spawning mostly occurs in May and June with nest construction in sand, gravel, and around vegetation. Males guard the nest in early life stages. App. B at B-16. Because nesting behavior limits exposure to entrainment, Largemouth Bass larvae and early fry were not collected in 2004-2005 studies at Joliet 29 or the 2016 study at Joliet 9. *Id.*

Bluegill. Bluegill is a widely distributed native species usually found in clear lakes, although it can tolerate habitats near the Joliet Stations. App. B at B-16. From 1994 to 2016 near the Station, Bluegill was the most abundant of eight sunfish species. It occurred in each of 22 survey years with an average catch of 2,577 and a maximum of 6,307. *Id.* at B-17, citing Table B-3. “It ranked 1st to 13th annually in abundance and averaged 2nd overall.” App. B at B-17. While catch rates varied, they have generally increased since 2000. *Id.*

“Spawning begins in late May and often continues into August.” App. B at B-16. Entrainment studies do not collect juvenile Bluegill in large numbers. *Id.* During the week prior to the first observation of yolk-sac larvae, water temperatures were 74.6 °F in 2004 and 81.7 °F in 2005. *Id.*

Freshwater Drum. Freshwater Drum is a native species that prefers large rivers, but it is also found in larger lakes and may ascend smaller rivers. App. B at B-17. From 1994 to 2016 near the Stations, Freshwater Drum occurred in every study year with an average catch of 89 and a maximum of 144. “It ranked 3rd to 22nd annually in abundance and averaged 19th overall.” *Id.* Catch rates have varied but decreased after 2004. *Id.*, citing Table B-3.

Although spawning information is limited, it is believed that spawning occurs during May and June. App. B at B-17. During 2004-2005 entrainment studies at Joliet 9 and 29, “Freshwater Drum eggs were the most abundant taxa/life stage.” *Id.* In 2016 entrainment studies at Joliet 9, “Freshwater Drum eggs accounted for 5.4% of the ichthyoplankton collected.” *Id.* When eggs first appeared in entrainment samples, water temperatures ranged from 59.8 °F to 65.4 °F. *Id.*

Species-Specific Biothermal Response Data

Acclimation-Ambient Temperatures. Because fish are cold-blooded, their body temperature is determined by the temperature of the surrounding water. App. B at B-18. “Acclimation temperature is the temperature to which an organism has been exposed for a period adequate to achieve physiological equilibrium.” *Id.* Acclimation condition can affect response to a water temperature gradient. As an example, “organisms acclimated to winter or early spring water temperatures typically exhibit avoidance or preference for temperatures significantly lower than the same organisms acclimated to warmer summer ambient water temperatures.” *Id.*

The demonstration argues that thermal effects data based on controlled laboratory acclimation temperatures “need to be considered in the context of the acclimation history of

organisms that might be exposed to the Joliet Station 9 and 29 thermal discharges and conditions in available proximal habitat.” *Id.*

Thermal Assessment Diagrams for RIS. The demonstration constructed thermal diagrams for the RIS “to graphically present the relationship of acclimation temperature and the selected biothermal response metrics” to help interpret potential effects of the Stations’ thermal discharges on the RIS and the aquatic community they represent.” App. B at B-20; *see id.*, Figures B-2 – B-10. The demonstration notes that, because of limited thermal endpoint data, it could not develop a thermal diagram for Banded Killifish. App. B at B-20. The demonstration uses the thermal diagrams to predict potential effects of measured and modeled thermal discharges on the aquatic community represented by the RIS. *Id.*

Acute Thermal Mortality. “This metric depicts the lethal response of organisms to dynamic temperature increases over a relatively short period.” App. B at B-21. It is expressed by CTM, which may use loss of equilibrium in place of final mortality as the test endpoint. *Id.*

Chronic Thermal Mortality. This metric depicts a mean tolerance limit, “the acclimation/exposure temperature combinations at which 50 percent mortality would occur due to elevated temperatures for a prolonged exposure of more than 24 hours.” App. B at B-21. The demonstration argues that “[c]hronic mortality is a very conservative measure of potential thermal effects because it assumes fish are unable to avoid potentially lethal elevated temperatures by moving to cooler temperatures.” *Id.*

Avoidance. “A thermal avoidance response occurs when mobile species evade stressful high temperatures by moving to water with lower, more acceptable temperatures.” App. B at B-21. While avoidance can minimize mortality, “it can also deter organisms from occupying otherwise useful or critical habitat that may occur near a thermal plume.” *Id.*; *see id.*, Table B-6.

Thermal Preference Zone. “Optimal temperatures for growth are defined as the preferred temperature of fish in a thermal gradient.” App. B at B-21. Thermal preference data “delineate the acclimation and exposure temperature combinations from which optimal growth (*i.e.*, preferred temperatures) would be predicted.” *Id.* (citation omitted). Distribution of optimal and non-optimal water temperatures vary naturally, and the configuration of a thermal plume can add variability. *Id.* Using MWAT for growth attempts to account for this variability. *Id.*

The demonstration argues that “growth occurs to a greater or lesser extent over a range of temperatures and a thriving population can be maintained even when temperatures are non-optimal during certain periods or in a segment of a waterbody.” App. B at B-22. It further argues that fish can avoid areas with non-optimal temperatures. *Id.* Because it is difficult to measure the effect of the plume on individuals, the demonstration considers the amount of habitat affected by the thermal plume where water temperatures are outside of the optimum range for growth and the frequency of that effect. *Id.*

Thermal Tolerance Zone. This extends beyond the preference zone and “delineates the temperature regime over which each species can survive and continue to grow, but at less than optimum rates.” App. B at B-22. The demonstration argues that temperatures outside the

tolerance zone but below the onset of predicted chronic mortality “delineate the temperature regime over which a species can survive, but in which they may be stressed and experience near-zero growth or weight loss.” *Id.* (citations omitted).

Thermal Range for Spawning. “This range is typically based on field observations of natural spawning activity.” App. B at B-22. With adequate documented data, this range indicates the temperature range for spawning based on the season during which it occurs near the Stations. *Id.*

Lower Lethal Temperatures. “Lower incipient lethal temperatures (chronic exposure) and cold shock (acute rapid exposure) measure mortality caused when organisms acclimated to warm temperatures in the thermal plumes are exposed to significantly colder ambient water temperatures.” App. B at B-23. This may occur after a Station outage when fish attracted to plumes in winter are exposed to cold ambient water temperatures. *Id.*

The demonstration stresses that ambient winter temperatures in the LDPR typically are higher than in other systems “because much of the winter flow is treated wastewater.” App. B at B-23. At Joliet 29, measured intake temperatures from 2012-2017 “have been greater than 40.0 °F more than 50% of the time.” *Id.*, citing App. D, Table D-1d. The demonstration argues that, “[a]t ambient temperatures exceeding 45 °F cold shock typically does not occur, regardless of the magnitude of the change.” App. B at B-23

Periods of Occurrence. Entrainment studies conducted at the Stations “confirmed spawning of resident species in the LDPR occurs from April through August. App. B at B-23. “Primary spawning activity generally occurred in May, increased and stabilized through June, and then tapered off through July with significantly lower abundance of early life stages of fish in April and August.” *Id.*

For the RIS, the demonstration states that young of the year and adults of the RIS occur June through September, during which proposed summer near-field limits would apply. App. B at B-23. Proposed winter near-field limits are not expected to affect RIS near the Stations “because temperatures will remain lower than avoidance temperatures and preferred temperatures.” *Id.*

Hydrothermal Analysis

The demonstration compared model-estimated water temperatures to biothermal metrics “to estimate the extent of otherwise available aquatic habitat that would be excluded or would be at less than optimum conditions for selected life history functions . . . of RIS due to water temperature, while still allowing for an adequate zone of passage.” Pet. at 29; *see* Exh. A at 3-5, 4-2; App. B at B-17 – B-18, B-25, B-45.

Summer Worst-Case Model Results.

Projected Isotherm Extents. The model calculated the thermal isotherm surface area for different temperature increments:

Scenario 1	Isotherm Temperature		Near-Surface Layer Plume Area in Entire Model Domain
	(°F)	(°C)	(acres)
"Worst-Case" Summer Conditions comparable to July 2012	>90	32.2	460
	>93	33.9	291
	>94	34.4	183
	>95	35.0	47
	>96	35.6	21
	>97	36.1	11
	>98	36.7	0

App. B at B-28; App. D at D-56; *see* App. D at D-68. The demonstration acknowledges that the "summer worst-case" scenario "resulted in temperatures in excess of the numeric thermal limits" that took effect in 2018. App. D at D-56. However, it argues that the isotherm distribution and cross-sectional temperature distribution show that "the highest water temperatures are largely confined to the areas immediately below each Station's discharge, and become largely surficial and/or fully mixed as the thermal influence of the Joliet Stations' discharges moves downstream." *Id.*, citing *id.*, Figures D-13a, D-13b (isotherm distributions), Tables D-12a – D-12p (cross-sectional temperatures).

Zone of Passage. Although this scenario resulted in plume temperatures exceeding new numerical thermal water quality standards, cross-sectional temperature distributions show that "the thermal plume, once downstream of the immediate discharge area, is largely surficial." App. B at B-28, citing App. B, Table B-7a; App. D, Table D-12a – D-12p, Figures D-12a, D-12b; *see* Exh. A at 2-5. The demonstration argues that the proposed ATEs maintain an adequate ZOP:

Transect (ft)	Transect Description	Mean Transect Temperature (°F)	ZOP ≤90°F	ZOP ≤93°F	ZOP ≤94°F	ZOP ≤95°F	ZOP ≤96°F	ZOP ≤97°F	ZOP ≤98°F
-3350	Upstream	86.2	100%	100%	100%	100%	100%	100%	100%
-1720	J9 discharge into river	92.8	29%	40%	46%	59%	94%	100%	100%
-250	Upstream of J29 discharge	93.4	20%	44%	51%	70%	77%	91%	100%
250	J29 discharge into river/theoretical J9 MZ edge	93.7	3%	17%	64%	91%	97%	100%	100%
2000	Theoretical J29 MZ edge	93.9	0%	20%	54%	89%	100%	100%	100%
7000	Downstream of both J9/J29 discharges	94.3	0%	0%	31%	100%	100%	100%	100%
15000	~Halfway down to I-55	93.2	0%	19%	100%	100%	100%	100%	100%
26700	Jackson Creek/downstream dischargers	93.5	0%	7%	83%	100%	100%	100%	100%
33350	I-55 Bridge/end of model domain	92.3	0%	67%	100%	100%	100%	100%	100%

Adjacent shaded areas generally represent a difference between isotherms of less than 0.5-1.0°F

(The above represents specific transects of interest and is a sub-set of the 16 transects for which model data was generated—all cross-section data is provided in Appendix D, Tables D-12a through D-12p).

App. D at D-56, citing 35 Ill. Adm. Code 302.102(b)(6), (b)(8).

Downstream Dischargers. Under worst-case scenarios, model results suggest that two of the three downstream dischargers may not consistently be able to comply with the UDIP summer thermal limit. App. D. at D-86, citing *id.*, Figures D-13a, D-13b, Tables D-12n, D-12o. The demonstration adds that 'worst-case summer' modeling shows that downstream thermal

dischargers “could potentially experience upstream water temperatures directly attributable to the operation of the Joliet Stations that would make it difficult or impossible for the discharges to consistently meet the UDIP summer limits.” App. D at D-84. MG recommended that “IEPA consider whether these downstream discharges may be afforded coverage” under the proposed ATEs, if granted, under specified adverse conditions. *Id.*

Summary. This scenario generated the highest expected discharge temperatures and the “largest thermal plume extents, with maximum surface plume isotherms near 96 °F.” App. B at B-45. The demonstration notes that this is the proposed maximum near-field limit. *Id.* Based on recorded discharge temperatures from 2012 to 2017, temperatures approaching this scenario “are expected in July and/or August up to 10% of the time on average.” *Id.*; *see* Exh. A at 3-5. The demonstration stresses that, “on an annual basis, the Joliet Stations’ discharge temperatures have never exceeded 93 °F for more than 5% of the time.” Exh. A at 3-5.

The demonstration adds that extended periods of low river flow “can limit allowable dilution and thereby lessen the available heat dissipation, resulting in higher calculated near-field compliance temperatures.” App. B at B-45. This is the basis for MG’s proposed summer thermal limit of 93 °F applied at the edge of the mixing zone with excursions up to 96 °F. *Id.*

The demonstration argues that these summer worst-case modeling results show that MG “has proposed near-field summer thermal AELs which will remain protective of the BIC in the UDIP, while allowing both Joliet Stations to continue to operate under adverse weather and flow conditions when power demand is generally at its greatest.” App. B at B-28. The demonstration further argues that the previous limit of 93 °F with excursions allowed up to 100 °F has been shown to have no detrimental effect on the BIC in the UDIP. It adds that temperatures reaching or exceeding 96 °F “would occur infrequently and for short durations. Furthermore, fish are able to seek cooler temperatures if their avoidance temperatures are reached or exceeded.” *Id.* at B-46.

The demonstration also argues that proposed far-field thermal ATEs, in place as the AS 96-10 standards, “continue to be protective of the RIS and, by extension, the BIC of the LDPR as a whole.” App. B at B-28; *see* App. D. at D-55.

Summer Typical Median Flow Model Results.

Projected Isotherm Extents. The demonstration includes the thermal plume surface area as a function of temperature:

Scenario 2	Isotherm Temperature		Near-Surface Layer Plume Area in Entire Model Domain
	(°F)	(°C)	(acres)
"Typical" Summer/Median Flow	>90	>32.2	25
	>93	>33.9	7
	>94	>34.4	5
	>95	>35.0	2
	>96	>35.6	0
	>97	>36.1	0
	>98	>36.7	0

App. D at D-62, citing *id.*, Figure D-14 (model results); App. B at B-29; *see* App. D at D-68. The demonstration argues that this area was "substantially smaller" than the "summer worst-case" scenario. App. B at B-29.

The demonstration argues that modeled conditions indicate that both Stations could "meet 90 °F – 93 °F at the edge of their respective 26-acre mixing zone extents." App. D at D-62; *see* App. B at B-29, citing App. D, Table D-14a – D-14p (cross-sectional temperatures).

Zone of Passage. The demonstration includes cross-sectional temperature distributions at nine transects:

Transect (ft)	Transect Description	Mean Temperature (°F)	ZOP of <=90°F	ZOP of <=93°F	ZOP of <=94°F	ZOP of <=95°F	ZOP of <=96°F
-3350	Upstream	82.0	100%	100%	100%	100%	100%
-1720	J9 discharge into river	84.3	89%	89%	89%	100%	100%
-250	Upstream of J29 discharge	86.3	89%	100%	100%	100%	100%
250	J29 discharge into river/theoretical J9 MZ edge	88.4	59%	100%	100%	100%	100%
2000	Theoretical J29 MZ edge	88.2	98%	100%	100%	100%	100%
7000	Downstream of both J9/J29 discharges	88.5	100%	100%	100%	100%	100%
15000	~Halfway down to I-55	87.9	100%	100%	100%	100%	100%
26700	Jackson Creek/downstream dischargers	86.9	100%	100%	100%	100%	100%
33350	I-55 Bridge/end of model domain	87.3	100%	100%	100%	100%	100%

App. D at D-63; *see* App. D, Figures D-14a, D-14b, D-16b, Tables D-14a – D-14p; Exh. B, Table B-7b. Outside of the immediate areas of the discharges, there were no areas "where the entire water column was at an elevated temperature." App. D at D-66.

Summary. The demonstration argues that these modeled results "indicate that under typical/average summer weather and with consistently favorable river flow conditions, the Joliet Stations would be able to meet the existing UDIP near-field summer numeric thermal limits at the edge of their respective 26-acre allowed mixing zones." App. D at D-63; *see id.* at D-66; App. B at B-29.

However, the demonstration notes that, because anthropogenic factors influence the UDIP, "it is unclear whether the '5 °F above natural temperature' requirement would apply to

this waterway, or how it would be assessed if it did.” App. D at D-63; *see* Exh. A at 3-6. The demonstration acknowledges that, between the transect farthest upstream and the edge of each Station’s mixing zone, water temperatures “would rise more than 5 °F even under favorable conditions.” App. D at D-63; *see* App. D at D-66.

The demonstration argues that this narrative standard had not applied to the UDIP before 2018. Exh. A at 3-9, citing 35 Ill. Adm. Code 302.408(e). It further argues that this standard is not necessary to maintain the BIC in the UDIP “as long as the seasonal numeric standards remain protective of the resident aquatic community.” Exh. A at 3-9.

Summer Typical Low Flow Model Results.

Projected Isotherm Extents. The demonstration includes the thermal plume surface area as a function of temperature:

Scenario 3	Isotherm Temperature		Near-Surface Layer Plume Area in Entire Model Domain
	(°F)	(°C)	(acres)
“Typical” Summer with Low Flow	>90	>32.2	106
	>93	>33.9	13
	>94	>34.4	8
	>95	>35.0	4
	>96	>35.6	0
	>97	>36.1	0
	>98	>36.7	0

App. D at D-65; *see id.* at D-68. The demonstration argues that this scenario reflects the influence of lower flow conditions, which “resulted in some upstream plume intrusion.” App. D at D-65, citing *id.*, Figures D-15a, D-15b. Also, with a river flow 20% lower, “the plume areas greater than 90 °F increased by more than 400% over the corresponding typical flow case.” *Id.* at D-65; App. B at B-31. Plume temperatures also persisted longer than in the median flow scenario. App. D at D-65.

Zone of Passage. The demonstration includes cross-sectional temperature distributions at nine transects:

Percent cross-sectional area at or below given limit
(at the model-identified maximum temperature time-step*)

Transect (ft)	Transect Description	Mean Transect Temperature (°F)	ZOP of	ZOP of	ZOP of	ZOP of	ZOP of
			<90°F	<93°F	<94°F	<95°F	<96°F
-3350	Upstream	82	100%	100%	100%	100%	100%
-1720	J9 discharge into river	83.6	89%	92%	93%	100%	100%
-250	Upstream of J29 discharge	85.1	97%	100%	100%	100%	100%
250	J29 discharge into river/theoretical J9 MZ edge	89.6	40%	100%	100%	100%	100%
2000	Theoretical J29 MZ edge	89.4	66%	100%	100%	100%	100%
7000	Downstream of both J9/J29 discharges	89.6	72%	100%	100%	100%	100%
15000	~Halfway down to I-55	89	100%	100%	100%	100%	100%
26700	Jackson Creek/downstream dischargers	88.7	100%	100%	100%	100%	100%
33350	I-55 Bridge/end of model domain	89	100%	100%	100%	100%	100%

(The above represents specific transects of interest and is a sub-set of the 16 transects for which model data was generated—all cross-section data is provided in Appendix D, Tables D-16a through D-16p).

App. D at D-66, citing *id.*, Table D-16a – D-16p, Figure D-16c; App. B, Table B-7c. Outside of the immediate areas of the discharges, there were no areas “where the entire water column was at an elevated temperature.” App. D at D-66.

Summary. While the limited flow in this scenario did not result in exceeding the UDIP near-field numeric limit, it illustrates “how lower flows under adverse weather conditions” could affect the Stations’ compliance. App. D at D-65; *see* App. B at B-30 - B-31. The demonstration argues that low-flow conditions occur regularly in the UDIP “as the result of upstream flood control and hydropower generation activities, as well as navigational depth manipulations.” App. D at D-67; App. B at B-31. Although expected, these fluctuations do not follow a seasonal pattern and are beyond the Stations’ control. The demonstration suggests that these factors illustrate the situations requiring the proposed ATELS. App. D at D-67; *see* App. B at B-31.

Winter Worst-Case Model Results.

Projected Isotherm Extents. The model calculated the area of the near-surface thermal isotherm for different temperatures:

Winter Scenario 1	Isotherm Temperature		Near-Surface Layer Isotherm Area
	(°F)	(°C)	(acres)
“Worst-Case” Winter	60	15.6	620
	63	17.2	419
	65	18.3	260
	68	20.0	14
	70	21.1	0
	75	23.9	0

App. B at B-32; App. D at D-73. The demonstration argues that these modeled conditions would result in temperatures higher than those that became effective on July 1, 2018. App. D at D-73; App. B at B-32. However, it also argues that cross-sectional temperature distributions show that, even under these circumstances, there are no areas within the Stations’ thermal influence that would be considered adverse to the BIC of the UDIP. *Id.*, citing App. D, Figures D-17a, D-17b;

Tables D-18a – D-18p; App. B at B-32 – B-33. It stresses that this area is acclimated to warmer water temperatures as a result of upstream flow from POTWs. App. D at D-73; App. B at B-33. It adds that these extreme conditions are likely to develop over a period of days, which would allow for additional acclimation. *Id.*

Zone of Passage. For this scenario, the demonstration included a percent cross-sectional area as a function of temperature at nine transects. App. D at D-75, citing *id.* at Figures D-17a, D-17b; App. B at B-33, citing *id.*, Table B-8a. It argues that the 70 °F near-field limit applied at the edge of the mixing zone provides a ZOP of greater than 75 while maintaining the current far-field limit of 65 °F. App. D at D-75, citing *id.*, Tables D-18a – D-18p, Figure D-20a.

The demonstration argues that, because these worst-case conditions are more likely in the transitional months of December and March, MG proposed a slightly lower limit for January and February. App. D at D-75 – D-76.

Downstream Dischargers. Under the worst-case scenario, model results suggest that two of the three downstream dischargers may not be able to consistently comply with the UDIP winter thermal limit. App. D. at D-86, citing *id.*, Figures D-17a, D-17b, Tables D-18n, D-18o. MG recommended that “IEPA consider whether these downstream discharges may be afforded coverage” under the proposed ATEs, if granted, under specified adverse conditions. *Id.*, citing *id.*, Exhs. D-2a, D-2b.

Summary. Results show that the Stations’ “surface thermal plumes disperse quickly under lower air temperatures, with somewhat more subsurface mixing and diffusion than found during the summer.” Exh. A at 3-8; *see* App. D at D-72. Chronic or sporadic low flow conditions may result in larger plume areas and slower heat dissipation. Exh. A at 3-8.

This winter scenario “resulted in the highest discharge temperatures and largest downstream thermal influence.” App. B at B-35; App. D at D-82, D-85. “The lower the flow, the greater the overall plume dimensions and magnitude of thermal influence downstream.” App. B at B-35. The demonstration argues that data and modeling show neither Station “could consistently meet the winter numeric UDIP thermal limit of 60 °F under all expected combinations of weather, river flow, and/or station operating conditions during the winter,” even with allowed excursion hours. *Id.* at B-36; *see* Pet. at 28; Exh. A at 2-5, 3-8; App. B at B-32; App. D at D-83, D-85. However, ambient water temperatures did not exceed 53.4 °F and the Stations’ discharge temperatures did not exceed 69.1 °F. App. B at B-20, citing App. D, Tables D-19, D-21. Under these conditions, the demonstration argues that no temperatures within the thermal range of Joliet 29 would be considered adverse to the BIC. App. B at B-32 – B-33; *see* Exh. A at 4-4. The demonstration argues that upstream flow from POTWs would acclimate the BIC to warmer water temperatures. It further argues that worst-case conditions are likely to develop over a period of days, a period that would allow for additional acclimation. App. B at B-33.

Winter Typical Median Flow Model Results.

Projected Isotherm Areal Extents. The model calculated the area of the near-surface thermal isotherm for different temperatures:

Winter Scenario 2	Isotherm Temperature		Surface Layer Plume Area
	(°F)	(°C)	(acres)
“Typical” Winter with Median Flow	60	15.6	10
	63	17.2	2
	68	6.2	0
	70	21.1	0
	75	23.9	0

App. B at B-33 – B-34, citing App. D, Figures D-18a, D-18b; App. D at D-77.

Zone of Passage. For this scenario, the demonstration included a percent cross-sectional area as a function of temperature at nine transects. App. D at D-78, citing App. D, Figures D-18a, D-18b, D-20b, Tables D-20a – D-20p; see App. B, Table B-8b.

Summary. Based on these results, the demonstration argues that the Stations “could potentially be able to comply with a near-field UDIP 60 °F numeric limit” under typical conditions at the edge of their respective mixing zones. App. D at D-78; see App. B at B-35; Pet. at 28. However, under more adverse or fluctuating conditions, it argues that neither could consistently meet this limit without load reductions. App. D at D-78. MG proposed winter near-field thermal ATELS to allow the Stations to comply under these conditions. App. B at B-35.

Winter Typical Low Flow Model Results.

Projected Isotherm Areal Extents. The model calculated the area of the near-surface thermal isotherm for different temperatures:

Winter Scenario 3	Isotherm Temperature		Surface Layer Plume Area
	(°F)	(°C)	(acres)
“Typical” Winter with 25th Percentile Low Flow	60	15.6	45
	63	17.2	4
	68	6.2	0
	70	21.1	0
	75	23.9	0

App. D at D-79 - D-80, citing App. D, Figures D-19a, D-19b, Tables D-22a – D-22p; App. B at B-34 – B-35. The demonstration states that, “[u]nder lower flow conditions, the plume temperature diffuses across and along the river more slowly, resulting in higher overall temperatures throughout the water column.” App. D at D-79. Also, reduced dilution resulted in a more compact plume that extended further downstream.” *Id.*

Zone of Passage. For this scenario, the demonstration included a percent cross-sectional area as a function of temperature at nine transects. App. D at D-81 – D-82, citing *id.*, Figures D-19a, D-19b, D-20c; *see* App. B at B-35, citing *id.*, Table B-8c, App. D, Tables D-22a – D-22p.

Summary. Based on these results, the demonstration argues that the Stations “would theoretically be able to comply with the numeric UDIP limits most of the time.” App. D at D-81; *see* App. B at B-35; Pet. at 28. However, under more adverse or fluctuating conditions, adverse compliance conditions can and do occur. App. D at D-81; *see* App. B at B-36. MG proposed winter near-field thermal ATEs to allow the Stations to comply under these conditions. App. B at B-35.

Transitional Months. In the months of April, May, October, and November, both water and air temperatures are in transition between summer and winter extremes. App. D at D-86; *see* Exh. A at 4-5; App. B at B-47. Historical data for these transitional months show “the same type of inter-annual variation that is seen for the remainder of the year.” Exh. A at 4-5.

Instead of modeling scenarios for transitional months, the demonstration applied a “stair-step” approach. It argues that this reflects “the natural variability observed during the spring and fall, and is more realistic than either the former Secondary Contact thermal limits, or the UDIP numeric limits for these months.” *Id.* It stresses that the proposed ATEs for transitional months “are also more stringent than the corresponding UDIP numeric limitations.” App. B at B-47; *see* Exh. A at 4-5. The demonstration argues that this approach will protect the BIC “and will effectively supersede, yet still fulfill the intent of the ‘5 °F above natural temperature’ and related narrative criteria in the UDIP limits. App. B at B-47; *see* Exh. A at 4-5.

Decision Criteria

Potential for Thermal Mortality. The demonstration reported that the following acute, chronic, and avoidance thermal endpoints for available for the RIS:

Species	Acute	Chronic	Avoidance
Gizzard Shad	34.2°C 93.6°F	34.6°C 94.3°F	32.1°C 89.8°F
Common Carp	36.7°C 98.2°F	36.8°C 98.1°F	34.5°C 94.1°F
Bluntnose Minnow	37.5°C 99.5°F	33.8°C 92.8°F	>31.1°C >89.9°F
Golden Redhorse	33.4°C 92.1°F	- -	28.5°C 83.3°F
White Sucker	36.2°C 97.2°F	31.6°C 88.9°F	31.8°C 89.4°F
Channel Catfish	38.6°C 101.5°F	36.4°C 97.5°F	33.6°C 92.5°F
Banded Killifish**	39.7°C 103.5°F	--	--
Bluegill	32.0°C 89.6°F	33.6°C 92.5°F	32.0°C 89.6°F
Largemouth bass	38.9°C 102.0°F	34.7°C 94.5°F	33.3°C 91.8°F
Freshwater Drum	34.0°C 93.2°F	32.8°C 91.0°F	30°C 86.0°F
Thermal endpoints assume an acclimation temperature of 25.6°C (78.0°F) **Based on surrogate data (see Table B-5).			

App. B at B-37, citing *id.*, Figures B-2 – B-10.

At ambient/acclimation temperatures above 31.1 °C (88 °F), the demonstration does not predict acute mortality for the RIS “until temperatures in the thermal discharges exceed about 35 °C (95 °F).” App. B at B-37. Worse-case modeled temperatures averaged 34.3 - 34.4 °C (93.7-93.9 °F) at the 250 foot transect, the theoretical edge of Joliet 9 mixing zone, and at the 2,000 foot transect, the theoretical edge of the Joliet 29 mixing zone. *Id.*, citing *id.*, Tables D-12f, D-12i. Based on these data, the demonstration predicts no acute or chronic mortality for any of the RIS. *Id.* at B-37. Even at these two transects, there is a ZOP in the lower water column of 93 °F or less. Based on avoidance temperatures, the RIS can be expected to avoid near-field acute or chronic water temperatures. *Id.* at B-37 – B-38, B-49; see Exh. A at 4-4.

Because flow conditions in the LDPR constantly change, the demonstration argues that “these temperatures and worst-case ZOP gradients would not be expected to persist for long periods of time.” App. B at B-38. It cites long-term fisheries investigations that the Stations’ thermal discharges “have not had a significant effect on the fish community, even under the extreme weather conditions experience in the summer of 2012.” *Id.*, citing App. C.

The demonstration argues that the assumption that ambient temperatures represent acclimation temperatures is conservative and could predict higher potential for thermal mortality. It argues that fish may become acclimated to temperatures higher than the upstream ambient if they reside in the discharge where temperatures are above ambient but lower than avoidance. App. B at B-38. The demonstration stresses that aquatic organisms near the Stations are not exposed to constant elevated temperatures. *Id.* It adds that various thermal mortality test protocols expose the organisms in a regulated test chamber and not in natural habitats where

ranges of temperatures are often available and organisms may be able to avoid stressful temperatures. *Id.*

Thermal Avoidance and Habitat Loss. The demonstration reported avoidance temperature test data for RIS with known avoidance temperatures:

Acclimation Temperature (°F)	Avoidance Temperature (°F)						
	80	86	87	88	91.4	93.2	95
Gizzard Shad	91	93	94	94	95	96	97
Channel Catfish	95	96	96	96	98	99	99
Bluegill	91	94	95	95	97	98	99
Largemouth Bass	93	96	96	96	98	99	100

App. B at B-39; *id.*, Table B-6. It argues that, under the worst-case summer scenarios, these RIS would not consistently avoid the thermal plume areas at the edge of the Station’s mixing zones. App. B at B-39. Even under this scenario, there is substantial habitat upstream and downstream from the Stations “with cooler water temperatures for fish that may prefer to avoid portions of the elevated thermal discharge temperatures.” *Id.*

Although this avoidance reduces the risk of fish mortality, “it could result in avoidance of habitat areas that may be affected by portions of the thermal plume.” App. B at B-39. The demonstration argues that the Stations’ discharges chiefly affect the main channel and main channel border habitats “that account for nearly 80% of the habitat between the Brandon Road tailwaters downstream to the I-55 Bridge.” *Id.* It further argues that the discharges do not typically influence tailwater habitat or backwater habitat upstream and downstream from the discharges. *Id.*

The RIS for which avoidance data are available would not consistently avoid the Station’s thermal plumes under the summer worst-case scenario. App. B at B-39, B-50, citing App. D, Tables D-12f, D-12i. For those RIS, “the temperatures avoided are typically higher than the highest plume cross-section temperature for the two typical summer scenarios.” App. B at B-39, citing App. D, Tables D-14f, D-14i, D-16f, D-16i. These temperatures typically fall several degrees below chronic mortality temperatures. *Id.* at B-39, B-50.

The demonstration argues that species for which avoidance data were not available generally have acute or chronic thermal endpoints similar to the RIS for which the data are available. *Id.* Consequently, it concludes that none of the RIS would be expected to avoid large areas of habitat near the Stations. *Id.*

Potential Effects on Spawning and Early Development. The demonstration reported the upper spawning temperatures for the RIS:

RIS	Mean Spawning Temperature
Gizzard Shad	22.8°C/72.9°F
Common Carp	27.0°C/80.6°C
Bluntnose Minnow	26.0°C/78.4°F
Golden Redhorse	22.2°C/72.0°F
White Sucker	17.6°C/63.6°F
Channel Catfish	29.0°C/84.2°F
Banded Killifish	25.7°C/78.3°F
Bluegill	29.3°C/84.7°F
Largemouth Bass	22.5°C/72.5°F
Freshwater Drum	23.6°C/74.5°F

Exh. B at B-41. Upstream of the Stations, ambient intake temperatures averaged 73.7 °F to 79.0 °F from June through August from 2012 to 2017. *Id.*, citing *id.*, Tables D-1a, D1-b.

While the upper range of spawning temperatures for Largemouth Bass is 72.5 °F, ambient water temperatures upstream of the Stations exceeded 79.0 °F under the three summer scenarios. App. B at B-41, citing App. D, Tables D-11, D-13, D-15. “However, Largemouth Bass spawn in shallow weed-free habitat,” which tends to warm faster. The demonstration concludes that Largemouth Bass spawning ends before temperatures reach these levels. App. B at B-42.

Of the RIS, both Channel Catfish and Bluegill may continue spawning into July or August in parts of their ranges. App. B at B-42, B-50. Under the two typical summer scenarios, ambient temperatures upstream of the Stations are not expected to exceed their upper range of spawning temperatures. *Id.* at B-42, citing App. D at D-11, D-13, D-15. Under the summer worst-case scenario, temperatures above 84 °F would exist at all transects downstream from the Stations. The demonstration argues that there will be cooler water temperatures at off-peak hours. App. B at B-42, citing App. D, Figure D-16b, D-16c. While Channel Catfish and Bluegill spawning could not continue in July in areas within the immediate areas of the Stations’ discharge plumes, it could continue into July upstream of the Stations and downstream during lower temperatures. App. B at B-42; B-50; *see* Exh. A at 5-3. Also, the demonstration adds that the worst-case scenario could occur in August after spawning has ended. App. B at B-42.

For ichthyoplankton occurring into late June and July “mortality is not predicted based on available thermal tolerance data.” App. B at B-42.

Finally, the demonstration argues that fisheries monitoring data since 1994 show consistent recruitment of fish, showing that they are spawning as expected. App. B at B-41.

Potential Effects on Performance and Growth. The demonstration includes available upper zero growth temperatures for RIS:

RIS	Upper Zero-Growth		Optimum Growth		Lower Zero-Growth	
	°C	°F	°C	°F	°C	°F
Gizzard shad	34	93.2	29-32	84.2-89.6	--	--
Common carp	35	95	14.5-32	58.1-89.6	10-13.8	50.0-56.8
Bluntnose Minnow	34	93.2	7-31	44.6-87.8	--	--
Golden Redhorse	29.6	85.3	--	--	--	--
White Sucker	29	84.2	19-26	66-79	--	--
Channel catfish	34.7	94.5	20-32	68.0-89.6	10	50
Banded Killifish	--	--	--	--	--	--
Bluegill	34.0	93.2	13-28	56-82	20	68
Largemouth bass	36	96.8	23-31	73.4-87.8	10	50
Freshwater Drum	33	91.4	14.4-22	57.9-71.6	--	--

App. B, Table B-9. Because this temperature exceeds 93 °F for a number of the RIS, it is not likely that temperatures in the Stations’ thermal plumes “would adversely affect growth or cause a cessation of growth for these RIS under average conditions.” App. B at B-43, citing App. D at Tables D-1a, D-1b. Under the worst-case summer scenario, near surface temperatures exceed 93 °F in and downstream from the Stations’ immediate discharge zones. Under the typical summer scenarios, these temperatures would occur “only occasionally in the immediate discharge zones.” App. B at B-43, citing App. D, Tables D-12a-p, D-14a-p, D-16a-p.

The demonstration concludes that temperatures in the Stations’ thermal plumes “are not expected to adversely affect normal patterns of growth as long as high temperature periods are of limited duration.” App. B at B-43; *see id.* at B-50 – B-51.

Potential to Block Migration. The demonstration argues that, because the RIS are not likely to avoid significant areas of habitat, it is not likely that the Stations’ thermal plumes would interfere with their migration or localize movement patterns. App. B at B-40; *see Exh. A at 5-2.* Under the summer worst-case scenario, the demonstration argued that modeled water temperatures at various transects would allow passage through ZOPs. App. B at B-40, citing App. B, Table B-7a; *see Exh. A at 5-2.* During the two summer typical scenarios, it argued that “[t]emperatures at transects downstream of the 250 ft transect will not limit upstream/downstream movements.” App. B at B-40; *see Exh. A at 5-2.*

Under the winter worst-case scenario, water temperatures in “85% to 100% of the water column from the 250 ft transect downstream were greater than 60 °F.” App. B at B-40, citing *id.*, Table B-8a. The demonstration argues that the proposed winter ATELS do not approach avoidance temperatures and trigger the need for a ZOP. App. B at B-40. While these water temperatures may attract fish, they are not expected to persist long enough for fish to become acclimated. *Id.*

Potential for Reduced Survival from Thermal Shock.

Cold Shock. Cold shock can occur when “plants shut down when fish are acclimated to warmer discharge temperatures.” App. B at B-44. The demonstration cites four factors for evaluating the potential for cold shock:

- 1) the length of time fish have resided at the elevated temperatures in the plume;
- 2) the difference between discharge and ambient temperatures;
- 3) the rate of temperature decrease; and
- 4) the absolute magnitude of the lower temperature. *Id.*; *see* Exh. A at 5-5.

“[A]t final temperatures exceeding 45 °F, cold shock typically does not occur, regardless of the magnitude of the change.” App. B at B-44; *see* Exh. A at 5-5; Pet. at 29. From 2012 to 2017, mean winter ambient temperatures at the Stations generally fell between 40.6 °F and 48.1 °F with maximums from 52.2 °F to 72 °F. App. B at B-44; Pet. at 29. The demonstration argues that cold shock “is not expected to be a concern with the current and expected future cycling of the two Joliet Stations, as they will not be running consistently enough to allow for acclimation to warmer water temperatures than those coming downstream from POTW flow contributions.” App. B at B-44; *see* Exh. A at 5-5. The demonstration also stresses that the Stations did not experience cold shock incidents during their past operation in a more base-loaded manner. Exh. A at 5-5; *see* Pet. at 30.

Plume Entrainment. When water currents transport and distribute the early life stages of fish and invertebrates, they are “at greater risk of plume entrainment and exposure to rapid temperature increases.” Exh. A at 5-5. The early life stages of these species generally move through the Stations’ thermal plumes when summer near-field ATELS would apply.

Based on available thermal tolerance data, mortality is not predicted for ichthyoplankton with life stages occurring before July. Exh. A at 5-6. Eggs and larvae of the RIS Common Carp and Channel Catfish tolerate chronic and acute exposure to temperatures higher than those predicted in the Stations’ plumes even in the worst-case scenario. *Id.*, citing App. B.

Conclusion on Decision Criteria. The demonstration argues that, under proposed near-field thermal ATELS, the predictive assessment does not indicate that the Stations’ thermal plumes are likely “to have more than minimal and transitory effects on incidental components of the aquatic community even under rare and extreme meteorological conditions.” App. B at B-51; *see* Exh. A at 4-15 – 4-16.

The demonstration further argues that the proposed near-field thermal ATELS for winter and transitional months “are also not expected to have any adverse effect upon the BIC of the UDIP/Five-Mile Stretch.” App. B at B-51. It stresses that the BIC “is already acclimated to higher winter temperatures due to the predominance of POTW effluents during these times of year.” *Id.*

The demonstration also emphasizes that the predictive assessment shows “no temperatures exceeding 93 °F would be expected to occur at or downstream of the I-55 Bridge.” App. B at B-51. MG argues that this supports its position that its proposed far-field ATELS based on current standards “are fully supporting of the BOC.” *Id.*; *see* Exh. A at 4-16.

Conclusions on Protecting BIC

The demonstration argues that satisfying the criteria summarized in the following subsections satisfies the standard of protecting the BIC. Exh. A at 4-11; *see* App. C at C-43. It argues that MG’s retrospective and prospective evaluations show that the criteria will be met if the Board adopts its proposed ATELS. App. C at C-43; *see* Pet. at 26; Exh. A at 4-11.

No Substantial Increases in Abundance or Distribution of Any Nuisance Species and Pollution-Tolerant Organisms. The demonstration argues that the retrospective analysis shows “no appreciable changes in the physical and biological components of the system” while the Stations were subject to the Secondary Contact thermal standards. App. C at C-43; *see* Pet. at 26, 30. It argues that the LDPR’s channelized nature and regulated flow “influence the aquatic species assemblage which is able to successfully carry out their life histories in the waterway.” App. C at C-43. It indicates that the presence of invasive species “must also be taken into consideration as a permanent part of the LDPR environment.” *Id.* at C-43 – C-44; *see* Exh. A at 4-6 – 4-7. However, the demonstration argues that the Stations’ operations “have not been responsible” for the introduction or spread of nuisance species in the LDPR. Exh. A at 4-7.

The demonstration argues that, “[t]o date, no substantial changes in abundance of nuisance species have been observed in the LDPR” near the Stations. App. C at C-43; *see* Exh. A at 4-12. While it notes that the Stations will discharge less heat overall under the proposed ATELS, the demonstration argues that this change “will not benefit or in any way affect the abundance or distribution of nuisance species.” Exh. A at 4-12. The demonstration concludes that the proposed ATELS, which are more stringent than previous Secondary Contact limits, “are not expected to cause changes in abundance or distribution of other indigenous or nuisance species.” App. C at C-44; *see* Exh. A at 4-7; Pet. at 26.

No Substantial Decreases of Formerly Abundant Indigenous Species Other Than Nuisance Species. The demonstration argues that the retrospective analysis indicates that the Stations “are not a significant contributing factor influencing the current or future fish assemblage in the UDIP or the Five-Mile Stretch.” App. C at C-44; *see* Pet. at 26. The demonstration acknowledges the presence of ANS but argues that “there is no connection” between their presence and the Stations’ operations. App. C at C-44. Fish monitoring from 1994 to 2016 shows no significant shift in the fish community over time. *Id.*, citing Apps. G, H; *see* Exh. A at 4-12. The demonstration argues that this supports a conclusion that the lower trophic levels on which fish depend have also been unaffected. App. C at C-44; *see* Exh. A at 4-12. It also notes the conclusion of the prospective analysis that indigenous fish species will not suffer appreciable harm from the proposed ATELS, which are “more stringent than the former Secondary Contact thermal standards.” App. C at C-44, citing App. B; *see* Exh. A at 4-12.

No Unaesthetic Appearance, Odor or Taste. The demonstration argues that “[t]here is no evidence of an unnatural odor or an unaesthetic appearance” attributable to the Stations’ operations. App. C at C-44; *see* Exh. A at 4-12. It further argues that the proposed ATELS are “not expected to cause any such impacts.” *Id.*

No Elimination of Established or Potential Economic or Recreational Use of the Waters. The demonstration argues that the Stations’ operations have neither eliminated nor minimized any economic or recreational uses of the LDPR. App. C at C-45; *see* Exh. A at 4-13; Pet. at 26. It cites a number of factors supporting this conclusion: the absence of commercial or recreational fishing, fish consumption advisories, frequent barge traffic limiting boating, frequent CSO events, and designation of the waterway only for incidental contact recreation that is unsuitable for swimming and similar uses. App. C at C-45, citing 35 Ill. Adm. Code 303.225. The demonstration also argues that the prospective analysis “indicates the small increment in additional heat above the UDIP limits that may be released if the proposed AELs are authorized will not affect these conditions.” App. C at C-45; *see* Exh. A at 4-13. It adds that operation under AS 96-10 standards has not had an adverse effect on recreational uses at or downstream from the I-55 Bridge. Exh. A at 4-13. While it acknowledges that that segment is subject to a fish consumption advisory due to fecal coliform, the demonstration argues that this is not attributable to the Stations’ operations. *Id.*

No Reductions in Successful Completion of Life Cycles of Indigenous Species. The demonstration cites the retrospective analysis as indication “that thermal effects have not compromised the overall success of indigenous species in completing their life cycles.” App. C at C-45; *see* Exh. A at 4-13; Pet. at 26. When combined with the prospective analysis, it argues that “the small increment of heat” allowed under the proposed ATELs would result in no change in condition. The demonstration stresses that the proposed ATELs are more stringent than previous limits that resulted in no appreciable harm. App. C at C-45; *see* Exh. A at 4-13.

No Substantial Reduction of Community Heterogeneity or Trophic Structure. The demonstration argues that the results of long-term monitoring “indicate that the number of species collected has remained reasonably consistent across years.” App. C at C-45; *see* Exh. A at 4-14; Pet. at 26. It attributes long-range changes to evolving practices at upstream POTWs unrelated to the Stations’ operations. App. C at C-45; *see* Exh. A at 4-14. The demonstration argues that the proposed ATELs are not significantly different from otherwise applicable standards and are not expected to contribute to these changes. App. C at C-45.

No Adverse Impacts on Threatened or Endangered Species. Although the retrospective analysis did not find federally-listed threatened or endangered species, it identified four state-listed fish species. App. C at C-45; Exh. A at 4-8, 4-14; *see* App. C, Table C-7. Surveys collected the threatened River Redhorse “infrequently and in low numbers downstream of the Brandon Road Lock and Dam.” Exh. A at 4-8; *see* App. B at B-9; App. C at C-27. Surveys collected one endangered Greater Redhorse in 2010 at a far-field sampling location. Exh. A at 4-8 – 4-9; *see* App. C at C-27. The demonstration argues that the Stations’ operations have a low potential impact on these incidental species because their preferred habitat is downstream in the Kankakee River beyond the Stations’ thermal influence. Exh. A at 4-14. The demonstration adds that these species were found when the former Secondary Contact thermal standards were in place, indicating that the Stations’ discharges had not negatively affected them or their habitat. *Id.* at 4-9, 4-15; *see* App. C at C-45; Pet. at 26.

The endangered Pallid Shiner was first collected downstream of the I-55 Bridge in 2001 and has since been collected chiefly in the Five-Mile Stretch. Exh. A at 4-9; *see* Exh. A at 4-14;

App. B at B-9; App. C at C-27. The demonstration adds that this species was found when the former Secondary Contact thermal standards were in place, indicating that the Stations' discharges had not negatively affected it or its habitat. Exh. A at 4-9, 4-15; *see* App. C at C-45; Pet. at 26.

Surveys first collected the threatened Banded Killifish in 2012, and it has "increased dramatically over time" with less stringent thermal standards in place. Exh. A at 4-9; *see* Exh. A at 4-14; *see* App. B at B-9; App. C at C-45; Pet. at 26. The demonstration cites the INHS to argue that this increase "represents an expansion of the Lake Michigan population through the CAWS into the Des Plaines River." Exh. A at 4-9. It also argues that the Banded Killifish found in the LDPR are an invasive subspecies, the Eastern Banded Killifish, and not the threatened Western Banded Killifish. *Id.* Because the Western Banded Killifish populations and distributions "had remained unchanged from 1880 to 2000," the demonstration argues that its recent growth is "unusual." *Id.* (citation omitted). The demonstration reports that IDNR is expanding its research on the Banded Killifish to determine whether it should be listed as threatened. *Id.*; *see* App. C. at C-28.

The Board asked MG to comment on whether its rationale would change if the Western Banded Killifish is in fact the Eastern Banded Killifish. Board Questions at 2. MG responded that it would not change because adverse impacts on the BIC, including either subspecies, are not expected to occur as the result of the Stations' discharges. MG Resps. at 6. It adds that "[w]ater temperature has not been found to either attract nor cause long-term avoidance for both native and invasive species in the LDPR or the Upper Illinois Waterway as a whole." *Id.*

The Board also asked whether IDNR has provided additional information on distinguishing the two species from one another. Board Questions at 2. MG reported that IDNR recently updated Illinois' Threatened and Endangered Species list, which recognizes only the Western Banded Killifish as threatened. MG Resps. at 6, citing Att. 2. MG states that, "[w]hile there is still ongoing research being conducted on the geographic range of the Western subspecies, data collected by natural resource agencies and other researchers in the Upper Illinois Waterway suggest that it is the non-listed Eastern subspecies (*Fundulus diaphanus diaphanus*) that prevails in the LDPR." MG Resps. at 6 (citation omitted).

The Board also asked MG whether it would be opposed to additional surveillance of state-listed Banded Killifish numbers in the study area if the Board grants ATEs. Board Questions at 2. MG responded that it continues its annual fisheries monitoring program, including monitoring for the Banded Killifish population, under Special Conditions 17 and 18 of the Stations' NPDES Permits. MG Resps at 7. MG argues that "it is not necessary to condition a grant of an alternative standard on additional surveillance of their numbers because this is something that the IEPA already requires." *Id.* In addition, MG notes that there is also continued fisheries monitoring work in this waterway by IDNR and other agencies involved with the Asian Carp Regional Coordinating Committee (ACRCC) monitoring programs, that would provide similar information. *Id.*

Based on these factors, the demonstration argues that the Stations' discharges are unlikely to have had and are not expected to have adverse effects on any threatened or endangered species. Exh. A at 4-10, 4-15; *see* Pet. at 26.

No Destruction of Unique or Rare Habitat. The demonstration reports that factors such as flow modification, impoundment, and channelization have altered flow conditions and limited the types of habitat available in the LDPR. Exh. A at 4-10. It argues that these factors have not resulted from the Stations' discharges. *Id.* QHEI scores have generally characterized habitats near the Stations as "fair" or "poor." *Id.* at 4-10, 4-15. The demonstration concludes that "[t]here are no unique or rare habitat components that would be affected by the Joliet Station thermal discharges, either in the UDIP or Five-Mile Stretch." *Id.* at 4-15; *see id.* at 4-10; App. C at C-45; Pet. at 26.

Biocides. The demonstration reports that Joliet 9 relies on dehumidification and "does not use biocides, or other chemical processes, to minimize biofouling of its condenser cooling system." Exh. A at 4-10. Although Joliet 29 is permitted to use the biocide sodium hypochlorite, it uses dechlorination so that its final effluent complies with its NPDES permit. *Id.* at 4-10 – 4-11. It has also relied more recently on dehumidification. *Id.* at 4-11. The demonstration concludes that neither Station "poses a threat of appreciable harm to the BIC as a result of biocide use." *Id.*

No Interactions with Other Pollutants, Discharges, or Other Activities. The demonstration argues that the Stations' thermal discharges have not had a detrimental effect on the recreational or commercial uses of the UDIP or Five-Mile Stretch. Exh. A at 4-15; *see* App. C at C-46. It adds that cumulative effects from upstream or downstream thermal discharges "have not occurred." Exh. A at 4-15. If the Board adopts the proposed ATELS, "[n]o harmful interactions with other pollutants, such as organic carbon, phosphorus, and nitrogen, have occurred, or are expected to occur." *Id.*; *see* App. C at C-46; Pet. at 26. The demonstration adds that these interactions have not occurred under the far-field standards in AS 96-10. Exh. A at 4-15.

Cold Shock. The demonstration argues that the risk of cold shock depends on the acclimation temperature and rarely occurs at ambient temperatures above 45 °F. App. B at B-44; *see* Pet. at 29-30. It argues that mean winter ambient temperatures near the Stations are normally between 40.6 °F and 48.1 °F because much of the flow in the UDIP is treated wastewater discharged upstream. App. B at B-44. It also argues that water temperatures do not immediately decrease when the Stations stop generating. *Id.* It stresses that the Stations have not caused cold shock in the UDIP and Five-Mile Stretch. Pet. at 30. Based on these factors, the demonstration concludes that "cold shock is not expected to be an issue or concern for the Joliet Stations." App. B at B-44; *see* Exh. A at 4-5.

Developing Values for Proposed Alternative Limitations

MG requests near-field thermal ATELS for specified thermal standards that the Board adopted in 2015 and became effective July 1, 2018: Sections 302.408(c), (d), (e), (f), and (i). Exh. A at 3-4. MG's request includes applicable ZOP provisions. *Id.*

As far-field thermal ATELS, MG requests that the Board adopt current adjusted standards enacted through AS 96-10. Exh. A at 3-4. These would then apply in place of General Use water quality standards effective at that point and continuing downstream. *Id.*, citing 35 Ill. Adm. Code 302.211(b) – (e).

Temperature Limitations. The demonstration argues that 93 °F is the appropriate summer near-field ATEL for the Stations. Exh. A at 3-7. It argues that long-term data show that the previous Secondary Contact standard of 93 °F has not had a detrimental effect on the BIC of the UDIP/Five-Mile Stretch. *Id.*

Under the summer worst-case scenario, modeling results show that neither Station could consistently meet new UDIP thermal limits. Exh. A at 3-6; *see* Pet. at 20. At the theoretical edge of the Stations’ mixing zones, the maximum surface temperature under this scenario would be approximately 96 °F, which is the maximum compliance temperature MG requests as its proposed near-field ATEL. Exh. A at 3-5; *see* App. B at B-45.

The demonstration states that, under more typical summer conditions, both Stations could meet the UDIP limits “but would not be able to consistently meet the narrative portions.” Exh. A at 3-6.

For winter months, the demonstration states that the July 1, 2018 UDIP standards set a limit of 60 °F at the edge of the mixing zone, “which is up to 33 °F cooler than the prior thermal standard.” Exh. A at 3-7. A review of data for discharge temperature and river flow showed that “there would be periods, ranging from 0% up to 45% of the time during one or more of the winter months,” when this standard could not be met. *Id.* The demonstration added that the Joliet 29 cooling towers are not available during the winter months. *Id.* If required to run during the winter, neither of the Stations could consistently meet the thermal limit, “even with the allowed 3 °F excursion for up to 1% of the hours in any 12-month period.” *Id.* at 3-9. However, the demonstration argues that the Stations would be able to meet the proposed ATELS, which are more stringent than the previous Secondary Contact standards, while adequately protecting the BIC. *Id.*

Excursion Hours. The UDIP and General Use standards provide excursion hours of up to one percent of the hours in any period, which MG characterizes as “entirely insufficient” to operate the Stations, “especially if unseasonal weather patterns and/or low flow conditions persisted during any given year.” Pet. at 20.

The demonstration proposed excursion hours during which the maximum compliance temperature can be up to 3 °F above the proposed limit. It argues that the BIC will be adequately protected if near-field excursions are allowed up to 5% of the time in a calendar year. Exh. A at 3-4, 3-7; *see* App. B at B-45 – B-46.

The demonstration stresses that the far-field limits from AS 96-10 “allows for temperatures up to 3 °F higher than the applicable period limit, up to 2% of the hours in a calendar year, with the additional provision that at no time would the temperature at the I-55 Bridge be allowed to exceed 93 °F at any time.” Exh. A at 3-4. It argues that complying with

these standards has not resulted in appreciable harm to the BIC. *Id.* MG requests that the Board approved the AS 96-10 standards as the far-field thermal standards in lieu of the General Use standards. *Id.* at 3-5.

Cooling Towers. IEPA's recommendation notes that Joliet 29 currently uses cooling towers "to avoid or limit excursion hours." Rec. at 3. IEPA recommends that "[c]ooling towers should be used prior to and during excursion hours when possible." *Id.* IEPA acknowledged that "the cooling towers cannot be operated in the winter and at other times where mechanical and other issues could prevent them from operating." *Id.*

MG responded that it "has no objection to the substance of the Agency's recommendation." MG Resp. at 2. MG expressed appreciation for IEPA's recognition that there may be obstacles to using the cooling towers, and it suggested clarifying the condition to provide that MG "will continue to operate its Joliet 29 Generating Station Cooling Towers to minimize the use of excursion hours when possible." *Id.* at 3. IEPA "has no objection" to MG's proposed language. IEPA Reply at 2.

Narrative Criteria. The demonstration argues that the "5 °F above natural temperature" limit at 35 Ill. Adm. Code 302.408(e) has not historically applied to the UDIP. Exh. A at 3-9. It adds that the current far-field standard under AS 96-10 does not contain this limit or any other narrative criteria. *Id.* MG argues that this limit "is difficult to apply in a regulated and anthropogenically influenced waterway such as the LDPR, and does not provide any protections that would not be afforded by the proposed seasonal AELs." Exh. A at 3-6. It concludes that this limit is "overly restrictive and unnecessary to maintain and protect the BIC of the UDIP/LDPR." *Id.* at 3-10.

The demonstration notes that the UDIP limits include other narrative standards. Under 35 Ill. Adm. Code 302.408(c), "there shall be no abnormal temperature changes that may adversely affect aquatic life unless caused by natural conditions." Under 35 Ill. Adm. Code 302.408(d), "the normal daily and seasonal temperature fluctuations that existed before the addition of heat due to other than natural causes shall be maintained." Exh. A at 3-9.

The demonstration acknowledges that these narrative criteria apparently intend "to prevent elevated water temperatures" from impeding the movement of fish in a natural system. Exh. A at 3-9. The demonstration stresses that natural habitats in the LDPR have undergone significant modifications. *Id.* It argues that, even if normal temperature changes could be identified, applying them would not change the BIC. *Id.*

The demonstration adds that proposed near-field standards for transitional months would limit the need for a "5 °F above natural temperature" limit to minimize abrupt temperature changes. Exh. A at 3-10. Also, "the proposed thermal AELs for April, May, October, and November are more stringent than the corresponding UDIP limits." *Id.*; see App. B at B-47. The proposed far-field standards based on AS 96-10 provide the same seasonally-based transitions. Exh. A at 3-10. The demonstration argues that these standards "have been shown over years of study to not have caused any adverse harm to the Five-Mile Stretch BIC at and below the I-55 Bridge." *Id.* at 3-11.

The demonstration argues that field studies and modeling show that the Stations' discharges do not result in any kind of thermal block during summer or winter operations. *Id.* It concludes that the BIC can be maintained without these narrative criteria, "as long as the seasonal numeric standards remain protective of the resident aquatic community." *Id.*; *see* Pet. at 22.

Zone of Passage. The demonstration argues that the Brandon Road Lock & Dam and proposed nuisance species barriers impede maintaining a ZOP near the Stations. Exh. A at 3-9 - 3-10. Under proposed near-field limits, it argues that modeling shows the Stations' discharges would meet ZOP requirements. *Id.* at 3-10, citing 35 Ill. Adm. Code 302.102(b)(8); *See* Pet. at 20. The demonstration concludes that the Stations' operations would "at no time" completely eliminate a ZOP. Exh. A at 3-10.

Far-Field Temperature Limitations. The demonstration argues that proposed far-field ATELS have been in place as adjusted standards since 1996. Exh. A at 3-8; *see* Pet. at 23. It adds that they have "resulted in no adverse harm to the BIC" and should continue to support it. Exh. A at 3-8.

The demonstration argues that the proposed winter far-field thermal ATELS differ only slightly from the UDIP and General Use winter limits. Exh. A at 3-9; *see* Pet. at 24. It elaborates that the proposed limits are "more realistic" for December and March, when unseasonably warm temperatures have been experienced. Exh. A at 3-9.

Summary. The demonstration argues that operating the Stations for more than 40 years under the previous limits did not result in documented adverse effects on the aquatic community in the UDIP and Five-Mile Stretch. Exh. A at 3-6. It adds that long-term fish monitoring shows that the community has improved over time. *Id.* With the Stations operating less frequently as peaking plants, MG argues that "there is even less likelihood of adverse impacts" from the Stations' thermal discharges. *Id.* It stresses that its proposed ATELS are more stringent than the previous Secondary Contact limits. *Id.* MG proposed the ATELS "to maintain regulatory flexibility" so that it could operate the Stations "to serve expected power demands during critical weather and flow periods, not just operations under average conditions." *Id.* at 3-6 – 3-7.

Board Findings

Board Findings on Biotic Category Criteria That Assure the Protection and Propagation of the BIC. A CWA Section 316(a) demonstration describes the impact of the thermal discharge on each of six biotic categories: (1) habitat formers; (2) phytoplankton; (3) zooplankton and meroplankton; (4) macroinvertebrates and shellfish; (5) fish; and (6) other vertebrate wildlife. A successful demonstration shows that each biotic category meets specified decision criteria. USEPA 316(a) Manual at 18-32. MG's retrospective assessment first analyzed the condition of each biotic category "by comparing available information on its abundance and species composition to what would be expected based on existing habitat, flow, and chemical characteristics of the UDIP and Five-Mile Stretch." Pet. at 25; *see* App. C at C-2; *see also* Rec. at 5. Second, the demonstration analyzed long-term trends for the biotic categories "to determine

whether a change in population abundance has occurred that can be attributed to the operation of the Joliet Stations.” Pet. at 25; *see* App. C at C-2; *see also* Rec. at 5-6.

MG argues that its assessment shows “there have been no substantial changes in abundance of nuisance species or in the physical and biological components of the ecology of the UDIP/Five-Mile Stretch during the past 24 years.” Pet. at 30. MG stresses that, for much of that 24-year period, the UDIP was subject to thermal standard less stringent than its proposed ATELS. *Id.* It also stresses that the Stations have converted from base-load to peaking operations, reducing the Stations’ thermal loading. *Id.*

MG concludes that temperatures in the UDIP/Five-Mile Stretch are not harming the BIC, and “this BIC can be adequately protected” by its proposed ATELS. Pet. at 30. In the following subsections, the Board summarizes the record on criteria for the biotic categories.

Habitat Formers (Aquatic Vegetation). The demonstration argues that, while the UDIP/Five-Mile Stretch includes habitat suitable for aquatic life, the potential for habitat formers is limited by the waterway’s uses to convey treated wastewater and transport materials in an urban and industrial environment. Exh. A at 6-3; *see* App. K at K-7. The demonstration further asserts that the distribution and abundance of habitat formers result chiefly from the dominance of main channel and main channel border habitats, which hinder developing greater diversity of habitat formers. Exh. A at 6-4. It maintains that the Station’s thermal discharges have not affected the quality of aquatic habitat and have not caused appreciable harm to this community. *Id.* at 6-3. The demonstration concludes that the community of habitat formers “would be substantively the same regardless of the operation of the Joliet Stations’ cooling water discharges” under the proposed ATELS. *Id.* at 6-4.

The Board notes that QHEI scores from 2016 support MG’s contentions that there have been no significant changes in habitat quality in the UDIP and that the existing habitat limitations are not related to the operation of Joliet Stations 9 or 29 or their thermal discharges. MG’s demonstration shows that the low QHEI scores are attributable to a lack of riffle/run habitat; lack of clean, hard substrates such as gravel and cobble; areas of excessive siltation; channelization; poor riparian and floodplain areas; and lack of instream cover. Thus, the habitat former community will continue to be essentially the same regardless of MG’s operation under the proposed alternative thermal effluent limitations. MG’s demonstration shows that the proposed thermal discharges: (1) will not result in deterioration of habitat formers so as to cause appreciable harm to the balanced, indigenous community of fish or mussels; and (2) will not adversely impact threatened or endangered species due to impact on habitat formers. In light of these factors, the Board finds that MG’s Section 316(a) Demonstration meets the decision criteria for habitat formers at sites that are not low potential impact areas. *See* USEPA 316(a) Manual at 22.

Phytoplankton. The demonstration argues that existing data show the Station’s thermal discharges have not caused appreciable harm to the phytoplankton community. Exh. A at 6-2. “The similarity between the plankton communities at the intake and discharge areas of the Stations indicates that there is no adverse impact from the thermal discharges of the Joliet Stations on the plankton community.” *Id.* at 6-1 - 6-2. It adds that the Stations’ operations under

previous thermal limits did not result in a shift toward nuisance species or algal blooms. *Id.* at 6-2. It also notes that phytoplankton diversity supports a diverse food chain in the UDIP/Five-Mile Stretch. *Id.* It concludes that the proposed ATELS are not expected “to have any adverse effects on phytoplankton communities in the vicinity of Joliet Stations 9 and 29, nor those further downstream.” *Id.*

The Board finds that MG’s 316(a) demonstration shows that the proposed thermal discharges are not likely to: (1) result in a shift toward nuisance species of phytoplankton; (2) alter the indigenous community from a detrital-based to phytoplankton-based system; and (3) cause appreciable harm to the balanced indigenous population resulting from phytoplankton community changes. Thus, the Board finds that MG’s Section 316(a) demonstration meets the decision criteria for phytoplankton at sites that are not low potential impact areas. *See* USEPA 316(a) Manual at 18.

Zooplankton. The demonstration cites three factors indicating that the Station’s thermal discharges are not likely to affect the zooplankton community: it has adapted to variable environments by evolving tolerances and behaviors; it is rapidly transported through the discharge plumes, and it has high reproductive capacity to offset the loss of individuals. Exh. A at 6-4. The demonstration argues that no evidence indicates that thermal discharges from the Stations “have caused appreciable harm to the downstream zooplankton assemblage.” *Id.* at 6-5. The demonstration emphasizes “the long-term success of the fish community that would utilize zooplankton as a food source.” *Id.* Based on these factors, it concludes that there is no expectation that more stringent proposed ATELS would result in any adverse effect in the UDIP/Five-Mile Stretch. *Id.*

The Board finds that MWG’s 316(a) Demonstration shows that: (1) changes in zooplankton and meroplankton will not result in appreciable harm to the balanced, indigenous community of fish and shellfish; (2) the heated discharge is not likely to alter the standing crop or relative abundance of zooplankton; and (3) the thermal plume is not a lethal barrier to free movement (drift) of zooplankton. Thus, the Board finds that MG’s Section 316(a) demonstration meets the decision criteria for zooplankton at sites that are not low potential impact areas. *See* USEPA 316(a) Manual at 21.

Macroinvertebrates and Shellfish. This category consists of benthic community and mussels in the receiving waterways.

Benthic Community. The demonstration argues that the persistence of this community through various assessments indicates that a factor other than thermal discharges is limiting the community. App. A at 6-7. It further argues that the absence of significant temporal differences among the assessments indicates that there have not been observable cumulative effects from the Stations’ thermal discharges. *Id.* The demonstration concludes that these discharges “have had no significant adverse effect on the benthic macroinvertebrate community.” *Id.*

Freshwater Mussels. The demonstration argues that surveys and studies establish that areas in vicinity of the Stations’ thermal plumes include “minimal suitable habitat for mussels.” Exh. A at 6-7. Because the plumes are buoyant, water temperatures will be lower in sediments

where mussels reside. *Id.* While there are native mussel species present in limited areas of the UDIP, “they have not been adversely affected” by the Stations under previous thermal limits. *Id.* at 6-9. Consequently, “[t]here is no expectation that mussels would be negatively impacted” by the Stations’ discharges. *Id.* at 6-7, 6-9. The proposed ATELS are not expected to interfere with maintaining the community or with its life history cycles such as spawning. *Id.* at 6-9 – 6-10.

Board Finding. The demonstration shows that the lack of a diverse benthic macroinvertebrate and mussel community near the Joliet Stations is due to limitations related to habitat, and modified physical/hydrological characteristics of the waterway rather than the thermal discharges. Thus, the Board finds that MWG’s Section 316(a) Demonstration shows that any measurable reduction of standing crop of shellfish and macroinvertebrates is not likely to: cause appreciable harm to balanced indigenous populations; or interfere with maintenance or critical, seasonal, life cycle of mussels or benthic macroinvertebrates. USEPA 316(a) Manual at 23-25

Fish. At a site that is not classified as a low potential impact area, a successful CWA Section 316(a) demonstration for fish must show that fish communities “will not suffer appreciable harm” from:

1. Direct or indirect mortality from cold shocks;
2. Direct or indirect mortality from excess heat;
3. Reduced reproductive success or growth as a result of plant discharges;
4. Exclusion from unacceptably large areas; or
5. Blockage of migration. USEPA 316(a) Manual at 28–29; *see* Exh. A at 6-10.

The demonstration argues that the entire range of data both before and after the Station’s conversion to gas indicate no adverse effect on the fish community under the former thermal limits. Exh. A at 6-16. The UDIP and Five-Mile Stretch sustain spawning and reproduction near the plume. *Id.* The demonstration argues that the community is consistent with the characteristics of the waterway and available habitat. It adds that an adequate zone of passage exists near the Stations’ plumes and that it will continue to exist under the proposal ATELS. *Id.* The demonstration concludes that “there is no expectation” that operating the Stations under the proposed ATELS would cause adverse effects on the fish community. *Id.*

Based on the demonstration’s extensive information on fish communities, which the Board has discussed above under identification of biotic categories (*supra* at 70-80), the Board finds that MWG’s requested alternative thermal effluent limitations will protect the balanced, indigenous fish communities in the UDIP and the Five-Mile Stretch. Accordingly, the Board finds that MWG’s Section 316(a) Demonstration meets the criteria for a site that is not a low potential impact area for fish. MWG has demonstrated that (1) there will be no direct or indirect mortality from cold shock; (ii) there will be no direct or indirect mortality from excess heat; (iii) there will be no reduced reproductive success or growth due to the heated discharge; (iv) there

will not be exclusion from unacceptably large areas; and (v) there will not be blockage of migration due to the thermal discharge.

Other Vertebrate Wildlife. The USEPA 316(a) Manual states that “most sites in the United States” will be considered to have low potential impact for other vertebrate wildlife “simply because the projected thermal plume will not impact large or unique populations of wildlife.” USEPA 316(a) Manual at 32. The “main exceptions” are: (1) sites where important, threatened, or endangered wildlife may be adversely affected by the discharge and (2) sites in cold areas where the thermal plume is predicted to attract geese and ducks and encourage them to stay through the winter. *Id.* The demonstration argues that consistent with this USEPA Guidance, this can be considered a low potential impact biotic category for the Station’s thermal discharges. Exh. A at 6-17.

The demonstration argues that the previous thermal limits for the Stations have not limited activity of other vertebrate wildlife. It adds that the thermal discharge does not prohibit or restrict access to the shoreline by wildlife in areas that do not already have limited access. Exh. A at 6-17. It stresses that the thermally-influenced area is small and that “higher water temperatures occur in the summer when migratory waterfowl use is at its lowest.” *Id.* The demonstration concludes that this category is not expected to be affected by the proposed ATELS. *Id.*

The Board finds that the UDIP near the Joliet Stations’ mixing zones is a low potential impact area for other vertebrate wildlife. Further, the Board finds that MG’s demonstration meets the decision criteria for low potential impact areas by showing that the thermal plume does not harm any important, threatened, or endangered populations of vertebrate wildlife, including migratory birds.

Board Findings on MG’s Master Rationale. The Board notes that the decision train in the USEPA 316(a) Manual provides steps to ensure that the demonstration is complete; required data has been submitted; the studies justify the conclusions for each of the biotic category criteria; the information shows the representative important species will not suffer appreciable harm; the engineering and hydrological data justify the conclusions for the Master Rationale; technical experts were consulted that include other government agencies; and the information is not negated by outside evidence. USEPA 316(a) Manual at 16–17, 70. Through its Type I Retrospective/Absence of Prior Appreciable Harm and Type II Predictive/Representative Important Species Demonstrations, MG has addressed each of the following biotic category criteria for a demonstration to be judged successful. App. C at C-43; *see* Pet. at 26; Exh. A at 4-11.

No Appreciable Harm to the Balanced, Indigenous Community. The demonstration argues that extensive monitoring and studies show that the aquatic community in the vicinity of the Stations’ discharges is similar to the community in adjacent upstream and downstream areas. Exh. A at 4-2, 4-4. It attributes any differences to the availability of suitable habitat and not to the Stations’ thermal discharges. *Id.* at 4-2. The demonstration argues that the retrospective analysis shows the Stations’ discharges under the previous Secondary Contact limits have not resulted in appreciable harm to the BIC. *Id.* at 4-1.

The demonstration also argues that predictive modeling shows the Stations' operations under the proposed ATELS will not appreciably affect survival, reproduction, development, and growth of the RIS. Exh. A at 4-6; *see* App. C at C-45. It concludes that the proposed near-field and far-field ATELS "will assure the propagation and protection of the BIC represented by the RIS that reside in the UDIP/Five-Mile Stretch, given its existing and inherent habitat limitations and upstream anthropogenic influences." Exh. A at 4-6.

Not in Excess of Upper Temperature Limits. Under the typical summer scenarios, the demonstration argues that modeled "discharge temperatures do not exceed the chronic or acute thermal mortality threshold or avoidance temperatures for the RIS." Exh. A at 4-4. The demonstration argues that these modeled scenarios are typical of both previous and expected summer operations, and it projects shorter operations in the future under peaking operation than under earlier base-loaded operation. *Id.*

The demonstration adds that modeling for winter scenarios "indicates that even under 'worst-case' conditions, there would be no temperatures that would have an adverse impact" in the UDIP on avoidance, reproduction, or mortality. Exh. A at 4-4; *see* App. C at C-45. It argues that, because the UDIP is commonly warmer than a natural waterway during winter months because of the flow of treated POTW effluent, the BIC is acclimated to warmer winter water temperatures than a typical natural system. Exh. A at 4-4 – 4-5. Also, the demonstration argues that, under peaking operation for shorter durations, the fish community is not expected to become acclimated to temperatures in the discharge plumes. *Id.* at 4-5. Finally, the demonstration adds that the gradual rate of heat decay after a shutdown is expected to limit temperature fluctuations and minimize the risk of cold shock. *Id.* Based on these factors, the demonstration concludes that proposed winter ATELS will ensure adequate protection for the BIC. *Id.*

For the transitional months of April, May, October, and November, MG proposes transitional limits similar to those adopted in AS 96-10. Exh. A at 4-5. The demonstration argues that this seasonal approach reflects transitions between the extremes of summer and winter. *Id.* It adds that many of the proposed ATELS are more stringent than near-field UDIP standards or General Use standard applicable at the I-55 Bridge. *Id.* The demonstration concludes that this seasonal approach "will ensure continued protection of the BIC." *Id.*

Nuisance Organisms. The demonstration argues that the retrospective analysis shows "no appreciable changes in the physical and biological components of the system" while the Stations were subject to the Secondary Contact thermal standards. App. C at C-43; *see* Pet. at 26, 30. It argues that the LDPR's channelized nature and regulated flow "influence the aquatic species assemblage which is able to successfully carry out their life histories in the waterway." App. C at C-43. It indicates that the presence of invasive species "must also be taken into consideration as a permanent part of the LDPR environment." *Id.* at C-43 – C-44; *see* Exh. A at 4-6 – 4-7. However, the demonstration argues that the Stations' operations "have not been responsible" for the introduction or spread of nuisance species in the LDPR. Exh. A at 4-7.

The demonstration argues that, "[t]o date, no substantial changes in abundance of nuisance species have been observed in the LDPR" near the Stations. App. C at C-43; *see* Exh.

A at 4-12. While it notes that the Stations will discharge less heat overall under the proposed ATEs, the demonstration argues that this change “will not benefit or in any way affect the abundance or distribution of nuisance species.” Exh. A at 4-12. The demonstration concludes that the proposed ATEs, which are more stringent than previous Secondary Contact limits, “are not expected to cause changes in abundance or distribution of other indigenous or nuisance species.” App. C at C-44; *see* Exh. A at 4-7; Pet. at 26.

Zone of Passage Not Impaired. The demonstration argues that, whether under typical or worst-case scenarios, the RIS are not likely to avoid significant areas of habitat near the Stations. Exh. A at 4-7. It adds that the Stations’ thermal plumes are not likely to interfere with localized movement or migration patterns. *Id.* It argues that avoidance, “if it occurred, would be of very short duration.” *Id.* The demonstration concludes that the proposed ATEs will maintain an adequate zone of passage for the fish community near the Stations’ discharges. *Id.* at 4-8; *see id.* at 6-16; Pet. at 31.

No Adverse Impact on Threatened or Endangered Species. Although the retrospective analysis did not find federally-listed threatened or endangered species, it identified four state-listed fish species. App. C at C-45; Exh. A at 4-8, 4-14; *see* App. C, Table C-7. Surveys collected the threatened River Redhorse “infrequently and in low numbers downstream of the Brandon Road Lock and Dam.” Exh. A at 4-8; *see* App. B at B-9; App. C at C-27. Surveys collected one endangered Greater Redhorse in 2010 at a far-field sampling location. Exh. A at 4-8 – 4-9; *see* App. C at C-27. The demonstration argues that the Stations’ operations have a low potential impact on these incidental species because their preferred habitat is downstream in the Kankakee River beyond the Stations’ thermal influence. Exh. A at 4-14. The demonstration adds that these species were found when the former Secondary Contact thermal standards were in place, indicating that the Stations’ discharges had not negatively affected them or their habitat. *Id.* at 4-9, 4-15; *see* App. C at C-45; Pet. at 26.

The endangered Pallid Shiner was first collected downstream of the I-55 Bridge in 2001 and has since been collected chiefly in the Five-Mile Stretch. Exh. A at 4-9; *see id.* at 4-14; App. B at B-9; App. C at C-27. The demonstration adds that this species was found when the former Secondary Contact thermal standards were in place, indicating that the Stations’ discharges had not negatively affected it or its habitat. Exh. A at 4-9, 4-15; *see* App. C at C-45; Pet. at 26.

Surveys first collected the threatened Banded Killifish in 2012, and it has “increased dramatically over time” with less stringent thermal standards in place. Exh. A at 4-9; *see id.* at 4-14; *see* App. B at B-9; App. C at C-45; Pet. at 26. The demonstration cites the INHS to argue that this increase “represents an expansion of the Lake Michigan population through the CAWS into the Des Plaines River.” *Id.* at 4-9. It also argues that the Banded Killifish found in non-preferred habitat such as the LDPR are an invasive subspecies, the Eastern Banded Killifish, and not the threatened Western Banded Killifish. *Id.* Because the Western Banded Killifish populations and distributions “had remained unchanged from 1880 to 2000,” the demonstration argues that its recent growth is “unusual.” *Id.* (citation omitted). The demonstration reports that IDNR is expanding its research on the Banded Killifish to determine whether it should be listed as threatened. *Id.*; *see* App. C. at C-28. Also, IDNR has determined that adverse impacts on the Banded Killifish were “unlikely.” Rec. at 11, citing Att. A (IDNR letter to IEPA).

Based on these factors, the demonstration argues that the Stations' discharges are unlikely to have had and are not expected to have adverse effects on any threatened or endangered species. Exh. A at 4-10, 4-15; *see* Pet. at 26.

No Destruction of Unique or Rare Habitat. The demonstration reports that factors such as flow modification, impoundment, and channelization have altered flow conditions and limited the types of habitat available in the LDPR. Exh. A at 4-10. It argues that these factors have not resulted from the Stations' discharges. *Id.* QHEI scores have generally characterized habitats near the Stations as "fair" or "poor." *Id.* at 4-10, 4-15. The demonstration concludes that "[t]here are no unique or rare habitat components that would be affected by the Joliet Station thermal discharges, either in the UDIP or Five-Mile Stretch." *Id.* at 4-15; *see id.* at 4-10; App. C at C-45; Pet. at 26.

Biocides. The demonstration reports that Joliet 9 relies on dehumidification and "does not use biocides, or other chemical processes, to minimize biofouling of its condenser cooling system." Exh. A at 4-10. Although Joliet 29 is permitted to use the biocide sodium hypochlorite, it uses dichlorination so that its final effluent complies with its NPDES permit. *Id.* at 4-10 – 4-11. It has also relied more recently on dehumidification. *Id.* at 4-11. The demonstration concludes that neither Station "poses a threat of appreciable harm to the BIC as a result of biocide use." *Id.*

Conclusion. The demonstration argues that 24 years of monitoring have shown no significant change in the abundance of nuisance species or the physical and biological components of the ecology of the UDIP/Five Mile Stretch. Pet. at 30. It stresses that, for most of that time, the UDP was subject to thermal standards less stringent than both the 2018 limits and the proposed ATELS. *Id.* MG also stresses that the UDIP had been subject to significantly more thermal loading from upstream generating stations that have become inactive or reduced generating capacity. *Id.* In addition, MG argues that converting the Joliet Stations from base-load to peaker operations results in "a dramatic drop in annual thermal loading." *Id.*

Based on the results of its predictive assessment, MG argues that its proposed ATELS will maintain temperatures consistent with normal growth pattern for aquatic life in the BIC. Pet. at 31. It argues that, even under temporary "worst-case" conditions, "thermal discharge temperatures will not fundamentally change the habitability of the UDIP or Five-Mile Stretch." *Id.* It also argues that the Stations' thermal discharges will be able to meet requirements for maintaining a zone of passage even under the modeled worst-case conditions. *Id.*

The demonstration concludes that the BIC can be adequately protected by the proposed ATELS and that the narrative thermal criteria at 35 Ill. Adm. Code 302.211(b-d) do not benefit aquatic life. *Id.*

IEPA agrees that MG has met its burden of proof and shown that proposed ATELS would not adversely affect the BIC in the receiving water. Rec. at 5, 9-10.

Board Finding. Based on the above, the Board finds that MG's 316(a) Demonstration successfully addresses each of the elements of the Master Rationale outlined in the USEPA

316(a) Manual. *See* USEPA 316(a) Manual at 70–71. Specifically, for the alternative thermal effluent limitations in the order below, the Board finds that MG’s demonstration shows the following: (1) due consideration of the requisite steps in the USEPA 316(a) Manual’s “decision train”; (2) there will be no appreciable harm to the balanced, indigenous community; (3) receiving water temperatures will not be in excess of the upper temperature limits for the life cycles of the representative important species; (4) the absence of the proposed thermal discharge would not result in excessive growth of nuisance organisms; (5) a zone of passage provides for the normal movement of representative important species; (6) there will be no adverse impact on threatened or endangered species; (7) there will be no destruction of unique or rare habitat, and (8) there will be no use of biocides and therefore biocides will not result in appreciable harm to the balanced, indigenous community.

Board Finding That Applicable Effluent Limits Are More Stringent Than Necessary. MG has the burden of demonstrating that the generally applicable thermal water quality standards are more stringent than necessary to assure the protection and propagation of the BIC in the receiving waters. Pet. at 7, citing 35 Ill. Adm. Code 106.1160(a, b).

The demonstration argues that operating the Stations for more than 40 years under the previous Secondary Contact thermal standards did not result in documented adverse effects on the BIC in the UDIP/Five-Mile Stretch. Exh. A at 3-6. It further argues that “this community has, in fact, improved over the time during which the two Joliet Stations have been in operation.” *Id.*, citing Apps. A, C, F, G, H, J. With less frequent operation as peaking plants in the future, it argues that the Stations are less likely to result in adverse impacts under proposed ATELS that are more stringent than the previous limits. Exh. A at 3-6. It concludes that the 2018 UDIP thermal standards are more stringent than necessary to assure the protection and propagation of the BIC. App. B at B-1; *see* Pet. at 15, 30, 34; Rec. at 10.

UDIP Numeric Temperature Water Quality Standards. Section 302.408(i) limits daily maximum water temperatures to 60 °F (December–March) and 90 °F (April–November). 35 Ill. Adm. Code 302.408(i).

The demonstration argues that the previous Secondary Contact baseline standard of 93 °F has been shown not to have had a detrimental effect on the BIC. Exh. A at 3-7; *see* Rec. at 9, 10. It also argues that far-field numeric standards in place since 1996 under AS 96-10 “have also resulted in no adverse harm to the BIC.” Exh. A at 3-7; *see* Pet. at 22; Rec. at 9, 10.

The demonstration cites the predictive assessment as providing “reasonable assurance that the proposed numeric ATELS will allow for the protection and propagation of the UDIP/Five-Mile Stretch BIC.” Pet. at 30. It argues that the proposed limits are consistent with maintaining temperatures within normal patterns for growth. *Id.* at 31. Although less stringent than the 2018 UDIP standard for December-March and June-September, MG argues they are within the thermal tolerances of the RIS. Exh. A at 4-5; *see* Rec. at 8.

Based on these factors, for the Joliet Stations’ thermal discharges the Board finds that MG has demonstrated that effluent limitations based on the 2018 UDIP numeric temperature

water quality standards of Section 302.408(i) are more stringent than necessary to assure the protection and propagation of BIC in the UDIP/Five-Mile Stretch.

Five-Mile Stretch Numeric Temperature Water Quality Standards. MG notes that the Board granted adjusted thermal water quality standards applicable to the Five-Mile Stretch in 1996 to Commonwealth Edison, the previous owner of the Joliet Stations under 35 Ill. Adm. Code 304.141(c) and CWA § 316(a). Pet at 23, citing AS 96-10. MG asserts that the proposed seasonal far-field ATELS for the Five-Mile Stretch “would result in temperature standards that are more stringent than the AS 96-10 Standards that currently govern the waterway.” Pet. at 23-24. Further, MG clarifies that the far-field thermal ATELS would, in effect, replace both the existing AS96-10 limits and the Stations’ obligation to comply with the existing General Use thermal standards that would otherwise be effective at and below the I-55 Bridge, specifically, the narrative criteria under 35 Ill. Adm. Code 302.211 (b), (c), (d), and (e). *Id.* at 24.

Excursion Hours. Section 302.408(f) of the Board’s UDIP water quality standards limit excursion hours to 87.6 hours in each 12-month period ending with any month (1% of the 8,760 hours in 12 months). 35 Ill. Adm. Code 302.408(f). A similar requirement applies to the Five-Mile Stretch under Section 302.211(e). However, MG asserts that this “small number of allowable excursion hours” under the 2018 UDIP thermal standards and the General Use standards is “entirely insufficient” to support the Stations’ operation in the event of persistent unseasonable weather or low flow conditions. Pet. at 20; *see* Exh. A at 3-6 – 3-7. MG’s proposed ATELS consider worst-case scenarios when elevated air and water temperatures coincide with low flow conditions and include “excursion hours so that the Joliet Stations can continue to remain in compliance during these periods of time.” Pet. at 31.

As the UDIP ATELS, MG proposed that daily maximum temperature is not be exceeded more than five percent of the time in a calendar year. Pet. at 21. IEPA’s recommendation agrees that this is similar to the previous Secondary Contact standards. Rec. at 8. The recommendation also agrees that MG’s demonstration showed there is no evidence that operating the Stations under the previous standards has caused appreciable harm to the BIC in the UDIP/Five-Mile Stretch. *Id.*

As the far-field standards, MG proposed that the daily maximum temperatures “may be exceeded by no more than 3 °F during 2% of the hours in the 12-month period ending December 31,” which is consistent with far-field standards under AS 96-10. Pet. at 24; *see* Exh. A at 3-4; Rec. at 4. MG argues that there is no evidence that these standards have caused appreciable harm to the BIC in the UDIP or the Five-Mile Stretch downstream from the I-55 Bridge. *Id.*

MG argues that species inhabiting the UDIP/Five-Mile Stretch are generally tolerant and can avoid temperatures outside their preferred range. Pet. at 31; *see* App. B at B-46. The demonstration argues that “higher temperatures would occur infrequently and for short durations.” App. B at B-46. It argues that temporary increases in thermal discharge temperatures “will not fundamentally change the habitability of the UDIP or the Five-Mile Stretch.” Pet. at 31. The demonstration further argues that the previous limit of 93 °F with excursions allowed up to 100 °F has been shown to have no detrimental effect on the BIC in the UDIP. App. B at B-46; *see* Exh. A at 3-4.

Also, MG proposed to “track the use of excursion hours on a calendar-year basis, rather than the rolling 12-month period described in the 2018 Thermal Standards.” *Id.*, n.13. MG argues that this tracking is consistent with ATELS approved by the Board. *Id.*, citing Midwest Generation v. IEPA, PCB 18-58, slip op. at 74 (Nov. 21, 2019); Exelon Generation v. IEPA, PCB 14-123, slip op. at 48,54 (Sept. 18, 2014). Also, the Stations’ permits have included provisions tracking excursion hours on “the 12-month period ending December 31.” App. A, Exh. A-1 (Joliet 9 Special Condition 4C); Exh. A-2 (Joliet 29 Special Condition 4C).

In its Recommendation, IEPA notes that MG requests excursion hours of five percent for both the UDIP and the Five-Mile Stretch. Rec. at 4; *see* Pet. at 32. However, it notes that MG’s background information proposed far-field excursion hours of two percent, which is consistent with AS 96-10. Rec. at 4, citing Pet. at 24. IEPA argues that any relief granted by the Board “should specify that the excursion hours are 5% for the UDIP/Near-Field and 2% for the Five-Mile Stretch/Far-Field.” Rec. at 4; *see id.* at 8.

MG’s response accepts this clarification of the excursion hours for the Five-Mile Stretch. MG Resp. at 2-3. MG emphasizes that it seeks an ATEL “that is largely identical to existing adjusted thermal standards in AS 96-10, including the 2% excursion-hour allowance from those standards.” *Id.*; *see id.*, Exh. A (Corrected Statement of Requested Relief).

Based on these factors, the Board concludes that it is appropriate to include in ATELS for the Stations excursion hours limited to five percent of hours in the UDIP/NEAR-Field and two percent of hours in the Five-Mile Stretch/Far-Field based on the twelve-month period ending on December 31.

Minimum Zone of Passage. MG argues that, even under worst-case modeled conditions, “it can be expected that a 75% or greater zone of passage under the proposed maximum thermal AELs would continue to be available” near the Stations in the UDIP. Pet. at 20, 31. It adds that, even if the dilution ratio drops below 3:1, the Stations “would be able to comply with the lower 50% zone-of-passage requirement during that time.” *Id.*; *see* App. B at B-40, Tables B-7a, b, c; B-8a, b, c (zones of passage). MG concludes that its hydrothermal modeling and predictive assessment show the Stations’ “thermal discharges would be able to meet the existing zone of passage criteria in place under the proposed near-field thermal AELs.” Pet. at 31; *see* Exh. A at 3-10, citing 35 Ill. Adm. Code 302.102(b)(8).

Based on these factors, the Board concludes that MG’s proposed near-field thermal ATELS are projected to maintain an adequate zone of passage.

Narrative Temperature Water Quality Standards. MG argues that the apparent purpose of narrative thermal standards “is to prevent elevated water temperatures from negatively impacting fish movement and activity in a natural system.” Exh. A at 3-9. However, it suggests that the UDIP and Five-Mile Stretch “are anything but natural.” *Id.*

MG argues that the UDIP and Five-Mile Stretch have been adequately protected solely by numeric thermal criteria. Pet. at 22. Because its proposed ATELS will adequately protect the BIC, MG argues that “narrative thermal criteria like those in 35 Ill. Adm. Code 302.211(b) – (d)

would offer no foreseeable benefit to aquatic life.” *Id.* at 30; *see* 35 Ill. Adm. Code 302.408; Rec. at 8.

Section 302.408(c) provides that “[t]here shall be no abnormal temperature changes that may adversely affect aquatic life unless caused by natural conditions.” 35 Ill. Adm. Code 302.408(c). Section 302.408(d) provides that “[t]he normal daily and seasonal temperature fluctuations that existed before the addition of heat due to other than natural causes shall be maintained.” 35 Ill. Adm. Code 302.408(d). MG stresses that modifications such as channelization and locks and dams have significantly changed the natural habitat in the UDIP and Five-Mile Stretch. Exh. A at 3-9. It argues that, even if the historic normal and seasonal temperature fluctuations before the addition of heat could be identified, their application here would not significantly change (or improve) the BIC.” *Id.* MG asserts that, because its proposed thermal ATEs protect the BIC, it can be maintained without this narrative standard. *Id.*

Section 302.408(e) provides that “[t]he maximum temperature rise above natural temperatures shall not exceed 2.8 °C (5 °F).” 35 Ill. Adm. Code 302.408(e). MG argues that this standard has not historically applied to the UDIP and does not now apply as the far-field standard under AS 96-10. Exh. A at 3-9. MG argues that, because its proposed ATEs will continue to maintain an adequate zone of passage, applying this narrative standard “is overly restrictive and unnecessary to maintain and protect the BIC of the UDIP/Five-Mile Stretch near the Joliet Stations.” *Id.* at 3-10. It adds that its proposed thermal ATEs for transitional months provide an appropriate progression between summer and winter months, which limits the need for a narrative standard intended to minimize abrupt temperature changes. *Id.* MG notes that AS 96-10 includes similar seasonally-based standards instead of narrative criteria to limit abrupt changes. *Id.* at 3-10 – 3-11, 4-5.

In its recommendation, IEPA agrees that MG’s “requested numeric thermal ATEs will protect the BIC in lieu of other narrative criteria found in [Sections] 302.408(c)-(f) and (i) and 302.211.” Rec. at 8.

Based on the above, for the Joliet Stations’ thermal discharges, the Board finds that the narrative temperature standards under Sections 302.408 (c) - (e), and 302.211 (b) - (d) are more stringent than necessary to assure the protection and propagation of the balanced, indigenous population in and on the UDIP and the Five-Mile Stretch.

Board Finding. Based on the record before it, the Board finds that the generally applicable thermal water quality standard is more stringent than necessary to assure the protection and propagation of the BIC in the receiving waters. The Board finds that MG’s demonstration shows that the proposed thermal ATEs will protect the BIC in the UDIP/Near-Field and in the Five-Mile Stretch/Far-Field.

CONCLUSION

Based on the record, the Board finds that MG has justified the grant of alternative thermal effluent limitations for Joliet Stations 9 and 29 in compliance with 33 U.S.C. § 1326(a), 35 Ill. Adm. Code 304.141(c), and 35 Ill. Adm. Code 106.Subpart K.

The Board finds that MG demonstrates, for the discharges from Joliet 9 and Joliet 29, that thermal effluent limitations based on Sections 302.211(b)-(d) and 302.408(c)-(f), and (i) of the Board's water pollution regulations are more stringent than necessary to assure the protection and propagation of a balanced, indigenous community of shellfish, fish, and wildlife in and on the UDIP near Joliet 9 and Joliet 29, and the Five-Mile Stretch. MG's Type I Retrospective/Absence of Prior Appreciable Harm Demonstration shows that no appreciable harm to the balanced, indigenous community has resulted from the heated discharge from Joliet Stations 9 or 29. The Board also finds that MG's Type II Predictive/Representative Important Species Demonstration shows that the thermal effluent limitations in the order below will assure the protection and propagation of a balanced, indigenous community in and on the UDIP near Joliet Stations 9 and 29, and the Five-Mile Stretch. Accordingly, the Board grants MWG's requested relief, effective today.

ORDER

Under 35 Ill. Adm. Code 106.Subpart K and 35 Ill. Adm. Code 204.141(c), the Board orders that the following alternative thermal effluent limitations apply to the discharges to the Upper Dresden Island Pool (UDIP) from Midwest Generation, LLC's Joliet Generating Stations 9 and 29.

- 1) Temperature
 - a) Instead of thermal effluent limitations based on the General Use thermal water quality standards contained in 35 Ill. Adm. Code 302.211 and the Upper Dresden Island Pool (UDIP) Use thermal water quality standards provisions contained in 35 Ill. Adm. Code 302.408 (c)-(f), and (i), the following daily maximum temperature effluent limitations apply to Joliet Stations 9 and 29:

Month	Daily Maximum Near-Field (UDIP) (° F)	Daily Maximum Far- Field (Five- Mile Stretch) (° F)
January	65	60
February	65	60
March	70	65
April	80	73
May	85	85
June	93	90
July	93	91
August	93	91
September	93	90
October	90	85
November	85	75
December	70	65

- b) Instead of the water temperature requirements of 35 Ill. Adm. Code 302.408(c), (d), (e), (f) and (i) applicable to UDIP, effluent temperatures must not exceed the near-field daily maximum temperature limitations in paragraph (1)(a) during more than 5% of the hours (438 hours) in a calendar year. Moreover, the effluent temperature must never exceed the daily maximum near-field temperature limitations in paragraph (1)(a) by more than 3 °F.
 - c) Instead of the water temperature requirements of 35 Ill. Adm. Code 302.211 applicable to the Five-Mile Stretch, effluent temperatures must not exceed the daily maximum far-field temperature limitations in paragraph (1)(a) during more than 2% of the hours (175 hours) in a calendar year. Moreover, the effluent temperature must never exceed the daily maximum far-field temperature limitations in paragraph (1)(a) by more than 3 °F.
 - d) The alternative near-field thermal effluent limitations in paragraphs (1)(a) and 1(b) apply at the edges of each of the two 26-acre mixing zones allowed in each of the Joliet Generating Stations' National Pollutant Discharge Elimination System (NPDES) permits.
 - e) The alternative far-field thermal effluent limitations in paragraph (1)(a) and 1(c) apply at the I-55 Bridge (River Mile 277.9). For purposes of this order, the "Five-Mile Stretch" is the segment of the Lower Des Plaines River starting from the I-55 Bridge (River Mile 277.9) to the Illinois River (River Mile 273.0).
- 2) Midwest Generation will continue to minimize the use of excursion hours through the use of its Joliet 29 Generating Station Cooling Towers.
 - 3) Compliance.
 - a) Midwest Generation must demonstrate compliance with the near-field temperature limits in paragraph (1) by modeling that is approved by the Illinois Environmental Protection Agency (IEPA) as a condition of each of the Joliet Stations' NPDES permits.
 - b) Midwest Generation must demonstrate compliance with the far-field temperature limits in a manner that is approved by the IEPA as a condition of each of the Joliet Stations' NPDES permits.
 - 4) NPDES Permit. IEPA must expeditiously modify Midwest Generation, LLC's NPDES permits for the Joliet Generating Stations to make the permits consistent with this opinion and order.

IT IS SO ORDERED.

Section 41(a) of the Act provides that final Board orders may be appealed directly to the Illinois Appellate Court within 35 days after the Board serves the order. 415 ILCS 5/41(a) (2018); *see also* 35 Ill. Adm. Code 101.300(d)(2), 101.906, 102.706. Illinois Supreme Court Rule 335 establishes filing requirements that apply when the Illinois Appellate Court, by statute, directly reviews administrative orders. 172 Ill. 2d R. 335. The Board's procedural rules provide that motions for the Board to reconsider or modify its final orders may be filed with the Board within 35 days after the order is received. 35 Ill. Adm. Code 101.520; *see also* 35 Ill. Adm. Code 101.902, 102.700, 102.702.

Names and Addresses for Receiving Service of Any Petition for Review Filed with the Appellate Court	
Parties	Board
Midwest Generation, LLC Nijman Franzetti, LLP Attn.: Susan Franzetti 10 South LaSalle Street, Suite 3600 Chicago, Illinois 60603 sf@nijmanfranzetti.com	Illinois Pollution Control Board Attn: Don A. Brown, Clerk James R. Thompson Center 100 West Randolph Street, Suite 11-500 Chicago, Illinois 60601 don.brown@illinois.gov
Illinois Environmental Protection Agency Attn.: Sara G. Terranova 1021 North Grand Avenue East PO Box 19276 Springfield, Illinois 62794-9276 Sara.Terranova@illinois.gov	

I, Don A. Brown, Clerk of the Illinois Pollution Control Board, certify that the Board adopted the above opinion and order on July 8, 2021, by a vote of 4-0.



Don A. Brown, Clerk
 Illinois Pollution Control Board