## POLLUTION CONTROL BOARD

## NOTICE OF ADOPTED AMENDMENTS

TITLE 35: ENVIRONMENTAL PROTECTION SUBTITLE I: ATOMIC RADIATION CHAPTER I: POLLUTION CONTROL BOARD

# PART 1010 PROCEDURES FOR REPORTING RELEASES OF RADIONUCLIDES AT NUCLEAR POWER PLANTS

SUBPART A: GENERAL PROVISIONS

Section			
1010.100	Purpose		
1010.102	Applicability		
1010.104	Scope		
1010.106	Definitions		
1010.108	Severability		
SUBPART B: REPORTING			
1010.200	Evaluation of Releases		
1010.202			
1010.204	Follow-up Written Report		
AUTHORITY: Implementing and authorized by Sections 13.6 and 27 of the Environmental Protection Act [415 ILCS 5/13.6 and 27].  SOURCE: Adopted at 32 Ill. Reg. 7789, effective May 2, 2008; amended in R18-28 at 47 Ill. Reg, effective			
SUBPART A: GENERAL PROVISIONS			
Section 1010.100 Purpose			
This Part prescribes standards for detecting and reporting unpermitted releases of radionuclides from nuclear power plants <u>underpursuant to Section 13.6</u> of the Illinois Environmental Protection Act [415 ILCS 5/13.6].			
(Source	ee: Amended at 47 Ill. Reg, effective)		
Section 1010.106 Definitions			

#### POLLUTION CONTROL BOARD

#### NOTICE OF ADOPTED AMENDMENTS

Except as stated in this Section, or unless a different meaning of a word or term is clear from the context, the definition of words or terms in this Part <u>are shall be</u> the same as that applied to the same words or terms in the Illinois Environmental Protection Act [415 ILCS 5].

"Act" means the Illinois Environmental Protection Act [415 ILCS 5].

"Agency" means the Illinois Environmental Protection Agency.

"Curie" or "Ci" means the quantity of radioactive material <u>that produces producing</u> 37 billion nuclear transformations per second.

"Groundwater" means underground water <u>whichthat</u> occurs within the saturated zone and geologic materials where the fluid pressure in the pore space is equal to or greater than atmospheric pressure. [415 ILCS 5/3.2103.64]

"IEMA" means the Illinois Emergency Management Agency, <u>Division of Nuclear Safety</u>.

"L" means liter.

"Licensee" means the holder of a license issued for a nuclear power plant under <u>10</u> CFR chapter I of title 10 of the Code of Federal Regulations.

"<u>Licensee-controlled</u> Licensee controlled area" means the land or property that is owned, leased, or otherwise controlled by the licensee.

"Picocurie" or "pCi" means the quantity of radioactive material <u>that produces producing</u> 2.22 nuclear transformations per minute. One pCi is one trillionth  $(10^{-12})$  of one curie.

"Person" is any individual, partnership, co-partnership, firm, company, limited liability company, corporation, association, joint stock company, trust, estate, political subdivision, State agency, or any other legal entity, or their legal representative, agent, or assigns. [415 ILCS 5/3.315]

"<u>Station-generated</u> <u>Station generated</u> liquids" means liquids used in, or as a part of, the power generation process at a nuclear power plant <del>and</del> that contain, or potentially could contain, radionuclides.

#### POLLUTION CONTROL BOARD

#### NOTICE OF ADOPTED AMENDMENTS

"Surface water" means all water that is open to the atmosphere and subject to surface runoff.

"Unpermitted release of a radionuclide" means any spilling, leaking, emitting, discharging, escaping, leaching, or disposing of a radionuclide into groundwater, surface water, or soil that is not permitted under State or federal law or regulation. [415 ILCS 5/13.6(c)]. "Unpermitted release of a radionuclide" does not include the discharge of a radionuclide from a point source at a designated process water or cooling water outfall identified in the nuclear power plant's National Pollutant Discharge Elimination System permit, ifprovided the discharge is authorized in the nuclear power plant's United States Nuclear Regulatory Commission operating license.

(Source: Amended at 47 Ill. Reg., effective	(Source:	Amended at 4'	7 Ill. Reg.	, effective	,
---	----------	---------------	-------------	-------------	---

## Section 1010.108 Severability

If any provision in this Part or its application to any person or under any circumstances is adjudged invalid, <u>thatsuch</u> adjudication <u>willshall</u> not affect the validity of this Part as a whole or of any portion not adjudged invalid.

Source: Amended at 47 Ill. Reg, effective	_`	)
---	----	---

### SUBPART B: REPORTING

### Section 1010.200 Evaluation of Releases

Within 24 hours after an unpermitted release of a radionuclide from a nuclear power plant into groundwater, surface water, or soil, the licensee must evaluate the release in <u>complianceaecordance</u> with this Section to determine whether it must be reported. The <u>evaluation cannot take into account remedial actions taken in response to the release (i.e., the</u> evaluation must be based on the volumes of <u>station-generated station generated</u> liquids and concentrations or quantities of radionuclides released, not on the volumes of <u>station-generated station generated</u> liquids and concentrations or quantities of radionuclides remaining after the initiation or completion of response actions). <u>The If the release is required to be reported, the licensee must report the release in <u>complianceaecordance</u> with Section 1010.202 <u>if the unpermitted release of station-generated liquids either results of this Part. a) Licensees must report unpermitted releases of station generated liquids that result in tritium concentrations of 200 pCi/L or more outside <u>of</u> the licensee-controlled licensee controlled area or contains. b)</u></u>

#### POLLUTION CONTROL BOARD

#### NOTICE OF ADOPTED AMENDMENTS

Licensees must report unpermitted releases of station generated liquids that contain	tritium at
quantities of 0.002 <u>curies</u> or more.	

(Source: Amended at 47 Ill. Reg. , effective )

## **Section 1010.202 Reporting of Releases**

- a) Reports required <u>byunder</u> Section 1010.200 must be <u>madegiven</u> within 24 hours after the release to both the Agency and IEMA in <u>compliance</u> with the following:
  - 1) Reports to the Agency must be <u>madegiven</u> by telephone and electronically. The Agency's telephone number for reporting environmental emergencies is 1-217-782-3637.
  - 2) Reports to IEMA must be <u>madegiven</u> by telephone and electronically. IEMA's telephone number for reporting emergencies is 1-800-782-7860, or, if calling from outside Illinois, 1-217-782-7860.
  - 3) Electronic reports must be submitted on forms and in a format prescribed by the Agency, and must be submitted to addresses prescribed by the Agency and IEMA. The Agency <u>mustshall</u> consult with IEMA in developing the forms and format for electronic reports required under this Section.
- b) Reporting Reports required byunder Section 1010.200 must include, at a minimum, the following information using the best data available at the time of the report:
  - 1) The name and address of the nuclear power plant where the release occurred;
  - The name, signature (in electronic reports), and telephone number of the principal executive officer Principal Executive Officer for the nuclear power plant or the principal executive officer's Principal Executive Officer's authorized agent;
  - 3) The specific location of the release;
  - 4) The time and duration of the release;

#### POLLUTION CONTROL BOARD

#### NOTICE OF ADOPTED AMENDMENTS

- 5) An estimate of the volume and radionuclide concentrations (in pCi/L) of <u>station-generated</u> station generated liquids released, and an estimate of the flow rate if the release is ongoing;
- 6) Identification of the radionuclides released and an estimate of the quantities released (in <u>curiesCuries</u>);
- 7) Whether the release was to groundwater, surface water, or soil, and a description of the area into which the release occurred (e.g., field, ditch, stream, or other description) and the size of the area affected;
- 8) The actions taken to respond to, contain, and mitigate the release;
- 9) The known and anticipated impacts to human health and the environment, including but not limited to groundwater and surface water resources, due toas a result of the release;
- 10) The names, addresses, and telephone numbers of persons at the nuclear power plant who may be contacted for further information regarding the release; and
- 11) The name and mailing address of the licensee of the nuclear power plant.
- c) The Agency must post copies of the electronic reports it receives under this Section on the Agency's website.

Source: Amended at 47 Ill. Reg.	, effective
---------------------------------	-------------

### Section 1010.204 Follow-up Written Report

A licensee An owner or operator who reports a release under this Part must provide to the Agency and to IEMA a follow-up written report of the release within five business days after reporting the release.

a) The follow-up report must confirm and update the information provided by the licensee under Section 1010.202 utilizing the best data available and must also include the following information:

#### POLLUTION CONTROL BOARD

#### NOTICE OF ADOPTED AMENDMENTS

- 1) Copies of all lab analyses used to confirm the presence of, or conducted in response to, the release if lab analyses have been conducted;
- Plan view and, if available, geological cross-section maps showing, at a minimum, the location of the release, the locations of samples taken to confirm the release if samples have been taken, the locations of samples taken in response to the release if samples have been taken, the measured and modeled extents of the release if known, the groundwater flow direction if known, groundwater contours if known, the boundary of the licensee controlled area, and structures, roads, and other surface features;
- 3) An estimate of the volume and radionuclide concentrations (in pCi/L) of station generated liquids released but not recovered;
- 4) An estimate of the quantities (in <u>curies</u>Curies) of radionuclides released but not recovered;
- 5) An updated description of activities taken in response to the release;
- 6) If additional activities in response to the release are planned, a description of those activities; and
- 7) The name and signature of the <u>principal executive officerPrincipal</u>

  <u>Executive Officer</u> for the nuclear power plant or the <u>principal executive</u>

  <u>officer'sPrincipal Executive Officer's</u> authorized agent.
- b) The follow-up report must be submitted electronically on forms and in a format prescribed by the Agency and must be submitted to addresses prescribed by the Agency and IEMA. Within five business days after submission of the electronic follow-up report, hard copies of the follow-up report must be submitted to the Agency and IEMA at the following addresses:

Illinois Environmental Protection Agency Bureau of Water Groundwater Section 1021 North Grand Avenue East P.O. Box 19276 Springfield, ILH 62794-9276

Illinois Emergency Management Agency

## POLLUTION CONTROL BOARD

## NOTICE OF ADOPTED AMENDMENTS

Division of Nuclear Safety

Bureau of Environmental Safety

1035 Outer Park Drive

Springfield, ILH 62704

c) The Agency <u>mustshall</u> consult with IEMA in developing the forms and format for reports required under this Section.
 d)e) The Agency must post copies of the follow-up reports it receives under this Section on the Agency's website.
 (Source: Amended at 47 Ill. Reg. \_\_\_\_\_\_, effective \_\_\_\_\_\_)