

BEFORE THE ILLINOIS POLLUTION CONTROL BOARD

IN THE MATTER OF:)	
)	R 23-18(A)
AMENDMENTS TO 35 ILL. ADM. CODE)	
201, 202, AND 212)	(Rulemaking – Air)
)	
)	

NOTICE OF FILING

To: Attached Service List

PLEASE TAKE NOTICE that on this day, the 15th day of March, 2024, I caused to be filed with the Clerk of the Illinois Pollution Control Board **Second Pre-filed Testimony of Bryan Higgins** and a **Certificate of Service**, a true and correct copy of which is attached hereto and hereby served upon you.

/s/ Alexander Garel-Frantzen

David M. Loring
Alexander J. Garel-Frantzen
ARENTFOX SCHIFF LLP
233 South Wacker Drive, Suite 7100
Chicago, Illinois 60606
(312) 258-5521
David.Loring@afslaw.com
Alex.Garel-Frantzen@afslaw.com

SERVICE LIST

Illinois Pollution Control Board Don Brown don.brown@illinois.gov 100 W. Randolph St., Suite 11-500 Chicago, IL 60601 Timothy Fox Tim.fox@illinois.gov Chloe Salk Chloe.salk@illinois.gov 60 East Van Buren Street, Ste. 630 Chicago, IL 60605	Illinois Environmental Protection Agency Dana Vetterhoffer dana.vetterhoffer@illinois.gov Gina Roccaforte Gina.Roccaforte@illinois.gov 1021 North Grand Avenue East P.O. Box 19276 Springfield, IL 62794
Office of the Attorney General Jason James Jason.James@ilag.gov 201 West Point Drive, Suite 7 Belleville, IL 62226 Molly Kordas molly.kordas@ilag.gov Ann Marie A. Hanohano annmarie.hanohano@ilag.gov 69 West Washington Street, Suite 1800 Chicago, IL 60602	Illinois Department of Natural Resources Renee Snow - General Counsel renee.snow@illinois.gov One Natural Resources Way Springfield, IL 62702
U.S. EPA - Region 5 Michael Leslie leslie.michael@epa.gov Ralph H. Metcalfe Federal Building 77 West Jackson Blvd. Chicago, IL 60604	HeplerBroom LLC Melissa S. Brown Melissa.brown@heplerbroom.com Alec Messina Alec.Messina@heplerbroom.com 4340 Acer Grove Drive Springfield, IL 62711
Faith E. Bugel fbugel@gmail.com 1004 Mohawk Rd. Wilmette, IL 60091	Environmental Law and Policy Center David McEllis dmcellis@elpc.org 35 E. Wacker Drive, Suite 1600 Chicago, IL 60601
Greater Chicago Legal Clinic, Inc. Keith I. Harley kharley@kentlaw.edu 211 West Wacker Drive, Suite 750 Chicago, IL 60606	McDermott, Will & Emery Mark A. Bilut mbilut@mwe.com 227 West Monroe Street Chicago, IL 60606-5096
IERG Kelly Thompson	Dynegy Joshua R. More

kthompson@ierg.org 215 E. Adams St. Springfield, IL 62701	Joshua.More@afslaw.com Sam Rasche Sam.Rasche@afslaw.com 233 South Wacker Drive, Suite 7100 Chicago, IL 60606 Andrew N. Sawula Andrew.Sawula@afslaw.com One Westminster Place, Suite 200 Lake Forest, IL 60045
East Dubuque Nitrogen Fertilizers, LLC Byron F. Taylor Bftaylor@sidley.com John M. Heyde jheyde@sidley.com One South Dearborn Chicago, Illinois 60603	

BEFORE THE ILLINOIS POLLUTION CONTROL BOARD

IN THE MATTER OF:)	
)	R 23-18(A)
AMENDMENTS TO 35 ILL. ADM. CODE)	
201, 202, AND 212)	(Rulemaking – Air)
)	
)	

SECOND PRE-FILED TESTIMONY OF BRYAN HIGGINS

I. Introduction

My name is Bryan Higgins of Trinity Consultants (“Trinity”), and I am presenting testimony in this matter on behalf of Rain CII Carbon LLC (“Rain Carbon”) in support of the Supplemental Technical Support Document (“Supplemental TSD”) prepared with my colleague, Jeremias Szust. I am a Senior Consultant at Trinity and an expert in providing environmental compliance and permitting support to a variety of industries, and have worked extensively with Rain Carbon’s coke calcining facility located at 12817 East 950th Avenue in Robinson, Illinois (the “Facility”). I previously submitted pre-filed testimony in this matter on September 5, 2023, and I testified at the First Hearing on September 27, 2023.

This supplemental testimony is being submitted in support of Rain Carbon’s revised proposed amendments to the Illinois Administrative Code to provide alternative emission limits and standards (“AELs”) applicable to the Facility’s coke calcining kilns during periods of start-up, malfunction, and breakdown (“SMB”) (the “Revised Proposed AELs”). The Revised Proposed AELs are narrowly tailored and provide AELs for particulate matter (“PM”) during SMB and AELs for opacity and for volatile organic materials (“VOM”) during periods of start-up. As demonstrated in the Supplemental TSD, Rain Carbon’s Revised Proposed AELs will not result in a degradation in air quality and will not otherwise impact Illinois EPA’s Section 110(l) demonstration under the Clean Air Act (the “CAA”).

The Supplemental TSD submitted in conjunction with this testimony as **Exhibit 1** provides a detailed discussion of the air quality modeling and analysis used to demonstrate that Rain Carbon's Revised Proposed AELs will have an insignificant impact on air quality.

Following Illinois EPA's review of the initial TSD, I participated in a number of meetings and discussions with Illinois EPA on behalf of Rain Carbon to address concerns raised by Illinois EPA regarding the modeling inputs for PM and VOM, and to discuss additional modeling methodologies to satisfy the requirements of Section 110(l) of the CAA. The following testimony provides an overview of the *changes and additions* to the PM and VOM modeling¹ that are reflected in the Supplemental TSD:

1. First, with respect to VOM, the Method 25A test results from the July 2023 engineering study were converted from 'as propane' to 'as carbon' to represent the worst-case potential VOM emission rate from the kilns during start-up. This approach served to significantly increase the annualized VOM emission rate used to compare the worst-case VOM emissions during start-up to the Modeled Emission Rates for Precursors (MERPs) for the secondary formation of ozone from precursor pollutants (in this case, VOM).
2. As was the result in the initial TSD, the more conservative annualized VOM emission rate utilized in the Supplemental TSD continues to demonstrate that the potential contribution to ozone from VOM emissions from Rain Carbon's kilns during start-up is orders of magnitude less than what constitutes a significant contribution. Therefore, the modeling confirms that Rain Carbon's Revised Proposed AEL for VOM that allows for a 12-hour averaging period

¹ Note: No changes to Section 2 of the Supplemental TSD discussing opacity were made, other than to provide additional justification for the averaging period proposed in Rain Carbon's original AEL for opacity.

for VOM emissions during start-up will not interfere with the Ozone NAAQS in accordance with Section 110(l) of the CAA.

3. Second, with respect to PM, a number of changes were made to the model inputs and modeling approach to ensure that worst-case impacts from the generation of PM emissions during SMB events were fully and accurately modeled. Additional PM emissions data was generated from the July 2023 engineering study by using a third-order polynomial curve to derive maximum PM emissions from approximately 1,300°F to 1,800°F, which was not collected during the study. This resulted in a conservative interpolated maximum PM emission rate for use in the model that reflects the entire range of pyroscrubber inlet temperatures experienced during SMB events.
4. In addition, EPA AP-42 particle size distribution factors were used to speciate the PM emissions data from the July 2023 engineering study into PM₁₀ and PM_{2.5} maximum emission rates. The speciated emissions rates were utilized in the model to compare against the corresponding significant impact levels (“SILs”) for PM₁₀ NAAQS and PM_{2.5} NAAQS. This had the effect of creating a model that more accurately represented the maximum concentration of PM₁₀ and PM_{2.5} emissions during SMB events.
5. Further, an alternative approach was utilized in the model to appropriately and accurately account for the intermittent and unpredictable nature of SMB events. Based upon an EPA-approved methodology used to model start-up and shutdown events for the 1-hour Nitrogen Dioxide NAAQS, an average hourly rate approach was used to adjust the maximum hourly PM₁₀ and PM_{2.5} emission rates based on the frequency that those hours will occur during a calendar year. As detailed in Rain Carbon’s Supplemental Response to Illinois EPA’s Comments (submitted concurrently with this Supplemental TSD), Rain Carbon set forth a

Revised Proposed AEL for PM that limits maximum PM emissions to 300 hours per kiln per year during SMB. Therefore, the maximum hourly PM₁₀ and PM_{2.5} emission rates were adjusted downward to reflect this limitation while allowing the model to assess the impact of such rates across all meteorological conditions (*i.e.*, every hour over the course of five calendar years). The resulting model avoids modeled impacts that are unrealistically high compared to actual impacts realistically expected for SMB events.

6. Lastly, to add additional conservativeness to the PM modeling, the modeling was run with only the SMB PM₁₀ and PM_{2.5} emission rates. Baseline emission rates (*i.e.*, emissions generated during non-SMB operations) were excluded from consideration in evaluating the modeled impact of SMB events.
7. As was the result under the initial TSD, the supplemental PM modeling results presented in the Supplemental TSD continue to model impacts far-below the respective SILs for the PM₁₀ 24-hour NAAQS, the PM_{2.5} 24-hour NAAQS, and the PM_{2.5} Annual NAAQS. Consequently, the modeling demonstrates that the Proposed Revised AEL for PM will not interfere with the applicable NAAQS in accordance with Section 110(l) of the CAA.

Dated: March 15, 2024

EXHIBIT 1

SUPPLEMENTAL TECHNICAL SUPPORT DOCUMENT



Rain CII Carbon LLC – Robinson Plant

Prepared By:

Bryan Higgins – Senior Consultant
Jeremias Szust – Managing Consultant

TRINITY CONSULTANTS

16252 Westwoods Business Park
Ellisville, MO 63021
(636) 530 - 4600

March 15, 2024



TABLE OF CONTENTS

1. INTRODUCTION	1-1
2. OPACITY	2-1
3. VOLATILE ORGANIC MATTER	3-1
3.1 Engineering Study.....	3-1
3.2 Extrapolated Emission Rate	3-2
3.3 Modeled Emission Rates for Precursors	3-3
3.4 MERPs View Qlik and Hypothetical Source Selection.....	3-4
3.5 Assessment Approach and Results.....	3-5
4. PARTICULATE MATTER	4-1
4.1 Engineering Study.....	4-1
4.2 Correlation and Interpolated Emission Rate	4-2
4.2.1 Emission Rates for Modeling.....	4-3
4.3 Air Dispersion Modeling	4-4
4.3.1 Dispersion Modeling Selection	4-4
4.3.2 Source Characterization	4-5
4.3.3 Building Downwash	4-5
4.3.4 Coordinate System	4-7
4.3.5 Receptor Grid	4-7
4.3.6 Terrain Elevations	4-9
4.3.7 Meteorological Data.....	4-9
4.3.8 Representation of Emission Sources.....	4-10
4.3.9 Results.....	4-10
APPENDIX A. AIRSOURCE STACK TESTING REPORT	A-1

LIST OF FIGURES

Figure 3-1. THC & Temperature Correlation (as propane)	3-2
Figure 3-2. THC & Temperature Correlation (as carbon)	3-3
Figure 3-3. MERPs View Qlik Hypothetical Sources Near Robinson, IL	3-4
Figure 4-1. PM & Temperature Correlation	4-2
Figure 4-2. General Model Overview	4-6
Figure 4-3. Receptor Grid and Boundaries	4-8
Figure 4-4. PM ₁₀ 24-Hour Modeling Results Compared to NAAQS	4-11
Figure 4-5. PM ₁₀ 24-Hour Modeling Results Compared to SIL	4-12
Figure 4-6. PM _{2.5} 24-Hour Modeling Results Compared to NAAQS	4-12
Figure 4-7. PM _{2.5} 24-Hour Modeling Results Compared to SIL	4-13
Figure 4-8. PM _{2.5} Annual Modeling Results Compared to NAAQS	4-13
Figure 4-9. PM _{2.5} Annual Modeling Results Compared to SIL	4-14

LIST OF TABLES

Table 2-1. Opacity Observation Results	2-1
Table 3-1. VOM Sampling Results	3-1
Table 3-2. 8-Hour Ozone MERPs Data for Boone County, IN	3-5
Table 3-3. 8-Hour Ozone MERPs Data for Christian County, IL	3-5
Table 3-4. 8-Hour Ozone MERPs Data for Dubois County, IN	3-5
Table 3-5. Secondary 8-Hour Ozone MERPs Analysis	3-6
Table 4-1. Particulate Matter Sampling Results	4-1
Table 4-2. Evansville Regional Airport Meteorological Data Valid Hours	4-9
Table 4-3. Release Parameters for Modeled Point Sources	4-10
Table 4-4. Air Dispersion Modeling Results	4-10

1. INTRODUCTION

Trinity Consultants, Inc. (Trinity) is providing this Technical Support Document (TSD) to provide detailed data, analyses, and conclusions supporting the proposed rule R23-18A, as it pertains to Rain CII Carbon LLC (Rain Carbon). Rain Carbon's coke calcining process generates exhaust gases from the heating of green coke in a rotary kiln. The exhaust gases contain volatile organic matter (VOM) and particulate matter (PM) and are routed to a pyroscrubber air pollution control device to reduce the amount of VOM and PM in the exhaust gas before being released to the atmosphere via the stack attached to the pyroscrubber. If the temperature at the inlet to the pyroscrubber is at least 1,800°F (3-hour rolling average¹), then Rain Carbon's kilns are able to comply with the applicable opacity, VOM, and PM limitations. There are instances during which it is not possible to maintain this temperature including start-up, malfunction, and breakdown (SMB). When the temperature falls below 1,800°F, the probability of achieving compliance with the applicable emission limits decreases.

In R23-18A, Rain Carbon is proposing emission standards for opacity, VOM, and PM applicable to the two kilns at Rain Carbon's facility during certain periods of SMB. Rain Carbon engaged Trinity to conduct modeling analyses to demonstrate that the potential impact of the proposed emission standards is insignificant and, therefore, would not interfere with the PM and ozone National Ambient Air Quality Standards (NAAQS)² in accordance with Section 110(l) of the Clean Air Act (42 U.S.C. § 7410(l)).

This TSD provides the details about the collection of emissions data from in-stack sampling, air dispersion modeling, and results analysis which demonstrates that the potential impacts on the environment related to each of the proposed rulemakings is insignificant. Note that this TSD is supplementing the original TSD which was filed with the Illinois Pollution Control Board (IPCB) on September 5, 2023. While Rain Carbon believes that the original TSD sufficiently demonstrated non-interference with the affected NAAQS, this TSD presents additional analyses for PM and VOM which provide supplemental demonstrations of non-interference with the affected NAAQS.

¹ When the pyroscrubber inlet temperature of 1,800°F is referenced throughout this document, it is based on a 3-hour rolling average.

² Rain Carbon's Facility is located in Crawford County, Illinois. Crawford County is in attainment with the 2015 8-hour ozone NAAQS. Similarly, Crawford County is in attainment of the 2012 PM NAAQS (including the annual PM_{2.5} standard, the 1997 24-hour PM_{2.5} standard and the 2006 24-hour PM₁₀ standard).

2. OPACITY

For opacity, Rain Carbon has proposed a standard alternative to the standards in 35 Ill. Adm. Code 212.123 in the proposed rulemaking R23-18A. The current rule requires opacity to remain below 30% with an exception for short periods of higher opacity with specific restrictions. During normal operations³, Rain Carbon can maintain compliance with this limitation; however, during a kiln start-up, Rain Carbon is unable to consistently maintain compliance with this standard. Therefore, Rain Carbon is proposing to allow for up to three (3) hours during a kiln start-up for averaging opacity observation results. The analysis below demonstrates that the opacity observed during a kiln start-up may be relatively high during the beginning of a start-up but quickly dissipates.

On July 20, 2023, Rain Carbon contracted AirSource Technologies, Inc. (AirSource) to execute an engineering study during a single start-up of one of its two coke calcining kilns (Kiln 1) in order to obtain emissions data for VOM, opacity, and PM during start-up.

For opacity, AirSource conducted observations in accordance with USEPA Method 9 (40 C.F.R. 60, Appendix A-4). AirSource observed and recorded the opacity during five (5) separate 1-hour periods⁴ during a single start-up event. Results from the observations are summarized in Table 2-1 below.

Table 2-1. Opacity Observation Results

Parameter	Run 1	Run 2	Run 3	Run 4	Run 5	Average
Start/Stop Time	9:45-10:45	12:11-13:11	13:44-14:37	16:15-17:15	17:47-18:47	-
Maximum Opacity (%)	50	5	5	0	0	-
Average Opacity (%)	13.90	2.71	0.60	0.00	0.00	3.44

Detailed field data sheets have been provided in Appendix A of this TSD (See Appendix C-3 of the AirSource report). During a typical start-up, once Rain Carbon begins to introduce feed coke into the kiln, opacity tends to be in excess of the current standard under 35 Ill. Adm. Code 212.123. For example, during the start-up performed on July 20, 2023, the maximum opacity reading was recorded at 50% and above 30% for more than 8-minutes in a 60-minute period.

During the first run of Method 9 observations performed on July 20, 2023, the inlet temperature to the pyroscrubber was approximately 700°F. Introduction of green coke into a kiln may begin at a pyroscrubber inlet temperature as low as 400°F. The results from the July 20, 2023, testing indicate that the relationship between pyroscrubber inlet temperature and opacity is such that higher opacity occurs at lower temperatures. Therefore, at the minimum pyroscrubber inlet temperature at which green coke can be introduced into a kiln, it can be expected that opacity would be higher than the results from Run 1 of the July 20, 2023, testing and span a longer period of time.

³ "Normal operations" refers to the kilns and associated equipment operating, but not in an SMB event.

⁴ Run 3 had a 53-minute duration. The observed opacity for 40 minutes preceding the end of Run 3 was zero, and the observed opacity following Run 3 was zero for 120 minutes.

3. VOLATILE ORGANIC MATTER

In the proposed rulemaking R23-18A, Rain Carbon has proposed an alternative emission standard which would allow Rain Carbon to demonstrate compliance with the existing 8 lbs/hr VOM limit (35 Ill. Adm. Code 215.301) as an average over 12 hours during kiln start-ups. The analysis below demonstrates that allowing Rain Carbon to operate under the proposed alternative standard would have an insignificant impact to the ozone NAAQS.

3.1 Engineering Study

In addition to observing opacity during the start-up of Kiln 1 that was performed on July 20, 2023, AirSource collected stack samples to obtain VOM emission rates. AirSource utilized USEPA Method 25A (40 CFR 60, Appendix A-7) to determine the concentration of total hydrocarbons (THC) in the stack gas stream during the Kiln 1 start-up. The mass emission rates during each run were calculated by AirSource and are presented in Table 3-1 below.

Table 3-1. VOM Sampling Results

Parameter	Run 1	Run 2	Run 3	Run 4	Run 5	Average
Gas Time Period	9:45-10:30	12:47-13:32	13:45-14:30	16:46-17:31	17:45-18:30	-
Flow Time Period	9:44-10:49	12:11-13:10	13:44-14:37	16:15-17:17	17:47-18:50	-
Emission Rate (lbs/hr) (‘as propane’)	2.41	0.482	0.419	0.400	0.300	0.80
Emission Rate (lbs/hr) (‘as carbon’)	7.23	1.446	1.257	1.2	0.9	2.41

The allowable VOM emission rate pursuant to 35 Ill. Adm. Code 215.301 is 8 lbs/hr. Start-up events are inherently variable. While the start-up performed on July 20, 2023, generated emission rates that are below the regulatory limit, was procedurally representative of a typical start-up, and samples were collected based on USEPA methodology, a different set of sampling data could be collected during subsequent start-ups producing different results.

Similar to opacity measurements, the test results presented in Table 3-1 indicate that the VOM emission rate trends higher at lower pyroscrubber inlet temperatures. Since the pyroscrubber inlet temperature during Run 1 was nearly 700°F, and Rain Carbon can begin introducing green coke at a temperature as low as 400°F, it is expected that the maximum VOM emission rate from a kiln in start-up would be higher at lower temperatures, and therefore higher than the results from the July 20, 2023, stack testing.

The Method 25A testing conducted in July 2023 quantified the results “as propane”, which is a common basis for quantifying results from this test method and is appropriate for determining VOC emission rates particularly when the source being sampled is of unknown composition. However, there are other options for expressing the results, including on an “as carbon” or “as methane” basis. Since Method 25A utilizes a flame ionization detector (FID) to count carbon atoms, and because a propane molecule contains three (3) carbon atoms, the results vary by a factor of three if you compare results on an “as propane” versus “as carbon” basis. This means that “as propane” results can be multiplied by three to be converted to “as


carbon” results⁵. Further, the measured concentrations are also attributed to the calibration gas utilized for the testing (e.g., propane calibration gas generates results “as propane”). Propane is the most typical calibration gas used for Method 25A sampling, is readily and commercially available in various concentration ranges and a number of Federal NESHAP standards have a THC standard defined on an “as propane” basis. Converting the test results to an “as carbon” basis represents the upper-end of the potential VOM emission rate from the kilns during start-up.

Note that the table presents a “Gas Time Period” and a “Flow Time Period”. The gas time period represents the start/stop time of the sample gas collection for measuring VOM. This alone cannot be used to determine a mass emission rate of VOM, only a concentration. Stack flow data is needed to calculate emissions on a mass-basis, but stack flow data was not collected in sync with the VOM sampling start/stop time because this was instead being collected as part of the Method 5 testing. Since the sampling for both VOM and PM had similar start/stop times in the context of an entire kiln start-up period, the stack gas flow information collected during the PM sampling was used by AirSource to calculate the mass emission rates presented in Table 3-1.


3.2 Extrapolated Emission Rate

Based on the results presented in Table 3-1, an exponential decay relationship between pyroscrubber inlet temperature and VOM emissions can be derived. Figure 3-1 shows the exponential relationship curve, function, and coefficient of determination (R^2) for the results on an “as propane” basis. Figure 3-2 shows the same on an “as carbon” basis.

Figure 3-1. THC & Temperature Correlation (as propane)



⁵ Frequently Asked Questions (FAQs) for Method 25A (10/01/2020)
https://www.epa.gov/sites/default/files/2016-08/documents/method25a_faq.pdf

Figure 3-2. THC & Temperature Correlation (as carbon)

Each correlation plot has been extrapolated past the lowest temperature from the July sampling results (700°F) to show the approximate THC emissions which could have been emitted if the kiln had started operation at 400°F, which is the minimum temperature at which green coke may be introduced to the kiln. At 400°F, the THC emissions on an “as propane” basis could be emitted at a rate of nearly 5 lbs/hr and the “as carbon” THC emission rate can reach nearly 15 lbs/hr. Calculating the precise emission rate at 400°F using the correlations results in 4.82 lbs/hr and 14.47 lbs/hr, respectively.

3.3 Modeled Emission Rates for Precursors

Modeled Emission Rates for Precursors (MERPs) can be used to analyze the impacts of secondary formation of ozone from precursor pollutants, in this case VOM. The USEPA used complex photochemical modeling to model hundreds of hypothetical emission points across the United States. Each hypothetical emission point is characterized by a stack height, annual emission rate, and additional factors unique to each specific geographic area. The results from each of the hypothetical models have been provided by the USEPA as a reference for determining impacts from existing or proposed emission points as a function of annual emission rate(s).

The VOM MERPs represent a level of increased precursor emissions that are not expected to contribute significantly to ozone formation. For this analysis, Trinity utilized the USEPA's MERPs guidance document⁶ to estimate the level of emissions that would have a significant impact on ozone concentrations. These emissions levels are compared to emission rates from the start-up emission rates (annualized) for purposes


⁶ “Guidance on the Development of Modeled Emission Rates for Precursors (MERPs) as a Tier 1 Demonstration Tool for Ozone and PM_{2.5} under the PSD Permitting Program,” USEPA, April 30, 2019.

of demonstrating that allowing Rain Carbon to operate during start-up will not have a significant impact on ozone concentrations⁷.

3.4 MERPs View Qlik and Hypothetical Source Selection

To determine the appropriate MERP values for comparison, a hypothetical source must be selected from USEPA's MERPs View Qlik website⁸. Considering geographical proximity to the Rain Carbon Robinson facility, the three closest hypothetical sources available in the View Qlik website include Christian County, IL, Boone County, IN, and Dubois County, IN, as shown in Figure 3-3 below.

Figure 3-3. MERPs View Qlik Hypothetical Sources Near Robinson, IL



⁷ Note that for this assessment, Trinity considers only VOM to be a potential contributor to increased ozone impacts while recognizing that, in general, nitrogen oxides (NO_x) can have an impact on ozone formation too. During start-up, VOM has potential to have increased emissions, relative to normal operations due to reduced control; however, NO_x are believed to be emitted at a lower rate during start-up, relative to normal operation. Additionally, Rain Carbon is not subject to NO_x emission standards; thus, it is not seeking any alternative standard for NO_x. Refer to Zhu, B.; Shang, B.; Guo, X.; Wu, C.; Chen, X.; Zhao, L. *Study on Combustion Characteristics and NO_x Formation in 600 MW Coal-Fired Boiler Based on Numerical Simulation. Energies* 2022 for additional information regarding NO_x emissions from combustion units.

⁸ <https://www.epa.gov/scram/merps-view-qlik>

The MERPs data is shown in tables below for each of the three locations.

Table 3-2. 8-Hour Ozone MERPs Data for Boone County, IN

Precursor	Emissions (tpy)	Stack (m)	MERP (tpy)
VOC	500	10	2,985

Table 3-3. 8-Hour Ozone MERPs Data for Christian County, IL

Precursor	Emissions (tpy)	Stack (m)	MERP (tpy)
VOC	500	10	7,222

Table 3-4. 8-Hour Ozone MERPs Data for Dubois County, IN

Precursor	Emissions (tpy)	Stack (m)	MERP (tpy)
VOC	500	10	5,424

Based on the tables shown above, the MERP value for the Boone County hypothetical source was the lowest; therefore, it has the highest sensitivity to ozone impacts from VOM⁹ contribution, so it has been selected as the appropriate source location for this analysis. The EPA MERPs ViewQlik website provides a variety of model combinations with different stack heights and emission rates for each location. The stack heights relevant to this project are 45.72 m, so a stack height of 10 m was chosen as a conservative estimate¹⁰.

3.5 Assessment Approach and Results

Consistent with the USEPA's guidance, the following equation is used to calculate the MERP for VOM.

Equation 3-1. MERP Calculation

$$MERP = \text{Critical Air Quality Threshold} \times \left(\frac{\text{Modeled Emission Rate from Hypothetical Source}}{\text{Modeled Air Quality Impact from Hypothetical Source}} \right)$$

Based on USEPA's July 29, 2022, Guidance for Ozone and Fine Particulate Matter Permit Modeling, the significant impact limit (SIL) is 1 ppb for 8-hr Ozone. To calculate the secondary impact of VOM on Ozone, the maximum hourly VOM emission rate derived in Section 3.2 ("as carbon" basis) was annualized, assuming 8,760 hours of operation per kiln per year. This represents a worst-case annual emissions rate for both kilns, which assumes that both kilns operate at the start-up emission rate for every hour of an entire year. That annualized emission rate is calculated as follows:

⁹ Note that USEPA uses the term volatile organic compounds, or VOC, rather than VOM. For purposes of this demonstration, VOM and VOC are interchangeable.

¹⁰ Throughout this TSD, "conservative" is used as a term to indicate that a variable(s) was defined so that it ultimately contributes to a higher modeled concentration for the respective pollutant. Actual typical results are expected to be lower.

Equation 3-2. Annualized VOM Emissions Rate for MERPs

$$ER_{tpy} = \frac{VOM \frac{lb}{hr} * 8,760 \frac{hours}{year} * 2 Kilns}{2000 \frac{lb}{ton}}$$

Using the above equation, ER_{tpy} is equal to 126.76 tons per year.

This unrealistically high annualized emissions rate can be compared to the Boone VOM MERPs using the following equation to derive the expected secondary impacts from the additional VOM emissions:

Equation 3-3. Calculation of Secondary Formation Impacts

$$Ozone\ Secondary\ Impact_{ppb} = \frac{ER_{tpy}}{MERPs_{tpy}} * SIL_{ppb}$$

The secondary contribution is therefore expected to be below the Ozone SIL of 1 ppb based on the values presented in Table 3-5.

Table 3-5. Secondary 8-Hour Ozone MERPs Analysis

MERP (tpy)	SIL (ppb)	ER_{tpy}	Secondary Contribution (ppb)
2,985	1	126.76	0.043

As shown in Table 3-5, the potential contribution to ozone from VOM emissions from Rain Carbon's kilns during start-up is orders of magnitude less than what constitutes a significant contribution.

4. PARTICULATE MATTER

Rain Carbon's kilns are subject to the Process Weight Rate (PWR) rule established in 35 Ill. Adm. Code 212.322. This rule sets limits on PM based on equations that are dependent upon the process rate of an effected unit. When Rain Carbon's pyroscrubbers are not operating at a temperature greater than or equal to 1,800°F (during SMB events), the chances of achieving compliance with the limitation calculated in accordance with the PWR rule decrease. In the R23-18A rulemaking, Rain Carbon has proposed an allowance of 300 hours per year per kiln to operate during periods when the pyroscrubber inlet temperature is below 1,800°F and a SMB event is occurring. The analysis in this Section demonstrates that approving the proposed alternative standard for PM will not result in a significant impact to the environment.

4.1 Engineering Study

During the start-up conducted on July 20, 2023, AirSource collected stack gas samples and utilized USEPA Method 5 (40 CFR 60, Appendix A-3) to capture filterable PM. AirSource collected five samples, each over a 48-minute period¹¹. From the sampling, AirSource was able to determine mass emission rates of PM during five periods of the single kiln start-up. Table 4-1 presents the results from the testing performed on July 20, 2023.

Table 4-1. Particulate Matter Sampling Results

Parameter	Run 1	Run 2	Run 3	Run 4	Run 5	Average
Start/Stop Time	9:44-10:49	12:11-13:10	13:44-14:37	16:15-17:17	17:47-18:50	-
Sampling Time (min)	48	48	48	48	48	-
Pyroscrubber Inlet Temperature ^a (°F)	694	1,069	1,125	1,281	1,373	1,086
Filterable PM ^b (lbs/hr)	44.7	32.2	33.1	44.1	51.7	41.2

- Pyroscrubber temperature for individual runs is the average over the duration of the respective run. The average pyroscrubber inlet temperature is calculated as the average of all temperature recordings between the start of Run 1 and the end of Run 5.
- Rain Carbon's Clean Air Act Program Permit (CAAPP) operating permit 95120092, Condition 4.2.2.b.ii.C.I. specifies that Rain Carbon shall conduct a Method 5 test for PM emissions. This is the testing requirement associated with the PWR PM limit in the permit. Consistent with the CAAPP, this analysis considers only the results from EPA Method 5.

At the maximum process weight rate for Kiln 1 (28 T/hr), the maximum allowable PM emission rate determined in accordance with 35 Ill. Adm. Code 212.322 is:

Equation 4-1. Process Weight Rate Maximum Allowable PM Emission Rate

$$E = C + A(P)^B = 0 + 4.10(28)^{0.67} = 38.2 \text{ lb/hr}$$

Three (3) of the sample results presented in Table 4-1 were above 38.2 lbs/hr. The average pyroscrubber inlet temperature during each run was below 1,800°F.


¹¹ The start/stop time on each run indicates a runtime longer than 48 minutes. Sampling occurred for 48 minutes, but the total run time is longer due to the time it takes to move the sampling train to different stack ports to meet the traverse requirements defined in USEPA Method 1.

4.2 Correlation and Interpolated Emission Rate

Plotting the PM emissions results against the corresponding pyroscrubber inlet temperature for each run suggests that a quadratic curve would be the best fitting correlation; however, this would suggest that as temperature increases beyond 1,800°F, the PM emission rate would increase rapidly. Since the pyroscrubber's primary function is to utilize a high temperature environment to destroy PM, this would not be an appropriate correlation to use for extrapolating/interpolating emission results. The dataset can be expanded to facilitate the fitting of a more realistic curve and extrapolation/interpolation can generate more reliable results. Since 1,800°F represents the minimum temperature (at the inlet to the pyroscrubber) for the pyroscrubber to achieve the designed control of PM emissions, the dataset can be expanded by adding a datapoint at 1,800°F and the maximum allowable PM emission rate calculated using Equation 4-1, 38.2 lbs/hr.

Utilizing the expanded dataset, the PM emission sampling results correlate well with pyroscrubber inlet temperature using a third order polynomial with a coefficient of determination (R^2) in excess of 0.97. See Figure 4-1 below.

Figure 4-1. PM & Temperature Correlation



The curve shows a decrease in emissions as the pyroscrubber inlet temperature decreases from approximately 700°F to approximately 950°F, then PM emissions increase until reaching a maximum emission rate of approximately 57 lbs/hr at a temperature of approximately 1,550°F. The precise maximum emission rate can be calculated using the derivative of Equation 4-2 to generate a quadratic equation and then determining the temperature value at which the quadratic equation would equate to zero. The corresponding temperature of the derivative equating to zero is 1,547.0°F. Finally, this temperature value can be entered into Equation 4-2 to determine the corresponding emission rate as follows:

Equation 4-2. PM Correlation Equation

$$y = -2.539849 \times 10^{-7} x^3 + 9.480190 \times 10^{-4} x^2 - 1.109651x + 445.2877$$

Where:

y=PM emission rate (lbs/hr)

x=pyroscrubber inlet temperature (°F)

$$y = -2.539849 \times 10^{-7} * (1547.0)^3 + 9.480190 \times 10^{-4} * (1547.0)^2 - 1.109651 * 1547 + 445.2877$$

$$y = 57.1 \text{ lbs/hr}$$

This interpolated maximum PM emission rate can be used as the basis for a conservatively high emission rate for air dispersion modeling.

Note: The interpolated maximum emission rate is based on emissions testing performed during a kiln start-up. However, Rain Carbon's proposed rule for PM compliance allows for operation during start-up, malfunction, and breakdown. Given the unpredictable nature of malfunction and breakdown events, Rain Carbon cannot sample for emissions during a malfunction or breakdown, nor can it intentionally cause such an event to occur for purposes of a stack test. Emissions during start-up events are, in general, higher than emissions during malfunction and breakdown events for two reasons:

1. Start-up events occur for longer durations than malfunction and breakdown events, on average; and
2. Start-up events can begin at 400°F pyroscrubber inlet temperature and will progress all the way to 1,800°F while malfunction and breakdown events most often begin at temperatures above 1,800°F and decrease until the malfunction or breakdown is resolved, which is often associated with only a portion of the temperature range from 1,800°F down to 400°F.

4.2.1 Emission Rates for Modeling

The emission sources identified in the previous section require emission rates in order for the model to simulate the dispersion. As explained in Section 4.2, the maximum interpolated PM emission rate from the kilns, during an SMB event, is 57.1 lbs/hr.

The stack test conducted on July 20, 2023, did not speciate the results based on particle size which is appropriate for comparing the allowable emission rate determined by the PWR, which regulates PM. However, the NAAQS standards are specific to PM₁₀ and PM_{2.5}, not PM. Accordingly, demonstrating non-interference with the NAAQS requires modeling PM₁₀ and PM_{2.5} emissions impacts specifically. EPA's AP-42 Compilation of Air Emissions Factors from Stationary Sources, Appendix B.2 contains published particle size distributions for general processes and materials and can be used when source-specific distribution information is not available. Table B.2-2 on page B.2-15 provides distribution information for *Category 5: Calcining and Other Heat Reaction Processes*. In this table, PM₁₀ was determined by EPA to comprise 53% of PM and PM_{2.5} was determined to comprise 18% of PM. Applying these factors to the maximum PM emission rate (57.1 lbs/hr):

$$PM_{10} = 57.1 * 53\% = 30.3 \text{ lbs/hr}$$

$$PM_{2.5} = 57.1 * 18\% = 10.3 \text{ lbs/hr}$$

Another factor that the model must account for is how to accurately model the air dispersion impact of intermittent and unpredictable events like start-ups, malfunctions and breakdowns. While the modeled impacts of SMB events should reflect the worst-case conditions, the model should not reflect unrealistic emission scenarios. More specifically, the model must employ a methodology to appropriately account for the fact that a maximum PM emission rate of 57.1 lbs/hr cannot occur at every minute of every hour in a

given year. EPA has issued guidance providing a specific methodology to appropriately model “intermittent scenarios, such as startup/shutdown operations” in order to avoid “modeled impacts being significantly higher than actual impacts would realistically be expected to be for these emission scenarios.”¹² More specifically, EPA offered an average hourly rate approach to model intermittent sources to account for worst-case conditions while appropriately accounting for the reduced probability that emissions will actually be generated from the intermittent source:

“...model impacts from intermittent emissions based on an average hourly rate, rather than the maximum hourly emission. For example, if a proposed permit includes a limit of 500 hours/year or less for an emergency generator, a modeling analysis could be based on assuming continuous operation at the average hourly rate, i.e., the maximum hourly rate times 500/8760. This approach would account for potential worst-case meteorological conditions associated with emergency generator emissions by assuming continuous operation, while use of the average hourly emission represents a simple approach to account for the probability of the emergency generator actually operating for a given hour.”

In the case of Rain Carbon’s SMB events, Rain Carbon is proposing to limit kiln operation during SMB events to 300 hours per year per kiln, or less. The occurrence of these events will be intermittent and largely unpredictable. Therefore, applying EPA’s average hourly rate approach to the modeled emission rate and modeling this emission rate as if every hour of every year modeled could experience that emission episode is an appropriate modeling approach to assess the potential and realistic impacts of SMB events on the ambient air while considering probability in the model. This approach is valid because it accounts for the same mass basis for all potential operating hours (300 hours in this case), while avoiding biasing the results towards high results due to unfavorable meteorological conditions on any one day.

Applying the average hourly rate approach to the PM₁₀ and PM_{2.5} emissions rates produces the following:

$$PM_{10} = 30.3 \frac{lbs}{hr} \times \frac{300}{8760} = 1.04 \frac{lbs}{hr}$$

$$PM_{2.5} = 10.3 \frac{lbs}{hr} \times \frac{300}{8760} = 0.35 \frac{lbs}{hr}$$

4.3 Air Dispersion Modeling

In order to assess whether operating in accordance with the proposed rule will have a significant impact on the ambient air, air dispersion models representing these operating scenarios have been developed and executed using the maximum emission rate calculated in the previous section of this report.

4.3.1 Dispersion Modeling Selection

The current USEPA regulatory model, AERMOD (version 23132) was used as incorporated within Trinity’s BREEZE™ AERMOD Pro software to calculate ground-level concentrations with the regulatory default parameters. Appropriate averaging periods, based on federal and state ambient air quality standards, and model options were considered in the analysis, in conjunction with the following guidance documents:

¹² Memorandum: Additional Clarification Regarding Application of Appendix W Modeling Guidance for the 1-hour NO₂ National Ambient Air Quality Standard
https://www.epa.gov/sites/default/files/2015-07/documents/appwno2_2.pdf

- ▶ USEPA's *Guideline on Air Quality Models* 40 CFR 51, Appendix W (Revised, January 17, 2017)
- ▶ USEPA's *AERMOD Implementation Guide* (Revised June 2022);
- ▶ USEPA's Guidance on Significant Impact Levels for Ozone and Fine Particles in the Prevention of Significant Deterioration Permitting Program (April 17, 2018);
- ▶ USEPA's Guidance for Ozone and Fine Particulate Matter Permit Modeling (July 29, 2022);

4.3.2 Source Characterization

The kilns are the source of PM emissions; however, they route their exhaust gases to pyroscrubbers which reduce the amount of PM emissions before the exhaust gases are released to atmosphere via two individual stacks. Because the pyroscrubber exhaust stacks represent the point when emissions from the kilns are first released to the atmosphere, the stacks are placed into the air dispersion model as point sources where PM dispersion will begin.

The subsections below describe the development and execution of air dispersion models used to derive ambient air impact values that are compared to the SILs.

The recommended SIL values for the particulate matter standards are summarized below:

- ▶ PM_{2.5} 24-hr – 1.2 µg/m³
- ▶ PM_{2.5} Annual¹³ – 0.2 µg/m³
- ▶ PM₁₀ 24-hr – 5 µg/m³

4.3.3 Building Downwash

The purpose of a building downwash analysis is to determine if the plume discharged from a stack will become caught in the turbulent wake of a building (or other structure), resulting in downwash of the plume. The downwash of the plume can result in elevated ground-level concentrations.

The Building Profile Input Program (BPIP) with Plume Rise Model Enhancements (PRIME) (version 04274) was used to determine the building downwash characteristics for each stack in 10-degree directional intervals. The PRIME version of BPIP features enhanced plume dispersion coefficients due to turbulent wake and reduced plume rise caused by a combination of the descending streamlines in the lee of the building and the increased entrainment in the wake. For PRIME downwash analyses, the building downwash data include the following parameters for the dominant building:


- ▶ Building height,
- ▶ Building width,
- ▶ Building length,
- ▶ X-dimension building adjustment, and
- ▶ Y-dimension building adjustment.

Satellite imagery of the facility buildings, as digitized in AERMOD, are included in Figure 4-2 for reference.

¹³ EPA expects to have an updated SIL for the revised primary annual PM_{2.5} NAAQS on or before the effective date of the final NAAQS.

<https://www.federalregister.gov/d/2024-02637/p-1304>

Figure 4-2. General Model Overview



4.3.4 Coordinate System

In all modeling input and output files, the locations of emission sources, structures, and receptors were represented in the UTM coordinate system. The UTM grid divides the world into coordinates that are measured in north meters (measured from the equator) and east meters (measured from the central meridian of a particular zone, which is set at 500 km).

4.3.5 Receptor Grid


Trinity used a variable-density grid in order to determine the extent of the significant impact area (SIA).

- ▶ Property line receptors with spacing of approximately 50 meters
- ▶ 100 meter spacing grid extending approximately 5,000 meters from the facility center
- ▶ 500 meter spacing, from 5,000 meters to approximately 11,500 meters from the facility center

The Facility is surrounded by fencing and has active security measures, such as guard houses, that restrict access to the facility along the property line. The fences and active security measures cause the property line to serve as a boundary between the facility and its ambient air.¹⁴ Consistent with sulfur dioxide (SO₂) Data Requirements Rule (DRR) modeling submitted and approved by USEPA, most recently in 2019, the Marathon Robinson Refinery, which is located directly adjacent to the Facility, was excluded from the receptor grid as it also has fences and active security measures prohibiting public access to its property. The ambient air boundary for the facility can be seen in Figure 4-2 and Figure 4-3, denoted in purple.

¹⁴ https://www.epa.gov/sites/production/files/2019-12/documents/revised_policy_on_exclusions_from_ambient_air.pdf

Figure 4-3. Receptor Grid and Boundaries



4.3.6 Terrain Elevations

The terrain elevation for each receptor point was determined using Elevated Terrain Mode and National Elevation Dataset (NED) data. The data has terrain elevations at approximately 10-meter intervals. In addition, the AERMOD terrain processor, AERMAP (version 18081), was used to compute the hill height scales for each receptor. AERMAP searches all NED data points for the terrain height and location that has the greatest influence on each receptor to determine the hill height scale for that receptor. AERMOD then uses the hill height scale in order to select the correct critical dividing streamline and concentration algorithm for each receptor. The elevations of the sources and buildings involved in the modeling demonstration were set using AERMAP.

Note that the modeling inputs described in the above subsections were established in a USEPA approved SO₂ DRR model and are being used for this modeling effort.

4.3.7 Meteorological Data

The meteorological data used for this modeling demonstration were obtained from the Evansville Regional Airport (KEVV), located in Evansville, IN. The data is pre-processed for AERMOD using AERMET (version 22112) and NOAA data for the years 2018 through 2022. This meteorological data was processed prior to the release of AERMET version 23132 and a complete meteorological dataset for 2023. The model change bulleting for AERMET version 23132 does not indicate substantial changes from version 22112, with most updates relating to minor bug fixes, and the only update to formulation was for the COARE1 subroutine which was not used in the preparation of the meteorological dataset for this analysis. The meteorological data for 2023 also should not differ substantially from the existing 5 years of meteorological data, therefore, the met-data has not been updated for this analysis.

KEVV is located approximately 125 km to the south of the Facility. The Facility is located in rural Illinois, and KEVV is the meteorological station consistent with the USEPA approved SO₂ DRR model. One-minute wind data were processed using the AERMINUTE program and provided as inputs to AERMET. Finally, the regulatory default ADJ_U* option was selected in AERMET in the meteorological data used for this analysis.

As shown in Table 4-2, surface data from the KEVV are much greater than 90% complete (i.e., less than 10% missing) each year. The number of calm and missing hours from KEVV are shown for each year in Table 4-2.

Table 4-2. Evansville Regional Airport Meteorological Data Valid Hours

Year	Number of Calm Hours	Number of Missing Hours	Missing Hours (%)
2018	81	149	1.70%
2019	166	32	0.37%
2020	69	9	0.10%
2021	106	20	0.23%
2022	998	173	1.97%

Based on the high data capture rate and previously being used for the USEPA approved SO₂ DRR model, KEVV data was used in this modeling demonstration. The data station is 122.5 meters above sea level, and that was input as the PROFBASE elevation in AERMOD. The upper air data used in the processing is from the Lincoln National Weather Service office in Lincoln, IL.

4.3.8 Representation of Emission Sources

AERMOD allows for emission units to be represented as point, area, volume, or open pit sources, among other less commonly used source types. A source with a stack is most appropriately modeled as a point source. For point sources with unobstructed vertical releases, it is appropriate to use actual stack parameters (i.e., height, diameter, exhaust gas temperature, and gas exit velocity) in the modeling analyses. The modeled sources at the Facility include point sources with upward unrestricted releases, which were modeled with the POINT source type. The point source modeled release parameters for the pyroscrubber stacks are presented in Table 4-3 below.

Table 4-3. Release Parameters for Modeled Point Sources

Model ID	UTM East	UTM North	Elevation (m)	Stack Height (m)	Stack Temp (K)	Exit Velocity (m/s)	Stack Diameter (m)
K1	437,642.7	4,315,969.5	165.7	45.72	530.93	9.29	3.05
K2	437,639.4	4,315,893.1	166.6	45.72	530.93	9.29	3.05

4.3.9 Results

The results of the modeling described in the previous subsections of this report are as follows:

Table 4-4. Air Dispersion Modeling Results

Pollutant	Averaging Period	First High (µg/m ³)	Highest 8 th High (µg/m ³)	Highest 6 th High (µg/m ³)	NAAQS (µg/m ³)	SIL (µg/m ³)
PM ₁₀	24-Hour	0.12631		0.09030	150	5
PM _{2.5}	24-Hour	0.03335	0.0223		35	1.2
PM _{2.5}	Annual ¹⁵	0.00335			12	0.2

The modeled results are being compared to the respective NAAQS to highlight the insignificance of the potential impact to the ambient air. In fact, the Significance Impact Levels (SILs) have been established for this very reason. SILs are typically used in Prevention of Significant Deterioration (PSD) modeling to assess whether a project alone has a significant enough modeled impact to warrant further and more comprehensive modeling. Projects which can demonstrate air dispersion impacts that are less than the respective SIL are deemed to be insignificant. Similarly, Rain Carbon has conducted air dispersion modeling of the "project" (kilns only, based on SMB emission rates) and is comparing the results to the respective SILs.

Note that Rain Carbon's initial modeling accounted for baseline emissions when determining the modeled impact of the proposed rulemaking. This is another aspect of PSD modeling that applies to this modeling exercise. In PSD SIL modeling, modified emission units in a project are modeled as the increase in emissions that are related to the project. In this case, the pre-project baseline emissions would be best represented as normal operating emissions and there would be different stack characteristics, meaning that the project's post-project emission rate could be modeled as a positive rate, and the pre-project baseline as

¹⁵ EPA recently promulgated a new PM_{2.5} primary annual NAAQS of 9 µg/m³. 89 FR 16202. EPA has not yet developed a revised SIL based on the new 9 µg/m³ standard. The new standard is not effective until May 5, 2024; therefore, this supplemental TSD compares modeling results for PM_{2.5} against the currently applicable NAAQS, 12 µg/m³. However, because the modeling results for PM_{2.5} primary annual NAAQS are so far below the current 0.2 µg/m³ SIL, the modeling will continue to demonstrate compliance with the forthcoming SIL for the new PM_{2.5} primary annual NAAQS of 9 µg/m³.

a negative emission rate, to determine potential impacts to the ambient air quality standards. Note that Illinois EPA supported the use of this modeling approach, as stated in the March 7, 2023, comments to the Illinois Pollution Control Board (IPCB) for R23-18:

"What is generally considered in a 110(l) demonstration involving revisions of regulations is a comparison between the emissions that subject sources are allowed to emit under a current standard versus what they are allowed to emit under the revised standard."

Rain Carbon opted to run only the SMB emissions rate and ignore pre-project baseline emissions rates for this analysis, to add a conservative measure to the results.

4.3.9.1 PM_{10} 24-Hour

The PM_{10} 24-hour standard is $150 \mu\text{g}/\text{m}^3$ for the highest 6th high modeled concentration. As presented in Table 4-4, the highest 6th high concentration modeled for Rain Carbon's SMB operation modeling scenario is $0.0903 \mu\text{g}/\text{m}^3$. The modeled concentration is less than 0.1% of the NAAQS. The SIL for the PM_{10} 24-hour standard is $5 \mu\text{g}/\text{m}^3$ and the highest modeled concentration is $0.126 \mu\text{g}/\text{m}^3$, or 2.5 % of the SIL. Figure 4-4 and Figure 4-5 below provide visual representations of the modeling results and comparison to the NAAQS and SIL.

Figure 4-4. PM_{10} 24-Hour Modeling Results Compared to NAAQS





Figure 4-5. PM₁₀ 24-Hour Modeling Results Compared to SIL

4.3.9.2 PM_{2.5} 24-Hour

The PM_{2.5} 24-hour standard is 35 µg/m³ for the highest 8th high modeled concentration. As presented in Table 4-4, the highest 8th high concentration modeled for Rain Carbon's SMB operation modeling scenario is 0.0223 µg/m³. The modeled concentration is less than 0.1% of the NAAQS. The SIL for the PM_{2.5} 24-hour standard is 1.2 µg/m³ and the highest modeled concentration is 0.03335 µg/m³, or 2.8% of the SIL. Similar to the PM₁₀ 24-hour standard, Figure 4-6 and Figure 4-7 below depict the modeling results relative to their respective NAAQS and SIL values for PM_{2.5}.




Figure 4-6. PM_{2.5} 24-Hour Modeling Results Compared to NAAQS

Figure 4-7. PM_{2.5} 24-Hour Modeling Results Compared to SIL


4.3.9.3 PM_{2.5} Annual

The PM_{2.5} annual standard is 12 µg/m³¹⁶ for the highest modeled concentration. The highest concentration modeled for Rain Carbon's SMB operation modeling scenario is 0.00335 µg/m³. The modeled concentration is less than 0.1% of the NAAQS. The SIL for the PM_{2.5} annual standard is 0.2 µg/m³ and the highest modeled concentration is 0.00335 µg/m³, or 1.7% of the SIL. Refer to Figure 4-8 and Figure 4-9 below for visual representations of the modeling results relative to their respective NAAQS and SIL values for PM_{2.5}.

Figure 4-8. PM_{2.5} Annual Modeling Results Compared to NAAQS

¹⁶ See Footnote 15, above, for a discussion of the anticipated impact of the 9 µg/m³ PM_{2.5} annual standard on the modeling results.

Figure 4-9. PM_{2.5} Annual Modeling Results Compared to SIL



APPENDIX A. AIRSOURCE STACK TESTING REPORT

SOURCE EMISSIONS TEST REPORT

Prepared for

Rain CII Carbon, LLC

Regarding testing of

Kiln 1

Located at the

Robinson Facility
12187 E 950th Ave
Robinson, Illinois 62454

Performed on

July 20th, 2023

by

AIRSOURCE TECHNOLOGIES, INC.
20505 W. 67th St.
Shawnee, Kansas 66218
(913) 422-9001

Project No. 4173

PREFACE

This report was prepared by AirSource Technologies, Inc., and contains the results of engineering testing that was conducted on a kiln at the Rain CII Carbon, LLC facility in Robinson, Illinois on July 20th, 2023. To the best of our knowledge the data contained in this report are accurate and complete. Any questions concerning this report should be directed to Mr. Taylor Pittman, Project Manager, or Mr. Pete Liebl, Principal.

AirSource Technologies, Inc.

Approved by:



Taylor Pittman

Pete Liebl

Project Manager

Principal

August 29, 2023

TABLE OF CONTENTS

SECTION 1 - INTRODUCTION	1
1.1 FACILITY OVERVIEW	1
1.2 SOURCES TESTED AND PURPOSE OF TESTING.....	1
1.3 SUMMARY OF TESTING PERFORMED AND TEST PROJECT PERSONNEL.....	1
SECTION 2 - SUMMARY OF RESULTS.....	2
2.1 KILN 1 EMISSION RESULTS.....	2
2.2 POTENTIAL FACTORS AFFECTING TESTING	3
SECTION 3 - SAMPLING & ANALYTICAL PROCEDURES.....	4
3.1 DESCRIPTION OF SAMPLING LOCATIONS	4
3.2 SAMPLING AND ANALYSIS PROCEDURES	4
3.2.1 Traverse Point Layout	4
3.2.2 Velocity and Volumetric Flow Rate	4
3.2.3 Gas Molecular Weight.....	4
3.2.4 Moisture Content	4
3.2.5 Filterable/Condensable Particulate Matter Determination	5
3.2.6 VOC Determination	5
3.3 DESCRIPTION OF SAMPLING EQUIPMENT	6
3.3.1 Isokinetic Sampling Equipment	6
3.3.2 Instrumental Analyzers and Sampling System	6
3.4 ANALYTICAL PROCEDURES.....	6
3.4.1 Analysis for Filterable/Condensable Particulate Matter	6
3.4.2 Analysis for O ₂ and CO ₂	7
3.4.3 Analysis for VOC	7
3.5 DEVIATIONS AND MODIFICATIONS TO ANALYTICAL METHODS.....	7
3.6 DESCRIPTION OF ANALYTICAL EQUIPMENT	8
3.6.1 Isokinetic Sample Analytical Equipment.....	8
3.6.2 Instrumental Analyzers.....	8
SECTION 4 - QUALITY ASSURANCE/QUALITY CONTROL.....	9
4.1 COMPLETENESS.....	9
4.2 PARTICULATE MEASUREMENTS AND SAMPLING.....	9
4.3 ANALYSIS FOR PARTICULATE MATTER AND MOISTURE.....	9
4.4 ANALYSIS FOR O ₂ , CO ₂ , AND VOC.....	9

TABLE OF APPENDICES

APPENDIX A CALCULATED EQUATIONS

APPENDIX B CALCULATED RESULTS

APPENDIX B-1 PARTICULATE RESULTS

APPENDIX B-2 INSTRUMENTAL ANALYZER RESULTS

APPENDIX C FIELD DATA

APPENDIX C-1 PARTICULATE DATA

APPENDIX C-2 ANALYZER DATA LOG

APPENDIX C-3 VE FIELD DATA

APPENDIX D LABORATORY ANALYSIS

APPENDIX D-1 PARTICULATE GRAVIMETRIC ANALYSIS

APPENDIX E EQUIPMENT CALIBRATIONS

APPENDIX E-1 PRE-TEST

APPENDIX E-2 POST-TEST

APPENDIX F PROCESS DATA

SECTION 1 - INTRODUCTION

1.1 FACILITY OVERVIEW

The Rain CII Carbon, LLC (Rain) facility in Robinson produces calcined petroleum coke for the production of aluminum and titanium dioxide.

The facility is owned and operated by Rain Carbon, Inc., headquarters at 10 Signal Road, Stamford, Connecticut 06902, and is located at 12187 E 950th Avenue, Robinson, Illinois 62454.

1.2 SOURCES TESTED AND PURPOSE OF TESTING

The facility's Kiln 1 was the source tested. Engineering testing was conducted to evaluate emission rates that occur during a kiln start-up.

1.3 SUMMARY OF TESTING PERFORMED AND TEST PROJECT PERSONNEL

Testing of the Kiln 1 stack outlet included outlet stack measurements to determine filterable and condensable particulate matter, volatile organic compounds (VOC, as Total Gaseous Organic Compounds - TGOC), as well as visible emissions.

Concentrations of VOC were determined by instrumental analyzer. Volumetric flow rates determined in the course of performing particulate testing were applied to gaseous pollutant concentrations to obtain gaseous mass emission rates where applicable.

Five nominally 48-minute test runs for particulate matter and visible emissions were conducted, and nine 45-minute test runs for VOC emissions were conducted.

Isokinetic and gas sampling was conducted by AirSource Technologies, Inc. (AirSource), 20505 W. 67th St., Shawnee, Kansas, 66218. AirSource personnel who performed sampling were:

Mr. Taylor Pittman:	Instrument Operator
Mr. Kevin McKenna:	Isokinetic Sampling
Mr. Brian Greenall:	Sample Train Operator
Mr. David Hotz:	Sample Train Operator
Ms. Lex Hooper:	Certified Observer

AirSource personnel who recovered and analyzed particulate samples were Mr. Alex Vansickle and Ms. Lex Hooper, Laboratory Technicians.

Mr. Dan Fearday, Plant Manager, with Rain coordinated the test project scheduling and provided services and coordination on site necessary to conduct testing.

No regulatory agency representative was present during testing.

SECTION 2 - SUMMARY OF RESULTS

Test measurement results are presented in Tables 2-1 and 2-2 below. Complete results can be found in Appendix B, Calculated Results.

2.1 KILN 1 EMISSION RESULTS

The Kiln 1 emissions measurement results are presented in Tables 2-1 and 2-2 below. The VOC concentrations in Table 2-2 are expressed as an equivalent amount of propane.

Table 2-1
Kiln 1 Particulate Emission Results

Parameter	Units	Run 111	Run 112	Run 113	Run 114	Run 115	Average
Date	—	07/20/23	07/20/23	07/20/23	07/20/23	07/20/23	—
Run Time Period	—	09:44-10:49	12:11-13:10	13:44-14:37	16:15-17:17	17:47-18:50	—
Sampling Time	min	48.00	48.00	44.00	48.00	48.00	—
<u>Gas Stream</u>							
Avg. Velocity Head (Δp)	in H ₂ O	0.156	0.172	0.157	0.167	0.175	0.165
Avg. Temperature	°F	496	702	760	847	931	747
Absolute Pressure	in Hg	29.28	29.27	29.25	29.19	29.20	29.23
Moisture Concentration	%V	5.87	21.22	21.82	18.76	19.62	17.46
O ₂ Concentration, Dry	%V	17.72	15.90	16.07	15.33	14.97	16.00
CO ₂ Concentration, Dry	%V	1.86	3.04	3.16	3.65	3.85	3.11
Avg. Velocity	ft/min	1,829	2,177	2,133	2,261	2,392	2,158
Flow Rate, Actual	acfm	148,456	176,756	173,133	183,552	194,172	175,214
Flow Rate, Wet	scfm	80,207	78,537	73,204	72,282	71,881	75,222
Flow Rate, Dry	dscfm	75,497	61,875	57,232	58,725	57,778	62,221
<u>PM Concentration</u>							
Filterable PM	gr/dscf	6.91E-02	6.08E-02	6.75E-02	8.77E-02	1.04E-01	7.79E-02
Condensable PM	gr/dscf	1.19E-02	3.04E-02	2.94E-02	4.46E-02	6.83E-02	3.69E-02
Total PM	gr/dscf	8.10E-02	9.11E-02	9.69E-02	1.32E-01	1.73E-01	1.15E-01
<u>PM Emission Rate</u>							
Filterable PM	lb/hr	4.47E+01	3.22E+01	3.31E+01	4.41E+01	5.17E+01	4.12E+01
Condensable PM	lb/hr	7.67E+00	1.61E+01	1.44E+01	2.24E+01	3.38E+01	1.89E+01
Total PM	lb/hr	5.24E+01	4.83E+01	4.75E+01	6.66E+01	8.56E+01	6.01E+01
Sample Volume	dscf	42.169	29.644	26.796	31.003	31.891	—
Avg. Isokinetic Variation	%	93.3	111.5	102.7	108.8	109.2	—

Table 2-2
Kiln 1 Gaseous Pollutant Emission Results – TGOC (as propane)

Parameter	Units	1-1-1	1-1-2	1-1-3	Average
Date	—	07/20/23	07/20/23	07/20/23	—
Instrument Log Time(s)	—	09:45-10:30	10:45-11:30	11:45-12:30	—
<u>Gas Stream</u>					
O ₂ Concentration, Dry	%V	17.72	16.66	16.34	16.90
CO ₂ Concentration, Dry	%V	1.86	2.62	2.98	2.49
<u>Total Hydrocarbons</u>					
Concentration - Wet	ppmv	4.37	0.89	0.83	2.03
Parameter	Units	1-1-4	1-1-5	1-1-6	Average
Date	—	07/20/23	07/20/23	07/20/23	—
Instrument Log Time(s)	—	12:47-13:32	13:45-14:30	14:45-15:30	—
<u>Gas Stream</u>					
O ₂ Concentration, Dry	%V	15.90	16.07	15.93	15.97
CO ₂ Concentration, Dry	%V	3.04	3.16	3.31	3.17
<u>Total Hydrocarbons</u>					
Concentration - Wet	ppmv	0.71	0.69	0.63	0.68
Parameter	Units	1-1-7	1-1-8	1-1-9	Average
Date	—	07/20/23	07/20/23	07/20/23	—
Instrument Log Time(s)	—	15:45-16:30	16:46-17:31	17:45-18:30	—
<u>Gas Stream</u>					
O ₂ Concentration, Dry	%V	15.69	15.33	14.97	15.33
CO ₂ Concentration, Dry	%V	3.47	3.65	3.85	3.66
<u>Total Hydrocarbons</u>					
Concentration - Wet	ppmv	0.66	0.58	0.56	0.60

2.2 POTENTIAL FACTORS AFFECTING TESTING

During startup, changing conditions within the kiln stack as the process climbed toward full heat and load over the course of the day made attempts at selecting kiln condition parameters for testing difficult. Isokinetic performance was therefore negatively impacted. Run 112 was determined to be slightly over 110%. All other runs were within the 100±10% isokinetic criteria. This is not expected to have any significant effect on results.

There were no other apparent factors that may have introduced errors in the test results.

SECTION 3 - SAMPLING & ANALYTICAL PROCEDURES

3.1 DESCRIPTION OF SAMPLING LOCATIONS

Outlet emission measurements were conducted in Kiln 1's vertical, circular, steel 122" diameter exhaust stack. Access to the measurement location sampling ports was from a facility landing surrounding the stack and accessible by ladder. Four test ports consisting of steel pipe flanges 90° apart were used for particulate and gaseous concentration sampling.

Test location details such as duct diameter at the test port location, the nearest flow disturbances upstream and downstream of the test ports (with equivalent diameters), and the number of traverse points used for the particulate and associated volumetric flow rate sampling are located in Appendix C, Field Data.

3.2 SAMPLING AND ANALYSIS PROCEDURES

3.2.1 TRAVERSE POINT LAYOUT

The traverse point layout was determined according to procedures in EPA Method 1 in Appendix A-1 of 40 *CFR*, Part 60 to provide a means for obtaining measurements representative of the gas stream. The cross-sectional area of the gas stream at the measurement location was divided into a number of equal areas. The number of equal areas was dependent upon the nearest upstream and downstream flow disturbances. The traverse points were located within each of these equal areas. Actual traverse point location measurement data used to locate the traverse points in the cross-sectional area for sampling when sampling was conducted, and measuring gas stream parameters are in Appendix B, Calculated Results.

3.2.2 VELOCITY AND VOLUMETRIC FLOW RATE

Gas stream velocities and volumetric flow rates were determined according to procedures in EPA Method 2 in Appendix A-1 of 40 *CFR*, Part 60. Type S pitot tube-probe assemblies meeting the dimensional specifications in EPA Method 2 for a baseline pitot tube coefficient and an inclined manometer were used for measuring velocity heads and static pressure. Velocity heads and gas density were used in calculating velocity. Gas density was determined from the molecular weight of the gas, gas stream temperature, and gas stream pressure. Calibrated thermocouples and a temperature meter were used for measuring gas stream temperatures. A digital barometer calibrated against a mercury barometer was used to measure atmospheric pressure at the test location. The atmospheric pressure and the gas stream static pressure were used in calculating gas stream pressure.

3.2.3 GAS MOLECULAR WEIGHT

Oxygen and carbon dioxide concentrations along with an assumed balance of nitrogen were used in the calculation of the dry molecular weight of each gas stream which along with the moisture content of the gas stream was used in all applicable gas stream parameter calculations such as for gas density and velocity.

The procedures in EPA Method 3A in Appendix A-2 of 40 *CFR*, Part 60 were used to continuously extract and analyze gas from the gas stream for oxygen and carbon dioxide as described in Sections 3.3.2, Instrumental Analyzers and Sampling System, and 3.4.2, Analysis for O₂ and CO₂.

3.2.4 MOISTURE CONTENT

Moisture (water vapor) content of the gas stream was determined according to procedures in EPA Method 4 in Appendix A-3 of 40 *CFR*, Part 60 (incorporated as part of the Method 5 sampling procedures). Moisture collected in the back half of each sampling train was determined gravimetrically from the difference between the initial and final weights of all of the impingers. The theoretical moisture content of the gas stream at saturated conditions was determined

from the vapor pressure of water at gas stream temperature and the gas stream pressure. The lower of the two results (sampled moisture or saturation moisture) was used in gas stream parameter calculations such as for gas density and conversions of volumetric flow rate and pollutant concentration between wet and dry conditions.

3.2.5 FILTERABLE/CONDENSABLE PARTICULATE MATTER DETERMINATION

The collected particulate samples were recovered and analyzed at AirSource's laboratory. AirSource performed the gravimetric analysis of the EPA Method 5 sampling train nozzle, filterable particulate filter holder front-half acetone rinses, and the dry fraction (filtered particulate matter) samples according to procedures in EPA Method 5. All nozzles and filter holder front halves were brushed and rinsed with reagent grade acetone. Rinse samples were transferred to tared 50-mL beakers and evaporated to dryness at room temperature. Filters along with any loose material were recovered and returned to their original petri dishes.

Gravimetric analysis of the samples and rinses recovered from the EPA Method 202 sampling train for condensable particulate matter were conducted according to procedures in EPA Method 202 in Appendix M of 40 CFR, Part 51 (Dry Impinger Method). All of the components after the filterable particulate filter and up to the condensable particulate filter were rinsed with deionized ultra-filtered water which was added to the sample condensate. Another set of rinses with acetone and hexane was performed and the rinsates stored in a separate sample bottle. Hexane extractions were performed on the recovered aqueous samples to separate the organic and inorganic condensable particulate matter fractions. The hexane and aqueous samples were returned to their respective sample containers after extraction. The condensable particulate filter was extracted three times with water and the extract added to the inorganic sample. This was repeated with hexane and the extract added to the organic sample. The hexane extracts were transferred to tared 50-mL beakers and evaporated to dryness at room temperature. The aqueous samples were transferred to 600-mL beakers and evaporated on a hot plate to about 50-mLs. These aqueous samples were then transferred to tared 50-mL beakers and evaporated on a hotplate to 10-mL. The residual moisture that remained was evaporated at room temperature. This recovery procedure was then immediately repeated on one of the recovered test run sample trains to create a Field Train Recovery Blank (FTRB).

All filterable and condensable rinse sample beakers, and filterable filters in petri dishes were desiccated for 24 hours and weighed to a constant weight (i.e., <0.5 mg change or <1% of total weight less tare weight change, whichever was greater) at intervals of six hours or longer. Each front-half rinse sample volume was determined from the difference between the weights of the empty sample container and the same container with sample divided by the density of acetone for blank correction determination. The total organic and inorganic blank sample weight from the FTRB was subtracted from the total organic and inorganic test run sample up to a maximum allowed subtraction of 2.0 mg. A proof blank train analysis was conducted with the collected sample and field recovery blank trains. The analysis data are located in Appendix D-1, Particulate Gravimetric Analysis.

3.2.6 VOC DETERMINATION

The procedures in EPA Method 25A in Appendix A of 40 CFR, Part 60 were used to continuously extract gas stream sample for pollutant analysis and to determine measurement system performance.

Volumetric flow rates measured during the course of testing for particulate emissions were applied to gaseous concentrations determined by instrumental analyzers to report mass emission rates of pollutant emissions where applicable.

3.3 DESCRIPTION OF SAMPLING EQUIPMENT

3.3.1 ISOKINETIC SAMPLING EQUIPMENT

Apex Instruments Inc. or Environmental Supply Company nozzles, probe liners, filter holders, and impingers were used for sample collection. Nutech, Apex, or Environmental Supply sampling probes, filter heater boxes, and impinger boxes, housed all sample glassware. Nutech, Apex, or Environmental Supply sample umbilical adapters and umbilicals and Nutech Model 2010 Stack Samplers with Watlow or Fuji temperature readouts, and Ambient Weather Model WS-108 barometers were used for volume, temperature and pressure measurements.

3.3.2 INSTRUMENTAL ANALYZERS AND SAMPLING SYSTEM

The emission measurement systems consisted of a sample extraction, transport, conditioning, distribution system, analyzers, and a data acquisition system.

The procedures in EPA Methods 3A in Appendix A of 40 CFR, Part 60 were used to continuously extract gas stream sample for analysis and to determine measurement system performance. Sample gas was extracted through a heated 316 stainless steel sampling probe, a Universal Analyzers Model 270S heated, stainless steel out-of-stack filter assembly with a two-micron ceramic filter element for particulate matter removal, and a Technical Heaters 100 foot long heated Teflon® sample transfer line all operated at approximately 250 °F to prevent condensation. Sample gas was extracted with a heated filter assembly which fed sample directly to the instrument sample inlet port. Sample for diluent testing was routed from a tee at the FID inlet port and connected to a thermo-electrically cooled gas sample dryer. Sample flow through the system was approximately 6 liters per minute.

The conditioned dry sample was directed through unheated Teflon® tubing to a flow panel controlling pressure at an instrument manifold delivering sample gas to diluent instrumental analyzers. The flow panel also controlled direct delivery of calibration gas to the instrument manifold and system bias calibration gas delivery to the inlet of the stack probe/filter assembly. Delivery of calibration gas to the filter assembly was adjusted so that excess calibration gas flooded and back fed through the probe.

Calibration gas flow rate to the filter assembly was adjusted so that excess gas flowed in reverse direction through the probe thus preventing dilution of the calibration or zero gas flowing into the filter element, the sample transfer line and to the analyzer.

Calibration gases prepared according to the EPA traceability protocol for assay and certification of gaseous calibration standards were used to calibrate the measurement system.

The data acquisition system included a duTec I/O Plexer for analog-to-digital conversion of instrument voltage or current signals and a personal computer for data logging digitized data. The system software read analyzer signal outputs approximately twice every second and recorded averages every 60 seconds. Data logged during calibrations, quality control checks, and sample gas analysis was transferred into a Microsoft Excel workbook where results for measurement system performance, sample gas concentrations and emission rates were computed. The measurement system performance results are located in Appendix B-2, Instrumental Analyzer Results.

3.4 ANALYTICAL PROCEDURES

3.4.1 ANALYSIS FOR FILTERABLE/CONDENSABLE PARTICULATE MATTER

The collected particulate samples were recovered and analyzed at AirSource's laboratory. AirSource performed the gravimetric analysis of the EPA Method 5 sampling train nozzle, filterable particulate filter holder front-half acetone rinses, and the dry fraction (filtered particulate matter) samples according to procedures in EPA Method 5. All nozzles and filter holder front halves were brushed and rinsed with reagent grade acetone. Rinse samples were

transferred to tared 50-mL beakers and evaporated to dryness at room temperature. Filters along with any loose material were recovered and returned to their original petri dishes.

Gravimetric analysis of the samples and rinses recovered from the EPA Method 202 sampling train for condensable particulate matter were conducted according to procedures in EPA Method 202 in Appendix M of 40 *CFR*, Part 51 (Dry Impinger Method). All of the components after the filterable particulate filter and up to the condensable particulate filter were rinsed with deionized ultra-filtered water which was added to the sample condensate. Another set of rinses with acetone and hexane was performed and the rinsates stored in a separate sample bottle. Hexane extractions were performed on the recovered aqueous samples to separate the organic and inorganic condensable particulate matter fractions. The hexane and aqueous samples were returned to their respective sample containers after extraction. The condensable particulate filter was extracted three times with water and the extract added to the inorganic sample. This was repeated with hexane and the extract added to the organic sample. The hexane extracts were transferred to tared 50-mL beakers and evaporated to dryness at room temperature. The aqueous samples were transferred to 600-mL beakers and evaporated on a hot plate to about 50-mLs. These aqueous samples were then transferred to tared 50-mL beakers and evaporated on a hotplate to 10-mL. The residual moisture that remained was evaporated at room temperature. This recovery procedure was then immediately repeated on one of the recovered test run sample trains to create a Field Train Recovery Blank (FTRB).

All filterable and condensable rinse sample beakers, and filterable filters in petri dishes were desiccated for 24 hours and weighed to a constant weight (i.e., <0.5 mg change or <1% of total weight less tare weight change, whichever was greater) at intervals of six hours or longer. Each front-half rinse sample volume was determined from the difference between the weights of the empty sample container and the same container with sample divided by the density of acetone for blank correction determination. The total organic and inorganic blank sample weight from the FTRB was subtracted from the total organic and inorganic test run sample up to a maximum allowed subtraction of 2.0 mg. A proof blank train analysis was conducted with the collected sample and field recovery blank trains. The analysis data are in Appendix D-1, Particulate Gravimetric Analysis.

3.4.2 ANALYSIS FOR O₂ AND CO₂

The procedures in EPA Method 3A in Appendix A-2 of 40 *CFR*, Part 60 were used to continuously extract and analyze gas stream sample for oxygen and carbon dioxide concentrations. The calibration gases were EPA traceability protocol certified concentrations of O₂ and CO₂ in nitrogen.

The analysis results are in Appendix B-2, Instrumental Analyzer Results. Instrument data and copies of the calibration gas certificates are in Appendix C-2, Analyzer Data Lo.

3.4.3 ANALYSIS FOR VOC

The procedures in EPA Method 25A in Appendix A-7 of 40 *CFR*, Part 60 were used to continuously extract and analyze sample gas from the gas stream for VOC expressed as propane. The calibration gases contained EPA traceability protocol certified concentrations of propane in nitrogen.

The analysis results are in Appendix B-2, Instrumental Analyzer Results. Instrument data and copies of the calibration gas certificates are in Appendix C-2, Analyzer Data Lo.

3.5 DEVIATIONS AND MODIFICATIONS TO ANALYTICAL METHODS

There were no deviations or modifications to the published analytical methods.

3.6 DESCRIPTION OF ANALYTICAL EQUIPMENT

3.6.1 ISOKINETIC SAMPLE ANALYTICAL EQUIPMENT

Reagents used were Fisher DIUF water, Fisher Optima grade acetone, and Fisher hexanes. Filterable particulate filters were Whatman 934AH glass microfiber and condensable filters were Tisch PTFE membrane SF16015. Liquid sample was collected in Thermo Scientific I-Chem bottles. Impinger weights were measured with an Ohaus Galaxy Explorer E0D110 and Acculab VIC-1501 balances. Particulate sample weights were measured with a Mettler Toledo XPE 205 analytical balance.

3.6.2 INSTRUMENTAL ANALYZERS

The analyzer used in measuring oxygen and carbon dioxide concentrations according to EPA Method 3A was a California Analytical Model 602P multi-component gas analyzer measuring oxygen using paramagnetic detection and carbon dioxide by nondispersive infrared absorption spectroscopy.

The analyzer used to measure VOC concentration according to procedures in EPA Method 25A was a Thermo Fisher Scientific Model 51i-HT flame ionization detector (FID). The FID was maintained at 392 °F during testing.

SECTION 4 - QUALITY ASSURANCE/QUALITY CONTROL

The Quality Assurance/Quality Control (QA/QC) procedures and requirements specified in the EPA methods or any other methods used and AirSource standard operating procedures were used. Those procedures include test equipment calibrations and procedural elements of the methods. Examples of those procedural elements are test equipment leak checks, proper traversing and placement of sampling probes in gas streams, and verification of the integrity of measurement systems before and after sampling. The performance and results of all QA/QC procedures were recorded on appropriate forms, data sheets, or in computer workbooks as appropriate.

An assessment of the overall quality of the data generated for this test project was conducted. The data assessment included a review of the sample collection and analytical data, including calibrations. The data generated for this report are traceable and of known and acceptable quality.

4.1 COMPLETENESS

All measurements specified in the test plan were completed. All measurements specified in the test plan were completed and are reported. All samples specified in the test plan were collected and analyzed and the results are reported.

4.2 PARTICULATE MEASUREMENTS AND SAMPLING

The EPA Method 5 sample extraction for the test runs on Kiln 1 was within the $100 \pm 10\%$ isokinetic criteria required by the test method, except for Run 112 which was slightly above the 110% criteria. All of the final sampling train leak checks were within method criteria for test runs reported. All of the sampling temperatures were within specified ranges. All of the test equipment requiring calibration met the method criteria for calibrations before and after the testing.

4.3 ANALYSIS FOR PARTICULATE MATTER AND MOISTURE

All of the initial and final analytical balance-check weight values for the filter and beaker weighings were within 0.2 mg of each other. All of the initial and final field balance-check weight values for the impinger weighings were within 0.2 g of each other.

4.4 ANALYSIS FOR O₂, CO₂, AND VOC

The calibration error was less than the $\pm 2\%$ provided by the method. System bias was within the $\pm 5\%$ for the zero and high range calibration gases. Zero drift and calibration drift were less than $\pm 3\%$ of the span over the test run.

APPENDIX A

CALCULATED EQUATIONS

EPA Methods 5 and 202 – Filterable and Condensible Particulate Matter Calculations

Dry Gas Sample Volume

$$V_m = V_f - V_i \quad V_{m(std)} = \frac{17.64 \times V_m \times Y \times \left(P_{bar} \pm \frac{E_{Mtr}}{1,000 \text{ ft}} + \frac{\Delta H}{13.6} \right)}{T_m}$$

E_{Mtr}	Dry gas meter elevation relative to the barometer	ft
P_{bar}	Barometric pressure at the barometer	in Hg
T_m	Average absolute dry gas meter temperature	° R
V_f	Final dry gas meter volume reading	ft ³
V_i	Initial dry gas meter volume reading	ft ³
V_m	Net dry gas meter volume, actual	ft ³
$V_{m(std)}$	Net dry gas meter volume at standard conditions	dscf
Y	Dry gas meter calibration correction factor	dimensionless
ΔH	Average orifice meter pressure-drop	in H ₂ O
13.6	Specific gravity of mercury relative to water	in H ₂ O/in Hg
17.64	Standard absolute temperature (527.67 ° R) divided by standard absolute pressure (760 mm Hg/25.4 mm/in)	° R/in Hg

Gas Stream Moisture (Water Vapor) Content

$$V_{w(std)} = 0.04715 \times M_{lc} \quad B_{ws(Sample)} = \frac{V_{w(std)}}{V_{m(std)} + V_{w(std)}} \quad B_{ws(Sat)} = \frac{VP_{H_2O}}{P_s}$$

$$P_w = B_{ws} \times 100 \quad B_d = 1 - B_{ws}$$

B_d	Proportion of the dry gas by volume	dimensionless
B_{ws}	$B_{ws(Sample)}$ or $B_{ws(Sat)}$, whichever is less	dimensionless
$B_{ws(Sample)}$	Proportion of water vapor by volume determined with the sampling train	dimensionless
$B_{ws(Sat)}$	Proportion of water vapor by volume for a saturated or supersaturated gas stream	dimensionless
M_{lc}	Total mass of water collected in the sampling train	g
P_s	Absolute gas stream pressure	in Hg
P_w	Percent moisture (water vapor) in the gas stream	%V
$V_{m(std)}$	Net dry gas meter volume at standard conditions	dscf
$V_{w(std)}$	Equivalent volume of water vapor collected, at standard conditions	ft ³
VP_{H_2O}	Vapor pressure of water at gas stream temperature	in Hg
0.04715	Conversion factor for grams of water to cubic feet of water vapor at standard conditions	ft ³ /g

Gas Stream Absolute Pressure

$$P_s = P_{bar} \pm \frac{E_{Stk}}{1,000 \text{ ft}} + \frac{P_g}{13.6}$$

E_{Stk}	Sampling location elevation relative to the barometer	ft
P_{bar}	Barometric pressure at the barometer	in Hg
P_g	Gas stream static pressure	in H ₂ O
P_s	Absolute gas stream pressure	in Hg
13.6	Specific gravity of mercury relative to water	in H ₂ O/in Hg

Gas Molecular Weight
For Combustion Sources

$$\% N_2 = 100\% - (\% CO_2 + \% O_2)$$

$$M_d = 0.44 \times \% CO_2 + 0.32 \times \% O_2 + 0.28 \times \% N_2$$

$$M_s = M_d \times B_d + 18 \times B_{ws}$$

B_d	Proportion of the dry gas by volume	dimensionless
B_{ws}	Proportion of water vapor by volume	dimensionless
M_d	Molecular weight of the dry gas	lb/lb-mole
M_s	Molecular weight of the wet gas	lb/lb-mole
$\%CO_2$	Carbon dioxide concentration by volume, dry-basis	%V
$\%O_2$	Oxygen concentration by volume, dry-basis	%V
$\%N_2$	Nitrogen concentration by volume, dry-basis	%V
0.28	Molecular weight of nitrogen divided by 100	lb/lb-mole/100%
0.32	Molecular weight of oxygen divided by 100	lb/lb-mole/100%
0.44	Molecular weight of carbon dioxide divided by 100	lb/lb-mole/100%
18	Molecular weight of water	lb/lb-mole

For Ambient Air Sources

M_d	Molecular weight of dry ambient air	28.965 lb/lb-mole
-------	-------------------------------------	-------------------

Gas Stream Velocity

$$\Delta p = \left(\frac{\sum_{i=1}^n \sqrt{\Delta p_i}}{n} \right)^2 \quad v_s = 85.49 \times C_p \times \sqrt{\Delta p} \times \sqrt{\frac{T_s}{P_s \times M_s}} \times \frac{60 \text{ sec}}{1 \text{ min}}$$

C_p	Pitot tube coefficient	dimensionless
M_s	Molecular weight of the wet gas	lb/lb-mole
n	Number of traverse points sampled	
P_s	Absolute gas stream pressure	in Hg
T_s	Average absolute temperature of the gas stream	$^{\circ}\text{R}$
v_s	Average gas stream velocity	fpm
Δp	Average velocity head of the gas stream	in H_2O
Δp_i	Velocity head at sampling point i	in H_2O
85.49	Pitot tube constant	$\frac{\text{ft}}{\text{sec}} \left[\frac{(\text{lb/lb-mole})(\text{in Hg})}{(^{\circ}\text{R})(\text{in H}_2\text{O})} \right]^{1/2}$

Gas Stream Volumetric Flow Rate

$$A_s = \frac{D_1 \times D_2 \times \pi}{4} \times \frac{1 \text{ ft}^2}{144 \text{ in}^2} \text{ Circular Duct} \quad A_s = W_1 \times W_2 \times \frac{1 \text{ ft}^2}{144 \text{ in}^2} \text{ Rectangular Duct}$$

$$Q_{s[\text{acfm}]} = v_s \times A_s \quad Q_{s[\text{scfm}]} = \frac{17.64 \times Q_{s[\text{acfm}]} \times P_s}{T_s} \quad Q_{s[\text{dscfm}]} = Q_{s[\text{scfm}]} \times B_d$$

A_s	Cross sectional area of the stack or duct	ft^2
B_d	Proportion of the dry gas by volume	dimensionless
D_1	First internal diameter of the circular stack or duct	in
D_2	Second internal diameter of the circular stack or duct	in
P_s	Absolute gas stream pressure	in Hg
$Q_{s[\text{acfm}]}$	Gas stream flow rate at actual conditions	acfm
$Q_{s[\text{dscfm}]}$	Gas stream flow rate at dry standard conditions	dscfm
$Q_{s[\text{scfm}]}$	Gas stream flow rate at standard conditions	scfm
T_s	Average absolute temperature of the gas stream	$^{\circ}\text{R}$
v_s	Average gas stream velocity	fpm
W_1	First internal side of the rectangular stack or duct	in
W_2	Second internal side of the rectangular stack or duct	in
4	2 (radiuses per diameter) squared	
17.64	Standard absolute temperature (527.67 $^{\circ}\text{R}$) divided by standard absolute pressure (760 mm Hg/25.4 mm/in)	$^{\circ}\text{R/in Hg}$

Isokinetic Sampling Variation

$$I = \frac{100\% \times P_{std} \times T_s \times V_{m(std)}}{T_{std} \times v_s \times \theta \times P_s \times B_d \times \pi \times \frac{D_n^2}{4} \times \frac{1 \text{ ft}^2}{144 \text{ in}^2} \times \frac{60 \text{ sec}}{1 \text{ min}}}$$

B _d	Proportion of the dry gas by volume	dimensionless
D _n	Nozzle diameter	in
I	Percent of isokinetic sampling	%
P _s	Absolute gas stream pressure	in Hg
P _{std}	Standard absolute pressure	29.92 in Hg
t _s	Average absolute temperature of the gas stream	° R
T _{std}	Standard absolute temperature	528 ° R
V _{m (std)}	Net dry gas meter volume at standard conditions	dscf
v _s	Average gas stream velocity	fpm
θ	Total sampling time	min
4	2 (radiuses per diameter) squared	

Filterable Particulate Matter Collected

$$V_{aw} = \frac{WF_{aw} - WI_{aw}}{\rho_{aw}} \quad V_r = \frac{WF_r - WI_r}{\rho_{aw}} \quad C_{aw} = \frac{M_{aw}}{V_{aw}}$$

$$M_r = WF_{bkr} - WI_{bkr} - (C_{aw} \times V_r) \quad M_f = WF_f - WI_f \quad M_n = M_f + M_r$$

C _{aw}	Particulate matter concentration in the acetone (or water) reagent blank	mg/mL
M _{aw}	Mass of the residue in the reagent blank	mg
M _f	Mass of the particulate matter on the filter	mg
M _n	Total mass of the filterable particulate matter collected	mg
M _r	Mass of the particulate matter in the front-half rinses	mg
V _{aw}	Volume of the acetone (or water) reagent blank	mL
V _r	Volume of the front-half acetone (or water) rinses	mL
WF _{aw}	Weight of the container with the reagent blank sample	g
WF _{bkr}	Final beaker plus residue weight	mg
WF _f	Final filter plus particulate matter weight	mg
WF _r	Weight of the container with the front-half rinses sample	g
WI _{aw}	Tare weight of the container for the reagent blank sample	g
WI _{bkr}	Initial (tare) beaker weight	mg
WI _f	Initial (tare) filter weight	mg
WI _r	Tare weight of the container for the front-half rinses sample	g
ρ _{aw}	Density of the acetone (or water) reagent	g/mL

Condensable Particulate Matter Collected

$$V_w = \frac{WF_w - WI_w}{\rho_w} \quad V_{ic} = \frac{WF_i - WI_i}{\rho_w} \quad C_w = \frac{M_w}{V_w} \quad V_{cond} = \frac{M_{lc} - M_{sg}}{M_{lc}} \times \frac{M_{lc} - M_{sg}}{\rho_w}$$

When ammonium hydroxide (NH₄OH) is not added to the inorganic fraction because the final pH of the impinger solution was greater than 4.5:

$$M_i = WF_{ibkr} - WI_{ibkr} - [C_w \times (V_{ic} - V_{cond})]$$

When an aliquot is removed for analysis for sulfate by ion chromatography, NH₄OH is added to the inorganic fraction, and a correction is made only for the addition of NH₄OH:

$$M_i = (WF_{ibkr} - WI_{ibkr}) \times \frac{V_{ic}}{V_{ic} - V_b} - (0.35457 \times C_{SO4} \times V_{ic}) - [C_w \times (V_{ic} - V_{cond})]$$

When an aliquot is removed for analysis for sulfate by ion chromatography, NH₄OH is added to the inorganic fraction, and a correction is made for the addition of NH₄OH and the combined water removed by the acid-base reaction:

$$M_i = (WF_{ibkr} - WI_{ibkr}) \times \frac{V_{ic}}{V_{ic} - V_b} - (-0.02050 \times C_{SO4} \times V_{ic}) - [C_w \times (V_{ic} - V_{cond})]$$

When the re-dissolved inorganic fraction is titrated with NH₄OH titrant and a correction is made only for the addition of NH₄OH:

$$M_i = (WF_{ibkr} - WI_{ibkr}) - (0.35457 \times 48.0313 \times N \times V_t) - [C_w \times (V_{ic} - V_{cond})]$$

When the re-dissolved inorganic fraction is titrated with NH₄OH titrant and a correction is made for the addition of NH₄OH and the combined water removed by the acid-base reaction:

$$M_i = (WF_{ibkr} - WI_{ibkr}) - (-0.02050 \times 48.0313 \times N \times V_t) - [C_w \times (V_{ic} - V_{cond})]$$

$$V_{Mecl2} = \frac{WF_{Mecl2} - WI_{Mecl2}}{\rho_{Mecl2}} \quad V_o = \frac{WF_o - WI_o}{\rho_{Mecl2}} \quad C_{Mecl2} = \frac{M_{Mecl2}}{V_{Mecl2}}$$

$$M_o = WF_{obkr} - WI_{obkr} - (C_{Mecl2} \times V_o) \quad M_c = M_i + M_o$$

C _{Mecl2}	Particulate matter concentration in the methylene chloride reagent blank	mg/mL
C _{SO4}	Concentration of the sulfate ion (SO ₄ ²⁻) in the sample aliquot	mg/mL
C _w	Particulate matter concentration in the water reagent blank	mg/mL
M _c	Total mass of the condensable particulate matter collected	mg
M _i	Mass of the particulate matter in the inorganic fraction sample and rinses	mg
M _{lc}	Total mass of the condensate collected in the impingers	g
M _{Mecl2}	Mass of the residue in the methylene chloride reagent blank	mg
M _o	Mass of the particulate matter in the organic fraction sample and rinses	mg

Continued on the following page →

M_{sg}	Mass of moisture collected in the silica gel impinger	g
M_w	Mass of the residue in the water reagent blank	mg
N	Normality of the ammonium hydroxide titrant	meq/mL
V_b	Volume of aliquot taken for IC analysis for sulfate (SO_4^{-2})	mL
V_{cond}	Volume of the condensate collected in the impingers less <u>an estimated amount</u> of condensate collected in the silica gel impinger (The separate amounts of the condensate from the gas stream and the water reagent collected in the silica gel cannot be determined.)	mL
V_{ic}	Volume of the inorganic fraction sample (same as the final volume recovered from the impingers plus the rinses)	mL
V_{Mecl2}	Volume of the methylene chloride reagent blank	mL
V_o	Volume of the organic fraction sample and rinses	mL
V_t	Volume of ammonium hydroxide titrant used for titration	mL
V_w	Volume of the water reagent blank	mL
WF_i	Weight of the container with the inorganic fraction sample and rinses	g
WF_{ibkr}	Inorganic fraction sample and rinses final beaker plus residue weight	mg
WF_{Mecl2}	Weight of the container with the methylene chloride reagent blank sample	g
WF_o	Weight of the container with the organic fraction sample and rinses	g
WF_{obkr}	Organic fraction sample and rinses final beaker plus residue weight	mg
WF_w	Weight of the container with the water reagent blank sample	g
WI_i	Tare weight of the container for the inorganic fraction sample and rinses	g
WI_{ibkr}	Inorganic fraction sample and rinses initial (tare) beaker weight	mg
WI_{Mecl2}	Tare weight of the container for the methylene chloride reagent blank sample	g
WI_o	Tare weight of the container for the organic fraction sample and rinses	g
WI_{obkr}	Organic fraction sample and rinses initial (tare) beaker weight	mg
WI_w	Tare weight of the container for the water reagent blank sample	g
ρ_{Mecl2}	Density of the methylene chloride reagent	g/mL
ρ_w	Density of water	g/mL
48.0313	Equivalent weight of SO_4^{-2} (ionic weight of SO_4^{-2} divided by 2)	mg/meq
-0.02050	Factor for correcting for the amount of ammonia (NH_3) retained in the sample and the amount of combined water removed by the acid-base reaction ($2 \times$ the molecular weight of NH_3 divided by the molecular weight of SO_4^{-2} less $2 \times$ the molecular weight of H_2O divided by the molecular weight of SO_4^{-2})	
0.35457	Factor for correcting only for the amount of ammonia (NH_3) retained in the sample ($2 \times$ the molecular weight of NH_3 divided by the molecular weight of SO_4^{-2})	

Total Particulate Matter Concentration in the Stack or Duct

$$C_{s(std)} = \frac{(M_n + M_c)}{V_{m(std)}} \times \frac{1 \text{ g}}{1,000 \text{ mg}} \times \frac{1 \text{ lb}}{453.59237 \text{ g}} \times \frac{7,000 \text{ gr}}{1 \text{ lb}}$$

$$C_{s(act)} = 17.64 \times C_{s(std)} \times \frac{P_s}{T_s} \times B_d$$

$$C_{s(7\%O_2)} = C_{s(std)} \times \frac{20.9 - 7}{20.9 - \%O_2} \quad C_{s(12\%CO_2)} = C_{s(std)} \times \frac{12}{\%CO_2}$$

B_d	Proportion of the dry gas by volume	dimensionless
$C_{s(act)}$	Concentration of total particulate matter at actual conditions	gr/ft ³
$C_{s(std)}$	Concentration of total particulate matter at dry standard conditions	gr/dscf
$C_{s(7\%O_2)}$	Concentration of total particulate matter at dry standard conditions, corrected to 7% oxygen	gr/dscf
$C_{s(12\%CO_2)}$	Concentration of total particulate matter at dry standard conditions, corrected to 12% carbon dioxide	gr/dscf
M_c	Total mass of the condensable particulate matter collected	mg
M_n	Total mass of the filterable particulate matter collected	mg
P_s	Absolute gas stream pressure	in Hg
T_s	Average absolute temperature of the gas stream	° R
$V_{m(std)}$	Net dry gas meter volume at standard conditions	dscf
$\%CO_2$	Carbon dioxide concentration by volume in the gas stream, dry-basis	%V
$\%O_2$	Oxygen concentration by volume in the gas stream, dry-basis	%V
7	Oxygen concentration standard	%V
12	Carbon dioxide concentration standard	%V
17.64	Standard absolute temperature (527.67 °R) divided by standard absolute pressure (760 mm Hg/25.4 mm/in)	° R/in Hg
20.9	Oxygen concentration in dry air	%V

Filterable and condensable particulate matter concentrations are individually calculated in the same manner as above.

Total Particulate Matter Emission Rate

$$E_p = C_{s(std)} \times Q_{s[dscfm]} \times \frac{60 \text{ min}}{1 \text{ hr}} \times \frac{1 \text{ lb}}{7,000 \text{ gr}}$$

$$E_{p \text{ [lb/MMBtu]}} = C_{s(std)} \times \frac{1 \text{ lb}}{7,000 \text{ gr}} \times F_c \times \frac{100}{\%CO_2}$$

C _{s (std)}	Concentration of total particulate matter at dry standard conditions	gr/dscf
E _p	Total particulate matter emission rate	lb/hr
E _{p [lb/MMBtu]}	Total particulate matter emission rate	lb/MMBtu
F _c	Ratio of the carbon dioxide volume generated by combustion to the high heating value of the fuel combusted	scf/MMBtu
Q _{s [dscfm]}	Gas stream flow rate at dry standard conditions	dscfm
%CO ₂	Carbon dioxide concentration by volume, dry-basis	%V

Filterable and condensible particulate matter emission rates are individually calculated in the same manner as above.

EPA Methods 3A, 6C, 7E, 10, and 25A – Gaseous Diluent (CO₂ and O₂), Gaseous Pollutant (SO₂, NO_x, and CO), and Total Gaseous Organic Concentration (TGOc) Calculations

Calibration Adjusted CO₂, O₂, SO₂, NO_x, or CO Concentration in the Stack or Duct Effluent

$$C_{gas} = (\bar{C} - C_o) \times \frac{C_{ma}}{(C_m - C_o)}$$

\bar{C}	Average gas analyzer output concentration, dry-basis	ppmv or %V
C_{gas}	Average calibration-adjusted effluent gas concentration, dry-basis	ppmv or %V
C_m	Average of the initial and final gas measurement system bias check responses to the upscale calibration gas	ppmv or %V
C_{ma}	Certified analysis concentration in the upscale calibration gas	ppmv or %V
C_o	Average of the initial and final gas measurement system bias check responses to the zero calibration gas	ppmv or %V

CO₂, O₂, SO₂, NO_x, or CO Analyzer Calibration Error

$$CE = \frac{(C_{mai} - C_a)}{S} \times 100\%$$

C_a	Analyzer response to the zero, mid-range, or high-range calibration gas	ppmv or %V
CE	Analyzer calibration error for the zero, mid-range, or high-range calibration gas	%
C_{mai}	Certified analysis concentration in the zero, mid-range, or high-range calibration gas	ppmv or %V
S	Effective span of the instrument (span gas concentration)	ppmv or %V

CO₂, O₂, SO₂, NO_x, or CO Measurement System Bias Check

$$CB = \frac{(C_s - C_a)}{S} \times 100\%$$

C_a	Analyzer response to the zero or upscale calibration gas	ppmv or %V
CB	Gas measurement system bias for the zero or upscale calibration gas	%
C_s	Gas measurement system response to the zero or upscale calibration gas	ppmv or %V
S	Effective span of the instrument (span gas concentration)	ppmv or %V

CO₂, O₂, SO₂, NO_x, or CO Measurement System Zero & Calibration Drift

$$CD = \frac{(C_{sf} - C_{si})}{S} \times 100\%$$

CD	Gas measurement system zero or calibration drift	%
C _{sf}	Final gas measurement system bias check response to the zero or upscale calibration gas	ppmv or %V
C _{si}	Initial gas measurement system bias check response to the zero or upscale calibration gas	ppmv or %V
S	Effective span of the instrument (span gas concentration)	ppmv or %V

Calibration Adjusted TGOC (as Propane) in the Stack or Duct Effluent

$$C_{TGOC} = (\bar{C}_{HC} - C_{zero}) \times \frac{C_{mida}}{(C_{mid} - C_{zero})}$$

\bar{C}_{HC}	Average TGOC analyzer output concentration as propane, wet-basis	ppmv
C _{mid}	Average of the initial and final TGOC measurement system responses to the mid-level propane calibration gas	ppmv
C _{mida}	Certified analysis concentration of propane in the mid-level calibration gas	ppmv
C _{TGOC}	Average calibration-adjusted TGOC as propane, wet-basis	ppmv
C _{zero}	Average of the initial and final TGOC measurement system responses to the zero calibration gas as propane	ppmv

TGOC Measurement System Zero & Calibration Drift

$$CD_{TGOC} = \frac{(C_f - C_i)}{S_{TGOC}} \times 100\%$$

CD _{TGOC}	TGOC measurement system zero or calibration drift	%
C _f	Final TGOC measurement system response to the zero or mid-level calibration gas as propane	ppmv
C _i	Initial TGOC measurement system response to the zero or mid-level calibration gas as propane	ppmv
S _{TGOC}	Span is the upper limit of the gas concentration measurement range specified for the affected source category, usually 1.5 to 2.5 times the applicable emission limit; or, if not specified, 1.5 to 2.5 times the expected concentration	ppmv

TGOC Measurement System Calibration Error

$$CE_{TGOC} = \frac{(C_p - C_r)}{C_{cert}} \times 100\%$$

C_{cert}	Certified analysis concentration of propane in the low-level or mid-level calibration gas	ppmv
CE_{TGOC}	TGOC measurement system calibration error	%
C_p	Predicted response to the low-level or mid-level calibration gas as propane	ppmv
C_r	TGOC measurement system response to the low-level or mid-level calibration gas as propane	ppmv

Dry Gas Sample Volume for Moisture (If Used)

$$V_m = V_f - V_i \quad V_{m(std)} = \frac{17.64 \times V_m \times Y \times \left(P_{bar} \pm \frac{E_{Mtr}}{1,000 \text{ ft}} + \frac{\Delta H}{13.6} \right)}{T_m}$$

E_{Mtr}	Dry gas meter elevation relative to the barometer	ft
P_{bar}	Barometric pressure at the barometer	in Hg
T_m	Average absolute dry gas meter temperature	° R
V_f	Final dry gas meter volume reading	ft ³
V_i	Initial dry gas meter volume reading	ft ³
V_m	Net dry gas meter volume, actual	ft ³
$V_{m(std)}$	Net dry gas meter volume at standard conditions	dscf
Y	Dry gas meter calibration correction factor	dimensionless
ΔH	Average orifice meter pressure-drop	in H ₂ O
13.6	Specific gravity of mercury relative to water	in H ₂ O/in Hg
17.64	Standard absolute temperature (527.67 ° R) divided by standard absolute pressure (760 mm Hg/25.4 mm/in)	° R/in Hg

Sampled Gas Stream Moisture (Water Vapor) Content (If Used)

$$V_{w(std)} = 0.04715 \times M_{lc} \quad B_{ws(Sample)} = \frac{V_{w(std)}}{V_{m(std)} + V_{w(std)}} \quad B_{ws(Sat)} = \frac{VP_{H_2O}}{P_s}$$

$$P_w = B_{ws} \times 100 \quad B_d = 1 - B_{ws}$$

B_d	Proportion of the dry gas by volume	dimensionless
B_{ws}	$B_{ws(Sample)}$ or $B_{ws(Sat)}$, whichever is less	dimensionless
$B_{ws(Sample)}$	Proportion of water vapor by volume determined with the sampling train	dimensionless
$B_{ws(Sat)}$	Proportion of water vapor by volume for a saturated or supersaturated gas stream	dimensionless
M_{lc}	Total mass of water collected in the sampling train	g
P_s	Absolute gas stream pressure	in Hg
P_w	Percent moisture (water vapor) in the gas stream	%V
$V_{m(std)}$	Net dry gas meter volume at standard conditions	dscf
$V_{w(std)}$	Equivalent volume of water vapor collected, at standard conditions	ft ³
VP_{H_2O}	Vapor pressure of water at gas stream temperature	in Hg
0.04715	Conversion factor for grams of water to cubic feet of water vapor at standard conditions	ft ³ /g

Gas Stream Moisture (Water Vapor) Content from Psychrometer Data (If Used)

$$e_a = VP_{Tw} - \frac{(P_a - VP_{Tw}) \times (T_d - T_w)}{2800 - 1.3 \times T_w} \quad B_{ws} = \frac{e_a}{P_s}$$

$$P_w = B_{ws} \times 100 \quad B_d = 1 - B_{ws}$$

B_d	Proportion of the dry gas by volume	dimensionless
B_{ws}	Proportion of water vapor by volume	dimensionless
e_a	Vapor pressure of water in the gas stream at the wet and dry bulb measurement location	in Hg
P_a	Absolute gas pressure at the wet and dry bulb location ($P_a = P_s$ if measurements are in-situ)	in Hg
P_s	Absolute gas stream pressure	in Hg
P_w	Percent moisture (water vapor) in the gas stream	%V
T_d	Dry bulb temperature in the gas stream	°F
T_w	Wet bulb temperature in the gas stream	°F
VP_{Tw}	Vapor pressure of water at the wet bulb temperature	in Hg

Gas Stream Absolute Pressure

$$P_s = P_{bar} \pm \frac{E_{stk}}{1,000 \text{ ft}} + \frac{P_g}{13.6}$$

E_{stk}	Sampling location elevation relative to the barometer	ft
P_{bar}	Barometric pressure at the barometer	in Hg
P_g	Gas stream static pressure	in H ₂ O
P_s	Absolute gas stream pressure	in Hg
13.6	Specific gravity of mercury relative to water	in H ₂ O/in Hg

Gas Molecular WeightFor Combustion Sources

$$\% N_2 = 100\% - (\% CO_2 + \% O_2)$$

$$M_d = 0.44 \times \% CO_2 + 0.32 \times \% O_2 + 0.28 \times \% N_2$$

$$M_s = M_d \times B_d + 18 \times B_{ws}$$

B_d	Proportion of the dry gas by volume	dimensionless
B_{ws}	Proportion of water vapor by volume	dimensionless
M_d	Molecular weight of the dry gas	lb/lb-mole
M_s	Molecular weight of the wet gas	lb/lb-mole
$\%CO_2$	Carbon dioxide concentration by volume, dry-basis	%V
$\%O_2$	Oxygen concentration by volume, dry-basis	%V
$\%N_2$	Nitrogen concentration by volume, dry-basis	%V
0.28	Molecular weight of nitrogen divided by 100	lb/lb-mole/100%
0.32	Molecular weight of oxygen divided by 100	lb/lb-mole/100%
0.44	Molecular weight of carbon dioxide divided by 100	lb/lb-mole/100%
18	Molecular weight of water	lb/lb-mole

For Ambient Air Sources

M_d	Molecular weight of dry ambient air	28.965 lb/lb-mole
-------	-------------------------------------	-------------------

Gas Stream Velocity

$$\Delta p = \left(\frac{\sum_{i=1}^n \sqrt{\Delta p_i}}{n} \right)^2 \quad v_s = 85.49 \times C_p \times \sqrt{\Delta p} \times \sqrt{\frac{T_s}{P_s \times M_s}} \times \frac{60 \text{ sec}}{1 \text{ min}}$$

C_p	Pitot tube coefficient	dimensionless
M_s	Molecular weight of the wet gas	lb/lb-mole
n	Number of traverse points sampled	
P_s	Absolute gas stream pressure	in Hg
T_s	Average absolute temperature of the gas stream	$^{\circ}\text{R}$
v_s	Average gas stream velocity	fpm
Δp	Average velocity head of the gas stream	in H_2O
Δp_i	Velocity head at sampling point i	in H_2O
85.49	Pitot tube constant	$\frac{\text{ft}}{\text{sec}} \left[\frac{(\text{lb/lb-mole})(\text{in Hg})}{(^{\circ}\text{R})(\text{in H}_2\text{O})} \right]^{1/2}$

Gas Stream Volumetric Flow Rate

$$A_s = \frac{D_1 \times D_2 \times \pi}{4} \times \frac{1 \text{ ft}^2}{144 \text{ in}^2} \text{ Circular Duct} \quad A_s = W_1 \times W_2 \times \frac{1 \text{ ft}^2}{144 \text{ in}^2} \text{ Rectangular Duct}$$

$$Q_{s[\text{acfm}]} = v_s \times A_s \quad Q_{s[\text{scfm}]} = \frac{17.64 \times Q_{s[\text{acfm}]} \times P_s}{T_s} \quad Q_{s[\text{dscfm}]} = Q_{s[\text{scfm}]} \times B_d$$

A_s	Cross sectional area of the stack or duct	ft^2
B_d	Proportion of the dry gas by volume	dimensionless
D_1	First internal diameter of the circular stack or duct	in
D_2	Second internal diameter of the circular stack or duct	in
P_s	Absolute gas stream pressure	in Hg
$Q_{s[\text{acfm}]}$	Gas stream flow rate at actual conditions	acfm
$Q_{s[\text{dscfm}]}$	Gas stream flow rate at dry standard conditions	dscfm
$Q_{s[\text{scfm}]}$	Gas stream flow rate at standard conditions	scfm
T_s	Average absolute temperature of the gas stream	$^{\circ}\text{R}$
v_s	Average gas stream velocity	fpm
W_1	First internal side of the rectangular stack or duct	in
W_2	Second internal side of the rectangular stack or duct	in
4	2 (radiuses per diameter) squared	
17.64	Standard absolute temperature (527.67 $^{\circ}\text{R}$) divided by standard absolute pressure (760 mm Hg/25.4 mm/in)	$^{\circ}\text{R/in Hg}$

Corrected Gaseous Pollutant (SO₂, NO_x, or CO) Concentration and Corrected TGOC

$$C_{gas(7\%O_2)} = C_{gas} \times \frac{20.9 - 7}{20.9 - \%O_2}$$

$$C_{gas(12\%CO_2)} = C_{gas} \times \frac{12}{\%CO_2}$$

$$C_{TGOC(7\%O_2)} = \frac{C_{TGOC}}{B_d} \times \frac{20.9 - 7}{20.9 - \%O_2}$$

$$C_{TGOC(12\%CO_2)} = \frac{C_{TGOC}}{B_d} \times \frac{12}{\%CO_2}$$

B _d	Proportion of the dry gas by volume	dimensionless
C _{gas}	Average calibration-adjusted effluent gas concentration, dry-basis	ppmv
C _{gas (7%O₂)}	Concentration of the gaseous pollutant on a dry basis, corrected to 7% oxygen	ppmv
C _{gas (12%CO₂)}	Concentration of the gaseous pollutant on a dry basis, corrected to 12% carbon dioxide	ppmv
C _{TGOC}	Average calibration-adjusted TGOC as propane, wet-basis	ppmv
C _{TGOC (7%O₂)}	TGOC as propane on a dry basis, corrected to 7% oxygen	ppmv
C _{TGOC (12%CO₂)}	TGOC as propane on a dry basis, corrected to 12% carbon dioxide	ppmv
%CO ₂	Carbon dioxide concentration by volume in the gas stream, dry-basis	%V
%O ₂	Oxygen concentration by volume in the gas stream, dry-basis	%V
7	Oxygen concentration standard	%V
12	Carbon dioxide concentration standard	%V
20.9	Oxygen concentration in dry air	%V

Gaseous Pollutant (SO₂, NO_x, or CO) Emission Rate

$$E_a = \frac{C_{gas} \text{ mL}}{1 \text{ m}^3} \times \frac{M_w \text{ g}}{\text{g} - \text{mol}} \times \frac{\text{g} - \text{mol}}{24.05515 \text{ L}} \times \frac{1 \text{ lb}}{453.59237 \text{ g}} \times \frac{1 \text{ L}}{10^3 \text{ mL}} \times Q_{s[dscfm]} \times \frac{0.3048^3 \text{ m}^3}{1 \text{ ft}^3} \times \frac{60 \text{ min}}{1 \text{ hr}}$$

C _{gas}	Average calibration-adjusted effluent gas concentration, dry-basis	ppmv (mL/m ³)
E _a	Emission rate of the gaseous pollutant	lb/hr
M _w	Molecular weight of the gaseous pollutant	g/g-mole
	Sulfur dioxide = 64.0638	
	Oxides of nitrogen as nitrogen dioxide = 46.0055	
	Carbon monoxide = 28.0101	
Q _{s [dscfm]}	Gas stream flow rate at dry standard conditions	dscfm

Total Gaseous Organic Emission Rate (as Propane)

$$E_p = \frac{C_{TGO C} \text{ mL}}{1 \text{ m}^3} \times \frac{M_w \text{ g}}{\text{g} - \text{mol}} \times \frac{\text{g} - \text{mol}}{24.05515 \text{ L}} \times \frac{1 \text{ lb}}{453.59237 \text{ g}} \times \frac{1 \text{ L}}{10^3 \text{ mL}} \times Q_{s [\text{scfm}]} \times \frac{0.3048^3 \text{ m}^3}{1 \text{ ft}^3} \times \frac{60 \text{ min}}{1 \text{ hr}}$$

$C_{TGO C}$	Average calibration-adjusted TGO C as propane, wet-basis	ppmv (mL/m ³)
E_p	Total gaseous organic emission rate as propane	lb/hr
M_w	Molecular weight of propane (44.09562)	g/g-mole
$Q_{s [\text{scfm}]}$	Gas stream flow rate at standard conditions	scfm

APPENDIX B

CALCULATED RESULTS

Appendix B-1

Particulate Results



Run Report - Particulate Matter

Project	Rain	Location	K-1 Stack
Project Number	4173	Method	EPA Methods 5 and 202
Test Date	July 20, 2023	Run No.	111

Stack or Duct Dimensions

<input checked="" type="radio"/> Circular <input type="radio"/> Rectangular		
Diameter # 1	in.	122.000
Diameter # 2	in.	122.000
Cross-Section Area	ft ²	81.180

Gas Stream Conditions

Avg. Gas Temperature	°F	496
Avg. Velocity Head (Δp)	in. H ₂ O	0.156
Static Gas Pressure	in. H ₂ O	0.00
Absolute Gas Pressure	in. Hg	29.28
O ₂ Concentration, Dry	%V	17.72
CO ₂ Concentration, Dry	%V	1.86
Moisture	%V	5.87
Dry Molecular Weight	lb/lb-mole	29.01
Wet Molecular Weight	lb/lb-mole	28.36

Sampling Conditions

Sampling Time	min	48.00
Avg. Nozzle Diameter	in.	0.431
Avg. Isokinetic Variation	%	93.3
IKV 90-110% Criterion	—	Pass

Dry Gas Meter Conditions

Console Elevation	ft	0
DGM Correction (Y)	—	1.015
Average ΔH	in. H ₂ O	2.89
Avg. DGM Temperature	°F	84.4
Initial DGM Volume	ft ³	669.700
Final DGM Volume	ft ³	713.000
Leak Check Volume	ft ³	-0.000
Leak Correction Volume	ft ³	
Net DGM Volume	ft ³	43.300
Dry Gas Sample Volume	dscf	42.169

Other Related Data

Barometer Reading	in. Hg	29.40
Test Location Elevation	ft	125
Pitot Tube Coefficient	—	0.840
Average SQRT(Δp)	in. H ₂ O	0.396

Volumetric Flow Rate Results

Average Gas Velocity	ft/min	1,829
Volumetric Flow, Actual	acfm	148,456
Corrected Flow, Wet	scfm	80,207
Corrected Flow, Dry	dscfm	75,497

Particulate Matter Emission Results

		Filterable	Condensable	Total
Total Particulate Matter Collected	mg	188.9	32.4	221.3
Concentration (Wet)	mg/acf	2.28	0.391	2.67
Concentration (Wet)	gr/acf	0.0352	6.03E-03	0.0412
Concentration (Dry)	mg/dscf	4.48	0.768	5.25
Concentration (Dry)	gr/dscf	0.0691	0.0119	0.0810
Emission Rate	lb/hr	44.7	7.67	52.4



Metric Equivalents - Particulate Matter

Project	Rain	Location	K-1 Stack
Project Number	4173	Method	EPA Methods 5 and 202
Test Date	July 20, 2023	Run No.	111

Stack or Duct Dimensions

<input checked="" type="radio"/> Circular <input type="radio"/> Rectangular		
Diameter # 1	m	3.0988
Diameter # 2	m	3.0988
Cross-Section Area	m ²	7.5418

Gas Stream Conditions

Avg. Gas Temperature	°C	258
Avg. Velocity Head (Δp)	mm H ₂ O	4.0
Static Gas Pressure	mm H ₂ O	0.0
Absolute Gas Pressure	mm Hg	743.6
O ₂ Concentration, Dry	%V	17.72
CO ₂ Concentration, Dry	%V	1.86
Moisture	%V	5.87
Dry Molecular Weight	g/g-mole	29.01
Wet Molecular Weight	g/g-mole	28.36

Sampling Conditions

Sampling Time	min	48.00
Avg. Nozzle Diameter	mm	10.95
Avg. Isokinetic Variation	%	93.3
IKV 90-110% Criterion	—	Pass

Dry Gas Meter Conditions

Console Elevation	m	0.0
DGM Correction (Y)	—	1.015
Average ΔH	mm H ₂ O	73.4
Avg. DGM Temperature	°C	29.1
Initial DGM Volume	m ³	18.96379
Final DGM Volume	m ³	20.18991
Leak Check Volume	m ³	-0.00000
Leak Correction Volume	m ³	
Net DGM Volume	m ³	1.22612
Dry Gas Sample Volume	dscm	1.19411

Other Related Data

Barometer Reading	mm Hg	746.8
Test Location Elevation	m	38.1
Pitot Tube Coefficient	—	0.840
Average SQRT(Δp)	mm H ₂ O	1.99

Volumetric Flow Rate Results

Average Gas Velocity	m/min	557.4
Volumetric Flow, Actual	acm/min	4,203.8
Corrected Flow, Wet	scm/min	2,271.21
Corrected Flow, Dry	dscm/min	2,137.83

Particulate Matter Emission Results

		Filterable	Condensable	Total
Total Particulate Matter Collected	mg	188.9	32.4	221.3
Concentration (Wet)	mg/acm	80.4	13.8	94.2
Concentration (Dry)	mg/dscm	158	27.1	185
Emission Rate	kg/hr	20.3	3.48	23.8



Traverse Data - Particulate Matter

Project	Rain	Location	K-1 Stack
Project Number	4173	Method	EPA Methods 5 and 202
Test Date	July 20, 2023	Run No.	111

Traverse Point	Gas Temp., °F	Δp in. H ₂ O	ΔH in. H ₂ O	DGM Inlet, °F	DGM Outlet, °F
A1	412	0.100	2.00	78	78
2	423	0.150	3.00	80	80
3	437	0.170	3.30	82	82
B1	444	0.100	1.90	83	83
2	481	0.140	2.60	84	84
3	507	0.180	3.20	85	85
C1	501	0.130	2.40	86	86
2	531	0.180	3.20	86	86
3	540	0.200	3.50	87	87
D1	530	0.120	2.10	86	86
2	569	0.210	3.60	88	88
3	575	0.230	3.90	88	88
Average	496	0.156	2.89	84.4	84.4

Leak Check Volumes

Initial					
Final					
Difference					



Filterable Particulate Matter and Moisture Analysis

Project	Rain	Location	K-1 Stack
Project Number	4173	Method	EPA Methods 5 and 202
Test Date	July 20, 2023	Run No.	111

Impinger Weights

		Initial	Final	Difference
Condenser & Knockout	g	643.9	672.5	28.6
CPM Impinger	g	465.3	465.3	0.0
H ₂ O Impinger	g	693.0	695.2	2.2
H ₂ O Impinger	g			
Silica Gel	g	714.2	739.2	25.0
Total Collected			g	55.8

Moisture Results

Moisture Volume	scf	2.631
Dry Gas Sample Volume	dscf	42.169
Sampled Moisture	%V	5.87
Saturation Moisture	%V	N/A
Reported Moisture	%V	5.87

Rinse Reagent

☒ Acetone ☐ Water

Sampling Train Front-half Rinses

Container Gross Wt.	g	294.6
Container Empty Wt.	g	165.5
Sample Volume	mLs	163.4
Evap. Beaker No.	C22-8-36	
Beaker Tare Weight	g	30.0453
Beaker Final Weight	g	30.0937
Blank Correction	mg	-0.1
Net Weight	mg	48.3

Acetone Field Reagent Blank

Container Gross Wt.	g	300.5
Container Empty Wt.	g	166.9
Reagent Blank Volume	mLs	169.1
Evap. Beaker No.	C22-8-29	
Beaker Tare Weight	g	28.8716
Beaker Final Weight	g	28.8717
Residue Weight	mg	0.1
Blank Concentration	mg/mL	0.0006

Dry Catch and Filter Weights

Filter No.	F23-7-1	
Filter Tare Weight	g	37.3182
Filter Final Weight	g	37.4588
Filter Blank	g	NA
Net Weight	mg	140.6

Filter Blank

☒ Not Used ☐ Used

Filter No.		
Filter Tare Weight	g	
Filter Final Weight	g	

Total Filterable Particulate Matter

Total Weight	mg	188.9
--------------	----	-------



Condensable Particulate Matter Analysis

Project	Rain	Location	K-1 Stack
Project Number	4173	Method	EPA Methods 5 and 202
Test Date	July 20, 2023	Run No.	111

Hexane Field Reagent Blank

Container Gross Wt.	g	344.6
Container Empty Wt.	g	165.8
Reagent Blank Volume	mLs	269.7
Evap. Beaker No.	C22-8-30	
Beaker Tare Weight	g	29.9420
Beaker Final Weight	g	29.9428
Residue Weight	mg	0.8

Water Field Reagent Blank

Container Gross Wt.	g	261.0
Container Empty Wt.	g	164.4
Water Blank Volume	mLs	96.8
Evap. Beaker No.	C22-8-31	
Beaker Tare Weight	g	30.5884
Beaker Final Weight	g	30.5885
Residue Weight	mg	0.1

Field Train Recovery (FTR) Blank

Organic Fraction

Container Gross Wt.	g	557.0
Container Empty Wt.	g	297.0
Sample Wt.	g	260.0
Evap. Beaker No.	C22-8-35	
Beaker Tare Weight	g	29.9567
Beaker Final Weight	g	29.9575
Net Weight	mg	0.8

Mass of NH₄⁺ Added To Sample

NH ₄ OH Normality	meq/mL	0.0000
Titrat Volume Used	mLs	0.0
NH ₄ ⁺ added to Sample	mg	0.0

Total Condensable Particulate Matter

Total FTR Blank CPM	mg	3.5
---------------------	----	-----

Inorganic Fraction

Container Gross Wt.	g	763.5
Container Empty Wt.	g	504.1
Sample Wt.	g	259.4
Evap. Beaker No.	C22-8-34	
Beaker Tare Weight	g	29.5305
Beaker Final Weight	g	29.5332
Less NH ₄ ⁺ in Sample	mg	0.0
Net Weight	mg	2.7

Filter Weights

Filter No.	NA	
Filter Tare Weight	g	0.0
Filter Final Weight	g	0.0
Net Weight	mg	0.0

CPM Sampling Train

Organic Fraction

Container Gross Wt.	g	926.0
Container Empty Wt.	g	503.9
Sample Wt.	g	422.1
Evap. Beaker No.	C22-10-21	
Beaker Tare Weight	g	1.5955
Beaker Final Weight	g	1.6258
Net Weight	mg	30.3

Mass of NH₄⁺ Added To Sample

NH ₄ OH Normality	meq/mL	0.0000
Titrat Volume Used	mLs	0.0
NH ₄ ⁺ added to Sample	mg	0.0

Total Condensable Particulate Matter

Total CPM Weight	mg	34.4
Blank Correction Used	mg	-2.0
Corrected CPM Weight	mg	32.4

Inorganic Fraction

Container Gross Wt.	g	571.4
Container Empty Wt.	g	294.8
Sample Wt.	g	276.6
Evap. Beaker No.	C22-8-37	
Beaker Tare Weight	g	28.6473
Beaker Final Weight	g	28.6514
Less NH ₄ ⁺ in Sample	mg	0.0
Net Weight	mg	4.1

Filter Weights

Filter No.	NA	
Filter Tare Weight	g	0.0
Filter Final Weight	g	0.0
Net Weight	mg	0.0

FTR Blank CPM was >2.0 mg.



Run Report - Particulate Matter

Project	Rain	Location	K-1 Stack
Project Number	4173	Method	EPA Methods 5 and 202
Test Date	July 20, 2023	Run No.	112

Stack or Duct Dimensions

<input checked="" type="radio"/> Circular <input type="radio"/> Rectangular		
Diameter # 1	in.	122.000
Diameter # 2	in.	122.000
Cross-Section Area	ft ²	81.180

Gas Stream Conditions

Avg. Gas Temperature	°F	702
Avg. Velocity Head (Δp)	in. H ₂ O	0.172
Static Gas Pressure	in. H ₂ O	0.00
Absolute Gas Pressure	in. Hg	29.27
O ₂ Concentration, Dry	%V	15.90
CO ₂ Concentration, Dry	%V	3.04
Moisture	%V	21.22
Dry Molecular Weight	lb/lb-mole	29.12
Wet Molecular Weight	lb/lb-mole	26.76

Sampling Conditions

Sampling Time	min	48.00
Avg. Nozzle Diameter	in.	0.365
Avg. Isokinetic Variation	%	111.5
IKV 90-110% Criterion	—	Fail

Dry Gas Meter Conditions

Console Elevation	ft	0
DGM Correction (Y)	—	1.015
Average ΔH	in. H ₂ O	1.39
Avg. DGM Temperature	°F	89.5
Initial DGM Volume	ft ³	728.302
Final DGM Volume	ft ³	759.150
Leak Check Volume	ft ³	-0.000
Leak Correction Volume	ft ³	
Net DGM Volume	ft ³	30.848
Dry Gas Sample Volume	dscf	29.644

Other Related Data

Barometer Reading	in. Hg	29.39
Test Location Elevation	ft	125
Pitot Tube Coefficient	—	0.840
Average SQRT(Δp)	in. H ₂ O	0.415

Volumetric Flow Rate Results

Average Gas Velocity	ft/min	2,177
Volumetric Flow, Actual	acfm	176,756
Corrected Flow, Wet	scfm	78,537
Corrected Flow, Dry	dscfm	61,875

Particulate Matter Emission Results

		Filterable	Condensable	Total
Total Particulate Matter Collected	mg	116.7	58.3	175.0
Concentration (Wet)	mg/acf	1.38	0.688	2.07
Concentration (Wet)	gr/acf	0.0213	0.0106	0.0319
Concentration (Dry)	mg/dscf	3.94	1.97	5.90
Concentration (Dry)	gr/dscf	0.0608	0.0304	0.0911
Emission Rate	lb/hr	32.2	16.1	48.3



Metric Equivalents - Particulate Matter

Project	Rain	Location	K-1 Stack
Project Number	4173	Method	EPA Methods 5 and 202
Test Date	July 20, 2023	Run No.	112

Stack or Duct Dimensions

<input checked="" type="radio"/> Circular <input type="radio"/> Rectangular		
Diameter # 1	m	3.0988
Diameter # 2	m	3.0988
Cross-Section Area	m ²	7.5418

Gas Stream Conditions

Avg. Gas Temperature	°C	372
Avg. Velocity Head (Δp)	mm H ₂ O	4.4
Static Gas Pressure	mm H ₂ O	0.0
Absolute Gas Pressure	mm Hg	743.3
O ₂ Concentration, Dry	%V	15.90
CO ₂ Concentration, Dry	%V	3.04
Moisture	%V	21.22
Dry Molecular Weight	g/g-mole	29.12
Wet Molecular Weight	g/g-mole	26.76

Sampling Conditions

Sampling Time	min	48.00
Avg. Nozzle Diameter	mm	9.27
Avg. Isokinetic Variation	%	111.5
IKV 90-110% Criterion	—	Fail

Dry Gas Meter Conditions

Console Elevation	m	0.0
DGM Correction (Y)	—	1.015
Average ΔH	mm H ₂ O	35.3
Avg. DGM Temperature	°C	31.9
Initial DGM Volume	m ³	20.62322
Final DGM Volume	m ³	21.49673
Leak Check Volume	m ³	-0.00000
Leak Correction Volume	m ³	
Net DGM Volume	m ³	0.87352
Dry Gas Sample Volume	dscm	0.83942

Other Related Data

Barometer Reading	mm Hg	746.5
Test Location Elevation	m	38.1
Pitot Tube Coefficient	—	0.840
Average SQRT(Δp)	mm H ₂ O	2.09

Volumetric Flow Rate Results

Average Gas Velocity	m/min	663.7
Volumetric Flow, Actual	acm/min	5,005.2
Corrected Flow, Wet	scm/min	2,223.93
Corrected Flow, Dry	dscm/min	1,752.12

Particulate Matter Emission Results

		Filterable	Condensable	Total
Total Particulate Matter Collected	mg	116.7	58.3	175.0
Concentration (Wet)	mg/acm	48.7	24.3	73.0
Concentration (Dry)	mg/dscm	139	69.5	208
Emission Rate	kg/hr	14.6	7.30	21.9



Traverse Data - Particulate Matter

Project	Rain	Location	K-1 Stack
Project Number	4173	Method	EPA Methods 5 and 202
Test Date	July 20, 2023	Run No.	112

Traverse Point	Gas Temp., °F	Δp in. H ₂ O	ΔH in. H ₂ O	DGM Inlet, °F	DGM Outlet, °F
A1	676	0.140	1.10	86	86
2	688	0.220	1.80	88	88
3	695	0.240	1.90	89	89
B1	648	0.120	1.00	87	87
2	692	0.180	1.40	89	89
3	702	0.200	1.60	91	91
C1	672	0.130	1.00	89	89
2	703	0.160	1.30	91	91
3	707	0.170	1.40	91	91
D1	789	0.130	1.00	91	91
2	724	0.200	1.60	91	91
3	726	0.200	1.60	91	91
Average	702	0.172	1.39	89.5	89.5

Leak Check Volumes

Initial					
Final					
Difference					



Filterable Particulate Matter and Moisture Analysis

Project	Rain	Location	K-1 Stack
Project Number	4173	Method	EPA Methods 5 and 202
Test Date	July 20, 2023	Run No.	112

Impinger Weights

		Initial	Final	Difference
Condenser & Knockout	g	783.0	933.6	150.6
CPM Impinger	g	549.7	549.8	0.1
H ₂ O Impinger	g	559.9	549.0	-10.9
H ₂ O Impinger	g			
Silica Gel	g	714.9	744.4	29.5
Total Collected			g	169.3

Moisture Results

Moisture Volume	scf	7.982
Dry Gas Sample Volume	dscf	29.644
Sampled Moisture	%V	21.22
Saturation Moisture	%V	N/A
Reported Moisture	%V	21.22

Rinse Reagent

☒ Acetone ☐ Water

Sampling Train Front-half Rinses

Container Gross Wt.	g	303.1
Container Empty Wt.	g	167.1
Sample Volume	mLs	172.2
Evap. Beaker No.	C22-8-38	
Beaker Tare Weight	g	29.0256
Beaker Final Weight	g	29.0715
Blank Correction	mg	-0.1
Net Weight	mg	45.8

Acetone Field Reagent Blank

Container Gross Wt.	g	300.5
Container Empty Wt.	g	166.9
Reagent Blank Volume	mLs	169.1
Evap. Beaker No.	C22-8-29	
Beaker Tare Weight	g	28.8716
Beaker Final Weight	g	28.8717
Residue Weight	mg	0.1
Blank Concentration	mg/mL	0.0006

Dry Catch and Filter Weights

Filter No.	F22-9-9	
Filter Tare Weight	g	30.3950
Filter Final Weight	g	30.4659
Filter Blank	g	NA
Net Weight	mg	70.9

Filter Blank

☒ Not Used ☐ Used

Filter No.		
Filter Tare Weight	g	
Filter Final Weight	g	

Total Filterable Particulate Matter

Total Weight	mg	116.7
--------------	----	-------



Condensable Particulate Matter Analysis

Project	Rain	Location	K-1 Stack
Project Number	4173	Method	EPA Methods 5 and 202
Test Date	July 20, 2023	Run No.	112

Hexane Field Reagent Blank

Container Gross Wt.	g	344.6
Container Empty Wt.	g	165.8
Reagent Blank Volume	mLs	269.7
Evap. Beaker No.	C22-8-30	
Beaker Tare Weight	g	29.9420
Beaker Final Weight	g	29.9428
Residue Weight	mg	0.8

Water Field Reagent Blank

Container Gross Wt.	g	261.0
Container Empty Wt.	g	164.4
Water Blank Volume	mLs	96.8
Evap. Beaker No.	C22-8-31	
Beaker Tare Weight	g	30.5884
Beaker Final Weight	g	30.5885
Residue Weight	mg	0.1

Field Train Recovery (FTR) Blank

Organic Fraction

Container Gross Wt.	g	557.0
Container Empty Wt.	g	297.0
Sample Wt.	g	260.0
Evap. Beaker No.	C22-8-35	
Beaker Tare Weight	g	29.9567
Beaker Final Weight	g	29.9575
Net Weight	mg	0.8

Mass of NH₄⁺ Added To Sample

NH ₄ OH Normality	meq/mL	0.0000
Titrat Volume Used	mLs	0.0
NH ₄ ⁺ added to Sample	mg	0.0

Total Condensable Particulate Matter

Total FTR Blank CPM	mg	3.5
---------------------	----	-----

Inorganic Fraction

Container Gross Wt.	g	763.5
Container Empty Wt.	g	504.1
Sample Wt.	g	259.4
Evap. Beaker No.	C22-8-34	
Beaker Tare Weight	g	29.5305
Beaker Final Weight	g	29.5332
Less NH ₄ ⁺ in Sample	mg	0.0
Net Weight	mg	2.7

Filter Weights

Filter No.	NA	
Filter Tare Weight	g	0.0
Filter Final Weight	g	0.0
Net Weight	mg	0.0

CPM Sampling Train

Organic Fraction

Container Gross Wt.	g	932.6
Container Empty Wt.	g	505.7
Sample Wt.	g	426.9
Evap. Beaker No.	C22-10-22	
Beaker Tare Weight	g	1.5904
Beaker Final Weight	g	1.6476
Net Weight	mg	57.2

Mass of NH₄⁺ Added To Sample

NH ₄ OH Normality	meq/mL	0.0000
Titrat Volume Used	mLs	0.0
NH ₄ ⁺ added to Sample	mg	0.0

Total Condensable Particulate Matter

Total CPM Weight	mg	60.3
Blank Correction Used	mg	-2.0
Corrected CPM Weight	mg	58.3

Inorganic Fraction

Container Gross Wt.	g	579.4
Container Empty Wt.	g	298.2
Sample Wt.	g	281.2
Evap. Beaker No.	C22-8-39	
Beaker Tare Weight	g	30.8864
Beaker Final Weight	g	30.8895
Less NH ₄ ⁺ in Sample	mg	0.0
Net Weight	mg	3.1

Filter Weights

Filter No.	NA	
Filter Tare Weight	g	0.0
Filter Final Weight	g	0.0
Net Weight	mg	0.0

FTR Blank CPM was >2.0 mg.



Run Report - Particulate Matter

Project	Rain	Location	K-1 Stack
Project Number	4173	Method	EPA Methods 5 and 202
Test Date	July 20, 2023	Run No.	113

Stack or Duct Dimensions

<input checked="" type="radio"/> Circular <input type="radio"/> Rectangular		
Diameter # 1	in.	122.000
Diameter # 2	in.	122.000
Cross-Section Area	ft ²	81.180

Gas Stream Conditions

Avg. Gas Temperature	°F	760
Avg. Velocity Head (Δp)	in. H ₂ O	0.157
Static Gas Pressure	in. H ₂ O	0.00
Absolute Gas Pressure	in. Hg	29.25
O ₂ Concentration, Dry	%V	16.07
CO ₂ Concentration, Dry	%V	3.16
Moisture	%V	21.82
Dry Molecular Weight	lb/lb-mole	29.15
Wet Molecular Weight	lb/lb-mole	26.72

Sampling Conditions

Sampling Time	min	48.00
Avg. Nozzle Diameter	in.	0.376
Avg. Isokinetic Variation	%	102.7
IKV 90-110% Criterion	—	Pass

Dry Gas Meter Conditions

Console Elevation	ft	0
DGM Correction (Y)	—	1.015
Average ΔH	in. H ₂ O	1.35
Avg. DGM Temperature	°F	89.2
Initial DGM Volume	ft ³	759.510
Final DGM Volume	ft ³	787.400
Leak Check Volume	ft ³	-0.000
Leak Correction Volume	ft ³	
Net DGM Volume	ft ³	27.890
Dry Gas Sample Volume	dscf	26.796

Other Related Data

Barometer Reading	in. Hg	29.37
Test Location Elevation	ft	125
Pitot Tube Coefficient	—	0.840
Average SQRT(Δp)	in. H ₂ O	0.396

Volumetric Flow Rate Results

Average Gas Velocity	ft/min	2,133
Volumetric Flow, Actual	acfm	173,133
Corrected Flow, Wet	scfm	73,204
Corrected Flow, Dry	dscfm	57,232

Particulate Matter Emission Results

		Filterable	Condensable	Total
Total Particulate Matter Collected	mg	117.2	51.1	168.3
Concentration (Wet)	mg/acf	1.45	0.630	2.08
Concentration (Wet)	gr/acf	0.0223	9.73E-03	0.0320
Concentration (Dry)	mg/dscf	4.37	1.91	6.28
Concentration (Dry)	gr/dscf	0.0675	0.0294	0.0969
Emission Rate	lb/hr	33.1	14.4	47.5



Metric Equivalents - Particulate Matter

Project	Rain	Location	K-1 Stack
Project Number	4173	Method	EPA Methods 5 and 202
Test Date	July 20, 2023	Run No.	113

Stack or Duct Dimensions

<input checked="" type="radio"/> Circular <input type="radio"/> Rectangular		
Diameter # 1	m	3.0988
Diameter # 2	m	3.0988
Cross-Section Area	m ²	7.5418

Gas Stream Conditions

Avg. Gas Temperature	°C	404
Avg. Velocity Head (Δp)	mm H ₂ O	4.0
Static Gas Pressure	mm H ₂ O	0.0
Absolute Gas Pressure	mm Hg	742.8
O ₂ Concentration, Dry	%V	16.07
CO ₂ Concentration, Dry	%V	3.16
Moisture	%V	21.82
Dry Molecular Weight	g/g-mole	29.15
Wet Molecular Weight	g/g-mole	26.72

Sampling Conditions

Sampling Time	min	48.00
Avg. Nozzle Diameter	mm	9.55
Avg. Isokinetic Variation	%	102.7
IKV 90-110% Criterion	—	Pass

Dry Gas Meter Conditions

Console Elevation	m	0.0
DGM Correction (Y)	—	1.015
Average ΔH	mm H ₂ O	34.4
Avg. DGM Temperature	°C	31.8
Initial DGM Volume	m ³	21.50693
Final DGM Volume	m ³	22.29669
Leak Check Volume	m ³	-0.00000
Leak Correction Volume	m ³	
Net DGM Volume	m ³	0.78976
Dry Gas Sample Volume	dscm	0.75878

Other Related Data

Barometer Reading	mm Hg	746.0
Test Location Elevation	m	38.1
Pitot Tube Coefficient	—	0.840
Average SQRT(Δp)	mm H ₂ O	2.00

Volumetric Flow Rate Results

Average Gas Velocity	m/min	650.1
Volumetric Flow, Actual	acm/min	4,902.6
Corrected Flow, Wet	scm/min	2,072.92
Corrected Flow, Dry	dscm/min	1,620.64

Particulate Matter Emission Results

		Filterable	Condensable	Total
Total Particulate Matter Collected	mg	117.2	51.1	168.3
Concentration (Wet)	mg/acm	51.1	22.3	73.3
Concentration (Dry)	mg/dscm	154	67.3	222
Emission Rate	kg/hr	15.0	6.55	21.6



Traverse Data - Particulate Matter

Project	Rain	Location	K-1 Stack
Project Number	4173	Method	EPA Methods 5 and 202
Test Date	July 20, 2023	Run No.	113

Traverse Point	Gas Temp., °F	Δp in. H ₂ O	ΔH in. H ₂ O	DGM Inlet, °F	DGM Outlet, °F
A1	740	0.120	1.00	87	87
2	756	0.200	1.70	88	88
3	761	0.220	1.90	88	88
B1	746	0.130	1.10	89	89
2	761	0.150	1.30	89	89
3	764	0.170	1.40	90	90
C1	753	0.080	0.70	90	90
2	756	0.140	1.20	90	90
3	778	0.160	1.30	90	90
D1	758	0.150	1.30	89	89
2	788	0.240	2.00	91	91
3					
Average	760	0.157	1.35	89.2	89.2

Leak Check Volumes

Initial					
Final					
Difference					



Filterable Particulate Matter and Moisture Analysis

Project	Rain	Location	K-1 Stack
Project Number	4173	Method	EPA Methods 5 and 202
Test Date	July 20, 2023	Run No.	113

Impinger Weights

		Initial	Final	Difference
Condenser & Knockout	g	647.9	778.5	130.6
CPM Impinger	g	511.8	512.0	0.2
H ₂ O Impinger	g	637.1	643.2	6.1
H ₂ O Impinger	g			
Silica Gel	g	834.5	856.2	21.7
Total Collected		g		158.6

Moisture Results

Moisture Volume	scf	7.478
Dry Gas Sample Volume	dscf	26.796
Sampled Moisture	%V	21.82
Saturation Moisture	%V	N/A
Reported Moisture	%V	21.82

Rinse Reagent

☒ Acetone ☐ Water

Sampling Train Front-half Rinses

Container Gross Wt.	g	296.5
Container Empty Wt.	g	167.5
Sample Volume	mLs	163.3
Evap. Beaker No.	C22-8-40	
Beaker Tare Weight	g	30.2974
Beaker Final Weight	g	30.3450
Blank Correction	mg	-0.1
Net Weight	mg	47.5

Acetone Field Reagent Blank

Container Gross Wt.	g	300.5
Container Empty Wt.	g	166.9
Reagent Blank Volume	mLs	169.1
Evap. Beaker No.	C22-8-29	
Beaker Tare Weight	g	28.8716
Beaker Final Weight	g	28.8717
Residue Weight	mg	0.1
Blank Concentration	mg/mL	0.0006

Dry Catch and Filter Weights

Filter No.	F22-9-10	
Filter Tare Weight	g	34.5761
Filter Final Weight	g	34.6458
Filter Blank	g	NA
Net Weight	mg	69.7

Filter Blank

☒ Not Used ☐ Used

Filter No.		
Filter Tare Weight	g	
Filter Final Weight	g	

Total Filterable Particulate Matter

Total Weight	mg	117.2
--------------	----	-------



Condensable Particulate Matter Analysis

Project	Rain	Location	K-1 Stack
Project Number	4173	Method	EPA Methods 5 and 202
Test Date	July 20, 2023	Run No.	113

Hexane Field Reagent Blank

Container Gross Wt.	g	344.6
Container Empty Wt.	g	165.8
Reagent Blank Volume	mLs	269.7
Evap. Beaker No.	C22-8-30	
Beaker Tare Weight	g	29.9420
Beaker Final Weight	g	29.9428
Residue Weight	mg	0.8

Water Field Reagent Blank

Container Gross Wt.	g	261.0
Container Empty Wt.	g	164.4
Water Blank Volume	mLs	96.8
Evap. Beaker No.	C22-8-31	
Beaker Tare Weight	g	30.5884
Beaker Final Weight	g	30.5885
Residue Weight	mg	0.1

Field Train Recovery (FTR) Blank

Organic Fraction

Container Gross Wt.	g	557.0
Container Empty Wt.	g	297.0
Sample Wt.	g	260.0
Evap. Beaker No.	C22-8-35	
Beaker Tare Weight	g	29.9567
Beaker Final Weight	g	29.9575
Net Weight	mg	0.8

Mass of NH₄⁺ Added To Sample

NH ₄ OH Normality	meq/mL	0.0000
Titrat Volume Used	mLs	0.0
NH ₄ ⁺ added to Sample	mg	0.0

Total Condensable Particulate Matter

Total FTR Blank CPM	mg	3.5
---------------------	----	-----

Inorganic Fraction

Container Gross Wt.	g	763.5
Container Empty Wt.	g	504.1
Sample Wt.	g	259.4
Evap. Beaker No.	C22-8-34	
Beaker Tare Weight	g	29.5305
Beaker Final Weight	g	29.5332
Less NH ₄ ⁺ in Sample	mg	0.0
Net Weight	mg	2.7

Filter Weights

Filter No.	NA	
Filter Tare Weight	g	0.0
Filter Final Weight	g	0.0
Net Weight	mg	0.0

CPM Sampling Train

Organic Fraction

Container Gross Wt.	g	916.1
Container Empty Wt.	g	506.0
Sample Wt.	g	410.1
Evap. Beaker No.	C22-10-23	
Beaker Tare Weight	g	1.6017
Beaker Final Weight	g	1.6512
Net Weight	mg	49.5

Mass of NH₄⁺ Added To Sample

NH ₄ OH Normality	meq/mL	0.0000
Titrat Volume Used	mLs	0.0
NH ₄ ⁺ added to Sample	mg	0.0

Total Condensable Particulate Matter

Total CPM Weight	mg	53.1
Blank Correction Used	mg	-2.0
Corrected CPM Weight	mg	51.1

Inorganic Fraction

Container Gross Wt.	g	575.7
Container Empty Wt.	g	297.5
Sample Wt.	g	278.2
Evap. Beaker No.	C22-8-73	
Beaker Tare Weight	g	29.4557
Beaker Final Weight	g	29.4593
Less NH ₄ ⁺ in Sample	mg	0.0
Net Weight	mg	3.6

Filter Weights

Filter No.	NA	
Filter Tare Weight	g	0.0
Filter Final Weight	g	0.0
Net Weight	mg	0.0

FTR Blank CPM was >2.0 mg.



Run Report - Particulate Matter

Project	Rain	Location	K-1 Stack
Project Number	4173	Method	EPA Methods 5 and 202
Test Date	July 20, 2023	Run No.	114

Stack or Duct Dimensions

<input checked="" type="radio"/> Circular <input type="radio"/> Rectangular		
Diameter # 1	in.	122.000
Diameter # 2	in.	122.000
Cross-Section Area	ft ²	81.180

Gas Stream Conditions

Avg. Gas Temperature	°F	847
Avg. Velocity Head (Δp)	in. H ₂ O	0.167
Static Gas Pressure	in. H ₂ O	0.00
Absolute Gas Pressure	in. Hg	29.19
O ₂ Concentration, Dry	%V	15.33
CO ₂ Concentration, Dry	%V	3.65
Moisture	%V	18.76
Dry Molecular Weight	lb/lb-mole	29.20
Wet Molecular Weight	lb/lb-mole	27.10

Sampling Conditions

Sampling Time	min	48.00
Avg. Nozzle Diameter	in.	0.388
Avg. Isokinetic Variation	%	108.8
IKV 90-110% Criterion	—	Pass

Dry Gas Meter Conditions

Console Elevation	ft	0
DGM Correction (Y)	—	1.015
Average ΔH	in. H ₂ O	1.53
Avg. DGM Temperature	°F	88.0
Initial DGM Volume	ft ³	787.750
Final DGM Volume	ft ³	820.000
Leak Check Volume	ft ³	-0.000
Leak Correction Volume	ft ³	
Net DGM Volume	ft ³	32.250
Dry Gas Sample Volume	dscf	31.003

Other Related Data

Barometer Reading	in. Hg	29.31
Test Location Elevation	ft	125
Pitot Tube Coefficient	—	0.840
Average SQRT(Δp)	in. H ₂ O	0.408

Volumetric Flow Rate Results

Average Gas Velocity	ft/min	2,261
Volumetric Flow, Actual	acfm	183,552
Corrected Flow, Wet	scfm	72,282
Corrected Flow, Dry	dscfm	58,725

Particulate Matter Emission Results

		Filterable	Condensable	Total
Total Particulate Matter Collected	mg	176.2	89.5	265.7
Concentration (Wet)	mg/acf	1.82	0.924	2.74
Concentration (Wet)	gr/acf	0.0281	0.0143	0.0423
Concentration (Dry)	mg/dscf	5.68	2.89	8.57
Concentration (Dry)	gr/dscf	0.0877	0.0446	0.132
Emission Rate	lb/hr	44.1	22.4	66.6



Metric Equivalents - Particulate Matter

Project	Rain	Location	K-1 Stack
Project Number	4173	Method	EPA Methods 5 and 202
Test Date	July 20, 2023	Run No.	114

Stack or Duct Dimensions

<input checked="" type="radio"/> Circular <input type="radio"/> Rectangular		
Diameter # 1	m	3.0988
Diameter # 2	m	3.0988
Cross-Section Area	m ²	7.5418

Gas Stream Conditions

Avg. Gas Temperature	°C	453
Avg. Velocity Head (Δp)	mm H ₂ O	4.2
Static Gas Pressure	mm H ₂ O	0.0
Absolute Gas Pressure	mm Hg	741.3
O ₂ Concentration, Dry	%V	15.33
CO ₂ Concentration, Dry	%V	3.65
Moisture	%V	18.76
Dry Molecular Weight	g/g-mole	29.20
Wet Molecular Weight	g/g-mole	27.10

Sampling Conditions

Sampling Time	min	48.00
Avg. Nozzle Diameter	mm	9.86
Avg. Isokinetic Variation	%	108.8
IKV 90-110% Criterion	—	Pass

Dry Gas Meter Conditions

Console Elevation	m	0.0
DGM Correction (Y)	—	1.015
Average ΔH	mm H ₂ O	38.9
Avg. DGM Temperature	°C	31.1
Initial DGM Volume	m ³	22.30660
Final DGM Volume	m ³	23.21981
Leak Check Volume	m ³	-0.00000
Leak Correction Volume	m ³	
Net DGM Volume	m ³	0.91322
Dry Gas Sample Volume	dscm	0.87789

Other Related Data

Barometer Reading	mm Hg	744.5
Test Location Elevation	m	38.1
Pitot Tube Coefficient	—	0.840
Average SQRT(Δp)	mm H ₂ O	2.06

Volumetric Flow Rate Results

Average Gas Velocity	m/min	689.2
Volumetric Flow, Actual	acm/min	5,197.6
Corrected Flow, Wet	scm/min	2,046.80
Corrected Flow, Dry	dscm/min	1,662.90

Particulate Matter Emission Results

		Filterable	Condensable	Total
Total Particulate Matter Collected	mg	176.2	89.5	265.7
Concentration (Wet)	mg/acm	64.2	32.6	96.8
Concentration (Dry)	mg/dscm	201	102	303
Emission Rate	kg/hr	20.0	10.2	30.2



Traverse Data - Particulate Matter

Project	Rain	Location	K-1 Stack
Project Number	4173	Method	EPA Methods 5 and 202
Test Date	July 20, 2023	Run No.	114

Traverse Point	Gas Temp., °F	Δp in. H ₂ O	ΔH in. H ₂ O	DGM Inlet, °F	DGM Outlet, °F
A1	814	0.130	1.20	84	84
2	842	0.240	2.10	84	84
3	845	0.250	2.20	87	87
B1	813	0.200	1.80	86	86
2	845	0.050	0.50	88	88
3	853	0.200	1.80	88	88
C1	835	0.100	0.90	89	89
2	850	0.150	1.40	89	89
3	852	0.180	1.60	90	90
D1	861	0.140	1.20	90	90
2	877	0.210	1.80	90	90
3	881	0.220	1.90	91	91
Average	847	0.167	1.53	88.0	88.0

Leak Check Volumes

Initial					
Final					
Difference					



Filterable Particulate Matter and Moisture Analysis

Project	Rain	Location	K-1 Stack
Project Number	4173	Method	EPA Methods 5 and 202
Test Date	July 20, 2023	Run No.	114

Impinger Weights

		Initial	Final	Difference
Condenser & Knockout	g	648.5	798.0	149.5
CPM Impinger	g	579.9	579.9	0.0
H ₂ O Impinger	g	691.8	689.1	-2.7
H ₂ O Impinger	g			
Silica Gel	g	653.8	658.8	5.0
Total Collected		g		151.8

Moisture Results

Moisture Volume	scf	7.157
Dry Gas Sample Volume	dscf	31.003
Sampled Moisture	%V	18.76
Saturation Moisture	%V	N/A
Reported Moisture	%V	18.76

Rinse Reagent

☒ Acetone ☐ Water

Sampling Train Front-half Rinses

Container Gross Wt.	g	291.5
Container Empty Wt.	g	165.7
Sample Volume	mLs	159.2
Evap. Beaker No.	C22-8-74	
Beaker Tare Weight	g	29.6651
Beaker Final Weight	g	29.7389
Blank Correction	mg	-0.1
Net Weight	mg	73.7

Acetone Field Reagent Blank

Container Gross Wt.	g	300.5
Container Empty Wt.	g	166.9
Reagent Blank Volume	mLs	169.1
Evap. Beaker No.	C22-8-29	
Beaker Tare Weight	g	28.8716
Beaker Final Weight	g	28.8717
Residue Weight	mg	0.1
Blank Concentration	mg/mL	0.0006

Dry Catch and Filter Weights

Filter No.	F23-7-2	
Filter Tare Weight	g	29.3093
Filter Final Weight	g	29.4118
Filter Blank	g	NA
Net Weight	mg	102.5

Filter Blank

☒ Not Used ☐ Used

Filter No.		
Filter Tare Weight	g	
Filter Final Weight	g	

Total Filterable Particulate Matter

Total Weight	mg	176.2
--------------	----	-------



Condensable Particulate Matter Analysis

Project	Rain	Location	K-1 Stack
Project Number	4173	Method	EPA Methods 5 and 202
Test Date	July 20, 2023	Run No.	114

Hexane Field Reagent Blank

Container Gross Wt.	g	344.6
Container Empty Wt.	g	165.8
Reagent Blank Volume	mLs	269.7
Evap. Beaker No.	C22-8-30	
Beaker Tare Weight	g	29.9420
Beaker Final Weight	g	29.9428
Residue Weight	mg	0.8

Water Field Reagent Blank

Container Gross Wt.	g	261.0
Container Empty Wt.	g	164.4
Water Blank Volume	mLs	96.8
Evap. Beaker No.	C22-8-31	
Beaker Tare Weight	g	30.5884
Beaker Final Weight	g	30.5885
Residue Weight	mg	0.1

Field Train Recovery (FTR) Blank

Organic Fraction

Container Gross Wt.	g	557.0
Container Empty Wt.	g	297.0
Sample Wt.	g	260.0
Evap. Beaker No.	C22-8-35	
Beaker Tare Weight	g	29.9567
Beaker Final Weight	g	29.9575
Net Weight	mg	0.8

Mass of NH₄⁺ Added To Sample

NH ₄ OH Normality	meq/mL	0.0000
Titratant Volume Used	mLs	0.0
NH ₄ ⁺ added to Sample	mg	0.0

Total Condensable Particulate Matter

Total FTR Blank CPM	mg	3.5
---------------------	----	-----

Inorganic Fraction

Container Gross Wt.	g	763.5
Container Empty Wt.	g	504.1
Sample Wt.	g	259.4
Evap. Beaker No.	C22-8-34	
Beaker Tare Weight	g	29.5305
Beaker Final Weight	g	29.5332
Less NH ₄ ⁺ in Sample	mg	0.0
Net Weight	mg	2.7

Filter Weights

Filter No.	NA	
Filter Tare Weight	g	0.0
Filter Final Weight	g	0.0
Net Weight	mg	0.0

CPM Sampling Train

Organic Fraction

Container Gross Wt.	g	857.8
Container Empty Wt.	g	501.5
Sample Wt.	g	356.3
Evap. Beaker No.	C22-10-24	
Beaker Tare Weight	g	1.6011
Beaker Final Weight	g	1.6891
Net Weight	mg	88.0

Mass of NH₄⁺ Added To Sample

NH ₄ OH Normality	meq/mL	0.0000
Titratant Volume Used	mLs	0.0
NH ₄ ⁺ added to Sample	mg	0.0

Total Condensable Particulate Matter

Total CPM Weight	mg	91.5
Blank Correction Used	mg	-2.0
Corrected CPM Weight	mg	89.5

Inorganic Fraction

Container Gross Wt.	g	560.9
Container Empty Wt.	g	295.2
Sample Wt.	g	265.7
Evap. Beaker No.	C22-8-75	
Beaker Tare Weight	g	28.5397
Beaker Final Weight	g	28.5432
Less NH ₄ ⁺ in Sample	mg	0.0
Net Weight	mg	3.5

Filter Weights

Filter No.	NA	
Filter Tare Weight	g	0.0
Filter Final Weight	g	0.0
Net Weight	mg	0.0

FTR Blank CPM was >2.0 mg.



Run Report - Particulate Matter

Project	Rain	Location	K-1 Stack
Project Number	4173	Method	EPA Methods 5 and 202
Test Date	July 20, 2023	Run No.	115

Stack or Duct Dimensions

<input checked="" type="radio"/> Circular <input type="radio"/> Rectangular		
Diameter # 1	in.	122.000
Diameter # 2	in.	122.000
Cross-Section Area	ft ²	81.180

Gas Stream Conditions

Avg. Gas Temperature	°F	931
Avg. Velocity Head (Δp)	in. H ₂ O	0.175
Static Gas Pressure	in. H ₂ O	0.00
Absolute Gas Pressure	in. Hg	29.20
O ₂ Concentration, Dry	%V	14.97
CO ₂ Concentration, Dry	%V	3.85
Moisture	%V	19.62
Dry Molecular Weight	lb/lb-mole	29.21
Wet Molecular Weight	lb/lb-mole	27.01

Sampling Conditions

Sampling Time	min	48.00
Avg. Nozzle Diameter	in.	0.396
Avg. Isokinetic Variation	%	109.2
IKV 90-110% Criterion	—	Pass

Dry Gas Meter Conditions

Console Elevation	ft	0
DGM Correction (Y)	—	1.015
Average ΔH	in. H ₂ O	1.65
Avg. DGM Temperature	°F	92.1
Initial DGM Volume	ft ³	821.200
Final DGM Volume	ft ³	854.600
Leak Check Volume	ft ³	-0.000
Leak Correction Volume	ft ³	
Net DGM Volume	ft ³	33.400
Dry Gas Sample Volume	dscf	31.891

Other Related Data

Barometer Reading	in. Hg	29.32
Test Location Elevation	ft	125
Pitot Tube Coefficient	—	0.840
Average SQRT(Δp)	in. H ₂ O	0.418

Volumetric Flow Rate Results

Average Gas Velocity	ft/min	2,392
Volumetric Flow, Actual	acfm	194,172
Corrected Flow, Wet	scfm	71,881
Corrected Flow, Dry	dscfm	57,778

Particulate Matter Emission Results

		Filterable	Condensable	Total
Total Particulate Matter Collected	mg	215.8	141.2	357.0
Concentration (Wet)	mg/acf	2.01	1.32	3.33
Concentration (Wet)	gr/acf	0.0311	0.0203	0.0514
Concentration (Dry)	mg/dscf	6.77	4.43	11.2
Concentration (Dry)	gr/dscf	0.104	0.0683	0.173
Emission Rate	lb/hr	51.7	33.8	85.6



Metric Equivalents - Particulate Matter

Project	Rain	Location	K-1 Stack
Project Number	4173	Method	EPA Methods 5 and 202
Test Date	July 20, 2023	Run No.	115

Stack or Duct Dimensions

<input checked="" type="radio"/> Circular <input type="radio"/> Rectangular		
Diameter # 1	m	3.0988
Diameter # 2	m	3.0988
Cross-Section Area	m ²	7.5418

Gas Stream Conditions

Avg. Gas Temperature	°C	500
Avg. Velocity Head (Δp)	mm H ₂ O	4.4
Static Gas Pressure	mm H ₂ O	0.0
Absolute Gas Pressure	mm Hg	741.6
O ₂ Concentration, Dry	%V	14.97
CO ₂ Concentration, Dry	%V	3.85
Moisture	%V	19.62
Dry Molecular Weight	g/g-mole	29.21
Wet Molecular Weight	g/g-mole	27.01

Sampling Conditions

Sampling Time	min	48.00
Avg. Nozzle Diameter	mm	10.06
Avg. Isokinetic Variation	%	109.2
IKV 90-110% Criterion	—	Pass

Dry Gas Meter Conditions

Console Elevation	m	0.0
DGM Correction (Y)	—	1.015
Average ΔH	mm H ₂ O	41.9
Avg. DGM Temperature	°C	33.4
Initial DGM Volume	m ³	23.25379
Final DGM Volume	m ³	24.19958
Leak Check Volume	m ³	-0.00000
Leak Correction Volume	m ³	
Net DGM Volume	m ³	0.94578
Dry Gas Sample Volume	dscm	0.90304

Other Related Data

Barometer Reading	mm Hg	744.7
Test Location Elevation	m	38.1
Pitot Tube Coefficient	—	0.840
Average SQRT(Δp)	mm H ₂ O	2.11

Volumetric Flow Rate Results

Average Gas Velocity	m/min	729.0
Volumetric Flow, Actual	acm/min	5,498.3
Corrected Flow, Wet	scm/min	2,035.45
Corrected Flow, Dry	dscm/min	1,636.08

Particulate Matter Emission Results

		Filterable	Condensable	Total
Total Particulate Matter Collected	mg	215.8	141.2	357.0
Concentration (Wet)	mg/acm	71.1	46.5	118
Concentration (Dry)	mg/dscm	239	156	395
Emission Rate	kg/hr	23.5	15.3	38.8



Traverse Data - Particulate Matter

Project	Rain	Location	K-1 Stack
Project Number	4173	Method	EPA Methods 5 and 202
Test Date	July 20, 2023	Run No.	115

Traverse Point	Gas Temp., °F	Δp in. H ₂ O	ΔH in. H ₂ O	DGM Inlet, °F	DGM Outlet, °F
A1	886	0.100	1.00	89	89
2	909	0.190	2.00	90	90
3	930	0.230	2.10	91	91
B1	901	0.120	1.10	91	91
2	924	0.150	1.40	92	92
3	934	0.200	1.80	92	92
C1	925	0.120	1.10	92	92
2	922	0.170	1.60	93	93
3	941	0.200	1.80	93	93
D1	950	0.150	1.40	94	94
2	970	0.250	2.20	94	94
3	982	0.260	2.30	94	94
Average	931	0.175	1.65	92.1	92.1

Leak Check Volumes

Initial					
Final					
Difference					



Filterable Particulate Matter and Moisture Analysis

Project	Rain	Location	K-1 Stack
Project Number	4173	Method	EPA Methods 5 and 202
Test Date	July 20, 2023	Run No.	115

Impinger Weights

		Initial	Final	Difference
Condenser & Knockout	g	770.1	922.2	152.1
CPM Impinger	g	605.9	606.0	0.1
H ₂ O Impinger	g	615.9	605.4	-10.5
H ₂ O Impinger	g			
Silica Gel	g	741.4	764.8	23.4
Total Collected		g		165.1

Moisture Results

Moisture Volume	scf	7.784
Dry Gas Sample Volume	dscf	31.891
Sampled Moisture	%V	19.62
Saturation Moisture	%V	N/A
Reported Moisture	%V	19.62

Rinse Reagent

☒ Acetone ☐ Water

Sampling Train Front-half Rinses

Container Gross Wt.	g	306.4
Container Empty Wt.	g	165.7
Sample Volume	mLs	178.1
Evap. Beaker No.	C22-8-76	
Beaker Tare Weight	g	31.3314
Beaker Final Weight	g	31.4437
Blank Correction	mg	-0.1
Net Weight	mg	112.2

Acetone Field Reagent Blank

Container Gross Wt.	g	300.5
Container Empty Wt.	g	166.9
Reagent Blank Volume	mLs	169.1
Evap. Beaker No.	C22-8-29	
Beaker Tare Weight	g	28.8716
Beaker Final Weight	g	28.8717
Residue Weight	mg	0.1
Blank Concentration	mg/mL	0.0006

Dry Catch and Filter Weights

Filter No.	F22-10-24	
Filter Tare Weight	g	37.0460
Filter Final Weight	g	37.1496
Filter Blank	g	NA
Net Weight	mg	103.6

Filter Blank

☒ Not Used ☐ Used

Filter No.		
Filter Tare Weight	g	
Filter Final Weight	g	

Total Filterable Particulate Matter

Total Weight	mg	215.8
--------------	----	-------



Condensable Particulate Matter Analysis

Project	Rain	Location	K-1 Stack
Project Number	4173	Method	EPA Methods 5 and 202
Test Date	July 20, 2023	Run No.	115

Hexane Field Reagent Blank

Container Gross Wt.	g	344.6
Container Empty Wt.	g	165.8
Reagent Blank Volume	mLs	269.7
Evap. Beaker No.	C22-8-30	
Beaker Tare Weight	g	29.9420
Beaker Final Weight	g	29.9428
Residue Weight	mg	0.8

Water Field Reagent Blank

Container Gross Wt.	g	261.0
Container Empty Wt.	g	164.4
Water Blank Volume	mLs	96.8
Evap. Beaker No.	C22-8-31	
Beaker Tare Weight	g	30.5884
Beaker Final Weight	g	30.5885
Residue Weight	mg	0.1

Field Train Recovery (FTR) Blank

Organic Fraction

Container Gross Wt.	g	557.0
Container Empty Wt.	g	297.0
Sample Wt.	g	260.0
Evap. Beaker No.	C22-8-35	
Beaker Tare Weight	g	29.9567
Beaker Final Weight	g	29.9575
Net Weight	mg	0.8

Mass of NH₄⁺ Added To Sample

NH ₄ OH Normality	meq/mL	0.0000
Titrat Volume Used	mLs	0.0
NH ₄ ⁺ added to Sample	mg	0.0

Total Condensable Particulate Matter

Total FTR Blank CPM	mg	3.5
---------------------	----	-----

Inorganic Fraction

Container Gross Wt.	g	763.5
Container Empty Wt.	g	504.1
Sample Wt.	g	259.4
Evap. Beaker No.	C22-8-34	
Beaker Tare Weight	g	29.5305
Beaker Final Weight	g	29.5332
Less NH ₄ ⁺ in Sample	mg	0.0
Net Weight	mg	2.7

Filter Weights

Filter No.	NA	
Filter Tare Weight	g	0.0
Filter Final Weight	g	0.0
Net Weight	mg	0.0

CPM Sampling Train

Organic Fraction

Container Gross Wt.	g	876.0
Container Empty Wt.	g	502.3
Sample Wt.	g	373.7
Evap. Beaker No.	C22-8-77	
Beaker Tare Weight	g	31.2497
Beaker Final Weight	g	31.3864
Net Weight	mg	136.7

Mass of NH₄⁺ Added To Sample

NH ₄ OH Normality	meq/mL	0.0000
Titrat Volume Used	mLs	0.0
NH ₄ ⁺ added to Sample	mg	0.0

Total Condensable Particulate Matter

Total CPM Weight	mg	143.2
Blank Correction Used	mg	-2.0
Corrected CPM Weight	mg	141.2

Inorganic Fraction

Container Gross Wt.	g	557.3
Container Empty Wt.	g	296.5
Sample Wt.	g	260.8
Evap. Beaker No.	C22-8-78	
Beaker Tare Weight	g	28.9085
Beaker Final Weight	g	28.9150
Less NH ₄ ⁺ in Sample	mg	0.0
Net Weight	mg	6.5

Filter Weights

Filter No.	NA	
Filter Tare Weight	g	0.0
Filter Final Weight	g	0.0
Net Weight	mg	0.0

FTR Blank CPM was >2.0 mg.

Appendix B-2

Instrumental Analyzer Results



Initial Instrument Calibrations

Project No.	4173	Project	Rain CII Inv. '23
Test Date	7/20/2023	Location	Kiln #1

Standards			Calibration Error		Calibration Bias	
	Span	EPA Protocol Gas	Instrument Response	Calibration Error	System Response	Calibration Bias
O ₂	21	0	0.00	0.0%	0.04	0.2%
		12.11 % v/v	12.25	0.7%	12.06	-0.9%
		21	20.98	-0.1%		
CO ₂	12	0	-0.01	0.0%	0.16	1.4%
		5.86 % v/v	5.93	0.6%		
		12.36	12.35	-0.1%	12.43	0.7%
Standards			System Response			
	Span	EPA Protocol Gas			System Response	Calibration Error
THC	25	0.0 ppmv			-0.1	
		8.4 ppmv			8.5	1.2%
		16.2 ppmv			16.1	-0.5%
		30.2 ppmv			30.0	
	50	51.9 ppmv			52.0	0.2%



Instrument Run Report

Project No. 4173

Project Rain CII Inv. '23

Run ID: 1-1-1

Location

Kiln #1

Date

7/20/2023

Time

09:45-10:30

Adjusted Data

O2

% v/v

dry

17.72

CO2

% v/v

dry

1.86

THC

ppmv

wet

4.4

Instrument Responses

Gas Standards

12.11

12.36

8.4

Initial Calibration

Zero

Upscale

0.04

0.16

-0.1

12.06

12.43

8.5

Raw Data

17.60

2.02

4.33

Final Calibration

Zero

Upscale

0.14

0.18

-0.1

12.06

12.49

8.3

Calibration Performance

Instrument Span

21

12

25

Initial Bias

Zero

Upscale

0.2%

1.4%

-0.2%

-0.9%

0.7%

0.4%

Final Bias

Zero

Upscale

0.6%

1.5%

-0.4%

-0.9%

1.1%

-0.4%

Drift

Zero

Upscale

0.4%

0.1%

-0.2%

0.0%

0.5%

-0.8%



Instrument Run Report

Project No. 4173

Project Rain CII Inv. '23

Run ID: 1-1-2

Location

Kiln #1

Date

7/20/2023

Time

10:45-11:30

Adjusted Data

O2

% v/v

dry

16.66

CO2

% v/v

dry

2.62

THC

ppmv

wet

0.9

Instrument Responses

Gas Standards

12.11

12.36

8.4

Initial Calibration

Zero

Upscale

0.14

0.18

-0.1

12.06

12.49

8.3

Raw Data

16.52

2.81

0.75

Final Calibration

Zero

Upscale

0.05

0.24

-0.2

12.00

12.45

8.2

Calibration Performance

Instrument Span

21

12

25

Initial Bias

Zero

Upscale

0.6%

1.5%

-0.4%

-0.9%

1.1%

-0.4%

Final Bias

Zero

Upscale

0.2%

2.0%

-0.7%

-1.2%

0.8%

-0.7%

Drift

Zero

Upscale

-0.4%

0.5%

-0.3%

-0.3%

-0.3%

-0.3%



Instrument Run Report

Project No. 4173

Project Rain CII Inv. '23

Run ID: 1-1-3

Location

Kiln #1

Date

7/20/2023

Time

11:45-12:30

Adjusted Data

O2

% v/v

dry

16.34

CO2

% v/v

dry

2.98

THC

ppmv

wet

0.8

Instrument Responses

Gas Standards

12.11

12.36

8.4

Initial Calibration

Zero

0.05

0.24

-0.2

Raw Data

16.15

3.17

0.64

Final Calibration

Zero

0.16

0.22

-0.2

Upscale

11.99

12.42

8.2

Calibration Performance

Instrument Span

21

12

25

Initial Bias

Zero

0.2%

2.0%

-0.7%

Upscale

-1.2%

0.8%

-0.7%

Final Bias

Zero

0.7%

1.8%

-0.8%

Upscale

-1.2%

0.6%

-0.7%

Drift

Zero

0.5%

-0.1%

-0.1%

Upscale

-0.1%

-0.2%

0.0%



Instrument Run Report

Project No. 4173

Project Rain CII Inv. '23

Run ID: 1-1-4

Location

Kiln #1

Date

7/20/2023

Time

12:47-13:32

Adjusted Data

O2

% v/v

dry

15.90

CO2

% v/v

dry

3.04

THC

ppmv

wet

0.7

Instrument Responses

Gas Standards

12.11

12.36

8.4

Initial Calibration

Zero

Upscale

0.16

0.22

-0.2

11.99

12.42

8.2

Raw Data

15.71

3.18

0.51

Final Calibration

Zero

Upscale

0.10

0.15

-0.2

12.00

12.34

8.2

Calibration Performance

Instrument Span

21

12

25

Initial Bias

Zero

Upscale

0.7%

1.8%

-0.8%

-1.2%

0.6%

-0.7%

Final Bias

Zero

Upscale

0.5%

1.2%

-0.8%

-1.2%

-0.1%

-0.7%

Drift

Zero

Upscale

-0.3%

-0.6%

0.0%

0.1%

-0.7%

0.0%



Instrument Run Report

Project No. 4173

Project Rain CII Inv. '23

Run ID: 1-1-5

Location

Kiln #1

Date

7/20/2023

Time

13:45-14:30

Adjusted Data

O2

% v/v

dry

16.07

CO2

% v/v

dry

3.16

THC

ppmv

wet

0.7

Instrument Responses

Gas Standards

12.11

12.36

8.4

Initial Calibration

Zero

Upscale

0.10

0.15

-0.2

12.00

12.34

8.2

Raw Data

15.92

3.26

0.46

Final Calibration

Zero

Upscale

0.06

0.15

-0.3

12.03

12.34

8.2

Calibration Performance

Instrument Span

21

12

25

Initial Bias

Zero

Upscale

0.5%

1.2%

-0.8%

-1.2%

-0.1%

-0.7%

Final Bias

Zero

Upscale

0.3%

1.2%

-1.1%

-1.1%

-0.1%

-0.8%

Drift

Zero

Upscale

-0.2%

0.0%

-0.2%

0.1%

0.0%

-0.2%



Instrument Run Report

Project No. 4173

Project Rain CII Inv. '23

Run ID: 1-1-6

Location

Kiln #1

Date

7/20/2023

Time

14:45-15:30

Adjusted Data

O2 % v/v dry	CO2 % v/v dry	THC ppmv wet
15.93	3.31	0.6

Instrument Responses

Gas Standards		12.11	12.36	8.4
Initial Calibration	Zero	0.06	0.15	-0.3
	Upscale	12.03	12.34	8.2
Raw Data		15.79	3.40	0.37
Final Calibration	Zero	0.07	0.14	-0.3
	Upscale	12.01	12.32	8.2

Calibration Performance

Instrument Span		21	12	25
Initial Bias	Zero	0.3%	1.2%	-1.1%
	Upscale	-1.1%	-0.1%	-0.8%
Final Bias	Zero	0.3%	1.2%	-1.1%
	Upscale	-1.2%	-0.2%	-0.7%
Drift	Zero	0.0%	-0.1%	-0.1%
	Upscale	-0.1%	-0.2%	0.1%



Instrument Run Report

Project No. 4173

Project Rain CII Inv. '23

Run ID: 1-1-7

Location

Kiln #1

Date

7/20/2023

Time

15:45-16:30

Adjusted Data

O2

% v/v

dry

15.69

CO2

% v/v

dry

3.47

THC

ppmv

wet

0.7

Instrument Responses

Gas Standards

12.11

12.36

8.4

Initial Calibration

Zero

Upscale

0.07

0.14

-0.3

12.01

12.32

8.2

Raw Data

15.58

3.58

0.45

Final Calibration

Zero

Upscale

0.02

0.18

-0.2

12.06

12.40

8.3

Calibration Performance

Instrument Span

21

12

25

Initial Bias

Zero

Upscale

0.3%

1.2%

-1.1%

-1.2%

-0.2%

-0.7%

Final Bias

Zero

Upscale

0.1%

1.5%

-0.6%

-0.9%

0.4%

-0.3%

Drift

Zero

Upscale

-0.3%

0.3%

0.5%

0.3%

0.7%

0.4%



Instrument Run Report

Project No. 4173

Project Rain CII Inv. '23

Run ID: 1-1-8

Location

Kiln #1

Date

7/20/2023

Time

16:46-17:31

Adjusted Data

O2

% v/v

dry

15.33

CO2

% v/v

dry

3.65

THC

ppmv

wet

0.6

Instrument Responses

Gas Standards

12.11

12.36

8.4

Initial Calibration

Zero

Upscale

0.02

0.18

-0.2

12.06

12.40

8.3

Raw Data

15.27

3.78

0.50

Final Calibration

Zero

Upscale

0.03

0.18

0.0

12.08

12.36

8.4

Calibration Performance

Instrument Span

21

12

25

Initial Bias

Zero

Upscale

0.1%

1.5%

-0.6%

-0.9%

0.4%

-0.3%

Final Bias

Zero

Upscale

0.1%

1.5%

-0.1%

-0.8%

0.1%

-0.2%

Drift

Zero

Upscale

0.1%

0.0%

0.6%

0.1%

-0.3%

0.1%



Instrument Run Report

Project No. 4173

Project Rain CII Inv. '23

Run ID: 1-1-9

Location

Kiln #1

Date

7/20/2023

Time

17:45-18:30

Adjusted Data

O2

% v/v

dry

14.97

CO2

% v/v

dry

3.85

THC

ppmv

wet

0.6

Instrument Responses

Gas Standards

12.11

12.36

8.4

Initial
CalibrationZero
Upscale

0.03

0.18

0.0

12.08

12.36

8.4

Raw Data

14.88

3.95

0.51

Final
CalibrationZero
Upscale

0.02

0.14

-0.1

12.01

12.33

8.3

Calibration Performance

Instrument Span

21

12

25

Initial Bias

Zero
Upscale

0.1%

1.5%

-0.1%

-0.8%

0.1%

-0.2%

Final Bias

Zero
Upscale

0.1%

1.2%

-0.3%

-1.1%

-0.2%

-0.3%

Drift

Zero
Upscale

-0.1%

-0.3%

-0.3%

-0.3%

-0.3%

-0.1%

Project No.

4173

Project

Rain CII Inv. '23

Run ID: 1-1-1
Location: Kiln #1
Flow Rate

Flow Train ID: 1-1-1

Gas Velocity	ft/min	1,829
Volumetric Flow, Actual	acfm	148,456
Corrected Flow, Wet	scfm	80,207
Corrected Flow, Dry	dscfm	75,497

Date

Gas Time(s)

7/20/2023	09:45-10:30
Flow Time(s)	
09:44-10:49	

Pollutant Emissions
TGOC

Molecular Weight		g/g-mol	44.1
Concentration	(dry)	ppmv	4.6
	(wet)	ppmv	4.4
	(dry)	lb/dscf	5.31E-7
	(wet)	lb/scf	5.00E-7
Emission Rate		lb/hr	2.41

Run ID: 1-1-2
Location: Kiln #1
Flow Rate

Flow Train ID 1-1-2

Gas Velocity	ft/min	2,177
Volumetric Flow, Actual	acfm	176,756
Corrected Flow, Wet	scfm	78,537
Corrected Flow, Dry	dscfm	61,875

Date

Gas Time(s)

7/20/2023	12:47-13:32
Flow Time(s)	
12:11-13:10	

Pollutant Emissions
TGOC

Molecular Weight		g/g-mol	44.1
Concentration	(dry)	ppmv	1.1
	(wet)	ppmv	0.9
	(dry)	lb/dscf	1.30E-7
	(wet)	lb/scf	1.02E-7
Emission Rate		lb/hr	0.482

Run ID: 1-1-3
Location: Kiln #1
Flow Rate

Flow Train ID 1-1-3

Gas Velocity	ft/min	2,133
Volumetric Flow, Actual	acfm	173,133
Corrected Flow, Wet	scfm	73,204
Corrected Flow, Dry	dscfm	57,232

Date

Gas Time(s)

7/20/2023	13:45-14:30
Flow Time(s)	
13:44-14:37	

Pollutant Emissions
TGOC

Molecular Weight		g/g-mol	44.1
Concentration	(dry)	ppmv	1.1
	(wet)	ppmv	0.8
	(dry)	lb/dscf	1.22E-7
	(wet)	lb/scf	9.54E-8
Emission Rate		lb/hr	0.419

Project No.

4173

Project

Rain CII Inv. '23

Run ID: 1-1-1
Location: Kiln #1
Flow Rate

Flow Train ID 1-1-1

Date

Gas Time(s)

Gas Velocity	m/min	557
Volumetric Flow, Actual	acm/min	4,204
Corrected Flow, Wet	scm/min	2,271
Corrected Flow, Dry	dscm/min	2,138

7/20/2023	09:45-10:30
Flow Time(s)	
09:44-10:49	

Pollutant Emissions
TGOC

Molecular Weight		g/g-mol	44.1
Concentration	(dry)	ppmv	4.6
	(wet)	ppmv	4.4
	(dry)	g/dscm	8.51E-3
	(wet)	g/scm	8.01E-3
Emission Rate		g/hr	1,091

Run ID: 1-1-2
Location: Kiln #1
Flow Rate

Flow Train ID 1-1-2

Date

Gas Time(s)

Gas Velocity	m/min	664
Volumetric Flow, Actual	acm/min	5,005
Corrected Flow, Wet	scm/min	2,224
Corrected Flow, Dry	dscm/min	1,752

7/20/2023	12:47-13:32
Flow Time(s)	
12:11-13:10	

Pollutant Emissions
TGOC

Molecular Weight		g/g-mol	44.1
Concentration	(dry)	ppmv	1.1
	(wet)	ppmv	0.9
	(dry)	g/dscm	2.08E-3
	(wet)	g/scm	1.64E-3
Emission Rate		g/hr	218

Run ID: 1-1-3
Location: Kiln #1
Flow Rate

Flow Train ID 1-1-3

Date

Gas Time(s)

Gas Velocity	m/min	650
Volumetric Flow, Actual	acm/min	4,903
Corrected Flow, Wet	scm/min	2,073
Corrected Flow, Dry	dscm/min	1,621

7/20/2023	13:45-14:30
Flow Time(s)	
13:44-14:37	

Pollutant Emissions
TGOC

Molecular Weight		g/g-mol	44.1
Concentration	(dry)	ppmv	1.1
	(wet)	ppmv	0.8
	(dry)	g/dscm	1.96E-3
	(wet)	g/scm	1.53E-3
Emission Rate		g/hr	190

Project No.

4173

Project

Rain CII Inv. '23

Run ID: 1-1-4
Location: Kiln #1
Flow Rate

Flow Train ID: 1-1-4

Gas Velocity	ft/min	2,261
Volumetric Flow, Actual	acfm	183,552
Corrected Flow, Wet	scfm	72,282
Corrected Flow, Dry	dscfm	58,725

Date

Gas Time(s)

7/20/2023	16:46-17:31
Flow Time(s)	
16:15-17:17	

Pollutant Emissions
TGOC

Molecular Weight		g/g-mol	44.1
Concentration	(dry)	ppmv	0.9
	(wet)	ppmv	0.7
	(dry)	lb/dscf	1.01E-7
	(wet)	lb/scf	8.17E-8
Emission Rate		lb/hr	0.4

Run ID: 1-1-5
Location: Kiln #1
Flow Rate

Flow Train ID 1-1-5

Gas Velocity	ft/min	2,392
Volumetric Flow, Actual	acfm	194,172
Corrected Flow, Wet	scfm	71,881
Corrected Flow, Dry	dscfm	57,778

Date

Gas Time(s)

7/20/2023	17:45-18:30
Flow Time(s)	
17:47-18:50	

Pollutant Emissions
TGOC

Molecular Weight		g/g-mol	44.1
Concentration	(dry)	ppmv	0.9
	(wet)	ppmv	0.7
	(dry)	lb/dscf	9.89E-8
	(wet)	lb/scf	7.95E-8
Emission Rate		lb/hr	0.3

Project No.

4173

Project

Rain CII Inv. '23

Run ID: 1-1-4
Location: Kiln #1
Flow Rate

Flow Train ID 1-1-4

Date

Gas Time(s)

Gas Velocity	m/min	689
Volumetric Flow, Actual	acm/min	5,198
Corrected Flow, Wet	scm/min	2,047
Corrected Flow, Dry	dscm/min	1,663

7/20/2023	16:46-17:31
Flow Time(s)	
16:15-17:17	

Pollutant Emissions
TGOC

Molecular Weight		g/g-mol	44.1
Concentration	(dry)	ppmv	0.9
	(wet)	ppmv	0.7
	(dry)	g/dscm	1.61E-3
	(wet)	g/scm	1.31E-3
Emission Rate		g/hr	161

Run ID: 1-1-5
Location: Kiln #1
Flow Rate

Flow Train ID 1-1-5

Date

Gas Time(s)

Gas Velocity	m/min	729
Volumetric Flow, Actual	acm/min	5,498
Corrected Flow, Wet	scm/min	2,035
Corrected Flow, Dry	dscm/min	1,636

7/20/2023	17:45-18:30
Flow Time(s)	
17:47-18:50	

Pollutant Emissions
TGOC

Molecular Weight		g/g-mol	44.1
Concentration	(dry)	ppmv	0.9
	(wet)	ppmv	0.7
	(dry)	g/dscm	1.58E-3
	(wet)	g/scm	1.27E-3
Emission Rate		g/hr	156

APPENDIX C

FIELD DATA

Appendix C-1
Particulate Data



Traverse Point Layout

Project	Rain	Location	K-1 Stack
Project Number	4173	Method	EPA Method 1
Test Date	July 20, 2023	Runs	NA


Stack or Duct Dimensions

Internal Diameter supplied by facility	10 ft	2	in.
No Applicable Measurements*	ft		in.
Port A Length**	1 ft	6	in.
Internal ID supplied by facility*	10 ft	2	in.
No Applicable Measurements*	ft		in.
Port B Length**	1 ft	6	in.
Internal ID supplied by facility*	10 ft	2	in.
Port C Length**	1 ft	6	in.
Port D Length**	1 ft	6	in.
Equivalent ID supplied by facility	10 ft	2	in.
Cross-Sectional Area	81.180	ft ²	

* Distance as measured. Not determined when internal diameter (ID) supplied by the facility is used.


** Actual port length or distance from outside reference point to inside wall, as measured.

Port Location From Nearest Flow Disturbance

Distance Upstream (A)	18 ft	in.
Distance Downstream (B)	98 ft	in.
Diameters Upstream	1.77	
Diameters Downstream	9.64	

Number of Traverse Points


Minimum for Particulate Traverses	12
Minimum for Velocity Traverses	12
Number of Traverse Points Used	12
Number of Test Ports Used	4
Traverse Points Per Test Port	3

[illegible][illegible]

Project #	4173	Date	7.20.23
Project	Rain Carbon II.	Method	EPA Methods 1 and 2
Location	Kiln 1	Run Time	08:43 - 08:57
Performed by	D. Hotz	Run #	Cyclonics

Equipment		Run Parameters	
Probe ID	5-5	Barometer Reading	in. Hg
Pitot ID	5-2	Test Port Elevation	ft. 125'
Pitot Coefficient	0.84	Stack Diameter	in. 122"
Thermocouple ID	—	Static Pressure	in. H ₂ O
Temp. Meter ID	—	Moisture	%V
Diff. Press. Gauge ID	—	CO ₂ Concentration	%V
Barometer ID	—	O ₂ Concentration	%V
		Final Pitot Leak Check	Pass/Fail PASS

Traverse Point	Δp (in. H ₂ O)	Stack Temp (°F)	Rotation Angle (°)	Traverse Point	Δp (in. H ₂ O)	Stack Temp (°F)	Rotation Angle (°)	Traverse Point	Δp (in. H ₂ O)	Stack Temp (°F)	Rotation Angle (°)
A1			8.3								
2			6.1								
3			2.0								
B1			7.7								
2			5.2								
3			4.0								
C1			8.3								
2			6.7								
3			6.0								
D1			8.0								
2			3.8								
3			4.6								



Run Information

Project #	4173
Project	Rain CII LLC
Location	K-1 Stack
Date	7/20/23
Run #	111
Method	EPA Methods 5 and 202

Assumed Conditions

Percent H ₂ O	10
Percent O ₂	10
Percent CO ₂	10
Average Δp	.05
Stack Temp	500

Equipment

Probe ID	5-5
Liner Type	Q
Pitot ID	55-2
Pitot Coefficient	.84
Thermocouple ID	68.3

Oven Box ID	
Umbilical ID	U-200-1
Barometer ID	B24

Palmtop ID	3
Meter Box ID	1
DGM Correction (Y)	1.015
Orifice Meter ΔH@	1.900

Run Parameters

Train ID	M5202-2
FPM Filter ID/TC ID	F23-17-1 G
CPM Filter TC ID	4
Barometer Reading	29.40
Meter Box Elevation	0
Test Port Elevation	125

Stack Diameter	122"
Static Pressure	
Min/Point	4

Nozzle ID	Q-213
Nozzle Type	Q
Nozzle Diameter	440.430

Pitot Leak Checks	Initial (>3" H ₂ O)	915					
	Final (>3" H ₂ O)	1020					
	Pass/Fail	P					

Initial Sample Train Leak Check	Time (24 hour)	920					
	Vacuum (in Hg)	>15	>15	>15	>15	>15	>15
	Leak Rate (CFM)	.005					
Final Sample Train Leak Check	Time (24 hour)	1020					
	Vacuum (in. Hg)	18"					
	Leak Rate (CFM)	.004					

Comments

Equipment Problems/Changes/Notes

Performed By: K. McKenna

Reviewed By: LK 8/1/23

2K 8/7/23

Project # 4173 Project

Train ID M5/202-2
Box ID 33 Hook-Up ID 21

Date	7/17/23	7-20-23
Time	17:42	13:04
Analyst	L. HOOPER	T. P. Hume
1000 g Cal. Wt.	1000.0	2000.0

Impinger	Type	Charge	Initial Wt.	Final Wt.	Difference
1	Cond/KO Catch	Dry (w/Condenser)	643.9	672.5	
2	MGBS	Dry	465.3	465.3	
-	CPM Filter Holder and Filter				-
3	MGBS	100 mL H ₂ O	707.0 ⁹ ₁₄	695.2	
Silica Gel	MGBS	~ 200 g Silica Gel	714.2	739.2	
				Total	

693.0

Run ID 111 FPM Filter ID F23-7-1 Optional CPM Filter ID NA

FPM Filter Condition
Intact? YES
Color: Black
Loading: Heavy
Recovered By: A. VanSickle

Sample Identification
FH Rinses: Proj. No. - Run No. - 010
FPM Filter: ~ Proj. No. - Run No. - 011
Impinger Catch/Aq Rinses: Proj. No. - Run No. - 012
Organic Rinses: Proj. No. - Run No. - 013
Filter CPM: Proj. No. - Run No. - 014

CPM Filter Condition
Intact? YES
Color: Tan/White
Recovered By: A. VanSickle

Reagent/Material Information
Acetone: Fisher Lot
Reagent Water: Fisher Lot
Hexane: Fisher Lot
FPM Filter:
CPM Filter:

Silica Gel Condition
99 % Spent

Comments:

Reviewed By:

Project

Project #

Train ID

Run Number

Date	2/20/23
Analyst	T. Pittman
H₂O added (mL)	122.0
Beginning Pressure (psi)	~ 2150

Purge Time (≥60 min)	Clock Time (24hr)	Flow (≥14 LPM)	Temp (65-85 °F)
0	11:45	14	78.6
10	11:55	14	76.3
20	12:05	14.17	74.4
30	12:15	14.16	73.9
40	12:25	14.16	74.4
50	12:35	14.15	75.1
60	12:45	14.15	75.0

Ending Pressure (psi)

Reagent/Material Information

H₂O Lot No. :

N₂ Cylinder No. :

Regulator ID No. :

Rotometer ID No. :

Comments:

Reviewed By:

Run Information

Project #	4173
Project	Rain CII LLC
Location	K-1 Stack
Date	7/20/23
Run #	112
Method	EPA Methods 5 and 202

Equipment

Probe ID	5-5
Liner Type	Q
Pitot ID	55 2
Pitot Coefficient	.84
Thermocouple ID	68-3

Oven Box ID	13
Umbilical ID	U200-1
Barometer ID	B-24

Palmtop ID	3
Meter Box ID	1
DGM Correction (Y)	1.015 ✓
Orifice Meter ΔH@	1.900

Run Parameters 115-202-3

Train ID	115-202-3
FPM Filter ID/TC ID	923-7-15
CPM Filter TC ID	644 9
Barometer Reading	29.39
Meter Box Elevation	0
Test Port Elevation	125

Stack Diameter	122"
Static Pressure	
Min/Point	4

Nozzle ID	0.242
Nozzle Type	Q
Nozzle Diameter	.365

Assumed Conditions

Percent H ₂ O	10
Percent O ₂	16.75
Percent CO ₂	2.65
Average Δp	.160
Stack Temp	520

Pitot Leak Checks	Initial (>3" H ₂ O)	1125					
	Final (>3" H ₂ O)	1320					
	Pass/Fail	PASS					

Initial Sample Train Leak Check	Time (24 hour)	1125	1144				
	Vacuum (in Hg)	>15	>15	>15	>15	>15	>15
	Leak Rate (CFM)	—	0.003				
Final Sample Train Leak Check	Time (24 hour)		1320				
	Vacuum (in. Hg)		17"				
	Leak Rate (CFM)		.004				

Comments

Equipment Problems/Changes/Notes

Performed By: K. McKenna

Reviewed By: *AK* 8/7/23

JK 7/23

Lab Data - Filterable and Condensible Particulate Matter

Project # 4173

Project Rain CII Env. '23

Train ID M5/202-3

Box ID 34

Hook-Up ID 22

Date	<u>7/17/23</u>	<u>7/21/23</u>
Time	<u>18:00</u>	<u>14:30</u>
Analyst	<u>L. HOOPER</u>	<u>A. VanSickle</u>
1000 g Cal. Wt.	<u>1000.0</u>	<u>1000.1</u>

Impinger	Type	Charge	Initial Wt.	Final Wt.	Difference
1	Cond/KO Catch	Dry (w/Condenser)	<u>783.0</u>	<u>933.6</u>	
2	MGBS	Dry	<u>549.7</u>	<u>549.8</u>	
-	CPM Filter Holder and Filter				-
3	MGBS	100 mL H ₂ O	<u>559.9</u>	<u>549.0</u>	
Silica Gel	MGBS	~ 200 g Silica Gel	<u>714.9</u>	<u>744.4</u>	
				Total	

Run ID 112

FPM Filter ID F22-9-9

Optional CPM Filter ID NA

FPM Filter Condition	
Intact?	<u>YES</u>
Color:	<u>Black</u>
Loading:	<u>Heavy</u>
Recovered By:	<u>A. VanSickle</u>

Sample Identification	
FH Rinses:	Proj. No. - Run No. - 010
FPM Filter:	Proj. No. - Run No. - 011
Impinger Catch/Aq Rinses:	Proj. No. - Run No. - 012
Organic Rinses:	Proj. No. - Run No. - 013
Filter CPM:	Proj. No. - Run No. - 014

CPM Filter Condition	
Intact?	<u>YES</u>
Color:	<u>White</u>
Recovered By:	<u>A. VanSickle</u>

Reagent/Material Information	
Acetone:	Fisher Lot
Reagent Water:	Fisher Lot
Hexane:	Fisher Lot
FPM Filter:	
CPM Filter:	

Silica Gel Condition	
<u>95</u>	% Spent

Comments:

Reviewed By:

Project

Project #

Train ID

Run Number

Date	7.20.23
Analyst	T. J. Hume
H ₂ O added (mL)	116.4
Beginning Pressure (psi)	~1550

Purge Time (≥60 min)	Clock Time (24hr)	Flow (≥14 LPM)	Temp (65-85 °F)
0	13:55	14	79.1
10	14:05	14	75.3
20	14:15	14	74.1
30	14:25	14	73.5
40	14:35	14	73.6
50	14:45	14	73.9
60	14:55	14	73.5

Ending Pressure (psi)

Reagent/Material Information

H₂O Lot No. :

N₂ Cylinder No. :

Regulator ID No. :

Rotometer ID No. :

Comments:

Reviewed By:

Run Information		Equipment		Run Parameters	
Project #	4173	Probe ID	5-5	Train ID	45202-1
Project	Rain CII LLC	Liner Type	Q	FPM Filter ID/TC ID	F22-19-10-9
Location	K-1 Stack	Pitot ID	55-2	CPM Filter TC ID	2
Date	7/24/23	Pitot Coefficient	.84	Barometer Reading	29.37 ✓
Run #	113	Thermocouple ID	68.3	Meter Box Elevation	0
Method	EPA Methods 5 and 202			Test Port Elevation	125
		Oven Box ID	13	Stack Diameter	122"
		Umbilical ID	U-200-1	Static Pressure	
		Barometer ID	B-24	Min/Point	4
		Palmtop ID	3	Nozzle ID	Q234
		Meter Box ID	1	Nozzle Type	Q
		DGM Correction (Y)	1.015 ✓	Nozzle Diameter	.376
		Orifice Meter ΔH@	1.900		

Assumed Conditions	
Percent H ₂ O	10
Percent O ₂	15.90
Percent CO ₂	3.30
Average Δp	.172
Stack Temp	740

Pitot Leak Checks	Initial (>3" H ₂ O)	13:37					
	Final (>3" H ₂ O)	1440					
	Pass/Fail	PASS					
Initial Sample Train Leak Check	Time (24 hour)	13:37					
	Vacuum (in Hg)	>15	>15	>15	>15	>15	>15
	Leak Rate (CFM)	0.004					
Final Sample Train Leak Check	Time (24 hour)	1440					
	Vacuum (in. Hg)	18"					
	Leak Rate (CFM)	.003					

Comments

Equipment Problems/Changes/Notes

Performed By: K. McKenna	Reviewed By: SK 8/1/23
--------------------------	------------------------

OK 8/1/23

Lab Data - Filterable and Condensable Particulate Matter

Project # 4173

Project

Train ID M5/202-1

Box ID 32

Hook-Up ID 20

Date	<u>7/17/23</u>	<u>7/21/23</u>
Time	<u>17:15</u>	<u>14:45</u>
Analyst	<u>L. HOOPER</u>	<u>A. VanSickle</u>
1000 g Cal. Wt.	<u>1000.0</u>	<u>1000.1</u>

Impinger	Type	Charge	Initial Wt.	Final Wt.	Difference
1	Cond/KO Catch	Dry (w/Condenser)	<u>647.9</u>	<u>778.5</u>	
2	MGBS	Dry	<u>511.8</u>	<u>512.0</u>	
-	CPM Filter Holder and Filter				-
3	MGBS	100 mL H ₂ O	<u>637.1</u>	<u>643.2</u>	
Silica Gel	MGBS	~ 200 g Silica Gel	<u>834.5</u>	<u>856.2</u>	
				Total	

Run ID 113

FPM Filter ID F22-9-10

Optional CPM Filter ID NA

FPM Filter Condition
Intact? <u>YES</u>
Color: <u>Black</u>
Loading: <u>Heavy</u>
Recovered By: <u>A. VanSickle</u>

CPM Filter Condition
Intact? <u>YES</u>
Color: <u>White</u>
Recovered By: <u>A. VanSickle</u>

Silica Gel Condition
<u>90</u> % Spent

Sample Identification
FH Rinses: Proj. No. - Run No. - 010
FPM Filter: Proj. No. - Run No. - 011
Impinger Catch/Aq Rinses: Proj. No. - Run No. - 012
Organic Rinses: Proj. No. - Run No. - 013
Filter CPM: Proj. No. - Run No. - 014

Reagent/Material Information
Acetone: Fisher Lot
Reagent Water: Fisher Lot
Hexane: Fisher Lot
FPM Filter:
CPM Filter:

Comments:

Reviewed By:

Purge Data - Condensible Particulate Matter

 Project

 Project #

 Train ID

 Run Number

Date	7.20.23
Analyst	T. Pittman
H ₂ O added (mL)	105.6
Beginning Pressure (psi)	~ 1100

Purge Time (≥60 min)	Clock Time (24hr)	Flow (≥14 LPM)	Temp (65-85 °F)
0	15:05	14	76.8
10	15:15	14	76.2
20	15:25	14	75.7
30	15:35	14	74.7
40	15:45	14	74.9
50	15:55	14	76.0
60	16:05	14	76.0

 Ending Pressure (psi)
Reagent/Material Information

 H₂O Lot No. :

 N₂ Cylinder No. :

Regulator ID No. :

Rotometer ID No. :

Comments:

Reviewed By:

Run Information

Project #	4173
Project	Rain CII LLC
Location	K-1 Stack
Date	7/20/23
Run #	114
Method	EPA Methods 5 and 202

Equipment

Probe ID	5-5
Liner Type	Q
Pitot ID	55-2
Pitot Coefficient	.84
Thermocouple ID	68.3

Oven Box ID	13
Umbilical ID	U-200-1
Barometer ID	B24

Palmtop ID	3
Meter Box ID	1
DGM Correction (Y)	1.015
Orifice Meter ΔH@	1.900

Run Parameters

Train ID	MS202-4
FPM Filter ID/TC ID	F22-7-2-8
CPM Filter TC ID	3
Barometer Reading	29.31
Meter Box Elevation	0
Test Port Elevation	125

Stack Diameter	122"
Static Pressure	
Min/Point	4

Nozzle ID	Q-264
Nozzle Type	Q
Nozzle Diameter	.388

Assumed Conditions

Percent H ₂ O	10
Percent O ₂	15.9
Percent CO ₂	3.4
Average Δp	.160
Stack Temp	760

Pitot Leak Checks	Initial (>3" H ₂ O)	1614					
	Final (>3" H ₂ O)	1720					
	Pass/Fail	Pass					

Initial Sample Train Leak Check	Time (24 hour)	1614					
	Vacuum (in Hg)	>15	>15	>15	>15	>15	>15
	Leak Rate (CFM)	.002					
Final Sample Train Leak Check	Time (24 hour)	1720					
	Vacuum (in. Hg)	18"					
	Leak Rate (CFM)	.004					

Comments

Equipment Problems/Changes/Notes

Performed By:

K. McKenna

Reviewed By:

dk 8/7/23

Project #: 4173		Project: Rain CIT LLC						Location: K-1 Stack				Run #: 114			
Traverse Point	Clock Time (24 hr)	Sampling Time (min)	Gas Meter Temp (°F)		Stack Temp (°F)	Ap (in. H ₂ O)	ΔH (in. H ₂ O)		Gas Meter Reading (ft ³)		Pump Vac. (in. Hg)	Probe Temp (°F)	FPM Temp (°F)	CPM Temp (°F)	Impinger Temp (°F)
			Inlet	Outlet			Desired	Actual	Desired	Actual					
START	1615									787.750					
A1		4		84	814	.13	1.19	1.20	790.14	790.10	7	250	249	80	65
2		8		84	842	.24	2.15	2.10	793.35	793.30	8	250	250	80	65
3		12		87	845	.25	2.25	2.20	796.64	796.54	8	250	249	80	65
B1		16		86	813	.20	1.84	1.80	799.61	799.60	8	250	249	79	65
2		20		88	845	.05	.45	.50	801.09	801.10	9	250	250	70	63
3		24		88	853	.20	1.79	1.80	804.03	804.00	9	250	250	70	64
C1		28		89	835	.10	.91	.90	806.13	806.10	9	250	250	70	65
2		32		89	850	.15	1.35	1.40	808.69	808.70	9	250	250	70	65
3		36		90	852	.18	1.62	1.60	811.49	811.50	10	249	250	74	65
D1		40		90	861	.14	1.55	1.20	813.95	813.90	10	250	251	75	65
2		44		90	877	.21	1.85	1.80	816.95	816.90	11	249	250	76	65
3		48		91	881	.22	1.94	1.90	820.01	820.01	11	250	250	77	66
	1717			88	847	.167		1.533							

2/15/24

Project # 4173

Project

Train ID M5/202-4

Box ID 35

Hook-Up ID 26

Date	<u>7/17/23</u>	<u>7/21/23</u>
Time	<u>18:45</u>	<u>17:45</u>
Analyst	<u>L. HOOPER</u>	<u>A. VanSickle</u>
1000 g Cal. Wt.	<u>1000.0</u>	<u>1000.1</u>

Impinger	Type	Charge	Initial Wt.	Final Wt.	Difference
1	Cond/KO Catch	Dry (w/Condenser)	<u>648.5</u>	<u>798.0</u>	
2	MGBS	Dry	<u>579.9</u>	<u>579.9</u>	
-	CPM Filter Holder and Filter				-
3	MGBS	100 mL H ₂ O	<u>691.8</u>	<u>689.1</u>	
Silica Gel	MGBS	~ 200 g Silica Gel	<u>635.8</u>	<u>658.8</u>	
				Total	

Run ID 114

FPM Filter ID F23-7-2

Optional CPM Filter ID NA

FPM Filter Condition	
Intact?	<u>YES</u>
Color:	<u>Black</u>
Loading:	<u>Heavy</u>
Recovered By:	<u>A. VanSickle</u>

CPM Filter Condition	
Intact?	<u>YES</u>
Color:	<u>White</u>
Recovered By:	<u>A. VanSickle</u>

Silica Gel Condition	
<u>90</u>	% Spent

Sample Identification	
FH Rinses:	Proj. No. - Run No. - 010
FPM Filter:	Proj. No. - Run No. - 011
Impinger Catch/Aq Rinses:	Proj. No. - Run No. - 012
Organic Rinses:	Proj. No. - Run No. - 013
Filter CPM:	Proj. No. - Run No. - 014

Reagent/Material Information	
Acetone:	Fisher Lot
Reagent Water:	Fisher Lot
Hexane:	Fisher Lot
FPM Filter:	
CPM Filter:	

Comments:

Reviewed By:

Project

 Project #

 Train ID

 Run Number

Date	7.20.23
Analyst	T. P. H.
H ₂ O added (mL)	111.7
Beginning Pressure (psi)	~ 600

Purge Time (≥60 min)	Clock Time (24hr)	Flow (≥14 LPM)	Temp (65-85 °F)
0	17:42	14	79.6
10	17:52	14	79.4
20	18:02	14	79.0
30	18:12	14	78.4
40	18:22	14	78.7
50	18:32	14	78.1
60	18:42	14	78.1

 Ending Pressure (psi)
Reagent/Material Information

 H₂O Lot No. :

 N₂ Cylinder No. :

Regulator ID No. :

Rotometer ID No. :

Comments:

Reviewed By:

Run Information

Project #	4173
Project	Rain CII LLC
Location	K-1 Stack
Date	7/20/23
Run #	115
Method	EPA Methods 5 and 202

Equipment

Probe ID	5-5
Liner Type	Q
Pitot ID	55-2
Pitot Coefficient	.84
Thermocouple ID	68.3

Oven Box ID	13
Umbilical ID	0-200-1
Barometer ID	B24

Palmtop ID	3
Meter Box ID	1
DGM Correction (Y)	1.015
Orifice Meter ΔH@	1.900

Run Parameters

Train ID	P22-10-245-1
FPM Filter ID/TC ID	M5-202-16
CPM Filter TC ID	6
Barometer Reading	29.32
Meter Box Elevation	0
Test Port Elevation	125

Stack Diameter	122"
Static Pressure	
Min/Point	4

Nozzle ID	Q261
Nozzle Type	Quartz
Nozzle Diameter	0.396

Assumed Conditions

Percent H ₂ O	10
Percent O ₂	15.9
Percent CO ₂	3.4
Average Δp	.160
Stack Temp	850

Pitot Leak Checks	Initial (>3" H ₂ O)	1742					
	Final (>3" H ₂ O)	1854					
	Pass/Fail	PASS					

Initial Sample Train Leak Check	Time (24 hour)	1742					
	Vacuum (in Hg)	>15	>15	>15	>15	>15	>15
	Leak Rate (CFM)	.001					
Final Sample Train Leak Check	Time (24 hour)	1854					
	Vacuum (in. Hg)	19"					
	Leak Rate (CFM)	.002					

Comments

Equipment Problems/Changes/Notes

Performed By:

K. McKenna

Reviewed By:

JK 8/7/23



LR 8/7/23

Project # 4173

Project

Train ID M5/202-6

Box ID 41

Hook-Up ID 29

Date	<u>7/17/23</u>	<u>7/28/23</u>
Time	<u>19:20</u>	<u>19:50</u>
Analyst	<u>L. Hopper</u>	<u>A. VanSickle</u>
1000 g Cal. Wt.	<u>1000.0</u>	<u>1000.1</u>

Impinger	Type	Charge	Initial Wt.	Final Wt.	Difference
1	Cond/KO Catch	Dry (w/Condenser)	<u>770.1</u>	<u>922.2</u>	
2	MGBS	Dry	<u>605.9</u>	<u>606.0</u>	
-	CPM Filter Holder and Filter				-
3	MGBS	100 mL H ₂ O	<u>615.9</u>	<u>605.4</u>	
Silica Gel	MGBS	~ 200 g Silica Gel	<u>741.4</u>	<u>764.8</u>	
Total					

Run ID 115

FPM Filter ID F22-10-24

Optional CPM Filter ID NA

FPM Filter Condition
Intact? <u>YES</u>
Color: <u>Black</u>
Loading: <u>Heavy</u>
Recovered By: <u>A. VanSickle</u>

Sample Identification
FH Rinses: Proj. No. - Run No. - 010
FPM Filter: Proj. No. - Run No. - 011
Impinger Catch/Aq Rinses: Proj. No. - Run No. - 012
Organic Rinses: Proj. No. - Run No. - 013
Filter CPM: Proj. No. - Run No. - 014

CPM Filter Condition
Intact? <u>YES</u>
Color: <u>White</u>
Recovered By: <u>A. VanSickle</u>

Reagent/Material Information
Acetone: Fisher Lot
Reagent Water: Fisher Lot
Hexane: Fisher Lot
FPM Filter:
CPM Filter:

Silica Gel Condition
<u>85</u> % Spent

Comments:

#8 CLIP ON COND/KO

Reviewed By:

Project Rain CII LLC	Project # 4173
---	---

Train ID M5/202- 5
Run Number 115

Date	7-20-23
Analyst	T. P. H.
H₂O added (mL)	120.7
Beginning Pressure (psi)	~2100

Purge Time (≥60 min)	Clock Time (24hr)	Flow (≥14 LPM)	Temp (65-85 °F)
0	19:07	14	79.0
10	19:17	14	79.3
20	19:27	14	79.4
30	19:37	14	79.8
40	19:47	14	79.8
50	19:57	14	80.0
60	20:07	14	81.1

Ending Pressure (psi)	~1500
------------------------------	-------

Reagent/Material Information	
H ₂ O Lot No. :	
N ₂ Cylinder No. :	
Regulator ID No. :	
Rotometer ID No. :	

Comments:

Reviewed By:

Appendix C-2
Analyzer Data Log



TIER 5 LABS
5353 W. SOUTHERN AVE.
INDIANAPOLIS, IN 46241
317-536-5590

Product:	Nitrogen CEM	Minimum Purity:	99.9995%
Mixture Grade:	5.5	Certification Date:	22 October 2021
Cylinder Fill Pressure:	2015 PSIG	Issuance Date:	22 October 2021
		Expiration Date:	22 October 2029
		Lot Number:	S29513A9

Do not use below 100 psi (0.7 megapascals)

Purity Specification

Analyte	Specification	Concentration	Assay Dates
Total Hydrocarbons	< 0.05 PPM	< 0.05 PPM	10/22/2021
Carbon Monoxide	< 1 PPM	< 1 PPM	10/22/2021
Carbon Dioxide	< 10 PPM	< 10 PPM	10/22/2021
Oxygen	< 2 PPM	= 0.53 PPM	10/22/2021
Total NOx	< 0.02 PPM	< 0.02 PPM	10/22/2021
Nitrous Oxide	< 0.02 PPM	< 0.02 PPM	10/22/2021
Moisture	< 2 PPM	= 0.81 PPM	10/22/2021

Cylinders in Lot

CC458715	CC84077	EB0048027
CC478929	EB0004527	CC81798
EB0053738	CC362797	CC94875
CC517259	CC514172	EB0132154
CC516345	CC480389	CC455093
CC479020	CC462284	CC722220
CC300260	EB0132125	CC479431
EB0053746	CC454521	EB0051888
	CC480390	

40 CFR1065.750 Compliant

The calibration results published in this certificate were obtained using equipment and standards capable of producing results that are traceable to National Institute of Standards and Technology (NIST) and through NIST to the International System of Units (SI). The expanded uncertainties, if included on this certificate, use a coverage factor of $k=2$ to approximate the 95% confidence level of the measurement, unless otherwise noted. If uncertainties are not included on this certificate, they are available upon request. This calibration certificate applies only to the item described and shall not be reproduced other than in full, without written approval from the calibration facility. Calibration certificates without signatures are not valid. This calibration meets the requirements of ISO/IEC 17025-2005

Christopher Haas

Analytical Chemist: Christopher Haas

Eric Frymier

Production Manager: Eric Frymier

Production Laboratory:

Tier 5 Labs, LLC

5353W. Southern Ave.

Indianapolis, IN 46241

PGVP Vendor ID R12021

CERTIFICATE OF ANALYSIS

Grade of Product: EPA Protocol

Part Number:	E03NI73E15A1FW8	Reference Number:	54-401323400-1
Cylinder Number:	CC414201	Cylinder Volume:	149.6 CF
Laboratory:	124 - Chicago (SAP) - IL	Cylinder Pressure:	2015 PSIG
PGVP Number:	B12018	Valve Outlet:	590
Gas Code:	CO2,O2,BALN	Certification Date:	Oct 15, 2018

Expiration Date: Oct 15, 2026

Certification performed in accordance with "EPA Traceability Protocol for Assay and Certification of Gaseous Calibration Standards (May 2012)" document EPA 600/R-12/531, using the assay procedures listed. Analytical Methodology does not require correction for analytical interference. This cylinder has a total analytical uncertainty as stated below with a confidence level of 95%. There are no significant impurities which affect the use of this calibration mixture. All concentrations are on a volume/volume basis unless otherwise noted.

Do Not Use This Cylinder below 100 psig, i.e. 0.7 megapascals.

ANALYTICAL RESULTS					
Component	Requested Concentration	Actual Concentration	Protocol Method	Total Relative Uncertainty	Assay Dates
CARBON DIOXIDE	6.000 %	5.860 %	G1	+/- 1% NIST Traceable	10/15/2018
OXYGEN	21.00 %	21.00 %	G1	+/- 1% NIST Traceable	10/15/2018
NITROGEN	Balance			-	

CALIBRATION STANDARDS					
Type	Lot ID	Cylinder No	Concentration	Uncertainty	Expiration Date
NTRM	13060414	CC413576	7.489 % CARBON DIOXIDE/NITROGEN	+/- 0.6%	Jan 14, 2019
NTRM	15010409	K013750	22.454 % OXYGEN/NITROGEN	+/- 0.2%	Aug 05, 2021

ANALYTICAL EQUIPMENT		
Instrument/Make/Model	Analytical Principle	Last Multipoint Calibration
CO2-1 HORIBA VIA-510 V1E3H7P5	NDIR	Oct 12, 2018
O2-1 HORIBA MPA-510 3VUYL9NR	Paramagnetic	Sep 17, 2018

Triad Data Available Upon Request



Signature on file

Approved for Release



Certificate of Analysis – EPA Protocol Gas

Customer:
American Welding & Gas
E Frontage Road
Grandview, MO 64030

PO Number: 438794
Reference#: CGS-10-24195
Date Filled: 7/20/2022
Customer Part #: CSG E840001-A1-1 J20

Serial Number	Size	Concentration Basis	Standard type	Certificate ID
216803160	ALS	Mole	EPA Protocol	05-07282201

Certified Concentration

Carbon Dioxide =	12.36%	+/- 0.06%
Oxygen =	12.11%	+/- 0.05%
Nitrogen =	Balance Gas	

Analytical Information

Component	Analyzer Make/Model/SN	Analytical Principle	Last Calibration Date
Carbon Dioxide	Thermo Nicolet 6700 APW100179	FT-IR	7/6/2022
Oxygen	Servomex 5200 12730	Paramagnetic	7/18/2022
Assay Date	7/28/2022		

Reference Standard(s)

Component	GMIS #	Cylinder #	Concentration	Uncertainty	Expiration Date
Carbon Dioxide	10-15142-5-2	EB0005338	16.23%	+/- 0.12%	8/31/2026
Oxygen	10-4838-2	CC300673	14.90%	+/- 0.04%	5/5/2028
Nitrogen			Balance Gas		

CO2 GMIS certified by:						
Component	SRM #	N.I.S.T. Sample #	Cylinder #	Concentration	Uncertainty	Expiration Date
Carbon Dioxide	2745	9-D-10	FF13635	16.080%	+/- 0.020%	4/8/2021
Nitrogen				Balance Gas		

O2 GMIS certified by:						
Component	SRM #	N.I.S.T. Sample #	Cylinder #	Concentration	Uncertainty	Expiration Date
Oxygen	2659a	71-D-35	CAL015756	20.720%	+/- 0.043%	8/23/2021
Nitrogen				Balance Gas		

This calibration standard has been certified per the 2012 EPA Traceability Protocol, Document EPA 600/R-12/531, using the procedure G1.

Do Not Use This Standard Below 100 psig (0.7 Megapascals).

Valve Outlet Connection CGA: 590
Mix Pressure(psig)@70F: 2000
Certification Date: 7/28/2022
Shelf Life: 8 years
Expiration date: 7/28/2030

Certified By:

Reviewed By:

Produced By:

Coastal Specialty Gas: (409) 981-7700
2150 Interstate 10 East, Beaumont, TX 77703
Coastal Specialty Gas PGVP Vendor ID: O12022



Certificate of Analysis – EPA Protocol Gas

Customer:
American Welding & Gas
5353 W Southern Ave
Indianapolis, IN 46241

PO Number: 394546
Reference#: CGS-10-22568
Date Filled: 9/8/2021
Customer Part #: P6MB001-A1-1

Cylinder Number	Size	Concentration Basis	Standard type	Certificate ID
CC463386	ALS	Mole	EPA Protocol	03-04012201

Certified Concentration

Carbon Monoxide =	6.20 ppm	+/- 0.07 ppm
Nitric Oxide =	6.77 ppm	+/- 0.09 ppm
NOx =	6.88 ppm	
Propane =	8.40 ppm	+/- 0.08 ppm
Nitrogen =	Balance Gas	

Analytical Information

Component	Analyzer Make/Model/SN	Analytical Principle	Last Calibration Date
Carbon Monoxide	Thermo Nicolet 6700 APW100179	FT-IR	3/23/2022
Nitric Oxide	Thermo Nicolet 6700 APW100179	FT-IR	3/10/2022
Propane	Thermo Nicolet 6700 APW100179	FT-IR	3/11/2022

First Assay Date 3/25/2022

Second Assay Date 4/1/2022

Reference Standard(s)

Component	GMIS #	Cylinder #	Concentration	Uncertainty	Expiration Date
Carbon Monoxide	10-18973	CC482690	10.37 ppm	+/- 0.06 ppm	10/25/2027
Nitric Oxide	10-09-1402	ND52081	4.97 ppm	+/- 0.04 ppm	11/22/2022
NOx	10-09-1402	ND52081	5.03 ppm		11/22/2022
Propane	PRM	D970450	4.999 ppm	+/- 0.025 ppm	9/14/2026
Nitrogen			Balance Gas		

CO GMIS certified by:

Component	SRM #	N.I.S.T. Sample #	Cylinder #	Concentration	Uncertainty	Expiration Date
Carbon Monoxide	1677c	5-J-16	CAL015280	9.825 ppm	+/- 0.047 ppm	6/24/2024
Nitrogen				Balance Gas		

NO GMIS certified by:

Component	PRM	Cylinder #	Concentration	Uncertainty	Expiration Date
Nitric Oxide		APEX1324309	5.00 ppm	+/- 0.04 ppm	9/12/2021
Nitrogen Oxides (NOx)		APEX1324309	5.00 ppm	+/- 0.04 ppm	9/12/2021
Nitrogen			Balance Gas		

This calibration standard has been certified per the 2012 EPA Traceability Protocol, Document EPA 600/R-12/531, using the procedure G1.

Do Not Use This Standard Below 100 psig (0.7 Megapascals).

Valve Outlet Connection CGA: **660**
Mix Pressure(psig)@70F: **1500**
Certification Date: **4/1/2022**
Shelf Life: **2 years**
Expiration date: **4/1/2024**

Certified By:

Kelly Nage

Reviewed By:

Jennifer Healy

Produced By:

Coastal Specialty Gas: (409) 981-7700
2150 Interstate 10 East, Beaumont, TX 77703
Coastal Specialty Gas PGVP Vendor ID: 012022



Certificate of Analysis – EPA Protocol Gas

Customer:
American Welding & Gas
5353 W Southern Ave
Indianapolis, IN 46241

PO Number: 471431
Reference#: CGS-10-25339
Date Filled: 3/6/2023
Customer Part #: CSG E6MAB01-A1-2

Cylinder Number RR04942	Size ALS	Concentration Basis Mole	Standard type EPA Protocol	Certificate ID 03-03212301
-----------------------------------	--------------------	------------------------------------	--------------------------------------	--------------------------------------

Certified Concentration

Carbon Monoxide =	13.00 ppm	+/- 0.13 ppm
Nitric Oxide =	12.46 ppm	+/- 0.14 ppm
NOx =	12.59 ppm	
Sulfur Dioxide =	12.95 ppm	+/- 0.17 ppm
Propane =	16.22 ppm	+/- 0.16 ppm
Nitrogen =	Balance Gas	

Analytical Information

Component	Analyzer Make/Model/SN	Analytical Principle	Last Calibration Date
Carbon Monoxide	Thermo Nicolet iS50 AUP2210530	FT-IR	3/3/2023
Nitric Oxide	Thermo Nicolet iS50 AUP2210530	FT-IR	3/10/2023
Sulfur Dioxide	Thermo Nicolet iS50 AUP2210530	FT-IR	3/17/2023
Propane	Thermo Nicolet iS50 AUP2210530	FT-IR	3/9/2023

First Assay Date 3/14/2023

Second Assay Date 3/21/2023

Reference Standard(s)

Component	GMIS #	Cylinder #	Concentration	Uncertainty	Expiration Date
Carbon Monoxide	10-18973	CC474269	10.34 ppm	+/- 0.06 ppm	10/25/2027
Nitric Oxide	01-142002	CC493943	9.90 ppm	+/- 0.10 ppm	3/10/2026
NOx	01-142002	CC493943	10.07 ppm		3/10/2026
Sulfur Dioxide	5-08-1303	EB0025323	5.06 ppm	+/- 0.06 ppm	2/3/2026
Propane	05-01-1701	CC493803	10.01 ppm	+/- 0.03 ppm	5/1/2025
Nitrogen			Balance Gas		

CO GMIS certified by:

Component	SRM #	N.I.S.T. Sample #	Cylinder #	Concentration	Uncertainty	Expiration Date
Carbon Monoxide	1677c	5-J-16	CAL015280	9.825 ppm	+/- 0.047 ppm	6/24/2024
Nitrogen				Balance Gas		

NO GMIS certified by:

Component	PRM	Cylinder #	Concentration	Uncertainty	Expiration Date
Nitric Oxide		APEX1324311	10.00 ppm	+/- 0.05 ppm	9/12/2023
Nitrogen Oxides (NOx)		APEX1324311	10.00 ppm	+/- 0.05 ppm	9/12/2023
Nitrogen			Balance Gas		

SO2 GMIS certified by:

Component	PRM	Cylinder #	Concentration	Uncertainty	Expiration Date
Sulfur Dioxide		D887573	5.00 ppm	+/- 0.06 ppm	9/20/2022
Nitrogen			Balance Gas		

Propane GMIS certified by:

Component	SRM #	N.I.S.T. Sample #	Cylinder #	Concentration	Uncertainty	Expiration Date
Propane	1666b	84-K-21	FF10563	9.888 ppm	+/- 0.032 ppm	10/5/2019
Nitrogen				Balance Gas		

This calibration standard has been certified per the 2012 EPA Traceability Protocol, Document EPA 600/R-12/531, using the procedure G1.

Do Not Use This Standard Below 100 psig (0.7 Megapascals).

Valve Outlet Connection CGA: **660**
Mix Pressure (psig) @ 70°F: **1900**
Certification Date: **3/21/2023**
Shelf Life: **2 years**
Expiration date: **3/21/2025**

Certified By:

Reviewed By:

Produced By:

Coastal Specialty Gas: (409) 981-7700
2150 Interstate 10 East, Beaumont, TX 77703
Coastal Specialty Gas PGVP Vendor ID: 012023



**GASES &
WELDING SUPPLIES**

Certificate of Analysis – EPA Protocol Gas

Customer:
American Welding & Gas
6353 W Southern Ave
Indianapolis, IN 46241

PO Number: 471203
Reference#: CGS-10-25338
Date Filled: 3/2/2023
Customer Part #: CSG E4MAB01-A1-1

Cylinder Number	Size	Concentration Basis	Standard type	Certificate ID
RR04905	ALS	Mole	EPA Protocol	03-03182301

Certified Concentration

Carbon Monoxide =	25.01 ppm	+/- 0.24 ppm
Nitric Oxide =	25.86 ppm	+/- 0.26 ppm
NOx =	25.14 ppm	
Sulfur Dioxide =	25.91 ppm	+/- 0.28 ppm
Propane =	30.22 ppm	+/- 0.18 ppm
Nitrogen =	Balance Gas	

Analytical Information

Component	Analyzer Make/Model/SN	Analytical Principle	Last Calibration Date
Carbon Monoxide	Thermo Nicolet IS50 AUP2210530	FT-IR	3/3/2023
Nitric Oxide	Thermo Nicolet IS50 AUP2210530	FT-IR	3/10/2023
Sulfur Dioxide	Thermo Nicolet IS50 AUP2210530	FT-IR	2/17/2023
Propane	Thermo Nicolet IS50 AUP2210530	FT-IR	3/9/2023

First Assay Date 3/9/2023

Second Assay Date 3/18/2023

Reference Standard(s)

Component	GMIS #	Cylinder #	Concentration	Uncertainty	Expiration Date
Carbon Monoxide	12-15-2001	CC713082	25.19 ppm	+/- 0.11 ppm	12/15/2028
Nitric Oxide	10-23877-4	CC740243	25.89 ppm	+/- 0.12 ppm	9/26/2025
NOx	10-23877-4	CC740243	26.35 ppm		9/26/2025
Sulfur Dioxide	2-17-2101	CC408176	50.19 ppm	+/- 0.34 ppm	2/17/2025
Propane	05-10-1710	CC493924	25.13 ppm	+/- 0.08 ppm	5/1/2025
Nitrogen			Balance Gas		

CO GMIS certified by:			Concentration	Uncertainty	Expiration Date
Component	SRM #	N.I.S.T. Sample #			
Carbon Monoxide	1578c	4-K-30	49.07 ppm	+/- 0.19 ppm	2/4/2021
Nitrogen			Balance Gas		

NO GMIS certified by:			Concentration	Uncertainty	Expiration Date
Component	PRM	Cylinder #			
Nitric Oxide		APEX1324305	50.02 ppm	+/- 0.20 ppm	9/12/2023
Nitrogen Oxides (NOx)		APEX1324305	50.02 ppm	+/- 0.20 ppm	9/12/2023
Nitrogen			Balance Gas		

SO2 GMIS certified by:			Concentration	Uncertainty	Expiration Date
Component	SRM #	N.I.S.T. Sample #			
Sulfur Dioxide	1893a	96-N-80	50.18 ppm	+/- 0.28 ppm	9/27/2023
Nitrogen			Balance Gas		

Propane GMIS certified by:			Concentration	Uncertainty	Expiration Date
Component	SRM #	N.I.S.T. Sample #			
Propane	1867b	83-K-03	49.61 ppm	+/- 0.11 ppm	7/1/2024
Nitrogen			Balance Gas		

This calibration standard has been certified per the 2012 EPA Traceability Protocol, Document EPA 600/R-12/531, using the procedure G1.

Do Not Use This Standard Below 100 psig (0.7 Megapascals).

Valve Outlet Connection CGA: **550**
Mix Pressure(psig)/PSI: **1900**
Certification Date: **3/16/2023**
Shelf Life: **2 years**
Expiration date: **3/16/2025**

Certified By:

Kelly Nag

Reviewed By:

Becca Dunbar

Produced By:
Coastal Specialty Gas: (409) 981-7700
2150 Interstate 10 East, Beaumont, TX 77703
Coastal Specialty Gas PGVP Vendor ID: 012023



Certificate of Analysis – EPA Protocol Gas

Customer:
American Welding & Gas
5353 W Southern Ave
Indianapolis, IN 46241

PO Number: 444080
Reference#: CGS-10-24386
Date Filled: 9/2/2022
Customer Part #: E6MAB01-A 1.1

Cylinder Number
CC508574

Size
ALS

Concentration Basis
Mole

Standard type
EPA Protocol

Certificate ID
03-10112201

Certified Concentration

Carbon Monoxide = 51.45 ppm +/- 0.51 ppm
Nitric Oxide = 50.41 ppm +/- 0.55 ppm
NOx = 50.52 ppm
Sulfur Dioxide = 51.95 ppm +/- 0.55 ppm
Propane = 51.88 ppm +/- 0.21 ppm
Nitrogen = Balance Gas

Analytical Information

Component	Analyzer Make/Model/SN	Analytical Principle	Last Calibration Date
Carbon Monoxide	Thermo Nicolet IS50 AUP2010168 FT-IR		9/12/2022
Nitric Oxide	Thermo Nicolet IS50 AUP2010168 FT-IR		10/10/2022
Sulfur Dioxide	Thermo Nicolet IS50 AUP2010168 FT-IR		9/29/2022
Propane	Thermo Nicolet IS50 AUP2010168 FT-IR		9/12/2022
First Assay Date	9/26/2022	Second Assay Date	10/11/2022

Reference Standard(s)

Component	GMIS #	Cylinder #	Concentration	Uncertainty	Expiration Date
Carbon Monoxide	01-27-2201	CC16375	50.71 ppm	+/- 0.16 ppm	1/27/2030
Nitric Oxide	10-21521-2	CC438453	51.32 ppm	+/- 0.21 ppm	4/9/2025
NOx	10-21521-2	CC438453	52.83 ppm		4/9/2025
Sulfur Dioxide	2-17-2101	CC408176	50.19 ppm	+/- 0.34 ppm	2/17/2025
Propane	05-10-1706	CC493805	49.86 ppm	+/- 0.13 ppm	5/1/2025
Nitrogen			Balance Gas		

CO GMIS certified by:	Component	PRM	Cylinder #	Concentration	Uncertainty	Expiration Date
Carbon Monoxide			D687692	50.05 ppm	+/- 0.15 ppm	9/10/2025
Nitrogen				Balance Gas		

NO GMIS certified by:	Component	PRM	Cylinder #	Concentration	Uncertainty	Expiration Date
Nitric Oxide			APEX1324305	50.02 ppm	+/- 0.20 ppm	9/12/2022
Nitrogen Oxides (NOx)			APEX1324305	50.02 ppm	+/- 0.20 ppm	9/12/2022
Nitrogen				Balance Gas		

SO2 GMIS certified by:	Component	SRM #	N.I.S.T. Sample #	Cylinder #	Concentration	Uncertainty	Expiration Date
Sulfur Dioxide		1693a	96-N-60	FF28076	50.18 ppm	+/- 0.28 ppm	6/27/2023
Nitrogen					Balance Gas		

Propane GMIS certified by:	Component	SRM #	N.I.S.T. Sample #	Cylinder #	Concentration	Uncertainty	Expiration Date
Propane		1667b	83-K-06	FF55567	49.61 ppm	+/- 0.11 ppm	7/1/2024
Nitrogen					Balance Gas		

This calibration standard has been certified per the 2012 EPA Traceability Protocol, Document EPA 600/R-12/531, using the procedure G1.

Do Not Use This Standard Below 100 psig (0.7 Megapascals)

Valve Outlet Connection CGA: **660**
Mix Pressure(psig)@70°F: **1900**
Certification Date: **10/11/2022**
Shelf Life: **2 years**
Expiration date: **10/11/2024**

Certified By:

Reviewed By:

Produced By:
Coastal Specialty Gas: (409) 981-7700
2150 Interstate 10 East, Beaumont, TX 77703
Coastal Specialty Gas PGVP Vendor ID: 012022

Data Cal

Data File Path:	C:\Users\taylor.pittman\Documents\AirSource Log Data Files
Data File Name:	Rain CII Kiln 23 7-20-2023 Cal

Time	Comment	CAI 2-O2	CAI 2-CO2	hermo THC 1-THC
7/20/2023 7:29	zero direct	0.004577637	-0.006103516	30.09338
7/20/2023 7:30				
7/20/2023 7:31	21 o2	20.98134	5.455526	31.38428
7/20/2023 7:32				
7/20/2023 7:33	12.11/12.36	20.98134	5.455526	31.38428
7/20/2023 7:34		12.24874	12.34741	30.62541
7/20/2023 7:34	5.86 co2	20.96522	6.104234	30.48742
7/20/2023 7:34		20.96522	6.104234	30.48742
7/20/2023 7:39		20.96522	6.104234	30.48742
7/20/2023 7:39		20.96522	6.104234	30.48742
7/20/2023 7:39		20.96522	6.104234	30.48742
7/20/2023 7:39		20.96522	6.104234	30.48742
7/20/2023 7:48		20.92712	5.934448	26.86768
7/20/2023 8:30	n2 bias	0.04490444	0.164359	-100
7/20/2023 8:36		0.07019043	0.1642863	-0.05795898
7/20/2023 8:37				
7/20/2023 8:39	12/12/2023	12.06027	12.4312	4.246129
7/20/2023 8:40				
7/20/2023 8:41	51.88 c3h8 span	0.1657104	0.2432251	51.99525
7/20/2023 8:42				
7/20/2023 8:43	30.22	1.607444	0.2125133	30.01185
7/20/2023 8:45				
7/20/2023 8:46	16.22	1.983643	0.201416	16.14484
7/20/2023 8:48				
7/20/2023 8:49	8.4	1.072998	0.1885986	8.504053
7/20/2023 10:32	zero			
7/20/2023 10:32	r1 zero			
7/20/2023 10:33		0.1376065	0.1792214	-0.1106712
7/20/2023 10:34	12/12/2023	12.05885	12.48847	-0.1115343
7/20/2023 10:38				
7/20/2023 10:40	8.4	0.02929688	0.2563477	8.30996
7/20/2023 10:43				
7/20/2023 11:30	r2 n2	0.05249023	0.2380371	-0.1861328
7/20/2023 11:32				
7/20/2023 11:33	12/12/2023	12.00256	12.44812	-0.0640625
7/20/2023 11:34				
7/20/2023 11:34	8.4	0.5132502	0.3712047	8.234498
7/20/2023 11:36				
7/20/2023 12:35	r3 zero	0.15625	0.2197266	-0.2105469
7/20/2023 12:38				
7/20/2023 12:40	12/12/2023	11.9873	12.42065	-0.1128906
7/20/2023 12:43		0.09416853	0.2443586	8.234105
7/20/2023 13:30	r4 zero	0.1009428	0.1464844	-0.2105469
7/20/2023 13:32				
7/20/2023 13:32	12/12/2023	12.00409	12.33521	-0.1373047
7/20/2023 13:34				
7/20/2023 13:35	8.4	0.05187988	0.1413981	8.236718
7/20/2023 14:36				
7/20/2023 14:37	r5 zero	0.06209664	0.1464844	-0.2646825
7/20/2023 14:37				
7/20/2023 14:39	12/12/2023	12.02637	12.33867	-0.1861328
7/20/2023 14:39				
7/20/2023 14:40	8.4	0.181071	0.2543131	8.171615
7/20/2023 14:40		0.09969076	0.2258301	8.187891
7/20/2023 15:30	r6 zero			
7/20/2023 15:32		0.07171631	0.1373291	-0.2837891
7/20/2023 15:32	12/12/2023			
7/20/2023 15:34		11.97876	12.31812	-0.1861328
7/20/2023 15:34		12.00562	12.31842	-0.1861328
7/20/2023 15:35				
7/20/2023 15:37	8.4	0.04621233	0.1534598	8.18789
7/20/2023 15:38		0.002034505	0.1495361	8.224511
7/20/2023 16:33	r7 zero	0.0189209	0.178833	-0.1592773
7/20/2023 16:35				
7/20/2023 16:35	12/12/2023			
7/20/2023 16:38		12.06421	12.40112	-0.08115233
7/20/2023 16:42	8.4			
7/20/2023 16:42		0.000678168	0.1803928	8.331661
7/20/2023 17:31	r8 zero			
7/20/2023 17:33		0.03313337	0.1796177	-0.08847655

Electronic Filing: Received, Clerk's Office 03/15/2024

Time	Comment	CAI 2-O2	CAI 2-CO2	hermo THC 1-THC
7/20/2023 17:33	12/12/2023			
7/20/2023 17:35		11.97859	12.33521	-0.01523438
7/20/2023 17:35		11.97917	12.34131	-0.01523438
7/20/2023 17:36		12.07581	12.36115	-0.01523437
7/20/2023 17:36	8.4			
7/20/2023 17:37		0.3363715	0.2882216	8.358788
7/20/2023 18:42	r9 zero			
7/20/2023 18:44		0.0221946	0.1376065	-0.08181817
7/20/2023 18:47		12.00867	12.32605	-0.01523438
7/20/2023 18:47		11.9873	12.32571	-0.009809027
7/20/2023 18:48	8.4			
7/20/2023 18:48		0.3869098	0.2685547	8.332253

Data 1-min			
		Thermo 1HC 1-	
Time	Comment	CAI 2-O2	CAI 2-CO2
7/20/2023 6:49		20.2274	-0.1154436
7/20/2023 6:50		20.2395	-0.08691406
7/20/2023 6:51		20.2446	-0.04279437
7/20/2023 6:52		20.25438	-0.04692078
7/20/2023 6:53		20.25803	-0.07913279
7/20/2023 6:54		20.26224	-0.145949
7/20/2023 6:55		20.2636	-0.165366
7/20/2023 6:56		20.26085	-0.1626533
7/20/2023 6:57		20.2666	-0.1640097
7/20/2023 6:58		20.27171	-0.1724782
7/20/2023 6:59		20.2646	-0.1597205
7/20/2023 7:00		20.26949	-0.1289948
7/20/2023 7:01		20.26856	-0.1112553
7/20/2023 7:02		20.27038	-0.05279006
7/20/2023 7:03		20.26123	-0.01999799
7/20/2023 7:04		20.2571	-0.01863178
7/20/2023 7:05		20.25553	-0.0422606
7/20/2023 7:06		20.25507	-0.08148729
7/20/2023 7:07		20.26064	-0.1101131
7/20/2023 7:08		20.26025	-0.1061869
7/20/2023 7:09		20.2626	-0.0922209
7/20/2023 7:10		20.26178	-0.07081506
7/20/2023 7:11		20.24936	-0.09030347
7/20/2023 7:12		20.25386	-0.09612145
7/20/2023 7:13		20.25782	-0.09180259
7/20/2023 7:14		20.26014	-0.09119581
7/20/2023 7:15		20.2543	-0.09884105
7/20/2023 7:16		20.24981	-0.08613138
7/20/2023 7:17		20.25511	-0.0856298
7/20/2023 7:18		20.26658	-0.1056626
7/20/2023 7:19		20.26899	-0.1205883
7/20/2023 7:20		20.26468	-0.139189
7/20/2023 7:21		20.26665	-0.1557474
7/20/2023 7:22		20.27113	-0.1701489
7/20/2023 7:23		20.27689	-0.184514
7/20/2023 7:24		20.28299	-0.1955997
7/20/2023 7:25		20.28621	-0.2296944
7/20/2023 7:26		20.284	-0.2230853
7/20/2023 7:27		20.28603	-0.1784827
7/20/2023 7:28		20.2887	-0.1613841
7/20/2023 7:29		20.32521	-0.1887034
7/20/2023 7:30		5.780896	-0.27585
7/20/2023 7:31		0.1737154	-0.003467086
7/20/2023 7:32		16.62916	4.65557
7/20/2023 7:33		20.29647	6.100611
7/20/2023 7:34		12.32022	11.12364
7/20/2023 7:35		16.20703	9.07527
7/20/2023 7:36		21.02014	6.103333
7/20/2023 7:37		21.03323	6.111775
7/20/2023 7:38		21.0378	6.111073
7/20/2023 7:39		21.0485	6.096937
7/20/2023 7:40		21.04916	6.100592
7/20/2023 7:41		20.67261	0.1464844
7/20/2023 7:42		20.63599	0.1464844
7/20/2023 7:43		20.5621	0.1676382
7/20/2023 7:44		20.87702	5.641574
7/20/2023 7:45		20.84404	4.278857
7/20/2023 7:51		20.81529	2.957939
7/20/2023 7:52	setup	20.76135	2.123366
7/20/2023 7:53		20.72735	1.642586
7/20/2023 7:54		20.71056	1.507568
7/20/2023 7:54		20.71659	1.290894
7/20/2023 7:55		20.695	0.7321691
7/20/2023 7:56		20.59232	0.28022
7/20/2023 7:57		20.56242	0.1685288
7/20/2023 7:58		20.56585	0.1300518
7/20/2023 7:59		20.55686	0.1102582
7/20/2023 8:00		20.55057	0.1227204
7/20/2023 8:01		20.54702	0.1367188
7/20/2023 8:02		20.54819	0.1410309
7/20/2023 8:03		20.54504	0.1563936
7/20/2023 8:04		20.54138	0.1728013
7/20/2023 8:05		20.50637	0.1941929
7/20/2023 8:06		20.49051	0.2093147
7/20/2023 8:07		20.47686	0.2154288
7/20/2023 8:08		20.47816	0.2267276
7/20/2023 8:09		20.48239	0.2377843
7/20/2023 8:10		20.49507	0.2367087
7/20/2023 8:11		20.50182	0.2367805
7/20/2023 8:12		20.51327	0.2283582
7/20/2023 8:13		20.50157	0.2305693
7/20/2023 8:14		20.4839	0.237062
7/20/2023 8:15		20.47442	0.2380371
7/20/2023 8:16		20.47956	0.2355957
7/20/2023 8:17		20.49203	0.2323309
7/20/2023 8:18		20.50052	0.2205882
7/20/2023 8:19		20.51197	0.2229408

Data 1-min			
Time	Comment	CAI 2-O2	CAI 2-CO2
Thermo 1HC 1-			
T _{HC}			
7/20/2023 8:20		20.51413	0.2211627
7/20/2023 8:21		20.51594	0.2220018
7/20/2023 8:22		20.50056	0.2229937
7/20/2023 8:23		20.48394	0.2396623
7/20/2023 8:24		20.46458	0.2601534
7/20/2023 8:25		20.47037	0.2628102
7/20/2023 8:26		19.57782	0.9909955
7/20/2023 8:27		18.63501	1.398825
7/20/2023 8:28		18.65073	1.399464
7/20/2023 8:29		18.64826	1.4249
7/20/2023 8:30		18.64445	1.427469
7/20/2023 8:31		18.63468	1.430678
7/20/2023 8:32		7.742741	0.4273897
7/20/2023 8:33		0.1120534	0.1533059
7/20/2023 8:34		0.05109002	0.149967
7/20/2023 8:35		0.04060633	0.161061
7/20/2023 8:36		0.03795737	0.1643615
7/20/2023 8:37		0.03331502	0.1617795
7/20/2023 8:38		0.02989626	0.1612132
7/20/2023 8:39		6.5797	0.1612132
7/20/2023 8:40		11.99586	6.590262
7/20/2023 8:41		5.570838	12.44584
7/20/2023 8:42		0.09528063	4.193878
7/20/2023 8:43		9.375365	0.2375254
7/20/2023 8:44		1.963951	0.9614682
7/20/2023 8:45		11.13102	0.2167838
7/20/2023 8:46		18.23255	1.12714
7/20/2023 8:47		2.03788	1.399532
7/20/2023 8:48		10.24594	0.2102972
7/20/2023 8:49		13.25724	1.05653
7/20/2023 8:50		1.493534	0.9273689
7/20/2023 8:51		17.23114	0.366284
7/20/2023 8:52		18.53455	1.452088
7/20/2023 8:53		18.57472	1.452088
7/20/2023 8:54		18.5473	1.461627
7/20/2023 8:55		18.58127	1.457832
7/20/2023 8:56		18.59182	1.460652
7/20/2023 8:57		18.59968	1.452927
7/20/2023 8:58		18.5981	1.460275
7/20/2023 8:59		18.59436	1.45805
7/20/2023 9:00		18.59383	1.467292
7/20/2023 9:01		18.6064	1.463894
7/20/2023 9:02		18.59058	1.457973
7/20/2023 9:03		18.58615	1.465611
7/20/2023 9:04		18.58279	1.470984
7/20/2023 9:05		18.5916	1.456306
7/20/2023 9:06		18.60304	1.455853
7/20/2023 9:07		18.60373	1.448858
7/20/2023 9:08		18.60483	1.452198
7/20/2023 9:09		18.60607	1.450846
7/20/2023 9:10		18.59039	1.459325
7/20/2023 9:11		18.61324	1.439004
7/20/2023 9:12		18.61064	1.439626
7/20/2023 9:13		18.60249	1.442915
7/20/2023 9:14		18.60181	1.45053
7/20/2023 9:15		18.62161	1.437579
7/20/2023 9:16		18.6105	1.445217
7/20/2023 9:17		18.60889	1.443463
7/20/2023 9:18		18.62891	1.435271
7/20/2023 9:19		18.63699	1.432279
7/20/2023 9:20		18.64584	1.424444
7/20/2023 9:21		18.61196	1.447264
7/20/2023 9:22		18.63732	1.431914
7/20/2023 9:23		18.63283	1.432682
7/20/2023 9:24		18.65512	1.424751
7/20/2023 9:25		18.63389	1.441672
7/20/2023 9:26		18.64777	1.428477
7/20/2023 9:27		18.63319	1.433449
7/20/2023 9:28		18.62947	1.427894
7/20/2023 9:29		18.63012	1.428003
7/20/2023 9:30		18.61912	1.423142
7/20/2023 9:31		18.63396	1.405589
7/20/2023 9:32		18.63743	1.403589
7/20/2023 9:33		18.63712	1.404208
7/20/2023 9:34		18.63648	1.403187
7/20/2023 9:35		18.63491	1.404832
7/20/2023 9:36		18.63312	1.400483
7/20/2023 9:37		18.62462	1.406061
7/20/2023 9:38		18.62117	1.40761
7/20/2023 9:39		18.63685	1.395914
7/20/2023 9:40		18.62409	1.406842
7/20/2023 9:41		18.61733	1.418391
7/20/2023 9:42		18.6181	1.413
7/20/2023 9:43		18.64547	1.414773
7/20/2023 9:44		18.62401	1.402853
7/20/2023 9:45		18.63659	1.416343
7/20/2023 9:46		18.63433	1.411228
7/20/2023 9:47			1.422229

Data 1-min

Time	Comment	CAI 2-O2	CAI 2-CO2	Thermo IHC 1-TLC
7/20/2023 9:48		18.58802	1.460604	4.577529
7/20/2023 9:49		18.55055	1.482827	8.584315
7/20/2023 9:50		18.48883	1.522407	12.38461
7/20/2023 9:51		18.42436	1.548392	17.92151
7/20/2023 9:52		18.34523	1.579568	21.77896
7/20/2023 9:53		18.28241	1.618053	22.20613
7/20/2023 9:54		18.2288	1.650129	21.74194
7/20/2023 9:55		18.18807	1.686836	17.42929
7/20/2023 9:56		18.08106	1.755985	11.96504
7/20/2023 9:57		17.95961	1.849182	8.316965
7/20/2023 9:58		17.84643	1.913416	5.088168
7/20/2023 9:59		17.76569	1.975858	3.253475
7/20/2023 10:00		17.65813	2.041023	2.455268
7/20/2023 10:01		17.54098	2.101693	1.993886
7/20/2023 10:02		17.54293	2.11485	1.878394
7/20/2023 10:03		17.50971	2.120063	1.765687
7/20/2023 10:04		17.47086	2.131735	1.639369
7/20/2023 10:05		17.41585	2.157977	1.523
7/20/2023 10:06		17.38881	2.172705	1.399906
7/20/2023 10:07		17.37759	2.178078	1.329295
7/20/2023 10:08		17.3428	2.203479	1.279444
7/20/2023 10:09		17.30895	2.216848	1.249648
7/20/2023 10:10		17.35387	2.179869	1.236609
7/20/2023 10:11		17.36081	2.181111	1.205763
7/20/2023 10:12		17.33264	2.183315	1.155044
7/20/2023 10:13		17.31464	2.187743	1.125251
7/20/2023 10:14		17.28984	2.191816	1.128304
7/20/2023 10:15		17.28107	2.187706	1.073104
7/20/2023 10:16		17.26605	2.196757	1.026142
7/20/2023 10:17		17.27396	2.184734	0.9974443
7/20/2023 10:18		17.24134	2.207257	0.982255
7/20/2023 10:19		17.23858	2.207075	0.9438899
7/20/2023 10:20		17.19227	2.234465	0.9085997
7/20/2023 10:21		17.1697	2.243187	0.9530452
7/20/2023 10:22		17.13648	2.261846	0.9127924
7/20/2023 10:23		17.15379	2.238682	0.8969506
7/20/2023 10:24		17.15702	2.229854	0.8888125
7/20/2023 10:25		17.14525	2.236757	0.8812557
7/20/2023 10:26		17.11835	2.263454	0.8667417
7/20/2023 10:27		17.08342	2.276539	0.8545706
7/20/2023 10:28		17.08154	2.277659	0.8394019
7/20/2023 10:29		17.07804	2.268023	0.8309244
7/20/2023 10:30		17.08356	2.26868	0.8203984
7/20/2023 10:31		17.04372	2.285419	0.8146969
7/20/2023 10:32		17.02377	2.30077	0.8053405
7/20/2023 10:33		5.347406	0.5157107	1.385092
7/20/2023 10:34		0.08512028	0.1787928	-0.1044113
7/20/2023 10:35		8.137331	2.849869	0.3268524
7/20/2023 10:36		11.71681	12.32684	-0.009240493
7/20/2023 10:37		12.05068	12.4341	-0.06406245
7/20/2023 10:38		12.05883	12.45948	-0.106458
7/20/2023 10:39		12.05869	12.4927	-0.1114372
7/20/2023 10:40		12.73954	10.0943	0.1626814
7/20/2023 10:41		10.27821	2.842557	4.711149
7/20/2023 10:42		0.1570468	0.3086113	8.303953
7/20/2023 10:43		0.06322803	0.2735252	8.309655
7/20/2023 10:44		0.04535607	0.2602949	8.309947
7/20/2023 10:45		6.203804	1.355273	4.208823
7/20/2023 10:46		16.66775	2.500358	0.9227336
7/20/2023 10:47		16.80967	2.522799	0.8826768
7/20/2023 10:48		16.79175	2.570779	0.8396934
7/20/2023 10:49		16.73997	2.617202	0.8246381
7/20/2023 10:50		16.70803	2.624475	0.8136736
7/20/2023 10:51		16.74786	2.601925	0.8144893
7/20/2023 10:52		16.76881	2.594323	0.817036
7/20/2023 10:53		16.73275	2.633849	0.7942073
7/20/2023 10:54		16.71519	2.661718	0.7771253
7/20/2023 10:55		16.7024	2.682769	0.7639679
7/20/2023 10:56		16.64927	2.728562	0.7588938
7/20/2023 10:57		16.66877	2.712831	0.7660146
7/20/2023 10:58		16.64189	2.73888	0.7751699
7/20/2023 10:59		16.6414	2.742635	0.7809263
7/20/2023 11:00		16.59754	2.76142	0.7532958
7/20/2023 11:01		16.59908	2.769278	0.7452553
7/20/2023 11:02		16.6134	2.751516	0.7462786
7/20/2023 11:03		16.59895	2.763512	0.7479947
7/20/2023 11:04		16.5791	2.785153	0.7612473
7/20/2023 11:05		16.54626	2.795922	0.7573892
7/20/2023 11:06		16.55517	2.79214	0.7586032
7/20/2023 11:07		16.56382	2.793568	0.7566245
7/20/2023 11:08		16.5172	2.820733	0.7414552
7/20/2023 11:09		16.48788	2.842858	0.7411645
7/20/2023 11:10		16.44669	2.879697	0.7414552
7/20/2023 11:11		16.42511	2.894011	0.7414552
7/20/2023 11:12		16.44901	2.881041	0.7416005
7/20/2023 11:13		16.46089	2.864111	0.7312827
7/20/2023 11:14		16.43263	2.89274	0.7027996
7/20/2023 11:15		16.39386	2.914974	0.6929177

Time	Comment	CAI 2-O2	CAI 2-CO2	Thermo 1HC 1-TLC
7/20/2023 11:16		16.3562	2.947316	0.6934904
7/20/2023 11:17		16.35283	2.946842	0.6966729
7/20/2023 11:18		16.35404	2.92798	0.7000385
7/20/2023 11:19		16.3596	2.934047	0.6968414
7/20/2023 11:20		16.34685	2.949924	0.6950976
7/20/2023 11:21		16.35843	2.92929	0.6959506
7/20/2023 11:22		16.35088	2.949996	0.6901566
7/20/2023 11:23		16.32876	2.964274	0.6968414
7/20/2023 11:24		16.32471	2.951945	0.6940882
7/20/2023 11:25		16.34829	2.951945	0.6907257
7/20/2023 11:26		16.34056	2.96907	0.6913192
7/20/2023 11:27		16.29518	2.99573	0.6930648
7/20/2023 11:28		16.3208	2.97659	0.6943709
7/20/2023 11:29		16.29944	2.990178	0.6887034
7/20/2023 11:30		16.29341	2.994392	0.6937897
7/20/2023 11:31		16.27351	3.008448	0.6758142
7/20/2023 11:32		7.715502	1.198957	1.241143
7/20/2023 11:33		0.09791209	0.2415457	-0.1789692
7/20/2023 11:34		3.062466	4.671419	-0.1481226
7/20/2023 11:35		11.89382	12.43169	-0.06523199
7/20/2023 11:36		7.717023	6.342497	4.504707
7/20/2023 11:37		0.1161861	0.3040062	8.239337
7/20/2023 11:38		8.419307	2.044458	2.999542
7/20/2023 11:39		16.05148	3.071421	0.7411619
7/20/2023 11:40		16.19001	3.046817	0.7019277
7/20/2023 11:41		16.21481	3.05099	0.700813
7/20/2023 11:42		16.22906	3.025809	0.697012
7/20/2023 11:43		16.19511	3.084139	0.6782994
7/20/2023 11:44		16.21002	3.061538	0.6698291
7/20/2023 11:45		16.22614	3.057715	0.6617797
7/20/2023 11:46		16.24029	3.045983	0.6524234
7/20/2023 11:47		16.22059	3.071311	0.6388276
7/20/2023 11:48		16.21397	3.076428	0.6329799
7/20/2023 11:49		16.26471	3.043438	0.6323186
7/20/2023 11:50		16.22643	3.072042	0.631518
7/20/2023 11:51		16.21072	3.094556	0.6351728
7/20/2023 11:52		16.22333	3.088633	0.6247619
7/20/2023 11:53		16.2339	3.074101	0.6183677
7/20/2023 11:54		16.17897	3.130377	0.6263604
7/20/2023 11:55		16.17467	3.139433	0.6145039
7/20/2023 11:57		16.18714	3.131104	0.6283949
7/20/2023 11:58		16.18689	3.132858	0.6321028
7/20/2023 11:59		16.15005	3.157143	0.6143297
7/20/2023 12:00		16.19342	3.124278	0.605662
7/20/2023 12:01		16.17307	3.140058	0.6040339
7/20/2023 12:02		16.1609	3.152886	0.6069577
7/20/2023 12:03		16.16694	3.137243	0.5951163
7/20/2023 12:04		16.18748	3.144083	0.5952633
7/20/2023 12:05		16.15392	3.148756	0.5980401
7/20/2023 12:06		16.17167	3.136045	0.5727367
7/20/2023 12:07		16.17068	3.135572	0.5869783
7/20/2023 12:08		16.14855	3.174413	0.5869295
7/20/2023 12:09		16.13927	3.162608	0.5809357
7/20/2023 12:10		16.13064	3.177615	0.5880567
7/20/2023 12:11		16.12957	3.157215	0.5808145
7/20/2023 12:12		16.13163	3.18768	0.58576
7/20/2023 12:13		16.09057	3.207615	0.5840718
7/20/2023 12:14		16.14095	3.162864	0.5981863
7/20/2023 12:15		16.072	3.229338	0.5916492
7/20/2023 12:16		16.10986	3.20953	0.6033523
7/20/2023 12:17		16.10467	3.194355	0.6093577
7/20/2023 12:18		16.15232	3.188922	0.6022797
7/20/2023 12:19		16.09084	3.226348	0.6079811
7/20/2023 12:20		16.08611	3.237357	0.6189349
7/20/2023 12:21		16.10419	3.207577	0.8877661
7/20/2023 12:22		16.06203	3.26027	0.8574945
7/20/2023 12:23		16.09562	3.240821	0.7789484
7/20/2023 12:24		16.10177	3.217869	0.7717161
7/20/2023 12:25		16.07306	3.25361	0.7045434
7/20/2023 12:26		16.09764	3.229966	0.7148474
7/20/2023 12:27		16.06018	3.269474	0.6895562
7/20/2023 12:28		16.06874	3.235517	0.693935
7/20/2023 12:29		16.07465	3.258656	0.6557859
7/20/2023 12:30		16.03021	3.273641	0.6651421
7/20/2023 12:31		16.07564	3.253137	0.6734751
7/20/2023 12:32		16.08887	3.224337	0.6655807
7/20/2023 12:33		16.09795	3.235819	0.6398263
7/20/2023 12:34		16.04373	3.261945	0.6392662
7/20/2023 12:35		16.08756	3.241148	0.627959
7/20/2023 12:36		16.02916	3.268852	0.6145298
7/20/2023 12:37		8.496313	1.426213	1.046415
7/20/2023 12:38		0.106976	0.2256108	-0.1615723
7/20/2023 12:39		0.05156922	0.2184839	-0.2204879
7/20/2023 12:40		7.727123	9.48203	-0.1387576
7/20/2023 12:41		12.02371	12.35147	-0.07795055
7/20/2023 12:42		13.81098	4.518685	2.267992
7/20/2023 12:43		0.6689746	0.3044448	8.218577
7/20/2023 12:44		0.05835108	0.2375959	8.231999

Time	Comment	CAI 2-O2	CAI 2-CO2	Thermo IHC 1-THC
7/20/2023 12:45		10.48273	2.592861	1.992279
7/20/2023 12:46		15.92725	3.222181	0.7073916
7/20/2023 12:47		16.02323	3.223314	0.6303485
7/20/2023 12:48		16.0589	3.201003	0.6009291
7/20/2023 12:49		16.02107	3.25131	0.5977477
7/20/2023 12:52		15.9634	3.261589	0.5782142
7/20/2023 12:53		16.00225	3.259059	0.5577686
7/20/2023 12:54		16.00451	3.265454	0.5661973
7/20/2023 12:55		15.99267	3.263005	0.553013
7/20/2023 12:56		15.98256	3.259568	0.5521648
7/20/2023 12:57		15.99446	3.238006	0.5253828
7/20/2023 12:58		16.01446	3.215383	0.5078397
7/20/2023 12:59		16.03	3.226701	0.5190798
7/20/2023 13:00		16.04742	3.186912	0.4971677
7/20/2023 13:01		16.03076	3.210669	0.499653
7/20/2023 13:02		15.99381	3.243708	0.4964367
7/20/2023 13:03		16.0291	3.209069	0.4994946
7/20/2023 13:04		16.02144	3.223204	0.5011149
7/20/2023 13:05		16.01383	3.23808	0.4973139
7/20/2023 13:06		16.02926	3.198279	0.4971677
7/20/2023 13:07		16.01069	3.235083	0.4990682
7/20/2023 13:08		15.99647	3.262494	0.492782
7/20/2023 13:09		16.01033	3.225763	0.5002378
7/20/2023 13:10		16.02085	3.221743	0.5170498
7/20/2023 13:11		16.01051	3.227225	0.4940977
7/20/2023 13:12		15.93858	3.279013	0.4954134
7/20/2023 13:13		15.99074	3.246413	0.4986296
7/20/2023 13:14		15.97312	3.231775	0.515916
7/20/2023 13:15		15.99125	3.226087	0.5013605
7/20/2023 13:16		15.94794	3.269534	0.4973156
7/20/2023 13:17		15.95528	3.258699	0.5049721
7/20/2023 13:18		15.96874	3.257303	0.4916473
7/20/2023 13:19		15.97268	3.243619	0.5001887
7/20/2023 13:20		15.93966	3.263395	0.4899481
7/20/2023 13:21		15.94059	3.283801	0.4525793
7/20/2023 13:22		15.94067	3.267793	0.4907353
7/20/2023 13:23		15.91863	3.278246	0.5138336
7/20/2023 13:24		15.98328	3.241259	0.463836
7/20/2023 13:25		15.95039	3.274847	0.4498016
7/20/2023 13:26		15.95207	3.264869	0.4556493
7/20/2023 13:27		15.95737	3.255038	0.4571112
7/20/2023 13:28		15.94629	3.286323	0.4648594
7/20/2023 13:29		15.99362	3.233767	0.4452696
7/20/2023 13:30		15.9994	3.226676	0.4451235
7/20/2023 13:31		15.97211	3.231396	0.5147956
7/20/2023 13:32		3.766783	0.4761839	0.622454
7/20/2023 13:33		0.2594908	0.2079581	-0.2276514
7/20/2023 13:34		9.905677	11.47549	-0.1400821
7/20/2023 13:35		12.04081	12.37029	-0.1375968
7/20/2023 13:36		8.982885	7.893844	3.44328
7/20/2023 13:37		0.1921518	0.2293541	8.217669
7/20/2023 13:38		0.05745345	0.1734568	8.236413
7/20/2023 13:40		0.03673074	0.1470326	8.233782
7/20/2023 13:41		0.1752842	0.2379275	7.646967
7/20/2023 13:42		13.66219	3.100951	0.8568007
7/20/2023 13:43		15.85348	3.246198	0.548468
7/20/2023 13:44		15.94067	3.211546	0.5325461
7/20/2023 13:45		15.91366	3.249775	0.5084245
7/20/2023 13:46		15.95766	3.207123	0.4919048
7/20/2023 13:47		15.97542	3.213702	0.478309
7/20/2023 13:48		15.93014	3.259972	0.4636898
7/20/2023 13:49		15.95609	3.225361	0.4604736
7/20/2023 13:50		15.98792	3.206612	0.4550645
7/20/2023 13:51		15.92974	3.251612	0.4679599
7/20/2023 13:52		15.99995	3.257962	0.4604736
7/20/2023 13:53		15.96256	3.215931	0.4479011
7/20/2023 13:54		15.93771	3.22474	0.4454158
7/20/2023 13:55		15.935	3.230989	0.4354748
7/20/2023 13:56		15.9458	3.238896	0.4397674
7/20/2023 13:57		15.95225	3.219257	0.4410301
7/20/2023 13:58		15.93917	3.245462	0.4169084
7/20/2023 13:59		15.92561	3.238116	0.4287499
7/20/2023 14:00		15.93474	3.240711	0.4161775
7/20/2023 14:01		15.9127	3.255136	0.4051809
7/20/2023 14:02		15.95126	3.229308	0.4283114
7/20/2023 14:03		15.92667	3.260008	0.4357672
7/20/2023 14:04		15.91187	3.247472	0.4338667
7/20/2023 14:05		15.88226	3.296666	0.4041898
7/20/2023 14:06		15.84771	3.296262	0.4790044
7/20/2023 14:07		15.89728	3.277734	0.4506788
7/20/2023 14:08		15.93482	3.239249	0.4587193
7/20/2023 14:09		15.95933	3.23957	0.4546621
7/20/2023 14:10		15.92612	3.254343	0.4457082
7/20/2023 14:11		15.90993	3.248898	0.4489245
7/20/2023 14:12		15.86048	3.295789	0.4423458
7/20/2023 14:13		15.89991	3.269182	0.4479011

Data 1-min			
Time	Comment	CAI 2-O2	CAI 2-CO2
			Inthermo IHC 1-T _{HC}
7/20/2023 14:14		15.95782	3.228542
7/20/2023 14:15		15.93452	3.243342
7/20/2023 14:16		15.9384	3.261982
7/20/2023 14:17		15.92703	3.268707
7/20/2023 14:18		15.93983	3.256503
7/20/2023 14:19		15.92888	3.258447
7/20/2023 14:20		15.94345	3.265896
7/20/2023 14:21		15.93555	3.261239
7/20/2023 14:22		15.92016	3.269328
7/20/2023 14:23		15.91256	3.288077
7/20/2023 14:24		15.89853	3.289539
7/20/2023 14:25		15.90097	3.285117
7/20/2023 14:26		15.88738	3.294912
7/20/2023 14:27		15.86095	3.305328
7/20/2023 14:28		15.87144	3.325722
7/20/2023 14:30		15.84582	3.320934
7/20/2023 14:31		15.87019	3.322819
7/20/2023 14:32		15.85383	3.344763
7/20/2023 14:33		15.89235	3.293157
7/20/2023 14:34		15.87946	3.323255
7/20/2023 14:35		15.8926	3.317739
7/20/2023 14:36		13.17468	2.36334
7/20/2023 14:37		0.3473918	0.1597087
7/20/2023 14:38		0.3191006	0.2424229
7/20/2023 14:40		9.65715	11.10602
7/20/2023 14:40		12.04428	12.29219
7/20/2023 14:41		2.803058	1.472712
7/20/2023 14:42		0.8461362	0.5360921
7/20/2023 14:43		14.48534	3.29384
7/20/2023 14:44		15.84709	3.32271
7/20/2023 14:45		15.87415	3.344069
7/20/2023 14:46		15.81098	3.374526
7/20/2023 14:47		15.87652	3.328316
7/20/2023 14:48		15.8598	3.347397
7/20/2023 14:49		15.80022	3.413791
7/20/2023 14:50		15.8315	3.373864
7/20/2023 14:51		15.81373	3.403298
7/20/2023 14:52		15.80029	3.395081
7/20/2023 14:53		15.84567	3.358968
7/20/2023 14:54		15.81586	3.39668
7/20/2023 14:55		15.86092	3.36936
7/20/2023 14:56		15.84929	3.370347
7/20/2023 14:57		15.86128	3.352913
7/20/2023 14:58		15.84826	3.362853
7/20/2023 14:59		15.76863	3.42696
7/20/2023 15:00		15.7682	3.4115
7/20/2023 15:01		15.79963	3.389863
7/20/2023 15:02		15.8236	3.399366
7/20/2023 15:03		15.7789	3.428385
7/20/2023 15:04		15.80697	3.420248
7/20/2023 15:05		15.80229	3.398854
7/20/2023 15:06		15.80858	3.401266
7/20/2023 15:07		15.75401	3.426923
7/20/2023 15:08		15.79462	3.392422
7/20/2023 15:09		15.7854	3.392787
7/20/2023 15:10		15.84754	3.361063
7/20/2023 15:11		15.80131	3.395309
7/20/2023 15:12		15.77362	3.411718
7/20/2023 15:13		15.82528	3.384454
7/20/2023 15:14		15.75588	3.421351
7/20/2023 15:15		15.76943	3.42674
7/20/2023 15:16		15.72708	3.447317
7/20/2023 15:17		15.74755	3.429225
7/20/2023 15:18		15.78577	3.398014
7/20/2023 15:19		15.78278	3.40949
7/20/2023 15:20		15.76089	3.413327
7/20/2023 15:21		15.75744	3.424219
7/20/2023 15:22		15.7167	3.450277
7/20/2023 15:23		15.71849	3.450277
7/20/2023 15:24		15.6748	3.395908
7/20/2023 15:25		15.73581	3.428714
7/20/2023 15:26		15.77214	3.410659
7/20/2023 15:27		15.75533	3.427873
7/20/2023 15:28		15.67673	3.416032
7/20/2023 15:29		15.65764	3.506013
7/20/2023 15:30		15.67928	3.468214
7/20/2023 15:31		15.71973	3.436886
7/20/2023 15:32		10.37703	1.90862
7/20/2023 15:33		0.1486407	0.11377129
7/20/2023 15:34		3.772594	4.942715
7/20/2023 15:35		11.92443	12.30443
7/20/2023 15:36		9.531258	8.1499
7/20/2023 15:37		0.2084387	0.2172999
7/20/2023 15:38		0.05087481	0.1574853
7/20/2023 15:39		0.03358761	0.1473615
7/20/2023 15:40		4.533852	1.528145
7/20/2023 15:41		15.36927	3.483317

Time	Comment	CAI 2-O2	CAI 2-CO2	Thermo 1HC 1-TLC
7/20/2023 15:42		15.65775	3.447207	0.4138384
7/20/2023 15:43		15.68995	3.457258	0.3882549
7/20/2023 15:44		15.67237	3.48954	0.4175332
7/20/2023 15:45		15.59865	3.547093	0.4031664
7/20/2023 15:46		15.62489	3.539712	0.3938459
7/20/2023 15:47		15.58907	3.556824	0.4166613
7/20/2023 15:48		15.67573	3.495487	0.4125227
7/20/2023 15:49		15.66805	3.514426	0.3973335
7/20/2023 15:50		15.62547	3.534517	0.3862891
7/20/2023 15:51		15.61141	3.563981	0.4061982
7/20/2023 15:52		15.62467	3.530244	0.3938102
7/20/2023 15:53		15.62326	3.541238	0.4125923
7/20/2023 15:54		15.62128	3.53036	0.4077494
7/20/2023 15:55		15.61624	3.549994	0.4057622
7/20/2023 15:56		15.63531	3.536932	0.4132536
7/20/2023 15:57		15.56459	3.58894	0.4044822
7/20/2023 15:58		15.57471	3.562078	0.3957106
7/20/2023 15:59		15.56184	3.599466	0.4003888
7/20/2023 16:00		15.60592	3.539125	0.4550645
7/20/2023 16:01		15.59478	3.565961	0.4517206
7/20/2023 16:02		15.5704	3.595443	0.4226195
7/20/2023 16:03		15.57544	3.586418	0.4063827
7/20/2023 16:04		15.59803	3.58693	0.4421996
7/20/2023 16:05		15.62233	3.544205	0.500384
7/20/2023 16:06		15.62957	3.552977	0.4479011
7/20/2023 16:07		15.59757	3.574117	0.4861251
7/20/2023 16:08		15.60534	3.548518	0.514126
7/20/2023 16:09		15.57508	3.594605	0.4303581
7/20/2023 16:10		15.54693	3.600855	0.4369367
7/20/2023 16:11		15.52789	3.634114	0.4408839
7/20/2023 16:12		15.58239	3.576331	0.4430768
7/20/2023 16:13		15.61897	3.554183	0.4601812
7/20/2023 16:14		15.60048	3.595592	0.5337157
7/20/2023 16:15		15.57741	3.617301	0.5119331
7/20/2023 16:16		15.59181	3.590695	0.4610583
7/20/2023 16:17		15.57727	3.609846	0.4677832
7/20/2023 16:18		15.57354	3.588428	0.4565264
7/20/2023 16:19		15.60807	3.552282	0.4416566
7/20/2023 16:20		15.58242	3.596981	0.480648
7/20/2023 16:21		15.56871	3.593132	0.5320221
7/20/2023 16:22		15.52559	3.622674	0.5173423
7/20/2023 16:23		15.52793	3.633894	0.4689527
7/20/2023 16:24		15.5087	3.648112	0.4566726
7/20/2023 16:25		15.49215	3.646832	0.4288962
7/20/2023 16:26		15.4573	3.656805	0.4346812
7/20/2023 16:27		15.54512	3.598406	0.4461468
7/20/2023 16:28		15.51605	3.633894	0.4581345
7/20/2023 16:29		15.54456	3.587844	0.4900043
7/20/2023 16:30		15.50951	3.632725	0.4671984
7/20/2023 16:31		15.45523	3.662183	0.4809404
7/20/2023 16:32		15.4498	3.656925	0.5426114
7/20/2023 16:33		15.43667	3.664631	0.473777
7/20/2023 16:34		15.30969	3.521147	1.045614
7/20/2023 16:35		1.826559	0.2411802	0.1824159
7/20/2023 16:36		0.04802886	0.1864115	-0.1591027
7/20/2023 16:37		8.554863	10.16265	-0.07692732
7/20/2023 16:38		11.98668	12.37164	-0.08102065
7/20/2023 16:39		12.00759	12.40991	-0.07663491
7/20/2023 16:40		6.821782	5.209976	5.123774
7/20/2023 16:41		0.06873721	0.2463568	8.308058
7/20/2023 16:42		0.02386584	0.2029876	8.330999
7/20/2023 16:43		0.01520397	0.1881491	8.328806
7/20/2023 16:44		2.530864	1.083681	5.930659
7/20/2023 16:45		14.80926	3.69476	0.6836538
7/20/2023 16:46		15.33024	3.689009	0.5362009
7/20/2023 16:47		15.41361	3.655348	0.520997
7/20/2023 16:48		15.3969	3.666925	0.5417563
7/20/2023 16:49		15.43162	3.674024	0.5231898
7/20/2023 16:50		15.35509	3.729577	0.4888348
7/20/2023 16:51		15.34943	3.704071	0.5133002
7/20/2023 16:52		15.35895	3.711228	0.5098124
7/20/2023 16:53		15.33178	3.711851	0.5075473
7/20/2023 16:54		15.34501	3.729395	0.4999603
7/20/2023 16:55		15.3525	3.729431	0.5031616
7/20/2023 16:56		15.35824	3.726324	0.4768471
7/20/2023 16:57		15.32933	3.742113	0.4780166
7/20/2023 16:58		15.37688	3.699863	0.4954134
7/20/2023 16:59		15.34793	3.719234	0.520266
7/20/2023 17:00		15.33982	3.744379	0.5031616
7/20/2023 17:01		15.34827	3.727977	0.47479
7/20/2023 17:02		15.34336	3.734474	0.4815252
7/20/2023 17:03		15.31354	3.760789	0.48518
7/20/2023 17:04		15.3167	3.758421	0.4396221
7/20/2023 17:05		15.32907	3.762909	0.4679294
7/20/2023 17:06		15.32359	3.754905	0.4800633
7/20/2023 17:07		15.25612	3.834433	0.453895
7/20/2023 17:08		15.26997	3.813089	0.4818176
7/20/2023 17:09		15.25232	3.809329	0.4962835

Time	Comment	CAI 2-O2	CAI 2-CO2	Thermo IHC 1-THC
7/20/2023 17:10		15.307	3.777966	0.4895657
7/20/2023 17:11		15.33018	3.765179	0.5066153
7/20/2023 17:12		15.36067	3.718943	0.5170208
7/20/2023 17:13		15.2779	3.795071	0.4740694
7/20/2023 17:14		15.232	3.80143	0.4777242
7/20/2023 17:15		15.22962	3.786775	0.447024
7/20/2023 17:16		15.215	3.799749	0.4689527
7/20/2023 17:17		15.25824	3.748655	0.466175
7/20/2023 17:18		15.24435	3.78915	0.4587193
7/20/2023 17:19		15.22834	3.803952	0.4806481
7/20/2023 17:20		15.20762	3.853584	0.4807943
7/20/2023 17:21		15.20897	3.850031	0.4984896
7/20/2023 17:22		15.16749	3.874897	0.4899034
7/20/2023 17:23		15.17132	3.85073	0.480988
7/20/2023 17:24		15.07957	3.941672	0.5108296
7/20/2023 17:25		15.08697	3.923678	0.5712906
7/20/2023 17:26		15.11491	3.858766	0.5441083
7/20/2023 17:27		15.11447	3.891249	0.5117261
7/20/2023 17:28		15.18357	3.829974	0.5841519
7/20/2023 17:29		15.12817	3.889745	0.5335695
7/20/2023 17:30		15.07652	3.902778	0.5442415
7/20/2023 17:31		15.10178	3.899489	0.5503815
7/20/2023 17:32		14.81027	3.707356	1.222865
7/20/2023 17:33		1.481583	0.2340899	0.165166
7/20/2023 17:34		0.0445048	0.1769656	-0.09051093
7/20/2023 17:35		4.703216	6.06229	-0.0545989
7/20/2023 17:36		11.96267	12.3295	-0.01523438
7/20/2023 17:37		12.01643	12.37457	-0.01348008
7/20/2023 17:38		4.877148	3.430761	6.475828
7/20/2023 17:39		3.247397	3.921491	5.526163
7/20/2023 17:40		14.58534	3.921491	0.6752924
7/20/2023 17:41		14.92942	3.914557	0.5455658
7/20/2023 17:42		14.90694	3.964544	0.4945363
7/20/2023 17:43		14.93628	3.923035	0.4938271
7/20/2023 17:44		15.01294	3.871264	0.5162066
7/20/2023 17:45		14.97991	3.916868	0.4900925
7/20/2023 17:46		15.01134	3.876688	0.493195
7/20/2023 17:47		14.96564	3.92986	0.4604736
7/20/2023 17:48		14.9228	3.944699	0.4474625
7/20/2023 17:49		14.94053	3.946526	0.4844491
7/20/2023 17:50		14.96535	3.912207	0.4939515
7/20/2023 17:51		14.93508	3.927996	0.4756775
7/20/2023 17:52		14.91243	3.931289	0.4802527
7/20/2023 17:53		14.96827	3.887574	0.4895657
7/20/2023 17:54		14.94543	3.921198	0.4900682
7/20/2023 17:55		14.97956	3.877889	0.5052083
7/20/2023 17:56		14.9993	3.871456	0.482841
7/20/2023 17:57		14.94243	3.903472	0.4894196
7/20/2023 17:58		14.95084	3.901389	0.5654393
7/20/2023 17:59		14.94236	3.893495	0.5087169
7/20/2023 18:00		14.96264	3.893129	0.5693865
7/20/2023 18:01		14.94641	3.897479	0.5604687
7/20/2023 18:02		14.91586	3.939143	0.5100326
7/20/2023 18:03		14.8591	4.013628	0.5098864
7/20/2023 18:04		14.89688	3.938974	0.5256981
7/20/2023 18:05		14.91769	3.926388	0.5256675
7/20/2023 18:06		14.87379	3.972841	0.5293299
7/20/2023 18:07		14.90391	3.934406	0.5189677
7/20/2023 18:08		14.86254	3.966225	0.5259675
7/20/2023 18:09		14.86346	3.985118	0.5127556
7/20/2023 18:10		14.89634	3.949048	0.5404406
7/20/2023 18:11		14.85487	3.989701	0.5422192
7/20/2023 18:12		14.8519	3.963484	0.524798
7/20/2023 18:13		14.89367	3.969039	0.5250903
7/20/2023 18:14		14.84693	3.976715	0.5272832
7/20/2023 18:15		14.87009	3.983924	0.5425098
7/20/2023 18:16		14.85033	3.954822	0.5022845
7/20/2023 18:17		14.8905	3.927777	0.4749466
7/20/2023 18:18		14.81466	3.979273	0.5221666
7/20/2023 18:19		14.82361	3.951825	0.547604
7/20/2023 18:20		14.83586	3.974193	0.5338619
7/20/2023 18:21		14.85007	3.965896	0.4813791
7/20/2023 18:22		14.81798	4.016515	0.5158802
7/20/2023 18:23		14.81027	4.000727	0.5066702
7/20/2023 18:24		14.81861	3.998936	0.4825486
7/20/2023 18:25		14.80848	3.983439	0.5204123
7/20/2023 18:26		14.85238	3.961474	0.5157341
7/20/2023 18:27		14.78435	4.016912	0.4931004
7/20/2023 18:28		14.72973	4.034461	0.5092259
7/20/2023 18:29		14.71856	4.026504	0.5220195
7/20/2023 18:30		14.66406	4.060198	0.5224624
7/20/2023 18:31		14.6173	4.105144	0.5218741
7/20/2023 18:32		14.68974	4.019659	0.5163189
7/20/2023 18:33		14.7037	4.027626	0.5131027
7/20/2023 18:34		14.80428	3.965714	0.5471654
7/20/2023 18:35		14.72588	4.053502	0.578158
7/20/2023 18:36		14.73096	4.038883	0.5829824
7/20/2023 18:37		14.63988	4.126379	0.5737723

Time	Comment	CAI 2-O2	CAI 2-CO2	Thermo IHC 1-THC
7/20/2023 18:38		14.59136	4.152752	0.5583498
7/20/2023 18:39		14.69226	4.047215	0.5397096
7/20/2023 18:40		14.67143	4.071447	0.5617845
7/20/2023 18:41		14.67197	4.070241	0.5707022
7/20/2023 18:42		14.73696	4.010083	0.5594454
7/20/2023 18:43		13.36118	3.356093	1.278127
7/20/2023 18:44		0.5572728	0.1557486	-0.05359934
7/20/2023 18:45		0.04765859	0.1342773	-0.08116685
7/20/2023 18:46		1.768082	2.944014	-0.08204393
7/20/2023 18:47		11.72044	12.24663	-0.01302828
7/20/2023 18:48		12.00415	12.32567	-0.01157956
7/20/2023 18:49		5.671619	4.543123	5.814924
7/20/2023 18:50		1.102361	0.7428015	6.873757
7/20/2023 18:51		13.73328	4.021924	0.8075334
7/20/2023 18:52		14.51499	4.153391	0.658842

Appendix C-3

VE Field Data

Client/Facility	MAIN OIL CARBON	Project #	4173
Source Identification	K1 STACK	Run #	1

Regulation/Test Method	M9
Observation Time	
Test Date:	7/20/23
Start Time:	9:45
End Time:	10:45
Observer Location	
Direction from Source:	NE
Distance from Source:	100'
Height of Observation Point:	130'
Meterological Data	
Wind Direction:	05
Wind Speed (mph):	3
Temperature (°F):	79
Sky Condition:	CLOUDY
Background:	CLOUDY SKY
Production Data	

Site Drawing

Certified Observer	
Name:	Wes Hopper
Signature:	Wes Hopper
Certification Date:	03-18-23

	0	15	30	45
0	0	0	0	0
1	5	5	5	5
2	5	10	10	10
3	10	15	15	20
4	20	20	25	25
5	30	30	30	30
Set Average:				
6	35	35	40	40
7	40	40	45	45
8	45	45	40	45
9	40	40	45	45
10	40	45	45	45
11	50	50	50	45
Set Average:				
12	45	50	50	50
13	45	45	45	45
14	45	50	50	45
15	45	40	40	40
16	35	35	35	35
17	30	30	30	25
Set Average:				
18	25	25	20	20
19	20	20	20	15
20	15	15	15	15
21	15	15	10	15
22	15	20	20	15
23	15	20	20	20
Set Average:				
24	15	15	15	20
25	20	20	20	20
26	15	15	15	15
27	10	10	15	10
28	15	10	10	5
29	5	10	5	5
Set Average:				

	0	15	30	45
30	5	5	5	5
31	5	5	5	5
32	5	5	5	5
33	5	5	5	5
34	5	5	5	5
35	0	0	0	0
Set Average:				
36	0	0	0	0
37	0	0	0	0
38	0	0	0	0
39	0	0	0	0
40	0	0	0	0
41	0	0	0	0
Set Average:				
42	0	0	0	0
43	0	0	0	0
44	0	0	0	0
45	5	0	5	0
46	5	0	5	0
47	5	0	5	0
Set Average:				
48	5	0	5	0
49	5	0	5	0
50	5	0	5	0
51	5	0	5	0
52	5	0	5	0
53	5	0	5	0
Set Average:				
54	5	0	5	0
55	5	0	5	0
56	5	0	5	0
57	5	0	5	0
58	5	0	5	0
59	5	0	5	0
Set Average:				

Summary of Results	
Minimum:	0
Maximum:	50
Average:	13.9

Comments

2K 8/1/20

Client/Facility	RAIN CARBON	Project #	4173
Source Identification	K1 STACK	Run #	2

Regulation/Test Method	M9
Observation Time	
Test Date:	7/20/23
Start Time:	12:11
End Time:	13:11
Observer Location	
Direction from Source:	NE
Distance from Source:	100'
Height of Observation Point:	100' 130'
Meteorological Data	
Wind Direction:	SW
Wind Speed (mph):	7
Temperature (°F):	82
Sky Condition:	MOSTLY CLOUDY
Background:	CLOUDY SKY
Production Data	

Site Drawing

	0	15	30	45
0	0	0	0	0
1	0	0	0	0
2	0	0	0	0
3	0	0	0	0
4	0	0	0	0
5	0	0	0	0
Set Average:				
6	0	0	0	0
7	0	0	0	0
8	5	5	5	5
9	5	5	5	5
10	5	5	5	5
11	5	5	5	5
Set Average:				
12	5	5	5	5
13	5	5	5	5
14	0	5	0	5
15	0	5	0	5
16	5	5	5	5
17	0	5	0	5
Set Average:				
18	0	5	0	5
19	0	5	0	5
20	0	5	0	5
21	0	5	0	5
22	0	5	0	5
23	0	5	0	5
Set Average:				
24	5	5	5	5
25	5	5	5	5
26	5	5	5	5
27	5	5	5	5
28	5	5	5	5
29	5	5	5	5
Set Average:				

	0	15	30	45
30	0	0	0	0
31	0	5	0	5
32	0	5	0	5
33	0	5	0	5
34	0	5	0	5
35	0	5	0	5
Set Average:				
36	0	5	0	5
37	0	5	0	5
38	0	5	0	5
39	0	5	0	5
40	0	5	0	5
41	0	5	0	5
Set Average:				
42	0	5	0	5
43	0	5	0	5
44	0	5	0	5
45	5	5	5	5
46	0	5	0	5
47	5	5	5	5
Set Average:				
48	0	5	0	5
49	0	5	0	5
50	0	5	0	5
51	0	5	0	5
52	0	5	0	5
53	0	5	0	5
Set Average:				
54	0	5	0	5
55	0	5	0	5
56	0	5	0	5
57	0	5	0	5
58	0	5	0	5
59	0	5	0	5
Set Average:				

Certified Observer
Name: LEX HOOPER
Signature: Lex Hooper
Certification Date: 03-14-23

Summary of Results
Minimum: 0
Maximum: 5
Average: 2.71

Comments

248/1/23

Client/Facility	RAIN CARBON	Project #	4173
Source Identification	K1 STACK	Run #	3

Regulation/Test Method	M9
Observation Time	
Test Date:	7/20/23
Start Time:	13:44
End Time:	14:37
Observer Location	
Direction from Source:	NE
Distance from Source:	100'
Height of Observation Point:	130'
Meteorological Data	
Wind Direction:	W
Wind Speed (mph):	10
Temperature (°F):	80
Sky Condition:	PARTLY CLOUDY
Background:	BLUE/CLOUDY SKY
Production Data	

Site Drawing
<p>X = OBSERVER</p>

	0	15	30	45
0	0	5	0	5
1	0	5	0	5
2	0	5	0	5
3	0	5	0	5
4	0	5	0	5
5	0	5	0	5
Set Average:				
6	0	5	0	5
7	0	5	0	5
8	0	5	0	5
9	0	5	0	5
10	0	5	0	5
11	0	5	0	5
Set Average:				
12	0	5	0	5
13	0	0	0	0
14	0	0	0	0
15	0	0	0	0
16	0	0	0	0
17	0	0	0	0
Set Average:				
18	0	0	0	0
19	0	0	0	0
20	0	0	0	0
21	0	0	0	0
22	0	0	0	0
23	0	0	0	0
Set Average:				
24	0	0	0	0
25	0	0	0	0
26	0	0	0	0
27	0	0	0	0
28	0	0	0	0
29	0	0	0	0
Set Average:				

	0	15	30	45
30	0	0	0	0
31	0	0	0	0
32	0	0	0	0
33	0	0	0	0
34	0	0	0	0
35	0	0	0	0
Set Average:				
36	0	0	0	0
37	0	0	0	0
38	0	0	0	0
39	0	0	0	0
40	0	0	0	0
41	0	0	0	0
Set Average:				
42	0	0	0	0
43	0	0	0	0
44	0	0	0	0
45	0	0	0	0
46	0	0	0	0
47	0	0	0	0
Set Average:				
48	0	0	0	0
49	0	0	0	0
50	0	0	0	0
51	0	0	0	0
52	0	0	0	0
53	0	0	0	0
Set Average:				
54				
55				
56				
57				
58				
59				
Set Average:				

Certified Observer
Name: LEX HOOPER
Signature:
Certification Date: 3-14-23

Summary of Results
Minimum: 0
Maximum: 5
Average: 0.6

Comments

AL 8/1/23

Client/Facility	RAW CARBON	Project #	4173
Source Identification	K1 STACK	Run #	4

Regulation/Test Method	M9
Observation Time	
Test Date:	7/20/23
Start Time:	16:15
End Time:	17:15
Observer Location	
Direction from Source:	NE
Distance from Source:	100'
Height of Observation Point:	130'
Meteorological Data	
Wind Direction:	W
Wind Speed (mph):	11
Temperature (°F):	85
Sky Condition:	PART CLOUDY
Background:	BLUE/PART CLOUDY SKY
Production Data	

Site Drawing

Certified Observer
Name: LEX HOOPER
Signature: Lex Hooper
Certification Date: 03-14-23

	0	15	30	45		0	15	30	45
0	0	0	0	0	30	0	0	0	0
1	0	0	0	0	31	0	0	0	0
2	0	0	0	0	32	0	0	0	0
3	0	0	0	0	33	0	0	0	0
4	0	0	0	0	34	0	0	0	0
5	0	0	0	0	35	0	0	0	0
Set Average:					Set Average:				
6	0	0	0	0	36	0	0	0	0
7	0	0	0	0	37	0	0	0	0
8	0	0	0	0	38	0	0	0	0
9	0	0	0	0	39	0	0	0	0
10	0	0	0	0	40	0	0	0	0
11	0	0	0	0	41	0	0	0	0
Set Average:					Set Average:				
12	0	0	0	0	42	0	0	0	0
13	0	0	0	0	43	0	0	0	0
14	0	0	0	0	44	0	0	0	0
15	0	0	0	0	45	0	0	0	0
16	0	0	0	0	46	0	0	0	0
17	0	0	0	0	47	0	0	0	0
Set Average:					Set Average:				
18	0	0	0	0	48	0	0	0	0
19	0	0	0	0	49	0	0	0	0
20	0	0	0	0	50	0	0	0	0
21	0	0	0	0	51	0	0	0	0
22	0	0	0	0	52	0	0	0	0
23	0	0	0	0	53	0	0	0	0
Set Average:					Set Average:				
24	0	0	0	0	54	0	0	0	0
25	0	0	0	0	55	0	0	0	0
26	0	0	0	0	56	0	0	0	0
27	0	0	0	0	57	0	0	0	0
28	0	0	0	0	58	0	0	0	0
29	0	0	0	0	59	0	0	0	0
Set Average:					Set Average:				

Summary of Results
Minimum: 0
Maximum: 0
Average: 0

Comments

LEX/7/23

Client/Facility	RAIN CARBON	Project #	4173
Source Identification	L1 STACK	Run #	5

Regulation/Test Method
Observation Time
Test Date: 7/20/23
Start Time: 17:47
End Time: 18:47
Observer Location
Direction from Source: NE
Distance from Source: 100'
Height of Observation Point: 10'
Meteorological Data
Wind Direction: W
Wind Speed (mph): 11
Temperature (°F): 86
Sky Condition: PART CLOUDY
Background: BLUE/PART CLOUDY SKY
Production Data

Site Drawing

	0	15	30	45
0	0	0	0	0
1	0	0	0	0
2	0	0	0	0
3	0	0	0	0
4	0	0	0	0
5	0	0	0	0
Set Average:				
6	0	0	0	0
7	0	0	0	0
8	0	0	0	0
9	0	0	0	0
10	0	0	0	0
11	0	0	0	0
Set Average:				
12	0	0	0	0
13	0	0	0	0
14	0	0	0	0
15	0	0	0	0
16	0	0	0	0
17	0	0	0	0
Set Average:				
18	0	0	0	0
19	0	0	0	0
20	0	0	0	0
21	0	0	0	0
22	0	0	0	0
23	0	0	0	0
Set Average:				
24	0	0	0	0
25	0	0	0	0
26	0	0	0	0
27	0	0	0	0
28	0	0	0	0
29	0	0	0	0
Set Average:				

	0	15	30	45
30	0	0	0	0
31	0	0	0	0
32	0	0	0	0
33	0	0	0	0
34	0	0	0	0
35	0	0	0	0
Set Average:				
36	0	0	0	0
37	0	0	0	0
38	0	0	0	0
39	0	0	0	0
40	0	0	0	0
41	0	0	0	0
Set Average:				
42	0	0	0	0
43	0	0	0	0
44	0	0	0	0
45	0	0	0	0
46	0	0	0	0
47	0	0	0	0
Set Average:				
48	0	0	0	0
49	0	0	0	0
50	0	0	0	0
51	0	0	0	0
52	0	0	0	0
53	0	0	0	0
Set Average:				
54	0	0	0	0
55	0	0	0	0
56	0	0	0	0
57	0	0	0	0
58	0	0	0	0
59	0	0	0	0
Set Average:				

Certified Observer
Name: LEX HOOPER
Signature: Lex Hooper
Certification Date: 03-14-23

Summary of Results
Minimum: 0
Maximum: 0
Average: 0

Comments

2 8/1/23

Visible Emission Training

This certifies that

Lex Hooper

has successfully completed the Visible Emission Training held March 14th and 15th, 2023 by the Kansas City, Missouri Health Department, Air Quality Program and is now certified as a visible emission observer.

Expiration: October 2023



A handwritten signature in black ink, reading 'Naser Jouhari'.

Naser Jouhari, MIS
Deputy Director
Environmental Health Division

APPENDIX D

LABORATORY ANALYSIS



Sample Evaporations

Project Number	4173	Project Name	Rain Carbon M5.202 '23
-----------------------	-------------	---------------------	-------------------------------

Reagent Information		Analyst	A. VanSickle	L. Hooper
DIUF H2O	LabChem LC267505	Date	07/24/23	07/31/23
Hexane	Fisher 214233	Time	11:20	11:50
Acetone	Fisher 222473	Cal. Wt.	1000.1	1000.1

Run No.	Sample No.	Container No.	Leakage	Full Weight	Empty Weight	Comments
000	010	C22-8-29	None	300.5	166.9	
000	012	C22-8-30	None	344.6	165.8	
000	013	C22-8-31	None	261.0	164.4	
PB	012	C22-8-32	None	739.1	505.5	
PB	013	C22-8-33	None	524.5	293.5	
FTRB	012	C22-8-34	None	763.5	504.1	
FTRB	013	C22-8-35	None	557.0	297.0	
111	010	C22-8-36	None	294.6	165.5	
111	012	C22-10-21	None	926.0	503.9	
111	013	C22-8-37	None	571.4	294.8	
112	010	C22-8-38	None	303.1	167.1	
112	012	C22-10-22	None	932.6	505.7	
112	013	C22-8-39	None	579.4	298.2	
113	010	C22-8-40	None	296.5	167.5	
113	012	C22-10-23	None	916.1	506.0	
113	013	C22-8-73	None	575.7	297.5	
114	010	C22-8-74	None	291.5	165.7	
114	012	C22-10-24	None	857.8	501.5	
114	013	C22-8-75	None	560.9	295.2	
115	010	C22-8-76	None	306.4	165.7	
115	012	C22-8-77	None	876.0	502.3	
115	013	C22-8-78	None	557.3	296.5	

Comments:

Completed By:
Date:



Container Final Weights

Project Number	4173	Project Name	Rain Carbon M5.202 '23
-----------------------	-------------	---------------------	-------------------------------

Container LogIn	Analyst	Date Into Dryer:	08/01/23
	L. Hooper	Time Into Dryer:	10:00

Analyst	L. Hooper	L. Hooper	L. Hooper	L. Hooper
Date	08/02/23	08/02/23	08/03/23	08/04/23
Time (24 hr)	10:00	16:00	13:00	11:30
Room Temp, °F	78	77	77	78
Relative Humidity	51 %	51 %	50 %	51 %
Cal Weight (g)	30	30	30	30

Initial Cal Check	29.9990	29.9991	29.9990	29.9990
--------------------------	---------	---------	---------	---------

Decimals: 4

Run No.	Sample No.	Container No.	Weight (g)	Weight (g)	Weight (g)	Weight (g)	Average (g)	P/F
000	010	C22-8-29	28.8717	28.8716	28.8717	28.8718	28.8718	P
000	012	C22-8-30	29.9428	29.9425	29.9425	29.9426	29.9426	P
000	013	C22-8-31	30.5885	30.5884	30.5884	30.5886	30.5885	P
PB	012	C22-8-32	28.2044	28.2040	28.2041	28.2044	28.2043	P
PB	013	C22-8-33	28.7388	28.7386	28.7386	28.7388	28.7387	P
FTRB	012	C22-8-34	29.5332	29.5328	29.5329	29.5331	29.5330	P
FTRB	013	C22-8-35	29.9575	29.9574	29.9574	29.9575	29.9575	P
111	010	C22-8-36	30.0937	30.0935	30.0938	30.0939	30.0939	P
111	012	C22-10-21	1.6258	1.6260	1.6261	1.6263	1.6262	P
111	013	C22-8-37	28.6514	28.6513	28.6513	28.6513	28.6513	P
112	010	C22-8-38	29.0715	29.0710	29.0721	29.0722	29.0722	P
112	012	C22-10-22	1.6476	1.6476	1.6477	1.6477	1.6477	P
112	013	C22-8-39	30.8895	30.8892	30.8893	30.8894	30.8894	P
113	010	C22-8-40	30.3450	30.3445	30.3456	30.3453	30.3455	P
113	012	C22-10-23	1.6512	1.6511	1.6511	1.6510	1.6511	P
113	013	C22-8-73	29.4593	29.4591	29.4592	29.4593	29.4593	P
114	010	C22-8-74	29.7389	29.7383	29.7378	29.7373	29.7376	P
114	012	C22-10-24	1.6891	1.6891	1.6890	1.6889	1.6890	P
114	013	C22-8-75	28.5432	28.5430	28.5430	28.5432	28.5431	P
115	010	C22-8-76	31.4437	31.4409	31.4404	31.4404	31.4404	P
115	012	C22-8-77	31.3864	31.3770	31.3670	31.3675	31.3673	P
115	013	C22-8-78	28.9150	28.9148	28.9150	28.9149	28.9150	P

Final Cal Check	29.9990	29.9991	29.9990	29.9991
------------------------	---------	---------	---------	---------

Comments:

Drying Method: <input checked="" type="checkbox"/> Desiccator <input type="checkbox"/> Oven <input type="checkbox"/> Other:

Completed By:	Date:
----------------------	--------------



Container Tare Weights

Container LogIn	Date Into Dryer:	08/25/22
	Time Into Dryer:	12:15

Analyst	L. Hooper	L. Hooper		
Date	08/26/22	08/30/22		
Time (24 hr)	12:40	12:10		
Room Temp, °F	77	75		
Relative Humidity	50 %	49 %		
Cal Weight (g)	30	30		

Initial Cal Check	29.9990	29.9990		
--------------------------	---------	---------	--	--

Decimals: 4

Container No.	Type	Weight (g)	Weight (g)	Weight (g)	Weight (g)	Average (g)	P/F
C22-8-25	50mL	29.5212	29.5212			29.5212	P
C22-8-26	50mL	29.9222	29.9222			29.9222	P
C22-8-27	50mL	29.0748	29.0749			29.0749	P
C22-8-28	50mL	29.4385	29.4384			29.4385	P
C22-8-29	50mL	28.8716	28.8716			28.8716	P
C22-8-30	50mL	29.9420	29.9420			29.9420	P
C22-8-31	50mL	30.5883	30.5884			30.5884	P
C22-8-32	50mL	28.2023	28.2024			28.2024	P
C22-8-33	50mL	28.7370	28.7371			28.7371	P
C22-8-34	50mL	29.5305	29.5305			29.5305	P
C22-8-35	50mL	29.9567	29.9567			29.9567	P
C22-8-36	50mL	30.0453	30.0452			30.0453	P
C22-8-37	50mL	28.6473	28.6472			28.6473	P
C22-8-38	50mL	29.0257	29.0255			29.0256	P
C22-8-39	50mL	30.8864	30.8863			30.8864	P
C22-8-40	50mL	30.2974	30.2973			30.2974	P
C22-8-41	50mL	28.9688	28.9689			28.9689	P
C22-8-42	50mL	29.3532	29.3535			29.3534	P
C22-8-43	50mL	29.0382	29.0384			29.0383	P
C22-8-44	50mL	28.4812	28.4811			28.4812	P
C22-8-45	50mL	29.4936	29.4935			29.4936	P
C22-8-46	50mL	28.5523	28.5523			28.5523	P
C22-8-47	50mL	28.6655	28.6655			28.6655	P
C22-8-48	50mL	29.8683	29.8683			29.8683	P

Final Cal Check	29.9990	29.9990		
------------------------	---------	---------	--	--

Comments:

Drying Method: ☒ Desiccator ☐ Oven ☐ Other:

Completed By:

Date:



Container Tare Weights

Container LogIn	Date Into Dryer:	08/25/22
	Time Into Dryer:	12:15

Analyst	L. Hooper	L. Hooper		
Date	08/26/22	08/30/22		
Time (24 hr)	13:00	12:20		
Room Temp, °F	77	75		
Relative Humidity	52 %	49 %		
Cal Weight (g)	30	30		

Initial Cal Check	29.9990	29.9990		
--------------------------	---------	---------	--	--

Decimals: 4

Container No.	Type	Weight (g)	Weight (g)		Weight (g)	Average (g)	P/F
C22-8-73	50mL	29.4556	29.4557			29.4557	P
C22-8-74	50mL	29.6650	29.6652			29.6651	P
C22-8-75	50mL	28.5396	28.5397			28.5397	P
C22-8-76	50mL	31.3313	31.3314			31.3314	P
C22-8-77	50mL	31.2496	31.2497			31.2497	P
C22-8-78	50mL	28.9085	28.9085			28.9085	P
C22-8-79	50mL	28.7896	28.7896			28.7896	P
C22-8-80	50mL	29.3156	29.3155			29.3156	P
C22-8-81	50mL	30.8033	30.8034			30.8034	P
C22-8-82	50mL	29.4781	29.4779			29.4780	P
C22-8-83	50mL	29.9455	29.9452			29.9454	P
C22-8-84	50mL	28.5254	28.5254			28.5254	P
C22-8-85	50mL	29.1104	29.1102			29.1103	P
C22-8-86	50mL	29.7081	29.7078			29.7080	P
C22-8-87	50mL	29.8353	29.8350			29.8352	P
C22-8-88	50mL	30.2636	30.2634			30.2635	P
C22-8-89	50mL	29.3369	29.3370			29.3370	P
C22-8-90	50mL	28.7700	28.7699			28.7700	P
C22-8-91	50mL	30.5821	30.5821			30.5821	P
C22-8-92	50mL	30.0616	30.0615			30.0616	P
C22-8-93	50mL	28.8915	28.8916			28.8916	P
C22-8-94	50mL	30.3928	30.3925			30.3927	P
C22-8-95	50mL	28.9429	28.9426			28.9428	P
C22-8-96	50mL	30.0988	30.0987			30.0988	P

Final Cal Check	29.9990	29.9990		
------------------------	---------	---------	--	--

Comments:

Drying Method: ☒ Desiccator ☐ Oven ☐ Other:

Completed By:

Date:



Container Tare Weights

Container LogIn	Date Into Dryer:	09/16/22
	Time Into Dryer:	16:00

Analyst	A. VanSickle	L. Hooper		
Date	09/17/22	09/19/22		
Time (24 hr)	16:30	10:00		
Room Temp, °F	78	78		
Relative Humidity	58 %	53 %		
Cal Weight (g)	30	30		

Initial Cal Check	29.9990	29.9990		
--------------------------	---------	---------	--	--

Decimals: 4

Container No.	Type	Weight (g)	Weight (g)	Weight (g)	Weight (g)	Average (g)	P/F
C22-10-1	pan	1.5868	1.5869			1.5869	P
C22-10-2	pan	1.5795	1.5797			1.5796	P
C22-10-3	pan	1.5829	1.5830			1.5830	P
C22-10-4	pan	1.5836	1.5836			1.5836	P
C22-10-5	pan	1.5896	1.5897			1.5897	P
C22-10-6	pan	1.5953	1.5956			1.5955	P
C22-10-7	pan	1.5896	1.5897			1.5897	P
C22-10-8	pan	1.5845	1.5845			1.5845	P
C22-10-9	pan	1.5797	1.5798			1.5798	P
C22-10-10	pan	1.5844	1.5844			1.5844	P
C22-10-11	pan	1.5880	1.5880			1.5880	P
C22-10-12	pan	1.5930	1.5931			1.5931	P
C22-10-13	pan	1.5892	1.5893			1.5893	P
C22-10-14	pan	1.5960	1.5960			1.5960	P
C22-10-15	pan	1.5974	1.5976			1.5975	P
C22-10-16	pan	1.5977	1.5980			1.5979	P
C22-10-17	pan	1.5908	1.5910			1.5909	P
C22-10-18	pan	1.6029	1.6030			1.6030	P
C22-10-19	pan	1.5963	1.5965			1.5964	P
C22-10-20	pan	1.6011	1.6013			1.6012	P
C22-10-21	pan	1.5954	1.5956			1.5955	P
C22-10-22	pan	1.5902	1.5905			1.5904	P
C22-10-23	pan	1.6015	1.6018			1.6017	P
C22-10-24	pan	1.6010	1.6012			1.6011	P

Final Cal Check	29.9990	29.9990		
------------------------	---------	---------	--	--

Comments:

Drying Method: ☒ Desiccator ☐ Oven ☐ Other:

Completed By:

Date:



Filter Final Weights

Project Number	4173	Project Name	Rain Carbon M5.202 '23
-----------------------	-------------	---------------------	-------------------------------

Filter LogIn	Analyst	Date Into Dryer:	07/22/23
	A. VanSickle	Time Into Dryer:	17:00

Analyst	A. VanSickle	A. VanSickle	L. Hooper	
Date	07/27/23	07/28/23	08/02/23	
Time (24 hr)	12:10	13:25	16:30	
Room Temp, °F	74	76	77	
Relative Humidity	54 %	54 %	51 %	
Cal Weight (g)	30	30	30	

Initial Cal Check	29.9991	29.9991	29.9991	
--------------------------	---------	---------	---------	--

Decimals: 4

[illegible]

Final Cal Check	29.9991	29.9991	29.9991	
------------------------	---------	---------	---------	--

Comments:

Drying Method: ☒ Desiccator ☐ Oven ☐ Other:

Completed By:

Date:

Filter LogIn	Date Into Dryer:	09/16/22
	Time Into Dryer:	14:40

Analyst	A. VanSickle	L. Hooper		
Date	09/17/22	09/19/22		
Time (24 hr)	16:20	10:15		
Room Temp, °F	78	78		
Relative Humidity	58 %	53 %		
Cal Weight (g)	30	30		

Initial Cal Check	29.9989	29.9990		
--------------------------	---------	---------	--	--

[illegible]

Final Cal Check	29.9990	29.9990		
------------------------	---------	---------	--	--

Drying Method:	<input checked="" type="checkbox"/> Desiccator	<input type="checkbox"/> Oven	<input type="checkbox"/> Other:	

Date:



Filter Tare Weights

Filter LogIn	Date Into Dryer:	10/05/22
	Time Into Dryer:	14:45

Analyst	A. VanSickle	A. VanSickle	A. VanSickle	
Date	10/06/22	10/10/22	10/11/22	
Time (24 hr)	14:55	12:00	12:30	
Room Temp, °F	70	64	70	
Relative Humidity	54 %	54 %	58 %	
Cal Weight (g)	30	30	30	

Initial Cal Check	29.9991	29.9991	29.9990	
--------------------------	---------	---------	---------	--

Decimals: 4

Filter No.	Type	Weight (g)	Weight (g)	Weight (g)	Weight (g)	Average (g)	P/F
F22-10-1	82.6mm glass	31.8870	31.8868	31.8868		31.8868	P
F22-10-2	82.6mm glass	32.4212	32.4201	32.4202		32.4202	P
F22-10-3	82.6mm glass	43.7019	43.7014	43.7016		43.7015	P
F22-10-4	82.6mm glass	42.3161	42.3161	42.3160		42.3161	P
F22-10-5	82.6mm glass	41.3842	41.3842	41.3837		41.3840	P
F22-10-6	82.6mm glass	36.9454	36.9454	36.9455		36.9455	P
F22-10-7	82.6mm glass	33.8759	33.8758	33.8762		33.8760	P
F22-10-8	82.6mm glass	30.4432	30.4430	30.4434		30.4432	P
F22-10-9	82.6mm glass	31.1834	31.1830	31.1825		31.1828	P
F22-10-10	82.6mm glass	36.2564	36.2565	36.2560		36.2563	P
F22-10-11	82.6mm glass	32.6084	32.6084	32.6084		32.6084	P
F22-10-12	82.6mm glass	32.5784	32.5782	32.5782		32.5782	P
F22-10-13	82.6mm glass	30.1311	30.1307	30.1311		30.1309	P
F22-10-14	82.6mm glass	30.8198	30.8198	30.8198		30.8198	P
F22-10-15	82.6mm glass	33.7245	33.7244	33.7245		33.7245	P
F22-10-16	82.6mm glass	37.0475	37.0466	37.0468		37.0467	P
F22-10-17	82.6mm glass	35.0316	35.0315	35.0315		35.0315	P
F22-10-18	82.6mm glass	31.7286	31.7277	31.7273		31.7275	P
F22-10-19	82.6mm glass	44.8298	44.8291	44.8295		44.8293	P
F22-10-20	82.6mm glass	34.8711	34.8711	34.8711		34.8711	P
F22-10-21	82.6mm glass	32.0230	32.0233	32.0232		32.0233	P
F22-10-22	82.6mm glass	34.7828	34.7827	34.7822		34.7825	P
F22-10-23	82.6mm glass	33.1028	33.1029	33.1026		33.1028	P
F22-10-24	82.6mm glass	37.0462	37.0458	37.0461		37.0460	P

Final Cal Check	29.9991	29.9992	29.9990	
------------------------	---------	---------	---------	--

Comments:

Drying Method:	<input checked="" type="checkbox"/> Desiccator	<input type="checkbox"/> Oven	<input type="checkbox"/> Other:

Completed By:	Date:
----------------------	--------------



Filter Tare Weights

Filter LogIn	Date Into Dryer:	07/17/23
	Time Into Dryer:	15:00

Analyst	L. Hooper	A. VanSickle		
Date	07/18/23	07/19/23		
Time (24 hr)	15:00	9:45		
Room Temp, °F	75	78		
Relative Humidity	54 %	60 %		
Cal Weight (g)	30	30		

Initial Cal Check	29.9990	29.9990		
--------------------------	---------	---------	--	--

Decimals: 4

[illegible]

Final Cal Check	29.9990	29.9991		
------------------------	---------	---------	--	--

Comments:

Drying Method:	<input checked="" type="checkbox"/> Desiccator	<input type="checkbox"/> Oven	<input type="checkbox"/> Other:

Completed By: _____ **Date:** _____

APPENDIX E

EQUIPMENT CALIBRATIONS

Equipment Calibration Request

Project **Rain LLC**

Project No. **4173**

Test Dates **7/20/2023**

Project Manager **T. Pittman**

Nozzle

ID	Diameter	ID	Diameter
Q213	0.440		
Q242	0.365		
Q234	0.376		
Q264	0.388		
Q261	0.396		

Probe and Pitot Assemblies

Probe ID	Pitot ID	T/C ID
5-5	S-2	68-3

Sample Train Thermocouples

FPF	TRAP/CPF	SG
FPF-6	CPF-4	20
FPF-5	CPF-9	21
FPF-9	CPF-7	22
FPF-8	CPF-3	26
FPF-1	CPF-6	29

Umbilicals

U200-1

Method 5 Consoles

Console No.	Avg. ΔH
1	1.763

Barometers

B24

Method 6/VOST Consoles

Console No.	Flow Rate

Include

Balance Calibration
Comments

Special/Other Equipment

Equipment Problems/Changes/Notes (Copied from all Field Data Sheets)

Mettler Toledo, LLC

1900 Polaris Parkway
Columbus, OH 43240
1.800.METTLER

Comprehensive Test Report

Customer

Company:	Air Source Technology	Contact:	Alexander VanSickle
Address:	20505 W 67th St	Order Number:	0332632316
City:	Shawnee		
Zip / Postal:	66218-9620		
State / Province:	Kansas		

Weighing Device

Manufacturer:	Mettler Toledo	Instrument Type:	Weighing Instrument
Model:	XPE205	Asset Number:	N/A
Serial No.:	B427775532	Terminal Model:	PEAT
Building:	Main	Terminal Serial No.:	B427775532
Floor:	1	Terminal Asset No.:	NA
Room:	N/A	Alternate Asset No.:	N/A

Range	Max. Capacity	Readability (d)
1	220 g	0.00001 g

Procedure

Guideline:	EURAMET cg-18 v. 4.0 (11/2015)
METTLER TOLEDO Work Instruction:	30260953 v1.61

This report contains measurements for As Found and As Left testing.

The sensitivity/span of the weighing instrument was adjusted before As Left testing with a built-in weight.

In accordance with EURAMET cg-18 (11/2015), the test loads were selected to reflect the specific use of the weighing device or to accommodate specific test conditions.

As Found Testing Date:	18-Apr-2023	Service Technician:	
As Left Testing Date:	18-Apr-2023		
Issue Date:	18-Apr-2023		Alex Rickert
Next Testing Date:	30-Apr-2024		


Measurement Results

Eccentricity

Eccentricity Test Load: 100 g

Position	As Found	As Left
1	0.00000 g	0.00000 g
2	0.00015 g	0.00017 g
3	0.00000 g	0.00000 g
4	-0.00020 g	-0.00016 g
5	-0.00009 g	-0.00004 g

Maximum Deviation	0.00020 g	0.00017 g
-------------------	-----------	-----------



Error of Indication

	Tare Load	Reference Value	As Found		As Left	
			Indication	Error of Indication	Indication	Error of Indication
1	N/A	0.00000 g	0.00000 g	0.00000 g	0.00000 g	0.00000 g
2	N/A	50.00003 g	49.99997 g	-0.00006 g	50.00005 g	0.00002 g
3	50 g	50.00003 g	49.99995 g	-0.00008 g	50.00004 g	0.00001 g
4	100 g	50.00003 g	49.99996 g	-0.00007 g	50.00005 g	0.00002 g
5	150 g	50.00003 g	49.99993 g	-0.00010 g	50.00002 g	-0.00001 g
6	N/A	100.00001 g	99.99996 g	-0.00005 g	100.00013 g	0.00012 g
7	N/A	150.00004 g	149.99996 g	-0.00008 g	150.00018 g	0.00014 g
8	N/A	199.99995 g	199.99955 g	-0.00040 g	199.99986 g	-0.00009 g

Test Equipment

All weights used for metrological testing are traceable to national or international standards. The weights were calibrated and certified by an accredited calibration laboratory.

Weight Set 1: OIML E2

Weight Set No.:	480	Date of Issue:	07-Sep-2022
Certificate Number:	220609555	Calibration Due Date:	30-Sep-2023

Remarks

Equipment condition: Good
Next calibration according to customer's procedure
Service adjustments were applied to balance.

This document is issued to record completion of the work performed by METTLER TOLEDO on the subject device in accordance with agreed standards. It does not guarantee the continued performance of the subject device. Any measurements recorded are based on the subject device's performance at a given time as tested by METTLER TOLEDO and, except where explicitly stated otherwise, do not express an opinion as to the sufficiency of any customer designed procedures used to test the device. This document is not a warranty, either implied or express. METTLER TOLEDO expressly disclaims any liability arising from the use of the information in this document for any purpose other than as specified herein.

Manufacturer Tolerance Assessment

Assessment done without considering measurement uncertainty.
The measurements from the attached test report were assessed against METTLER TOLEDO tolerances defined in the SOP 'Test and Measurement Procedures for METTLER TOLEDO balances', Document: 10000018502.

	As Found	As Left
Overall	✓	✓
Repeatability	N/A	N/A
Eccentricity	✓	✓
Linearity	✓	✓
Sensitivity	N/A	✓

Measurement Results

Repeatability

Eccentricity

Test Load: 100 g

Position	As Found	As Left
1	0.00000 g	0.00000 g
2	0.00015 g	0.00017 g
3	0.00000 g	0.00000 g
4	-0.00020 g	-0.00016 g
5	-0.00009 g	-0.00004 g

Maximum Deviation	0.00020 g	0.00017 g
Tolerance	0.000200 g ✓	0.000200 g ✓

The maximum deviation is determined as the absolute value of the largest deviation from the center.

NA1821-007-041823-CTR

Manufacturer Tolerance Assessment

Linearity - Differential Method**As Found**

	Preload	Reference Value	Indication	Deviation
2	N/A	50.00003 g	49.99997 g	0.000018 g
3	50 g	50.00003 g	49.99995 g	0.000015 g
4	100 g	50.00003 g	49.99996 g	0.000023 g
5	150 g	50.00003 g	49.99993 g	0.000000 g
8	N/A	199.99995 g	199.99955 g	N/A


Linearity Deviation	0.000023 g
Linearity Tolerance	0.0001 g 

Sensitivity Deviation	0.00040 g
Sensitivity Tolerance	N/A

The As Found Sensitivity Tolerance is only valid if the device has been adjusted before the test.

As Left

	Preload	Reference Value	Indication	Deviation
2	N/A	50.00003 g	50.00005 g	0.000010 g
3	50 g	50.00003 g	50.00004 g	0.000010 g
4	100 g	50.00003 g	50.00005 g	0.000020 g
5	150 g	50.00003 g	50.00002 g	0.000000 g
8*	N/A	199.99995 g	199.99986 g	N/A

Linearity Deviation	0.000020 g
Linearity Tolerance	0.0001 g 

Sensitivity Deviation	0.00009 g
Sensitivity Tolerance	0.0005 g 

The values in column "Deviation" and the "Linearity Deviation" are zero point offset and sensitivity error compensated.

* This point was used to satisfy the sensitivity requirement.

Certification of Calibration

Kansas City Calibration Lab., Inc.

8847 Long Street

Lenexa, Kansas 66215

Telephone: (913) 541-0629 Internet: www.kccl.com Email: service@kccl.com

UNIT UNDER TEST:	Omega CL23A Calibrator-Thermometer K-J-T	TEST RESULT:	PASS
SERIAL NUMBER:	T-263302	PERFORMED ON:	12/30/2022
ASSET NUMBER:	T-263302	DATA TYPE:	FOUND-LEFT
PROCEDURE NAME:	12 Months NIST Certification	TEMPERATURE:	24.4°C
PROCEDURE REV.:	Met Temp	HUMIDITY:	45 %
CALIBRATED BY:	Bart Schwartz		
P.O. NUMBER:		Recertification Date	
CUSTOMER:	AirSource Technologies	December 30, 2023	
	20505 W. 67th Street	Certification Number:	00075443
	Shawnee, KS 66218	Previous Certification Date:	
Cal Seals Intact:	Yes	December 13, 2021	

K.C. Calibration Lab., Inc. certifies that the above listed instrument meets or exceeds all specifications as stated in the referenced procedure (unless otherwise noted). This calibration is traceable to the International System of Units (SI), through National Metrology Institutes (NIST, PTB, NRC, NPL, etc), radiometric techniques, or natural physical constants. This calibration complies with MIL-STD-45662A and ANSI/NCSL Z540-1-1994.

This report may not be reproduced, except in full, unless permission for the publication of an approved abstract is obtained in writing from the calibration organization issuing this report.

Note: Any Test Uncertainty Ratio (TUR) that is less than four to one will appear under the "TUR" heading on the data record. If the TUR meets or exceeds four to one, the field is left blank.

REMARKS:

Standards Used

Asset #	Description	Cal Date	Due Date
2659119	Hart Scientific 1523 Single Chan Reference Thermometer	1/4/2022	1/4/2023
905040	Burns Engineering 5615 Platinum Resistance Thermometer	2/3/2022	2/3/2023
DW518	Fluke 518 Dry-Block Calibrator	9/5/2022	9/5/2023

Test Results

Nominal Set-point		Actual Value (Reference)	UUT (Test Sensor)	Error	Measurement Uncertainty	Method of Realization
Accuracy $\pm 0.5 > 50^\circ\text{F}$, $\pm 0.04\%$ Rdg $> 1250^\circ\text{F}$, $\pm 1.0^\circ\text{F}$ $< 50^\circ\text{F}$						
32.00	F	32.33	32.50	0.17		
72.00	F	72.55	72.10	-0.45		
212.00	F	211.98	210.60	-1.38		
600.00	F	600.05	595.70	-4.35		
1200.0	F	1200.1	1193.33	-6.77		

*****END OF CERTIFICATE*****



Signed:

Bart A. Schwartz , Engineer in Charge

Report of Certification for

SERIAL NUMBER: T-263302

ASSET NUMBER: T-263302

Printed On: Friday, December 30, 2022

Calibration Services Since 1962

Page 2 of 2

Test Results indicate the following: Found-Left: Unit was left as found. As-Left: Unit was left after adjustments.



Nozzle Calibration Data

Project **Rain Carbon M5202 '23**

Project No. **4173**

Nozzle Number	Type	D ₁	D ₂	D ₃	D _n	Calibrated by	Date
Q213	Quartz	0.440	0.440	0.440	0.440	FLS	10/03/00
Q242	Quartz	0.364	0.365	0.365	0.365	KRM	12/29/22
Q234	Quartz	0.376	0.376	0.376	0.376	JSS	08/11/06
Q264	Quartz	0.389	0.387	0.387	0.388	KRM	01/03/23
Q261	Quartz	0.396	0.396	0.397	0.396	KRM	01/03/23

Appendix E-1

Pre-Test Calibrations



Barometer Calibration


Barometer No.	B24	Reference	Mercury No. 1
Performed By	Lex Hooper	Date	05/10/23

Mercury Reference Barometer		
Mercury Barometer Reading	In. Hg	29.29
Room Temperature	°F	78
Temperature Correction	In. Hg	-0.131
Latitude	° N or S	39
Gravity Correction	In. Hg	-0.017
Corrected Reading	In. Hg	29.14
Test Barometer		
Test Barometer Reading	In. Hg	29.16
Error	In. Hg	0.02
Error ≤ 0.2 In.	Pass/Fail	PASS
Comments		


Performed by: Lex Hooper

Performed By	<div style="border: 1px solid black; padding: 2px;">L. Hooper</div>	Probe ID	<div style="border: 1px solid black; padding: 2px;">5-5</div>
Date	<div style="border: 1px solid black; padding: 2px;">5/26/23</div>	Pitot ID	<div style="border: 1px solid black; padding: 2px;">S-2</div>
		Thermocouple ID	<div style="border: 1px solid black; padding: 2px;">68-3</div>


Probe Pitot	
Pitot Tube assembly level? (yes/no)	Yes
Pitot Tube openings damaged? (yes/no, if yes - comment below)	No




A (no criteria)	in.	0.890		
D _t (0.188" < D _t < 0.375" Recommended)	in.	0.370		
P _A (1.05 D _t < P _A < 1.05 D _t)	in.	0.450	PASS	
P _B (1.05 D _t < P _B < 1.05 D _t)	in.	0.420	PASS	



θ	deg.	0.5		
ω = A sin (θ)				
ω (ω < 0.032")	in.	0.008	PASS	



γ	deg.	2.5		
Z = A sin (g)				
Z (Z < 0.125")	in.	0.039	PASS	



α ₁ (α ₁ < 10°)	deg.	4.0	PASS	
α ₂ (α ₂ < 10°)	deg.	4.5	PASS	
β ₁ (β ₁ < 5°)	deg.	1.5	PASS	
β ₂ (β ₂ < 5°)	deg.	1.0	PASS	

Stack ThermoCouple Calibration			
Reference TC ID	<div style="border: 1px solid black; padding: 2px;">FPTC-10/CL23A#2</div>		
Heat Source	Stack TC °F	Ref. TC °F	Difference
Ambient Air	69.5	69.8	0.3
Ice Water Bath	34.7	35.0	0.3
Stack TC - Reference TC _{max} < 2.0 °F			0.3
Stack TC Pass/Fail			PASS

Comments

Performed by Lex Hooper



Umbilical Hookup Check-Out

Performed By L. HooperReference TC FPTC-10/CL23A #2Hookup No. 20TC No. 20Date 06/26/23**Check-Out Procedure**

Leak Check	Yes
Flow Check (>4" ΔH)	Yes
Check Valve Operational	Yes

Thermocouple Calibration

Hookup T/C Temp. (°F)	Reference Temp. (°F)	Difference (°F)	Difference < 2.0 °F
33.7	33.9	0.2	PASS

Hookup No. 21TC No. 21Date 06/26/23**Check-Out Procedure**

Leak Check	Yes
Flow Check (>4" ΔH)	Yes
Check Valve Operational	Yes

Thermocouple Calibration

Hookup T/C Temp. (°F)	Reference Temp. (°F)	Difference (°F)	Difference < 2.0 °F
33.7	33.9	0.2	PASS

Hookup No. 22TC No. 22Date 06/26/23**Check-Out Procedure**

Leak Check	Yes
Flow Check (>4" ΔH)	Yes
Check Valve Operational	Yes

Thermocouple Calibration

Hookup T/C Temp. (°F)	Reference Temp. (°F)	Difference (°F)	Difference < 2.0 °F
33.8	33.9	0.1	PASS

Hookup No. 26TC No. 26Date 06/26/23**Check-Out Procedure**

Leak Check	Yes
Flow Check (>4" ΔH)	Yes
Check Valve Operational	Yes

Thermocouple Calibration

Hookup T/C Temp. (°F)	Reference Temp. (°F)	Difference (°F)	Difference < 2.0 °F
33.8	33.9	0.1	PASS

Hookup No. 29TC No. 29Date 05/10/23**Check-Out Procedure**

Leak Check	Yes
Flow Check (>4" ΔH)	Yes
Check Valve Operational	Yes

Thermocouple Calibration

Hookup T/C Temp. (°F)	Reference Temp. (°F)	Difference (°F)	Difference < 2.0 °F
32.3	32.3	0.0	PASS

Comments

Performed by Lex Hooper



Filterable Particulate Filter TC

 Performed By L. Hooper

 Reference TC FPTC-10/CL23A #2

Themocouple Calibration

 Date 05/24/23

 FPM TC ID 1

Source	FPM TC Temp. (°F)	Reference Temp. (°F)	Difference (°F)	Difference < 5.4 °F
Ambient Air	69.8	69.3	0.5	PASS
Ice Water Bath	32.4	32.2	0.2	PASS

Themocouple Calibration

 Date 05/24/23

 FPM TC ID 5

Source	FPM TC Temp. (°F)	Reference Temp. (°F)	Difference (°F)	Difference < 5.4 °F
Ambient Air	70.1	69.3	0.8	PASS
Ice Water Bath	32.3	32.2	0.1	PASS

Themocouple Calibration

 Date 05/25/23

 FPM TC ID 6

Source	FPM TC Temp. (°F)	Reference Temp. (°F)	Difference (°F)	Difference < 5.4 °F
Ambient Air	69.8	69.3	0.5	PASS
Ice Water Bath	32.4	32.3	0.1	PASS

Themocouple Calibration

 Date 05/25/23

 FPM TC ID 8

Source	FPM TC Temp. (°F)	Reference Temp. (°F)	Difference (°F)	Difference < 5.4 °F
Ambient Air	70.0	69.3	0.7	PASS
Ice Water Bath	32.5	32.3	0.2	PASS

Themocouple Calibration

 Date 05/02/23

 FPM TC ID 9

Source	FPM TC Temp. (°F)	Reference Temp. (°F)	Difference (°F)	Difference < 5.4 °F
Ambient Air	61.5	61.1	0.4	PASS
Ice Water Bath	32.8	32.7	0.1	PASS

Comments

 Performed by Lex Hooper



Condensable Particulate Filter TC

 Performed By L. Hooper

 Reference TC FPTC-10/CL23A #2

Themocouple Calibration

 Date 05/02/23
CPF TC ID CPF 3

Source	FPM TC Temp. (°F)	Reference Temp. (°F)	Difference (°F)	Difference < 5.4 °F
Ambient Air	61.8	61.1	0.7	PASS
Ice Water Bath	27.8	32.7	4.9	PASS

Themocouple Calibration

 Date 05/02/23
CPF TC ID CPF 4

Source	FPM TC Temp. (°F)	Reference Temp. (°F)	Difference (°F)	Difference < 5.4 °F
Ambient Air	61.6	61.1	0.5	PASS
Ice Water Bath	32.3	32.7	0.4	PASS

Themocouple Calibration

 Date 12/08/22
CPF TC ID CPF 6

Source	FPM TC Temp. (°F)	Reference Temp. (°F)	Difference (°F)	Difference < 5.4 °F
Ambient Air	63.9	64.1	0.2	PASS
Ice Water Bath	33.9	34.4	0.5	PASS

Themocouple Calibration

 Date 05/10/23
CPF TC ID CPF 7

Source	FPM TC Temp. (°F)	Reference Temp. (°F)	Difference (°F)	Difference < 5.4 °F
Ambient Air	85.7	85.8	0.1	PASS
Ice Water Bath	32.7	32.3	0.4	PASS

Themocouple Calibration

 Date 10/05/22
CPF TC ID CPF 9

Source	FPM TC Temp. (°F)	Reference Temp. (°F)	Difference (°F)	Difference < 5.4 °F
Ambient Air	68.6	68.7	0.1	PASS
Ice Water Bath	32.5	33.1	0.6	PASS

Comments

 Performed by Lex Hooper

Console #

Performed By

Previous Y

Date

DRY GAS METER VOLUME CALIBRATION

Leak Checks

Inlet thru Pump (Front)	Pass	Pump to Orifice (Back)		Pass
PARAMETER	UNIT	RUN 1	RUN 2	BRACKETING
Orifice Number		1		15 16
K Factor		0.5229		0.4163 0.5608
Initial DGM Volume	cf	585.100	610.000	573.300 598.000
Final DGM Volume	cf	590.100	615.000	578.300 603.000
Net DGM Volume	cf	5.000	5.000	5.000 5.000
Initial DGM Inlet Temp.	° F	72.0	74.0	69.0 73.0
Initial DGM Outlet Temp.	° F	72.0	74.0	70.0 73.0
Final DGM Inlet Temp.	° F	72.0	75.0	70.0 74.0
Final DGM Outlet Temp.	° F	72.0	75.0	70.0 74.0
Average DGM Temp.	° F	72.0	74.5	69.8 73.5
Initial Room Temp.	° F	68.0	74.0	68.0 73.0
Final Room Temp.	° F	69.0	74.0	68.0 73.0
Average Room Temp.	° F	68.5	74.0	68.0 73.0
Time	m:ss	7:25	7:27	9:13 7:02
	sec	445	447	553 422
Orifice ΔH	in. H ₂ O	1.50	1.50	0.92 1.70
Barometric Pressure	in. Hg	29.31	29.21	29.31 29.22
Pump Vacuum	in. Hg	22	22	23 22
Vcr (std)	dscf	4.946	4.926	4.896 4.994
Vm (std)	dscf	4.880	4.841	4.894 4.854
Y		1.013	1.017	1.000 1.029
ΔH@		1.873	1.927	1.778 1.942
Error From Average Y	%	0.20	-0.20	1.49 -1.31
+/- 2% Criteria		PASS	PASS	PASS PASS

Average Y	1.015
Average ΔH@	1.900
Error From Initial Y	1.14%
+/- 5% Criteria	PASS

DRY GAS METER THERMOCOUPLE CALIBRATION

Thermocouple ID		Console	Reference ID	FPTC-10/CL23A #2
DGM TC	Heat Source	DGM TC °F	Ref. TC °F	Difference
Inlet	Ambient Air	67.0	68.8	1.8
	Hot Water Bath	204.0	204.5	0.5
Outlet	Ambient Air	67.0	68.8	1.8
	Hot Water Bath	204.0	204.5	0.5
DGM TC - Reference TC _{max} < 5.4 °F				1.8
DGM TC Pass/Fail				PASS

Appendix E-2

Post-Test Calibrations



Barometer Calibration


Barometer No.	B24	Reference	Mercury No. 1
Performed By	Lex Hooper	Date	07/27/23

Mercury Reference Barometer		
Mercury Barometer Reading	In. Hg	29.20
Room Temperature	°F	78
Temperature Correction	In. Hg	-0.130
Latitude	° N or S	39
Gravity Correction	In. Hg	-0.017
Corrected Reading	In. Hg	29.05
Test Barometer		
Test Barometer Reading	In. Hg	29.07
Error	In. Hg	0.02
Error ≤ 0.2 In.	Pass/Fail	PASS
Comments		


Performed by: Lex Hooper

Performed By L. Hooper	Probe ID 5-5
Date 7/27/23	Pitot ID S-2
Thermocouple ID 68-3	


Probe Pitot	
Pitot Tube assembly level? (yes/no)	Yes
Pitot Tube openings damaged? (yes/no, if yes - comment below)	No




A (no criteria)	in.	0.900		
D_t ($0.188" < D_t < 0.375"$ Recommended)	in.	0.370		
P_A ($1.05 D_t < P_A < 1.05 D_t$)	in.	0.480	PASS	
P_B ($1.05 D_t < P_B < 1.05 D_t$)	in.	0.430	PASS	



θ	deg.	0.5		
$\omega = A \sin (\theta)$				
ω ($\omega < 0.032"$)	in.	0.008	PASS	



γ	deg.	2.0		
$Z = A \sin (\gamma)$				
Z ($Z < 0.125"$)	in.	0.031	PASS	



α_1 ($\alpha_1 < 10^\circ$)	deg.	2.5	PASS	
α_2 ($\alpha_2 < 10^\circ$)	deg.	3.0	PASS	
β_1 ($\beta_1 < 5^\circ$)	deg.	1.5	PASS	
β_2 ($\beta_2 < 5^\circ$)	deg.	2.0	PASS	

Stack ThermoCouple Calibration			
Reference TC ID	FPTC-10/CL23A#2		
Heat Source	Stack TC °F	Ref. TC °F	Difference
Ambient Air	77.7	77.8	0.1
Ice Water Bath	33.1	33.0	0.1
Stack TC - Reference TC _{max} < 2.0 °F			0.1
Stack TC Pass/Fail			PASS

Comments

Performed by Lex Hooper



Umbilical Hookup Check-Out

Performed By L. HooperReference TC FPTC-10/CL23A #2Hookup No. 20TC No. 20Date 07/25/23

Check-Out Procedure

Leak Check	Yes
Flow Check (>4" ΔH)	Yes
Check Valve Operational	Yes

Thermocouple Calibration

Hookup T/C Temp. (°F)	Reference Temp. (°F)	Difference (°F)	Difference < 2.0 °F
32.5	32.0	0.5	PASS

Hookup No. 21TC No. 21Date 07/25/23

Check-Out Procedure

Leak Check	Yes
Flow Check (>4" ΔH)	Yes
Check Valve Operational	Yes

Thermocouple Calibration

Hookup T/C Temp. (°F)	Reference Temp. (°F)	Difference (°F)	Difference < 2.0 °F
32.4	32.0	0.4	PASS

Hookup No. 22TC No. 22Date 07/25/23

Check-Out Procedure

Leak Check	Yes
Flow Check (>4" ΔH)	Yes
Check Valve Operational	Yes

Thermocouple Calibration

Hookup T/C Temp. (°F)	Reference Temp. (°F)	Difference (°F)	Difference < 2.0 °F
33.0	32.0	1.0	PASS

Hookup No. 26TC No. 26Date 07/25/23

Check-Out Procedure

Leak Check	Yes
Flow Check (>4" ΔH)	Yes
Check Valve Operational	Yes

Thermocouple Calibration

Hookup T/C Temp. (°F)	Reference Temp. (°F)	Difference (°F)	Difference < 2.0 °F
31.8	32.0	0.2	PASS

Hookup No. 29TC No. 29Date 07/24/23

Check-Out Procedure

Leak Check	Yes
Flow Check (>4" ΔH)	Yes
Check Valve Operational	Yes

Thermocouple Calibration

Hookup T/C Temp. (°F)	Reference Temp. (°F)	Difference (°F)	Difference < 2.0 °F
32.7	32.3	0.4	PASS

Comments

Performed by Lex Hooper



Filterable Particulate Filter TC

 Performed By L. Hooper

 Reference TC FPTC-10/CL23A #2

Themocouple Calibration

 Date 07/24/23
FPM TC ID 1

Source	FPM TC Temp. (°F)	Reference Temp. (°F)	Difference (°F)	Difference < 5.4 °F
Ambient Air	73.5	73.5	0.0	PASS
Ice Water Bath	32.5	32.3	0.2	PASS

Themocouple Calibration

 Date 07/24/23
FPM TC ID 5

Source	FPM TC Temp. (°F)	Reference Temp. (°F)	Difference (°F)	Difference < 5.4 °F
Ambient Air	73.7	73.5	0.2	PASS
Ice Water Bath	32.5	32.3	0.2	PASS

Themocouple Calibration

 Date 07/24/23
FPM TC ID 6

Source	FPM TC Temp. (°F)	Reference Temp. (°F)	Difference (°F)	Difference < 5.4 °F
Ambient Air	73.3	73.5	0.2	PASS
Ice Water Bath	32.4	32.3	0.1	PASS

Themocouple Calibration

 Date 07/24/23
FPM TC ID 8

Source	FPM TC Temp. (°F)	Reference Temp. (°F)	Difference (°F)	Difference < 5.4 °F
Ambient Air	73.6	73.5	0.1	PASS
Ice Water Bath	32.4	32.3	0.1	PASS

Themocouple Calibration

 Date 07/24/23
FPM TC ID 9

Source	FPM TC Temp. (°F)	Reference Temp. (°F)	Difference (°F)	Difference < 5.4 °F
Ambient Air	73.3	73.5	0.2	PASS
Ice Water Bath	32.5	32.3	0.2	PASS

Comments

 Performed by Lex Hooper



Condensable Particulate Filter TC

 Performed By L. Hooper

 Reference TC FPTC-10/CL23A #2

Themocouple Calibration

 Date 07/24/23
CPF TC ID CPF 3

Source	FPM TC Temp. (°F)	Reference Temp. (°F)	Difference (°F)	Difference < 5.4 °F
Ambient Air	73.3	73.5	0.2	PASS
Ice Water Bath	32.5	32.3	0.2	PASS

Themocouple Calibration

 Date 07/24/23
CPF TC ID CPF 4

Source	FPM TC Temp. (°F)	Reference Temp. (°F)	Difference (°F)	Difference < 5.4 °F
Ambient Air	73.3	73.5	0.2	PASS
Ice Water Bath	32.6	32.3	0.3	PASS

Themocouple Calibration

 Date 07/24/23
CPF TC ID CPF 6

Source	FPM TC Temp. (°F)	Reference Temp. (°F)	Difference (°F)	Difference < 5.4 °F
Ambient Air	73.3	73.5	0.2	PASS
Ice Water Bath	32.4	32.3	0.1	PASS

Themocouple Calibration

 Date 07/24/23
CPF TC ID CPF 7

Source	FPM TC Temp. (°F)	Reference Temp. (°F)	Difference (°F)	Difference < 5.4 °F
Ambient Air	73.2	73.5	0.3	PASS
Ice Water Bath	32.4	32.3	0.1	PASS

Themocouple Calibration

 Date 07/24/23
CPF TC ID CPF 9

Source	FPM TC Temp. (°F)	Reference Temp. (°F)	Difference (°F)	Difference < 5.4 °F
Ambient Air	73.2	73.5	0.3	PASS
Ice Water Bath	32.2	32.3	0.1	PASS

Comments

 Performed by Lex Hooper

Console #

Performed By

Previous Y

Date

DRY GAS METER VOLUME CALIBRATION

Leak Checks

Inlet thru Pump (Front)		Pass	Pump to Orifice (Back)		Pass
PARAMETER	UNIT	RUN 1	RUN 2	BRACKETING	
Orifice Number		16		7	1
K Factor		0.5608		0.6381	0.5229
Initial DGM Volume	cf	884.000	889.500	897.000	621.500
Final DGM Volume	cf	889.000	894.500	902.000	626.500
Net DGM Volume	cf	5.000	5.000	5.000	5.000
Initial DGM Inlet Temp.	° F	84.0	84.0	86.0	86.0
Initial DGM Outlet Temp.	° F	84.0	84.0	86.0	86.0
Final DGM Inlet Temp.	° F	84.0	85.0	86.0	86.0
Final DGM Outlet Temp.	° F	84.0	85.0	86.0	86.0
Average DGM Temp.	° F	84.0	84.5	86.0	86.0
Initial Room Temp.	° F	79.0	79.0	80.0	80.0
Final Room Temp.	° F	79.0	80.0	80.0	80.0
Average Room Temp.	° F	79.0	79.5	80.0	80.0
Time	m:ss	6:59	6:58	6:00	7:24
	sec	419	418	360	444
Orifice ΔH	in. H ₂ O	1.70	1.70	2.20	1.50
Barometric Pressure	in. Hg	29.06	29.06	29.06	29.06
Pump Vacuum	in. Hg	21	21	20	22
Vcr (std)	dscf	4.903	4.889	4.789	4.840
Vm (std)	dscf	4.734	4.730	4.723	4.715
Y		1.036	1.034	1.014	1.027
ΔH@		1.931	1.923	1.845	1.913
Error From Average Y	%	-0.10	0.10	2.00	0.78
+/- 2% Criteria		PASS	PASS	PASS	PASS

Average Y	1.035
Average ΔH@	1.927
Error From Initial Y	1.94%
+/- 5% Criteria	PASS

DRY GAS METER THERMOCOUPLE CALIBRATION

Thermocouple ID		Console	Reference ID	FPTC-10/CL23A #2	
DGM TC	Heat Source	DGM TC °F	Ref. TC °F	Difference	
Inlet	Ambient Air	74.0	76.5	2.5	
	Hot Water Bath	209.0	208.3	0.7	
Outlet	Ambient Air	74.0	76.5	2.5	
	Hot Water Bath	209.0	208.3	0.7	
DGM TC - Reference TC _{max} < 5.4 °F					2.5
DGM TC Pass/Fail					PASS

APPENDIX F

PROCESS DATA

Robinson - Kiln 1 - Start-up Engineering Study Operating Data			
Date/Time	Feedrate (Tons Per Hour)	Pyroscrubber Inlet Temperature A Thermocouple (Degrees F)	Pyroscrubber Inlet Temperature B Thermocouple (Degrees F)
7/20/23 9:01	0	582	552
7/20/23 9:02	0	581	551
7/20/23 9:03	0	582	552
7/20/23 9:04	0	585	555
7/20/23 9:05	0	588	559
7/20/23 9:06	0	590	561
7/20/23 9:07	0	590	561
7/20/23 9:08	0	590	560
7/20/23 9:09	0	590	560
7/20/23 9:10	0	589	559
7/20/23 9:11	0	588	558
7/20/23 9:12	0	585	555
7/20/23 9:13	0	584	553
7/20/23 9:14	0	582	550
7/20/23 9:15	0	579	548
7/20/23 9:16	0	579	550
7/20/23 9:17	0	582	553
7/20/23 9:18	0	587	558
7/20/23 9:19	0	589	558
7/20/23 9:20	0	587	556
7/20/23 9:21	0	588	558
7/20/23 9:22	0	588	558
7/20/23 9:23	0	588	558
7/20/23 9:24	0	589	558
7/20/23 9:25	0	587	556
7/20/23 9:26	0	586	555
7/20/23 9:27	0	585	554
7/20/23 9:28	0	584	554
7/20/23 9:29	0	586	556
7/20/23 9:30	0	590	561
7/20/23 9:31	0	592	563
7/20/23 9:32	0	593	564
7/20/23 9:33	0	593	562
7/20/23 9:34	0	592	561
7/20/23 9:35	0	590	559
7/20/23 9:36	0	588	556
7/20/23 9:37	0	586	555
7/20/23 9:38	0	585	554
7/20/23 9:39	0	586	556
7/20/23 9:40	0	584	553
7/20/23 9:41	0	583	554
7/20/23 9:42	0	587	559
7/20/23 9:43	0	591	562

Electronic Filing: Received, Clerk's Office 03/15/2024

7/20/23 9:44	0	591	562
7/20/23 9:45	0	591	561
7/20/23 9:46	6	589	559
7/20/23 9:47	6	586	556
7/20/23 9:48	6	586	557
7/20/23 9:49	6	585	555
7/20/23 9:50	6	585	555
7/20/23 9:51	6	587	557
7/20/23 9:52	6	590	560
7/20/23 9:53	6	594	564
7/20/23 9:54	6	598	570
7/20/23 9:55	6	601	573
7/20/23 9:56	6	609	580
7/20/23 9:57	6	618	590
7/20/23 9:58	6	627	600
7/20/23 9:59	6	637	610
7/20/23 10:00	6	646	619
7/20/23 10:01	6	657	631
7/20/23 10:02	6	668	641
7/20/23 10:03	6	679	652
7/20/23 10:04	6	689	660
7/20/23 10:05	6	699	669
7/20/23 10:06	6	706	677
7/20/23 10:07	6	713	683
7/20/23 10:08	6	720	690
7/20/23 10:09	6	725	696
7/20/23 10:10	6	728	698
7/20/23 10:11	6	731	701
7/20/23 10:12	6	735	704
7/20/23 10:13	6	740	709
7/20/23 10:14	6	744	713
7/20/23 10:15	6	747	716
7/20/23 10:16	6	750	720
7/20/23 10:17	6	754	723
7/20/23 10:18	6	758	728
7/20/23 10:19	6	762	733
7/20/23 10:20	6	767	737
7/20/23 10:21	6	769	740
7/20/23 10:22	6	771	742
7/20/23 10:23	6	775	746
7/20/23 10:24	6	777	750
7/20/23 10:25	6	781	754
7/20/23 10:26	6	785	758
7/20/23 10:27	6	787	758
7/20/23 10:28	6	792	763
7/20/23 10:29	6	794	765
7/20/23 10:30	6	796	766
7/20/23 10:31	6	796	766

Electronic Filing: Received, Clerk's Office 03/15/2024

7/20/23 10:32	6	798	769
7/20/23 10:33	6	801	772
7/20/23 10:34	6	803	774
7/20/23 10:35	6	804	775
7/20/23 10:36	6	807	778
7/20/23 10:37	6	808	779
7/20/23 10:38	6	811	784
7/20/23 10:39	6	815	787
7/20/23 10:40	6	818	790
7/20/23 10:41	6	825	798
7/20/23 10:42	6	825	798
7/20/23 10:43	6	824	797
7/20/23 10:44	6	826	799
7/20/23 10:45	6	825	798
7/20/23 10:46	6	828	800
7/20/23 10:47	6	831	803
7/20/23 10:48	6	835	806
7/20/23 10:49	6	838	810
7/20/23 10:50	6	840	812
7/20/23 10:51	6	841	814
7/20/23 10:52	6	843	816
7/20/23 10:53	6	847	819
7/20/23 10:54	6	850	822
7/20/23 10:55	6	850	822
7/20/23 10:56	6	850	823
7/20/23 10:57	6	851	824
7/20/23 10:58	6	852	824
7/20/23 10:59	6	855	827
7/20/23 11:00	6	861	835
7/20/23 11:01	6	866	839
7/20/23 11:02	6	865	839
7/20/23 11:03	6	867	840
7/20/23 11:04	6	868	841
7/20/23 11:05	6	867	840
7/20/23 11:06	6	868	842
7/20/23 11:07	6	868	842
7/20/23 11:08	6	871	846
7/20/23 11:09	6	874	848
7/20/23 11:10	6	877	852
7/20/23 11:11	6	881	856
7/20/23 11:12	6	881	856
7/20/23 11:13	6	881	855
7/20/23 11:14	6	883	857
7/20/23 11:15	6	887	861
7/20/23 11:16	6	891	866
7/20/23 11:17	6	897	871
7/20/23 11:18	6	900	873
7/20/23 11:19	6	900	873

Electronic Filing: Received, Clerk's Office 03/15/2024

7/20/23 11:20	6	901	875
7/20/23 11:21	6	904	878
7/20/23 11:22	6	905	880
7/20/23 11:23	6	906	881
7/20/23 11:24	6	909	882
7/20/23 11:25	6	910	885
7/20/23 11:26	6	912	886
7/20/23 11:27	6	915	888
7/20/23 11:28	6	915	887
7/20/23 11:29	6	917	889
7/20/23 11:30	6	918	890
7/20/23 11:31	6	920	892
7/20/23 11:32	6	922	895
7/20/23 11:33	6	923	895
7/20/23 11:34	6	924	897
7/20/23 11:35	6	927	899
7/20/23 11:36	6	929	902
7/20/23 11:37	6	933	907
7/20/23 11:38	6	936	908
7/20/23 11:39	6	939	910
7/20/23 11:40	6	942	914
7/20/23 11:41	6	946	919
7/20/23 11:42	6	945	919
7/20/23 11:43	6	949	922
7/20/23 11:44	6	952	923
7/20/23 11:45	6	952	924
7/20/23 11:46	6	953	924
7/20/23 11:47	6	955	926
7/20/23 11:48	6	959	931
7/20/23 11:49	6	959	930
7/20/23 11:50	6	962	936
7/20/23 11:51	6	965	938
7/20/23 11:52	6	963	937
7/20/23 11:53	6	964	936
7/20/23 11:54	6	968	941
7/20/23 11:55	6	969	943
7/20/23 11:56	6	970	943
7/20/23 11:57	6	974	947
7/20/23 11:58	6	978	951
7/20/23 11:59	6	978	951
7/20/23 12:00	6	976	950
7/20/23 12:01	6	976	950
7/20/23 12:02	6	979	953
7/20/23 12:03	6	983	955
7/20/23 12:04	6	983	956
7/20/23 12:05	6	985	958
7/20/23 12:06	6	988	961
7/20/23 12:07	6	988	961

Electronic Filing: Received, Clerk's Office 03/15/2024

7/20/23 12:08	6	989	962
7/20/23 12:09	6	990	963
7/20/23 12:10	6	993	966
7/20/23 12:11	6	995	968
7/20/23 12:12	6	996	970
7/20/23 12:13	6	1000	974
7/20/23 12:14	6	1004	977
7/20/23 12:15	6	1007	980
7/20/23 12:16	6	1006	980
7/20/23 12:17	6	1007	980
7/20/23 12:18	6	1008	982
7/20/23 12:19	6	1010	983
7/20/23 12:20	6	1011	984
7/20/23 12:21	6	1013	986
7/20/23 12:22	6	1017	990
7/20/23 12:23	6	1017	991
7/20/23 12:24	6	1018	993
7/20/23 12:25	6	1017	991
7/20/23 12:26	6	1017	991
7/20/23 12:27	6	1019	993
7/20/23 12:28	6	1020	995
7/20/23 12:29	6	1025	998
7/20/23 12:30	6	1026	999
7/20/23 12:31	6	1029	1004
7/20/23 12:32	6	1032	1006
7/20/23 12:33	6	1030	1005
7/20/23 12:34	6	1030	1004
7/20/23 12:35	6	1031	1006
7/20/23 12:36	6	1035	1010
7/20/23 12:37	6	1039	1013
7/20/23 12:38	6	1037	1012
7/20/23 12:39	6.1	1036	1011
7/20/23 12:40	6	1033	1008
7/20/23 12:41	6	1034	1009
7/20/23 12:42	6	1036	1012
7/20/23 12:43	6	1038	1014
7/20/23 12:44	6	1041	1016
7/20/23 12:45	6	1041	1015
7/20/23 12:46	6	1041	1014
7/20/23 12:47	6	1042	1016
7/20/23 12:48	6	1042	1016
7/20/23 12:49	6	1043	1018
7/20/23 12:50	6	1045	1020
7/20/23 12:51	6	1049	1024
7/20/23 12:52	6	1049	1024
7/20/23 12:53	6	1049	1025
7/20/23 12:54	5.9	1053	1029
7/20/23 12:55	6.1	1055	1031

Electronic Filing: Received, Clerk's Office 03/15/2024

7/20/23 12:56	6	1057	1032
7/20/23 12:57	6	1058	1033
7/20/23 12:58	6	1060	1036
7/20/23 12:59	6	1061	1037
7/20/23 13:00	6	1061	1036
7/20/23 13:01	6	1058	1033
7/20/23 13:02	6	1059	1035
7/20/23 13:03	6	1059	1033
7/20/23 13:04	6	1057	1033
7/20/23 13:05	6	1059	1035
7/20/23 13:06	6	1061	1036
7/20/23 13:07	6	1066	1041
7/20/23 13:08	6	1067	1043
7/20/23 13:09	6	1067	1043
7/20/23 13:10	6	1067	1044
7/20/23 13:11	6	1068	1044
7/20/23 13:12	6	1068	1044
7/20/23 13:13	6	1073	1049
7/20/23 13:14	6	1075	1050
7/20/23 13:15	6	1077	1051
7/20/23 13:16	6	1075	1051
7/20/23 13:17	6	1078	1054
7/20/23 13:18	6	1082	1059
7/20/23 13:19	6	1082	1059
7/20/23 13:20	6	1082	1058
7/20/23 13:21	6	1085	1061
7/20/23 13:22	6	1087	1064
7/20/23 13:23	6	1088	1066
7/20/23 13:24	6	1086	1062
7/20/23 13:25	6	1086	1061
7/20/23 13:26	6	1088	1064
7/20/23 13:27	6	1089	1064
7/20/23 13:28	6	1091	1067
7/20/23 13:29	6	1090	1066
7/20/23 13:30	6	1092	1069
7/20/23 13:31	6	1094	1071
7/20/23 13:32	6	1095	1071
7/20/23 13:33	6	1096	1071
7/20/23 13:34	6	1096	1071
7/20/23 13:35	6	1099	1074
7/20/23 13:36	6	1101	1076
7/20/23 13:37	6	1104	1080
7/20/23 13:38	6	1105	1081
7/20/23 13:39	6	1103	1080
7/20/23 13:40	6	1102	1079
7/20/23 13:41	6	1105	1081
7/20/23 13:42	6	1106	1083
7/20/23 13:43	6	1106	1083

Electronic Filing: Received, Clerk's Office 03/15/2024

7/20/23 13:44	6	1108	1086
7/20/23 13:45	6	1109	1086
7/20/23 13:46	6	1111	1087
7/20/23 13:47	6	1110	1086
7/20/23 13:48	6	1108	1083
7/20/23 13:49	6	1107	1083
7/20/23 13:50	6	1108	1084
7/20/23 13:51	6	1110	1087
7/20/23 13:52	6	1114	1091
7/20/23 13:53	6	1113	1090
7/20/23 13:54	6	1115	1092
7/20/23 13:55	6	1117	1093
7/20/23 13:56	6	1118	1096
7/20/23 13:57	6	1117	1092
7/20/23 13:58	6	1117	1093
7/20/23 13:59	6	1121	1097
7/20/23 14:00	6	1122	1097
7/20/23 14:01	6	1120	1095
7/20/23 14:02	6	1122	1098
7/20/23 14:03	6	1126	1102
7/20/23 14:04	6	1127	1102
7/20/23 14:05	6	1127	1101
7/20/23 14:06	6	1124	1100
7/20/23 14:07	6	1126	1101
7/20/23 14:08	6	1127	1101
7/20/23 14:09	6	1127	1101
7/20/23 14:10	6	1128	1104
7/20/23 14:11	6	1130	1106
7/20/23 14:12	6	1131	1107
7/20/23 14:13	6	1132	1106
7/20/23 14:14	6	1129	1104
7/20/23 14:15	6	1131	1106
7/20/23 14:16	6	1132	1107
7/20/23 14:17	6	1132	1107
7/20/23 14:18	6	1132	1107
7/20/23 14:19	6	1129	1104
7/20/23 14:20	6	1129	1104
7/20/23 14:21	6	1131	1106
7/20/23 14:22	6	1132	1108
7/20/23 14:23	6	1130	1107
7/20/23 14:24	6	1131	1107
7/20/23 14:25	6	1131	1107
7/20/23 14:26	6	1134	1112
7/20/23 14:27	6	1137	1115
7/20/23 14:28	6	1139	1116
7/20/23 14:29	6	1142	1119
7/20/23 14:30	6	1144	1120
7/20/23 14:31	6	1145	1121

Electronic Filing: Received, Clerk's Office 03/15/2024

7/20/23 14:32	6	1146	1121
7/20/23 14:33	6	1141	1116
7/20/23 14:34	6	1142	1118
7/20/23 14:35	6	1141	1117
7/20/23 14:36	6	1142	1116
7/20/23 14:37	6	1142	1117
7/20/23 14:38	6	1142	1117
7/20/23 14:39	6	1144	1119
7/20/23 14:40	6	1142	1118
7/20/23 14:41	6	1140	1116
7/20/23 14:42	6.1	1143	1119
7/20/23 14:43	6	1146	1123
7/20/23 14:44	6	1145	1120
7/20/23 14:45	6	1144	1121
7/20/23 14:46	6	1146	1122
7/20/23 14:47	6	1148	1124
7/20/23 14:48	6	1147	1123
7/20/23 14:49	6	1149	1125
7/20/23 14:50	5.9	1148	1124
7/20/23 14:51	6	1150	1125
7/20/23 14:52	6	1149	1125
7/20/23 14:53	6	1149	1125
7/20/23 14:54	6	1152	1127
7/20/23 14:55	6	1152	1126
7/20/23 14:56	6	1152	1126
7/20/23 14:57	6	1157	1132
7/20/23 14:58	6	1162	1136
7/20/23 14:59	6	1165	1139
7/20/23 15:00	6	1161	1135
7/20/23 15:01	6	1157	1132
7/20/23 15:02	6	1155	1132
7/20/23 15:03	6	1159	1135
7/20/23 15:04	6	1161	1137
7/20/23 15:05	6	1161	1137
7/20/23 15:06	6	1160	1134
7/20/23 15:07	6	1157	1133
7/20/23 15:08	6	1160	1135
7/20/23 15:09	6	1165	1139
7/20/23 15:10	6	1169	1145
7/20/23 15:11	6	1163	1139
7/20/23 15:12	6	1161	1138
7/20/23 15:13	6	1161	1139
7/20/23 15:14	6	1163	1140
7/20/23 15:15	6	1165	1142
7/20/23 15:16	6	1166	1145
7/20/23 15:17	6	1165	1143
7/20/23 15:18	6.1	1168	1145
7/20/23 15:19	6	1165	1141

Electronic Filing: Received, Clerk's Office 03/15/2024

7/20/23 15:20	6	1166	1142
7/20/23 15:21	6	1165	1141
7/20/23 15:22	6	1167	1142
7/20/23 15:23	6	1170	1144
7/20/23 15:24	6	1172	1147
7/20/23 15:25	6	1171	1145
7/20/23 15:26	6	1168	1143
7/20/23 15:27	6	1170	1146
7/20/23 15:28	6	1178	1153
7/20/23 15:29	6	1180	1154
7/20/23 15:30	6	1181	1156
7/20/23 15:31	6	1182	1157
7/20/23 15:32	6	1179	1153
7/20/23 15:33	6	1179	1154
7/20/23 15:34	6	1180	1156
7/20/23 15:35	6	1184	1159
7/20/23 15:36	6	1183	1158
7/20/23 15:37	6	1185	1159
7/20/23 15:38	6	1188	1161
7/20/23 15:39	6	1190	1164
7/20/23 15:40	6	1195	1171
7/20/23 15:41	6	1192	1167
7/20/23 15:42	6	1191	1166
7/20/23 15:43	6	1189	1165
7/20/23 15:44	6	1193	1170
7/20/23 15:45	6	1194	1171
7/20/23 15:46	6	1195	1172
7/20/23 15:47	6	1194	1170
7/20/23 15:48	6	1194	1169
7/20/23 15:49	6	1196	1173
7/20/23 15:50	6	1200	1175
7/20/23 15:51	6	1199	1175
7/20/23 15:52	6	1195	1170
7/20/23 15:53	6	1199	1175
7/20/23 15:54	6	1199	1175
7/20/23 15:55	6	1198	1173
7/20/23 15:56	6	1198	1174
7/20/23 15:57	6	1201	1177
7/20/23 15:58	6	1204	1180
7/20/23 15:59	6	1205	1182
7/20/23 16:00	6	1208	1184
7/20/23 16:01	6	1211	1188
7/20/23 16:02	6	1212	1188
7/20/23 16:03	6	1210	1184
7/20/23 16:04	6	1209	1184
7/20/23 16:05	6	1205	1180
7/20/23 16:06	6	1202	1177
7/20/23 16:07	6	1205	1181

Electronic Filing: Received, Clerk's Office 03/15/2024

7/20/23 16:08	6	1207	1182
7/20/23 16:09	6	1209	1183
7/20/23 16:10	6	1216	1190
7/20/23 16:11	6	1214	1189
7/20/23 16:12	6.5	1216	1191
7/20/23 16:13	6.5	1215	1189
7/20/23 16:14	6.5	1211	1186
7/20/23 16:15	6.5	1211	1187
7/20/23 16:16	6.5	1213	1187
7/20/23 16:17	6.5	1214	1190
7/20/23 16:18	6.5	1217	1192
7/20/23 16:19	6.5	1217	1193
7/20/23 16:20	6.5	1212	1187
7/20/23 16:21	6.5	1208	1186
7/20/23 16:22	6.5	1208	1185
7/20/23 16:23	6.5	1213	1189
7/20/23 16:24	6.5	1215	1191
7/20/23 16:25	6.5	1217	1193
7/20/23 16:26	6.5	1220	1197
7/20/23 16:27	6.5	1223	1199
7/20/23 16:28	6.5	1225	1200
7/20/23 16:29	6.5	1225	1199
7/20/23 16:30	6.5	1227	1202
7/20/23 16:31	6.5	1227	1201
7/20/23 16:32	6.5	1231	1205
7/20/23 16:33	6.5	1230	1205
7/20/23 16:34	6.5	1230	1205
7/20/23 16:35	6.5	1232	1208
7/20/23 16:36	6.5	1236	1212
7/20/23 16:37	6.5	1240	1215
7/20/23 16:38	6.5	1240	1215
7/20/23 16:39	6.5	1240	1214
7/20/23 16:40	6.5	1237	1212
7/20/23 16:41	6.5	1238	1214
7/20/23 16:42	6.5	1239	1215
7/20/23 16:43	6.5	1246	1220
7/20/23 16:44	6.5	1251	1226
7/20/23 16:45	6.5	1256	1231
7/20/23 16:46	6.5	1255	1230
7/20/23 16:47	6.5	1254	1228
7/20/23 16:48	6.5	1248	1223
7/20/23 16:49	6.5	1248	1224
7/20/23 16:50	6.5	1253	1230
7/20/23 16:51	6.5	1255	1232
7/20/23 16:52	7	1253	1231
7/20/23 16:53	7	1255	1233
7/20/23 16:54	7	1257	1234
7/20/23 16:55	7	1264	1240

Electronic Filing: Received, Clerk's Office 03/15/2024

7/20/23 16:56	7	1267	1243
7/20/23 16:57	7	1267	1242
7/20/23 16:58	7	1266	1242
7/20/23 16:59	7	1270	1247
7/20/23 17:00	7	1272	1249
7/20/23 17:01	7	1270	1246
7/20/23 17:02	7	1269	1245
7/20/23 17:03	7	1270	1246
7/20/23 17:04	7	1275	1250
7/20/23 17:05	7	1273	1249
7/20/23 17:06	7	1273	1250
7/20/23 17:07	7	1277	1254
7/20/23 17:08	7	1275	1253
7/20/23 17:09	7	1277	1253
7/20/23 17:10	7.5	1275	1251
7/20/23 17:11	7.5	1274	1249
7/20/23 17:12	7.5	1272	1247
7/20/23 17:13	7.5	1278	1255
7/20/23 17:14	7.5	1286	1261
7/20/23 17:15	7.5	1289	1265
7/20/23 17:16	7.5	1294	1271
7/20/23 17:17	7.5	1298	1274
7/20/23 17:18	7.5	1301	1279
7/20/23 17:19	7.5	1297	1273
7/20/23 17:20	7.5	1298	1275
7/20/23 17:21	7.5	1299	1276
7/20/23 17:22	7.5	1301	1279
7/20/23 17:23	7.6	1307	1286
7/20/23 17:24	7.5	1313	1291
7/20/23 17:25	7.5	1310	1287
7/20/23 17:26	7.5	1311	1287
7/20/23 17:27	7.5	1312	1288
7/20/23 17:28	7.5	1312	1287
7/20/23 17:29	7.5	1314	1291
7/20/23 17:30	7.5	1320	1298
7/20/23 17:31	7.5	1321	1298
7/20/23 17:32	7.5	1324	1301
7/20/23 17:33	7.5	1332	1308
7/20/23 17:34	7.5	1329	1304
7/20/23 17:35	7.5	1325	1301
7/20/23 17:36	7.5	1321	1298
7/20/23 17:37	7.5	1319	1296
7/20/23 17:38	7.5	1319	1297
7/20/23 17:39	7.5	1325	1302
7/20/23 17:40	7.5	1332	1309
7/20/23 17:41	7.5	1340	1316
7/20/23 17:42	7.4	1344	1320
7/20/23 17:43	7.5	1345	1322

Electronic Filing: Received, Clerk's Office 03/15/2024

7/20/23 17:44	7.5	1344	1322
7/20/23 17:45	7.5	1346	1323
7/20/23 17:46	7.5	1346	1321
7/20/23 17:47	7.5	1352	1328
7/20/23 17:48	7.5	1356	1333
7/20/23 17:49	7.5	1359	1337
7/20/23 17:50	7.5	1357	1334
7/20/23 17:51	7.5	1358	1334
7/20/23 17:52	7.5	1358	1336
7/20/23 17:53	7.5	1358	1336
7/20/23 17:54	7.5	1360	1338
7/20/23 17:55	7.5	1362	1340
7/20/23 17:56	7.5	1362	1339
7/20/23 17:57	7.5	1362	1339
7/20/23 17:58	7.5	1363	1341
7/20/23 17:59	7.5	1360	1338
7/20/23 18:00	7.5	1361	1338
7/20/23 18:01	7.5	1366	1343
7/20/23 18:02	7.5	1371	1348
7/20/23 18:03	7.5	1374	1351
7/20/23 18:04	7.5	1373	1350
7/20/23 18:05	7.5	1369	1346
7/20/23 18:06	7.5	1368	1347
7/20/23 18:07	7.5	1371	1350
7/20/23 18:08	7.5	1372	1350
7/20/23 18:09	7.5	1372	1350
7/20/23 18:10	7.5	1374	1353
7/20/23 18:11	7.5	1378	1356
7/20/23 18:12	8	1375	1353
7/20/23 18:13	7.9	1377	1355
7/20/23 18:14	8	1378	1357
7/20/23 18:15	8	1381	1360
7/20/23 18:16	8	1385	1364
7/20/23 18:17	8	1385	1365
7/20/23 18:18	8	1388	1367
7/20/23 18:19	7.9	1392	1370
7/20/23 18:20	8	1388	1367
7/20/23 18:21	8	1387	1365
7/20/23 18:22	8	1387	1366
7/20/23 18:23	8	1384	1363
7/20/23 18:24	8.1	1384	1365
7/20/23 18:25	8	1384	1363
7/20/23 18:26	8	1383	1362
7/20/23 18:27	8	1386	1365
7/20/23 18:28	7.9	1391	1370
7/20/23 18:29	8	1400	1379
7/20/23 18:30	8	1405	1383
7/20/23 18:31	8	1411	1390

Electronic Filing: Received, Clerk's Office 03/15/2024

7/20/23 18:32	8	1412	1391
7/20/23 18:33	8	1408	1388
7/20/23 18:34	8	1405	1384
7/20/23 18:35	8.1	1404	1385
7/20/23 18:36	8	1408	1388
7/20/23 18:37	8	1412	1390
7/20/23 18:38	8	1417	1396
7/20/23 18:39	8	1418	1397
7/20/23 18:40	8	1416	1395
7/20/23 18:41	8	1411	1390
7/20/23 18:42	8	1410	1391
7/20/23 18:43	8	1412	1391
7/20/23 18:44	8.5	1418	1397
7/20/23 18:45	8.5	1421	1401
7/20/23 18:46	8.5	1428	1408
7/20/23 18:47	8.5	1429	1408
7/20/23 18:48	8.5	1433	1412
7/20/23 18:49	8.5	1428	1407
7/20/23 18:50	8.5	1426	1406
7/20/23 18:51	8.5	1426	1406
7/20/23 18:52	8.5	1436	1415
7/20/23 18:53	8.6	1435	1414
7/20/23 18:54	8.6	1440	1420
7/20/23 18:55	8.5	1438	1416
7/20/23 18:56	8.5	1441	1420
7/20/23 18:57	8.5	1440	1419
7/20/23 18:58	8.6	1436	1416
7/20/23 18:59	8.5	1440	1421
7/20/23 19:00	8.5	1443	1423
7/20/23 19:01	8.5	1443	1424
7/20/23 19:02	8.5	1450	1430
7/20/23 19:03	8.5	1449	1428
7/20/23 19:04	8.5	1452	1432
7/20/23 19:05	8.5	1449	1431
7/20/23 19:06	9	1450	1430
7/20/23 19:07	9	1456	1436
7/20/23 19:08	9	1460	1439
7/20/23 19:09	9	1462	1441
7/20/23 19:10	9	1461	1441
7/20/23 19:11	9	1461	1442
7/20/23 19:12	9	1462	1444
7/20/23 19:13	8.9	1463	1445
7/20/23 19:14	9	1461	1441
7/20/23 19:15	9	1461	1442
7/20/23 19:16	9	1469	1447
7/20/23 19:17	9	1469	1448
7/20/23 19:18	9	1470	1450
7/20/23 19:19	9	1471	1453

Electronic Filing: Received, Clerk's Office 03/15/2024

7/20/23 19:20	9	1474	1455
7/20/23 19:21	9.1	1474	1454
7/20/23 19:22	9.5	1478	1458
7/20/23 19:23	9.5	1482	1463
7/20/23 19:24	9.5	1482	1464
7/20/23 19:25	9.5	1481	1464
7/20/23 19:26	9.5	1483	1465
7/20/23 19:27	9.5	1485	1466
7/20/23 19:28	9.5	1487	1470
7/20/23 19:29	9.6	1494	1478
7/20/23 19:30	9.5	1505	1487
7/20/23 19:31	9.5	1505	1486
7/20/23 19:32	9.5	1510	1491
7/20/23 19:33	9.5	1512	1492
7/20/23 19:34	9.5	1510	1491
7/20/23 19:35	9.5	1514	1497
7/20/23 19:36	9.5	1520	1503
7/20/23 19:37	9.5	1523	1506
7/20/23 19:38	9.5	1522	1505
7/20/23 19:39	9.5	1530	1513
7/20/23 19:40	10	1535	1517
7/20/23 19:41	10	1538	1520
7/20/23 19:42	10	1539	1520
7/20/23 19:43	10	1533	1514
7/20/23 19:44	10.1	1514	1495
7/20/23 19:45	10	1503	1484
7/20/23 19:46	10	1499	1480
7/20/23 19:47	10.6	1493	1475
7/20/23 19:48	10.5	1492	1473
7/20/23 19:49	10.5	1496	1476
7/20/23 19:50	10.4	1493	1473
7/20/23 19:51	10.5	1490	1470
7/20/23 19:52	10.5	1489	1471
7/20/23 19:53	10.5	1491	1473
7/20/23 19:54	10.5	1490	1472
7/20/23 19:55	10.5	1494	1476
7/20/23 19:56	10.5	1492	1473
7/20/23 19:57	10.6	1495	1477
7/20/23 19:58	10.5	1497	1480
7/20/23 19:59	10.4	1503	1486
7/20/23 20:00	10.5	1512	1495
7/20/23 20:01	10.6	1517	1501
7/20/23 20:02	10.4	1517	1500
7/20/23 20:03	10.5	1519	1501
7/20/23 20:04	10.5	1518	1501
7/20/23 20:05	10.5	1518	1502
7/20/23 20:06	10.5	1516	1499
7/20/23 20:07	10.5	1521	1504

Electronic Filing: Received, Clerk's Office 03/15/2024

7/20/23 20:08	10.5	1524	1506
7/20/23 20:09	10.5	1526	1509
7/20/23 20:10	10.5	1535	1519
7/20/23 20:11	10.4	1536	1518
7/20/23 20:12	11	1536	1519
7/20/23 20:13	11	1534	1516
7/20/23 20:14	11	1530	1513
7/20/23 20:15	11.1	1534	1517
7/20/23 20:16	11	1536	1518
7/20/23 20:17	11	1540	1522
7/20/23 20:18	11	1547	1529
7/20/23 20:19	11.5	1553	1534
7/20/23 20:20	11.6	1557	1538
7/20/23 20:21	11.5	1563	1542
7/20/23 20:22	11.5	1567	1547
7/20/23 20:23	11.6	1566	1547
7/20/23 20:24	11.5	1568	1549
7/20/23 20:25	11.5	1568	1550
7/20/23 20:26	11.5	1566	1547
7/20/23 20:27	11.5	1564	1545
7/20/23 20:28	11.5	1563	1545
7/20/23 20:29	11.5	1562	1543
7/20/23 20:30	11.5	1562	1545
7/20/23 20:31	11.6	1560	1542
7/20/23 20:32	11.5	1561	1543
7/20/23 20:33	11.5	1559	1542
7/20/23 20:34	11.5	1565	1547
7/20/23 20:35	11.5	1568	1550
7/20/23 20:36	11.5	1569	1552
7/20/23 20:37	11.5	1571	1555
7/20/23 20:38	12.4	1579	1563
7/20/23 20:39	12.5	1577	1561
7/20/23 20:40	12.5	1578	1561
7/20/23 20:41	12.5	1583	1568
7/20/23 20:42	12.6	1592	1577
7/20/23 20:43	12.5	1592	1576
7/20/23 20:44	12.5	1594	1577
7/20/23 20:45	12.5	1592	1575
7/20/23 20:46	12.4	1590	1573
7/20/23 20:47	12.6	1590	1572
7/20/23 20:48	12.5	1593	1576
7/20/23 20:49	12.5	1599	1583
7/20/23 20:50	12.5	1599	1582
7/20/23 20:51	12.4	1595	1579
7/20/23 20:52	12.5	1598	1581
7/20/23 20:53	12.5	1608	1593
7/20/23 20:54	12.6	1613	1596
7/20/23 20:55	12.5	1618	1602

Electronic Filing: Received, Clerk's Office 03/15/2024

7/20/23 20:56	12.5	1629	1614
7/20/23 20:57	12.5	1628	1614
7/20/23 20:58	12.5	1625	1610
7/20/23 20:59	12.5	1629	1614
7/20/23 21:00	12.5	1631	1615
7/20/23 21:01	12.5	1628	1612
7/20/23 21:02	12.6	1634	1618
7/20/23 21:03	12.5	1636	1619
7/20/23 21:04	12.4	1637	1622
7/20/23 21:05	12.5	1642	1626
7/20/23 21:06	12.5	1648	1633
7/20/23 21:07	12.5	1653	1638
7/20/23 21:08	12.5	1656	1640
7/20/23 21:09	12.5	1660	1643
7/20/23 21:10	12.5	1666	1650
7/20/23 21:11	12.6	1665	1649
7/20/23 21:12	12.5	1670	1654
7/20/23 21:13	12.5	1669	1652
7/20/23 21:14	12.5	1667	1653
7/20/23 21:15	12.5	1669	1654
7/20/23 21:16	12.4	1672	1656
7/20/23 21:17	12.6	1675	1660
7/20/23 21:18	12.5	1677	1663
7/20/23 21:19	12.5	1680	1666
7/20/23 21:20	12.5	1685	1670
7/20/23 21:21	12.4	1688	1674
7/20/23 21:22	12.6	1692	1677
7/20/23 21:23	12.5	1690	1675
7/20/23 21:24	12.5	1686	1672
7/20/23 21:25	12.5	1689	1674
7/20/23 21:26	12.4	1688	1672
7/20/23 21:27	12.5	1687	1672
7/20/23 21:28	12.5	1691	1675
7/20/23 21:29	12.5	1690	1675
7/20/23 21:30	12.5	1692	1676
7/20/23 21:31	12.5	1692	1678
7/20/23 21:32	12.6	1693	1678
7/20/23 21:33	12.5	1696	1681
7/20/23 21:34	12.5	1697	1682
7/20/23 21:35	12.5	1699	1684
7/20/23 21:36	12.4	1697	1682
7/20/23 21:37	12.5	1701	1687
7/20/23 21:38	12.5	1707	1694
7/20/23 21:39	12.5	1715	1700
7/20/23 21:40	12.6	1715	1700
7/20/23 21:41	13.5	1712	1697
7/20/23 21:42	13.6	1708	1694
7/20/23 21:43	13.6	1708	1693

Electronic Filing: Received, Clerk's Office 03/15/2024

7/20/23 21:44	13.5	1707	1694
7/20/23 21:45	13.5	1706	1693
7/20/23 21:46	13.5	1709	1694
7/20/23 21:47	13.4	1711	1697
7/20/23 21:48	13.5	1712	1698
7/20/23 21:49	13.5	1708	1693
7/20/23 21:50	13.6	1706	1691
7/20/23 21:51	13.5	1706	1692
7/20/23 21:52	13.5	1710	1696
7/20/23 21:53	13.5	1714	1700
7/20/23 21:54	13.6	1717	1704
7/20/23 21:55	13.5	1726	1712
7/20/23 21:56	13.5	1730	1716
7/20/23 21:57	13.5	1735	1722
7/20/23 21:58	13.5	1739	1725
7/20/23 21:59	13.5	1738	1725
7/20/23 22:00	13.5	1733	1720
7/20/23 22:01	13.5	1732	1719
7/20/23 22:02	13.5	1735	1721
7/20/23 22:03	13.5	1738	1724
7/20/23 22:04	13.4	1740	1726
7/20/23 22:05	13.4	1741	1728
7/20/23 22:06	13.5	1738	1725
7/20/23 22:07	13.5	1741	1728
7/20/23 22:08	14.5	1743	1730
7/20/23 22:09	14.5	1740	1726
7/20/23 22:10	14.5	1738	1725
7/20/23 22:11	14.5	1742	1728
7/20/23 22:12	14.5	1746	1732
7/20/23 22:13	14.4	1751	1738
7/20/23 22:14	14.4	1754	1739
7/20/23 22:15	14.5	1756	1742
7/20/23 22:16	14.5	1760	1746
7/20/23 22:17	14.6	1769	1756
7/20/23 22:18	14.5	1769	1755
7/20/23 22:19	14.5	1762	1749
7/20/23 22:20	15.5	1762	1748
7/20/23 22:21	15.5	1762	1748
7/20/23 22:22	15.4	1763	1750
7/20/23 22:23	15.5	1767	1753
7/20/23 22:24	15.5	1770	1757
7/20/23 22:25	15.4	1768	1755
7/20/23 22:26	15.5	1767	1754
7/20/23 22:27	15.5	1772	1759
7/20/23 22:28	15.5	1770	1757
7/20/23 22:29	16.5	1770	1758
7/20/23 22:30	16.5	1775	1763
7/20/23 22:31	16.5	1773	1760

Electronic Filing: Received, Clerk's Office 03/15/2024

7/20/23 22:32	16.6	1776	1762
7/20/23 22:33	16.5	1781	1769
7/20/23 22:34	16.6	1779	1767
7/20/23 22:35	16.4	1783	1771
7/20/23 22:36	16.5	1789	1776
7/20/23 22:37	16.5	1793	1781
7/20/23 22:38	16.5	1795	1783
7/20/23 22:39	16.6	1797	1784
7/20/23 22:40	16.5	1795	1782
7/20/23 22:41	16.5	1793	1781
7/20/23 22:42	16.5	1793	1781
7/20/23 22:43	16.5	1794	1782
7/20/23 22:44	16.5	1798	1786
7/20/23 22:45	16.5	1804	1792
7/20/23 22:46	16.6	1809	1797
7/20/23 22:47	16.5	1812	1800
7/20/23 22:48	16.5	1811	1800
7/20/23 22:49	16.7	1814	1803
7/20/23 22:50	16.4	1816	1804
7/20/23 22:51	16.5	1820	1809
7/20/23 22:52	16.4	1822	1811
7/20/23 22:53	16.6	1824	1814
7/20/23 22:54	16.4	1828	1817
7/20/23 22:55	16.5	1832	1822
7/20/23 22:56	16.4	1837	1827
7/20/23 22:57	16.4	1837	1828
7/20/23 22:58	16.5	1845	1835
7/20/23 22:59	16.5	1848	1837
7/20/23 23:00	16.6	1848	1837
7/20/23 23:01	16.5	1854	1844
7/20/23 23:02	16.5	1854	1843
7/20/23 23:03	16.7	1857	1847
7/20/23 23:04	16.5	1856	1846
7/20/23 23:05	16.5	1856	1846
7/20/23 23:06	16.4	1859	1850
7/20/23 23:07	16.6	1876	1868
7/20/23 23:08	16.5	1902	1894
7/20/23 23:09	16.4	1916	1908
7/20/23 23:10	16.6	1922	1915
7/20/23 23:11	16.5	1925	1918
7/20/23 23:12	16.5	1922	1914
7/20/23 23:13	16.5	1921	1915
7/20/23 23:14	16.6	1922	1916
7/20/23 23:15	16.5	1923	1916
7/20/23 23:16	16.4	1922	1915
7/20/23 23:17	16.6	1927	1920
7/20/23 23:18	16.5	1931	1924
7/20/23 23:19	16.6	1933	1926

Electronic Filing: Received, Clerk's Office 03/15/2024

7/20/23 23:20	16.3	1937	1931
7/20/23 23:21	16.5	1937	1930
7/20/23 23:22	16.5	1940	1935
7/20/23 23:23	16.5	1948	1942
7/20/23 23:24	16.5	1952	1945
7/20/23 23:25	16.5	1952	1946
7/20/23 23:26	16.6	1956	1952
7/20/23 23:27	16.5	1958	1953
7/20/23 23:28	16.5	1966	1960
7/20/23 23:29	16.5	1974	1970
7/20/23 23:30	16.5	1978	1974
7/20/23 23:31	16.5	1977	1973
7/20/23 23:32	16.5	1979	1975
7/20/23 23:33	17.5	1972	1967
7/20/23 23:34	17.5	1932	1925
7/20/23 23:35	17.6	1908	1901
7/20/23 23:36	17.4	1906	1899
7/20/23 23:37	17.5	1907	1900
7/20/23 23:38	17.5	1908	1900
7/20/23 23:39	17.5	1910	1903
7/20/23 23:40	17.5	1905	1898
7/20/23 23:41	17.6	1906	1900
7/20/23 23:42	17.5	1909	1902
7/20/23 23:43	17.5	1915	1908
7/20/23 23:44	17.4	1923	1914
7/20/23 23:45	17.5	1912	1903
7/20/23 23:46	17.4	1906	1898
7/20/23 23:47	17.5	1907	1899
7/20/23 23:48	17.5	1906	1898
7/20/23 23:49	17.5	1904	1897
7/20/23 23:50	17.5	1903	1894
7/20/23 23:51	17.5	1904	1896
7/20/23 23:52	17.4	1904	1896
7/20/23 23:53	17.5	1905	1896
7/20/23 23:54	17.5	1907	1900
7/20/23 23:55	17.5	1912	1904
7/20/23 23:56	17.5	1911	1903
7/20/23 23:57	17.6	1912	1903
7/20/23 23:58	17.5	1918	1912
7/20/23 23:59	17.5	1931	1924
7/21/23 0:00	17.5	1923	1916
7/21/23 0:01	17.5	1919	1912
7/21/23 0:02	17.5	1911	1903
7/21/23 0:03	17.6	1913	1905
7/21/23 0:04	17.5	1909	1900
7/21/23 0:05	17.5	1907	1899
7/21/23 0:06	17.4	1903	1895
7/21/23 0:07	17.6	1905	1897

Electronic Filing: Received, Clerk's Office 03/15/2024

7/21/23 0:08	17.5	1907	1899
7/21/23 0:09	17.6	1902	1894
7/21/23 0:10	17.4	1900	1891
7/21/23 0:11	17.6	1900	1891
7/21/23 0:12	17.5	1899	1891
7/21/23 0:13	17.6	1901	1893
7/21/23 0:14	17.4	1897	1888
7/21/23 0:15	17.6	1896	1887
7/21/23 0:16	17.5	1893	1885
7/21/23 0:17	17.5	1892	1884
7/21/23 0:18	17.4	1893	1885
7/21/23 0:19	17.6	1893	1885
7/21/23 0:20	17.6	1891	1882
7/21/23 0:21	17.6	1890	1880
7/21/23 0:22	17.4	1890	1880
7/21/23 0:23	17.6	1887	1878
7/21/23 0:24	17.5	1885	1876
7/21/23 0:25	17.5	1883	1874
7/21/23 0:26	17.5	1876	1867
7/21/23 0:27	17.6	1870	1861
7/21/23 0:28	17.6	1872	1863
7/21/23 0:29	17.6	1873	1864
7/21/23 0:30	17.3	1869	1860
7/21/23 0:31	17.6	1868	1858
7/21/23 0:32	17.5	1865	1856
7/21/23 0:33	17.6	1864	1854
7/21/23 0:34	17.4	1864	1854
7/21/23 0:35	17.6	1859	1849
7/21/23 0:36	17.5	1860	1851
7/21/23 0:37	17.6	1859	1848
7/21/23 0:38	17.3	1858	1848
7/21/23 0:39	17.6	1856	1846
7/21/23 0:40	17.5	1857	1847
7/21/23 0:41	17.6	1857	1848
7/21/23 0:42	17.5	1855	1846
7/21/23 0:43	17.5	1856	1846
7/21/23 0:44	17.5	1852	1841
7/21/23 0:45	17.5	1851	1842
7/21/23 0:46	17.3	1852	1842
7/21/23 0:47	17.6	1854	1845
7/21/23 0:48	17.6	1854	1844
7/21/23 0:49	17.5	1850	1839
7/21/23 0:50	17.4	1850	1839
7/21/23 0:51	18.5	1856	1846
7/21/23 0:52	18.4	1859	1850
7/21/23 0:53	18.4	1856	1847
7/21/23 0:54	18.5	1853	1843
7/21/23 0:55	18.5	1853	1843

Electronic Filing: Received, Clerk's Office 03/15/2024

7/21/23 0:56	18.5	1856	1847
7/21/23 0:57	18.5	1856	1847
7/21/23 0:58	18.4	1854	1845
7/21/23 0:59	18.4	1853	1845
7/21/23 1:00	18.4	1851	1842

BEFORE THE ILLINOIS POLLUTION CONTROL BOARD

IN THE MATTER OF:)	
)	R 23-18(A)
AMENDMENTS TO 35 ILL. ADM. CODE)	
201, 202, AND 212)	(Rulemaking – Air)
)	
)	

CERTIFICATE OF SERVICE

I, the undersigned, certify that on this 15th day of March, 2024, I have electronically served a true and correct copy of **Second Pre-Filed Testimony of Bryan Higgins** by electronically filing with the Clerk of the Illinois Pollution Control Board and by e-mail upon the persons identified on the attached Service List.

My e-mail address is Alex.Garel-Frantzen@afslaw.com.

The number of pages in the e-mail transmission is 214.

The e-mail transmission took place before 5:00 p.m.

/s/ Alexander J. Garel-Frantzen

Alexander J. Garel-Frantzen

Dated: March 15, 2024

David M. Loring
Alexander J. Garel-Frantzen
ArentFox Schiff LLP, Attorneys for Rain CII Carbon LLC
233 S. Wacker Drive Suite 7100
Chicago, Illinois 60606
(312) 258-5521
David.Loring@afslaw.com
Alex.Garel-Frantzen@afslaw.com

AFDOCS:199710198.1