



CITY WATER, LIGHT AND POWER  
CITY OF SPRINGFIELD, ILLINOIS

MISTY BUSCHER, MAYOR  
DOUG BROWN, CHIEF UTILITY ENGINEER

VIA E-MAIL: [dierich.andrea@epa.gov](mailto:dierich.andrea@epa.gov)

September 23, 2025

Andrea Dierich  
EPA Project Officer  
US EPA, Region 5  
77 W Jackson Blvd  
Chicago, IL 60604

RE: CCR Surface Impoundments  
Revised Closure and Post-Closure Plans

Dear Ms. Dierich:

Provided herein are the revised Closure and Post-Closure Plans for the CCR Surface Impoundments. CWLP agreed to revise the 2016 Closure and Post-Closure Plans in accordance with paragraph 275 and Attachment 3 of the Consent Agreement and Final Order (CAFO) effective January 14, 2025.

Should you have any questions or require additional information, please contact me at 217-757-8610 ext. 1110.

Sincerely,


A handwritten signature in blue ink, appearing to be "PJ Becker", written in a cursive style.

PJ Becker  
Environmental Health and Safety Manager

**Certification of City Water, Light and Power**

City of Springfield, Office of Public Utilities, d/b/a City Water, Light and Power provides the following certification as required by paragraph 300 of the Consent Agreement and Final Order effective January 14, 2025.

I certify under penalty of law that this document and all attachments were prepared under my direction or supervision in accordance with a system designed to assure that qualified personnel properly gather and evaluate the information submitted. Based on my inquiry of the person or persons who manage the system, or those persons directly responsible for gathering the information, the information submitted is, to the best of my knowledge and belief, true, accurate, and complete. I have no personal knowledge that the information submitted is other than true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment for knowing violations.

Signature:   
Name: PJ Becker  
Title: Environmental Health and Safety Manager  
Date: 9/23/2025

Dallman and Lakeside Ash Ponds  
**Closure Plan**  
City Water, Light and Power  
Springfield, Sangamon County, Illinois

September 23, 2025

## Table of Contents

<b>1. Responses to Attachment 3 Items.....</b>	<b>1</b>
1.1 Closure Plan .....	1
1.1.1 A narrative describing how the unit will be closed and covered (40 CFR §257.102(b) and (d)). .....	1
1.1.2 Lake Springfield, Lakeside Ash Pond, and Clarification Pond affect groundwater after closure. ....	1
1.1.3 Detailed information included in all construction drawings. ....	1
1.1.4 A liquid migration assessment (horizontal and vertical) after final cover installation. ....	1
1.1.5 A design sufficient to withstand a 1,000-year flood event. ....	1
1.1.6 A discussion of the permeability of the final cover system. ....	2
1.1.7 A demonstration that there will not be sloughing or movement of the final cover system. ....	2
1.1.8 A closure schedule that describes the sequential steps that will be taken to close the unit. ....	2
1.1.9 A description of all methods for removing free liquids. ....	2
1.1.10 A description of how the wastes and materials remaining in the units will be stabilized. ....	2
1.1.11 Supporting calculations and information that the final cover system will be designed and constructed consistent with recognized and generally accepted good engineering practices. For example, the plan should include, when appropriate:.....	2
1.1.11.1 Supporting calculations and information that the final cover system will be designed and constructed consistent with recognized and generally accepted good engineering practices. ....	2
1.1.11.2 Geotechnical information demonstrating that the final cover system will not reduce slope stability.....	2
1.1.11.3 Information regarding the potential settlement of CCR.....	2
1.1.11.4 Drawings and cross sections showing the vertical and horizontal extent of CCR. ....	2
1.1.11.5 Drawings and cross sections showing the extent of the protective soil layer necessary to support vegetation.....	2
1.1.11.6 Calculations demonstrating that the geocomposite drainage layer can effectively transmit liquid off the geomembrane.....	3
1.1.11.7 Calculations demonstrating that the perimeter drainage ditches can provide adequate capacity.....	3
1.1.11.8 Calculations supporting the size of any culverts used to support drainage.....	3
1.1.11.9 Provide for a Construction Quality Assurance Plan. ....	3
1.1.11.9.a Trial seams tested for peel strength and shear strength via ASTM D 6392. ....	3
1.1.11.9.b Non-destructive field seam continuity testing via ASTM D 5641 or ASTM D 5820. ....	3
1.1.11.9.c An organized, grid-based visual survey for geomembrane penetrations. ....	3
1.1.11.9.d Manufacturer requirements as needed to meet the manufacturer’s warranty. ....	3
1.1.11.9.e A log to document where each test occurred. ....	3
<b>2. Introduction.....</b>	<b>4</b>
2.1 Regulatory Requirements.....	4
<b>3. Site Background .....</b>	<b>4</b>
3.1 Lakeside Ash Pond .....	4
3.2 Dallman Ash Pond.....	4
3.3 Clarification Pond.....	6
<b>4. Closure of the CWLP Surface Impoundments.....</b>	<b>6</b>

---

4.1 Introduction .....	6
4.2 Lakeside Ash Pond Closure .....	6
4.3 Dallman Ash Pond Closure .....	10
4.3.1 Alternative Final Cover System .....	10
4.3.2 Closure Process.....	11
4.3.3 Post-Closure Groundwater .....	13
<b>5. Construction Quality Assurance Plan.....</b>	<b>14</b>
5.1 Introduction.....	14
5.2 Responsibility and Authority of Project Personnel .....	14
5.2.1 Owner .....	16
5.2.2 Design Engineer .....	16
5.2.3 CQA Personnel .....	16
5.2.3.1 Key Personnel (Owner’s Representative) .....	16
5.2.3.2 Document Control .....	18
5.2.4 Testing and Monitoring Firms .....	18
5.2.4.1 Soil/Concrete Testing (Lab and Field) .....	18
5.2.4.2 Surveyor .....	18
5.2.4.3 Geosynthetics Monitor and Geosynthetics Testing Laboratory .....	19
5.2.5 Contractors, Suppliers and Installers.....	19
5.3 Project Meetings .....	19
5.3.1 Preconstruction Meetings .....	19
5.3.2 Progress Meetings .....	20
5.3.3 Problem or Work Deficiency Meetings.....	20
5.4 In-Progress Acceptance of Work.....	21
5.4.1 Introduction .....	21
5.4.2 Elements of Work Requiring Prior Acceptance.....	21
5.5 Sampling and Testing Requirements .....	21
5.5.1 Introduction .....	21
5.5.2 Soils.....	22
5.5.2.1 Foundations and Berms .....	22
5.5.3 Geosynthetics.....	23
5.5.3.1 Geomembrane .....	23
5.5.3.1.a Prequalification Testing .....	23
5.5.3.1.b Installer Certification of Placement Surface.....	23
5.5.3.1.c Placement Testing for Seam Overlap .....	23
5.5.3.1.d Placement Non-Destructive Testing .....	23
5.5.3.1.e Pre-Placement Destructive Testing .....	25
5.5.3.1.f Grid-Based Visual Inspection.....	27
5.5.3.2 Geotextile .....	27
5.5.3.2.a Prequalification Testing.....	27
5.5.3.2.b Installer Certification of Placement Surface .....	27
5.5.3.2.c Deployment .....	28
5.5.3.3 Synthetic Turf .....	28
5.5.3.3.a Prequalification Testing.....	28
5.5.3.3.b Installer Certification of Placement Surface .....	29
5.5.3.3.c Deployment .....	29

---

5.5.4 Drainage Media .....29

    5.5.4.1 Coarse Aggregate .....29

        5.5.4.1.a Prequalification Testing ..... 29

        5.5.4.1.b Material Placement ..... 29

        5.5.4.1.c Certification of Work ..... 30

    5.5.4.2 Specified Aggregate Infill .....30

        5.5.4.2.a Prequalification Testing..... 30

        5.5.4.2.b Material Placement..... 30

        5.5.4.2.c Certification of Work ..... 30

5.5.5 Other Material Placement Testing .....30

    5.5.5.1 Placement Testing of Dewatering System Piping System.....30

    5.5.5.2 Placement Testing of Surface Water Management System..... 31

    5.5.5.3 Placement Testing of Concrete ..... 31

5.6 Corrective Measures..... 31

5.7 Documentation Of Sampling, Inspections and Testing..... 31

    5.7.1 Daily Summary Reports ..... 31

    5.7.2 Daily Inspection Reports..... 31

    5.7.3 Photographs .....32

5.8 Acceptance Report .....32

5.9 Construction Management Activities .....32

    5.9.1 Requests for Information (RFIs).....32

    5.9.2 Review of Contractor Submittals.....32

    5.9.3 Field Change Order Process .....33

5.10 Document Control and Project Records .....33

    5.10.1 CQA Plan .....33

    5.10.2 Project Records .....34

**6. References .....36**

**Appendices**

- Appendix A ClosureTurf® Documentation
- Appendix B Final Cover HELP Model Results
  - Appendix B.1 40 CFR 257.102(d) Final Cover HELP Model Results
  - Appendix B.2 ClosureTurf® Final Cover HELP Model Results
- Appendix C CQA Plan Table C.1
- Appendix D 1,000-year Storm Drainage Calculations
- Appendix E Settlement and Slope Stability Calculations
- Appendix F Closure Plan Drawings and Sections

**Figures and Tables**

**Figures**

Figure 1. Site Location Map .....5

Figure 2. Closure Schedule for Lakeside and Dallman Ash Ponds..... 7

Figure 3. Dallman Dewatering Well Location Map ..... 12

Figure 4. Project Organization Chart ..... 15

Figure 5. Control of CQA Documents and Samples..... 35

**Tables**

Table 1. Physical Properties of LAP CCR.....6  
Table 2. Physical Properties of DAP CCR ..... 11  
Table 3. Lower Cohesive Unit Permeability Results..... 13  
Table 4. Installer Certifications for Acceptance of Work ..... 21  
Table 5. Geomembrane Destructive Seam Tests and Frequency .....26

*Copyright ©2025 by Hanson Professional Services Inc. All rights reserved. This document is intended solely for the individual or the entity to which it is addressed. The information contained in this document shall not be duplicated, stored electronically, or distributed, in whole or in part, by anyone other than the recipient without the express written permission of Hanson Professional Services Inc., 1525 S. Sixth St., Springfield, IL 62703, (217) 788-2450, www.hanson-inc.com. Unauthorized reproduction or transmission of any part of this document is a violation of federal law. Any concepts, designs and project approaches contained herein are considered proprietary. Any use of these concepts and approaches by others is considered a violation of copyright law.*