

ILLINOIS POLLUTION CONTROL BOARD
November 4, 1993

CALUMET PARK CITGO,)
)
 Petitioner,)
)
 v.) PCB 93-209
) (Provisional Variance)
 ILLINOIS ENVIRONMENTAL)
 PROTECTION AGENCY,)
)
 Respondent.)

ORDER OF THE BOARD (by C. A. Manning):

Pursuant to Section 35(b) of the Environmental Protection Act (Act) (415 ILCS 5/35(b)), Calumet Park Citgo has requested that the Illinois Environmental Protection Agency (Agency) recommend that the Board grant a provisional variance to allow Calumet Park Citgo's gasoline dispensing operations (service station) to continue operating even though it will not have installed operational vapor recovery equipment by November 1, 1993. Such request for a provisional variance and the Notification of Recommendation was filed with the Board by the Agency on Tuesday, November 2, 1993. Pursuant to Section 35(b) of the Act, the Board must issue the variance within two (2) days of this filing.

Specifically, the Agency recommends that we grant Calumet Park Citgo a forty-five (45)-day provisional variance for its facility located in Cook County in the Chicago metropolitan statistical area from the Stage II vapor recovery requirements, as set forth in 35 Ill. Adm. Code 218.586, for the period beginning November 1, 1993, and continuing for forty-five (45) days or until the required vapor recovery equipment is installed, whichever comes first.

The Agency's provisional variance recommendation states that Calumet Park Citgo has requested a provisional variance on behalf of its service station in the Chicago area, located as follows:

<u>County</u>	<u>City or Village</u>	<u>Street Address</u>
Cook	Calumet Park	1336 West 127th Street

Upon receipt of the request, the Agency issued its recommendation, notifying the Board that the failure to grant the requested forty-five (45)-day provisional variance would impose an arbitrary or unreasonable hardship on Petitioner. The Agency recommendation states that installation of Stage II vapor recovery equipment at the Calumet Park Citgo facility is not possible by the November 1, 1993 deadline for compliance because Tokheim is in the last stages of CARB approval for vacuum assist

vapor recovery equipment for its gasoline dispensers, and that equipment will not be available before the compliance deadline.

Provisional variances are by their very nature temporary. The responsibilities of the Agency and the Board in these short-term provisional variances are different from the responsibilities in standard variances. (See 415 ILCS 5/35(b) & (c)). In provisional variances it is the responsibility of the Agency to make the technical determinations and finding of arbitrary or unreasonable hardship. The Board's responsibility is to adopt a formal Order, to assure the formal maintenance of the record, to assure the enforceability of the variance, and to provide notification of the action by a press release.


Having received the Agency recommendation notifying the Board that a denial of the requested relief would impose an arbitrary or unreasonable hardship, the Board hereby grants Petitioner a provisional variance from 35 Ill. Adm. Code 218.586, subject to the following conditions:

1. The term of this provisional variance shall commence on November 1, 1993, and it shall expire on the date the Petitioner completes the required installation of vacuum assist Stage II vapor recovery equipment, or after forty-five (45) days have elapsed, whichever comes first;
2. The Petitioner shall notify the Agency of the installation of the vapor recovery equipment, by sending notification addressed as follows:

Mr. Terry Sweitzer, P.E.
 Manager, Air Monitoring Section
 Illinois Environmental Protection Agency
 Division of Air Pollution Control
 P.O. Box 19276
 Springfield, Illinois 62794-9276

IT IS SO ORDERED.

I, Dorothy M. Gunn, Clerk of the Illinois Pollution Control Board, do hereby certify that the above order was adopted on the 4th day of November, 1993, by a vote of 6-0.


 Dorothy M. Gunn, Clerk
 Illinois Pollution Control Board