

ILLINOIS POLLUTION CONTROL BOARD  
July 23, 1981

COMMONWEALTH EDISON COMPANY, )  
 )  
 ) Petitioner, )  
 )  
 ) v. ) PCB 81-34  
 )  
 )  
 ) ILLINOIS ENVIRONMENTAL )  
 ) PROTECTION AGENCY, )  
 )  
 ) Respondent. )

ORDER OF THE BOARD (by I. Goodman):

Upon the motion for reconsideration of the Illinois Environmental Protection Agency (Agency) the Board hereby amends its Order of July 10, 1981 to vacate conditions 1 and 2 of the Order.

Condition 1 shall read as follows:

1. During the term of this variance Commonwealth Edison Company shall comply with the following thermal effluent standards: The water temperatures at representative locations in the Main River shall not exceed the following maximum limitations during more than 4% of the hours in 12-month periods ending with any month. Moreover, at no time shall the water temperatures at such locations exceed the following maximum limitations by more than 5°F.

January and February, 60°F; March, 70°F;  
April, 77°F; May, 85°F; June, July, August,  
September, and October, 90°F; November, 76°F;  
and December, 70°F.

Condition 2 shall read as follows:

2. Commonwealth Edison Company shall participate in any regulatory proceeding relating to the thermal standards in that portion of the Illinois River affected by its discharge from the Joliet Station during the term of this variance.

IT IS SO ORDERED.

I, Christan L. Moffett, Clerk of the Illinois Pollution Control Board, hereby certify that the above Order was adopted on the 23<sup>rd</sup> day of July, 1981 by a vote of 5-0.

*Christan L. Moffett*  
Christan L. Moffett, Clerk  
Illinois Pollution Control Board