

ILLINOIS POLLUTION CONTROL BOARD  
May 31, 1973

ANNA STATE HOSPITAL

v.

ENVIRONMENTAL PROTECTION AGENCY

PCB 73-129

ORDER OF THE BOARD (by Mr. Dumelle)

Variance is granted from Rule 203(f) of the Water Pollution Regulations to permit copper levels in excess of 0.02 mg/l subject to the following conditions;

1. Treatment with copper sulfate shall be limited to one per month for the months of June through and including October, 1973.
2. Dosage with copper sulfate shall not exceed 500 lbs. per treatment.
3. Copper concentrations at the raw water intake to the water treatment plant shall never exceed 1.0 mg/l.
4. Copper concentrations in the reservoir shall be measured immediately prior to and after each copper sulfate treatment and the results submitted to the Agency on a monthly basis.

IT IS SO ORDERED.

I, Christan L. Moffett, Clerk of the Illinois Pollution Control Board, hereby certify the above Order was adopted on the 31<sup>st</sup> day of May, 1973 by a vote of 4-0.

  
Christan L. Moffett, Clerk  
Illinois Pollution Control Board