

ILLINOIS POLLUTION CONTROL BOARD
June 28, 1973

VILLAGE OF SHIPMAN)
)
)
 v.) PCB 73-259
)
)
 ENVIRONMENTAL PROTECTION AGENCY)
)

INTERIM ORDER OF THE BOARD (by Mr. Dumelle)

The petition filed June 25, 1973 with the Board is inadequate since it does not give the frequency of dosage nor does it discuss the alternative of using biodegradable algicides. Further, the resulting copper concentration is given as 2.2 ppm which is far in excess of the 1.0 mg/l maximum set by the U.S. Public Health Service Drinking Water Standards.

Petition is given 30 days in which to file an amended petition. Waiver of the 90 day decision period for the portion of time elapsed until the new filing is made is required. Failure to do the above shall subject the petition to dismissal for inadequacy.

IT IS SO ORDERED.

I, Christan L. Moffett, Clerk of the Illinois Pollution Control Board, hereby certify the above Interim Order was adopted on the _____ day of June, 1973 by a vote of _____.

Christan L. Moffett, Clerk
Illinois Pollution Control Board