## ILLINOIS POLLUTION CONTROL BOARD July 26, 1973

VILLAGE OF AVON	)	
V •	) ) )	PCB 73-256
ENVIRONMENTAL PROTECTION AGENCY	)	

OPINION OF THE BOARD (by Mr. Dumelle)

Variance is granted from Rule 203(f) of the Water Pollution Regulations to permit exceeding the water quality standard for copper of 0.02 mg/l when dosing with copper sulfate for algae control in the water supply reservoir.

The variance is subject to the following conditions:

- 1. Copper sulfate treatments are limited to one each for the months of July through and including October 1973.
- 2. The dosage shall not exceed 200 lbs. per treatment of copper sulfate.
- 3. The copper concentration at the raw water intake to the treatment plant shall never exceed 1.0 mg/1.
- 4. The copper concentrations in the reservoir be measured immediately prior to and after each treatment and the results submitted to the Agency on a monthly basis.

IT IS SO ORDERED.

I, Christan L. Moffett, Clerk of the Illinois Pollution Control Board, hereby certify the above Opinion was adopted on the day of July, 1973 by a vote of

Christan L. Moffett, Clerk Illinois Pollution Control Board