### POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

- 1) <u>Heading of the Part</u>: Primary Drinking Water Standards
- 2) <u>Code Citation</u>: 35 Ill. Adm. Code 611

3)

Section Numbers:	Proposed action:
611.102	Amendment
611.300	Amendment
611.301	Amendment
611.311	Amendment
611.330	Amendment
611.359	Amendment
611.382	Amendment
611.600	Amendment
611.603	Amendment
611.609	Amendment
611.611	Amendment
611.612	Amendment
611.641	Amendment
611.645	Amendment
611.646	Amendment
611.648	Amendment
611.720	Amendment
611.731	Amendment
611.732	Amendment
611.884	Amendment
611.920	Amendment
611.923	Amendment
611.970	Amendment
611.974	Amendment
611.1001	Amendment
611.1004	Amendment
611.1012	Amendment
611.1013	Amendment
611.1014	Amendment
611.APPENDIX A	Amendment
611.APPENDIX B	Amendment
611.APPENDIX C	Amendment
611.APPENDIX D	Amendment
611.APPENDIX E	Amendment
611.APPENDIX G	Amendment



NOV 1 3 2012 STATE OF ILLINUIS

STATE OF ILLINOIS Pollution Control Board

R13-2-

<u>1</u> 12

### ILLINOIS REGISTER

### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

611.APPENDIX H 611.APPENDIX I	Amendment Amendment
611.TABLE A	Amendment
611.TABLE B	Amendment
611.TABLE C	Amendment
611.TABLE D	Amendment
611.TABLE E	Amendment
611.TABLE F	Amendment
611.TABLE G	Amendment
611.TABLE H	Amendment
611.TABLE I	Amendment
611.TABLE J	Amendment
611.TABLE Z	Amendment

- 4) <u>Statutory Authority:</u> 415 ILCS 5/7.2, 17, 17.5, and 27
- 5) <u>A Complete Description of the Subjects and Issues Involved:</u> The following briefly describes the subjects and issues involved in the docket R13-2 rulemaking. A comprehensive description is contained in the Board's opinion and order of October 18, 2012, proposing amendments in docket R13-2, which opinion and order is available from the address below.

This proceeding updates the Illinois Safe Drinking Water Act (SDWA) rules to correspond with amendments adopted by the United States Environmental Protection Agency (USEPA) that appeared in the Federal Register during a single update period. The docket and time period that is involved in this proceeding is the following:

R13-2 Federal SDWA amendments that occurred during the period January 1, 2012 through June 30, 2012.

The docket R13-2 amends rules in Parts 611S. The amendments to the various Parts are inter-related. The following table briefly summarizes the federal actions in the update period:

May 2, 2012	USEPA adopted the third installment of the
(77 Fed. Reg. 26072)	Unregulated Contaminants Monitoring Rule (UCMR
	3). Included with the UCMR 3 rule was a series of
	updates to analytical methods for regulated
	contaminants, which were not related to the UCMR.

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

June 28, 2012	USEPA approved alternative equivalent analytical
(77 Fed. Reg. 38523)	methods for use in demonstrating compliance with
	the drinking water standards.

In addition to the federal actions that fall within the timeframe of this docket, the Board included one additional federal action that occurred later. This additional action directly impacted one of the actions that USEPA took within the timeframe that is involved.

July 2, 2012 (77 Fed. Reg. 39182)	USEPA made a minor correction to the May 2
July 25, 2012 (77 Fed. Reg. 43523)	USEPA made a minor correction to the May 2

A comprehensive description is contained in the Board's opinion and order of October 18, 2012, proposing amendments in docket R13-2, which opinion and order is available from the address below. The Board has included a limited number of corrections and clarifying amendments that are not directly derived from the instant federal amendments.

Tables appear in the Board's opinion and order of October 18, 2012 in docket R13-2 that list numerous corrections and amendments that are not based on current federal amendments. The tables contain deviations from the literal text of the federal amendments underlying these amendments, as well as corrections and clarifications that the Board made in the base text involved. Persons interested in the details of those corrections and amendments should refer to the October 18, 2012 opinion and order in docket R13-2.

Section 17.5 of the Environmental Protection Act [415 ILCS 5/17.5] provides that Section 5-35 of the Illinois Administrative Procedure Act [5 ILCS 100/5-35] does not apply to this rulemaking. Because this rulemaking is not subject to Section 5-35 of the IAPA, it is not subject to First Notice or to Second Notice review by the Joint Committee on Administrative Rules (JCAR).

- 6) <u>Published studies or reports. and sources of underlying data, used to compose this</u> <u>rulemaking</u>: None
- 7) <u>Will this rulemaking replace any emergency rulemaking currently in effect</u>? No
- 8) <u>Does this rulemaking contain an automatic repeal date</u>? No

<u>3</u> 12

## ILLINOIS REGISTER

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

- 9) <u>Does this rulemaking contain incorporations by reference</u>? Yes. The updates to analytical methods are accomplished by numerous incorporations by reference of USEPA-approved standards and regulations in Section 611.102.
- Statement of Statewide Policy Objectives: These proposed amendments do not create or enlarge a State Mandate, as defined in Section 3(b) of the State Mandates Act [30 ILCS 805/3(b)].
- 11) Are there any other proposed rulemakings pending on this Part? No
- 12) <u>Time, Place and manner in which interested persons may comment on this proposed</u> <u>rulemaking:</u> The Board will accept written public comment on this proposal for a period of 45 days after the date of this publication. Comments should reference docket <u>R13-2</u> and be addressed to:

John T. Therriault, Assistant Clerk Illinois Pollution Control Board State of Illinois Center, Suite 11-500 100 W. Randolph St. Chicago, IL 60601

Please direct inquiries to the following person and reference docket R13-2:

Michael J. McCambridge Staff Attorney Illinois Pollution Control Board 100 W. Randolph 11-500 Chicago, IL 60601

Phone: 312-814-6924 E-mail: mccambm@ipcb.state.il.us

Request copies of the Board's opinion and order at 312-814-3620, or download a copy from the Board's Website at http://www.ipcb.state.il.us.

- 13) Initial regulatory flexibility analysis:
  - A) <u>Types of small businesses, small municipalities, and not-for-profit corporations</u> <u>affected:</u> This rulemaking may affect those small businesses, small

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

municipalities, and not-for-profit corporations that own or operate a public water supply.

- B) <u>Reporting, bookkeeping or other procedures required for compliance:</u> The existing rules and proposed amendments require extensive reporting, bookkeeping and other procedures, including the preparation of reports, water analyses, and maintenance of operating records.
- C) <u>Types of professional skills necessary for compliance</u>: Compliance with the existing rules and proposed amendments may require the services of an attorney, certified public accountant, chemist, and registered professional engineer.
- 14) <u>Regulatory agenda on which this rulemaking was summarized:</u> July 2012

The full text of the Proposed Amendments begins on the next page:

## POLLUTION CONTROL BOARD

NOTICE OF PROPOSED AMENDMENTS

# TITLE 35: ENVIRONMENTAL PROTECTION SUBTITLE F: PUBLIC WATER SUPPLIES CHAPTER I: POLLUTION CONTROL BOARD

# PART 611 PRIMARY DRINKING WATER STANDARDS

SUBPART A: GENERAL

213-2

### Section

- 611.100 Purpose, Scope, and Applicability
- 611.101 Definitions
- 611.102 Incorporations by Reference
- 611.103 Severability
- 611.105 Electronic Reporting
- 611.107 Agency Inspection of PWS Facilities
- 611.108 Delegation to Local Government
- 611.109 Enforcement
- 611.110 Special Exception Permits
- 611.111 Relief Equivalent to SDWA Section 1415(a) Variances
- 611.112 Relief Equivalent to SDWA Section 1416 Exemptions
- 611.113 Alternative Treatment Techniques
- 611.114 Siting Requirements
- 611.115 Source Water Quantity
- 611.120 Effective Dates
- 611.121 Maximum Contaminant Levels and Finished Water Quality
- 611.125 Fluoridation Requirement
- 611.126 Prohibition on Use of Lead
- 611.130 Special Requirements for Certain Variances and Adjusted Standards
- 611.131 Relief Equivalent to SDWA Section 1415(e) Small System Variance
- 611.160 Composite Correction Program
- 611.161 Case-by-Case Reduced Subpart Y Monitoring for Wholesale and Consecutive Systems

# SUBPART B: FILTRATION AND DISINFECTION

- 611.201 Requiring a Demonstration
- 611.202 Procedures for Agency Determinations



# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

- 611.211 Filtration Required
- 611.212 Groundwater under Direct Influence of Surface Water
- 611.213 No Method of HPC Analysis
- 611.220 General Requirements
- 611.230 Filtration Effective Dates
- 611.231 Source Water Quality Conditions
- 611.232 Site-Specific Conditions
- 611.233 Treatment Technique Violations
- 611.240 Disinfection
- 611.241 Unfiltered PWSs
- 611.242 Filtered PWSs
- 611.250 Filtration
- 611.261 Unfiltered PWSs: Reporting and Recordkeeping
- 611.262 Filtered PWSs: Reporting and Recordkeeping
- 611.271 Protection during Repair Work
- 611.272 Disinfection Following Repair
- 611.276 Recycle Provisions

## SUBPART C: USE OF NON-CENTRALIZED TREATMENT DEVICES

#### Section

- 611.280 Point-of-Entry Devices
- 611.290 Use of Point-of-Use Devices or Bottled Water

## SUBPART D: TREATMENT TECHNIQUES

# Section

- 611.295 General Requirements
- 611.296 Acrylamide and Epichlorohydrin
- 611.297 Corrosion Control

# SUBPART F: MAXIMUM CONTAMINANT LEVELS (MCLs) AND MAXIMUM RESIDUAL DISINFECTANT LEVELS (MRDLs)

- 611.300 Old MCLs for Inorganic Chemical Contaminants
- 611.301 Revised MCLs for Inorganic Chemical Contaminants
- 611.310 State-Only Maximum Contaminant Levels (MCLs) for Organic Chemical Contaminants

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

- 611.311 Revised MCLs for Organic Chemical Contaminants
- 611.312 Maximum Contaminant Levels (MCLs) for Disinfection Byproducts (DBPs)
- 611.313 Maximum Residual Disinfectant Levels (MRDLs)
- 611.320 Turbidity (Repealed)
- 611.325 Microbiological Contaminants
- 611.330 Maximum Contaminant Levels for Radionuclides
- 611.331 Beta Particle and Photon Radioactivity (Repealed)

# SUBPART G: LEAD AND COPPER

### Section

I

- 611.350 General Requirements
- 611.351 Applicability of Corrosion Control
- 611.352 Corrosion Control Treatment
- 611.353 Source Water Treatment
- 611.354 Lead Service Line Replacement
- 611.355 Public Education and Supplemental Monitoring
- 611.356 Tap Water Monitoring for Lead and Copper
- 611.357 Monitoring for Water Quality Parameters
- 611.358 Monitoring for Lead and Copper in Source Water
- 611.359 Analytical Methods
- 611.360 Reporting
- 611.361 Recordkeeping

# SUBPART I: DISINFECTANT RESIDUALS, DISINFECTION BYPRODUCTS, AND DISINFECTION BYPRODUCT PRECURSORS

## Section

- 611.380 General Requirements
- 611.381 Analytical Requirements
- 611.382 Monitoring Requirements
- 611.383 Compliance Requirements
- 611.384 Reporting and Recordkeeping Requirements
- 611.385 Treatment Technique for Control of Disinfection Byproduct (DBP) Precursors

## SUBPART K: GENERAL MONITORING AND ANALYTICAL REQUIREMENTS

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

- 611.490 Certified Laboratories
- 611.491 Laboratory Testing Equipment
- 611.500 Consecutive PWSs
- 611.510 Special Monitoring for Unregulated Contaminants (Repealed)

# SUBPART L: MICROBIOLOGICAL MONITORING AND ANALYTICAL REQUIREMENTS

### Section

- 611.521 Routine Coliform Monitoring
- 611.522 Repeat Coliform Monitoring
- 611.523 Invalidation of Total Coliform Samples
- 611.524 Sanitary Surveys
- 611.525 Fecal Coliform and E. Coli Testing
- 611.526 Analytical Methodology
- 611.527 Response to Violation
- 611.531 Analytical Requirements
- 611.532 Unfiltered PWSs
- 611.533 Filtered PWSs

## SUBPART M: TURBIDITY MONITORING AND ANALYTICAL REQUIREMENTS

## Section

611.560 Turbidity

## SUBPART N: INORGANIC MONITORING AND ANALYTICAL REQUIREMENTS

- 611.591 Violation of a State MCL
- 611.592 Frequency of State Monitoring
- 611.600 Applicability
- 611.601 Monitoring Frequency
- 611.602 Asbestos Monitoring Frequency
- 611.603 Inorganic Monitoring Frequency
- 611.604 Nitrate Monitoring
- 611.605 Nitrite Monitoring
- 611.606 Confirmation Samples
- 611.607 More Frequent Monitoring and Confirmation Sampling
- 611.608 Additional Optional Monitoring

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

- 611.609 Determining Compliance
- 611.610 Inorganic Monitoring Times
- 611.611 Inorganic Analysis
- 611.612 Monitoring Requirements for Old Inorganic MCLs
- 611.630 Special Monitoring for Sodium
- 611.631 Special Monitoring for Inorganic Chemicals (Repealed)

## SUBPART O: ORGANIC MONITORING AND ANALYTICAL REQUIREMENTS

## Section

- 611.640 Definitions
- 611.641 Old MCLs
- 611.645 Analytical Methods for Organic Chemical Contaminants
- 611.646 Phase I, Phase II, and Phase V Volatile Organic Contaminants
- 611.647 Sampling for Phase I Volatile Organic Contaminants (Repealed)
- 611.648 Phase II, Phase IIB, and Phase V Synthetic Organic Contaminants
- 611.650 Monitoring for 36 Contaminants (Repealed)
- 611.657 Analytical Methods for 36 Contaminants (Repealed)
- 611.658 Special Monitoring for Organic Chemicals (Repealed)

# SUBPART P: THM MONITORING AND ANALYTICAL REQUIREMENTS (REPEALED)

## Section

- 611.680 Sampling, Analytical, and other Requirements (Repealed)
- 611.683 Reduced Monitoring Frequency (Repealed)
- 611.684 Averaging (Repealed)
- 611.685 Analytical Methods (Repealed)
- 611.686 Modification to System (Repealed)
- 611.687 Sampling for THM Potential (Repealed)
- 611.688 Applicability Dates (Repealed)

# SUBPART Q: RADIOLOGICAL MONITORING AND ANALYTICAL REQUIREMENTS

- 611.720 Analytical Methods
- 611.731 Gross Alpha
- 611.732 Beta Particle and Photon Radioactivity
- 611.733 General Monitoring and Compliance Requirements

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

# SUBPART R: ENHANCED FILTRATION AND DISINFECTION: SYSTEMS THAT SERVE 10,000 OR MORE PEOPLE

# Section

Section

- 611.740 General Requirements
- 611.741 Standards for Avoiding Filtration
- 611.742 Disinfection Profiling and Benchmarking
- 611.743 Filtration
- 611.744 Filtration Sampling Requirements
- 611.745 Reporting and Recordkeeping Requirements

# SUBPART S: GROUNDWATER RULE

- 611.800 General Requirements and Applicability
- 611.801 Sanitary Surveys for GWS Suppliers
- 611.802 Groundwater Source Microbial Monitoring and Analytical Methods
- 611.803 Treatment Technique Requirements for GWS Suppliers
- 611.804 Treatment Technique Violations for GWS Suppliers
- 611.805 Reporting and Recordkeeping for GWS Suppliers

# SUBPART T: REPORTING AND RECORDKEEPING

## Section

- 611.830 Applicability
- 611.831 Monthly Operating Report
- 611.832 Notice by Agency (Repealed)
- 611.833 Cross Connection Reporting
- 611.840 Reporting
- 611.851 Reporting MCL, MRDL, and other Violations (Repealed)
- 611.852 Reporting other Violations (Repealed)
- 611.853 Notice to New Billing Units (Repealed)
- 611.854 General Content of Public Notice (Repealed)
- 611.855 Mandatory Health Effects Language (Repealed)
- 611.856 Fluoride Notice (Repealed)
- 611.858 Fluoride Secondary Standard (Repealed)
- 611.860 Record Maintenance
- 611.870 List of 36 Contaminants (Repealed)

# SUBPART U: CONSUMER CONFIDENCE REPORTS

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

Section

- 611.881 Purpose and Applicability
- 611.882 Compliance Dates
- 611.883 Content of the Reports
- 611.884 Required Additional Health Information
- 611.885 Report Delivery and Recordkeeping

# SUBPART V: PUBLIC NOTIFICATION OF DRINKING WATER VIOLATIONS

Section

- 611.901 General Public Notification Requirements
- 611.902 Tier 1 Public Notice: Form, Manner, and Frequency of Notice
- 611.903 Tier 2 Public Notice: Form, Manner, and Frequency of Notice
- 611.904 Tier 3 Public Notice: Form, Manner, and Frequency of Notice
- 611.905 Content of the Public Notice
- 611.906 Notice to New Billing Units or New Customers
- 611.907 Special Notice of the Availability of Unregulated Contaminant Monitoring Results
- 611.908 Special Notice for Exceedence of the Fluoride Secondary Standard
- 611.909 Special Notice for Nitrate Exceedences above the MCL by a Non-Community Water System
- 611.910 Notice by the Agency on Behalf of a PWS
- 611.911 Special Notice for Cryptosporidium

# SUBPART W: INITIAL DISTRIBUTION SYSTEM EVALUATIONS

Section

- 611.920 General Requirements
- 611.921 Standard Monitoring
- 611.922 System-Specific Studies
- 611.923 40/30 Certification
- 611.924 Very Small System Waivers
- 611.925 Subpart Y Compliance Monitoring Location Recommendations

## SUBPART X: ENHANCED FILTRATION AND DISINFECTION \_\_\_\_\_ SYSTEMS SERVING FEWER THAN 10,000 PEOPLE

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

- 611.950 General Requirements
- 611.951 Finished Water Reservoirs
- 611.952 Additional Watershed Control Requirements for Unfiltered Systems
- 611.953 Disinfection Profile
- 611.954 Disinfection Benchmark
- 611.955 Combined Filter Effluent Turbidity Limits
- 611.956 Individual Filter Turbidity Requirements
- 611.957 Reporting and Recordkeeping Requirements

# SUBPART Y: STAGE 2 DISINFECTION BYPRODUCTS REQUIREMENTS

## Section

- 611.970 General Requirements
- 611.971 Routine Monitoring
- 611.972 Subpart Y Monitoring Plan
- 611.973 Reduced Monitoring
- 611.974 Additional Requirements for Consecutive Systems
- 611.975 Conditions Requiring Increased Monitoring
- 611.976 Operational Evaluation Levels
- 611.977 Requirements for Remaining on Reduced TTHM and HAA5 Monitoring Based on Subpart I Results
- 611.978 Requirements for Remaining on Increased TTHM and HAA5 Monitoring Based on Subpart I Results
- 611.979 Reporting and Recordkeeping Requirements

# SUBPART Z: ENHANCED TREATMENT FOR CRYPTOSPORIDIUM

## Section

- 611.1000 General Requirements
- 611.1001 Source Water Monitoring Requirements: Source Water Monitoring
- 611.1002 Source Water Monitoring Requirements: Sampling Schedules
- 611.1003 Source Water Monitoring Requirements: Sampling Locations
- 611.1004 Source Water Monitoring Requirements: Analytical Methods
- 611.1005 Source Water Monitoring Requirements: Approved Laboratories
- 611.1006 Source Water Monitoring Requirements: Reporting Source Water Monitoring Results
- 611.1007 Source Water Monitoring Requirements: Grandfathering Previously Collected Data

# 611.1008 Disinfection Profiling and Benchmarking Requirements: Requirements When Making a Significant Change in Disinfection Practice

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

- 611.1009 Disinfection Profiling and Benchmarking Requirements: Developing the Disinfection Profile and Benchmark
  611.1010 Treatment Technique Requirements: Bin Classification for Filtered Systems
  611.1011 Technique Requirements: Bin Classification for Filtered Systems
- 611.1011 Treatment Technique Requirements: Filtered System Additional Cryptosporidium Treatment Requirements
- 611.1012 Treatment Technique Requirements: Unfiltered System Cryptosporidium Treatment Requirements
- 611.1013 Treatment Technique Requirements: Schedule for Compliance with Cryptosporidium Treatment Requirements
- 611.1014 Treatment Technique Requirements: Requirements for Uncovered Finished Water Storage Facilities
- 611.1015 Requirements for Microbial Toolbox Components: Microbial Toolbox Options for Meeting Cryptosporidium Treatment Requirements
- 611.1016 Requirements for Microbial Toolbox Components: Source Toolbox Components
- 611.1017 Requirements for Microbial Toolbox Components: Pre-Filtration Treatment Toolbox Components
- 611.1018 Requirements for Microbial Toolbox Components: Treatment Performance Toolbox Components
- 611.1019 Requirements for Microbial Toolbox Components: Additional Filtration Toolbox Components
- 611.1020 Requirements for Microbial Toolbox Components: Inactivation Toolbox Components
- 611.1021 Reporting and Recordkeeping Requirements: Reporting Requirements
- 611.1022 Reporting and Recordkeeping Requirements: Recordkeeping Requirements
- 611.1023 Requirements to Respond to Significant Deficiencies Identified in Sanitary Surveys Performed by USEPA or the Agency

611.APPENDIX A	Regulated Contaminants
611.APPENDIX B	Percent Inactivation of G. Lamblia Cysts
611.APPENDIX C	Common Names of Organic Chemicals
611.APPENDIX D	Defined Substrate Method for the Simultaneous Detection of Total
	Coliforms and Eschericia Coli from Drinking Water
611.APPENDIX E	Mandatory Lead Public Education Information for Community Water
	Systems
611.APPENDIX F	Mandatory Lead Public Education Information for Non-Transient
	Non-Community Water Systems
611.APPENDIX G	NPDWR Violations and Situations Requiring Public Notice
611.APPENDIX H	Standard Health Effects Language for Public Notification
611.APPENDIX I	Acronyms Used in Public Notification Regulation

### POLLUTION CONTROL BOARD

### NOTICE OF PROPOSED AMENDMENTS

Total Coliform Monitoring Frequency
Fecal or Total Coliform Density Measurements
Frequency of RDC Measurement
Number of Lead and Copper Monitoring Sites
Lead and Copper Monitoring Start Dates
Number of Water Quality Parameter Sampling Sites
Summary of Section 611.357 Monitoring Requirements for Water Quality
Parameters
CT Values (mg·min/l) for Cryptosporidium Inactivation by Chlorine
Dioxide
CT Values (mg·min/l) for Cryptosporidium Inactivation by Ozone
UV Dose Table for Cryptosporidium, Giardia lamblia, and Virus
Inactivation Credit
Federal Effective Dates

AUTHORITY: Implementing Sections 7.2, 17, and 17.5 and authorized by Section 27 of the Environmental Protection Act [415 ILCS 5/7.2, 17, 17.5, and 27].

SOURCE: Adopted in R88-26 at 14 Ill. Reg. 16517, effective September 20, 1990; amended in R90-21 at 14 Ill. Reg. 20448, effective December 11, 1990; amended in R90-13 at 15 Ill. Reg. 1562, effective January 22, 1991; amended in R91-3 at 16 Ill. Reg. 19010, effective December 1, 1992; amended in R92-3 at 17 Ill. Reg. 7796, effective May 18, 1993; amended in R93-1 at 17 Ill. Reg. 12650, effective July 23, 1993; amended in R94-4 at 18 Ill. Reg. 12291, effective July 28, 1994; amended in R94-23 at 19 Ill. Reg. 8613, effective June 20, 1995; amended in R95-17 at 20 Ill. Reg. 14493, effective October 22, 1996; amended in R98-2 at 22 Ill. Reg. 5020, effective March 5, 1998; amended in R99-6 at 23 Ill. Reg. 2756, effective February 17, 1999; amended in R99-12 at 23 Ill. Reg. 10348, effective August 11, 1999; amended in R00-8 at 23 Ill. Reg. 14715, effective December 8, 1999; amended in R00-10 at 24 Ill. Reg. 14226, effective September 11, 2000; amended in R01-7 at 25 Ill. Reg. 1329, effective January 11, 2001; amended in R01-20 at 25 Ill. Reg. 13611, effective October 9, 2001; amended in R02-5 at 26 Ill. Reg. 3522, effective February 22, 2002; amended in R03-4 at 27 Ill. Reg. 1183, effective January 10, 2003; amended in R03-15 at 27 Ill. Reg. 16447, effective October 10, 2003; amended in R04-3 at 28 Ill. Reg. 5269, effective March 10, 2004; amended in R04-13 at 28 Ill. Reg. 12666, effective August 26, 2004; amended in R05-6 at 29 Ill. Reg. 2287, effective January 28, 2005; amended in R06-15 at 30 III. Reg. 17004, effective October 13, 2006; amended in R07-2/R07-11 at 31 Ill. Reg. 11757, effective July 27, 2007; amended in R08-7/R08-13 at 33 Ill. Reg. 633, effective December 30, 2008; amended in R10-1/R10-17/R11-6 at 34 Ill. Reg. 19848, effective December 7, 2010; amended in R12-4 at 36 Ill. Reg. 7110, effective April 25, 2012; amended in R13-2 at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_\_

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

# SUBPART A: GENERAL

## Section 611.102 Incorporations by Reference

a) Abbreviations and short-name listing of references. The following names and abbreviated names, presented in alphabetical order, are used in this Part to refer to materials incorporated by reference:

"AMI Turbiwell Method"" means "Continuous Measurement of Turbidity Using a SWAN AMI Turbiwell Turbidimeter," available from NEMI or from SWAN Analytische Instrumente AG.

- "\_ASTM Method<sup>22</sup>" means a method published by and available from the American Society for Testing and Materials (ASTM).
- "Colisure Test" means "Colisure Presence/Absence Test for Detection and Identification of Coliform Bacteria and Escherichia Coli in Drinking Water," available from Millipore Corporation, Technical Services Department.

"Colitag® Test" means "Colitag® Product as a Test for Detection and Identification of Coliforms and E. coli Bacteria in Drinking Water and Source Water as Required in National Primary Drinking Water Regulations," available from CPI International.

"Chromocult® Method" means "Chromocult® Coliform Agar Presence/Absence Membrane Filter Test Method for Detection and Identification of Coliform Bacteria and Escherichia coli in Finished Waters," available from EMD Chemicals Inc.

"Determination of Inorganic Oxyhalide" means "Determination of Inorganic Oxyhalide Disinfection By-Products in Drinking Water Using Ion Chromatography with the Addition of a Postcolumn Reagent for Trace Bromate Analysis," available from NTIS.

"Dioxin and Furan Method 1613" means "Tetra- through Octa- Chlorinated Dioxins and Furans by Isotope-Dilution HRGC/HRMS," available from NTIS.

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

""E\*Colite Test" means "Charm E\*Colite Presence/Absence Test for Detection and Identification of Coliform Bacteria and Escherichia coli in Drinking Water," available from Charm Sciences, Inc. and USEPA, Water Resource Center.

"EC-MUG" means "Method 9221 F: Multiple-Tube Fermentation Technique for Members of the Coliform Group, Escherichia coli Procedure (Proposed)," available from American Public Health Association and American Waterworks Association.

""EML Procedures Manual"" means "EML Procedures Manual, HASL 300,"" available from USDOE, EML.

""Enterolert" means "Evaluation of Enterolert for Enumeration of Enterococci in Recreational Waters," available from American Society for Microbiology.

"Georgia Radium Method" means "The Determination of Radium-226 and Radium-228 in Drinking Water by Gamma-ray Spectrometry Using HPGE or Ge(Li) Detectors," Revision 1.2, December 2004, available from the Georgia Tech Research Institute.

"GLI Method 2<sup>22</sup>" means GLI Method 2, ""Turbidity,"" Nov. 2, 1992, available from Great Lakes Instruments, Inc.

""Guidance Manual for Filtration and Disinfection<sup>22</sup>" means "Guidance Manual for Compliance with the Filtration and Disinfection Requirements for Public Water Systems using Surface Water Sources,<sup>22</sup>" March 1991, available from USEPA, NSCEP.

"Hach FilterTrak Method 10133" means "Determination of Turbidity by Laser Nephelometry," available from Hach Co.

"Hach SPDANS 2 Method 10225<sup>20</sup> means "Hach Company SPADNS 2 (Arsenic-free) Fluoride Method 10225—\_\_Spectrophotometric Measurement of Fluoride in Water and Wastewater,<sup>20</sup> available from the Hach Co.

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

"Hach TNTplus 835/836 Method 10206" means "Hach Company TNTplus 835/836 Nitrate Method 10206——Spectrophotometric Measurement of Nitrate in Water and Wastewater," available from the Hach Co.

""ITS Method D99-003"" means Method D99-003, Revision 3.0, "Free Chlorine Species (HOCI- and OCI-) by Test Strip," available from Industrial Test Systems, Inc.

"Kelada 01"" means "Kelada Automated Test Methods for Total Cyanide, Acid Dissociable Cyanide, And Thiocyanate," Revision 1.2, available from NTIS.

""m-ColiBlue24 Test" means "Total Coliforms and E. coli Membrane Filtration Method with m-ColiBlue24® Broth," available from USEPA, Water Resource Center and Hach Company.

""Method ME355.01"" means "Determination of Cyanide in Drinking Water by GC/MS Headspace Analysis," available from NEMI or from H&E Testing Laboratory.

""Mitchell Method M5271"" means "Determination of Turbidity by Laser Nephelometry," available from NEMI and Leck Mitchell, PhD.

"Mitchell Method M5331" means "Determination of Turbidity by LED Nephelometry," available from NEMI and Leck Mitchell, PhD.

"Modified Colitag<sup>™</sup> Method<sup>™</sup> means "Modified Colitag<sup>™</sup> Test Method for Simultaneous Detection of E. coli and other Total Coliforms in Water,<sup>™</sup> available from NEMI and CPI International.

""NA-MUG" means "Method 9222 G: Membrane Filter Technique for Members of the Coliform Group, MF Partition Procedures," available from American Public Health Association and American Waterworks Association.

"\_\_\_NCRP Report Number 22<sup>22</sup>" means "\_\_Maximum Permissible Body Burdens and Maximum Permissible Concentrations of Radionuclides in Air and in Water for Occupational Exposure,<sup>22</sup>" available from NCRP.

### POLLUTION CONTROL BOARD

### NOTICE OF PROPOSED AMENDMENTS

- "New Jersey Radium Method?" means "Determination of Radium 228 in Drinking Water,?" available from the New Jersey Department of Environmental Protection.
- "\_"New York Radium Method"" means "Determination of Ra-226 and Ra-228 (Ra-02)," available from the New York Department of Public Health.

<sup>44</sup>OI Analytical Method OIA-1677<sup>10</sup> means <sup>44</sup>Method OIA-1677, DW Available Cyanide by Flow Injection, Ligand Exchange, and Amperometry,<sup>22</sup> available from ALPKEM, Division of OI Analytical.

# "\_"ONPG-MUG Test" (meaning "minimal medium

ortho-nitrophenyl-beta-d-galactopyranoside-4-methyl-umbelliferyl -beta-d-glucuronide test<sup>25</sup>), also called the <sup>26</sup>Autoanalysis Colilert System,<sup>25</sup> is Method 9223, available in <sup>26</sup>Standard Methods for the Examination of Water and Wastewater,<sup>26</sup> 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., from American Public Health Association and the American Water Works Association.

"Orion Method AQ4500"" means "Determination of Turbidity by LED Nephelometry," available from Thermo Scientific.

""Palintest ChloroSense?" means "Measurement of Free and Total Chlorine in Drinking Water by Palintest ChloroSense,?" available from NEMI or Palintest Ltd.

- "\_Palintest Method 1001" means "Method Number 1001," available from Palintest, Ltd. or the Hach Company.
- "\_QuikChem Method 10-204-00-1-X" means "Digestion and distillation of total cyanide in drinking and wastewaters using MICRO DIST and determination of cyanide by flow injection analysis," available from Lachat Instruments.
- "\_"Readycult® 2000"" means ""Readycult Coliforms 100 Presence/Absence Test for Detection and Identification of Coliform Bacteria and Escherichia coli in Finished Waters," v. 1.0, available from EMD Chemicals Inc.

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

"Readycult® 2007" means "Readycult® Coliforms 100 Presence/Absence Test for Detection and Identification of Coliform Bacteria and Escherichia coli in Finished Waters," v. 1.1, available from EMD Chemicals Inc.

- "\_"SimPlate Method"" means ""IDEXX SimPlate TM HPC Test Method for Heterotrophs in Water," available from IDEXX Laboratories, Inc.
- "Standard Methods" means "Standard Methods for the Examination of Water and Wastewater," available from the American Public Health Association or the American Waterworks Association.

""Standard Methods Online" means the website maintained by the Standard Methods Organization (at www.standardmethods.org) for purchase of the latest versions of methods in an electronic format.

"\_Syngenta AG-625"" means "Atrazine in Drinking Water by Immunoassay,"" February 2001 is available from Syngenta Crop Protection, Inc.

"Systea Easy (1-Reagent)" means "Systea Easy (1-Reagent) Nitrate Method," available from NEMI or Systea Scientific LLC.

- "Technical Bulletin 601<sup>20</sup>" means "Technical Bulletin 601, Standard Method of Testing for Nitrate in Drinking Water," July 1994, available from Analytical Technology, Inc.
- "\_\_\_Technicon Methods" means "Fluoride in Water and Wastewater," available from Bran & Luebbe.
- "USEPA Asbestos Method 100.12" means Method 100.1, "Analytical Method for Determination of Asbestos Fibers in Water, "September 1983, available from NTIS.
- "USEPA Asbestos Method 100.2" means Method 100.2, "Determination of Asbestos Structures over 10-mm in Length in Drinking Water," June 1994, available from NTIS.
- "USEPA Environmental Inorganic Methods "means "Methods for the Determination of Inorganic Substances in Environmental Samples,"

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

August 1993, available from NTIS.

- "\_"USEPA Environmental Metals Methods"" means ""Methods for the Determination of Metals in Environmental Samples, " available from NTIS.
- "USEPA Inorganic Methods" means "Methods for Chemical Analysis of Water and Wastes," March 1983, available from NTIS.
- "USEPA Interim Radiochemical Methods" means "Interim Radiochemical Methodology for Drinking Water," EPA 600/4-75/008 (revised), March 1976. Available from NTIS.

"USEPA Method 1600" means "Method 1600: Enterococci in Water by Membrane Filtration Using Membrane-Enterococcus Indoxyl =b-=D =Glucoside Agar (mEI)," available from USEPA, Water Resource Center.

""USEPA Method 1601"" means ""Method 1601: Male-specific (F<sup>+</sup>) and Somatic Coliphage in Water by Two-step Enrichment Procedure,"" available from USEPA, Water Resource Center.

"USEPA Method 1602" means "Method 1602: Male-specific (F<sup>4</sup>) and Somatic Coliphage in Water by Single Agar Layer (SAL) Procedure," available from USEPA, Water Resource Center.

"USEPA Method 1604" means "Method 1604: Total Coliforms and Escherichia coli in Water by Membrane Filtration Using a Simultaneous Detection Technique (MI Medium)," available from USEPA, Water Resource Center.

"USEPA NERL Method 415.3 (rev. 1.1)"" means Method 415.3, Revision 1.1, "Determination of Total Organic Carbon and Specific UV

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

Absorbance at 254 nm in Source Water and Drinking Water,<sup>2</sup> USEPA, February 2005, EPA 600/R-05/055. Available from USEPA, Office of Research and Development.

"USEPA NERL Method 415.3 (rev. 1.2)" means Method 415.3, Revision 1.2, "Determination of Total Organic Carbon and Specific UV Absorbance at 254 nm in Source Water and Drinking Water," USEPA, August 2009, EPA 600/R-09/122. Available from USEPA, Office of Research and Development.

"USEPA NERL Method 525.3 (ver. 1.0)" means Method 525.3, Version 1.0, "Determination of Total Semivolatile Organic Chemicals in Drinking Water by Solid Phase Extraction and Capillary Column Gas Chromatography/Mass Spectrometry (GC/MS)," USEPA, February 2012, EPA 600/R-12/010. Available from USEPA, Office of Research and Development.

"USEPA NERL Method 549.2" means Method 549.2, Revision 1.0, "Determination of Diquat and Paraquat in Drinking Water by Liquid-Solid Extraction and High Performance Liquid Chromatography with Ultraviolet Detection," June 1997. Available from USEPA, Office of Research and Development.

"USEPA OGWDW Methods"" means the methods listed as available from the USEPA, Office of Ground Water and Drinking Water (Methods 302.0, 317.0 (rev. 2.0), 326.0 (rev. 1.0), 327.0 (rev. 1.1), 334.0, 515.4 (rev. 1.0), 523 (ver. 1.0), 524.3 (rev. 1.0), 531.2 (rev. 1.0), 536 (ver. 1.0), 552.3 (rev. 1.0), 557, 1622 (99), 1622 (01), 1622 (05), 1623 (99), 1623 (01), and 1623 (05)), and <u>1623.1.1623.1</u>). Available from NTIS; USEPA, NSCEP; or USEPA, OGWDW.

"USEPA Organic Methods<sup>22</sup>" means "Methods for the Determination of Organic Compounds in Drinking Water,<sup>22</sup>" December 1988 (revised\_July 1991) (Methods 508A (rev. 1.0) and 515.1 (rev. 4.0)); "Methods for the Determination of Organic Compounds in Drinking Water—\_\_\_Supplement I,<sup>22</sup>" July 1990 (Methods 547, 550, and 550.1); "Methods for the Determination of Organic Compounds in Drinking Water—\_\_\_Supplement II,<sup>22</sup>" August 1992 (Methods 548.1 (rev. 1.0), 552.1 (rev. 1.0), and 555 (rev. 1.0)); and "Methods for the Determination of Organic Compounds

### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

"USEPA Organic and Inorganic Methods<sup>22</sup>" means "Methods for the Determination of Organic and Inorganic Compounds in Drinking Water, Volume 1,"" EPA 815/R-00/014, PB2000-106981, August 2000. Available from NTIS.

- "USEPA Radioactivity Methods" means "Prescribed Procedures for Measurement of Radioactivity in Drinking Water," EPA 600/4-80/032, August 1980. Available from NTIS.
- "USEPA Radiochemical Analyses" means "Radiochemical Analytical Procedures for Analysis of Environmental Samples," March 1979. Available from NTIS.
- "USEPA Radiochemistry Procedures" means "Radiochemistry Procedures Manual," EPA 520/5-84/006, December 1987. Available from NTIS.
- "USEPA Technical Notes" means "Technical Notes on Drinking Water Methods," available from NTIS and USEPA, NSCEP.
- "USGS Methods" means "Methods of Analysis by the U.S. Geological Survey National Water Quality Laboratory Determination of Inorganic and Organic Constituents in Water and Fluvial Sediments," available from NTIS and USGS. BOARD NOTE: The USGS Methods are available in three volumes published in 1977, 1989, and 1993, as outlined in subsection (b) of this Section.
- "Waters Method B-1011<sup>20</sup>" means "Waters Test Method for the Determination of Nitrite/Nitrate in Water Using Single Column Ion Chromatography,<sup>20</sup>" available from Waters Corporation, Technical Services Division.
- b) The Board incorporates the following publications by reference:

### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

ALPKEM, Division of OI Analytical, P.O. Box 9010, College Station, TX 77842-9010, telephone: 979-690-1711, Internet: www.oico.com.

""Method OIA-1677 DW, Available Cyanide by Flow Injection, Ligand Exchange, and Amperometry,"" EPA 821/R-04/001, January 2004 (referred to as "OI Analytical Method OIA-1677"), referenced in Section 611.611. BOARD NOTE: Also available online for download from www.epa.gov/waterscience/methods/method/cyanide/1677-2004.p df.

APHA. American Public Health Association, 1015 Fifteenth Street NW, Washington, DC 20005 202-777-2742.

- "Standard Methods for the Examination of Water and Wastewater," 17th Edition, 1989 (referred to as "Standard Methods, 17th ed."). See the methods listed separately for the same references under American Waterworks Association.
- "Standard Methods for the Examination of Water and Wastewater," 18<sup>th</sup> Edition, 1992, including ""Supplement to the 18<sup>th</sup> Edition of Standard Methods for the Examination of Water and Wastewater," 1994 (collectively referred to as "Standard Methods, 18<sup>th</sup> ed."). See the methods listed separately for the same references under American Waterworks Association.
- "Standard Methods for the Examination of Water and Wastewater," 19 " Edition, 1995 (referred to as "Standard Methods, 19" ed."). See the methods listed separately for the same references under American Waterworks Association.
- "Standard Methods for the Examination of Water and Wastewater," 20th Edition, 1998 (referred to as "Standard Methods, 20th ed."). See the methods listed separately for the same references under American Waterworks Association.

Standard Methods for the Examination of Water and Wastewater, 21<sup>st</sup> Edition, 2005 (referred to as Standard

### POLLUTION CONTROL BOARD

### NOTICE OF PROPOSED AMENDMENTS

Methods,  $21^{st}$  ed.<sup>20</sup>). See the methods listed separately for the same references under American Waterworks Association.

American Society for Microbiology, 1752 N Street N.W., Washington, DC 20036, 202-737-3600:

""Evaluation of Enterolect for Enumeration of Enterococci in Recreational Waters," Applied and Environmental Microbiology, Oct. 1996, vol. 62, no. 10, p. 3881 (referred to as ""Enterolect"), referenced in Section 611.802.

BOARD NOTE: At the table to 40 CFR 141.402(c)(2), USEPA approved the method as described in the above literature review. The method itself is embodied in the printed instructions to the proprietary kit available from IDEXX Laboratories, Inc. (accessible on-line and available by download from www.asm.org, as ""Enterolert<sup>™</sup> Procedure<sup>20</sup>"). ASTM approved the method as ""Standard Test Method for Enterococci in Water Using Enterolert<sup>™</sup>,<sup>20</sup>" which is available in two versions from ASTM: ASTM Method D6503-99 (superceded) and ASTM Method D6503-99. While it is more conventional to incorporate the method as presented in the kit instructions or as approved by ASTM by reference, the Board is constrained to incorporate the version that appears in the technical literature by reference, which is the version that USEPA has explicitly approved.

AWWA. American Water Works Association et al., 6666 West Quincy Ave., Denver, CO 80235 (303-794-7711).

""National Field Evaluation of a Defined Substrate Method for the Simultaneous Enumeration of Total Coliforms and Escherichia coli for Drinking Water: Comparison with the Standard Multiple Tube Fermentation Method," S.C. Edberg, M.J. Allen & D.B. Smith, Applied Environmental Microbiology, vol. 54, iss. 6, pp 1595-1601 (1988), referenced in Appendix D to this Part.

"\_Standard Methods for the Examination of Water and Wastewater," 13th Edition, 1971 (referred to as "Standard Methods, 13th ed.").

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

Method 302, Gross Alpha and Gross Beta Radioactivity in Water (Total, Suspended, and Dissolved), referenced in Section 611.720.

Method 303, Total Radioactive Strontium and Strontium 90 in Water, referenced in Section 611.720.

Method 304, Radium in Water by Precipitation, referenced in Section 611.720.

Method 305, Radium 226 by Radon in Water (Soluble, Suspended, and Total), referenced in Section 611.720.

Method 306, Tritium in Water, referenced in Section 611.720.

""Standard Methods for the Examination of Water and Wastewater,<sup>22</sup>" 17<sup>th</sup> Edition, 1989 (referred to as ""Standard Methods, 17<sup>th</sup> ed.<sup>22</sup>").

> Method 7110 B, Gross Alpha and Gross Beta Radioactivity in Water (Total, Suspended, and Dissolved), referenced in Section 611.720.

Method 7500-Cs B, Radioactive Cesium, Precipitation Method, referenced in Section 611.720.

Method 7500-<sup>3</sup>H B, Tritium in Water, referenced in Section 611.720.

Method 7500-I B, Radioactive Iodine, Precipitation Method, referenced in Section 611.720.

Method 7500-I C, Radioactive Iodine, Ion-Exchange Method, referenced in Section 611.720.

Method 7500-I D, Radioactive Iodine, Distillation Method, referenced in Section 611.720.

### POLLUTION CONTROL BOARD

### NOTICE OF PROPOSED AMENDMENTS

Method 7500-Ra B, Radium in Water by Precipitation, referenced in Section 611.720.

Method 7500-Ra C, Radium 226 by Radon in Water (Soluble, Suspended, and Total), referenced in Section 611.720.

Method 7500-Ra D, Radium, Sequential Precipitation Method (Proposed), referenced in Section 611.720.

Method 7500-Sr B, Total Radioactive Strontium and Strontium 90 in Water, referenced in Section 611.720.

Method 7500-U B, Uranium, Radiochemical Method (Proposed), referenced in Section 611.720.

Method 7500-U C, Uranium, Isotopic Method (Proposed), referenced in Section 611.720.

"\_Standard Methods for the Examination of Water and Wastewater," 18th Edition, 1992 (referred to as "Standard Methods, 18th ed.").

Method 2130 B, Turbidity, Nephelometric Method, referenced in Section 611.531.

Method 2320 B, Alkalinity, Titration Method, referenced in Section 611.611.

Method 2510 B, Conductivity, Laboratory Method, referenced in Section 611.611.

Method 2550, Temperature, Laboratory and Field Methods, referenced in Section 611.611.

Method 3111 B, Metals by Flame Atomic Absorption Spectrometry, Direct Air-Acetylene Flame Method, referenced in Sections 611.611 and 611.612.

Method 3111 D, Metals by Flame Atomic Absorption

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

Spectrometry, Direct Nitrous Oxide-Acetylene Flame Method, referenced in Section 611.611.

Method 3112 B, Metals by Cold-Vapor Atomic Absorption Spectrometry, Cold-Vapor Atomic Absorption Spectrometric Method, referenced in Section 611.611.

Method 3113 B, Metals by Electrothermal Atomic Absorption Spectrometry, Electrothermal Atomic Absorption Spectrometric Method, referenced in Sections 611.611 and 611.612.

Method 3114 B, Metals by Hydride Generation/Atomic Absorption Spectrometry, Manual Hydride Generation/Atomic Absorption Spectrometric Method, referenced in Section 611.611.

Method 3120 B, Metals by Plasma Emission Spectroscopy, Inductively Coupled Plasma (ICP) Method, referenced in Sections 611.611 and 611.612.

Method 3500-Ca D, Calcium, EDTA Titrimetric Method, referenced in Section 611.611.

Method 3500-Mg E, Magnesium, Calculation Method, referenced in Section 611.611.

Method 4110 B, Determination of Anions by Ion Chromatography, Ion Chromatography with Chemical Suppression of Eluent Conductivity, referenced in Section 611.611.

Method 4500-CN C, Cyanide, Total Cyanide after Distillation, referenced in Section 611.611.

Method 4500-CN E, Cyanide, Colorimetric Method, referenced in Section 611.611.

Method 4500-CN F, Cyanide, Cyanide-Selective

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

Electrode Method, referenced in Section 611.611.

Method 4500-CN-G, Cyanide, Cyanides Amenable to Chlorination after Distillation, referenced in Section 611.611.

Method 4500-Cl D, Chlorine, Amperometric Titration Method, referenced in Section 611.531.

Method 4500-Cl E, Chlorine, Low-Level Amperometric Titration Method, referenced in Section 611.531.

Method 4500-Cl F, Chlorine, DPD Ferrous Titrimetric Method, referenced in Section 611.531.

Method 4500-Cl G, Chlorine, DPD Colorimetric Method, referenced in Section 611.531.

Method 4500-Cl H, Chlorine, Syringaldazine (FACTS) Method, referenced in Section 611.531.

Method 4500-Cl I, Chlorine, Iodometric Electrode Method, referenced in Section 611.531.

Method 4500-ClO<sub>2</sub> C, Chlorine Dioxide, Amperometric Method I, referenced in Section 611.531.

Method 4500-ClO<sub>2</sub> D, Chlorine Dioxide, DPD Method, referenced in Section 611.531.

Method 4500-ClO<sub>2</sub> E, Chlorine Dioxide, Amperometric Method II (Proposed), referenced in Section 611.531.

Method 4500-F-B, Fluoride, Preliminary Distillation Step, referenced in Section 611.611.

Method 4500-F C, Fluoride, Ion-Selective Electrode Method, referenced in Section 611.611.

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

Method 4500-F $\overline{-}$  D, Fluoride, SPADNS Method, referenced in Section 611.611.

Method 4500- $F \stackrel{=}{=} E$ , Fluoride, Complexone Method, referenced in Section 611.611.

Method 4500-H<sup>+</sup> B, pH Value, Electrometric Method, referenced in Section 611.611.

Method 4500-NO<sub>2</sub> B, Nitrogen (Nitrite), Colorimetric Method, referenced in Section 611.611.

Method 4500-NO<sub>3</sub>- D, Nitrogen (Nitrate), Nitrate Electrode Method, referenced in Section 611.611.

Method 4500-NO<sub>3</sub>- E, Nitrogen (Nitrate), Cadmium Reduction Method, referenced in Section 611.611.

Method 4500-NO<sub>3</sub> F, Nitrogen (Nitrate), Automated Cadmium Reduction Method, referenced in Section 611.611.

Method 4500-O<sub>3</sub> B, Ozone (Residual) (Proposed), Indigo Colorimetric Method, referenced in Section 611.531.

Method 4500-P E, Phosphorus, Ascorbic Acid Method, referenced in Section 611.611.

Method 4500-P F, Phosphorus, Automated Ascorbic Acid Reduction Method, referenced in Section 611.611.

Method 4500-Si D, Silica, Molybdosilicate Method, referenced in Section 611.611.

Method 4500-Si E, Silica, Heteropoly Blue Method, referenced in Section 611.611.

Method 4500-Si F, Silica, Automated Method for Molybdate-Reactive Silica, referenced in Section 611.611.

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

Method 6651, Glyphosate Herbicide (Proposed), referenced in Section 611.645.

Method 7110 B, Gross Alpha and Beta Radioactivity (Total, Suspended, and Dissolved), Evaporation Method for Gross Alpha-Beta, referenced in Section 611.720.

Method 7110 C, Gross Alpha and Beta Radioactivity (Total, Suspended, and Dissolved), Coprecipitation Method for Gross Alpha Radioactivity in Drinking Water (Proposed), referenced in Section 611.720.

Method 7500-Cs B, Radioactive Cesium, Precipitation Method, referenced in Section 611.720.

Method 7500-<sup>3</sup>H B, Tritium, Liquid Scintillation Spectrometric Method, referenced in Section 611.720.

Method 7500-I B, Radioactive Iodine, Precipitation Method, referenced in Section 611.720.

Method 7500-I C, Radioactive Iodine, Ion-Exchange Method, referenced in Section 611.720.

Method 7500-I D, Radioactive Iodine, Distillation Method, referenced in Section 611.720.

Method 7500-Ra B, Radium, Precipitation Method, referenced in Section 611.720.

Method 7500-Ra C, Radium, Emanation Method, referenced in Section 611.720.

Method 7500-Ra D, Radium, Sequential Precipitation Method (Proposed), referenced in Section 611.720.

Method 7500-Sr B, Total Radioactive Strontium and Strontium 90, Precipitation Method, referenced in Section

### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

611.720.

Method 7500-U B, Uranium, Radiochemical Method (Proposed), referenced in Section 611.720.

Method 7500-U C, Uranium, Isotopic Method (Proposed), referenced in Section 611.720.

Method 9215 B, Heterotrophic Plate Count, Pour Plate Method, referenced in Section 611.531.

Method 9221 A, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Introduction, referenced in Sections 611.526 and 611.531.

Method 9221 B, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Standard Total Coliform Fermentation Technique, referenced in Sections 611.526 and 611.531.

Method 9221 C, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Estimation of Bacterial Density, referenced in Sections 611.526 and 611.531.

Method 9221 D, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Presence-Absence (P-A) Coliform Test, referenced in Section 611.526.

Method 9221 E, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Fecal Coliform Procedure, referenced in Sections 611.526 and 611.531.

Method 9222 A, Membrane Filter Technique for Members of the Coliform Group, Introduction, referenced in Sections 611.526 and 611.531.

Method 9222 B, Membrane Filter Technique for Members of the Coliform Group, Standard Total Coliform Membrane

### POLLUTION CONTROL BOARD

### NOTICE OF PROPOSED AMENDMENTS

Filter Procedure, referenced in Sections 611.526 and 611.531.

Method 9222 C, Membrane Filter Technique for Members of the Coliform Group, Delayed-Incubation Total Coliform Procedure, referenced in Sections 611.526 and 611.531.

Method 9222 D, Membrane Filter Technique for Members of the Coliform Group, Fecal Coliform Membrane Filter Procedure, referenced in Section 611.531.

Method 9223, Chromogenic Substrate Coliform Test (Proposed) (also referred to as the variations ""Autoanalysis Colilert System"" and ""Colisure Test""), referenced in Sections 611.526 and 611.531.

Method 9223 B, Chromogenic Substrate Coliform Test (Proposed), referenced in Section 611.1004.

"Supplement to the 18<sup>th</sup> Edition of Standard Methods for the Examination of Water and Wastewater," American Public Health Association, 1994.

Method 6610, Carbamate Pesticide Method, referenced in Section 611.645.

"\_"Standard Methods for the Examination of Water and Wastewater," 19th Edition, 1995 (referred to as "Standard Methods, 19th ed.").

Method 2130 B, Turbidity, Nephelometric Method, referenced in Section 611.531.

Method 2320 B, Alkalinity, Titration Method, referenced in Section 611.611.

Method 2510 B, Conductivity, Laboratory Method, referenced in Section 611.611.

Method 2550, Temperature, Laboratory, and Field

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

Methods, referenced in Section 611.611.

Method 3111 B, Metals by Flame Atomic Absorption Spectrometry, Direct Air-Acetylene Flame Method, referenced in Sections 611.611 and 611.612.

Method 3111 D, Metals by Flame Atomic Absorption Spectrometry, Direct Nitrous Oxide-Acetylene Flame Method, referenced in Section 611.611.

Method 3112 B, Metals by Cold-Vapor Atomic Absorption Spectrometry, Cold-Vapor Atomic Absorption Spectrometric Method, referenced in Section 611.611.

Method 3113 B, Metals by Electrothermal Atomic Absorption Spectrometry, Electrothermal Atomic Absorption Spectrometric Method, referenced in Sections 611.611 and 611.612.

Method 3114 B, Metals by Hydride Generation/Atomic Absorption Spectrometry, Manual Hydride Generation/Atomic Absorption Spectrometric Method, referenced in Section 611.611.

Method 3120 B, Metals by Plasma Emission Spectroscopy, Inductively Coupled Plasma (ICP) Method, referenced in Sections 611.611 and 611.612.

Method 3500-Ca D, Calcium, EDTA Titrimetric Method, referenced in Section 611.611.

Method 3500-Mg E, Magnesium, Calculation Method, referenced in Section 611.611.

Method 4110 B, Determination of Anions by Ion Chromatography, Ion Chromatography with Chemical Suppression of Eluent Conductivity, referenced in Section 611.611.

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

Method 4500-Cl D, Chlorine, Amperometric Titration Method, referenced in Sections 611.381 and 611.531.

Method 4500-Cl E, Chlorine, Low-Level Amperometric Titration Method, referenced in Sections 611.381 and 611.531.

Method 4500-Cl F, Chlorine, DPD Ferrous Titrimetric Method, referenced in Sections 611.381 and 611.531.

Method 4500-Cl G, Chlorine, DPD Colorimetric Method, referenced in Sections 611.381 and 611.531.

Method 4500-Cl H, Chlorine, Syringaldazine (FACTS) Method, referenced in Sections 611.381 and 611.531.

Method 4500-Cl I, Chlorine, Iodometric Electrode Method, referenced in Sections 611.381 and 611.531.

Method 4500-ClO<sub>2</sub> C, Chlorine Dioxide, Amperometric Method I, referenced in Section 611.531.

Method 4500-ClO<sub>2</sub> D, Chlorine Dioxide, DPD Method, referenced in Sections 611.381 and 611.531.

Method 4500-ClO<sub>2</sub> E, Chlorine Dioxide, Amperometric Method II, referenced in Sections 611.381 and 611.531.

Method 4500-CN C, Cyanide, Total Cyanide after Distillation, referenced in Section 611.611.

Method 4500-CN-E, Cyanide, Colorimetric Method, referenced in Section 611.611.

Method 4500-CN F, Cyanide, Cyanide-Selective Electrode Method, referenced in Section 611.611.

Method 4500-CN-G, Cyanide, Cyanides Amenable to Chlorination after Distillation, referenced in Section

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

611.611.

Method 4500-F-B, Fluoride, Preliminary Distillation Step, referenced in Section 611.611.

Method 4500-F-: C, Fluoride, Ion-Selective Electrode Method, referenced in Section 611.611.

Method 4500-F- D, Fluoride, SPADNS Method, referenced in Section 611.611.

Method 4500-F E, Fluoride, Complexone Method, referenced in Section 611.611.

Method 4500-H<sup>+</sup> B, pH Value, Electrometric Method, referenced in Section 611.611.

Method 4500-NO<sub>2</sub>- B, Nitrogen (Nitrite), Colorimetric Method, referenced in Section 611.611.

Method 4500-NO<sub>3</sub> D, Nitrogen (Nitrate), Nitrate Electrode Method, referenced in Section 611.611.

Method 4500-NO<sub>3</sub>— E, Nitrogen (Nitrate), Cadmium Reduction Method, referenced in Section 611.611.

Method 4500-NO<sub>3</sub>-F, Nitrogen (Nitrate), Automated Cadmium Reduction Method, referenced in Section 611.611.

Method 4500-O<sub>3</sub> B, Ozone (Residual) (Proposed), Indigo Colorimetric Method, referenced in Section 611.531.

Method 4500-P E, Phosphorus, Ascorbic Acid Method, referenced in Section 611.611.

Method 4500-P F, Phosphorus, Automated Ascorbic Acid Reduction Method, referenced in Section 611.611.

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

Method 4500-Si D, Silica, Molybdosilicate Method, referenced in Section 611.611.

Method 4500-Si E, Silica, Heteropoly Blue Method, referenced in Section 611.611.

Method 4500-Si F, Silica, Automated Method for Molybdate-Reactive Silica, referenced in Section 611.611.

Method 5310 B, TOC, Combustion-Infrared Method, referenced in Section 611.381.

Method 5310 C, TOC, Persulfate-Ultraviolet Oxidation Method, referenced in Section 611.381.

Method 5310 D, TOC, Wet-Oxidation Method, referenced in Section 611.381.

Method 5910 B, UV Absorbing Organic Constituents, Ultraviolet Absorption Method, referenced in Section 611.381.

Method 6251 B, Disinfection Byproducts: Haloacetic Acids and Trichlorophenol, Micro Liquid-Liquid Extraction Gas Chromatographic Method, referenced in Section 611.381.

Method 6610, Carbamate Pesticide Method, referenced in Section 611.645.

Method 6651, Glyphosate Herbicide (Proposed), referenced in Section 611.645.

Method 7110 B, Gross Alpha and Gross Beta Radioactivity, Evaporation Method for Gross Alpha-Beta, referenced in Section 611.720.

Method 7110 C, Gross Alpha and Beta Radioactivity (Total, Suspended, and Dissolved), Coprecipitation Method

## POLLUTION CONTROL BOARD

### NOTICE OF PROPOSED AMENDMENTS

for Gross Alpha Radioactivity in Drinking Water (Proposed), referenced in Section 611.720.

Method 7120 B, Gamma-Emitting Radionuclides, Gamma Spectrometric Method, referenced in Section 611.720.

Method 7500-Cs B, Radioactive Cesium, Precipitation Method, referenced in Section 611.720.

Method 7500-<sup>3</sup>H B, Tritium, Liquid Scintillation Spectrometric Method, referenced in Section 611.720.

Method 7500-I B, Radioactive Iodine, Precipitation Method, referenced in Section 611.720.

Method 7500-I C, Radioactive Iodine, Ion-Exchange Method, referenced in Section 611.720.

Method 7500-I D, Radioactive Iodine, Distillation Method, referenced in Section 611.720.

Method 7500-Ra B, Radium, Precipitation Method, referenced in Section 611.720.

Method 7500-Ra C, Radium, Emanation Method, referenced in Section 611.720.

Method 7500-Ra D, Radium, Sequential Precipitation Method, referenced in Section 611.720.

Method 7500-Sr B, Total Radiactive Strontium and Strontium 90, Precipitation Method, referenced in Section 611.720.

Method 7500-U B, Uranium, Radiochemical Method, referenced in Section 611.720.

Method 7500-U C, Uranium, Isotopic Method, referenced in Section 611.720.

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

Method 9215 B, Heterotrophic Plate Count, Pour Plate\_ Method, referenced in Section 611.531.

Method 9221 A, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Introduction, referenced in Sections 611.526 and 611.531.

Method 9221 B, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Standard Total Coliform Fermentation Technique, referenced in Sections 611.526 and 611.531.

Method 9221 C, Multiple-Tube Fermentation Technique\_ for Members of the Coliform Group, Estimation of Bacterial Density, referenced in Sections 611.526 and 611.531.

Method 9221 D, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Presence-Absence (P-A) Coliform Test, referenced in Section 611.526.

Method 9221 E, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Fecal Coliform Procedure, referenced in Sections 611.526 and 611.531.

Method 9222 A, Membrane Filter Technique for Members\_ of the Coliform Group, Introduction, referenced in Sections 611.526 and 611.531.

Method 9222 B, Membrane Filter Technique for Members of the Coliform Group, Standard Total Coliform Membrane Filter Procedure, referenced in Sections 611.526 and 611.531.

Method 9222 C, Membrane Filter Technique for Members of the Coliform Group, Delayed-Incubation Total Coliform Procedure, referenced in Sections 611.526 and 611.531.

POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

Method 9222 D, Membrane Filter Technique for Members of the Coliform Group, Fecal Coliform Membrane Filter Procedure, referenced in Section 611.531.

Method 9222 G, Membrane Filter Technique for Members of the Coliform Group, MF Partition Procedures, referenced in Section 611.526.

Method 9223, Chromogenic Substrate Coliform Test (also referred to as the variations "Autoanalysis Colilert System" and "Colisure Test"), referenced in Sections 611.526 and 611.531.

Method 9223 B, Chromogenic Substrate Coliform Test (Proposed), referenced in Section 611.1004.

"Supplement to the 19<sup>th</sup> Edition of Standard Methods for the Examination of Water and Wastewater," American Public Health Association, 1996.

Method 5310 B, TOC, Combustion-Infrared Method, referenced in Section 611.381.

Method 5310 C, TOC, Persulfate-Ultraviolet Oxidation Method, referenced in Section 611.381.

Method 5310 D, TOC, Wet-Oxidation Method, referenced in Section 611.381.

"Standard Methods for the Examination of Water and Wastewater," 20<sup>th</sup> Edition, 1998 (referred to as "Standard Methods, 20<sup>th</sup> ed.").

Method 2130 B, Turbidity, Nephelometric Method, referenced in Section 611.531.

Method 2320 B, Alkalinity, Titration Method, referenced in Section 611.611.

# POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

Method 2510 B, Conductivity, Laboratory Method, referenced in Section 611.611.

Method 2550, Temperature, Laboratory, and Field Methods, referenced in Section 611.611.

Method 3120 B, Metals by Plasma Emission Spectroscopy, Inductively Coupled Plasma (ICP) Method, referenced in Sections 611.611 and 611.612.

Method 3125. Metals by Inductively Coupled Plasma/Mass Spectrometry, referenced in Sections 611.720.

Method 3500-Ca B, Calcium, EDTA Titrimetric Method, referenced in Section 611.611.

Method 3500-Mg B, Magnesium, EDTA Titrimetric Method, referenced in Section 611.611.

Method 4110 B, Determination of Anions by Ion Chromatography, Ion Chromatography with Chemical Suppression of Eluent Conductivity, referenced in Section 611.611.

Method 4500-CN C, Cyanide, Total Cyanide after Distillation, referenced in Section 611.611.

Method 4500-CN E, Cyanide, Colorimetric Method, referenced in Section 611.611.

Method 4500-CN-F, Cyanide, Cyanide-Selective Electrode Method, referenced in Section 611.611.

Method 4500-CN-G, Cyanide, Cyanides Amenable to Chlorination after Distillation, referenced in Section 611.611.

Method 4500-Cl D, Chlorine, Amperometric Titration Method, referenced in Section 611.531.

# POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

Method 4500-Cl E, Chlorine, Low-Level Amperometric Titration Method, referenced in Section 611.531.

Method 4500-Cl F, Chlorine, DPD Ferrous Titrimetric Method, referenced in Section 611.531.

Method 4500-Cl G, Chlorine, DPD Colorimetric Method, referenced in Section 611.531.

Method 4500-Cl H, Chlorine, Syringaldazine (FACTS) Method, referenced in Section 611.531.

Method 4500-Cl I, Chlorine, Iodometric Electrode Method, referenced in Section 611.531.

Method 4500-ClO<sub>2</sub> C, Chlorine Dioxide, Amperometric Method I, referenced in Section 611.531.

Method 4500-ClO<sub>2</sub> D, Chlorine Dioxide, DPD Method, referenced in Section 611.531.

Method 4500-ClO<sub>2</sub> E, Chlorine Dioxide, Amperometric Method II (Proposed), referenced in Section 611.531.

Method 4500-F $\stackrel{\frown}{=}$  B, Fluoride, Preliminary Distillation Step, referenced in Section 611.611.

Method 4500-F C, Fluoride, Ion-Selective Electrode Method, referenced in Section 611.611.

Method 4500- $F_{-2}^{-2}$  D, Fluoride, SPADNS Method, referenced in Section 611.611.

Method 4500-F = E, Fluoride, Complexone Method, referenced in Section 611.611.

Method 4500-H<sup>+</sup> B, pH Value, Electrometric Method, referenced in Section 611.611.

# POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

Method 4500-NO<sub>2</sub>-B, Nitrogen (Nitrite), Colorimetric Method, referenced in Section 611.611.

Method 4500-NO<sub>3</sub> D, Nitrogen (Nitrate), Nitrate Electrode Method, referenced in Section 611.611.

Method 4500-NO<sub>3</sub>— E, Nitrogen (Nitrate), Cadmium Reduction Method, referenced in Section 611.611.

Method 4500-NO<sub>3</sub>-<sup>2</sup> F, Nitrogen (Nitrate), Automated Cadmium Reduction Method, referenced in Section 611.611.

Method 4500-O<sub>3</sub> B, Ozone (Residual) (Proposed), Indigo Colorimetric Method, referenced in Section 611.531.

Method 4500-P E, Phosphorus, Ascorbic Acid Method, referenced in Section 611.611.

Method 4500-P F, Phosphorus, Automated Ascorbic Acid Reduction Method, referenced in Section 611.611.

Method 4500-Si C, Silica, Molybdosilicate Method, referenced in Section 611.611.

Method 4500-Si D, Silica, Heteropoly Blue Method, referenced in Section 611.611.

Method 4500-Si E, Silica, Automated Method for Molybdate-Reactive Silica, referenced in Section 611.611.

Method 5310 B, TOC, Combustion-Infrared Method, referenced in Section 611.381.

Method 5310 C, TOC, Persulfate-Ultraviolet Oxidation Method, referenced in Section 611.381.

## POLLUTION CONTROL BOARD

### NOTICE OF PROPOSED AMENDMENTS

Method 5310 D, TOC, Wet-Oxidation Method, referenced in Section 611.381.

Method 5910 B, UV-Absorbing Organic Constituents, Ultraviolet Absorption Method, referenced in Sections 611.381 and 611.382.

Method 6251, Disinfection By-Products: Haloacetic Acids and Trichlorophenol, referenced in Section 611.381.

Method 6610, Carbamate Pesticide Method, referenced in Section 611.645.

Method 6651, Glyphosate Herbicide (Proposed), referenced in Section 611.645.

Method 7110 B, Gross Alpha and Gross Beta Radioactivity, Evaporation Method for Gross Alpha-Beta, referenced in Section 611.720.

Method 7110 C, Gross Alpha and Beta Radioactivity (Total, Suspended, and Dissolved), Coprecipitation Method for Gross Alpha Radioactivity in Drinking Water (Proposed), referenced in Section 611.720.

Method 7120, Gamma-Emitting Radionuclides, referenced in Section 611.720.

Method 7500-Cs B, Radioactive Cesium, Precipitation Method, referenced in Section 611.720.

Method 7500-<sup>3</sup>H B, Tritium, Liquid Scintillation Spectrometric Method, referenced in Section 611.720.

Method 7500-I B, Radioactive Iodine, Precipitation Method, referenced in Section 611.720.

Method 7500-I C, Radioactive Iodine, Ion-Exchange Method, referenced in Section 611.720.

I

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

Method 7500-I D, Radioactive Iodine, Distillation Method, referenced in Section 611.720.

Method 7500-Ra B, Radium, Precipitation Method, referenced in Section 611.720.

Method 7500-Ra C, Radium, Emanation Method, referenced in Section 611.720.

Method 7500-Ra D, Radium, Sequential Precipitation Method, referenced in Section 611.720.

Method 7500-Sr B, Total Radioactive Strontium and Strontium 90, Precipitation Method, referenced in Section 611.720.

Method 7500-U B, Uranium, Radiochemical Method, referenced in Section 611.720.

Method 7500-U C, Uranium, Isotopic Method, referenced in Section 611.720.

Method 9215 B, Heterotrophic Plate Count, Pour Plate Method, referenced in Section 611.531.

Method 9221 A, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Introduction, referenced in Sections 611.526 and 611.531.

Method 9221 B, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Standard Total Coliform Fermentation Technique, referenced in Sections 611.526 and 611.531.

Method 9221 C, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Estimation of Bacterial Density, referenced in Sections 611.526 and 611.531.

# POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

Method 9221 D, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Presence-Absence (P-A) Coliform Test, referenced in Sections 611.526.

Method 9221 E, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Fecal Coliform Procedure, referenced in Sections 611.526 and 611.531.

Method 9221 F, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Escherichia Coli Procedure (Proposed), referenced in Section 611.802.

Method 9222 A, Membrane Filter Technique for Members of the Coliform Group, Introduction, referenced in Sections 611.526 and 611.531.

Method 9222 B, Membrane Filter Technique for Members of the Coliform Group, Standard Total Coliform Membrane Filter Procedure, referenced in Sections 611.526 and 611.531.

Method 9222 C, Membrane Filter Technique for Members of the Coliform Group, Delayed-Incubation Total Coliform Procedure, referenced in Sections 611.526 and 611.531.

Method 9222 D, Membrane Filter Technique for Members of the Coliform Group, Fecal Coliform Membrane Filter Procedure, referenced in Section 611.531.

Method 9222 G, Membrane Filter Technique for Members of the Coliform Group, MF Partition Procedures, referenced in Section 611.526.

Method 9223, Chromogenic Substrate Coliform Test (also referred to as the variations "Autoanalysis Colilert System" and "Colisure Test"), referenced in Sections 611.526 and 611.531.

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

Method 9223 B, Chromogenic Substrate Coliform Test (also referred to as the variations "Autoanalysis Colilert System" and "Colisure Test"), referenced in Sections 611.526, 611.802, and 611.1004.

Method 9230 B, Fecal Streptococcus and Enterococcus Groups, Multiple Tube Techniques, referenced in Section 611.802.

Method 9230 C, Fecal Streptococcus and Enterococcus Groups, Membrane Filter Techniques, referenced in Section 611.802.

"Standard Methods for the Examination of Water and Wastewater," 21<sup>st</sup> Edition, 2005 (referred to as "Standard Methods, 21<sup>st</sup> ed.").

Method 2130 B, Turbidity, Nephelometric Method, referenced in Section 611.531.

Method 2320 B, Alkalinity, Titration Method, referenced in Section 611.611.

Method 2510 B, Conductivity, Laboratory Method, referenced in Section 611.611.

Method 2550, Temperature, Laboratory, and Field Methods, referenced in Section 611.611.

Method 3111 B, Metals by Flame Atomic Absorption Spectrometry, Direct Air-Acetylene Flame Method, referenced in Sections 611.611 and 611.612.

Method 3111 D, Metals by Flame Atomic Absorption Spectrometry, Direct Nitrous Oxide-Acetylene Flame Method, referenced in Section 611.611.

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

Method 3112 B, Metals by Cold-Vapor Atomic Absorption Spectrometry, Cold-Vapor Atomic Absorption Spectrometric Method, referenced in Section 611.611.

Method 3113 B, Metals by Electrothermal Atomic Absorption Spectrometry, Electrothermal Atomic Absorption Spectrometric Method, referenced in Sections 611.611 and 611.612.

Method 3114 B, Metals by Hydride Generation/Atomic Absorption Spectrometry, Manual Hydride Generation/Atomic Absorption Spectrometric Method, referenced in Section 611.611.

Method 3120 B, Metals by Plasma Emission Spectroscopy, Inductively Coupled Plasma (ICP) Method, referenced in Sections 611.611 and 611.612.

Method 3125, Metals by Inductively Coupled Plasma/Mass Spectrometry, referenced in SectionsSection 611.720.

Method 3500-Ca B, Calcium, EDTA Titrimetric Method, referenced in Section 611.611.

Method 3500-Ca D, Calcium, EDTA Titrimetric Method, referenced in Section 611.611.

Method 3500-Mg B, Magnesium, Calculation Method, referenced in Section 611.611.

Method 4110 B, Determination of Anions by Ion Chromatography, Ion Chromatography with Chemical Suppression of Eluent Conductivity, referenced in Section 611.611.

Method 4500-Cl D, Chlorine, Amperometric Titration Method, referenced in Section 611.381.

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

Method 4500-Cl E, Chlorine, Low-Level Amperometric Titration Method, referenced in Section 611.381.

Method 4500-Cl F, Chlorine, DPD Ferrous Titrimetric Method, referenced in Section 611.381.

Method 4500-Cl G, Chlorine, DPD Colorimetric Method, referenced in Section 611.381.

Method 4500-Cl H, Chlorine, Syringaldazine (FACTS) Method, referenced in Section 611.381.

Method 4500-Cl I, Chlorine, Iodometric Electrode Method, referenced in Section 611.381.

Method 4500-ClO<sub>2</sub> C, Chlorine Dioxide, Amperometric Method I, referenced in Section 611.531.

Method 4500-ClO<sub>2</sub> E, Chlorine Dioxide, Amperometric Method II (Proposed), referenced in Section 611.381.

Method 4500-CN E, Cyanide, Colorimetric Method, referenced in Section 611.611.

Method 4500-CN F, Cyanide, Cyanide-Selective Electrode Method, referenced in Section 611.611.

Method 4500-CN<sup>--</sup> G, Cyanide, Cyanides Amenable to Chlorination after Distillation, referenced in Section 611.611.

Method 4500-F B, Fluoride, Preliminary Distillation Step, referenced in Section 611.611.

Method 4500-F<sup>-</sup> C, Fluoride, Ion-Selective Electrode Method, referenced in Section 611.611.

Method 4500-F= D, Fluoride, SPADNS Method, referenced in Section 611.611.

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

Method 4500-F E, Fluoride, Complexone Method, referenced in Section 611.611.

Method 4500-H<sup>+</sup> B, pH Value, Electrometric Method, referenced in Section 611.611.

Method 4500-NO<sub>2</sub> B, Nitrogen (Nitrite), Colorimetric Method, referenced in Section 611.611.

Method 4500-NO<sub>3</sub>- D, Nitrogen (Nitrate), Nitrate Electrode Method, referenced in Section 611.611.

Method 4500-NO<sub>3</sub>— E, Nitrogen (Nitrate), Cadmium Reduction Method, referenced in Section 611.611.

Method 4500-NO<sub>3</sub> F, Nitrogen (Nitrate), Automated Cadmium Reduction Method, referenced in Section 611.611.

Method 4500-O<sub>3</sub> B, Ozone (Residual) (Proposed), Indigo Colorimetric Method, referenced in Section 611.531.

Method 4500-P E, Phosphorus, Ascorbic Acid Method, referenced in Section 611.611.

Method 4500-P F, Phosphorus, Automated Ascorbic Acid Reduction Method, referenced in Section 611.611.

Method 4500-SiO<sub>2</sub> C, Silica, Molybdosilicate Method, referenced in Section 611.611.

Method 4500-SiO<sub>2</sub> D, Silica, Heteropoly Blue Method, referenced in Section 611.611.

Method 4500-SiO<sub>2</sub> E, Silica, Automated Method for Molybdate-Reactive Silica, referenced in Section 611.611.

### POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

Method 5310 B, TOC, Combustion-Infrared Method, referenced in Section 611.381.

Method 5310 C, TOC, Persulfate-Ultraviolet Oxidation Method, referenced in Section 611.381.

Method 5310 D, TOC, Wet-Oxidation Method, referenced in Section 611.381.

Method 5910 B, UV-Absorbing Organic Constituents, Ultraviolet Absorption Method, referenced in Sections 611.381 and 611.382.

Method 6251, Disinfection By-Products: Haloacetic Acids and Trichlorophenol, referenced in Section 611.381.

Method 6610, Method 6610 B, Carbamate Pesticide Method, referenced in Section 611.645.

Method 6640 B, Acidic Herbicide Compounds, Micro Liquid-Liquid Extraction Gas Chromatographic Method, referenced in Section 611.645.

Method 7110 B, Gross Alpha and Gross Beta Radioactivity, Evaporation Method for Gross Alpha-Beta, referenced in Section 611.720.

Method 7110 C, Gross Alpha and Beta Radioactivity (Total, Suspended, and Dissolved), Coprecipitation Method for Gross Alpha Radioactivity in Drinking Water (Proposed), referenced in Section 611.720.

Method 7120, Gamma-Emitting Radionuclides, referenced in Section 611.720.

Method 7500-Cs B, Radioactive Cesium, Precipitation Method, referenced in Section 611.720.

# POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

Method 7500-<sup>3</sup>H B, Tritium, Liquid Scintillation Spectrometric Method, referenced in Section 611.720.

Method 7500-I B, Radioactive Iodine, Precipitation Method, referenced in Section 611.720.

Method 7500-I C, Radioactive Iodine, Ion-Exchange Method, referenced in Section 611.720.

Method 7500-I D, Radioactive Iodine, Distillation Method, referenced in Section 611.720.

Method 7500-Ra B, Radium, Precipitation Method, referenced in Section 611.720.

Method 7500-Ra C, Radium, Emanation Method, referenced in Section 611.720.

Method 7500-Ra D, Radium, Sequential Precipitation Method, referenced in Section 611.720.

Method 7500-Sr B, Total Radioactive Strontium and Strontium 90, Precipitation Method, referenced in Section 611.720.

Method 7500-U B, Uranium, Radiochemical Method, referenced in Section 611.720.

Method 7500-U C, Uranium, Isotopic Method, referenced in Section 611.720.

Method 9221 A, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Introduction, referenced in Sections 611.526 and 611.531.

Method 9221 B, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Standard Total Coliform Fermentation Technique, referenced in Sections 611.526 and 611.531.

### POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

Method 9221 C, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Estimation of Bacterial Density, referenced in Sections 611.526 and 611.531.

Method 9221 D, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Presence-Absence (P-A) Coliform Test, referenced in Section 611.526.

Method 9221 E, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Fecal Coliform Procedure, referenced in Sections 611.526 and 611.531.

Method 9221 F, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Escherichia Coli Procedure (Proposed), referenced in Section 611.802.

Method 9222 A, Membrane Filter Technique for Members of the Coliform Group, Introduction, referenced in Sections 611.526 and 611.531.

Method 9222 B, Membrane Filter Technique for Members of the Coliform Group, Standard Total Coliform Membrane Filter Procedure, referenced in Sections 611.526 and 611.531.

Method 9222 C, Membrane Filter Technique for Members of the Coliform Group, Delayed-Incubation Total Coliform Procedure, referenced in Sections 611.526 and 611.531.

Method 9222 D, Membrane Filter Technique for Members of the Coliform Group, Fecal Coliform Membrane Filter Procedure, referenced in Section 611.531.

Method 9222 G, Membrane Filter Technique for Members of the Coliform Group, MF Partition Procedures, referenced in Section 611.526.

POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

Method 9223, Chromogenic Substrate Coliform Test (also referred to as the variations ""Autoanalysis Colilert System"" and "Colisure Test""), referenced in Sections 611.526 and 611.531.

Method 9223 B, Chromogenic Substrate Coliform Test (also referred to as the variations "Autoanalysis Colilert System" and "Colisure Test"), referenced in Sections 611.526,611.802, and 611.1004.

BOARD NOTE: See the Board note appended to Standard Methods Online in this Section about methods that appear in Standard Methods, 21<sup>st</sup> ed. which USEPA has cited as available from Standard Methods Online.

BOARD NOTE: Individual Methods from Standard Methods are available online from Standard Methods Online.

Analytical Technology, Inc. ATI Orion, 529 Main Street, Boston, MA 02129.

Technical Bulletin 601, "Standard Method of Testing for Nitrate in Drinking Water," July, 1994, PN 221890-001 (referred to as "Technical Bulletin 601"), referenced in Section 611.611.

ASTM. American Society for Testing and Materials, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959 (610-832-9585).

> ASTM Method D511-93 A and B, ""Standard Test Methods for Calcium and Magnesium in Water," "Test Method A—— Complexometric Titration" & ""Test Method B———Atomic Absorption Spectrophotometric," approved 1993, referenced in Section 611.611.

> ASTM Method D511-03 A and B, "Standard Test Methods for Calcium and Magnesium in Water," "Test Method A—\_\_\_ Complexometric Titration" & ""Test Method B—\_\_Atomic Absorption Spectrophotometric," approved 2003, referenced in Section 611.611.

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

ASTM Method D511-09 A and B, "Standard Test Methods for Calcium and Magnesium in Water," Test Method A—\_\_\_ Complexometric Titration" & ""Test Method B—\_\_\_Atomic Absorption Spectrophotometric," approved 2009, referenced in Section 611.611.

ASTM Method D515-88 A, "Standard Test Methods for Phosphorus in Water," "Test Method A———Colorimetric Ascorbic Acid Reduction," approved August 19, 1988, referenced in Section 611.611.

ASTM Method D859-94, "Standard Test Method for Silica in Water," approved 1994, referenced in Section 611.611.

ASTM Method D859-00, "Standard Test Method for Silica in Water," approved 2000, referenced in Section 611.611.

ASTM Method D859-05, "Standard Test Method for Silica in Water," approved 2005, referenced in Section 611.611.

ASTM Method D859-10, "Standard Test Method for Silica in Water," approved 2010, referenced in Section 611.611.

ASTM Method D1067-92 B, "Standard Test Methods for Acidity or Alkalinity in Water," Test Method B——Electrometric or Color-Change Titration," approved May 15, 1992, referenced in Section 611.611.

ASTM Method D1067-02 B, "Standard Test Methods for Acidity or Alkalinity in Water," Test Method B—\_\_\_Electrometric or Color-Change Titration," approved in 2002, referenced in Section 611.611.

ASTM Method D1067-06 B, "Standard Test Methods for Acidity or Alkalinity in Water," "Test Method B—\_\_Electrometric or Color-Change Titration," approved in 2006, referenced in Section 611.611.

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

ASTM Method D1125-95 (1999) A, "Standard Test Methods for Electrical Conductivity and Resistivity of Water," "Test Method A—\_\_\_\_Field and Routine Laboratory Measurement of Static (Non-Flowing) Samples," approved 1995, reapproved 1999, referenced in Section 611.611.

ASTM Method D1179-93 B, ""Standard Test Methods for Fluoride in Water," "Test Method B—\_\_\_Ion Selective Electrode," approved 1993, referenced in Section 611.611.

ASTM Method D1179-99 B, ""Standard Test Methods for Fluoride in Water," "Test Method B—\_\_\_Ion Selective Electrode,"" approved 1999, referenced in Section 611.611.

ASTM Method D1179-04 B, ""Standard Test Methods for Fluoride in Water," "Test Method B—\_\_\_Ion Selective Electrode,"" approved 2004, referenced in Section 611.611.

ASTM Method D1179-10 B, "Standard Test Methods for Fluoride in Water," "Test Method B——Ion Selective Electrode," approved 2010, referenced in Section 611.611.

ASTM Method D1253-86, "Standard Test Method for Residual Chlorine in Water," reapproved 1992, referenced in Section 611.381.

ASTM Method D1253-96, "Standard Test Method for Residual Chlorine in Water," approved 1996, referenced in Section 611.381.

ASTM Method D1253-03, "Standard Test Method for Residual Chlorine in Water," approved 2003, referenced in Sections 611.381 and 611.531.

ASTM Method D1253-08, "Standard Test Method for Residual Chlorine in Water," approved 2008, referenced in Sections 611.381 and 611.531.

ASTM Method D1293-95 A or B, "Standard Test Methods for pH

### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

of Water,<sup>22</sup>""Test Method A——Precise Laboratory Measurement<sup>20</sup> & "Test Method B——Routine or Continuous Measurement,<sup>20</sup>" approved 1995, referenced in Section 611.611.

ASTM Method D1293-99 A or B, "Standard Test Methods for pH of Water," "Test Method A—\_\_Precise Laboratory Measurement?" & "Test Method B—\_\_Routine or Continuous Measurement," approved 1999, referenced in Section 611.611.

ASTM Method D1688-02 A or C, "Standard Test Methods for Copper in Water," "Test Method A——Atomic Absorption, Direct?" & "Test Method C——Atomic Absorption, Graphite Furnace,?" approved 2002, referenced in Section 611.611.

ASTM Method D1688-07 A or C, "Standard Test Methods for Copper in Water," "Test Method A——Atomic Absorption, Direct?" & "Test Method C——Atomic Absorption, Graphite Furnace,?" approved 2007, referenced in Section 611.611.

ASTM Method D2036-98 A or B, "Standard Test Methods for Cyanide in Water," "Test Method A—\_Total Cyanides after Distillation" & "Test Method B—\_Cyanides Amenable to Chlorination by Difference," approved 1998, referenced in Section 611.611.

ASTM Method D2036-06 A or B, "Standard Test Methods for Cyanide in Water," "Test Method A—\_\_\_Total Cyanides after Distillation?" & "Test Method B—\_\_Cyanides Amenable to Chlorination by Difference," approved 2006, referenced in Section 611.611.

ASTM Method D2459-72, "Standard Test Method for Gamma Spectrometry in Water," approved July 28, 1972, discontinued 1988, referenced in Section 611.720.

### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

ASTM Method D2460-90, "Standard Test Method for Radionuclides of Radium in Water," approved 1990, referenced in Section 611.720.

ASTM Method D2460-07, ""Standard Test Method for Radionuclides of Radium in Water," approved 2007, referenced in Section 611.720.

ASTM Method D2907-91, ""Standard Test Methods for Microquantities of Uranium in Water by Fluorometry," "Test Method A—\_\_\_Direct Fluorometric<sup>32</sup>" & ""Test Method B—\_\_\_\_ Extraction,<sup>22</sup>" approved June 15, 1991, referenced in Section 611.720.

ASTM Method D2972-97 B or C, "Standard Test Methods for Arsenic in Water," "Test Method B—\_\_\_Atomic Absorption, Hydride Generation" & "Test Method C—\_\_Atomic Absorption, Graphite Furnace," approved 1997, referenced in Section 611.611.

ASTM Method D2972-03 B or C, "Standard Test Methods for Arsenic in Water," "Test Method B—\_\_\_Atomic Absorption, Hydride Generation" & "Test Method C—\_\_Atomic Absorption, Graphite Furnace," approved 2003, referenced in Section 611.611.

ASTM Method D2972-08 B or C, "Standard Test Methods for Arsenic in Water," "Test Method B———Atomic Absorption, Hydride Generation?" & "Test Method C———Atomic Absorption, Graphite Furnace,?" approved 2008, referenced in Section 611.611.

ASTM Method D3223-97, "Standard Test Method for Total Mercury in Water," approved 1997, referenced in Section 611.611.

ASTM Method D3223-02, "Standard Test Method for Total Mercury in Water," approved 2002, referenced in Section 611.611.

ASTM Method D3454-97, "Standard Test Method for

# POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

Radium-226 in Water,<sup>22</sup> approved 1997, referenced in Section 611.720.

ASTM Method D3454-05, "Standard Test Method for Radium-226 in Water," approved 2005, referenced in Section 611.720.

ASTM Method D3559-96 D, "Standard Test Methods for Lead in Water," "Test Method D——Atomic Absorption, Graphite Furnace," approved August 6, 1990, referenced in Section 611.611.

ASTM Method D3559-03 D, "Standard Test Methods for Lead in Water," "Test Method D——Atomic Absorption, Graphite Furnace," approved 2003, referenced in Section 611.611.

ASTM Method D3559-08 D, "Standard Test Methods for Lead in Water," "Test Method D—\_\_\_Atomic Absorption, Graphite Furnace," approved 2008, referenced in Section 611.611.

ASTM Method D3645-97 B, "Standard Test Methods for Beryllium in Water," "Method B—\_\_\_Atomic Absorption, Graphite Furnace," approved 1997, referenced in Section 611.611.

ASTM Method D3645-03 B, ""Standard Test Methods for Beryllium in Water," "Method B—\_\_\_Atomic Absorption, Graphite Furnace," approved 2003, referenced in Section 611.611.

ASTM Method D3645-08 B, "Standard Test Methods for Beryllium in Water," "Method B—\_\_\_Atomic Absorption, Graphite Furnace," approved 2008, referenced in Section 611.611.

ASTM Method D3649-91, "Standard Test Method for High-Resolution Gamma-Ray Spectrometry of Water," approved 1991, referenced in Section 611.720.

ASTM Method D3649-98a, "Standard Test Method for High-Resolution Gamma-Ray Spectrometry of Water," approved 1998, referenced in Section 611.720.

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

ASTM Method D3649-06, "Standard Test Method for High-Resolution Gamma-Ray Spectrometry of Water," approved 2006, referenced in Section 611.720.

ASTM Method D3697-92, ""Standard Test Method for Antimony in Water," approved June 15, 1992, referenced in Section 611.611.

ASTM Method D3697-02, "Standard Test Method for Antimony in Water," approved 2002, referenced in Section 611.611.

ASTM Method D3697-07, "Standard Test Method for Antimony in Water," approved 2007, referenced in Section 611.611.

ASTM Method D3859-98 A, ""Standard Test Methods for Selenium in Water," "Method A—\_\_\_Atomic Absorption, Hydride Method," approved 1998, referenced in Section 611.611.

ASTM Method D3859-03 A, ""Standard Test Methods for Selenium in Water," "Method A—\_\_\_Atomic Absorption, Hydride Method," approved 2003, referenced in Section 611.611.

ASTM Method D3859-08 A, "Standard Test Methods for Selenium in Water," "Method A———Atomic Absorption, Hydride Method<sup>22</sup>" & "Method B———Atomic Absorption, Graphite Furnace,<sup>22</sup>" approved 2008, referenced in Section 611.611.

ASTM Method D3867-90 A and B, "Standard Test Methods for Nitrite-Nitrate in Water," "Test Method A——Automated Cadmium Reduction?" & "Test Method B——Manual Cadmium Reduction," approved January 10, 1990, referenced in Section 611.611.

ASTM Method D3972-90, "Standard Test Method for Isotopic Uranium in Water by Radiochemistry," approved 1990, referenced in Section 611.720.

### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

ASTM Method D3972-02, "Standard Test Method for Isotopic Uranium in Water by Radiochemistry," approved 2002, referenced in Section 611.720.

ASTM Method D4107-91, "Standard Test Method for Tritium in Drinking Water," approved 1991, referenced in Section 611.720.

ASTM Method D4107-98, "Standard Test Method for Tritium in Drinking Water," approved 1998 (reapproved 2002), referenced in Section 611.720.

ASTM Method D4107-08, "Standard Test Method for Tritium in Drinking Water," approved 2008 (reapproved 2002), referenced in Section 611.720.

ASTM Method D4327-97, ""Standard Test Method for Anions in Water by Ion Chromatography," approved 1997, referenced in Section 611.611.

ASTM Method D4327-03, "Standard Test Method for Anions in Water by Ion Chromatography," approved 2003, referenced in Section 611.611.

ASTM Method D4785-93, "Standard Test Method for Low-Level Iodine-131 in Water," approved 1993, referenced in Section 611.720.

ASTM Method D4785-98, "Standard Test Method for Low-Level Iodine-131 in Water," approved 1998, referenced in Section 611.720.

ASTM Method D4785-08, "Standard Test Method for Low-Level Iodine-131 in Water," approved 2008, referenced in Section 611.720.

ASTM Method D5174-97, ""Standard Test Method for Trace Uranium in Water by Pulsed-Laser Phosphorimetry,"" approved 1997, referenced in Section 611.720.

### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

ASTM Method D5174-02, "Standard Test Method for Trace Uranium in Water by Pulsed-Laser Phosphorimetry," approved 2002, referenced in Section 611.720.

ASTM Method D5174-07, "Standard Test Method for Trace Uranium in Water by Pulsed-Laser Phosphorimetry," approved 2007, referenced in Section 611.720.

ASTM Method D5317-93, "Standard Test Method for Determination of Chlorinated Organic Acid Compounds in Water by Gas Chromatography with an Electron Capture Detector," approved 1993, referenced in Section 611.645.

ASTM Method D5317-98, ""Standard Test Method for Determination of Chlorinated Organic Acid Compounds in Water by Gas Chromatography with an Electron Capture Detector,"" approved 1998 (reapproved 2003), referenced in Section 611.645.

ASTM Method D5673-03, "Standard Test Method for Elements in Water by Inductively Coupled Plasma—\_\_Mass Spectrometry," approved 2003, referenced in Section 611.720.

ASTM Method D5673-05, ""Standard Test Method for Elements in Water by Inductively Coupled Plasma——Mass Spectrometry,"" approved 2005, referenced in Section 611.720.

ASTM Method D5673-10, "Standard Test Method for Elements in Water by Inductively Coupled Plasma——Mass Spectrometry," approved 2010, referenced in Section 611.720.

ASTM Method D6239-09, "Standard Test Method for Uranium in Drinking Water by High-Resolution Alpha-Liquid-Scintillation Spectrometry," approved 2009, referenced in Section 611.720.

ASTM Method D6508-00(2005), "Standard Test Method for Determination of Dissolved Inorganic Anions in Aqueous Matrices Using Capillary Ion Electrophoresis and Chromate Electrolyte," approved 2000 (revised 2005), referenced in Section 611.611.

## POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

ASTM Method D6581-00, "Standard Test Method for Bromate, Bromide, Chlorate, and Chlorite in Drinking Water by Chemically Suppressed Ion Chromatography," approved 2000, referenced in Section 611.381.

ASTM Method D6581-08 A and B, ""Standard Test Method for Bromate, Bromide, Chlorate, and Chlorite in Drinking Water by Suppressed Ion Chromatography," "Test Method A—\_\_\_\_ Chemically Suppressed Ion Chromatography" & ""Test Method B—\_\_Electrolytically Suppressed Ion Chromatography," approved 2008, referenced in Section 611.381.

ASTM Method D6919-03, "Standard Test Method for Determination of Dissolved Alkali and Alkaline Earth Cations and Ammonium in Water and Wastewater by Ion Chromatography," approved 2003, referenced in Section 611.611.

ASTM Method D6919-09, "Standard Test Method for Determination of Dissolved Alkali and Alkaline Earth Cations and Ammonium in Water and Wastewater by Ion Chromatography," approved 2009, referenced in Section 611.611.

ASTM Method D6888-04, "Standard Test Method for Available Cyanide with Ligand Displacement and Flow Injection Analysis (FIA) Utilizing Gas Diffusion Separation and Amperometric Detection," approved 2004, referenced in Section 611.611.

BOARD NOTE: The most recent version of ASTM methods are available for paid download from the ASTM at www.astm.org. Note that the most recent version of an ASTM method may not be the version approved for use by USEPA and incorporated by reference in subsection (b) of this Section.

Bran & Luebbe, 1025 Busch Parkway, Buffalo Grove, IL 60089.

"\_Fluoride in Water and Wastewater," Industrial Method #129-71W, December 1972 (referred to as "Technicon Methods, Method #129-71W"). See 40 CFR 141.23(k)(1), footnote 11 (2011). (2012), referenced in Section 611.611.

### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

"Fluoride in Water and Wastewater," #380-75WE, February 1976 (referred to as "Technicon Methods, Method #380-75WE"). See 40 CFR 141.23(k)(1), footnote 11 (2011) (2012), referenced in Section 611.611.

Charm Sciences, Inc., 659 Andover St., Lawrence, MA 01843-1032:

"Charm E\*Colite Presence/Absence Test for Detection and Identification of Coliform Bacteria and Escherichia coli in Drinking Water," January 9, 1998 (referred to as "E\*Colite Test"), referenced in Section 611.802 (also available from USEPA, Water Resource Center).

CPI International, Inc., 5580 Skylane Blvd., Santa Rosa, CA 95403 (800-878-7654 /fax: 707-545-7901/Internet address: www.cpiinternational.com).

"Colitag® Product as a Test for Detection and Identification of Coliforms and E. coli Bacteria in Drinking Water and Source Water as Required in National Primary Drinking Water Regulations,<sup>21</sup> August 2001, referenced in Section 611.526.

"Modified Colitag<sup>™</sup> Test Method for Simultaneous Detection of E. coli and other Total Coliforms in Water (ATP D05-0035)," August 2009 (referred to as "Modified Colitag<sup>™</sup> Method"), referenced in Sections 611.526 and 611.802. See also NEMI.

EMD Chemicals Inc. (an affiliate of Merck KGgA, Darmstadt, Germany), 480 S. Democrat Road, Gibbstown, NJ 08027–1297. (800-222–20342/e-mail: adellenbusch@emscience.com).

> "Chromocult® Coliform Agar Presence/Absence Membrane Filter Test Method for Detection and Identification of Coliform Bacteria and Escherichia coli in Finished Waters," November 2000 referred to as "Chromocult® Method, Version 1.0, referenced in Sections 611.526 and 611.802.

### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

""Readycult Coliforms 100 Presence/Absence Test for Detection and Identification of Coliform Bacteria and Escherichia coli in Finished Waters," November 2000 (referred to as Readycult® 2000), Version 1.0, referenced in Section 611.526.

""Readycult Coliforms 100 Presence/Absence Test for Detection and Identification of Coliform Bacteria and Escherichia coli in Finished Waters," Version 1.1, January 2007 (referred to as Readycult® 2007), referenced in Section 611.802.

Georgia Tech Research Institute, Robert Rosson, 925 Dalney Road, Atlanta, GA 30332 (404-407 -6339).

""The Determination of Radium-226 and Radium-228 in Drinking Water by Gamma-ray Spectrometry Using HPGE or Ge(Li) Detectors," Revision 1.2, December 2004 (called "Georgia Radium Method"), referenced in Section 611.720.

Great Lakes Instruments, Inc., 8855 North 55<sup>th</sup> Street, Milwaukee, WI 53223.

GLI Method 2, "Turbidity," Nov. 2, 1992, referenced in Section 611.531.

H&E Testing Laboratory, 221 State Street, Augusta, ME 04333 (207-287-2727).

Method ME355.01, Revision 1, "Determination of Cyanide in Drinking Water by GC/MS Headspace Analysis," May 2009, referenced in Section 611.611. See also NEMI.

The Hach Company, P.O. Box 389, Loveland, CO 80539-0389 (800-227-4224/Internet address: www.hach.com).

"Lead in Drinking Water by Differential Pulse Anodic Stripping Voltammetry," Method 1001, August 1999, referenced in Section 611.611.

## POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

"Determination of Turbidity by Laser Nephelometry," January 2000, Revision 2.0 (referred to as "Hach FilterTrak Method 10133"), referenced in Section 611.531.

"Total Coliforms and E. coli Membrane Filtration Method with m-ColiBlue24® Broth," Method No. 10029, Revision 2, August 17, 1999 (referred to as "m-ColiBlue24 Test"), referenced in Section 611.802 (also available from USEPA, Water Resource Center).

"Fluoride, USEPA SPADNS 2 Method 10225," revision 2.0, January 2011 (referred to as "Hach SPADNS 2 Method 10225"), referenced in Section 611.611.

""Hach Company TNTplus 835/836 Nitrate Method 10206—\_\_\_\_\_ Spectrophotometric Measurement of Nitrate in Water and Wastewater,"" revision 2.0, January 2011 (referred to as ""Hach TNTplus 835/836 Method 10206""), referenced in Section 611.611.

IDEXX Laboratories, Inc., One IDEXX Drive, Westbrook, Maine 04092 (800-321-0207).

"IDEXX SimPlate TM HPC Test Method for Heterotrophs in Water," November 2000 (referred to as "SimPlate method"), referenced in Section 611.531.

Industrial Test Systems, Inc., 1875 Langston St., Rock Hill, SC 29730.

Method D99-003, Revision 3.0, "Free Chlorine Species (HOCI and OCI") by Test Strip," November 21, 2003 (referred to as "ITS Method D99-003"), referenced in Section 611.381.

Lachat Instruments, 6645 W. Mill Rd., Milwaukee, WI 53218 (414-358-4200).

""Digestion and distillation of total cyanide in drinking and wastewaters using MICRO DIST and determination of cyanide by flow injection analysis,"" Revision 2.1, November 30, 2000

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

(referred to as "QuikChem Method 10-204-00-1-X"), referenced in Section 611.611.

Leck Mitchell, PhD, PE, 656 Independence Valley Dr., Grand Junction, CO 81507. See also NEMI.

Mitchell Method M5271, "Determination of Turbidity by Laser Nephelometry," March 2009, referenced in Section 611.531.

Mitchell Method M5331, "Determination of Turbidity by LED Nephelometry," March 2009, referenced in Section 611.531.

Millipore Corporation, Technical Services Department, 80 Ashby Road, Milford, MA 01730 (800-654-5476).

Colisure Presence/Absence Test for Detection and Identification of Coliform Bacteria and Escherichia Coli in Drinking Water, February 28, 1994 (referred to as "Colisure Test"), referenced in Section 611.526.

NCRP. National Council on Radiation Protection, 7910 Woodmont Ave., Bethesda, MD (301-657-2652).

NCRP Report Number 22, "Maximum Permissible Body Burdens and Maximum Permissible Concentrations of Radionuclides in Air and in Water for Occupational Exposure," NCRP Report Number 22, June 5, 1959, referenced in Section 611.101.

NEMI. National Environmental Method Index (on-line at www.nemi.gov).

AMI Turbiwell Method, "Continuous Measurement of Turbidity Using a SWAN AMI Turbiwell Turbidimeter," August 2009. See also SWAN Analytische Instrumente AG.

Method ME355.01, Revision 1, ""Determination of Cyanide in Drinking Water by GC/MS Headspace Analysis," May 2009, referenced in Section 611.611. See also H&E Testing Laboratory.

### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

Mitchell Method M5271, "Determination of Turbidity by Laser Nephelometry," March 2009, referenced in Section 611.531. See also Leck Mitchell, PhD, PE.

Mitchell Method M5331, "Determination of Turbidity by LED Nephelometry," March 2009, referenced in Section 611.531. See also Leck Mitchell, PhD, PE

Modified Colitag<sup>™</sup> Method, ""Modified Colitag<sup>™</sup> Test Method for Simultaneous Detection of E. coli and other Total Coliforms in Water (ATP D05-0035)," August 2009, referenced in Sections 611.526 and 611.802. See also CPI International, Inc.

Orion Method AQ4500, "Determination of Turbidity by LED Nephelometry," May 2009, referenced in Section 611.531. See also Thermo Scientific.

Palintest ChloroSense, "Measurement of Free and Total Chlorine in Drinking Water by Palintest ChloroSense," September 2009 (referred to as "Palintest ChloroSense"), referenced in Sections 611.381 and 611.531. See also Palintest.

"Systea Easy (1-Reagent) Nitrate Method," referenced in Section 611.611. See also Systea Scientific, LLC.

NSF. National Sanitation Foundation International, 3475 Plymouth Road, PO Box 130140, Ann Arbor, Michigan 48113-0140 (734-769-8010).

NSF Standard 61, section 9, November 1998, referenced in Sections 611.126 and 611.356.

NTIS. National Technical Information Service, U.S. Department of Commerce, <u>5285 Port Royal Road, Springfield, VA 22161 (703-487-4600or 800-553-6847)</u>5301 Shawnee Road, Alexandria, VA 22312 (703-605-6000 or 800-553-6847, www.ntis.gov).

> Dioxin and Furan Method 1613, Revision B, "Tetra- through Octa-Chlorinated Dioxins and Furans by Isotope Dilution HRGC/HRMS," October 1994, Revision B, EPA 821/B-94/005,

### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

Doc. No. 94-104774, referenced in Section 611.645. See also USEPA, NSCEP.

Kelada 01, "Kelada Automated Test Methods for Total Cyanide, Acid Dissociable Cyanide, and Thiocyanate,<sup>22"</sup> Revision 1.2, August 2001, EPA 821/B-01-009, referenced in Section 611.611.

"Maximum Permissible Body Burdens and Maximum Permissible Concentrations of Radionuclides in Air and in Water for Occupational Exposure," NBS (National Bureau of Standards) Handbook 69, as amended August 1963, U.S. Department of Commerce, referenced in Section 611.330.

> "Procedures for Radiochemical Analysis of Nuclear Reactor Aqueous Solutions," H.L. Krieger and S. Gold, EPA-R4-73-014, May 1973, Doc. No. PB222-154/7BA, referenced in Section 611.720.

> USEPA Asbestos Method 100.1, "Analytical Method for Determination of Asbestos Fibers in Water," EPA 600/4-83-043. September 1983, Doc. No. PB83-260471, referenced in Section 611.611. See also USEPA, NSCEP.

USEPA Asbestos Method 100.2, "Determination of Asbestos Structures over 10-mm in Length in Drinking Water," EPA 600/R-94-134, June 1994, Doc. No. PB94-201902, referenced in Section 611.611. See also USEPA, NSCEP.

USEPA Environmental Inorganic Methods, "Methods for the Determination of Inorganic Substances in Environmental Samples," August 1993, EPA 600/R-93-100, Doc. No. PB94-121811, referenced in Sections 611.381, 611.531, and 611.611. (Methods 180.1 (rev. 2.0), 300.0 (rev. 2.1), 335.4 (rev. 1.0), 353.2 (rev. 2.0), and 365.1 (rev. 2.0) only.) See also USEPA, NSCEP.

USEPA Environmental Metals Methods, ""Methods for the Determination of Metals in Environmental Samples—\_\_\_\_\_ Supplement I,"" May 1994, EPA 600/R-94-111, Doc. No.

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

PB95-125472, referenced in Sections 611.611, 611.612, and 611.720. (Methods 200.7 (rev. 4.4), 200.8 (rev. 5.3), 200.9 (rev. 2.2), and 245.1 (rev. 3.0) only.) See also USEPA, NSCEP.

USEPA Inorganic Methods, ""Methods for Chemical Analysis of Water and Wastes," March 1983, EPA 600/4-79-020, Doc. No. PB84-128677, referenced in Section 611.611. (Methods 150.1, 150.2, and 245.2 only.) See also USEPA, NSCEP.

USEPA Interim Radiochemical Methods, "Interim Radiochemical Methodology for Drinking Water," EPA 600/4-75-008 (revised), Doc. No. PB253258, March 1976, referenced in Section 611.720.

USEPA OGWDW Methods, Method 326.0, Revision 1.0, "Determination of Inorganic Oxyhalide Disinfection By-Products in Drinking Water Using Ion Chromatography Incorporating the Addition of a Suppressor Acidified Postcolumn Reagent for Trace Bromate Analysis," June 2002, EPA 815/R-03/007, Doc. No. PB2003-107402, referenced in Sections 611.381 and 611.382. See also USEPA, NSCEP and USEPA, OGWDW.

USEPA Organic and Inorganic Methods, ""Methods for the Determination of Organic and Inorganic Compounds in Drinking Water, Volume 1," August 2000, EPA 815/R-00/014, Doc. No. PB2000-106981, referenced in Section 611.381. (For methods 300.1 (rev. 1.0) and 321.8 (rev. 1.0).) See also USEPA, NSCEP.

USEPA Organic Methods, ""Methods for the Determination of Organic Compounds in Drinking Water," December 1988 (revised July 1991), EPA 600/4-88/039, Doc. No. PB91-231480, referenced in Sections 611.645 and 611.648 (Methods 508A (rev. 1.0) and 515.1 (rev. 4.0) only); "Methods for the Determination of Organic Compounds in Drinking Water Supplement I," July 1990, EPA 600/4-90/020, Doc. No. PB91-146027, referenced in Section 611.645 (Methods 547, 550, and 550.1 only); "Methods for the Determination of Organic Compounds in Drinking Water 547, 550, and 550.1 only); "Methods for the Determination of Organic Compounds in Drinking Water 547, 550, and 550.1 only); "Methods for the Determination of Organic Compounds in Drinking Water 547, 550, and 550.1 only); "Methods for the Determination of Organic Compounds in Drinking Water 547, 550, and 550.1 only); "Methods for the Methods 548.1 (rev. 1.0), 552.1 (rev. 1.0), and 555 (rev. 1.0)

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

only); and "Methods for the Determination of Organic Compounds in Drinking Water—\_\_\_Supplement III," August 1995, EPA 600/R-95/131, Doc. No. PB95-261616, referenced in Sections 611.381, 611.645, and 611.648 (Methods 502.2 (rev. 2.1), 504.1 (rev. 1.1), 505 (rev. 2.1), 506 (rev. 1.1), 507 (rev. 2.1), 508 (rev. 3.1), 508.1 (rev. 2.0), 515.2 (rev. 1.1), 524.2 (rev. 4.1), 525.2 (rev. 2.0), 531.1 (rev. 3.1), 551.1 (rev. 1.0), and 552.2 (rev. 1.0) only.) See also USEPA, EMSL and USEPA, NSCEP.

USEPA Radioactivity Methods, "Prescribed Procedures for Measurement of Radioactivity in Drinking Water," EPA 600/4-80/032, August 1980, Doc. No. PB80-224744, referenced in Section 611.720 (Methods 900.0, 901.0, 901.1, 902.0, 903.0, 903.1, 904.0, 905.0, 906.0, 908.0, 908.1). See also USEPA, NSCEP.

USEPA Radiochemical Analyses, "Radiochemical Analytical Procedures for Analysis of Environmental Samples," March 1979, Doc. No. EMSL LV 053917, referenced in Section 611.720. (Pages 1-5, 19-32, 33-48, 65-73, 87-91, and 92-95 only.)

USEPA Radiochemistry Procedures, "Radiochemistry Procedures Manual," EPA 520/5-84-006, August 1984, Doc. No. PB84-215581 (referred to as """), referenced in Section 611.720. (Methods 00-01, 00-02, 00-07, H-02, Ra-03, Ra-04, Ra-05, Sr-04 only.)

USEPA Technical Notes, "Technical Notes on Drinking Water Methods," EPA 600/R-94/173, October 1994, Doc. No. PB95-104766, referenced in Sections 611.531, 611.611, and 611.645. See also USEPA, NSCEP.

BOARD NOTE: USEPA made the following assertion with regard to this reference at 40 CFR 141.23(k)(1) and 141.24(e) and (n)(11<del>)</del>-(2011) (2012): "This document contains other analytical test procedures and approved analytical methods that remain available for compliance monitoring until July 1, 1996." Also available online at http://nepis.epa.gov/EPA///html/Pubs/pubtitleORD.htm under the document designation "600R94173."

## POLLUTION CONTROL BOARD

### NOTICE OF PROPOSED AMENDMENTS

New Jersey Department of Environment, Division of Environmental Quality, Bureau of Radiation and Inorganic Analytical Services, 9 Ewing Street, Trenton, NJ 08625.

"Determination of Radium 228 in Drinking Water," August 1990 (referred to as "New Jersey Radium Method"), referenced in Section 611.720.

New York Department of Health, Radiological Sciences Institute, Center for Laboratories and Research, Empire State Plaza, Albany, NY 12201.

"Determination of Ra-226 and Ra-228 (Ra-02)," January 1980, Revised June 1982 (referred to as "New York Radium Method"), referenced in Section 611.720.

Palintest, Ltd., 21 Kenton Lands Road, P.O. Box 18395, Erlanger, KY (800-835-9629).

Palintest Method 1001, "Lead in Drinking Water by Differential Pulse Anodic Stripping Voltammetry," Method 1001, August 1999, referenced in Section 611.611.

Palintest ChloroSense, ""Measurement of Free and Total Chlorine in Drinking Water by Palintest ChloroSense," September 2009, referenced in Sections 611.381 and 611.531. See also NEMI.

Standard Methods Online, available online from the Standard Methods Organization at www.standardmethods.org.

> Method 3112 B-09, Metals by Cold-Vapor Atomic Absorption Spectrometry, Cold-Vapor Atomic Absorption Spectrometric Method, referenced in Section 611.611.

Method 3113 B-04, Metals by Electrothermal Atomic Absorption Spectrometry, Electrothermal Atomic Absorption Spectrometric Method, referenced in Sections 611.611 and 611.612.

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

Method 3114 B-04, Metals by Hydride Generation/Atomic Absorption Spectrometry, Manual Hydride Generation/Atomic Absorption Spectrometric Method, referenced in Section 611.611.

Method 6610 B-04, Carbamate Pesticides, High-Performance Liquid Chromatographic Method, referenced in Section 611.645.

Method 9230 B-04, Fecal Streptococcus and Enterococcus Groups, Multiple Tube Techniques, referenced in Section 611.802.

BOARD NOTE: Where, in appendix A to subpart C of 40 CFR 141 (2011) (2012), USEPA has authorized use of an approved alternative method from Standard Methods Online, and that version of the method appears also in Standard Methods, 21<sup>st</sup> ed., the Board cites only to Standard Methods, 21<sup>st</sup> ed. for that method. The methods that USEPA listed as available from Standard Methods Online, and which are listed above as in Standard Methods, 21st edition, are the following: 4500-P E-99 and 4500-P F-99; (for orthophosphate);  $4500-SO_4$ ; C-97,  $4500-SO_4$ ; D-97, 4500-SO<sub>4</sub><sup>2</sup> E-97, and 4500-SO<sub>4</sub><sup>-2</sup> F-97 (for sulfate); 6640 B-01 (for 2,4-D, 2,4,5-TP (silvex); (dalapon, dinoseb, pentachlorophenol, and picloram); 5561 B-00 (for glyphosate); and 9223 B-97 (for E. coli). Since each method is the same version from both sources, the Board views a copy from Standard Methods Online as equivalent to a copy from Standard Methods Online, even though the Board does not also cite to Standard Methods Online. The Board intends that use of the version of the method that is incorporated by reference is acceptable from either source.

SWAN Analytische Instrumente AG, Studbachstrasse 13, CH-8340, Hinwil, Switzerland.

AMI Turbiwell Method, "Continuous Measurement of Turbidity Using a SWAN AMI Turbiwell Turbidimeter," August 2009, referenced in Section 611.531. See also NEMI.

Syngenta Crop Protection, Inc., 410 Swing Road, Post Office Box 18300, Greensboro, NC 27419 (336-632-26000).

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

"Atrazine in Drinking Water by Immunoassay," February 2001 (referred to as "Syngenta AG-625<sup>22</sup>"), referenced in Section 611.645.

Systea Scientific LLC, 900 Jorie Blvd., Suite 35, Oak Brook, IL 60523.

Systea Easy (1-Reagent), "Systea Easy (1-Reagent) Nitrate Method," February 2009, referenced in Section 611.611. See also NEMI.

Thermo Scientific, 166 Cummings Center, Beverly, MA 01915 (www.thermo.com).

Orion Method AQ4500, "Determination of Turbidity by LED Nephelometry," May 2009, referenced in Section 611.531. See also NEMI.

USDOE, EML. United States Department of Energy, Environmental Measurements Laboratory, U.S. Department of Energy, 376 Hudson Street, New York, NY 10014-3621.

"EML Procedures Manual," HASL 300, 27th Edition, Volume 1, 1990 (referred to as "EML Procedures Manual (27th ed.)"), referenced in Section 611.720.

""EML Procedures Manual," HASL 300, 28<sup>th</sup> ed., 1997 (referred to as "EML Procedures Manual (28<sup>th</sup> ed.)"), referenced in Section 611.720.

USEPA, EMSL. United States Environmental Protection Agency, Environmental Monitoring and Support Laboratory, Cincinnati, OH 45268 (513-569-7586).

USEPA Interim Radiochemical Methods, "Interim Radiochemical Methodology for Drinking Water," EPA 600/4-75/008 (revised), March 1976, referenced in Section 611.720. See also NTIS.

USEPA Organic Methods, "Methods for the Determination of Organic Compounds in Drinking Water," December 1988 (revised

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

July 1991), EPA 600/4-88/039, referenced in Sections 611.645 and 611.648 (Methods 508A (rev. 1.0) and 515.1 (rev. 4.0) only); "Methods for the Determination of Organic Compounds in Drinking Water ---- Supplement I, July 1990, EPA 600/4-90/020, referenced in Sections 611.645 and 611.648 (Methods 547, 550, and 550.1 only); "Methods for the Determination of Organic Compounds in Drinking Water-Supplement II,<sup>22</sup> August 1992, EPA 600/R-92/129, referenced in Sections 611.381 and 611.645 (Methods 548.1 (rev. 1.0), 552.1 (rev. 1.0), and 555 (rev. 1.0) only); "Methods for the Determination of Organic Compounds in Drinking Water-Supplement III,<sup>20</sup> August 1995, EPA 600/R-95/131, referenced in Sections 611.381, 611.645, and 611.648 (Methods 502.2 (rev. 2.1), 504.1 (rev. 1.1), 505 (rev. 2.1), 506 (rev. 1.1), 507 (rev. 2.1), 508 (rev. 3.1), 508.1 (rev. 2.0), 515.2 (rev. 4.1), 524.2 (rev. 4.1), 525.2 (rev. 2.0), 551.1 (rev. 1.0), and 552.2 (rev. 1.0) only). See also NTIS and USEPA, NSCEP.

""Procedures for Radiochemical Analysis of Nuclear Reactor Aqueous Solutions," referenced in Section 611.720. See also NTIS.

USEPA, NSCEP. United States Environmental Protection Agency, National Service Center for Environmental Publications, P.O. Box 42419, Cincinnati, OH 45242-0419 (accessible on-line and available by download from http://www.epa.gov/nscep/).

> Dioxin and Furan Method 1613, Revision B, "Tetra- through Octa-Chlorinated Dioxins and Furans by Isotope Dilution HRGC/HRMS," October 1994, EPA 821/B-94/005, referenced in Section 611.645. See also NTIS.

> Guidance Manual for Filtration and Disinfection, "Guidance Manual for Compliance with the Filtration and Disinfection Requirements for Public Water Systems Using Surface Water Sources," March 1991, EPA 570/3-91-001, referenced in Section 611.111.

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

USEPA Asbestos Method 100.1, "Analytical Method for Determination of Asbestos Fibers in Water," September 1983, EPA 600/4-83-043, referenced in Section 611.611. See also NTIS.

USEPA Asbestos Method 100.2, "Determination of Asbestos Structures over 10-mm in Length in Drinking Water," June 1994, EPA 600/R-94-134, referenced in Section 611.611. See also NTIS.

USEPA Environmental Inorganic Methods, "Methods for the Determination of Inorganic Substances in Environmental Samples," August 1993, EPA 600/R-93-100, referenced in Sections 611.381, 611.531, and 611.611. (Methods 180.1 (rev. 2.0), 300.0 (rev. 2.1), 335.4 (rev. 1.0), 353.2 (rev. 2.0), and 365.1 (rev. 2.0) only.) See also NTIS.

USEPA Environmental Metals Methods, ""Methods for the Determination of Metals in Environmental Samples—\_\_\_\_\_ Supplement I,?"" May 1994, EPA 600/R-94-111, referenced in Sections 611.611, 611.612, and 611.720. (Methods 200.7 (rev. 4.4), 200.8 (rev. 5.3), 200.9 (rev. 2.2), and 245.1 (rev. 3.0) only.) See also NTIS.

USEPA Inorganic Methods, ""Methods for Chemical Analysis of Water and Wastes," March 1983, EPA 600/4-79-020, referenced in Section 611.611. (Methods 150.1, 150.2, and 245.2 only.) See also NTIS.

USEPA OGWDW Methods, Method 302.0, "Determination of Bromate in Drinking Water Using Two-Dimensional Ion Chromatography with Suppressed Conductivity Detection," September 2009, EPA 815/B-09/014, referenced in Sections 611.381 and 611.382. See also USEPA, OGWDW.

USEPA OGWDW Methods, Method 317.0, rev. 2.0, "Determination of Inorganic Oxyhalide Disinfection By-Products in Drinking Water Using Ion Chromatography with the Addition of a Postcolumn Reagent for Trace Bromate Analysis," July 2001, EPA 815/B-01/001, referenced in Sections 611.381 and 611.382. See also USEPA, OGWDW.

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

USEPA OGWDW Methods, Method 326.0, rev. 1.0, "Determination of Inorganic Oxyhalide Disinfection By-Products in Drinking Water Using Ion Chromatography Incorporating the Addition of a Suppressor Acidified Postcolumn Reagent for Trace Bromate Analysis,<sup>221</sup> June 2002, EPA 815/R-03/007, referenced in Sections 611.381 and 611.382. See also NTIS and USEPA, OGWDW.

USEPA OGWDW Methods, Method 327.0, rev. 1.1, "Determination of Chlorine Dioxide and Chlorite Ion in Drinking Water Using Lissamine Green B and Horseradish Peroxidase with Detection by Visible Spectrophotometry," May 2005, EPA 815/R-05/008, referenced in Sections 611.381 and 611.531. See also USEPA, OGWDW.

USEPA OGWDW Methods, Method 334.0, "Determination of Residual in Drinking Water Using an On-line Chlorine Analyzer," August 2009, EPA 815/B-09/013, referenced in Section 611.531. See also USEPA, OGWDW.

USEPA OGWDW Methods, Method 523, ver. 1.0, "Determination of Triazine Pesticides and <u>therOther</u> Degradates in Drinking Water by Gas Chromatography/Mass Spectrometry (GC/MS)," February 2011, EPA 815/R-11/<u>002.002.</u> referenced in Section 611.645. See also USEPA, OGWDW.

USEPA OGWDW Methods, Method 531.2, rev. 1.0, "Measurement of N-methylcarbamoyloximes and N-methylcarbamates in Water by Direct Aqueous Injection HPLC with Postcolumn Derivatization," September 2001, EPA 815/B-01/002 (document file name "met531\_2.pdf?"), referenced in Section 611.645. See also USEPA, OGWDW.

USEPA OGWDW Methods, Method 552.3, rev. 1.0, "Determination of Haloacetic Acids and Dalapon in Drinking Water by Liquid-Liquid Microextraction, Derivatization, and Gas Chromatography with Electron Capture Detection,?" July 2003, EPA 815/B-03/002, referenced in Sections 611.381 and 611.645.

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

USEPA OGWDW Methods, Method 557, "Determination of Haloacetic Acids, Bromate, and Dalapon in Drinking Water by Ion Chromatography Electrospray Ionization Tandem Mass Spectrometry," July 2003, EPA 815/B-03/002, referenced in Sections 611.381, 611.382, and 611.645. See also USEPA, OGWDW.

USEPA OGWDW Methods, Method 1622 (01), ""Cryptosporidium in Water by Filtration/IMS/FA," April 2001, EPA 821/R-01/026, referenced in Section 611.1007. See also USEPA, OGWDW.

USEPA Organic and Inorganic Methods, "Methods for the Determination of Organic and Inorganic Compounds in Drinking Water, Volume 1,<sup>21</sup> August 2000, EPA 815/R-00/014, referenced in Section 611.381. (Methods 300.1 (rev. 1.0) and 321.8 (rev. 1.0) only.) See also NTIS.

USEPA Organic Methods, "Methods for the Determination of Organic Compounds in Drinking Water, December 1988, revised July 1991, EPA 600/4-88/039, referenced in Sections 611.645 and 611.648 (Methods 508A (rev. 1.0) and 515.1 (rev. 4.0) only); "Methods for the Determination of Organic Compounds in Drinking Water \_\_\_\_ Supplement I, July 1990, EPA 600/4-90/020, referenced in Section 611.645 and 611.648 (Methods 547, 550, and 550.1 only); "Methods for the Determination of Organic Compound's in Drinking Water-\_\_\_ Supplement II," August 1992, EPA 600/R-92/129, referenced in Sections 611.381 and 611.645 (Methods 548.1 (rev. 1.0), 552.1 (rev. 1.0), and 555 (rev. 1.0) only); "Methods for the Determination of Organic Compounds in Drinking Water ----Supplement III," August 1995, EPA 600/R-95/131, referenced in Sections 611.381, 611.645, and 611.648 (Methods 502.2 (rev. 2.1), 504.1 (rev. 1.1), 505 (rev. 2.1), 506 (rev. 1.1), 507 (rev. 2.1), 508 (rev. 3.1), 508.1 (rev. 2.0), 515.2 (rev. 4.1), 524.2 (rev. 4.1), 525.2 (rev. 2.0), 531.1 (rev. 3.1), 551.1 (rev. 1.0), and 552.2 (rev. 1.0) only). See also NTIS and USEPA, EMSL.

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

USEPA Radioactivity Methods, "Prescribed Procedures for Measurement of Radioactivity in Drinking Water," August 1980, EPA 600/4-80/032, referenced in Section 611.720. (For methods 900.0, 901, 901.1, 902, 903, 903.1, 904, 905, 906, 908, 908.1 only.) See also NTIS.

USEPA Technical Notes, "Technical Notes on Drinking Water Methods," October 1994, EPA 600/R-94/173, referenced in Sections 611.531, 611.611, and 611.645. See also NTIS.

BOARD NOTE: USEPA made the following assertion with regard to this reference at 40 CFR 141.23(k)(1) and 141.24(e) and (n)(11)-(2011) (2012): ""This document contains other analytical test procedures and approved analytical methods that remain available for compliance monitoring until July 1, 1996." Also available online at http://nepis.epa.gov/EPA/html//Pubs/pubtitleORD.htm under the document designation "600R94173."

USEPA, OGWDW. United States Environmental Protection Agency, Office of Ground Water and Drinking Water (accessible on-line and available by download from http://www.epa.gov/safewater/methods/).

> USEPA OGWDW Methods, Method 302.0, ""Determination of Bromate in Drinking Water Using Two-Dimensional Ion Chromatography with Suppressed Conductivity Detection,"" September 2009, EPA 815/B-09/014, referenced in Section 611.381. See also USEPA, NSCEP.

USEPA OGWDW Methods, Method 317.0, rev. 2.0, "Determination of Inorganic Oxyhalide Disinfection By-Products in Drinking Water Using Ion Chromatography with the Addition of a Postcolumn Reagent for Trace Bromate Analysis," USEPA, July 2001, EPA 815/B-01/001, referenced in Section 611.381. See also USEPA, NSCEP.

USEPA OGWDW Methods, Method 326.0, rev. 1.0, "Determination of Inorganic Oxyhalide Disinfection By-Products in Drinking Water Using Ion Chromatography Incorporating the Addition of a Suppressor Acidified Postcolumn Reagent for Trace

### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

Bromate Analysis,<sup>22</sup> USEPA, June 2002, EPA 815/R-03/007, referenced in Section 611.381. See also NTIS and USEPA, NSCEP.

USEPA OGWDW Methods, Method 327.0, rev. 1.1, ""Determination of Chlorine Dioxide and Chlorite Ion in Drinking Water Using Lissamine Green B and Horseradish Peroxidase with Detection by Visible Spectrophotometry," USEPA, May 2005, EPA 815/R-05/008, referenced in Sections 611.381 and 611.531. See also USEPA, NSCEP.

USEPA OGWDW Methods, Method 334.0, "Determination of Residual in Drinking Water Using an On-line Chlorine Analyzer," USEPA, August 2009, EPA 815/B-09/013, referenced in Section 611.531. See also USEPA, NSCEP.

USEPA OGWDW Methods, Method 515.4, rev. 1.0, ""Determination of Chlorinated Acids in Drinking Water by Liquid-Liquid Microextraction, Derivatization and Fast Gas Chromatography with Electron Capture Detection," April 2000, EPA 815/B-00/001 (document file name "met515\_4.pdf?"), referenced in Section 611.645.

USEPA OGWDW Methods, Method 523, ver. 1.0, <u>Method 523</u>. <u>Version 1.0, "</u>Determination of Triazine Pesticides and <u>therOther</u>. Degradates in Drinking Water by Gas Chromatography/Mass Spectrometry (GC/MS),<u>"</u>, February 2011, EPA 815/R-11/<u>002.002</u>, referenced in Section 611.645. See also USEPA, NSCEP.

USEPA OGWDW Methods, Method 524.3, rev. 1.0, ""Measurement of Purgeable Organic Compounds in Water by Capillary Column Gas Chromatography/Mass Spectrometry,"" June 2009, EPA 815/B-09/009 (referred to as ""Method 524.3 (rev. 1.0)""), referenced in Sections 611.381 and 611.645.

USEPA OGWDW Methods, Method 531.2, rev. 1.0, ""Measurement of N-methylcarbamoyloximes and N-methylcarbamates in Water by Direct Aqueous Injection HPLC with Postcolumn Derivatization,"" September 2001, EPA

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

815/B-01/002 (document file name "met531\_2.pdf"), referenced in Section 611.645. See also USEPA, NSCEP.

USEPA OGWDW Methods, Method 536, ver. 1.0, <u>Method 536</u>, <u>Version 1.0</u>, ""Determination of Triazine Pesticides and <u>therOther</u> Degradates in Drinking Water by Liquid Chromatography Electrospray Ionization Tandem Mass Spectrometry (LC/ESI-MS/MS)," October 2007, EPA 815/R-07/002.002. referenced in Section 611.645.

USEPA OGWDW Methods, Method 552.3, rev. 1.0, ""Determination of Haloacetic Acids and Dalapon in Drinking Water by Liquid-liquid Microextraction, Derivatization, and Gas Chromatography with Electron Capture Detection," USEPA, July 2003, EPA 815/B-03/002, referenced in Sections 611.381 and 611.645.

USEPA OGWDW Methods, Method 557, "Determination of Haloacetic Acids, Bromate, and Dalapon in Drinking Water by Ion Chromatography Electrospray Ionization Tandem Mass Spectrometry," July 2003, EPA 815/B-03/002, referenced in Sections 611.381 and 611.645. See also USEPA, NSCEP.

USEPA OGWDW Methods, Method 1622 (05), ""Method 1622: Cryptosporidium in Water by Filtration/IMS/FA," December 2005, EPA 815/R-05/001, referenced in Sections 611.1004 and 611.1007.

USEPA OGWDW Methods, Method 1622 (01), ""Method 1622: Cryptosporidium in Water by Filtration/IMS/FA," April 2001, EPA 821/R-01/026, referenced in Section 611.1007. See also USEPA, NSCEP.

USEPA OGWDW Methods, Method 1622 (99), ""Method 1622: Cryptosporidium in Water by Filtration/IMS/FA," April 1999, EPA 821/R-99/001, referenced in Section 611.1007.

USEPA OGWDW Methods, Method 1623 (05), "Method 1623: Cryptosporidium and Giardia in Water by Filtration/IMS/FA,"

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

December 2005, EPA 815/R-05/002, referenced in Sections 611.1004 and 611.1007.

USEPA OGWDW Methods, Method 1623 (01), "Method 1623: Cryptosporidium and Giardia in Water by Filtration/IMS/FA," April 2001, EPA 821/R-01/025, referenced in Section 611.1007.

USEPA OGWDW Methods, Method 1623 (99), "Method 1623: Cryptosporidium and Giardia in Water by Filtration/IMS/FA," January 1999, EPA 821/R-99/006, referenced in Sections Section 611.1007.

USEPA OGWDW Methods, Method 1623.1, "Method 1623.1: Cryptosporidium and Giardia in Water by Filtration/IMS/FA," January 2012, EPA 8161/R-12/001, referenced in Section 611.1004.

BOARD NOTE: Many of the above-listed documents available from the USEPA, Office of Ground Water and Drinking Water are also listed as available from NTIS.

USEPA, ORD. USEPA, Office of Research and Development, National Exposure Research Laboratory, Microbiological & Chemical Exposure Assessment Research Division (accessible on-line and available by download from http://www.epa.gov/nerlcwww/ordmeth.htm).

USEPA NERL Method 200.5, rev. 4.2, "Determination of Trace Elements in Drinking Water by Axially Viewed Inductively Coupled Plasma—\_\_\_Atomic Emission Spectrometry," October 2003, EPA 600/R-06/115, referenced in Sections 611.611 and 611.612.

USEPA NERL Method 415.3, rev. 1.1, "Determination of Total Organic Carbon and Specific UV Absorbance at 254 nm in Source Water and Drinking Water," February 2005, EPA 600/R \_05/055, referenced in Section 611.381.

USEPA NERL Method 415.3, rev. 1.2, "Determination of Total Organic Carbon and Specific UV Absorbance at 254 nm in Source

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

Water and Drinking Water,<sup>22</sup> February 2005, EPA 600/R-\_09/122, referenced in Section 611.381.

USEPA NERL Method 525.3, ver. 1.0, <u>"Method 525.3, Version 1.0, "</u>Determination of Total Semivolatile Organic Chemicals in Drinking Water by Solid Phase Extraction and Capillary Column Gas Chromatography/Mass Spectrometry (GC/MS), <u>"</u>February 2012, EPA 600/R-12/010.010, referenced in Section 611.645.

USEPA NERL Method 549.2, rev. 1.0, "Determination of Diquat and Paraquat in Drinking Water by Liquid-Solid Extraction and High Performance Liquid Chromatography with Ultraviolet Detection," June 1997.

USEPA Water Resource Center (RC-4100T), 1200 Pennsylvania Avenue, NW, Washington, DC 20460:

E\*Colite Test, "Charm E\*Colite Presence/Absence Test for Detection and Identification of Coliform Bacteria and Escherichia coli in Drinking Water," January 9, 1998, referenced in Section 611.802. See also Charm Sciences, Inc.

m-ColiBlue24 Test, "Total Coliforms and E. coli Membrane Filtration Method with m-ColiBlue24® Broth," Method No. 10029, rev. 2, August 17, 1999, referenced in Section 611.802. See also The Hach Company.

USEPA Method 1600, ""EPA Method 1600: Enterococci in Water by Membrane Filtration Using Membrane-Enterococcus Indoxyl-\_b-\_D-\_Glucoside Agar (mEI)," September 2002, EPA 821/R-\_02/022 is an approved variation of Standard Methods, Method 9230 C, ""Fecal Streptococcus and Enterococcus Groups, Membrane Filter Techniques?" (which has not itself been approved for use by USEPA) (accessible on-line and available by download from http://www.epa.gov//nerlcwww/1600sp02.pdf), referenced in Section 611.802.

USEPA Method 1601, <u>"</u>Method 1601: Male-specific (F<sup>+</sup>) and Somatic Coliphage in Water by Two-step Enrichment Procedure, <u>"</u>

#### POLLUTION CONTROL BOARD

### NOTICE OF PROPOSED AMENDMENTS

April 2001, EPA 821/R - 01/030 (accessible on-line and available by download from http://www.epa.gov/nerlcwww/1601ap01.pdf), referenced in Section 611.802.

USEPA Method 1602, "Method 1602: Male-specific (F<sup>+</sup>) and Somatic Coliphage in Water by Single Agar Layer (SAL) Procedure," April 2001, EPA 821/R. \_01/029 (accessible on-line and available by download from http://www.epa.gov/nerlcwww/1602ap01.pdf), referenced in Section 611.802.

USEPA Method 1604, ""Method 1604: Total Coliforms and Escherichia coli in Water by Membrane Filtration Using a Simultaneous Detection Technique (MI Medium)," September 2002, EPA 821/R-02/024 (accessible on-line and available by download from http://www.epa.gov/nerlcwww/1604sp02.pdf), referenced in Section 611.802.

USGS. Books and Open File Reports Section, United States Geological Survey, Federal Center, Box 25286, Denver, CO 80225-0425. Methods

Method available upon request by method number from ""Methods for Analysis by the U.S. Geological Survey National Water Quality Laboratory—\_\_\_Determination of Inorganic and Organic Constituents in Water and Fluvial Sediments,"" Open File Report 93-125, <del>1993, or Book 5, Chapter A-1, "Methods for Determination of Inorganic Substances in Water and Fluvial Sediments," 3rd ed., Open File Report 85-495, 1989, asappropriate (referred to as "USGS Methods" 1993 (referred to as "USGS Methods").</del>

I-1030-85, referenced in Section 611.611.

I-1601 85, referenced in Section 611.611.

I 1700-85, referenced in Section 611.611.

I-2598-85, referenced in Section 611.611.

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

I-2601-90, referenced in Section

611.611.

I-2700-85, referenced in Section 611.611.

I-3300-85, referenced in Section 611.611.

Methods available upon request by method number from Book 5, Chapter A-1, "Methods for Determination of Inorganic Substances in Water and Fluvial Sediments," 3<sup>rd</sup> ed., USGS Techniques of Water-Resource Investigation: 05-A1, 1989 (referred to as "USGS Methods").

I-1030-85, referenced in Section 611.611.

I-1601-85, referenced in Section 611.611.

I-1700-85, referenced in Section 611.611.

I-2598-85, referenced in Section 611.611.

I-2700-85, referenced in Section 611.611.

I-3300-85, referenced in Section 611.611.

Methods available upon request by method number from "Methods for Determination of Radioactive Substances in Water and Fluvial Sediments,"" Chapter A5 in Book 5 of "Techniques of Water-Resources Investigations of the United States Geological Survey," 1997" 1977.

R-1110-76, referenced in Section 611.720.

R-1111-76, referenced in Section 611.720.

R-1120-76, referenced in Section 611.720.

R-1140-76, referenced in Section 611.720.

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

R-1141-76, referenced in Section 611.720.

R-1142-76, referenced in Section 611.720.

R-1160-76, referenced in Section 611.720.

R-1171-76, referenced in Section 611.720.

R-1180-76, referenced in Section 611.720.

R-1181-76, referenced in Section 611.720.

R-1182-76, referenced in Section 611.720.

BOARD NOTE: USGS methods are freely available for download in an electronic format from the USGS Publications Warehouse; at pubs.er.usgs.gov/. Sections 611.611 and 611.720 do not distinguish the volume in which each USGS method appears. The distinction as to which volume where a particular method appears is made in this incorporation by reference.

Waters Corporation, Technical Services Division, 34 Maple St., Milford, MA 01757 (800-252-4752 or 508-482-2131, fax: 508-482-3625-508-478-2000, www.waters.com).

"Waters Test Method for Determination of Nitrite/Nitrate in Water Using Single Column Ion Chromatography," Method B-1011, August 1987 (referred to as "Waters Method B-1011"), referenced in Section 611.611.

c) The Board incorporates the following federal regulations by reference:

40 CFR 3.2 (2011) (2012) (How Does This Part Provide for Electronic Reporting?), referenced in Section 611.105.

40 CFR 3.3 (2011) (2012) (What Definitions Are Applicable to This Part?), referenced in Section 611.105.

### POLLUTION CONTROL BOARD

### NOTICE OF PROPOSED AMENDMENTS

40 CFR 3.10 (2011) (2012) (What Are the Requirements for Electronic Reporting to EPA?), referenced in Section 611.105.

40 CFR 3.2000 (2011) (2012) (What Are the Requirements Authorized State, Tribe, and Local Programs' Reporting Systems Must Meet?), referenced in Section 611.105.

40 CFR 136.3(a) (2011) (2012)), referenced in Section 611.1004.

Appendix B to 40 CFR 136 (2011) (2012), referenced in Sections 611.359, 611.609, and 611.646.

40 CFR 142.20(b)(1) (2011) (2012), referenced in Section 611.112.

d) This Part incorporates no later amendments or editions.

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

SUBPART F: MAXIMUM CONTAMINANT LEVELS (MCLs) AND MAXIMUM RESIDUAL DISINFECTANT LEVELS (MRDLs)

### Section 611.300 Old MCLs for Inorganic Chemical Contaminants

a) The old MCLs listed in subsection (b) of this Section for inorganic chemical contaminants (IOCs) apply only to CWS suppliers. Compliance with old MCLs for inorganic chemicals is calculated pursuant to Section 611.612, except that analyses and determination of compliance with the 0.05 mg/l MCL for arsenic are to be performed pursuant to Sections 611.600 through 611.611.612.

BOARD NOTE: Derived Formerly derived from 40 CFR 141.11(a) (2002)., this subsection (ba) has become an additional State requirement.

b) The following are the old MCLs for IOCs:

Contaminant	Level, mg/l	Additional State Requirement (*)
Arsenic, until January 23, 2006	0.05	
Iron	1.0	*
Manganese	0.15	*

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

Zinc

5.

\*

BOARD NOTE: Derived Formerly derived from 40 CFR 141.11(b) (2002), this subsection (b) will has become an additional State requirement after expiration of the old arsenic MCL on the January 23, 2006 effective date of the federal amendments that instituted a new MCL for Arsenic.

- c) This subsection corresponds with 40 CFR 141.11(c), marked as reserved by USEPA. This statement maintains structural parity with the federal rules.
- d) Nitrate. Non-CWSs may exceed the MCL for nitrate under the following circumstances:
  - 1) The nitrate level must not exceed 20 mg/l,
  - 2) The water must not be available to children under six months of age,
  - 3) The NCWS supplier is meeting the public notification requirements under Section 611.909, including continuous posting of the fact that the nitrate level exceeds 10 mg/ $\ell$  together with the potential health effects of exposure,
  - 4) The supplier will annually notify local public health authorities and the Department of Public Health of the nitrate levels that exceed 10 mg/ $\ell_{0}$  and
  - 5) No adverse public health effects result.

BOARD NOTE: Derived from 40 CFR 141.11(d) (2002) (2012). The Department of Public Health regulations may impose a nitrate limitation requirement. Those regulations are at 77 Ill. Adm. Code 900.50.

- e) The following supplementary condition applies to the MCLs listed in subsection
   (b) of this Section for iron and manganese:
  - 1) CWS suppliers that serve a population of 1000 or fewer, or 300 service connections or fewer, are exempt from the standards for iron and manganese.
  - 2) The Agency may, by a SEP issued pursuant to Section 611.110, allow iron

# POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

and manganese in excess of the MCL if sequestration tried on an experimental basis proves to be effective. If sequestration is not effective, positive iron or manganese reduction treatment as applicable must be provided. Experimental use of a sequestering agent may be tried only if approved by a SEP issued pursuant to Section 611.110.

BOARD NOTE: The requirements of this This subsection (e) are is an additional State requirement.

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

## Section 611.301 Revised MCLs for Inorganic Chemical Contaminants

- a) This subsection corresponds with 40 CFR 141.62(a), reserved by USEPA. This statement maintains structural consistency with USEPA rules.
- b) The MCLs in the following table apply to CWSs. Except for fluoride, the MCLs also apply to NTNCWSs. The MCLs for nitrate, nitrite, and total nitrate and nitrite also apply to transient non-CWSs.

Contaminant	MCL	Units
Antimory	0.006	
Antimony Arsenic (effective January 23, 2006)	0.006 0.010	mg/l mg/l
Asbestos	7	MFL
Barium	2	mg/l
Beryllium	0.004	mg/l
Cadmium	0.005	mg/l
Chromium	0.1	mg/l
Cyanide (as free CN <sup>-</sup> )	0.2	mg/l
Fluoride	4.0	mg/l
Mercury	0.002	mg/l
Nitrate (as N)	10	mg/l
Nitrite (as N)	1	mg/l
Total Nitrate and Nitrite (as N)	10	mg/l
Selenium	0.05	mg/l
Thallium	0.002	mg/l

### POLLUTION CONTROL BOARD

### NOTICE OF PROPOSED AMENDMENTS

BOARD NOTE: See Section 611.300(d) for an elevated nitrate level for non-CWSs. USEPA removed and reserved the MCL for nickel on June 29, 1995, at 60 Fed. Reg. 33932, as a result of a judicial order in Nickel Development Institute v. EPA, No. 92-1407, and Specialty Steel Industry of the U.S. v. Browner, No. 92-1410 (D.C. Cir. Feb. 23 & Mar. 6, 1995), while retaining the contaminant, analytical methodology, and detection limit listings for this contaminant.

c) USEPA has identified the following as BAT for achieving compliance with the MCL for the IOCs identified in subsection (b) of this Section, except for fluoride:

Contaminant	BATs
Antimony	C/F
	RO
Arsenic (BATs for As <sup>V</sup> . Pre-oxidation may be required to convert As <sup>III</sup> to As <sup>V</sup> .)	AAL C/F IX LIME RO ED O/F (To obtain high removals, the iron to- arsenic ratio must be at least 20:1) C/F IX LIME RO ED
	O/F (To obtain high removals, the iron to arsenic ratio must be at least 20:1)
Asbestos	C/F DDF CC
	DDF CC
Barium	IX

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

	LIME RO ED LIME RO ED
Beryllium	AA C/F IX LIME RO
	C/F IX LIME RO
Cadmium	C/F IX LIME RO IX LIME RO
Chromium	C/F IX LIME, BAT for Cr <sup>III</sup> only RO IX LIME, BAT for Cr <sup>III</sup> only
Cyanide	RO IX RO ALK Ch
	RO ALK Cl2

. .

# POLLUTION CONTROL BOARD

### NOTICE OF PROPOSED AMENDMENTS

Mercury	C/F, BAT only if influent Hg concentrations less than or equal to $\frac{10}{\mu g/\ell}$ GAC LIME, BAT only if influent Hg concentrations less than or equal to $\frac{10}{\mu g/\ell}$ RO, BAT only if influent Hg concentrations less than or equal to $\frac{10}{\mu g}$ $\frac{10}{\mu g/\ell}$ GAC LIME. BAT only if influent Hg concentrations less than or equal to $\frac{10}{\mu g/\ell}$ RO, BAT only if influent Hg concentrations less than or equal to $\frac{10}{\mu g/\ell}$ RO, BAT only if influent Hg
Nickel	IX LIME RO LIME RO
Nitrate	IX RO ED RO ED
Nitrite	IX <del>RO</del> RO
Selenium	AAL <del>C/F, BAT for Se<sup>rv</sup> only</del> <del>LIME</del> <del>RO</del> <del>ED</del>

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

	C/F. BAT for Se <sup>TV</sup> only LIME RO ED
Thallium	AAL IX
	IX

# Abbreviations

Abbreviations	
AAL	Activated alumina
ALK Ch2C12	Alkaline chlorination (pH $\geq$ 8.5)
C/F	Coagulation/filtration (not BAT for a system that has
	fewer than 500 service connections)
CC	Corrosion control
ClaC12	Oxidation (chlorine)
DDF	Direct and diatomite filtration
ED	Electrodialysis
GAC	Granular activated carbon
IX	Ion exchange
LIME	Lime softening
O/F	Oxidation/filtration
RO	Reverse osmosis
UV	Ultraviolet irradiation

d) At 40 CFR 141.62(d) (2003) (2012), USEPA identified the following as the affordable technology, treatment technique, or other means available to systems serving 10,000 persons or fewer for achieving compliance with the maximum contaminant level for arsenic:

Small System Compliance Techn	ologies (SSCTs) <sup>1</sup> for Arsenic <sup>2</sup>		
Small System Compliance Technologies (SSCTs) <sup>1</sup> for Arsenic <sup>2</sup>			
Small system compliance technology	Affordable for listed small system categories <sup>3</sup>		
Activated alumina (centralized)	All size categories		
Activated alumina (point-of-use)4	All size categories		
Coagulation/filtration <sup>5</sup>	501-3,300 persons,		
	3,301-10,000 persons		

### POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

Coagulation-assisted microfiltration	501-3,300 persons,
	3,301-10,000 persons
Electrodialysis reversal <sup>6</sup>	501-3,300 persons,
	3,301-10,000 persons
Enhanced coagulation/filtration	All size categories
Enhanced lime softening (pH $\ge$ 210.5)	All size categories
Ion exchange	All size categories
Lime softening <sup>5</sup>	501-3,300 persons,
	3,301-10,000 persons
Oxidation/filtration <sup>7</sup>	All size categories
Reverse osmosis (centralized) <sup>6</sup>	501-3,300 persons,
	3,301-10,000 persons
Reverse osmosis (point-of-use) <sup>4</sup>	All size categories

- Section 1412(b)(4)(E)(ii) of the federal SDWA (42 USC 300g-1(b)(4)(E)(ii)) specifies that SSCTs must be affordable and technically feasible for a small system supplier.
- <sup>2</sup> SSCTs for As<sup>V</sup>. Pre-oxidation may be required to convert As<sup>III</sup> to As<sup>V</sup>.
- <sup>3</sup> The federal SDWA specifies three categories of small system suppliers: (1) those serving 25 or more, but fewer than 501 persons, (2) those serving more than 500 but fewer than 3,301 persons, and (3) those serving more than 3,300 but fewer than 10,001 persons.
- <sup>4</sup> When POU or POE devices are used for compliance, programs to ensure proper long-term operation, maintenance, and monitoring must be provided by the water supplier to ensure adequate performance.
- <sup>5</sup> Unlikely to be installed solely for arsenic removal. May require pH adjustment to optimal range if high removals are needed.
- <sup>6</sup> Technologies reject a large volume of water—<u>may</u> not be appropriate for areas where water quantity may be an issue.
- <sup>7</sup> To obtain high removals, iron to arsenic ratio must be at least 20:1.

BOARD NOTE: Derived from 40 CFR 141.62 (2003)(2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

## Section 611.311 Revised MCLs for Organic Chemical Contaminants

a) Volatile organic chemical contaminants. The following MCLs for volatile organic chemical contaminants (VOCs) apply to CWS suppliers and NTNCWS suppliers.

### POLLUTION CONTROL BOARD

### NOTICE OF PROPOSED AMENDMENTS

CAS No.	Contaminant	MCL (mg/l)
71-43-2	Benzene	0.005
56-23-5	Carbon tetrachloride	0.005
95-50-1	o-Dichlorobenzene	0.6
106-46-7	p-Dichlorobenzene	0.075
107-06-2	1,2-Dichloroethane	0.005
75-35-4	1,1-Dichloroethylene	0.007
156-59-2	cis-1,2-Dichloroethylene	0.07
156-60-5	trans-1,2-Dichloroethylene	0.1
75-09-2	Dichloromethane (methylene chloride)0.005	0.005
78-87-5	1,2-Dichloropropane	0.005
100-41-4	Ethylbenzene	0.7
108-90-7	Monochlorobenzene	0.1
100-42-5	Styrene	0.1
127-18-4	Tetrachloroethylene	0.005
108-88-3	Toluene	1
120-82-1	1,2,4-Trichlorobenzene	0.07
71-55-6	1,1,1-Trichloroethane	0.2
79-00-5	1,1,2-Trichloroethane	0.005
79-01-6	Trichloroethylene	0.005
75-01-4	Vinyl chloride	0.002
1330-20-7	Xylenes (total)	10

BOARD NOTE: See the definition of  $\frac{60}{2}$  initial compliance period  $\frac{20}{2}$  at Section 611.101.

b) USEPA has identified, as indicated below, granular activated carbon (GAC), packed tower aeration (PTA), or oxidation (OX) as BAT for achieving compliance with the MCLs for volatile organic chemical contaminants (VOCs) and synthetic organic chemical contaminants (SOCs) in subsections (a) and (c) of this Section.

15972-60-8	Alachlor	GAC
116-06-3	Aldicarb*	GAC
1646-87-4	Aldicarb sulfone*	GAC
1646-87-3	Aldicarb sulfoxide*	GAC
1912-24-9	Atrazine	GAC
71-43-2	Benzene	GAC, PTA

i

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

50-32-8	Benzo(a)pyrene	GAC
1563-66-2	Carbofuran	GAC
56-23-5	Carbon tetrachloride	GAC, PTA
57-74-9	Chlordane	GAC
94-75-7	2.4-D	GAC
75-99-0	Dalapon	GAC
<del>96-12-8</del>	Dibromochloropropane	GAC, PTA
95-50-1	o-Dichlorobenzene	GAC, PTA
106-46-7	p-Dichlorobenzene	GAC, PTA
107-06-2	1,2-Dichloroethane	GAC, PTA
156-59-2	cis-1,2-Dichloroethylene	GAC, PTA
156-60-5	trans 1,2 Dichoroethylene	GAC, PTA
75-35-4	1,1-Dichloroethylene	GAC, PTA
75-09-2	Dichloromethane	PTA
78-87-5	1,2-Dichloropropane	GAC, PTA
103-23-1	Di(2 ethylhexyl)adipate	GAC, PTA
117-81-7	Di(2 ethylhexyl)phthalate	GAC
88-85-7	Dinoseb	GAC
85-00-7	Diquat	GAC
145 73 3	Endothall	GAC
72-20-8	Endrin	GAC
106-93-4	Ethylene dibromide (EDB)	GAC, PTA
100-41-4	Ethylbenzene	GAC, PTA
1071-53-6	Glyphosate	OX
76-44-8	Heptachlor	GAC
1024-57-3	Heptachlor epoxide	GAC
118-74-1	Hexachlorobenzene	GAC
77-47-3	Hexachlorocyclopentadiene	GAC, PTA
58-89-9	Lindane	GAC
72-43-5	Methoxychlor	GAC
108-90-7	Monochlorobenzene	GAC, PTA
23135-22-0	Oxamyl	GAC
87-86-5	Pentachlorophenol	GAC
1918-02-1	Picloram	GAC
1336-36-3	Polychlorinated biphenyls (PCB)	GAC
122-34-9	Simazine	GAC
100-42-5	Styrene	GAC, PTA
1746-01-6	2,3,7,8 TCDD	GAC
127-18-4	Tetrachloroethylene	GAC, PTA

•

# POLLUTION CONTROL BOARD

### NOTICE OF PROPOSED AMENDMENTS

108-88-3	Toluene	GAC
8001-35-2	Toxaphene	GAC
120-82-1	1,2,4-trichlorobenzene	GAC, PTA
71-55-6	1,1,1-Trichloroethane	GAC, PTA
79-00-5	1,1,2-trichloroethane	GAC, PTA
79-01-6	Trichloroethylene	GAC, PTA
93 72 1	2,4,5-TP	GAC
75-01-4	Vinyl chloride	PTA
1330-20-7	Xylene	GAC, PTA
*		

15972-60-8	Alachlor	GAC
116-06-3	Aldicarb*	GAC
1646-87-4	Aldicarb sulfone*	GAC
1646-87-3	Aldicarb sulfoxide*	GAC
1912-24-9	Atrazine	GAC
71-43-2	Benzene	GAC. PTA
50-32-8	Benzo(a)pyrene	GAC
1563-66-2	Carbofuran	GAC
56-23-5	Carbon tetrachloride	GAC. PTA
57-74-9	Chlordane	GAC
94-75-7	2.4-D	GAC
75-99-0	Dalapon	GAC
96-12-8	Dibromochloropropane	GAC. PTA
<u>95-50-1</u>	o-Dichlorobenzene	GAC. PTA
106-46-7	p-Dichlorobenzene	GAC. PTA
107-06-2	1.2-Dichloroethane	GAC. PTA
156-59-2	cis-1.2-Dichloroethylene	GAC. PTA
156-60-5	trans-1.2-Dichoroethylene	GAC. PTA
75-35-4	1.1-Dichloroethylene	GAC. PTA
75-09-2	Dichloromethane	PTA
78-87-5	1.2-Dichloropropane	GAC. PTA
103-23-1	Di(2-ethylhexyl)adipate	GAC. PTA
117-81-7	Di(2-ethylhexyl)phthalate	GAC
88-85-7	Dinoseb	GAC
85-00-7	Diquat	GAC
145-73-3	Endothall	GAC
72-20-8	Endrin	GAC
106-93-4	Ethylene dibromide (EDB)	GAC. PTA

### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

100-41-4	Ethylbenzene	GAC. PTA
1071-53-6	Glyphosate	OX
76-44-8	Heptachlor	GAC
1024-57-3	Heptachlor epoxide	GAC
118-74-1	Hexachlorobenzene	GAC
77-47-3	Hexachlorocyclopentadiene	GAC. PTA
58-89-9	Lindane	GAC
72-43-5	Methoxychlor	GAC
108-90-7	Monochlorobenzene	GAC. PTA
23135-22-0	Oxamyl	GAC
87-86-5	Pentachlorophenol	GAC
1918-02-1	Picloram	GAC
1336-36-3	Polychlorinated biphenyls (PCB)	GAC
122-34-9	Simazine	GAC
100-42-5	Styrene	GAC. PTA
1746-01-6	2.3.7.8-TCDD	GAC
127-18-4	Tetrachloroethylene	GAC. PTA
108-88-3	Toluene	GAC
8001-35-2	Toxaphene	GAC
120-82-1	1.2.4-trichlorobenzene	GAC. PTA
71-55-6	1.1.1-Trichloroethane	GAC. PTA
<u>79-00-5</u>	1.1.2-trichloroethane	GAC. PTA
<u>79-01-6</u>	Trichloroethylene	GAC. PTA
<u>93-72-1</u>	2.4.5-TP	GAC
<u>75-01-4</u>	Vinyl chloride	PTA
1330-20-7	Xylene	GAC. PTA

\*See the Board note appended to the end of this Section.

c) Synthetic organic chemical contaminants. The following MCLs for SOCs apply to CWS and NTNCWS suppliers.

CAS Numbe	er Contaminant	MCL (mg/l)
CAS Number	Contaminant	<u>MCL (mg/ℓ)</u>
15972-60-8 116-06-3 1646-87-4 1646-87-3	Alachlor Aldicarb* Aldicarb sulfone* Aldicarb sulfoxide*	0.002 0.002 0.002 0.004

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

1012 24 0	Atracina	0.002
1912-24-9	Atrazine	0.003
50-32-8	Benzo(a)pyrene	0.0002
1563-66-2	Carbofuran	0.04
57-74-9	Chlordane	0.002
94-75-7	2,4-D	0.07
75-99-0	Dalapon	0.2
96-12-8	Dibromochloropropane	0.0002
103-23-1	Di(2-ethylhexyl)adipate	0.4
117-81-7	Di(2-ethylhexyl)phthalate	0.006
<b>88-85-</b> 7	Dinoseb	0.007
85-00-7	Diquat	0.02
145-73-3	Endothall	0.1
72-20-8	Endrin	0.002
106-93-4	Ethylene dibromide	0.00005
1071-53-6	Glyphosate	0.7
76-44-8	Heptachlor	0.0004
1024-57-3	Heptachlor epoxide	0.0002
118-74-1	Hexachlorobenzene	0.001
77-47-4	Hexachlorocyclopentadiene	0.05
58-89-9	Lindane	0.0002
72-43-5	Methoxychlor	0.04
23135-22-0	Oxamyl (Vydate)	0.2
87-86-5	Pentachlorophenol	0.001
1918-02-1	Picloram	0.5
1336-36-3	Polychlorinated biphenyls (PCBs)	0.0005
122-34-9	Simazine	0.004
1746-01-6	2,3,7,8-TCDD (Dioxin)	0.00000003
8001-35-2	Toxaphene	0.003
93-72-1	2,4,5-TP	0.05

\* See the Board note appended to the end of this Section.

BOARD NOTE: Derived from 40 CFR 141.61 (2003) (2012). See the definition of "initial compliance period" at Section 611.101. More stringent state MCLs for 2,4 -D, heptachlor, and heptachlor epoxide appear at Section 611.310. See the Board Note at that provision. In 40 CFR 141.6(g), USEPA postponed the effectiveness of the MCLs for aldicarb, aldicarb sulfone, and aldicarb sulfoxide until it took further action on those MCLs. See 40 CFR 141.6(g) and 57 Fed. Reg. 22178 (May 27, 1992). USEPA has since stated that it anticipates taking no action until 2005 on a federal national primary drinking water regulation

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

(NPDWR) applicable to the aldicarbs. 68 Fed. Reg. 31108 (May 27, 2003). In-2005, USEPA indicated no projected date for final action on the aldicarbs. See 70-Fed. Reg. 27501, 671 (May 16, 2005). No An entry for the aldicarbs last appeared in USEPA."s Spring 2007 semiannual regulatory agenda, indicating no projected dates for further action. (See 72 Fed. Reg. 23156, 97 (Apr. 30, 2007); see also 72 Fed. Reg. 70118, 23 (Dec. 10, 2007) (the first USEPA regulatory agenda that included no entry for the aldicarbs).) While the Board must maintain entries for aldicarb, aldicarb sulfoxide, and aldicarb sulfone to maintain consistency with the letter of the federal regulations (see 415 ILCS 5/7.2 and 17.5 (2010); 42 <u>U.S.C.</u> §USC 300g-2 (2010); 40 <u>C.F.R.CFR</u> 142.10 (2012)), the Board intends that no aldicarb requirements apply in Illinois until after USEPA adopts such requirements, and the Board removes has removed this statement.

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

# Section 611.330 Maximum Contaminant Levels for Radionuclides

- a) This subsection corresponds with 40 CFR 141.66(a), marked reserved by USEPA. This statement maintains structural consistency with USEPA rules.
- b) MCL for combined radium-226 and -228. The maximum contaminant level for combined radium-226 and radium-228 is 5 pCi/ $\ell$ . The combined radium-226 and radium-228 value is determined by the addition of the results of the analysis for radium-226 and the analysis for radium-228.
- c) MCL for gross alpha particle activity (excluding radon and uranium). The maximum contaminant level for gross alpha particle activity (including radium-226 but excluding radon and uranium) is 15 pCi/ℓ.
- d) Effective December 8, 2003, MCL for beta particle and photon radioactivity.
  - 1) The average annual concentration of beta particle and photon radioactivity from man-made radionuclides in drinking water must not produce an annual dose equivalent to the total body or any internal organ greater than 4 millirem/year (mrem/year).
  - 2) Except for the radionuclides listed in the following table, the concentration of man-made radionuclides causing 4 mrem total body or organ dose equivalents must be calculated on the basis of two liters per day drinking

### POLLUTION CONTROL BOARD

### NOTICE OF PROPOSED AMENDMENTS

water intake, using the 168-hour data list set forth in "Maximum Permissible Body Burdens and Maximum Permissible Concentrations of Radionuclides in Air and in Water for Occupational Exposure," incorporated by reference in Section 611.102, available from the NTIS. If two or more radionuclides are present, the sum of their annual dose equivalent to the total body or to any organ must not exceed 4 mrem/year.

Average Annual Concentrations Assumed to Produce a Total Body or Organ Dose of 4 mrem/yr

Average Annual Concentrations Assumed to Produce a Total Body or Organ Dose of 4 mrem/yr				
Radionuclide Critical organ pCi per liter				
1. 1-Tritium	Total body	20,000		
2. 2. Strontium-90	Bone Marrow	8		

- e) MCL for uranium. Effective December 8, 2003, the The maximum contaminant level for uranium is 30 µgµg/l.
- f) Compliance dates for combined radium-226 and -228, gross alpha particle activity, gross beta particle and photon radioactivity, and uranium: Effective December 8, 2003, a., A CWS supplier must comply with the MCLs listed in subsections (b) through (e) of this Section, and compliance must be determined in accordance with the requirements of Subpart Q of this Part.
- g) Best available technologies (BATs) for radionuclides. USEPA has identified the technologies indicated in the following table as the BAT for achieving compliance with the MCLs for combined radium-226 and -228, uranium, gross alpha particle activity, and beta particle and photon radioactivity.

BAT for Combined Radium 226 and Radium 228, Uranium, Gross Alpha Particle Activity, and Beta Particle and Photon Radioactivity

BAT for Combined Radium-226 and Radium-228, Uranium, Gross Alpha Particle Activity, and Beta Particle and Photon Radioactivity				
Con	Contaminant BAT			
1. 1. Combined radium-226 and		Ion exchange, reverse osmosis,		
radium-228		lime softening.		
2	2. Uranium	Ion exchange, reverse osmosis,		

# POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

		lime softening, coagulation/ filtration.
3.	3. Gross alpha particle activity (excluding Radon and Uranium)	Reverse osmosis.
4.	4. Beta particle and photon radioactivity	Ion exchange, reverse osmosis.

# h) Small systems compliance technologies list for radionuclides.

List of Small Systems Compliance Technologies for Radionuclides and Limitations to Use

List of Small Systems Compliance Technologie	s for
Radionuclides and Limitations to Use	

1 million (		and the second sec		
Uni	t technologies	Limitations (see footnotes)	Operator skill level required <sup>1</sup>	Raw water quality range and considerations <sup>1</sup>
1	1. Ion exchange (IE)	(a)	Intermediate	All ground waters.
2.	2. Point of use (POU <sup>2</sup> ) IE	(b)	Basic	All ground waters.
3.	3. Reverse osmosis (RO)	(c)	Advanced	Surface waters usually require pre-filtration.
4.	4. POU <sup>2</sup> RO	(b)	Basic	Surface waters usually require pre-filtration.
5.	5. Lime softening	(d)	Advanced	All waters.
<u>6.</u>	6. Green sand filtration	(e)	Basic	
2.	7. Co-precipitation with Barium sulfate	(f)	Intermediate to Advanced	Ground waters with suitable water quality.
8.	<del>8.</del>		Basic to	All ground waters.

### POLLUTION CONTROL BOARD

### NOTICE OF PROPOSED AMENDMENTS

	Electrodialysis/ electrodialysis reversal		Intermediate	
2	9. Pre-formed hydrous Manganese oxide filtration	(g)	Intermediate	All ground waters.
10.	10. Activated alumina	(a), (h)	Advanced	All ground waters; competing anion concentrations may affect regeneration frequency.
11.	11. Enhanced coagulation/ filtration	(i)	Advanced	Can treat a wide range of water qualities.

- <u>National Research Council (NRC). "Safe Water from Every Tap: Improving</u> Water Service to Small Communities." National Academy Press. Washington, D.C. 1997.
- A POU. or "point-of-use" technology is a treatment device installed at a single tap used for the purpose of reducing contaminants in drinking water at that one tap. POU devices are typically installed at the kitchen tap. BOARD NOTE: USEPA refers the reader to the notice of data availability (NODA) at 66 Fed. Reg. 21576 (April 21, 2000) for more details.

<sup>+</sup> National Research Council (NRC). "Safe Water from Every Tap: Improving-Water Service to Small Communities," National Academy Press, Washington, D.C. 1997.

<sup>2</sup> A POU, or "point of use" technology is a treatment device installed at a single tap used for the purpose of reducing contaminants in drinking water at that one tap. POU devices are typically installed at the kitchen tap. BOARD NOTE: USEPA refers the reader to the notice of data availability (NODA) at 66 Fed. Reg. 21576 (April 21, 2000) for more details.

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

Limitations Footnotes: Technologies for Radionuclides:

- (a) The regeneration solution contains high concentrations of the contaminant ions. Disposal options should be carefully considered before choosing this technology.
- (b) When POU devices are used for compliance, programs for long-term operation, maintenance, and monitoring must be provided by water utility to ensure proper performance.
- (c) Reject water disposal options should be carefully considered before choosing this technology.

BOARD NOTE: In corresponding 40 CFR 141.66, Table C, footnote c states in part as follows: ""See other RO limitations described in the SWTR Compliance Technologies Table." Table C was based in significant part on "Table 13. Technologies for Radionuclides" that appears at 63 Fed. Reg. 42032 at 42043 (August 6, 1998), which refers to "Table 2. SWTR Compliance Technology Table: Filtration." That Table 2 lists the limitations on RO as follows:

- <sup>d</sup> Blending (combining treated water with untreated raw water) cannot be practiced at risk of increasing microbial concentrations in finished water.
- <sup>e</sup> Post-disinfection recommended as a safety measure and for residual maintenance.
- <sup>f</sup> Post-treatment corrosion control will be needed prior to distribution.

63 Fed. Reg. at 42036.

- (d) The combination of variable source water quality and the complexity of the water chemistry involved may make this technology too complex for small surface water systems.
- (e) Removal efficiencies can vary depending on water quality.
- (f) This technology may be very limited in application to small systems. Since the process requires static mixing, detention basins, and filtration, it is

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

most applicable to systems with sufficiently high sulfate levels that already have a suitable filtration treatment train in place.

- (g) This technology is most applicable to small systems that already have filtration in place.
- (h) Handling of chemicals required during regeneration and pH adjustment may be too difficult for small systems without an adequately trained operator.
- (i) Assumes modification to a coagulation/filtration process already in place.

Compliance Technologies by System Size Category for Radionuclide NPDWRs

	Compliance Technologies by System Size Category for Radionuclide NPDWRs					
		•	technologies' fo			
		categor	ies (population	served)		
Cot	ntaminant	25-500	501-3,300	3,300-10,000		
1.	1. Combined	1, 2, 3, 4, 5, 6,	1, 2, 3, 4, 5,	1, 2, 3, 4, 5, 6,		
102	radium-226	7, 8, 9	6, 7, 8, 9	7, 8, 9		
S n. 1	and radium-228					
2	2. Gross alpha	3,4	3,4	3,4		
	particle					
	activity					
3.	3. Beta particle	1, 2, 3, 4	1, 2, 3, 4	1, 2, 3, 4		
	activity					
	and photon activity					
4.	4. Uranium	1, 2, 4, 10, 11	1, 2, 3, 4, 5,	1, 2, 3, 4, 5,		
			10, 11	10, 11		

Note:

<sup>1</sup> Numbers correspond to those technologies found listed in the table, "List of Small Systems Compliance Technologies for Radionuclides and Limitations to Use," set forth above.

BOARD NOTE: Derived from 40 CFR 141.66 (2003) (2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

### SUBPART G: LEAD AND COPPER

#### Section 611.359 Analytical Methods

Analyses for lead, copper, pH, conductivity, calcium, alkalinity, orthophosphate, silica, and temperature must be conducted using the methods set forth in Section 611.611(a).

- a) Analyses for lead and copper performed for the purposes of compliance with this Subpart G must only be conducted by laboratories that have been certified by USEPA or the Agency. To obtain certification to conduct analyses for lead and copper, laboratories must do the following:
  - 1) Analyze performance evaluation samples that include lead and copper provided by USEPA Environmental Monitoring and Support Laboratory or equivalent samples provided by the Agency; and
  - 2) Achieve quantitative acceptance limits as follows:
    - A) For lead: ±30 percent of the actual amount in the performance evaluation sample when the actual amount is greater than or equal to 0.005 mg/ℓ (the PQL for lead is 0.005 mg/ℓ);
    - B) For copper:  $\pm 10$  percent of the actual amount in the performance evaluation sample when the actual amount is greater than or equal to 0.050 mg/ $\ell$  (the PQL for copper is 0.050 mg/ $\ell$ );
    - C) Achieve the method detection limit (MDL) for lead (0.001 mg/l, as defined in Section 611.350(a)) according to the procedures in 35-III. Adm. Code 186 and appendix B to 40 CFR 136: "Definition and Procedure for the Determination of the Method Detection Limit Revision 1.11", incorporated by reference in Section 611.102(c). This need only be accomplished if the laboratory will be processing source water composite samples under Section 611.358(a)(1)(D); and
    - D) Be currently certified by USEPA or the Agency to performanalyses to the specifications described in subsection (a)(1) of this-Section.

## POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

- 3) Achieve the method detection limit (MDL) for lead (0.001 mg/l, as defined in Section 611.350(a)) according to the procedures in 35 Ill. Adm. Code 186 and appendix B to 40 CFR 136: ""Definition and Procedure for the Determination of the Method Detection Limit—— Revision 1.112", incorporated by reference in Section 611.102(c). This need only be accomplished if the laboratory will be processing source water composite samples under Section 611.358(a)(1)(D); and
- 4) Be currently certified by USEPA or the Agency to perform analyses to the specifications described in subsection (a)(1) of this Section.

BOARD NOTE: Subsection (a) is derived from 40 CFR 141.89(a) and (a)(1)-(2007), as amended at 72 Fed. Reg. 57782 (October 10, 2007) (2012).

b) The Agency must, by a SEP issued pursuant to Section 611.110, allow a supplier to use previously collected monitoring data for the purposes of monitoring under this Subpart G if the data were collected and analyzed in accordance with the requirements of this Subpart G.

BOARD NOTE: Subsection (b) is derived from 40 CFR 141.89(a)(2) (2007) (2012).

- c) Reporting lead and copper levels.
  - All lead and copper levels greater than or equal to the lead and copper PQL (Pb ≥≥ 0.005 mg/ℓ and Cu ≥≥ 0.050 mg/ℓ) must be reported as measured.
  - All lead and copper levels measured less than the PQL and greater than the MDL (0.005 mg/ℓ > Pb > MDL and 0.050 mg/ℓ > Cu > MDL) must be either reported as measured or as one-half the PQL set forth in subsection (a) of this Section (i.e., reported as 0.0025 mg/ℓ for lead or 0.025 mg/ℓ for copper).
  - 3) All lead and copper levels below the lead and copper MDL (MDL > Pb) must be reported as zero.

BOARD NOTE: Subsection (c) is derived from 40 CFR 141.89(a)(3) and (a)(4)

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

# (<del>2007) (</del>2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_\_)

# SUBPART I: DISINFECTANT RESIDUALS, DISINFECTION BYPRODUCTS, AND DISINFECTION BYPRODUCT PRECURSORS

## Section 611.382 Monitoring Requirements

- a) General requirements.
  - 1) A supplier must take all samples during normal operating conditions.
  - 2) A supplier may consider multiple wells drawing water from a single aquifer as one treatment plant for determining the minimum number of TTHM and HAA5 samples required with Agency approval.
  - 3) Failure to monitor in accordance with the monitoring plan required under subsection (f) of this Section is a monitoring violation.
  - 4) Where compliance is based on a running annual average of monthly or quarterly samples or averages and the supplier's failure to monitor makes it impossible to determine compliance with MCLs or MRDLs, this failure to monitor will be treated as a violation for the entire period covered by the annual average.
  - 5) A supplier must use only data collected under the provisions of this Subpart I to qualify for reduced monitoring.
- b) Monitoring requirements for disinfection byproducts (DBPs).
  - 1) TTHMs and HAA5.
    - A) Routine monitoring. A supplier must monitor at the following frequency:
      - i) A Subpart B system supplier that serves 10,000 or more persons must collect four water samples per quarter per treatment plant. At least 25 percent of all samples collected

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

each quarter must be collected at locations representing maximum residence time. The remaining samples may be taken at locations representative of at least average residence time in the distribution system and representing the entire distribution system, taking into account the number of persons served, the different sources of water, and the different treatment methods.

- A Subpart B system supplier that serves from 500 to 9,999 persons must collect one water sample per quarter per treatment plant. The samples must be collected from locations representing maximum residence time.
- iii) A Subpart B system supplier that serves fewer than 500 persons must collect one sample per year per treatment plant during month of warmest water temperature. The samples must be collected from locations representing maximum residence time. If the sample (or average of annual samples, if more than one sample is taken) exceeds the MCL, the supplier must increase the monitoring frequency to one sample per treatment plant per quarter, taken at a point reflecting the maximum residence time in the distribution system, until the supplier meets the standards in subsection (b)(1)(D) of this Section.
- A supplier that uses only groundwater not under direct influence of surface water, which uses chemical disinfectant, and which serves 10,000 or more persons must collect one water sample per quarter per treatment plant. The samples must be collected from locations representing maximum residence time.
- v) A supplier that uses only groundwater not under direct influence of surface water, which uses chemical disinfectant, and which serves fewer than 10,000 persons must collect one sample per year per treatment plant during month of warmest water temperature. The samples must be collected from locations representing maximum residence time. If the sample (or average of annual samples, if more

### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

than one sample is taken) exceeds MCL, the supplier must increase monitoring to one sample per treatment plant per quarter, taken at a point reflecting the maximum residence time in the distribution system, until the supplier meets standards in subsection (b)(1)(D) of this Section.

BOARD NOTE: If a supplier elects to sample more frequently than the minimum required, at least 25 percent of all samples collected each quarter (including those taken in excess of the required frequency) must be taken at locations that represent the maximum residence time of the water in the distribution system. The remaining samples must be taken at locations representative of at least average residence time in the distribution system. For a supplier using groundwater not under the direct influence of surface water, multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the minimum number of samples required, with Agency approval.

- B) A supplier may reduce monitoring, except as otherwise provided, in accordance with the following:
  - A Subpart B system supplier that serves 10,000 or more persons and which has a source water annual average TOC level, before any treatment, of less than or equal to 4.0 mg/l may reduce monitoring if it has monitored for at least one year and its TTHM annual average is less than or equal to 0.040 mg/l and HAA5 annual average is less than or equal to 0.030 mg/l. The reduced monitoring allowed is a minimum of one sample per treatment plant per quarter at a distribution system location reflecting maximum residence time.
  - ii) A Subpart B system supplier that serves from 500 to 9,999 persons and which has a source water annual average TOC level, before any treatment, of less than or equal to 4.0 mg/l may reduce monitoring if it has monitored at least one year and its TTHM annual average is less than or equal to 0.040 mg/l and HAA5 annual average is less than or equal to 0.030 mg/l. The reduced monitoring allowed is a

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

minimum of one sample per treatment plant per year at a distribution system location reflecting maximum residence time during month of warmest water temperature.

BOARD NOTE: Any Subpart B system supplier that serves fewer than 500 persons may not reduce its monitoring to less than one sample per treatment plant per year.

- iii) A supplier using only groundwater not under direct influence of surface water using chemical disinfectant and that serves 10,000 or more persons may reduce monitoring if it has monitored at least one year and its TTHM annual average is less than or equal to 0.040 mg/l and HAA5 annual average is less than or equal to 0.030 mg/l. The reduced monitoring allowed is a minimum of one sample per treatment plant per year at a distribution system location reflecting maximum residence time during month of warmest water temperature.
- iv) A supplier using only groundwater not under direct influence of surface water that uses chemical disinfectant and which serves fewer than 10,000 persons may reduce monitoring if it has monitored at least one year and its TTHM annual average is less than or equal to 0.040 mg/land HAA5 annual average is less than or equal to 0.030 mg/ $\ell$  for two consecutive years or TTHM annual average is less than or equal to 0.020 mg/ $\ell$  and HAA5 annual average is less than or equal to 0.015 mg/l for one year. The reduced monitoring allowed is a minimum of one sample per treatment plant per three year monitoring cycle at a distribution system location reflecting maximum residence time during month of warmest water temperature, with the three -year cycle beginning on January 1 following the quarter in which the supplier qualifies for reduced monitoring.
- C) Monitoring requirements for source water TOC. In order to qualify for reduced monitoring for TTHM and HAA5 under subsection

### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

(b)(1)(B) of this Section, a Subpart B system supplier not monitoring under the provisions of subsection (d) of this Section must take monthly TOC samples every 30 days at a location prior to any treatment, beginning no later than April 1, 2008. In addition to meeting other criteria for reduced monitoring in subsection (b)(1)(B) of this Section, the source water TOC running annual average must be  $\leq 4.0 \text{ mg/}\ell$  (based on the most recent four quarters of monitoring) on a continuing basis at each treatment plant to reduce or remain on reduced monitoring for TTHM and HAA5. Once qualified for reduced monitoring for TTHM and HAA5 under subsection (b)(1)(B) of this Section, a system may reduce source water TOC monitoring to quarterly TOC samples taken every 90 days at a location prior to any treatment.

- D) A Subpart B system supplier on a reduced monitoring schedule may remain on that reduced schedule as long as the average of all samples taken in the year (for a supplier that must monitor quarterly) or the result of the sample (for a supplier that must monitor no more frequently than annually) is no more than 0.060  $mg/\ell$  and 0.045  $mg/\ell$  for TTHMs and HAA5, respectively. A supplier that does not meet these levels must resume monitoring at the frequency identified in subsection (b)(1)(A) of this Section in the quarter immediately following the monitoring period in which the supplier exceeds 0.060 mg/ $\ell$  for TTHMs or 0.045 mg/ $\ell$  for HAA5. For a supplier that uses only groundwater not under the direct influence of surface water and which serves fewer than 10,000 persons, if either the TTHM annual average is greater than 0.080 mg/l or the HAA5 annual average is greater than 0.060 $mg/\ell$ , the supplier must go to increased monitoring identified in subsection (b)(1)(A) of this Section in the quarter immediately following the monitoring period in which the supplier exceeds 0.080 mg/ $\ell$  for TTHMs or 0.060 mg/ $\ell$  for HAA5.
- E) The Agency may return a supplier to routine monitoring.
- 2) Chlorite. A CWS or NTNCWS supplier using chlorine dioxide, for disinfection or oxidation, must conduct monitoring for chlorite.
  - A) Routine monitoring.

### POLLUTION CONTROL BOARD

- Daily monitoring. A supplier must take daily samples at the entrance to the distribution system. For any daily sample that exceeds the chlorite MCL, the supplier must take additional samples in the distribution system the following day at the locations required by subsection (b)(2)(B) of this Section, in addition to the sample required at the entrance to the distribution system.
- ii) Monthly monitoring. A supplier must take a three \_sample set each month in the distribution system. The supplier must take one sample at each of the following locations: near the first customer, at a location representative of average residence time, and at a location reflecting maximum residence time in the distribution system. Any additional routine sampling must be conducted in the same manner (as three-\_sample sets, at the specified locations). The supplier may use the results of additional monitoring conducted under subsection (b)(2)(B) of this Section to meet the requirement for monitoring in this subsection (b)(2)(A)(ii).
- B) Additional monitoring. On each day following a routine sample monitoring result that exceeds the chlorite MCL at the entrance to the distribution system, the supplier must take three chlorite distribution system samples at the following locations: as close to the first customer as possible, in a location representative of average residence time, and as close to the end of the distribution system as possible (reflecting maximum residence time in the distribution system).
- C) Reduced monitoring.
  - i) Chlorite monitoring at the entrance to the distribution system required by subsection (b)(2)(A)(i) of this Section may not be reduced.
  - ii) Chlorite monitoring in the distribution system required by subsection (b)(2)(A)(ii) of this Section may be reduced to

### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

one three-sample set per quarter after one year of monitoring where no individual chlorite sample taken in the distribution system under subsection (b)(2)(A)(ii) of this Section has exceeded the chlorite MCL and the supplier has not been required to conduct monitoring under subsection (b)(2)(B) of this Section. The supplier may remain on the reduced monitoring schedule until either any of the three individual chlorite samples taken quarterly in the distribution system under subsection (b)(2)(A)(ii) of this Section exceeds the chlorite MCL or the supplier is required to conduct monitoring under subsection (b)(2)(B)of this Section, at which time the supplier must revert to routine monitoring.

- 3) Bromate.
  - A) Routine monitoring. A CWS or NTNCWS supplier using ozone, for disinfection or oxidation, must take one sample per month for each treatment plant in the system using ozone. A supplier must take samples monthly at the entrance to the distribution system while the ozonation system is operating under normal conditions.
  - B) Reduced monitoring. A supplier required to analyze for bromate may reduce monitoring from monthly to guarterly, if the supplier 's running annual average bromate concentration is not greater than 0.0025 mg/l based on monthly bromate measurements under subsection (b)(3)(A) of this Section for the most recent four guarters, with samples analyzed using USEPA OGWDW Methods, Method 302.0, Method 317.0 (rev. 2.0), Method 326.0 (rev. 1.0), or Method 557 or USEPA Organic and Inorganic Methods, Method 321.8. If a supplier has qualified for reduced bromate monitoring under subsection (b)(3)(B)(i) of this Section, that supplier may remain on reduced monitoring as long as the running annual average of quarterly bromate samples not greater than 0.0025 mg/l based on samples analyzed using USEPA OGWDW Methods, Method 302.0, Method 317.0, Method 326.0, or Method 557 or USEPA Organic and Inorganic Methods, Method 321.8. If the running annual average bromate concentration is greater than 0.0025 mg/l, the supplier must resume routine monitoring required

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

### by subsection (b)(3)(A) of this Section.

- Until March 31, 2009, a supplier required to analyze for bromate may reduce monitoring from monthly to quarterly, if the supplier demonstrates that the average source waterbromide concentration is less than 0.05 mg/l based on representative monthly bromide measurements for one year. The supplier may remain on reduced bromate monitoring until the running annual average source water bromide concentration, computed quarterly, is equal to or greater than 0.05 mg/l based on representative monthly measurements. If the running annual average source water bromide concentration is equal to or greater than 0.05 mg/l, the supplier must resume routine monitoring required by subsection (b)(3)(A) of this Section in the following month.
- Beginning April 1, 2009, a Subpart B system supplier mayii) no longer use the provisions of subsection (b)(3)(B)(i) of this Section to qualify for reduced monitoring. A supplierrequired to analyze for bromate may reduce monitoringfrom monthly to quarterly, if the supplier's running annualaverage bromate concentration is not greater than 0.0025 mg/l based on monthly bromate measurements undersubsection (b)(3)(A) of this Section for the most recent fourquarters, with samples analyzed using USEPA OGWDW-Methods, Method 302.0, Method 317.0 (rev. 2.0), Method 326.0 (rev. 1.0), or Method 557 or USEPA Organic and Inorganic Methods, Method 321.8. If a supplier hasqualified for reduced bromate monitoring under subsection-(b)(3)(B)(i) of this Section, that supplier may remain onreduced monitoring as long as the running annual averageof quarterly bromate samples not greater than 0.0025 mg/lbased on samples analyzed using USEPA OGWDW Methods, Method 302.0, Method 317.0, Method 326.0, or-Method 557 or USEPA Organic and Inorganic Methods, Method 321.8. If the running annual average bromateconcentration is greater than 0.0025 mg/l, the supplier mustresume routine monitoring required by subsection (b)(3)(A)of this Section.

## POLLUTION CONTROL BOARD

- c) Monitoring requirements for disinfectant residuals.
  - 1) Chlorine and chloramines.
    - A) Routine monitoring. A CWS or NTNCWS supplier that uses chlorine or chloramines must measure the residual disinfectant level in the distribution system at the same point in the distribution system and at the same time as total coliforms are sampled, as specified in Section 611.521. A Subpart B system supplier may use the results of residual disinfectant concentration sampling conducted under Section 611.532 for unfiltered systems or Section 611.533 for systems that filter, in lieu of taking separate samples.
    - B) Reduced monitoring. Monitoring may not be reduced.
  - 2) Chlorine dioxide.
    - A) Routine monitoring. A CWS, an NTNCWS, or a transient non-CWS supplier that uses chlorine dioxide for disinfection or oxidation must take daily samples at the entrance to the distribution system. For any daily sample that exceeds the MRDL, the supplier must take samples in the distribution system the following day at the locations required by subsection (c)(2)(B) of this Section, in addition to the sample required at the entrance to the distribution system.
    - B) Additional monitoring. On each day following a routine sample monitoring result that exceeds the MRDL, the supplier must take three chlorine dioxide distribution system samples. If chlorine dioxide or chloramines are used to maintain a disinfectant residual in the distribution system, or if chlorine is used to maintain a disinfectant residual in the distribution points after the entrance to the distribution system (i.e., no booster chlorination), the supplier must take three samples as close to the first customer as possible, at intervals of at least six hours. If chlorine is used to maintain a disinfectant residual in the distribution system and there are one or more disinfection addition points after the entrance to the distribution

### POLLUTION CONTROL BOARD

### NOTICE OF PROPOSED AMENDMENTS

system (i.e., booster chlorination), the supplier must take one sample at each of the following locations: as close to the first customer as possible, in a location representative of average residence time, and as close to the end of the distribution system as possible (reflecting maximum residence time in the distribution system).

- C) Reduced monitoring. Monitoring may not be reduced.
- d) Monitoring requirements for disinfection byproduct (DBP) precursors.
  - 1) Routine monitoring. A Subpart B system supplier that uses conventional filtration treatment (as defined in Section 611.101) must monitor each treatment plant for TOC not past the point of combined filter effluent turbidity monitoring and representative of the treated water. A supplier required to monitor under this subsection (d)(1) must also monitor for TOC in the source water prior to any treatment at the same time as monitoring for TOC in the treated water. These samples (source water and treated water) are referred to as paired samples. At the same time as the source water prior to any treatment. A supplier must take one paired sample and one source water alkalinity sample per month per plant at a time representative of normal operating conditions and influent water quality.
  - 2) Reduced monitoring. A Subpart B system supplier with an average treated water TOC of less than 2.0 mg/ $\ell$  for two consecutive years, or less than 1.0 mg/ $\ell$  for one year, may reduce monitoring for both TOC and alkalinity to one paired sample and one source water alkalinity sample per plant per quarter. The supplier must revert to routine monitoring in the month following the quarter when the annual average treated water TOC greater than or equal to 2.0 mg/ $\ell$ .
- e) Bromide. A supplier required to analyze for bromate may reduce bromate monitoring from monthly to once per quarter, if the supplier demonstrates that the average source water bromide concentration is less than 0.05 mg/ $\ell$  based upon representative monthly measurements for one year. The supplier must continue bromide monitoring to remain on reduced bromate monitoring.

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

- f) Monitoring plans. Each supplier required to monitor under this Subpart I must develop and implement a monitoring plan. The supplier must maintain the plan and make it available for inspection by the Agency and the general public no later than 30 days following the applicable compliance dates in Section 611.380(b). A Subpart B system supplier that serves more than 3,300 persons must submit a copy of the monitoring plan to the Agency no later than the date of the first report required under Section 611.384. After review, the Agency may require changes in any plan elements. The plan must include at least the following elements:
  - 1) Specific locations and schedules for collecting samples for any parameters included in this Subpart I;
  - 2) How the supplier will calculate compliance with MCLs, MRDLs, and treatment techniques; and
  - 3) If approved for monitoring as a consecutive system, or if providing water to a consecutive system, under the provisions of Section 611.500, the sampling plan must reflect the entire distribution system.

BOARD NOTE: Derived from 40 CFR 141.132 (2010)(2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

SUBPART N: INORGANIC MONITORING AND ANALYTICAL REQUIREMENTS

## Section 611.600 Applicability

The following types of suppliers must conduct monitoring to determine compliance with the old MCLs in Section 611.300 and the revised MCLs in 611.301, as appropriate, in accordance with this Subpart N:

- a) CWS suppliers.
- b) NTNCWS suppliers.
- c) Transient non--CWS suppliers to determine compliance with the nitrate and nitrite MCLs.
- d) Detection limits. The following are detection limits for purposes of this Subpart

# POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

N (MCLs from Section 611.301 are set forth for information purposes only):

Contaminant	MCL (mg/l, except asbestos)	Method	Detection Limit (mg/l)
Antimony	0.006	Atomic absorption- <u></u> furnace technique	0.003
		Atomic absorptionfurnace technique (stabilized temperature)	0.00085
		Inductively coupled plasma-mass spectrometry	0.0004
		Atomic absorption- <u>-</u> gaseous hydride technique	0.001
Arsenic	0.010 <sup>6</sup> 0.010	Atomic absorption- <u></u> furnace technique	0.001
		Atomic absorption- <u></u> furnace technique (stabilized temperature)	0.00005 <sup>76</sup> 0 .00005 <sup>6</sup>
		Atomic absorption- <u>gaseous</u> hydride technique	0.001
		Inductively coupled plasma-mass spectrometry	0.0014 <sup>87</sup> 0. 0014 <sup>7</sup>
Asbestos	7 MFL <sup>1</sup>	Transmission electron microscopy	0.01 MFL
Barium	2	Atomic absorptionfurnace technique	0.002

.

# POLLUTION CONTROL BOARD

		Atomic absorptiondirect aspiration technique	0.1
		Inductively coupled plasma arc furnace	0.002
		Inductively coupled plasma	0.001
Beryllium	0.004	Atomic absorption furnace technique	0.0002
		Atomic absorption- <u></u> furnace technique (stabilized temperature)	0.000025
		Inductively coupled plasma <sup>2</sup>	0.0003
		Inductively coupled plasma-mass spectrometry	0.0003
Cadmium	0.005	Atomic absorption <u>-</u> furnace technique	0.0001
		Inductively coupled plasma	0.001
Chromium	0.1	Atomic absorption <u>–</u> furnace technique	0.001
		Inductively coupled plasma	0.007
		Inductively coupled plasma	0.001
Cyanide	0.2	Distillation, spectrophotometric <sup>3</sup>	0.02
		Automated distillation,	0.005

•

# POLLUTION CONTROL BOARD

		spectrophotometric <sup>3</sup> Distillation, selective electrode <sup>3</sup>	0.05
		Distillation, amenable, spectrophotometric <sup>4</sup>	0.02
		UV, distillation, spectrophotometric <sup>988</sup>	0.0005
		Micro distillation, flow injection, spectrophotometric <sup>3</sup>	0.0006
		Ligand exchange with amperometry <sup>4</sup>	0.0005
Mercury	0.002	Manual cold vapor technique	0.0002
		Automated cold vapor technique	0.0002
Nickel	No MCL	Atomic absorptionfurnace technique	0.001
		Atomic absorption- <u></u> furnace technique (stabilized temperature)	0.00065
		Inductively coupled plasma <sup>2</sup>	0.005
		Inductively coupled plasma-mass spectrometry	0.0005
Nitrate (as N)	10	Manual cadmium reduction	0.01
		Automated hydrazine	0.01

.

|.

## POLLUTION CONTROL BOARD

		reduction Automated cadmium reduction Ion-selective electrode	0.05 1
		Ion chromatography	0.01
		Capillary ion electrophoresis	0.076
Nitrite (as N)	1	Spectrophotometric	0.01
		Automated cadmium reduction	0.05
		Manual cadmium reduction	0.01
		Ion chromatography	0.004
		Capillary ion electrophoresis	0.103
Selenium	0.05	Atomic absorptionfurnace technique	0.002
		Atomic absorption- <u></u> gaseous hydride technique	0.002
Thallium	0.002	Atomic absorption- <u></u> furnace technique	0.001
		Atomic absorption- <u></u> furnace technique (stabilized temperature)	0.00075
		Inductively coupled plasma-mass spectrometry	0.0003

### POLLUTION CONTROL BOARD

### NOTICE OF PROPOSED AMENDMENTS

#### Footnotes.

- "MFL" means millions of fibers per liter less than 10 µm.
- <sup>2</sup> Using a 2x preconcentration step as noted in Method 200.7. Lower MDLs may be achieved when using a 4x preconcentration.
- 3 Screening method for total cvanides.
- 4 Measures "free" cyanides when distillation, digestion, or ligand exchange is omitted.
- 5 Lower MDLs are reported using stabilized temperature graphite furnace atomic absorbtion.
- <sup>6</sup> The MDL reported for USEPA Method 200.9 (atomic absorption-platform furnace (stabilized temperature)) was determined using a 2x concentration step during sample digestion. The MDL determined for samples analyzed using direct analyses (i.e., no sample digestion) will be higher. Using multiple depositions, USEPA Method 200.9 is capable of obtaining an MDL of 0.0001 mg/l.
- <sup>2</sup> Using selective ion monitoring. USEPA Method 200.8 (ICP-MS) is capable of obtaining an MDL of 0.0001 mg/ℓ.
- Measures total cyanides when UV-digestor is used, and "free" cyanides when UV-digestor is bypassed.

#### Footnotes.

- 1 "MFL" means millions of fibers per liter less than 10 μm.
- 2 Using a 2× preconcentration step as noted in Method 200.7. Lower MDLsmay be achieved when using a 4× preconcentration.
- 3 Screening method for total cyanides.
- 4 Measures "free" cyanides when distillation, digestion, or ligand exchange is omitted.
- 5 Lower MDLs are reported using stabilized temperature graphite furnaceatomic absorption.
- 6 The value for arsenic is effective January 23, 2006. Until then, the MCL is 0.05 mg/t.
- 76 The MDL reported for USEPA Method 200.9 (atomic absorption platformfurnace (stabilized temperature)) was determined using a 2× concentrationstep during sample digestion. The MDL determined for samples analyzed using direct analyses (i.e., no sample digestion) will be higher. Using multipledepositions, USEPA Method 200.9 is capable of obtaining an MDL of 0.0001mg/ℓ.

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

- 87 Using selective ion monitoring, USEPA Method 200.8 (ICP-MS) is capable of obtaining an MDL of 0.0001 mg/l.
- 98 Measures total cyanides when UV-digestor is used, and "free" cyanides when UV digestor is bypassed.

BOARD NOTE: Subsections (a) through (c) of this Section are derived from 40 CFR 141.23 preamble (2007) (2012), and subsection (d) of this Section is derived from 40 CFR 141.23 (a)(4)(i) (2007) and appendix A to 40 CFR 141, as added at 73 Fed. Reg. 31616 (June 3, 2008) 141 (2012). See the Board Note at Section 611.301(b) relating to the MCL for nickel.

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

## Section 611.603 Inorganic Monitoring Frequency

The frequency of monitoring conducted to determine compliance with the revised MCLs in Section 611.301 for antimony, arsenic, barium, beryllium, cadmium, chromium, cyanide, fluoride, mercury, nickel, selenium, and thallium is as follows:

- a) Suppliers must take samples at each sampling point, beginning in the initial compliance period, as follows:
  - 1) For a GWS supplier: at least one sample during each compliance period;
  - 2) For an SWS or a mixed system supplier: at least one sample each year.

BOARD NOTE: Derived from 40 CFR 141.23(c)(1) (2002)(2012).

- b) SEP Application.
  - The supplier may apply to the Agency for a SEP that allows reduction from the monitoring frequencies specified in subsection (a) of this Section pursuant to subsections (d) through (f) of this Section and Section 611.110.
  - 2) The supplier may apply to the Agency for a SEP that relieves it of the requirement for monitoring cyanide pursuant to subsections (d) through (f) of this Section and Section 611.110 if it can demonstrate that its system is not vulnerable due to a lack of any industrial source of cyanide.

BOARD NOTE: Drawn from 40 CFR 141.23(c)(2) and (c)(6) (2002)(2012).

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

SEP Procedures. The Agency must review the request pursuant to the SEP procedures of Section 611.110 based on consideration of the factors in subsection (e) of this Section.

BOARD NOTE: Drawn from 40 CFR 141.23(c)(6) (2002) (2012).

- d) Standard for SEP reduction in monitoring. The Agency must grant a SEP that allows a reduction in the monitoring frequency if the supplier demonstrates that all previous analytical results were less than the MCL, provided the supplier meets the following minimum data requirements:
  - 1) For GWS suppliers: a minimum of three rounds of monitoring.
  - 2) For an SWS or mixed system supplier: annual monitoring for at least three years.
  - 3) At least one sample must have been taken since January 1, 1990.
  - 4) A supplier that uses a new water source is not eligible for a SEP until it completes three rounds of monitoring from the new source.

BOARD NOTE: Drawn from 40 CFR 141.23(c)(4) (2002)(2012).

- e) Standard for SEP monitoring conditions. As a condition of any SEP, the Agency must require that the supplier take a minimum of one sample during the term of the SEP. In determining the appropriate reduced monitoring frequency, the Agency must consider the following:
  - 1) Reported concentrations from all previous monitoring;
  - 2) The degree of variation in reported concentrations; and
  - 3) Other factors that may affect contaminant concentrations, such as changes in groundwater pumping rates, changes in the CWS<sup>2</sup>'s configuration, the CWS<sup>2</sup>'s operating procedures, or changes in stream flows or characteristics.

BOARD NOTE: Drawn from 40 CFR 141.23(c)(3) and (c)(5) (2002) (2012).

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

- f) SEP Conditions and Revision.
  - 1) A SEP will expire at the end of the compliance cycle for which it was issued.

BOARD NOTE: Drawn from 40 CFR 141.23(c)(3) (2002) (2012).

2) In issuing a SEP, the Agency must specify the level of the contaminant upon which the "reliably and consistently" determination was based. A SEP must provide that the Agency will review and, where appropriate, revise its determination of the appropriate monitoring frequency when the supplier submits new monitoring data or when other data relevant to the supplier 's appropriate monitoring frequency become available.

BOARD NOTE: Drawn from 40 CFR 141.23(c)(6) (2002) (2012).

g) A supplier that exceeds the MCL as determined in Section 611.609, must monitor quarterly for that contaminant, beginning in the next quarter after the violation occurred.

BOARD NOTE: Derived from 40 CFR 141.23(c)(7) (2002) (2012).

- h) Reduction of quarterly monitoring.
  - 1) The Agency must grant a SEP pursuant to Section 611.110 that reduces the monitoring frequency to that specified by subsection (a) of this Section if it determines that the sampling point is reliably and consistently below the MCL.
  - 2) A request for a SEP must include the following minimal information:
    - A) For a GWS: two quarterly samples.
    - B) For an SWS or mixed system supplier: four quarterly samples.
  - 3) In issuing the SEP, the Agency must specify the level of the contaminant upon which the ""reliably and consistently" determination was based. Any SEP that allows less frequent monitoring based on an Agency

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

"reliably and consistently" determination must include a condition requiring the supplier to resume quarterly monitoring for any contaminant pursuant to subsection (g) of this Section if it violates the MCL specified by Section 611.609 for that contaminant.

BOARD NOTE: Derived from 40 CFR 141.23(c)(8) (2002) (2012).

i) A new system supplier that begins operation after January 22, 2004 or a supplier whose system uses a new source of water beginning after January 22, 2004 must demonstrate compliance with the MCL within a period of time specified by a permit issued the Agency. The supplier must also comply with the initial sampling frequencies specified by the Agency to ensure a system can demonstrate compliance with the MCL. Routine and increased monitoring frequencies must be conducted in accordance with the requirements in this Section.

BOARD NOTE: Derived from 40 CFR 141.23(c)(9) (2002)(2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

## Section 611.609 Determining Compliance

Compliance with the MCLs of Section 611.300 or 611.301 (as appropriate) must be determined based on the analytical results obtained at each sampling point.

- a) For suppliers that monitor at a frequency greater than annual, compliance with the MCLs for antimony, arsenic (effective January 22, 2004), asbestos, barium, beryllium, cadmium, chromium, cyanide, fluoride, mercury, nickel, selenium, or thallium is determined by a running annual average at each sampling point. -Effective January 22, 2004, if a system fails to collect the required number of samples, compliance (average concentration) will be based on the total number of samples collected.
  - 1) If the average at any sampling point is greater than the MCL, then the supplier is out of compliance.
  - 2) If any one sample would cause the annual average to be exceeded, then the supplier is out of compliance immediately.
  - 3) Any sample below the method detection limit must be calculated at zero

# POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

for the purpose of determining the annual average.

BOARD NOTE: The "method detection limit" is different from the "detection limit, " as set forth in Section 611.600. The "method detection limit" is the level of contaminant that can be determined by a particular method with a 95 percent degree of confidence, as determined by the method outlined in appendix B to 40 CFR 136, incorporated by reference at Section 611.102.

- 4) If a system fails to collect the required number of samples, compliance (average concentration) will be based on the total number of samples collected.
- b) For suppliers that monitor annually or less frequently, compliance with the MCLs for antimony, arsenic (effective January 22, 2004), asbestos, barium, beryllium, cadmium, chromium, cyanide, fluoride, mercury, nickel, selenium, or thallium is determined by the level of the contaminant at any sampling point. If confirmation samples are required by the Agency, the determination of compliance will be based on the average of the annual average of the initial MCL exceedence and any Agency-required confirmation samples. Effective January 22, 2004, if If a supplier fails to collect the required number of samples, compliance (average concentration) will be based on the total number of samples collected.
- c) Compliance with the MCLs for nitrate and nitrite is determined based on one sample if the levels of these contaminants are below the MCLs. If the levels of nitrate or nitrite in the initial sample exceed the MCLs, Section 611.606 requires confirmation sampling, and compliance is determined based on the average of the initial and confirmation samples.
- d) Arsenic sampling results must be reported to the nearest  $0.001 \text{ mg/}\ell$ .

BOARD NOTE: Derived from 40 CFR 141.23(i) (2005) (2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

## Section 611.611 Inorganic Analysis

Analytical methods are from documents incorporated by reference in Section 611.102. These are mostly referenced by a short name defined by Section 611.102(a). Other abbreviations are defined in Section 611.101.

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

a) Analysis for the following contaminants must be conducted using the following methods or an alternative method approved pursuant to Section 611.480. Criteria for analyzing arsenic, chromium, copper, lead, nickel, selenium, sodium, and thallium with digestion or directly without digestion, and other analytical procedures, are contained in USEPA Technical Notes, incorporated by reference in Section 611.102.

BOARD NOTE: Because MDLs reported in USEPA Environmental Metals Methods 200.7 and 200.9 were determined using a 2× preconcentration step during sample digestion, MDLs determined when samples are analyzed by direct analysis (i.e., no sample digestion) will be higher. For direct analysis of cadmium and arsenic by USEPA Environmental Metals Method 200.7, and arsenic by Standard Methods, Method 3120 B, sample preconcentration using pneumatic nebulization may be required to achieve lower detection limits. Preconcentration may also be required for direct analysis of antimony, lead, and thallium by USEPA Environmental Metals Method 200.9; antimony and lead by Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, or 21<sup>st</sup> ed., Method 3113 B; and lead by ASTM Method D3559-96 D or D3559-03 D unless multiple in-furnace depositions are made.

- 1) Alkalinity.
  - A) Titrimetric.
    - i) ASTM Method D1067-92 B, D1067-02 B, or D1067-06 B;r
    - Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., Method 2320
       B; or
    - iii) Standard Methods Online, Method 3113 B-04.
  - B) Electrometric titration: USGS Methods, Method I-1030-85.

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed., Method 2320 B as an approved alternative method for alkalinity in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).\_ USEPA added ASTM Method D1067-06 B and Standard Methods Online, Method 3113 B-04 as approved alternative methods for alkalinity in

### POLLUTION CONTROL BOARD

### NOTICE OF PROPOSED AMENDMENTS

appendix A to subpart C of 40 CFR 141 on June 24, 2011 (at 76 Fed. Reg. 37014).

- 2) Antimony.
  - A) Inductively coupled plasma-mass spectrometry: USEPA Environmental Metals Methods, Method 200.8 (rev. 5.3).
  - B) Atomic absorption, hydride technique: ASTM Method D3697-92, D3697-02, or D3697-07.
  - C) Atomic absorption, platform furnace technique: USEPA Environmental Metals Methods, Method 200.9 (rev. 2.2).
  - D) Atomic absorption, furnace technique:
    - i) Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, or 21<sup>st</sup> ed., Method 3113 B; or
    - ii) Standard Methods Online, Method 3113 B-04.
  - E) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): USEPA NERL Method 200.5.

BOARD NOTE: USEPA added Standard Methods, 21st ed., Method 3113B and USEPA NERL Method 200.5 as approved alternative methods for antimony in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Method D3697-07 as an approved alternative method for antimony in appendix A to subpart C of 40 CFR 141 on November 10, 2009 (at 74 Fed. Reg. 57908. USEPA added Standard Methods Online, Method 3113 B-04 as an approved alternative method for antimony in appendix A to subpart C of 40 CFR 141 on June 24, 2011 (at 76 Fed. Reg. 37014).

3) Arsenic.

BOARD NOTE: If ultrasonic nebulization is used in the determination of arsenic by Method 200.8, the arsenic must be in the pentavalent state to provide uniform signal response. For direct analysis of arsenic with Method 200.8 using ultrasonic nebulization, samples and standards must contain one  $mg/\ell$  of sodium hypochlorite.

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

- A) Inductively coupled plasma-mass spectrometry: USEPA Environmental Metals Methods, Method 200.8 (rev. 5.3).
- B) Atomic absorption, platform furnace technique: USEPA Environmental Metals Methods, Method 200.9 (rev. 2.2).
- C) Atomic absorption, furnace technique.
  - i) ASTM Method D2972-97 C, D2972-03 C, or D2972-08 C;
  - Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, or 21<sup>st</sup> ed., Method 3113 B;
     or
  - iii) Standard Methods Online, Method 3113 B-04.
- D) Atomic absorption, hydride technique.
  - i) ASTM Method D2972-97 B, D2972-03 C, or D2972-08 B;
  - Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, or 21<sup>st</sup> ed., Method 3114 B; or
  - iii) Standard Methods Online, Method 3114 B-04.
- E) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): USEPA NERL Method 200.5.

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed., Methods 3113 B and 3114 B and USEPA NERL Method 200.5 as approved alternative methods for arsenic in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Methods D2972-08 B and C as approved alternative methods for arsenic in appendix A to subpart C of 40 CFR 141 on November 10, 2009 (at 74 Fed. Reg. 57908). USEPA added Standard Methods Online, Method 3113 B-04 and Method 3114 B-04 as approved alternative methods for arsenic in appendix A to subpart C of 40 CFR 141 on June 24, 2011 (at 76 Fed. Reg. 37014).

4) Asbestos: Transmission electron microscopy: USEPA Asbestos Method \_100.1 or USEPA Asbestos Method \_100.2.

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

- 5) Barium.
  - A) Inductively coupled plasma.
    - i) USEPA Environmental Metals Methods, Method 200.7 (rev. 4.4); or
    - ii) Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., Method 3120
       B.
  - B) Inductively coupled plasma-mass spectrometry: USEPA Environmental Metals Methods, Method 200.8 (rev. 5.3).
  - C) Atomic absorption, direct aspiration technique: Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, or 21<sup>st</sup> ed., Method 3111 D.
  - D) Atomic absorption, furnace technique:
    - i) Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, or 21<sup>st</sup> ed., Method 3113 B; or
    - ii) Standard Methods Online, Method 3113 B-04.
  - E) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): USEPA NERL Method 200.5.

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed., Methods 3111 D, 3113 B, and 3120 B and USEPA NERL Method 200.5 as approved alternative methods for barium in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added Standard Methods Online, Method 3113 B-04 as an approved alternative method for barium in appendix A to subpart C of 40 CFR 141 on June 24, 2011 (at 76 Fed. Reg. 37014).

- 6) Beryllium.
  - A) Inductively coupled plasma.

## POLLUTION CONTROL BOARD

### NOTICE OF PROPOSED AMENDMENTS

- i) USEPA Environmental Metals Methods, Method 200.7 (rev. 4.4); or
- Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., Method 3120
   B.
- B) Inductively coupled plasma-mass spectrometry: USEPA Environmental Metals Methods, Method 200.8 (rev. 5.3).
- C) Atomic absorption, platform furnace technique: USEPA Environmental Metals Methods, Method 200.9 (rev. 2.2).
- D) Atomic absorption, furnace technique.
  - i) ASTM Method D3645-97 B, D3645-03 B, or D3645-08 B;-
  - ii) Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, or 21<sup>st</sup> ed., Method 3113 B; or
  - iii) Standard Methods Online, Method 3113 B-04.
- E) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): USEPA NERL Method 200.5.

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed., Methods 3113 B and 3120 B and USEPA NERL Method 200.5 as approved alternative methods for beryllium in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Method D3645-08 B as an approved alternative method for beryllium in appendix A to subpart C of 40 CFR 141 on November 10, 2009 (at 74 Fed. Reg. 57908). USEPA added Standard Methods Online, Method 3113 B-04 as an approved alternative method for beryllium in appendix A to subpart C of 40 CFR 141 on June 24, 2011 (at 76 Fed. Reg. 37014).

- 7) Cadmium.
  - A) Inductively coupled plasma arc furnace: USEPA Environmental Metals Methods, Method 200.7 (rev. 4.4).

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

- B) Inductively coupled plasma-mass spectrometry: USEPA Environmental Metals Methods, Method 200.8 (rev. 5.3).
- C) Atomic absorption, platform furnace technique: USEPA Environmental Metals Methods, Method 200.9 (rev. 2.2).
- D) Atomic absorption, furnace technique:
  - i) Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, or 21<sup>st</sup> ed., Method 3113 B; or
  - ii) Standard Methods Online, Method 3113 B-04.
- E) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): USEPA NERL Method 200.5.

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed., Method 3113 B and USEPA NERL Method 200.5 as approved alternative methods for cadmium in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added Standard Methods Online, Method 3113 B-04 as an approved alternative method for cadmium in appendix A to subpart C of 40 CFR 141 on June 24, 2011 (at 76 Fed. Reg. 37014).

- 8) Calcium.
  - A) EDTA titrimetric.
    - i) ASTM Method D511-93 A, D511-03 A, or D511-09 A; or
    - ii) Standard Methods, 18<sup>th</sup> or 19<sup>th</sup> ed., Method 3500-Ca D or Standard Methods, 20<sup>th</sup> or 21<sup>st</sup> ed., Method 3500-Ca B.
  - B) Atomic absorption, direct aspiration.
    - i) ASTM Method D511-93 B, D511-03 B, or D511-09 B; or
    - ii) Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, or 21<sup>st</sup> ed., Method 3111 B.
  - C) Inductively coupled plasma.

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

- i) USEPA Environmental Metals Methods, Method 200.7 (rev. 4.4); or
- Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., Method 3120
   B.
- D) Ion chromatography: ASTM Method D6919-03 or D6919-09.
- E) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): USEPA NERL Method 200.5.

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed., Methods 3111 B, 3120 B, and 3500-Ca B and USEPA NERL Method 200.5 as approved alternative methods for calcium in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Methods D511-09 A and B as approved alternative methods for calcium in appendix A to subpart C of 40 CFR 141 on November 10, 2009 (at 74 Fed. Reg. 57908). USEPA added ASTM Method D6919-09 as an approved alternative method for calcium in appendix A to subpart C of 40 CFR 141 on June 24, 2011 (at 76 Fed. Reg. 37014).

- 9) Chromium.
  - A) Inductively coupled plasma.
    - i) USEPA Environmental Metals Methods, Method 200.7 (rev. 4.4); or
    - Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., Method 3120
       B.
  - B) Inductively coupled plasma-mass spectrometry: USEPA Environmental Metals Methods, Method 200.8 (rev. 5.3).
  - C) Atomic absorption, platform furnace technique: USEPA Environmental Metals Methods, Method 200.9 (rev. 2.2).
  - D) Atomic absorption, furnace technique:

## POLLUTION CONTROL BOARD

### NOTICE OF PROPOSED AMENDMENTS

- i) Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, or 21<sup>st</sup> ed., Method 3113 B; or
- ii) Standard Methods Online, Method 3113 B-04.
- E) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): USEPA NERL Method 200.5.

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed., Methods 3113 B and 3120 B and USEPA NERL Method 200.5 as approved alternative methods for chromium in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added Standard Methods Online, Method 3113 B-04 as an approved alternative method for chromium in appendix A to subpart C of 40 CFR 141 on June 24, 2011 (at 76 Fed. Reg. 37014).

- 10) Copper.
  - A) Atomic absorption, furnace technique.
    - i) ASTM Method D1688-95 C, D1688-02 C, or D1688-07 C;
    - ii) Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, or 21<sup>st</sup> ed., Method 3113 B; or
    - iii) Standard Methods Online, Method 3113 B-04.
  - B) Atomic absorption, direct aspiration.
    - i) ASTM Method D1688-95 A, D1688-02 A, or D1688-07 A; or
    - ii) Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, or 21<sup>st</sup> ed., Method 3111 B.
  - C) Inductively coupled plasma.
    - i) USEPA Environmental Metals Methods, Method 200.7 (rev. 4.4); or

### POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

- Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., Method 3120
   B.
- D) Inductively coupled plasma-mass spectrometry: USEPA Environmental Metals Methods, Method 200.8 (rev. 5.3).
- E) Atomic absorption, platform furnace technique: USEPA Environmental Metals Methods, Method 200.9 (rev. 2.2).
- F) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): USEPA NERL Method 200.5.

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed., Methods 3111 B, 3113 B, and 3120 B and USEPA NERL Method 200.5 as an approved alternative method for copper in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Methods D1688-07 A and C as approved alternative methods for copper in appendix A to subpart C of 40 CFR 141 on November 10, 2009 (at 74 Fed. Reg. 57908). USEPA added Standard Methods Online, Method 3113 B-04 as an approved alternative method for copper in appendix A to subpart C of 40 CFR 141 on June 24, 2011 (at 76 Fed. Reg. 37014).

- 11) Conductivity; Conductance.
  - A) ASTM Method D1125-95(1999) A; or
  - B) Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., Method 2510 B.

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed., Method 2510 B as an approved alternative method for conductivity in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

- 12) Cyanide.
  - A) Manual distillation (ASTM Method D2036-98 A or Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, or 20<sup>th</sup> ed., Method 4500-CN C), followed by spectrophotometric, amenable.
    - i) ASTM Method D2036-98 B or 2036-06 B; or

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

- ii) Standard Methods,  $18^{th}$ ,  $19^{th}$ ,  $20^{th}$ , or  $21^{st}$  ed., Method 4500-CN
- B) Manual distillation (ASTM Method D2036-98 A or Standard Methods, 18th, 19th, or 20th ed., Method 4500-CN-C), followed by spectrophotometric, manual.
  - i) ASTM Method D2036-98 A or D2036-06 A;
  - ii) Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., Method 4500-CN-E; or
  - iii) USGS Methods, Method I-3300-85.
- C) Spectrophotometric, semiautomated: USEPA Environmental Inorganic Methods, Method 335.4 (rev. 1.0).
- D) Selective electrode: Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., Method 4500-CN<sup>--</sup> F.
- E) UV/Distillation/Spectrophotometric: Kelada 01.
- F) Microdistillation/Flow Injection/Spectrophotometric: QuickChem 10-204-00-1-X.
- G) Ligand exchange and amperometry.
  - i) ASTM Method D6888-03.
  - ii) OI Analytical Method OIA-1677 DW.
- H) Gas chromatography-mass spectrometry headspace: Method ME355.01.

BOARD NOTE: USEPA added ASTM Method D2036-06 A and Standard Methods, 21<sup>st</sup> ed., Methods 4500-CN—E, F, and G as approved alternative methods for cyanide in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added Method

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

ME355.01 as an approved alternative method for cyanide in appendix A to subpart C of 40 CFR 141 on August 3, 2009 (at 74 Fed. Reg. 38348).

- 13) Fluoride.
  - A) Ion Chromatography.
    - i) USEPA Environmental Inorganic Methods, Method 300.0 (rev. 2.1) or USEPA Organic and Inorganic Methods, Method 300.1 (rev. 1.0);
    - ii) ASTM Method D4327-97 or D4327-03;
    - iii) Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., Method 4110
       B; or
    - iv) Hach SPADNS 2 Method 10225.
  - B) Manual distillation, colorimetric SPADNS: Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., Method 4500-F<sup>--</sup><sub>-</sub> B and D.
  - C) Manual electrode.
    - i) ASTM Method D1179-93 B, D1179-99 B, <del>or</del> D1179-04 B, or D1179-10 B; or
    - ii) Standard Methods,  $18^{\text{th}}$ ,  $19^{\text{th}}$ ,  $20^{\text{th}}$ , or  $21^{\text{st}}$  ed., Method  $4500 \text{-} F_{-5}^{-5} \text{C}$ .
  - D) Automated electrode: Technicon Methods, Method 380-75WE.
  - E) Automated alizarin.
    - i) Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., Method 4500-F \_: E; or
    - ii) Technicon Methods, Method 129-71W.
  - F) Capillary ion electrophoresis: ASTM Method D6508-00(2005).

### POLLUTION CONTROL BOARD

### NOTICE OF PROPOSED AMENDMENTS

BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for fluoride to add capillary ion electrophoresis in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of "Waters Method D6508, Rev. 2.3" The Board attempt to locate a copy of the method disclosed that it is an ASTM method originally approved in 2000 and reapproved in 2005. The Board has cited to the ASTM Method D6508-00 (2005).

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed., Methods 4110 B and 4500-F—B, C, D, and E and ASTM Method D1179-04 B as approved alternative methods for fluoride in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added Hach SPADNS 2 Method 10225 as an approved alternative method for fluoride in appendix A to subpart C of 40 CFR 141 on June 24, 2011 (at 76 Fed. Reg. 37014). USEPA added ASTM Method D1179-10 B as an approved alternative method for fluoride in appendix A to subpart C of 40 CFR 141 on June 24, 2011 (at 76 Fed. Reg. 37014). USEPA added ASTM Method D1179-10 B as an approved alternative method for fluoride in appendix A to subpart C of 40 CFR 141 on June 28, 2012 (at 77 Fed. Reg. 38528).

- 14) Lead.
  - A) Atomic absorption, furnace technique.
    - i) ASTM Method D3559-96 D, D3559-03 D, or D3559-08 D;
    - ii) Standard Methods, 18th, 19th, or 21st ed., Method 3113 B; or
    - iii) Standard Methods Online, Method 3113 B-04.
  - B) Inductively coupled plasma-mass spectrometry: USEPA Environmental Metals Methods, Method 200.8 (rev. 5.3).
  - C) Atomic absorption, platform furnace technique: USEPA Environmental Metals Methods, Method 200.9 (rev. 2.2).
  - D) Differential Pulse Anodic Stripping Voltammetry: Palintest Method 1001.

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

E) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): USEPA NERL Method 200.5.

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed., Method 3113 B and USEPA NERL Method 200.5 as approved alternative methods for lead in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Method D3559-08 D as an approved alternative method for lead in appendix A to subpart C of 40 CFR 141 on November 10, 2009 (at 74 Fed. Reg. 57908). USEPA added Standard Methods Online, Method 3113 B-04 as an approved alternative method for lead in appendix A to subpart C of 40 CFR 141 on June 24, 2011 (at 76 Fed. Reg. 37014).

- 15) Magnesium.
  - A) Atomic absorption.
    - i) ASTM Method D511-93 B, D511-03 B, or D511-09 B; or
    - ii) Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, or 21<sup>st</sup> ed., Method 3111 B.
  - B) Inductively coupled plasma.
    - i) USEPA Environmental Metals Methods, Method 200.7 (rev. 4.4); or
    - ii) Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., Method 3120 B.
  - C) Complexation titrimetric.
    - i) ASTM Method D511-93 A, D511-03 A, or D511-09 A; or
    - ii) Standard Methods, 18<sup>th</sup> or 19<sup>th</sup> ed., Method 3500-Mg E or Standard Methods, 20<sup>th</sup> or 21<sup>st</sup> ed., Method 3500-Mg B.
  - D) Ion chromatography: ASTM Method D6919-03 or D6919-09.

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

E) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): USEPA NERL Method 200.5.

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed., Methods 3111 B, 3120 B, and 3500-Mg B and USEPA NERL Method 200.5 as approved alternative methods for magnesium in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Methods D511-09 A and B as approved alternative methods for magnesium in appendix A to subpart C of 40 CFR 141 on November 10, 2009 (at 74 Fed. Reg. 57908). USEPA added ASTM Method D6919-09 as an approved alternative method for magnesium in appendix A to subpart C of 40 CFR 141 on June 24, 2011 (at 76 Fed. Reg. 37014).

- 16) Mercury.
  - A) Manual cold vapor technique.
    - USEPA Environmental Metals Methods, Method 245.1 (rev. 3.0);
    - ii) ASTM Method D3223-97 or D3223-02;-or
    - iii) Standard Methods, 18th, 19th, or 21st ed., Method 3112 B.;
    - iv) Standard Methods Online, Method 3112 B-09.
  - B) Automated cold vapor technique: USEPA Inorganic Methods, Method 245.2.
  - C) Inductively coupled plasma-mass spectrometry: USEPA Environmental Metals Methods, Method 200.8 (rev. 5.3).

BOARD NOTE: USEPA added Standard Methods,  $21^{st}$  ed., Method 3112 B as an approved alternative method for mercury in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added Standard Methods Online, Method 3112 B-09 as an approved alternative method for mercury in appendix A to subpart C of 40 CFR 141 on June 28, 2012 (at 77 Fed. Reg. 38528).

17) Nickel.

.

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

- A) Inductively coupled plasma.
  - i) USEPA Environmental Metals Methods, Method 200.7 (rev. 4.4); or
  - Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., Method 3120
     B.
- B) Inductively coupled plasma-mass spectrometry: USEPA Environmental Metals Methods, Method 200.8 (rev. 5.3).
- C) Atomic absorption, platform furnace technique: USEPA Environmental Metals Methods, Method 200.9 (rev. 2.2).
- D) Atomic absorption, direct aspiration technique: Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, or 21<sup>st</sup> ed., Method 3111 B.
- E) Atomic absorption, furnace technique:
  - i) Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, or 21<sup>st</sup> ed., Method 3113 B; or
  - ii) Standard Methods Online, Method 3113 B-04.
- F) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): USEPA NERL Method 200.5.

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed., Methods 3111 B, 3113 B, and 3120 B and USEPA NERL Method 200.5 as approved alternative methods for nickel in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added Standard Methods Online, Method 3113 B-04 as an approved alternative method for nickel in appendix A to subpart C of 40 CFR 141 on June 24, 2011 (at 76 Fed. Reg. 37014).

- 18) Nitrate.
  - A) Ion chromatography.

### POLLUTION CONTROL BOARD

- i) USEPA Environmental Inorganic Methods, Method 300.0 (rev. 2.1) or USEPA Organic and Inorganic Methods, Method 300.1 (rev. 1.0);
- ii) ASTM Method D4327-97 or D4327-03;
- iii) Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., Method 4110
   B; or
- iv) Waters Test Method B-1011, available from Millipore Corporation.
- B) Automated cadmium reduction.
  - USEPA Environmental Inorganic Methods, Method 353.2 (rev. 2.0);
  - ii) ASTM Method D3867-90 A; or
  - iii) Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., Method 4500-NO<sub>3</sub> F.
- C) Ion selective electrode.
  - i) Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., Method 4500-NO<sub>3</sub> D; or
  - ii) Technical Bulletin 601.
- D) Manual cadmium reduction.
  - i) ASTM Method D3867-90 B; or
  - ii) Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., Method 4500-NO<sub>3</sub>- E.
- E) Capillary ion electrophoresis: ASTM Method D6508-00(2005).

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for nitrate to add capillary ion electrophoresis in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of "Waters Method D6508, Rev. 2." The Boardattempt to locate a copy of the method disclosed that it is an ASTMmethod originally approved in 2000 and reapproved in 2005. The Board has cited to the ASTM Method D6508-00(2005).

- F) Reduction-colorimetric: Systea Easy (1-Reagent).
- G) Direct colorimetric: Hach TNTplus 835/836 Method 10206.

BOARD NOTE: USEPA added Standard Methods,  $21^{st}$  ed., Methods 4110 B and 4500-NO<sub>3</sub>-; D, E, and F as approved alternative methods for nitrate in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added Systea Easy (1-Reagent) as an approved alternative method for nitrate in appendix A to subpart C of 40 CFR 141 on August 3, 2009 (at 73 Fed. Reg. 38348). USEPA added Hach TNTplus 835/836 Method 10206 as an approved alternative method for nitrate in appendix A to subpart C of 40 CFR 141 on June 24, 2011 (at 76 Fed. Reg. 37014).

- 19) Nitrite.
  - A) Ion chromatography.
    - i) USEPA Environmental Inorganic Methods, Method 300.0 (rev. 2.1) or USEPA Organic and Inorganic Methods, Method 300.1 (rev. 1.0);
    - ii) ASTM Method D4327-97 or D4327-03;
    - iii) Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., Method 4110 B; or
    - iv) Waters Test Method B-1011, available from Millipore Corporation.
  - B) Automated cadmium reduction.

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

- i) USEPA Environmental Inorganic Methods, Method 353.2 (rev. 2.0);
- ii) ASTM Method D3867-90 A; or
- iii) Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., Method 4500-NO<sub>3</sub>-F.
- C) Manual cadmium reduction.
  - i) ASTM Method D3867-90 B; or
  - ii) Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., Method 4500-NO<sub>3</sub>- E.
- D) Spectrophotometric: Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., Method 4500-NO<sub>2</sub>-B.
- E) Capillary ion electrophoresis: ASTM Method D6508-00(2005).

BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for nitrite to add capillary ion electrophoresis in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of "Waters Method D6508, Rev. 2." The Board attempt to locate a copy of the method disclosed that it is an ASTM method originally approved in 2000 and reapproved in 2005. The Board has cited to the ASTM Method D6508-00(2005).

F) Reduction-colorimetric: Systea Easy (1-Reagent).

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed., Methods 4110 B, 4500-NO<sub>3</sub>— E and F; and 4500-NO<sub>2</sub>— B as approved alternative methods for nitrite in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added Systea Easy (1-Reagent) as an approved alternative method for nitrite in appendix A to subpart C of 40 CFR 141 on August 3, 2009 (at 73 Fed. Reg. 38348).

# POLLUTION CONTROL BOARD

- 20) Orthophosphate (unfiltered, without digestion or hydrolysis).
  - A) Automated colorimetric, ascorbic acid.
    - i) USEPA Environmental Inorganic Methods, Method 365.1 (rev. 2.0); or
    - ii) Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., Method 4500-P F.
  - B) Single reagent colorimetric, ascorbic acid.
    - i) ASTM Method D515-88 A; or
    - ii) Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., Method 4500-P E.
  - Colorimetric, phosphomolybdate: USGS Methods, Method I-1601-85.
  - D) Colorimetric, phosphomolybdate, automated-segmented flow: USGS Methods, Method I-2601-90.
  - E) Colorimetric, phosphomolybdate, automated discrete: USGS Methods, Method I-2598-85.
  - F) Ion Chromatography.
    - USEPA Environmental Inorganic Methods, Method 300.0 (rev. 2.1) or USEPA Organic and Inorganic Methods, Method 300.1 (rev. 1.0);
    - ii) ASTM Method D4327-97 or D4327-03; or
    - iii) Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., Method 4110
       B.
  - G) Capillary ion electrophoresis: ASTM Method D6508-00(2005).

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for orthophosphate to add capillary ion electrophoresis in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of "Waters Method D6508, Rev. 2." The Board attempt to locate a copy of the method disclosed that it is an ASTMmethod originally approved in 2000 and reapproved in 2005. The Board has cited to the ASTM Method D6508-00(2005).

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed., Methods 4110 B, 4500-P E and F as approved alternative methods for orthophosphate in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

- 21) pH: electrometric.
  - A) USEPA Inorganic Methods, Method 150.1 or Method 150.2;
  - B) ASTM Method D1293-95 or D1293-99; or
  - C) Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., Method 4500-H<sup>+</sup> B.

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed., Method 4500-H<sup>+</sup> B as an approved alternative method for pH in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

- 22) Selenium.
  - A) Atomic absorption, hydride.
    - i) ASTM Method D3859-98 A, D3859-03 A, or D3859-08 A;
    - ii) Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, or 21<sup>st</sup> ed., Method 3114 B; or
    - iii) Standard Methods Online, Method 3114 B-09.
  - B) Inductively coupled plasma-mass spectrometry: USEPA Environmental Metals Methods, Method 200.8 (rev. 5.3).

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

- C) Atomic absorption, platform furnace technique: USEPA Environmental Metals Methods, Method 200.9 (rev. 2.2).
- D) Atomic absorption, furnace technique.
  - i) ASTM Method D3859-98 B, D3859-03 B, or D3859-08 B;
  - ii) Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, or 21<sup>st</sup> ed., Method 3113 B; or
  - iii) Standard Methods Online, Method 3113 B-04.
- E) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): USEPA NERL Method 200.5.

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed., Methods 3113 B and 3114 B and USEPA NERL Method 200.5 as approved alternative methods for selenium in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Methods D3859-08 A and B as approved alternative methods for selenium in appendix A to subpart C of 40 CFR 141 on November 10, 2009 (at 74 Fed. Reg. 57908). USEPA added Standard Methods Online, Method 3113 B-04 and Method 3114 B-09 as approved alternative methods for selenium in appendix A to subpart C of 40 CFR 141 on June 24, 2011 (at 76 Fed. Reg. 37014).

- 23) Silica.
  - A) Colorimetric, molybdate blue: USGS Methods, Method I-1700-85.
  - B) Colorimetric, molybdate blue, automated-segmented flow: USGS Methods, Method I-2700-85.
  - C) Colorimetric: ASTM Method D859-94, D859-00, or D859-05, or D859-10.
  - D) Molybdosilicate: Standard Methods, 18<sup>th</sup> or 19<sup>th</sup> ed., Method 4500-Si D or Standard Methods, 20<sup>th</sup> or 21<sup>st</sup> ed., Method 4500-SiO<sub>2</sub> C.

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

- E) Heteropoly blue: Standard Methods, 18<sup>th</sup> or 19<sup>th</sup> ed., Method 4500-Si E or Standard Methods, 20<sup>th</sup> or 21<sup>st</sup> ed., Method 4500-SiO<sub>2</sub>
   D.
- F) Automated method for molybdate-reactive silica: Standard Methods, 18<sup>th</sup> or 19<sup>th</sup> ed., Method 4500-Si F or Standard Methods, 20<sup>th</sup> or 21<sup>st</sup> ed., Method 4500-SiO<sub>2</sub> E.
- G) Inductively coupled plasma.
  - i) USEPA Environmental Metals Methods, Method 200.7 (rev. 4.4); or
  - Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., Method 3120
     B.
- H) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): USEPA NERL Method 200.5.

BOARD NOTE: USEPA added ASTM Method D859-05, Standard Methods, 21<sup>st</sup> ed.; Methods 3120 B and 4500-SiO<sub>2</sub> C, D, and E; and USEPA NERL Method 200.5 as approved alternative methods for silica in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Method D859-10 as an approved alternative method for silica in appendix A to subpart C of 40 CFR 141 on June 28, 2012 (at 77 Fed. Reg. 38528).

- 24) Sodium.
  - A) Inductively coupled plasma: USEPA Environmental Metals Methods, Method 200.7 (rev. 4.4).
  - B) Atomic absorption, direct aspiration: Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, or 21<sup>st</sup> ed., Method 3111 B.
  - C) Ion chromatography: ASTM Method D6919-03 or D6919-09.
  - D) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): USEPA NERL Method 200.5.

#### POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed., Method 3113 B and USEPA NERL Method 200.5 as approved alternative methods for sodium in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Method D6919-09 as an approved alternative method for sodium in appendix A to subpart C of 40 CFR 141 on June 24, 2011 (at 76 Fed. Reg. 37014).

25) Temperature; thermometric: Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., Method 2550.

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed., Method 2550 as an approved alternative method for temperature in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

- 26) Thallium.
  - A) Inductively coupled plasma-mass spectrometry: USEPA Environmental Metals Methods, Method 200.8 (rev. 5.3).
  - B) Atomic absorption, platform furnace technique: USEPA Environmental Metals Methods, Method 200.9 (rev. 2.2).
- b) Sample collection for antimony, arsenic (effective January 22, 2004), asbestos, barium, beryllium, cadmium, chromium, cyanide, fluoride, mercury, nickel, nitrate, nitrite, selenium, and thallium pursuant to Sections 611.600 through 611.604 must be conducted using the following sample preservation, container, and maximum holding time procedures:

BOARD NOTE: For cyanide determinations samples must be adjusted with sodium hydroxide to pH 12 at the time of collection. When chilling is indicated the sample must be shipped and stored at 4° C or less. Acidification of nitrate or metals samples may be with a concentrated acid or a dilute (50% by volume) solution of the applicable concentrated acid. Acidification of samples for metals analysis is encouraged and allowed at the laboratory rather than at the time of sampling provided the shipping time and other instructions in Section 8.3 of USEPA Environmental Metals Method 200.7, 200.8, or 200.9 are followed.

1) Antimony.

# POLLUTION CONTROL BOARD

- A) Preservative: Concentrated nitric acid to pH less than 2.
- B) Plastic or glass (hard or soft).
- C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within six months.
- 2) Arsenic.
  - A) Preservative: Concentrated nitric acid to pH less than 2.
  - B) Plastic or glass (hard or soft).
  - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within six months.
- 3) Asbestos.
  - A) Preservative: Cool to 4° C.
  - B) Plastic or glass (hard or soft).
  - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within 48 hours.
- 4) Barium.
  - A) Preservative: Concentrated nitric acid to pH less than 2.
  - B) Plastic or glass (hard or soft).
  - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within six months.
- 5) Beryllium.
  - A) Preservative: Concentrated nitric acid to pH less than 2.

# POLLUTION CONTROL BOARD

- B) Plastic or glass (hard or soft).
- C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within six months.
- 6) Cadmium.
  - A) Preservative: Concentrated nitric acid to pH less than 2.
  - B) Plastic or glass (hard or soft).
  - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within six months.
- 7) Chromium.
  - A) Preservative: Concentrated nitric acid to pH less than 2.
  - B) Plastic or glass (hard or soft).
  - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within six months.
- 8) Cyanide.
  - A) Preservative: Cool to 4° C. Add sodium hydroxide to pH greater than 12. See the analytical methods for information on sample preservation.
  - B) Plastic or glass (hard or soft).
  - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within 14 days.
- 9) Fluoride.
  - A) Preservative: None.
  - B) Plastic or glass (hard or soft).

# POLLUTION CONTROL BOARD

- C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within one month.
- 10) Mercury.
  - A) Preservative: Concentrated nitric acid to pH less than 2.
  - B) Plastic or glass (hard or soft).
  - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within 28 days.
- 11) Nickel.
  - A) Preservative: Concentrated nitric acid to pH less than 2.
  - B) Plastic or glass (hard or soft).
  - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within six months.
- 12) Nitrate, chlorinated.
  - A) Preservative: Cool to 4° C.
  - B) Plastic or glass (hard or soft).
  - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within 14 days.
- 13) Nitrate, non-chlorinated.
  - A) Preservative: Concentrated sulfuric acid to pH less than 2.
  - B) Plastic or glass (hard or soft).
  - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within 14 days.

# POLLUTION CONTROL BOARD

- 14) Nitrite.
  - A) Preservative: Cool to 4° C.
  - B) Plastic or glass (hard or soft).
  - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within 48 hours.
- 15) Selenium.
  - A) Preservative: Concentrated nitric acid to pH less than 2.
  - B) Plastic or glass (hard or soft).
  - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within six months.
- 16) Thallium.
  - A) Preservative: Concentrated nitric acid to pH less than 2.
  - B) Plastic or glass (hard or soft).
  - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within six months.
- c) Analyses under this Subpart N must be conducted by laboratories that received approval from USEPA or the Agency. The Agency must certify laboratories to conduct analyses for antimony, arsenic (offective January 23, 2006), asbestos, barium, beryllium, cadmium, chromium, cyanide, fluoride, mercury, nickel, nitrate, nitrite, selenium, and thallium if the laboratory does as follows:
  - 1) It analyzes performance evaluation (PE) samples, provided by the Agency pursuant to 35 Ill. Adm. Code 186, that include those substances at levels not in excess of levels expected in drinking water; and

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

- 2) It achieves quantitative results on the analyses within the following acceptance limits:
  - A) Antimony:  $\pm 30\%$  at greater than or equal to 0.006 mg/ $\ell$ .
  - B) Arsenic:  $\pm 30\%$  at greater than or equal to 0.003 mg/ $\ell$ .
  - C) Asbestos: 2 standard deviations based on study statistics.
  - D) Barium:  $\pm 15\%$  at greater than or equal to 0.15 mg/ $\ell$ .
  - E) Beryllium:  $\pm 15\%$  at greater than or equal to 0.001 mg/ $\ell$ .
  - F) Cadmium:  $\pm 20\%$  at greater than or equal to 0.002 mg/ $\ell$ .
  - G) Chromium:  $\pm 15\%$  at greater than or equal to 0.01 mg/ $\ell$ .
  - H) Cyanide:  $\pm 25\%$  at greater than or equal to 0.1 mg/ $\ell$ .
  - I) Fluoride:  $\pm 10\%$  at 1 to 10 mg/ $\ell$ .
  - J) Mercury:  $\pm 30\%$  at greater than or equal to 0.0005 mg/ $\ell$ .
  - K) Nickel:  $\pm 15\%$  at greater than or equal to 0.01 mg/ $\ell$ .
  - L) Nitrate:  $\pm 10\%$  at greater than or equal to 0.4 mg/ $\ell$ .
  - M) Nitrite:  $\pm 15\%$  at greater than or equal to 0.4 mg/ $\ell$ .
  - N) Selenium:  $\pm 20\%$  at greater than or equal to 0.01 mg/ $\ell$ .
  - O) Thallium:  $\pm$  30% at greater than or equal to 0.002 mg/ $\ell$ .

BOARD NOTE: Derived from 40 CFR 141.23(k) and appendix A to 40 CFR 141 (2011) (2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

## Section 611.612 Monitoring Requirements for Old Inorganic MCLs

# POLLUTION CONTROL BOARD

- a) Analyses for the purpose of determining compliance with the old inorganic MCLs of Section 611.300 are required as follows:
  - 1) Analyses for all CWSs utilizing surface water sources must be repeated at yearly intervals.
  - 2) Analyses for all CWSs utilizing only groundwater sources must be repeated at three-year intervals.
  - 3) This subsection (a)(3) corresponds with 40 CFR 141.23(1)(3), which requires monitoring for the repealed old MCL for nitrate at a frequency specified by the state. The Board has followed the USEPA lead and repealed that old MCL. This statement maintains structural consistency with USEPA rules.
  - 4) This subsection (a)(4) corresponds with 40 CFR 141.23(1)(4), which authorizes the state to determine compliance and initiate enforcement action. This statement maintains structural consistency with USEPA rules.
- b) If the result of an analysis made under subsection (a) of this Section indicates that the level of any contaminant listed in Section 611.300 exceeds the old MCL, the supplier must report to the Agency within seven days and initiate three additional analyses at the same sampling point within one month.
- c) When the average of four analyses made pursuant to subsection (b) of this Section, rounded to the same number of significant figures as the old MCL for the substance in question, exceeds the old MCL, the supplier must notify the Agency and give notice to the public pursuant to Subpart V of this Part. Monitoring after public notification must be at a frequency designated by the Agency by a SEP granted pursuant to Section 611.110 and must continue until the old MCL has not been exceeded in two successive samples or until a different monitoring schedule becomes effective as a condition to a variance, an adjusted standard, a site specific rule, an enforcement action, or another SEP granted pursuant to Section 611.110.
- d) This subsection (d) corresponds with 40 CFR 141.23(o), which pertains to monitoring for the repealed old MCL for nitrate. This statement maintains structural consistency with USEPA rules.
- e) This subsection (e) corresponds with 40 CFR 141.23(p), which pertains to the use

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

of existing data up until a date long since expired. This statement maintains structural consistency with USEPA rules.

- f) Except for arsenic, for which analyses must be made in accordance with Section 611.611, analyses Analyses conducted to determine compliance with the old MCLs of Section 611.300 must be made in accordance with the following methods, incorporated by reference in Section 611.102, or alternative methods approved by the Agency pursuant to Section 611.480.
  - 1) Fluoride: The methods specified in Section 611.611(c) must apply for the purposes of this Section.
  - 2) Iron.
    - A) Standard Methods.
      - i) Method 3111 B, 18<sup>th,</sup> 19<sup>th</sup>, or 21<sup>st</sup> ed.;
      - ii) Method 3113 B, 18<sup>th,</sup> 19<sup>th</sup>, or 21<sup>st</sup> ed.; or
      - iii) Method 3120 B, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed.
    - B) Standard Methods Online, Method 3113 B-04.
    - C) USEPA Environmental Metals Methods.
      - i) Method 200.7 (rev. 4.4); or
      - ii) Method 200.9 (rev. 2.2).
    - D) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): USEPA NERL Method 200.5.

BOARD NOTE: USEPA added this method as an approved alternative method in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added Standard Methods Online, Method 3113 B-04 as an approved alternative method for iron in appendix A to subpart C of 40 CFR 141 on June 24, 2011 (at 76 Fed. Reg. 37014).

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed.; Methods 3111 B, 3113 B, and 3120 B and USEPA NERL Method 200.5 as approved alternative methods for iron in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

- 3) Manganese.
  - A) Standard Methods.
    - i) Method 3111 B, 18<sup>th</sup>, 19<sup>th</sup>, or 21<sup>st</sup> ed.;
    - ii) Method 3113 B, 18<sup>th</sup>, 19<sup>th</sup>, or 21<sup>st</sup> ed.; or
    - iii) Method 3120 B, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed.
  - B) Standard Methods Online, Method 3113 B-04.
  - C) USEPA Environmental Metals Methods.
    - i) Method 200.7 (rev. 4.4);
    - ii) Method 200.8 (rev. 5.3); or
    - iii) Method 200.9 (rev. 2.2).
  - D) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): USEPA NERL Method 200.5.

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed.; Methods 3111 B, 3113 B, and 3120 B and USEPA NERL Method 200.5 as approved alternative methods for manganese in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added Standard Methods Online, Method 3113 B-04 as an approved alternative method for manganese in appendix A to subpart C of 40 CFR 141 on June 24, 2011 (at 76 Fed. Reg. 37014).

- 4) Zinc.
  - A) Standard Methods.

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

- i) Method 3111 B, 18<sup>th</sup>, 19<sup>th</sup>, or 21<sup>st</sup> ed.; or
- ii) Method 3120 B, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed.
- B) USEPA Environmental Metals Methods.
  - i) Method 200.7 (rev. 4.4); or
  - ii) Method 200.8 (rev. 5.3).
- C) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): USEPA NERL Method 200.5.

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed.; Methods 3111 B and 3120 B and USEPA NERL Method 200.5 as approved alternative methods for zinc in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

BOARD NOTE: The provisions of subsections (a) through (e) of this Section derive from 40 CFR 141.23(l) through (p) (2011) (2012). Subsections (f)(2) through (f)(4) of this Section relate exclusively to additional State requirements. The Board retained subsection (f) of this Section to set forth methods for the inorganic contaminants for which there is a State-only MCL. The methods specified are those set forth in 40 CFR 143.4(b) and appendix A to subpart C of 40 CFR 141 (2011) (2012), for secondary MCLs.

	(Source:	Amended at 37	Ill. Reg. —	, effective	)	l
--	----------	---------------	-------------	-------------	---	---

SUBPART O: ORGANIC MONITORING AND ANALYTICAL REQUIREMENTS

## Section 611.641 Old MCLs

- a) An analysis of substances for the purpose of determining compliance with the old MCLs of Section 611.310 must be made as follows:
  - 1) The Agency-shall must, by SEP, require CWS suppliers utilizing surface water sources to collect samples during the period of the year when contamination by pesticides is most likely to occur. The Agency must

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

require the supplier to repeat these analyses at least annually.

- 2) The Agency shall must, by SEP, require CWS suppliers utilizing only groundwater sources to collect samples at least once every three years.
- b) If the result of an analysis made pursuant to subsection (a) indicates that the level of any contaminant exceeds its old MCL, the CWS supplier must report to the Agency within seven days and initiate three additional analyses within one month.
- c) When the average of four analyses made pursuant to subsection (a), rounded to the same number of significant figures as the MCL for the substance in question, exceeds the old MCL, the CWS supplier must report to the Agency and give notice to the public pursuant to Subpart T of this Part. Monitoring after public notification must be at a frequency designated by the Agency and must continue until the MCL has not been exceeded in two successive samples or until a monitoring schedule as a condition to a variance, adjusted standard, or enforcement action becomes effective.
- d) Analysis made to determine compliance with the old MCLs of Section 611.310 must be made in accordance with the appropriate methods specified in Section 611.645.

BOARD NOTE: This provision now applies only to State-only MCLs. It was formerly derived from 40 CFR 141.24(a) through (e), which USEPA removed and reserved.

(Source: Amended at 37 III. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

## Section 611.645 Analytical Methods for Organic Chemical Contaminants

Analysis for the Section 611.311(a) VOCs under Section 611.646; the Section 611.311(c) SOCs under Section 611.648; the Section 611.310 old MCLs under Section 611.641; and for THMs, TTHMs, and TTHM potential must be conducted using the methods listed in this Section. All methods are incorporated by reference in Section 611.102. Other required analytical test procedures germane to the conduct of these analyses are contained in the USEPA document, "Technical Notes of Drinking Water Methods," incorporated by reference in Section 611.102.

a) Volatile Organic Chemical Contaminants (VOCs).

# POLLUTION CONTROL BOARD

Contaminant	Analytical Methods
Benzene	USEPA Organic Methods, Methods 502.2 (rev. 2.1) and 524.2 (rev. 4.1); USEPA OGWDW Methods, Method 524.3 (rev. 1.0)
Carbon tetrachloride	USEPA Organic Methods, Methods 502.2 (rev. 2.1) and 524.2 (rev. 4.1); USEPA OGWDW Methods, Method 524.3 (rev. 1.0) and 551.1
Chlorobenzene	(rev. 1.0) USEPA Organic Methods, Methods 502.2 (rev. 2.1) and 524.2 (rev. 4.1); USEPA OGWDW Methods,
1,2-Dichlorobenzene	Method 524.3 (rev. 1.0) USEPA Organic Methods, Methods 502.2 (rev. 2.1) and 524.2 (rev. 4.1); USEPA OGWDW Methods,
1,4-Dichlorobenzene	Method 524.3 (rev. 1.0) USEPA Organic Methods, Methods 502.2 (rev. 2.1) and 524.2 (rev. 4.1); USEPA OGWDW Methods,
1,2-Dichloroethane	Method 524.3 (rev. 1.0) USEPA Organic Methods, Methods 502.2 (rev. 2.1) and 524.2 (rev. 4.1); USEPA OGWDW Methods,
cis-Dichloroethylene	Method 524.3 (rev. 1.0) USEPA Organic Methods, Methods 502.2 (rev. 2.1) and 524.2 (rev. 4.1); USEPA OGWDW Methods,
trans-Dichloroethylene	Method 524.3 (rev. 1.0) USEPA Organic Methods, Methods 502.2 (rev. 2.1) and 524.2 (rev. 4.1); USEPA OGWDW Methods, Method 524.3 (rev. 1.0)
Dichloromethane	USEPA Organic Methods, Methods 502.2 (rev. 2.1) and 524.2 (rev. 4.1); USEPA OGWDW Methods, Method 524.3 (rev. 1.0)

,

# POLLUTION CONTROL BOARD

1,2-Dichloropropane Ethylbenzene	USEPA Organic Methods, Methods 502.2 (rev. 2.1) and 524.2 (rev. 4.1); USEPA OGWDW Methods, Method 524.3 (rev. 1.0) USEPA Organic Methods, Methods
	502.2 (rev. 2.1) and 524.2 (rev. 4.1); USEPA OGWDW Methods, Method 524.3 (rev. 1.0)
Styrene	USEPA Organic Methods, Methods 502.2 (rev. 2.1) and 524.2 (rev. 4.1); USEPA OGWDW Methods, Method 524.3 (rev. 1.0)
Tetrachloroethylene	USEPA Organic Methods, Methods 502.2 (rev. 2.1) and 524.2 (rev. 4.1); USEPA OGWDW Methods, Method 524.3 (rev. 1.0) and 551.1 (rev. 1.0)
1,1,1-Trichloroethane	USEPA Organic Methods, Methods 502.2 (rev. 2.1) and 524.2 (rev. 4.1); USEPA OGWDW Methods, Method 524.3 (rev. 1.0) and 551.1 (rev. 1.0)
Trichloroethylene	USEPA Organic Methods, Methods 502.2 (rev. 2.1) and 524.2 (rev. 4.1); USEPA OGWDW Methods, Method 524.3 (rev. 1.0) and 551.1 (rev. 1.0)
Toluene	USEPA Organic Methods, Methods 502.2 (rev. 2.1) and 524.2 (rev. 4.1); USEPA OGWDW Methods, Method 524.3 (rev. 1.0)
1,2,4-Trichlorobenzene	USEPA Organic Methods, Methods 502.2 (rev. 2.1) and 524.2 (rev. 4.1); USEPA OGWDW Methods, Method 524.3 (rev. 1.0)
1,1-Dichloroethylene	USEPA Organic Methods, Methods 502.2 (rev. 2.1) and 524.2 (rev. 4.1); USEPA OGWDW Methods, Method 524.3 (rev. 1.0)

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

1,1,2-Trichloroethane	USEPA Organic Methods, Methods 502.2 (rev. 2.1) and 524.2 (rev. 4.1); USEPA OGWDW Methods, Method 524.3 (rev. 1.0)
Vinyl chloride	USEPA Organic Methods, Methods 502.2 (rev. 2.1) and 524.2 (rev. 4.1); USEPA OGWDW Methods, Method 524.3 (rev. 1.0)
Xylenes (total)	USEPA Organic Methods, Methods 502.2 (rev. 2.1) and 524.2 (rev. 4.1); USEPA OGWDW Methods, Method 524.3 (rev. 1.0)

BOARD NOTE: USEPA added USEPA OGWDW Method 524.3 (rev. 1.0) as an alternative method for all of the VOCs in appendix A to subpart C of 40 CFR 141 on August 3, 2009 (at 74 Fed. Reg. 38348).

b) Synthetic Organic Chemical Contaminants (SOCs).

Contaminant	Analytical Methods
2,3,7,8-Tetrachlorodibenzodioxin (2,3,7,8 - TCDD or dioxin) 2,4-D	Dioxin and Furan Method 1613 (rev. B) USEPA Organic Methods, Methods 515.2 (rev. 1.1), 555 (rev. 1.0), and 515.1 (rev. 4.0); USEPA Organic and Inorganic Methods, Method 515.3 (rev. 1.0); USEPA OGWDW Methods, Method 515.4 (rev. 1.0); ASTM Method D5317-93 or D5317-98; Standard Methods, 21 <sup>st</sup> ed., Method
2,4,5-TP (Silvex)	6640 B USEPA Organic Methods, Methods 515.2 (rev. 1.1), 555 (rev. 1.0), and 515.1 (rev. 4.0); USEPA Organic and Inorganic Methods, Method 515.3 (rev. 1.0); USEPA OGWDW Methods,

# POLLUTION CONTROL BOARD

	Method 515.4 (rev. 1.0); ASTM Method D5317-93 or D5317-98; Standard Methods, 21 <sup>st</sup> ed., Method 6640 B
Alachlor	USEPA Organic Methods, Methods 505 (rev. 2.1) <sup>1</sup> , 507 (rev. 2.1), 508.1 (rev. 2.0), 525.2 (rev. 2.0), 525.3 (ver. 1.0), and 551.1 (rev. 1.0)
Atrazine	USEPA Organic Methods, Methods 505 (rev. 2.1) <sup>3</sup> , 507 (rev. 2.1), 508.1 (rev. 2.1), 523 (ver. 1.0), 525.2 (rev. 2.0), 525.3 (ver. 1.0), 536 (ver. 1.0), and 551.1 (rev. 1.0); Syngenta AG-625 <sup>2</sup>
Benzo(a)pyrene	USEPA Organic Methods, Methods 525.2 (rev. 2.0), 525.3 (ver. 1.0), 550, and 550.1
Carbofuran	USEPA Organic Methods, Methods 531.1 (rev. 3.1); USEPA OGWDW Methods, Method 531.2 (rev. 1.0); Standard Methods, 18 <sup>th</sup> ed. Supplement, 19 <sup>th</sup> ed., or 20 <sup>th</sup> ed., Method 6610; Standard Methods, 21 <sup>st</sup> ed., Method 6610 B; Standard Methods Online, Method 6610 B-04
Chlordane	USEPA Organic Methods, Methods 505 (rev. 2.1), 508 (rev. 3.1), 508.1 (rev. 2.1), and 525.2 (rev. 2.0), and 525.3 (ver. 1.0)
Dalapon	USEPA Organic Methods, Methods 515.1 (rev. 4.0), 552.1 (rev. 1.0), and 552.2 (rev. 1.0); USEPA Organic and Inorganic Methods, Method 515.3 (rev. 1.0); USEPA OGWDW Methods,

# POLLUTION CONTROL BOARD

	Methods 515.4 (rev. 1.0), 552.3 (rev. 1.0), and 557 Standard Methods, 21 <sup>st</sup> ed., Method
Di(2-ethylhexyl)adipate	6640 B USEPA Organic Methods, Methods 506 (rev. 1.1) and, 525.2 (rev. 2.0),
Di(2-ethylhexyl)phthalate	and 525.3 (ver. 1.0) USEPA Organic Methods, Methods 506 (rev. 1.1) and, 525.2 (rev. 2.0),
Dibromochloropropane (DBCP)	and 525.3 (ver. 1.0) USEPA Organic Methods, Methods 504.1 (rev. 1.1), USEPA OGWDW Methods, Methods 524.3 (rev. 1.0)
Dinoseb	and 551.1 (rev. 1.0) USEPA Organic Methods, Methods 515.1 (rev. 4.0) and 515.2 (rev. 1.1); USEPA Organic and Inorganic Methods, Method 515.3 (rev. 1.0);
	USEPA OGWDW Methods, Methods 515.4 (rev. 1.0) and 555 (rev. 1.0);
	Standard Methods, 21 <sup>st</sup> ed., Method 6640 B
Diquat	USEPA NERL Method 549.2 (rev. 1.0)
Endothall	USEPA Organic Methods, Method
Endrin	548.1 (rev. 1.0) USEPA Organic Methods, Methods 505 (rev. 2.1), 508 (rev. 3.1), 508.1
Ethylene dibromide (EDB)	(rev. 2.0), 525.2 (rev. 2.0), 525.3 (ver. 1.0), and 551.1 (rev. 1.0) USEPA Organic Methods, Method 504.1 (rev. 1.1);
Glyphosate	USEPA OGWDW Methods, Methods 524.3 (rev. 1.0) and 551.1 (rev. 1.0) USEPA Organic Methods, Method 547; Standard Methods, 18 <sup>th</sup> ed., 19 <sup>th</sup> ed.,

.

#### POLLUTION CONTROL BOARD

Heptachlor	20 <sup>th</sup> , or 21 <sup>st</sup> ed., Method 6651 B USEPA Organic Methods, Methods 505 (rev. 2.1), 508 (rev. 3.1), 508.1 (rev. 2.0), 525.2 (rev. 2.0), 525.3
Heptachlor Epoxide	(ver. 1.0), and 551.1 (rev. 1.0) USEPA Organic Methods, Methods 505 (rev. 2.1), 508 (rev. 3.1), 508.1 (rev. 2.0), 525.2 (rev. 2.0), 525.3
Hexachlorobenzene	(ver. 1.0), and 551.1 (rev. 1.0) USEPA Organic Methods, Methods 505 (rev. 2.1), 508 (rev. 3.1), 508.1 (rev. 2.0), 525.2 (rev. 2.0), 525.3
Hexachlorocyclopentadiene	(ver. 1.0), and 551.1 (rev. 1.0) USEPA Organic Methods, Methods 505 (rev. 2.1), 508 (rev. 3.1), 508.1 (rev. 2.0), 525.2 (rev. 2.0), 525.3
Lindane	(ver. 1.0), and 551.1 (rev. 1.0) USEPA Organic Methods, Methods 505 (rev. 2.1), 508 (rev. 3.1), 508.1 (rev. 2.0), 525.2 (rev. 2.0), 525.3
Methoxychlor	(ver. 1.0), and 551.1 (rev. 1.0) USEPA Organic Methods, Methods 505 (rev. 2.1), 508 (rev. 3.1), 508.1 (rev. 2.0), 525.2 (rev. 2.0), 525.3
Oxamyl	<ul> <li>(ver. 1.0), and 551.1 (rev. 1.0)</li> <li>USEPA Organic Methods, Method</li> <li>531.1 (rev. 3.1);</li> <li>USEPA OGWDW Methods,</li> <li>Method 531.2 (rev. 1.0);</li> <li>Standard Methods, 18<sup>th</sup> ed.</li> <li>Supplement, 19<sup>th</sup> ed. or 20<sup>th</sup> ed.<sub>7</sub></li> <li>Method 6610;</li> <li>Standard Methods, 21<sup>st</sup> ed., Method</li> <li>6610 B;</li> <li>Standard Methods Online, Method</li> <li>6610 P. 04</li> </ul>
PCBs (measured for compliance purposes as decachlorobiphenyl) PCBs (qualitatively identified as	6610 B-04 USEPA Organic Methods, Method 508A (rev. 1.0) USEPA Organic Methods, Methods

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

Aroclors)	505 (rev. 2.1), 508 (rev. 3.1), 508.1 (rev. 2.0), and 525.2 (rev. 2.0), and 525.3 (ver. 1.0)
Pentachlorophenol	USEPA Organic Methods, Methods 515.1 (rev. 4.0), 515.2 (rev. 1.1), 525.2 (rev. 2.0), 525.3 (ver. 1.0), and 555 (rev. 1.0); USEPA Organic and Inorganic Methods, Method 515.3 (rev. 1.0); USEPA OGWDW Methods, Method 515.4 (rev. 1.0); ASTM Method D5317-93 or D5317-98 (2003); Standard Methods, 21 <sup>st</sup> ed., Method 6640 B
Picloram	USEPA Organic Methods, Methods 515.1 (rev. 4.0), 515.2 (rev. 1.1), and 555 (rev. 1.0); USEPA Organic and Inorganic Methods, Method 515.3 (rev. 1.0); USEPA OGWDW Methods, Method 515.4 (rev. 1.0); ASTM Method D5317-93 or D5317-98 (2003); Standard Methods, 21 <sup>st</sup> ed., Method 6640 B
Simazine	USEPA Organic Methods, Methods 505 (rev. 2.1) <sup>1</sup> , 507 (rev. 2.1), 508.1 (rev. 2.0), 523 (ver. 1.0), 525.2 (rev. 2.0), 525.3 (ver. 1.0), 536 (ver. 1.0), and 551.1 (rev. 1.0)
Toxaphene	USEPA Organic Methods, Methods 505 (rev. 2.1), 508 (rev. 2.1), 508.1 (rev. 2.0), and 525.2 (rev. 2.0), and 525.3 (ver. 1.0)

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed., Method 6610 B and Standard Methods Online, Method 6610 B-04 as approved alternative methods for carbofuran and oxamyl on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added USEPA

## POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

OGWDW Method 524.3 (rev. 1.0) as an alternative method for dibromochloropropane and ethylene dibromide in appendix A to subpart C of 40 CFR 141 on August 3, 2009 (at 74 Fed. Reg. 38348). USEPA approved Standard Methods, 21st ed., Method 6640 B and Standard Methods Online, Method 6640 B-01 and USEPA OGWDW Methods, Method 557 as approved alternative methods for dalapon in appendix A to subpart C of 40 CFR 141 on June 8, 2010 (at 75 Fed. Reg. 32295). USEPA added Standard Methods, 21st ed., Method 6640 B as an approved alternative method for 2,4-D, 2,4,5-TP (Silvex), dinoseb, pentachlorophenol, and picloram in appendix A to subpart C of 40 CFR 141 on June 24, 2011 (at 76 Fed. Reg. 37014). USEPA added Standard Methods, Online, Method 6640 B-01 as an approved alternative method for 2,4-D, 2,4,5-TP (Silvex), dalapon, dinoseb, pentachlorophenol, and picloram and in appendix A to subpart C of 40 CFR 141 on June 24, 2011 (at 76 Fed. Reg. 37014). Since the version of Method 6640 B that appears in Standard Methods Online is the same as that which appears in Standard Methods, 21st ed., the Board has cited only to Standard Methods, 21st ed. USEPA added Standard Methods, 21<sup>st</sup> ed., Method 6651 B as an approved alternative method for glyphosate in appendix A to subpart C of 40 CFR 141 on June 24, 2011 (at 76 Fed. Reg. 37014). USEPA added Standard Methods Online, Method 6651 B-00 as an approved alternative method for glyphosate in appendix A to subpart C of 40 CFR 141 on June 24, 2011 (at 76 Fed. Reg. 37014). Since the version of Method 6651 B that appears in Standard Methods Online is the same as that which appears in Standard Methods, 21<sup>st</sup> ed., the Board has cited only to Standard Methods, 21<sup>st</sup> ed. USEPA approved USEPA OGWDW Methods, Method 523 (ver. 1.0) and Method 536 (ver. 1.0) as approved alternative methods for atrazine and simazine and USEPA NERL Methods. Method 525.3 as an approved alternative method for alachlor, atrazine, benzo(a)pyrene, chlordane, di(2-ethylhexyl)adipate, di(2-ethylhexyl)phthalate, endrin, heptachlor, heptachlor epoxide, hexachlorobenzene, hexachlorocyclopentadiene, lindane, methoxychlor, PCBs (as aroclors), pentachlorophenol, simazine, and toxaphene in appendix A to subpart C of 40 CFR 141 on June 8, 2012 (at 77 Fed. Reg. 38523).

# c) Total Trihalomethanes (TTHMs).

Contaminant	Analytical Methods
Total Trihalomethanes (TTHMs), Trihalomethanes	USEPA Organic Methods,
(THMs), and Maximum Total Trihalomethane	Methods 502.2 (rev. 2.1)
Potential	and 524.2 (rev. 4.1);
	USEPA OGWDW
	Methods, Method 524.3
	(rev. 1.0) and 551.1 (rev.

# POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

1.0)

BOARD NOTE: USEPA added USEPA OGWDW Method 524.3 (rev. 1.0) as an alternative method for total trihalomethane in appendix A to subpart C of 40 CFR 141 on August 3, 2009 (at 74 Fed. Reg. 38348).

d) State-Only MCLs (for which a method is not listed in subsections (a) through (c) of this Section ).

Contaminant	Analytical Methods
Aldrin	USEPA Organic Methods, Methods 505 (rev. 2.1), 508 (rev. 3.1), 508.1
	(rev. 2.0), and 525.2 (rev. 2.0)
DDT	USEPA Organic Methods, Methods
	505 (rev. 2.1) and 508 (rev. 3.1)
Dieldrin	USEPA Organic Methods, Methods
	505 (rev. 2.1), 508 (rev. 3.1), 508.1
	(rev. 2.0), and 525.2 (rev. 2.0)

- e) The following footnotes are appended to method entries in subsections (a) and (b) of this Section:
  - <sup>1</sup> denotes that, for the particular contaminant, a nitrogen-phosphorus detector should be substituted for the electron capture detector in method 505 (or another approved method should be used) to determine alachlor, atrazine, and simazine if lower detection limits are required.
  - <sup>2</sup> denotes that Syngenta Method AG-625 may not be used for the analysis of atrazine in any system where chlorine dioxide is used for drinking water treatment. In samples from all other systems, any result for atrazine generated by Syngenta Method AG-625 that is greater than one-half the maximum contaminant level (MCL) (in other words, greater than 0.0015mg/ℓ or 1.5 µg/ℓ) must be confirmed using another approved method for this contaminant and should use additional volume of the original sample collected for compliance monitoring. In instances where a result from Syngenta Method AG \_625 triggers such confirmatory testing, the confirmatory result is to be used to determine compliance.

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

BOARD NOTE: Derived from 40 CFR 141.24(e) and appendix A to subpart C of 40 CFR 141-(2011) (2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

# Section 611.646 Phase I, Phase II, and Phase V Volatile Organic Contaminants

Monitoring of the Phase I, Phase II, and Phase V VOCs for the purpose of determining compliance with the MCL must be conducted as follows:

a) Definitions. As used in this Section the following have the given meanings:

"Detect" and "detection" mean that the contaminant of interest is present at a level greater than or equal to the "detection limit."

"Detection limit" means 0.0005 mg/l.

BOARD NOTE: Derived from 40 CFR 141.24(f)(7), (f)(11), (f)(14)(i), and (f)(20) (2005) (2012). This is a ""trigger level?" for Phase I, Phase II, and Phase V VOCs inasmuch as it prompts further action. The use of the term ""detect?" in this Section is not intended to include any analytical capability of quantifying lower levels of any contaminant, or the ""method detection limit." "Note, however, that certain language at the end of federal paragraph (f)(20) is capable of meaning that the ""method detection limit?" is used to derive the ""detection limit." The Board has chosen to disregard that language at the end of paragraph (f)(20) in favor of the more direct language of paragraphs (f)(7) and (f)(11).

"\_\_\_Method detection limit," as used in subsections (q) and (t) of this Section means the minimum concentration of a substance that can be measured and reported with 99 percent confidence that the analyte concentration is greater than zero and is determined from analysis of a sample in a given matrix containing the analyte.

BOARD NOTE: Derived from appendix B to 40 CFR 136 (2005) (2012). The method detection limit is determined by the procedure set forth in appendix B to 40 CFR 136, incorporated by reference in Section 611.102(c). See subsection (t) of this Section.

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

- b) Required sampling. Each supplier must take a minimum of one sample at each sampling point at the times required in subsection (u) of this Section.
- c) Sampling points.
  - 1) Sampling points for a GWS. Unless otherwise provided by a SEP granted by the Agency pursuant to Section 611.110, a GWS supplier must take at least one sample from each of the following points: each entry point that is representative of each well after treatment.
  - 2) Sampling points for an SWS or mixed system supplier. Unless otherwise provided by a SEP granted by the Agency pursuant to Section 611.110, an SWS or mixed system supplier must sample from each of the following points:
    - A) Each entry point after treatment; or
    - B) Points in the distribution system that are representative of each source.
  - 3) The supplier must take each sample at the same sampling point unless the Agency has granted a SEP pursuant to Section 611.110 that designates another location as more representative of each source, treatment plant, or within the distribution system.
  - 4) If a system draws water from more than one source, and the sources are combined before distribution, the supplier must sample at an entry point during periods of normal operating conditions when water is representative of all sources being used.

BOARD NOTE: Subsections (b) and (c) of this Section derived from 40 CFR 141.24(f)(1) through (f)(3) ( $\frac{2005}{4}$ 2012).

- d) Each CWS and NTNCWS supplier must take four consecutive quarterly samples for each of the Phase I VOCs, excluding vinyl chloride, and Phase II VOCs during each compliance period, beginning in the compliance period starting in the initial compliance period.
- e) Reduction to annual monitoring frequency. If the initial monitoring for the Phase

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

I, Phase II, and Phase V VOCs, as allowed in subsection (r)(1) of this Section, was completed by December 31, 1992, and the supplier did not detect any of the Phase I VOCs, including vinyl chloride; Phase II VOCs; or Phase V VOCs, then the supplier must take one sample annually beginning in the initial compliance period.

- f) GWS reduction to triennial monitoring frequency. After a minimum of three years of annual sampling, GWS suppliers that have not previously detected any of the Phase I VOCs, including vinyl chloride; Phase II VOCs; or Phase V VOCs must take one sample during each three-year compliance period.
- g) A CWS or NTNCWS supplier that has completed the initial round of monitoring required by subsection (d) of this Section and which did not detect any of the Phase I VOCs, including vinyl chloride; Phase II VOCs; and Phase V VOCs may apply to the Agency for a SEP pursuant to Section 611.110 that releases it from the requirements of subsection (e) or (f) of this Section. A supplier that serves fewer than 3300 service connections may apply to the Agency for a SEP that releases it from the requirements of subsection (d) of this Section as to 1,2,4-trichlorobenzene.

BOARD NOTE: Derived from 40 CFR 141.24(f)(7) and (f)(10) (2005) (2012), and the discussion at 57 Fed. Reg. 31825 (July 17, 1992). Provisions concerning the term of the waiver appear in subsections (i) and (j) of this Section. The definition of "detect," parenthetically added to the federal counterpart paragraph, is in subsection (a) of this Section.

- h) Vulnerability assessment. The Agency must consider the factors of Section 611.110(e) in granting a SEP from the requirements of subsection (d), (e), or (f) of this Section sought pursuant to subsection (g) of this Section.
- A SEP issued to a GWS pursuant to subsection (g) of this Section is for a maximum of six years, except that a SEP as to the subsection (d) of this Section monitoring for 1,2,4-trichlorobenzene must apply only to the initial round of monitoring. As a condition of a SEP, except as to a SEP from the initial round of subsection (d) of this Section monitoring for 1,2,4-trichlorobenzene, the supplier shall, within 30 months after the beginning of the period for which the waiver was issued, reconfirm its vulnerability assessment required by subsection (h) of this Section and submitted pursuant to subsection (g) of this Section, by taking one sample at each sampling point and reapplying for a SEP pursuant to subsection (g) of this Section. Based on this application, the Agency must do

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

either of the following:

- 1) If it determines that the PWS meets the standard of Section 611.610(e), issue a SEP that reconfirms the prior SEP for the remaining three-year compliance period of the six-year maximum term; or
- 2) Issue a new SEP requiring the supplier to sample annually.

BOARD NOTE: Subsection (i) of this Section does not apply to an SWS or mixed system supplier.

- j) Special considerations for a SEP for an SWS or mixed-system supplier.
  - The Agency must determine that an SWS is not vulnerable before issuing a SEP pursuant to Section 611.110 to an SWS supplier. A SEP issued to an SWS or mixed system supplier pursuant to subsection (g) of this Section is for a maximum of one compliance period; and
  - 2) The Agency may require, as a condition to a SEP issued to an SWS or mixed supplier, that the supplier take such samples for Phase I, Phase II, and Phase V VOCs at such a frequency as the Agency determines are necessary, based on the vulnerability assessment.

BOARD NOTE: There is a great degree of similarity between 40 CFR 141.24(f)(7) (2005) (2012), the provision applicable to GWSs, and 40 CFR 141.24(f)(10) (2005) (2012), the provision for SWSs. The Board has consolidated the common requirements of both paragraphs into subsection (g) of this Section. Subsection (j) of this Section represents the elements unique to an SWSs or mixed system, and subsection (i) of this Section relates to a GWS supplier. Although 40 CFR 141.24(f)(7) and (f)(10) are silent as to a mixed system supplier, the Board has included a mixed system supplier with an SWS supplier because this best follows the federal scheme for all other contaminants.

- k) If one of the Phase I VOCs, excluding vinyl chloride; a Phase II VOC; or a Phase
   V VOC is detected in any sample, then the following must occur:
  - 1) The supplier must monitor quarterly for that contaminant at each sampling point that resulted in a detection.

# POLLUTION CONTROL BOARD

- 2) Annual monitoring.
  - A) The Agency must grant a SEP pursuant to Section 611.110 that allows a supplier to reduce the monitoring frequency to annual at a sampling point if it determines that the sampling point is reliably and consistently below the MCL.
  - B) A request for a SEP must include the following minimal information:
    - i) For a GWS, two quarterly samples.
    - ii) For an SWS or mixed system supplier, four quarterly samples.
  - C) In issuing a SEP, the Agency must specify the level of the contaminant upon which the "reliably and consistently<sup>2</sup>" determination was based. Any SEP that allows less frequent monitoring based on an Agency "reliably and consistently<sup>2</sup>" determination must include a condition requiring the supplier to resume quarterly monitoring pursuant to subsection (k)(1) of this Section if it violates the MCL specified by Section 611.311.
- 3) Suppliers that monitor annually must monitor during the quarters that previously yielded the highest analytical result.
- 4) Suppliers that do not detect a contaminant at a sampling point in three consecutive annual samples may apply to the Agency for a SEP pursuant to Section 611.110 that allows it to discontinue monitoring for that contaminant at that point, as specified in subsection (g) of this Section.
- 5) A GWS supplier that has detected one or more of the two-carbon contaminants listed in subsection (k)(5)(A) of this Section must monitor quarterly for vinyl chloride as described in subsection (k)(5)(B) of this Section, subject to the limitation of subsection (k)(5)(C) of this Section.
  - A) <u>""</u>Two-carbon contaminants" (Phase I or II VOC) are the following:

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

- 1,2-Dichloroethane (Phase I)
- 1, I-Dichloroethylene (Phase I)
- cis-1,2-Dichloroethylene (Phase II)

trans-1,2-Dichloroethylene (Phase II)

Tetrachloroethylene (Phase II)

1,1,1 - Trichloroethylene (Phase I)

Trichloroethylene (Phase I)

- B) The supplier must sample quarterly for vinyl chloride at each sampling point at which it detected one or more of the two-carbon contaminants listed in subsection (k)(5)(A) of this Section.
- C) The Agency must grant a SEP pursuant to Section 611.110 that allows the supplier to reduce the monitoring frequency for vinyl chloride at any sampling point to once in each three-year compliance period if it determines that the supplier has not detected vinyl chloride in the first sample required by subsection (k)(5)(B) of this Section.
- 1) Quarterly monitoring following MCL violations.
  - Suppliers that violate an MCL for one of the Phase I VOCs, including vinyl chloride; Phase II VOCs; or Phase V VOCs, as determined by subsection (o) of this Section, must monitor quarterly for that contaminant, at the sampling point where the violation occurred, beginning the next quarter after the violation.
  - 2) Annual monitoring.
    - A) The Agency must grant a SEP pursuant to Section 611.110 that allows a supplier to reduce the monitoring frequency to annually if it determines that the sampling point is reliably and consistently below the MCL.

# POLLUTION CONTROL BOARD

- B) A request for a SEP must include the following minimal information: four quarterly samples.
- C) In issuing a SEP, the Agency must specify the level of the contaminant upon which the <u>"reliably</u> and consistently<u>"</u> determination was based. Any SEP that allows less frequent monitoring based on an Agency <u>"reliably</u> and consistently<u>"</u> determination must include a condition requiring the supplier to resume quarterly monitoring pursuant to subsection (l)(1) of this Section if it violates the MCL specified by Section 611.311.
- D) The supplier must monitor during the quarters that previously yielded the highest analytical result.
- m) Confirmation samples. The Agency may issue a SEP pursuant to Section 610.110 to require a supplier to use a confirmation sample for results that it finds dubious for whatever reason. The Agency must state its reasons for issuing the SEP if the SEP is Agency-initiated.
  - 1) If a supplier detects any of the Phase I, Phase II, or Phase V VOCs in a sample, the supplier must take a confirmation sample as soon as possible, but no later than 14 days after the supplier receives notice of the detection.
  - 2) Averaging is as specified in subsection (0) of this Section.
  - 3) The Agency must delete the original or confirmation sample if it determines that a sampling error occurred, in which case the confirmation sample will replace the original or confirmation sample.
- n) This subsection (n) corresponds with 40 CFR 141.24(f)(14), an optional USEPA provision relating to compositing of samples that USEPA does not require for state programs. This statement maintains structural consistency with USEPA rules.
- compliance with the MCLs for the Phase I, Phase II, and Phase V VOCs must be determined based on the analytical results obtained at each sampling point.— Effective January 22, 2004, if If one sampling point is in violation of an MCL, the system is in violation of the MCL.

# POLLUTION CONTROL BOARD

- Effective January 22, 2004, for For a supplier that monitors more than once per year, compliance with the MCL is determined by a running annual average at each sampling point.
- 2) Effective January 22, 2004, a A supplier that monitors annually or less frequently whose sample result exceeds the MCL must begin quarterly sampling. The system will not be considered in violation of the MCL until it has completed one year of quarterly sampling.
- Effective January 22, 2004, if If any sample result will cause the running annual average to exceed the MCL at any sampling point, the supplier is out of compliance with the MCL immediately.
- Effective January 22, 2004, if If a supplier fails to collect the required number of samples, compliance will be based on the total number of samples collected.
- 5) Effective January 22, 2004, if If a sample result is less than the detection limit, zero will be used to calculate the annual average.
- 6) Until January 22, 2004, for a supplier that conducts monitoring at a frequency greater than annual, compliance is determined by a running annual average of all samples taken at each sampling point.
  - A) If the annual average of any sampling point is greater than the MCL, then the supplier is out of compliance.
  - B) If the initial sample or a subsequent sample would cause the annual average to exceed the MCL, then the supplier is out of compliance immediately.
  - C) Any samples below the detection limit must be deemed as zero forpurposes of determining the annual average.
- 7) Until January 22, 2004, if monitoring is conducted annually, or less frequently, the supplier is out of compliance if the level of a contaminant at any sampling point is greater than the MCL. Until January 22, 2004, if a confirmation sample is taken, the determination of compliance is based on the average of two samples.

# POLLUTION CONTROL BOARD

- p) This subsection (p) corresponds with 40 CFR 141.24(f)(16), which USEPA removed and reserved. This statement maintains structural consistency with the federal regulations.
- q) Analysis under this Section must only be conducted by laboratories that have received certification by USEPA or the Agency according to the following conditions:
  - 1) To receive certification to conduct analyses for the Phase I VOCs, excluding vinyl chloride; Phase II VOCs; and Phase V VOCs, the laboratory must do the following:
    - A) It must analyze performance evaluation (PE) samples that include these substances provided by the Agency pursuant to 35 Ill. Adm. Code 186.170;
    - B) It must achieve the quantitative acceptance limits under subsections (q)(1)(C) and (q)(1)(D) of this Section for at least 80 percent of the regulated organic contaminants in the PE sample;
    - C) It must achieve quantitative results on the analyses performed under subsection (q)(1)(A) of this Section that are within  $\pm 20$ percent of the actual amount of the substances in the PE sample when the actual amount is greater than or equal to 0.010 mg/ $\ell$ ;
    - D) It must achieve quantitative results on the analyses performed under subsection (q)(1)(A) of this Section that are within  $\pm 40$ percent of the actual amount of the substances in the PE sample when the actual amount is less than 0.010 mg/ $\ell$ ; and
    - E) It must achieve a method detection limit of 0.0005 mg/l, according to the procedures in appendix B to 40 CFR 136, incorporated by reference in Section 611.102.
  - 2) To receive certification to conduct analyses for vinyl chloride the laboratory must do the following:
    - A) It must analyze PE samples provided by the Agency pursuant to 35

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

Ill. Adm. Code 186.170;

- B) It must achieve quantitative results on the analyses performed under subsection (q)(2)(A) of this Section that are within  $\pm 40$ percent of the actual amount of vinyl chloride in the PE sample;
- C) It must achieve a method detection limit of 0.0005 mg/ $\ell$ , according to the procedures in appendix B to 40 CFR 136, incorporated by reference in Section 611.102; and
- D) It must obtain certification pursuant to subsection (q)(1) of this Section for Phase I VOCs, excluding vinyl chloride; Phase II VOCs; and Phase V VOCs.
- r) This subsection (r) corresponds with 40 CFR 141.24(f)(18), an obsolete provision that relates to the initial compliance period from 1993 through 1995. This statement maintains consistency with the federal regulations.
- s) The Agency shall, by a SEP issued pursuant to Section 611.110, increase the number of sampling points or the frequency of monitoring if it determines that it is necessary to detect variations within the PWS.
- t) Each laboratory certified for the analysis of Phase I, Phase II, or Phase V VOCs pursuant to subsection (q)(1) or (q)(2) of this Section shall do the following:
  - 1) Determine the method detection limit (MDL), as defined in appendix B to 40 CFR 136, incorporated by reference in Section 611.102, at which it is capable of detecting the Phase I, Phase II, and Phase V VOCs; and,
  - 2) Achieve an MDL for each Phase I, Phase II, and Phase V VOC that is less than or equal to 0.0005 mg/ $\ell$ .
- u) Each supplier must monitor, within each compliance period, at the time designated by the Agency by SEP pursuant to Section 611.110.
- v) A new system supplier or a supplier that uses a new source of water that begins operation after January 22, 2004 must demonstrate compliance with the MCL within a period of time specified by a permit issued by the Agency. The supplier must also comply with the initial sampling frequencies specified by the Agency to

## POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

ensure the supplier can demonstrate compliance with the MCL. Routine and increased monitoring frequencies must be conducted in accordance with the requirements in this Section.

BOARD NOTE: Derived from 40 CFR 141.24(f) (2005) (2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_\_)

## Section 611.648 Phase II, Phase IIB, and Phase V Synthetic Organic Contaminants

Analysis of the Phase II, Phase IIB, and Phase V SOCs for the purposes of determining compliance with the MCL must be conducted as follows:

a) Definitions. As used in this Section, the following terms will have the following meanings:

"\_Detect?" or "detection?" means that the contaminant of interest is present at a level greater than or equal to the "detection limit."

"\_Detection limit" means the level of the contaminant of interest that is specified in subsection (r) of this Section.

BOARD NOTE: This is a ""trigger level" for Phase II, Phase IIB, and Phase V SOCs inasmuch as it prompts further action. The use of the term ""detect" or ""detection" in this Section is not intended to include any analytical capability of quantifying lower levels of any contaminant, or the ""method detection limit."

b) Required sampling. Each supplier must take a minimum of one sample at each sampling point at the times required in subsection (q) of this Section.

BOARD NOTE: See the Board note appended to Section 611.311(c) for information relating to implementation of requirements relating to aldicarb, aldicarb sulfone, and aldicarb sulfoxide.

- c) Sampling points.
  - 1) Sampling points for GWSs. Unless otherwise provided by SEP, a GWS supplier must take at least one sample from each of the following points:

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

each entry point that is representative of each well after treatment.

- 2) Sampling points for an SWS or mixed system supplier. Unless otherwise provided by SEP, an SWS or mixed system supplier must sample from each of the following points:
  - A) Each entry point after treatment; or
  - B) Points in the distribution system that are representative of each source.
- 3) The supplier must take each sample at the same sampling point unless the Agency has granted a SEP that designates another location as more representative of each source, treatment plant, or within the distribution system.
- 4) If a system draws water from more than one source, and the sources are combined before distribution, the supplier must sample at an entry point during periods of normal operating conditions when water is representative of all sources being used.

BOARD NOTE: Subsections (b) and (c) of this Section derived from 40 CFR 141.24(h)(1) through (h)(3) (2003)(2012).

- d) Monitoring frequency.
  - 1) Each CWS and NTNCWS supplier must take four consecutive quarterly samples for each of the Phase II, Phase IIB, and Phase V SOCs during each compliance period, beginning in the three-year compliance period starting in the initial compliance period.
  - 2) Suppliers serving more than 3,300 persons that do not detect a contaminant in the initial compliance period must take a minimum of two quarterly samples in one year of each subsequent three-year compliance period.
  - 3) Suppliers serving fewer than or equal to 3,300 persons that do not detect a contaminant in the initial compliance period must take a minimum of one sample during each subsequent three-year compliance period.

#### POLLUTION CONTROL BOARD

- e) Reduction to annual monitoring frequency. A CWS or NTNCWS supplier may apply to the Agency for a SEP that releases it from the requirements of subsection (d) of this Section. A SEP from the requirement of subsection (d) of this Section must last for only a single three-year compliance period.
- f) Vulnerability assessment. The Agency must grant a SEP from the requirements of subsection (d) of this Section based on consideration of the factors set forth at Section 611.110(e).
- g) If one of the Phase II, Phase IIB, or Phase V SOCs is detected in any sample, then the following must occur:
  - 1) The supplier must monitor quarterly for the contaminant at each sampling point that resulted in a detection.
  - 2) Annual monitoring.
    - A) A supplier may request that the Agency grant a SEP pursuant to Section 610.110 that reduces the monitoring frequency to annual.
    - B) A request for a SEP must include the following minimal information:
      - i) For a GWS, two quarterly samples.
      - ii) For an SWS or mixed system supplier, four quarterly samples.
    - C) The Agency must grant a SEP that allows annual monitoring at a sampling point if it determines that the sampling point is reliably and consistently below the MCL.
    - D) In issuing the SEP, the Agency must specify the level of the contaminant upon which the "reliably and consistently?" determination was based. Any SEP that allows less frequent monitoring based on an Agency "reliably and consistently?" determination must include a condition requiring the supplier to resume quarterly monitoring pursuant to subsection (g)(1) of this

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

Section if it detects any Phase II SOC.

- 3) Suppliers that monitor annually must monitor during the quarters that previously yielded the highest analytical result.
- 4) Suppliers that have three consecutive annual samples with no detection of a contaminant at a sampling point may apply to the Agency for a SEP with respect to that point, as specified in subsections (e) and (f) of this Section.
- 5) Monitoring for related contaminants.
  - A) If monitoring results in detection of one or more of the related contaminants listed in subsection (g)(5)(B) of this Section, subsequent monitoring must analyze for all the related compounds in the respective group.
  - B) Related contaminants.
    - i) First group.

aldicarb

aldicarb sulfone

aldicarb sulfoxide

BOARD NOTE: See the Board note appended to Section 611.311(c) for information relating to implementation of requirements relating to aldicarb, aldicarb sulfone, and aldicarb sulfoxide.

ii) Second group.

heptachlor

heptachlor epoxide.

h) Quarterly monitoring following MCL violations.

## POLLUTION CONTROL BOARD

- Suppliers that violate an MCL for one of the Phase II, Phase IIB, or Phase V SOCs, as determined by subsection (k) of this Section, must monitor quarterly for that contaminant at the sampling point where the violation occurred, beginning the next quarter after the violation.
- 2) Annual monitoring.
  - A) A supplier may request that the Agency grant a SEP pursuant to Section 611.110 that reduces the monitoring frequency to annual.
  - B) A request for a SEP must include, at a minimum, the results from four quarterly samples.
  - C) The Agency must grant a SEP that allows annual monitoring at a sampling point if it determines that the sampling point is reliably and consistently below the MCL.
  - D) In issuing the SEP, the Agency must specify the level of the contaminant upon which the ""reliably and consistently?" determination was based. Any SEP that allows less frequent monitoring based on an Agency ""reliably and consistently?" determination must include a condition requiring the supplier to resume quarterly monitoring pursuant to subsection (h)(1) of this Section if it detects any Phase II SOC.
  - E) The supplier must monitor during the quarters that previously yielded the highest analytical result.
- i) Confirmation samples.
  - If any of the Phase II, Phase IIB, or Phase V SOCs are detected in a sample, the supplier must take a confirmation sample as soon as possible, but no later than 14 days after the supplier receives notice of the detection.
  - 2) Averaging is as specified in subsection (k) of this Section.
  - 3) The Agency must delete the original or confirmation sample if it determines that a sampling error occurred, in which case the confirmation sample will replace the original or confirmation sample.

## POLLUTION CONTROL BOARD

- j) This subsection (j) corresponds with 40 CFR 141.24(h)(10), an optional USEPA provision relating to compositing of samples that USEPA does not require for state programs. This statement maintains structural consistency with USEPA rules.
- k) Compliance with the MCLs for the Phase II, Phase IIB, and Phase V SOCs must be determined based on the analytical results obtained at each sampling point. Effective January 22, 2004, if If one sampling point is in violation of an MCL, the supplier is in violation of the MCL.
  - Effective January 22, 2004, for For aFor supplier that monitors more than once per year, compliance with the MCL is determined by a running annual average at each sampling point.
  - 2) Effective January 22, 2004, a A supplier that monitors annually or less frequently whose sample result exceeds the regulatory detection level as defined by subsection (r) of this Section must begin quarterly sampling. The system will not be considered in violation of the MCL until it has completed one year of quarterly sampling.
  - 3) Effective January 22, 2004, if If any sample result will cause the running annual average to exceed the MCL at any sampling point, the supplier is out of compliance with the MCL immediately.
  - Effective January 22, 2004, if If a supplier fails to collect the required number of samples, compliance will be based on the total number of samples collected.
  - 5) Effective January 22, 2004, if If a sample result is less than the detection limit, zero will be used to calculate the annual average.
  - 6) Until January 22, 2004, for a supplier that conducts monitoring at a frequency greater than annual, compliance is determined by a running-annual average of all samples taken at each sampling point.
    - A) If the annual average of any sampling point is greater than the MCL, then the supplier is out of compliance.

#### POLLUTION CONTROL BOARD

- B) If the initial sample or a subsequent sample would cause the annualaverage to exceed the MCL, then the supplier is out of complianceimmediately.
- C) Any samples below the detection limit must be deemed as zero for purposes of determining the annual average.
- 7) Until January 22, 2004, if the supplier conducts monitoring annually, or less frequently, the supplier is out of compliance if the level of a contaminant at any sampling point is greater than the MCL. Until January 22, 2004, if a confirmation sample is taken, the determination of compliance is based on the average of two samples.
- 1) This subsection (11) corresponds with 40 CFR 141.24(h)(12), which USEPA removed and reserved. This statement maintains structural consistency with the federal regulations.
- m) Analysis for PCBs must be conducted as follows using the methods in Section 611.645:
  - 1) Each supplier that monitors for PCBs must analyze each sample using either USEPA Organic Methods, Method 505 or Method 508.
  - 2) If PCBs are detected in any sample analyzed using USEPA Organic Methods, Method 505 or 508, the supplier must reanalyze the sample using Method 508A to quantitate the individual Aroclors (as decachlorobiphenyl).
  - Compliance with the PCB MCL must be determined based upon the quantitative results of analyses using USEPA Organic Methods, Method 508A.
- n) This subsection (n) corresponds with 40 CFR 141.24(h)(14), an obsolete provision that relates to the initial compliance period from 1993 through 1995. This statement maintains consistency with the federal regulations.
- o) The Agency must issue a SEP that increases the number of sampling points or the frequency of monitoring if it determines that this is necessary to detect variations within the PWS due to such factors as fluctuations in contaminant concentration

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

due to seasonal use or changes in the water source.

BOARD NOTE: At 40 CFR 141.24(h)(15), USEPA uses the stated factors as non-limiting examples of circumstances that make additional monitoring necessary.

- p) This subsection (p) corresponds with 40 CFR 141.24(h)(16), a USEPA provision relating to reserving enforcement authority to the State that would serve no useful function as part of the State.'s rules. This statement maintains structural consistency with USEPA rules.
- q) Each supplier must monitor, within each compliance period, at the time designated by the Agency by SEP pursuant to Section 611.110.
- r) <u>"Detection</u>" means greater than or equal to the following concentrations for each contaminant:

Aroclor	Detection Limit (mg/l)	
1016	0.00008	
1221	0.02	
1232	0.0005	
1242	0.0003	
1248	0.0001	
1254	0.0001	
1260	0.0002	

1) for PCBs (Aroclors), the following:

2) for other Phase II, Phase IIB, and Phase V SOCs, the following:

Contaminant	Detection Limit (mg/l)
Alachlor	0.0002
Aldicarb	0.0005
Aldicarb sulfoxide	0.0005
Aldicarb sulfone	0.0008
Atrazine	0.0001

## POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

Benzo(a)pyrene	0.00002
Carbofuran	0.0009
Chlordane	0.0002
2,4-D	0.0001
Dalapon	0.001
1,2-Dibromo-3-chloropropane (DBCP)	0.00002
Di(2-ethylhexyl)adipate	0.0006
Di(2-ethylhexyl)phthalate	0.0006
Dinoseb	0.0002
Diquat	0.0004
Endothall	0.009
Endrin	0.00001
Ethylene dibromide (EDB)	0.00001
Glyphosate	0.006
Heptachlor	0.00004
Heptachlor epoxide	0.00002
Hexachlorobenzene	0.0001
Hexachlorocyclopentadiene	0.0001
Lindane	0.00002
Methoxychlor	0.0001
Oxamyl	0.002
Picloram	0.0001
Polychlorinated biphenyls (PCBs) (as	0.0001
decachlorobiphenyl)	
Pentachlorophenol	0.00004
Simazine	0.00007
Toxaphene	0.001
2,3,7,8-TCDD (dioxin)	0.000000005
2,4,5-TP (silvex)	0.0002

BOARD NOTE: See the Board note appended to Section 611.311(c) for information relating to implementation of requirements relating to aldicarb, aldicarb sulfone, and aldicarb sulfoxide.

- s) Laboratory certification.
  - Analyses under this Section must only be conducted by laboratories that have received approval by USEPA or the Agency according to the conditions of subsection (s)(2) of this Section.

#### POLLUTION CONTROL BOARD

- 2) To receive certification to conduct analyses for the Phase II, Phase IIB, and Phase V SOCs, the laboratory must do the following:
  - A) Analyze PE samples provided by the Agency pursuant to 35 Ill. Adm. Code 183.125(c) that include these substances; and
  - B) Achieve quantitative results on the analyses performed under subsection (s)(2)(A) of this Section that are within the following acceptance limits:

SOC	Acceptance Limits
Alachlor	± 45%
Aldicarb	2 standard deviations
Aldicarb sulfone	2 standard deviations
Aldicarb sulfoxide	2 standard deviations
Atrazine	± 45%
Benzo(a)pyrene	2 standard deviations
Carbofuran	± 45%
Chlordane	± 45%
Dalapon	2 standard deviations
Di(2-ethylhexyl)adipate	2 standard deviations
Di(2-ethylhexyl)phthalate	2 standard deviations
Dinoseb	2 standard deviations
Diquat	2 standard deviations
Endothall	2 standard deviations
Endrin	± 30%
Glyphosate	2 standard deviations
Dibromochloropropane (DBCP)	± 40%
Ethylene dibromide (EDB)	± 40%
Heptachlor	$\pm 45\%$
Heptachlor epoxide	± 45%
Hexachlorobenzene	2 standard deviations
Hexachlorocyclopentadiene	2 standard deviations
Lindane	± 45%
Methoxychlor	± 45%
Oxamyl	2 standard deviations
PCBs (as decachlorobiphenyl)	0-200%

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

- Pentachlorophenol Picloram Simazine Toxaphene 2,4-D 2,3,7,8-TCDD (dioxin) 2,4,5-TP (silvex)
- ± 50%
  2 standard deviations
  2 standard deviations
  ± 45%
  ± 50%
  2 standard deviations
  ± 50%

BOARD NOTE: See the Board note appended to Section 611.311(c) for information relating to implementation of requirements relating to aldicarb, aldicarb sulfone, and aldicarb sulfoxide.

t) A new system supplier or a supplier that uses a new source of water that beginsoperation after January 22, 2004 must demonstrate compliance with the MCL within a period of time specified by a permit issued by the Agency. The supplier must also comply with the initial sampling frequencies specified by the Agency to ensure the supplier can demonstrate compliance with the MCL. Routine and increased monitoring frequencies must be conducted in accordance with the requirements in this Section.

BOARD NOTE: Derived from 40 CFR 141.24(h) (2003) (2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

SUBPART Q: RADIOLOGICAL MONITORING AND ANALYTICAL REQUIREMENTS

# Section 611.720 Analytical Methods

- a) The methods specified below, or alternative methods approved by the Agency pursuant to Section 611.480, incorporated by reference in Section 611.102, are to be used to determine compliance with Section 611.330, except in cases where alternative methods have been approved in accordance with Section 611.480.
  - 1) Gross Alpha and Beta.
    - A) Standard Methods.
      - i) Method 302, 13<sup>th</sup> ed.; or

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

- ii) Method 7110 B, 17<sup>th</sup>, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed.;
- B) USEPA Interim Radiochemical Methods: pages 1-3;
- C) USEPA Radioactivity Methods, Method 900.0;
- D) USEPA Radiochemical Analyses: pages 1-5;
- E) USEPA Radiochemistry Procedures, Method 00-01; or
- F) USGS Methods, Method R-1120-76.

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed., Method 7110 B as an approved alternative method for gross alpha and beta in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

- 2) Gross Alpha.
  - A) Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., Method 7110 C; or
  - B) USEPA Radiochemistry Procedures, Method 00-02.

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed., Method 7110 C as an approved alternative method for gross alpha in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

- 3) Radium-226.
  - A) ASTM Methods.
    - i) Method D2460-97 or D2460-07; or
    - ii) Method D3454-97 or D3454-05;
  - B) New York Radium Method;
  - C) Standard Methods.

### POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

- i) Method 304, 13<sup>th</sup> ed.;
- ii) Method 305, 13<sup>th</sup> ed.;
- iii) Method 7500-Ra B, 17<sup>th</sup>, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed.; or
- iv) Method 7500-Ra C, 17<sup>th</sup>, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed.;
- D) EML Procedures Manual (27th or 28th ed.), Method Ra-04;
- E) USEPA Interim Radiochemical Methods: pages 13-15 or 16-23;
- F) USEPA Radioactivity Methods, Methods 903.0, 903.1;
- G) USEPA Radiochemical Analyses, pages 19-32;
- H) USEPA Radiochemistry Procedures, Method Ra-03 or Ra-04; or
- I) USGS Methods.
  - i) Method R-1140-76; or
  - ii) Method R-1141-76.
- J) Georgia Radium Method.

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed., Methods 7500-Ra B and C as approved alternative methods for radium-226 in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Methods D2460-07 and D3454-05 as approved alternative methods for radium-226 in appendix A to subpart C of 40 CFR 141 on June 8, 2010 (at 75 Fed. Reg. 32295).

- 4) Radium-228.
  - A) Standard Methods, 17<sup>th</sup>, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., Method 7500-Ra D;
  - B) New York Radium Method;

## POLLUTION CONTROL BOARD

NOTICE OF PROPOSED AMENDMENTS

- C) USEPA Interim Radiochemical Methods, pages 24-28;
- D) USEPA Radioactivity Methods, Method 904.0;
- E) USEPA Radiochemical Analyses, pages 19-32;
- F) USEPA Radiochemistry Procedures, Method Ra-05;
- G) USGS Methods, Method R-1142-76;
- H) New Jersey Radium Method; or
- I) Georgia Radium Method.

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed., Method 7500-Ra D as an approved alternative method for radium-228 in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

- 5) Uranium.
  - A) Standard Methods, 17<sup>th</sup>, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed., Method 7500-U
     C;
  - B) Standard Methods, 20<sup>th</sup> or 21<sup>st</sup> ed., Method 3125;
  - C) ASTM Methods.
    - i) Method D2907-97;
    - ii) Method D3972-97 or D3972-02;
    - iii) Method D5174-97, D5174-02, D5174-07, or D3972-09; or
    - iv) Method D5673-03, or Method 5673-05 D5673-05, or Method D5673-10; or
    - v) Method D6239-09;

## POLLUTION CONTROL BOARD

NOTICE OF PROPOSED AMENDMENTS

- D) USEPA Radioactivity Methods, Methods 908.0, 908.1;
- E) USEPA Environmental Metals Methods, Method 200.8 (rev. 5.3);
- F) USEPA Radiochemical Analyses, pages 33-48;
- G) USEPA Radiochemistry Procedures, Method 00-07;
- EML Procedures Manual (27<sup>th</sup> or 28<sup>th</sup> ed.), Method U-02 or U-04; or
- I) USGS Methods.
  - i) Method R-1180-76;
  - ii) Method R-1181-76; or
  - iii) Method R-1182-76.

BOARD NOTE: If uranium (U) is determined by mass, a conversion factor of 0.67 pCi/ $\mu$ g of uranium must be used. This conversion factor is based on the 1:1 activity ratio of <sup>234</sup>U and <sup>238</sup>U that is characteristic of naturally occurring uranium.

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed., Method 7500-U C and ASTM Method D5673-05 as approved alternative methods for uranium in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Method D5174-07 as an approved alternative method for uranium in appendix A to subpart C of 40 CFR 141 on June 8, 2010 (at 75 Fed. Reg. 32295). USEPA added ASTM Method D3972-09 as an approved alternative method for uranium in appendix A to subpart C of 40 CFR 141 on June 24, 2011 (at 76 Fed. Reg. 37014). USEPA added Standard Methods, 21<sup>st</sup> ed., Method 3125 and ASTM <u>MethodsMethods</u> D5673-10 and D6329-09 as approved alternative methods for uranium in appendix A to subpart C of 40 CFR 141 on June 3, 2012 (at 77 Fed. Reg. 38523).

6) Radioactive Cesium.

POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

- A) ASTM Methods.
  - i) Method D2459-72; or
  - ii) Method D3649-91, D3649-98a, or D3649-06;
- B) Standard Methods.
  - i) i) Method 7120, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed.; or
  - ii) Method 7500-Cs B, 17<sup>th</sup>, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed.;
- C) EML Procedures Manual (27th or 28th ed.), Method 4.5.2.3;
- D) USEPA Interim Radiochemical Methods, pages 4-5;
- E) USEPA Radioactivity Methods, Methods 901.0, 901.1;
- F) USEPA Radiochemical Analyses, pages 92-95; or
- G) USGS Methods.
  - i) Method R-1110-76; or
  - ii) Method R-1111-76.

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed., Methods 7120 and 7500-Cs B as approved alternative methods for radioactive cesium in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Method D3649-06 as an approved alternative method for radioactive cesium in appendix A to subpart C of 40 CFR 141 on June 8, 2010 (at 75 Fed. Reg. 32295).

- 7) Radioactive Iodine.
  - A) ASTM Methods.
    - i) D3649-91, D3649-98a, or D3649-06; or
    - ii) D4785-93, D4785-98, or D4785-08;

#### POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

- B) Standard Methods.
  - i) Method 7120, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed.;
  - ii) Method 7500-I B, 17<sup>th</sup>, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed.;
  - iii) Method 7500-I C, 17<sup>th</sup>, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed.; or
  - iv) Method 7500-I D, 17<sup>th</sup>, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed.;
- C) EML Procedures Manual (27<sup>th</sup> or 28<sup>th</sup> ed.), Method 4.5.2.3;
- D) USEPA Interim Radiochemical Methods, pages 6-8 or 9-12;
- E) USEPA Radiochemical Analyses, pages 92-95; or
- F) USEPA Radioactivity Methods, Methods 901.1 or 902.0.

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed., Methods 7120 and 7500-I B, C, and D as approved alternative methods for radioactive iodine in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Methods D3649-06 and D4785-08 as approved alternative methods for radioactive iodine in appendix A to subpart C of 40 CFR 141 on June 8, 2010 (at 75 Fed. Reg. 32295).

- 8) Radioactive Strontium-89 & 90.
  - A) Standard Methods.
    - i) Method 303, 13<sup>th</sup> ed.; or
    - ii) Method 7500-Sr B, 17<sup>th</sup>, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed.;
  - B) EML Procedures Manual (27<sup>th</sup> or 28<sup>th</sup> ed.), Method Sr-01 or Sr-02.
  - C) USEPA Interim Radiochemical Methods, pages 29-33;

## POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

- D) USEPA Radioactivity Methods, Method 905.0;
- E) USEPA Radiochemical Analyses, pages 65-73;
- F) USEPA Radiochemistry Procedures, Method Sr-04; or
- G) USGS Methods, Method R-1160-76.

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed., Method 7500-Sr B as an approved alternative method for radioactive strontium in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

- 9) Tritium.
  - A) ASTM Methods: Method D4107-91, D4107-98, or D4107-08;
  - B) Standard Methods.
    - i) Method 306, 13<sup>th</sup> ed.; or
    - ii) Method 7500-<sup>3</sup>H B, 17<sup>th</sup>, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed.;
  - C) USEPA Interim Radiochemical Methods, pages 34-37;
  - D) USEPA Radioactivity Methods, Method 906.0;
  - E) USEPA Radiochemical Analyses, pages 87-91;
  - F) USEPA Radiochemistry Procedures, Method H-02; or
  - G) USGS Methods, Method R-1171-76.

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed., Method 7500-<sup>3</sup>H B as an approved alternative method for tritium in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Method D4107-08 as an approved alternative method for tritium in appendix A to subpart C of 40 CFR 141 on June 8, 2010 (at 75 Fed. Reg. 32295).

## POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

- 10) Gamma Emitters.
  - A) ASTM Methods.
    - i) Method D3649-91, D3649-98a, or D3649-06; or
    - ii) Method D4785-93, D4785-00a, or D4785-08;
  - B) Standard Methods.
    - i) Method 7120, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed.;
    - ii) Method 7500-Cs B, 17<sup>th</sup>, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed.; or
    - iii) Method 7500-I B, 17<sup>th</sup>, 18<sup>th</sup>, 19<sup>th</sup>, 20<sup>th</sup>, or 21<sup>st</sup> ed.;
  - C) EML Procedures Manual (27th or 28th ed.), Method Ga-01-R;
  - D) USEPA Radioactivity Methods, Methods 901.0, 901.1, or 902.0;
  - E) USEPA Radiochemical Analyses, pages 92-95; or
  - F) USGS Methods, Method R-1110-76.

BOARD NOTE: USEPA added Standard Methods, 21<sup>st</sup> ed., Methods 7120, 7500-Cs B, and 7500-I B as approved alternative methods for gamma emitters in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Methods D3649-08 and D4785-08 as approved alternative methods for tritium in appendix A to subpart C of 40 CFR 141 on June 8, 2010 (at 75 Fed. Reg. 32295).

- b) When the identification and measurement of radionuclides other than those listed in subsection (a) of this Section are required, the following methods, incorporated by reference in Section 611.102, are to be used, except in cases where alternative methods have been approved in accordance with Section 611.480:
  - 1) "Procedures for Radiochemical Analysis of Nuclear Reactor Aqueous Solutions," available from NTIS.

# POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

- 2) EML Procedures Manual (27<sup>th</sup> or 28<sup>th</sup> ed.), available from USDOE, EML.
- c) For the purpose of monitoring radioactivity concentrations in drinking water, the required sensitivity of the radioanalysis is defined in terms of a detection limit. The detection limit must be that concentration which can be counted with a precision of plus or minus 100 percent at the 95 percent confidence level (1.96 $\sigma$ , where  $\sigma$  is the standard deviation of the net counting rate of the sample).
  - To determine compliance with Section 611.330(b), (c), and (e), the detection limit must not exceed the concentrations set forth in the following table:

Contaminant	<b>Detection</b> Limit
Gross alpha particle	3 pCi/l
activity	
Radium-226	1 pCi/l
Radium-228	1 pCi/ℓ
Uranium	1 μg/l

BOARD NOTE: Derived from 40 CFR 141.25(c) Table B (2011) (2012).

2) To determine compliance with Section 611.330(d), the detection limits must not exceed the concentrations listed in the following table:

Radionuclide	Detection Limit
Tritium	1,000 pCi/l
Strontium-89	10 pCi/l
Strontium-90	2 pCi/l
Iodine-131	1 pCi/l
Cesium-134	10 pCi/ℓ
Gross beta	4 pCi/ℓ
Other radionuclides	1/10 of applicable limit

BOARD NOTE: Derived from 40 CFR 141.25(c) Table C (2011) (2012).

d) To judge compliance with the MCLs listed in Section 611.330, averages of data must be used and must be rounded to the same number of significant figures as the MCL for the substance in question.

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

BOARD NOTE: Derived from 40 CFR 141.25 and appendix A to subpart C of 40 CFR 141-(2011) (2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

## Section 611.731 Gross Alpha

Monitoring requirements for gross alpha particle activity, radium-226, radium-228, and uranium are as follows:

- a) Effective December 8, 2003, a A community water system (CWS) supplier must conduct initial monitoring to determine compliance with Section 611.330(b), (c), and (e) by December 31, 2007. For the purposes of monitoring for gross alpha particle activity, radium-226, radium-228, uranium, and beta particle and photon radioactivity in drinking water, "detection limit" is defined as in Section 611.720(c).
  - 1) Applicability and sampling location for an existing CWS supplier. An existing CWS supplier using groundwater, surface water, or both groundwater and surface water (for the purpose of this Section hereafter referred to as a supplier) must sample at every entry point to the distribution system that is representative of all sources being used (hereafter called a sampling point) under normal operating conditions. The supplier must take each sample at the same sampling point, unless conditions make another sampling point more representative of each source or the Agency has designated a distribution system location, in accordance with subsection (b)(2)(C) of this Section.
  - 2) Applicability and sampling location for a new CWS supplier. A new CWS supplier or a CWS supplier that uses a new source of water must begin to conduct initial monitoring for the new source within the first quarter after initiating use of the source. A CWS supplier must conduct more frequent monitoring when ordered by the Agency in the event of possible contamination or when changes in the distribution system or treatment processes occur that may increase the concentration of radioactivity in finished water.
- b) Initial monitoring: Effective December 8, 2003, a A CWS supplier must conduct

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

initial monitoring for gross alpha particle activity, radium-226, radium-228, and uranium as follows:

- A CWS supplier without acceptable historical data, as defined in subsection (b)(2) of this Section, must collect is required to have collected four consecutive quarterly samples at all sampling points before December 31, 2007.
- 2) Grandfathering of data: A CWS supplier may use historical monitoring data collected at a sampling point to satisfy the initial monitoring requirements for that sampling point, under the following situations.
  - A) To satisfy initial monitoring requirements, a CWS supplier having only one entry point to the distribution system may use the monitoring data from the last compliance monitoring period that began between June 2000 and December 8, 2003.
  - B) To satisfy initial monitoring requirements, a CWS supplier with multiple entry points and having appropriate historical monitoring data for each entry point to the distribution system may use the monitoring data from the last compliance monitoring period that began between June 2000 and December 8, 2003.
  - C) To satisfy initial monitoring requirements, a CWS supplier with appropriate historical data for a representative point in the distribution system may use the monitoring data from the last compliance monitoring period that began between June 2000 and December 8, 2003, provided that the Agency finds that the historical data satisfactorily demonstrate that each entry point to the distribution system is expected to be in compliance based upon the historical data and reasonable assumptions about the variability of contaminant levels between entry points. The Agency must make its finding in writing, by a SEP issued pursuant to Section 611.110, indicating how the data conforms to the requirements of this subsection (b)(2).
- 3) For gross alpha particle activity, uranium, radium-226, and radium-228 monitoring, the Agency may, by a SEP issued pursuant to Section 611.110, waive the final two quarters of initial monitoring for a sampling

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

point if the results of the samples from the previous two quarters are below the detection limit.

- 4) If the average of the initial monitoring results for a sampling point is above the MCL, the supplier must collect and analyze quarterly samples at that sampling point until the system has results from four consecutive quarters that are at or below the MCL, unless the supplier enters into another schedule as part of a formal compliance agreement with the Agency.
- c) Reduced monitoring: Effective December 8, 2003, the The Agency may allow a CWS supplier to reduce the future frequency of monitoring from once every three years to once every six or nine years at each sampling point, based on the following criteria:
  - If the average of the initial monitoring results for each contaminant (i.e., gross alpha particle activity, uranium, radium-226, or radium-228) is below the detection limit specified in the table at Section 611.720(c)(1), the supplier must collect and analyze for that contaminant using at least one sample at that sampling point every nine years.
  - 2) For gross alpha particle activity and uranium, if the average of the initial monitoring results for each contaminant is at or above the detection limit but at or below one-half the MCL, the supplier must collect and analyze for that contaminant using at least one sample at that sampling point every six years. For combined radium-226 and radium-228, the analytical results must be combined. If the average of the combined initial monitoring results for radium-226 and radium-228 is at or above the detection limit but at or below one-half the MCL, the supplier must collect and analyze for that contaminant using at least one sample at that sampling point every six years.
  - 3) For gross alpha particle activity and uranium, if the average of the initial monitoring results for each contaminant is above one-half the MCL but at or below the MCL, the supplier must collect and analyze at least one sample at that sampling point every three years. For combined radium-226 and radium-228, the analytical results must be combined. If the average of the combined initial monitoring results for radium-226 and radium-228 is above one-half the MCL but at or below the MCL, the supplier must collect and analyze at least one sample at that sampling point every three years.

## POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

years.

- 4) A supplier must use the samples collected during the reduced monitoring period to determine the monitoring frequency for subsequent monitoring periods (e.g., if a supplier 's sampling point is on a nine year monitoring period, and the sample result is above one-half the MCL, then the next monitoring period for that sampling point is three years).
- 5) If a supplier has a monitoring result that exceeds the MCL while on reduced monitoring, the supplier must collect and analyze quarterly samples at that sampling point until the supplier has results from four consecutive quarters that are below the MCL, unless the supplier enters into another schedule as part of a formal compliance agreement with the Agency.
- d) Compositing: Effective December 8, 2003, to To fulfill quarterly monitoring requirements for gross alpha particle activity, radium-226, radium-228, or uranium, a supplier may composite up to four consecutive quarterly samples from a single entry point if analysis is done within a year after the first sample. The analytical results from the composited sample must be treated as the average analytical result to determine compliance with the MCLs and the future monitoring frequency. If the analytical result from the composited sample is greater than one-half the MCL, the Agency may, by a SEP issued pursuant to Section 611.110, direct the supplier to take additional quarterly samples before allowing the supplier to sample under a reduced monitoring schedule.
- e) Effective December 8, 2003, a A gross alpha particle activity measurement may be substituted for the required radium-226 measurement, provided that the measured gross alpha particle activity does not exceed 5 pCi/ $\ell$ . A gross alpha particle activity measurement may be substituted for the required uranium measurement provided that the measured gross alpha particle activity does not exceed 15 pCi/ $\ell$ .
  - The gross alpha measurement must have a confidence interval of 95% (1.65eg, where eg is the standard deviation of the net counting rate of the sample) for radium-226 and uranium.
  - 2) When a supplier uses a gross alpha particle activity measurement in lieu of a radium-226 or uranium measurement, the gross alpha particle activity

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

analytical result will be used to determine the future monitoring frequency for radium-226 or uranium.

- 3) If the gross alpha particle activity result is less than detection, one-half the detection limit will be used to determine compliance and the future monitoring frequency.
- f) Until December 8, 2003, compliance must be based on the analysis of an annual composite of four consecutive quarterly samples or the average of the analyses of four samples obtained at quarterly intervals.
  - 1) A gross alpha particle activity measurement may be substituted for the required radium-226 and radium-228 analysis, provided that the measured gross alpha particle activity does not exceed 5 pCi/ℓ at a confidence level of 95 percent (1.65σ where σ is the standard deviation of the net counting rate of the sample). In localities where radium-228 may be present in drinking water, the Agency may, by a SEP issued pursuant to Section-611.110, require radium-226 or radium-228 analyses if it determines that the gross alpha particle activity exceeds 2 pCi/ℓ.
  - 2) When the gross alpha particle activity exceeds 5 pCi/l, the same or an equivalent sample must be analyzed for radium 226. If the concentration of radium 226 exceeds 3 pCi/l the same or an equivalent sample must be analyzed for radium 228.
- g) Until December 8, 2003, CWS suppliers must monitor at least once every four years following the procedure required by subsection (f) of this Section. When an annual record taken in conformance with subsection (f) of this Section has established that the average annual concentration is less than half the MCLs established by Section 611.330, the Agency shall, by a SEP issued pursuant to Section 611.110, substitute analysis of a single sample for the quarterly sampling procedure required by subsection (f) of this Section.
  - The Agency shall, by a SEP issued pursuant to Section 611.110, requiremore frequent monitoring in the vicinity of mining or other operations thatmay contribute alpha particle radioactivity to either surface or groundwatersources of drinking water.

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

- 2) A CWS supplier must monitor in conformance with subsection (f) of this Section for one year after the introduction of a new water source. The Agency shall, by a SEP issued pursuant to Section 611.110, require morefrequent monitoring in the event of possible contamination or when changes in the distribution system or treatment process occur that may increase the concentration of radioactivity in finished water.
- 3) The Agency shall, by a SEP issued pursuant to Section 611.110, require a CWS supplier using two or more sources having different concentrations of radioactivity to monitor source water, in addition to water from a free flowing tap.
- 4) The Agency must not require monitoring for radium-228 to determinecompliance with Section 611.330 after the initial period, provided that the average annual concentration of radium-228 has been assayed at least onceusing the quarterly sampling procedure required by subsection (f) of this Section.
- 5) The Agency must require the CWS supplier to conduct annual monitoring if the radium-226 concentration exceeds 3 pCi/ℓ.
- h) Until December 8, 2003, if the average annual MCL for gross alpha particle activity or total radium as set forth in Section 611.330 is exceeded, the CWSsupplier must give notice to the Agency and notify the public as required by-Subpart V. Monitoring at quarterly intervals must be continued until the annualaverage concentration no longer exceeds the MCL or until a monitoring scheduleas a condition to a variance, adjusted standard or enforcement action becomeseffective.

BOARD NOTE:

Subsections (a) through (e) derive from 40 CFR 141.26(a) (2003)(2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_, effective \_\_\_\_\_)

#### Section 611.732 Beta Particle and Photon Radioactivity

Monitoring and compliance requirements for manmade radioactivity. To determine compliance with the maximum contaminant levels in Section 611.330(d) for beta particle and photon

# POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

radioactivity, a supplier must monitor at a frequency as follows:

- a) Effective December 8, 2003, a A CWS supplier (either a surface water or groundwater supplier) designated by the Agency, by a SEP issued pursuant to Section 611.110, as vulnerable must sample for beta particle and photon radioactivity. A supplier must collect quarterly samples for beta emitters and annual samples for tritium and strontium-90 at each entry point to the distribution system (hereafter called a sampling point), beginning within one quarter after being notified by the Agency. A supplier already designated by the Agency must continue to sample until the Agency reviews and either reaffirms or removes the designation, by a SEP issued pursuant to Section 611.110.
  - If the gross beta particle activity minus the naturally occurring potassium-40 beta particle activity at a sampling point has a running annual average (computed quarterly) less than or equal to 50 pCi/l (screening level), the Agency may reduce the frequency of monitoring at that sampling point to once every three years. A supplier must collect all samples required in subsection (a) of this Section during the reduced monitoring period.
  - 2) For a supplier in the vicinity of a nuclear facility, the Agency may allow the CWS supplier to utilize environmental surveillance data collected by the nuclear facility in lieu of monitoring at the supplier sentry points, where the Agency determines if such data is applicable to a particular water system, by a SEP issued pursuant to Section 611.110. In the event that there is a release from a nuclear facility, a supplier that is using surveillance data must begin monitoring at the community water supplier sentry points in accordance with subsection (b)(1) of this Section.
- b) Effective December 8, 2003, a A CWS supplier (either a surface water or groundwater supplier) designated by the Agency, by a SEP issued pursuant to Section 611.110, as utilizing waters contaminated by effluents from nuclear facilities must sample for beta particle and photon radioactivity. A supplier must collect quarterly samples for beta emitters and iodine-131 and annual samples for tritium and strontium-90 at each entry point to the distribution system (hereafter called a sampling point), beginning within one quarter after being notified by the Agency. A supplier already designated by the Agency as a supplier using waters contaminated by effluents from nuclear facilities must continue to sample until the

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

Agency reviews and either reaffirms or removes the designation, by a SEP issued pursuant to Section 611.110.

1) Quarterly monitoring for gross beta particle activity must be based on the analysis of monthly samples or the analysis of a composite of three monthly samples.

BOARD NOTE: In corresponding 40 CFR 141.26(b)(2)(i), USEPA recommends the use of a composite of three monthly samples.

- 2) For iodine-131, a composite of five consecutive daily samples must be analyzed once each quarter. The Agency may, by a SEP issued pursuant to Section 611.110, order more frequent monitoring for iodine-131 where it is identified in the finished water.
- 3) Annual monitoring for strontium-90 and tritium must be conducted by means of the analysis of a composite of four consecutive quarterly samples or analysis of four quarterly samples.

BOARD NOTE: In corresponding 40 CFR 141.26(b)(2)(iii), USEPA recommends the analysis of four consecutive quarterly samples.

- If the gross beta particle activity minus the naturally occurring potassium-40 beta particle activity at a sampling point has a running annual average (computed quarterly) less than or equal to 15 pCi/l, the Agency may, by a SEP issued pursuant to Section 611.110, reduce the frequency of monitoring at that sampling point to once every three years. The supplier must collect the same type of samples required in subsection (b) of this Section during the reduced monitoring period.
- 5) For a supplier in the vicinity of a nuclear facility, the Agency may allow the CWS to utilize environmental surveillance data collected by the nuclear facility in lieu of monitoring at the system? sentry points, where the Agency determines, by a SEP issued pursuant to Section 611.110, that such data is applicable to the particular water system. In the event that there is a release from a nuclear facility, a supplier that uses such surveillance data must begin monitoring at the CWS?'s entry points in accordance with subsection (b) of this Section.

### POLLUTION CONTROL BOARD

- c) Effective December 8, 2003, a A CWS supplier designated by the Agency to monitor for beta particle and photon radioactivity can not apply to the Agency for a waiver from the monitoring frequencies specified in subsection (a) or (b) of this Section.
- d) Effective December 8, 2003, a A CWS supplier may analyze for naturally occurring potassium-40 beta particle activity from the same or equivalent sample used for the gross beta particle activity analysis. A supplier is allowed to subtract the potassium-40 beta particle activity value from the total gross beta particle activity value to determine if the screening level is exceeded. The potassium-40 beta particle activity multiplying elemental potassium concentrations (in mg/ $\ell$ ) by a factor of 0.82.
- e) Effective December 8, 2003, if If the gross beta particle activity minus the naturally occurring potassium-40 beta particle activity exceeds the appropriate screening level, an analysis of the sample must be performed to identify the major radioactive constituents present in the sample and the appropriate doses must be calculated and summed to determine compliance with Section 611.330(d)(1), using the formula in Section 611.330(d)(2). Doses must also be calculated and combined for measured levels of tritium and strontium to determine compliance.
- f) Effective December 8, 2003, a A supplier must monitor monthly at the sampling points that exceeds the maximum contaminant level in Section 611.330(d) beginning the month after the exceedence occurs. A supplier must continue monthly monitoring until the supplier has established, by a rolling average of three monthly samples, that the MCL is being met. A supplier that establishes that the MCL is being met must return to quarterly monitoring until it meets the requirements set forth in subsection (a)(1) or (b)(4) of this Section.
- g) Until December 8, 2003, CWSs using surface water sources and serving more than 100,000 persons and such other CWSs as the Agency, by a SEP issued pursuant to Section 611.110, requires must monitor for compliance with Section 611.331 by analysis of a composite of four consecutive quarterly samples or analysis of four quarterly samples. Compliance with Section 611.331 is assumed without further analysis if the average annual concentration of gross beta particle activity is less than 50 pCi/l and if the average annual concentrations of tritium and strontium 90 are less than those listed in Section 611.331, provided that if both radionuclides are present the sum of their annual dose equivalents to bone marrow must not exceed 4 millirem/year.

#### POLLUTION CONTROL BOARD

- If the gross beta particle activity exceeds 50 pCi/l, an analysis of the sample must be performed to identify the major radioactive constituentspresent and the appropriate organ and total body doses must be calculated to determine compliance with Section 611.331.
- 2) If the MCLs are exceeded, the Agency shall, by a SEP issued pursuant to Section 611.110, require the supplier to conduct additional monitoring to determine the concentration of man-made radioactivity in principal watersheds.
- 3) The Agency shall, pursuant to subsection (j) of this Section, by a SEP issued pursuant to Section 611.110, require suppliers of water utilizingonly groundwater to monitor for man-made radioactivity.
- h) Until December 8, 2003, CWS suppliers must monitor at least every four yearsfollowing the procedure in subsection (g) of this Section.
- i) Until December 8, 2003, the Agency must, by a SEP issued pursuant to Section 611.110, require any CWS supplier utilizing waters contaminated by effluents from nuclear facilities to initiate quarterly monitoring for gross beta particle and iodine-131 radioactivity and annual monitoring for strontium-90 and tritium.
  - 1) Quarterly monitoring for gross beta particle activity must be based on the analysis of monthly samples or the analysis of a composite of three monthly samples. If the gross beta particle activity in a sample exceeds 15 pCi/ℓ, the same or an equivalent sample must be analyzed for strontium 89 and cesium-134. If the gross beta particle activity exceeds 50 pCi/ℓ, an analysis of the sample must be performed to identify the major radioactive constituents present and the appropriate organ and total body doses must be calculated to determine compliance with Section 611.331.
  - 2) For iodine 131, a composite of five consecutive daily samples must be analyzed once each quarter. The Agency shall, by a SEP issued pursuant to Section 611.110, require more frequent monitoring when iodine-131 isidentified in the finished water.
  - 3) The Agency shall, by a SEP issued pursuant to Section 611.110, require annual monitoring for strontium 90 and tritium by means of the analysis of

### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

a composite of four consecutive quarterly samples or analysis of four quarterly samples.

- 4) The Agency shall, by a SEP issued pursuant to Section 611.110, allow the substitution of environmental surveillance data taken in conjunction with a nuclear facility for direct monitoring of manmade radioactivity by the supplier where the Agency determines such data is applicable to the CWS.
- j) Until December 8, 2003, if the average annual MCL for man-made radioactivity set forth in Section 611.331 is exceeded, the CWS supplier must give notice to the Agency and to the public as required by Subpart T. Monitoring at monthlyintervals must be continued until the concentration no longer exceeds the MCL or until a monitoring schedule as a condition to a variance, adjusted standard, or enforcement action becomes effective.

BOARD NOTE: Subsections (a) through (f) derive from 40 CFR 141.26(b) (2003) (2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

# SUBPART U: CONSUMER CONFIDENCE REPORTS

## Section 611.884 Required Additional Health Information

- a) All reports must prominently display the following language: "Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA or Centers for Disease Control and Prevention guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the USEPA Safe Drinking Water Hotline (800-426-4791)."
- b) A supplier that detects arsenic above 0.005 mg/l and up to and including 0.010 mg/l must do the following:

## POLLUTION CONTROL BOARD

### NOTICE OF PROPOSED AMENDMENTS

- The supplier must include in its report a short informational statement about arsenic, using the following language: ""While your drinking water meets USEPA?'s standard for arsenic, it does contain low levels of arsenic. USEPA?'s standard balances the current understanding of arsenic?'s possible health effects against the costs of removing arsenic from drinking water. USEPA continues to research the health effects of low levels of arsenic, which is a naturally-occurring mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.""; or
- 2) The supplier may write its own educational statement, but only in consultation with the Agency.
- c) A supplier that detects nitrate at levels above 5 mg/ $\ell$ , but below the MCL, must do the following:
  - 1) The supplier must include a short informational statement about the impacts of nitrate on children, using the following language: ""Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health care provider ""."
  - 2) The CWS supplier may write its own educational statement, but only in consultation with the Agency.
- d) Every report must include the following lead-specific information:
  - 1) A short informational statement about lead in drinking water and its effects on children. The statement must include the following information:

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. [NAME OF SUPPLIER] is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing

### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to two minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at http://www.epa.gov/safewater/lead.

- 2) A supplier may write its own educational statement, but only in consultation with the Agency.
- e) A CWS supplier that detects TTHM above 0.080 mg/l, but below the MCL in Section 611.312, as an annual average, monitored and calculated under the provisions of former Section 611.680, must include the health effects language prescribed by Appendix A of this Part.
- f) Until January 22, 2006, a CWS supplier that detects arsenic above 0.010 mg/l and up to and including 0.05 mg/l must include the arsenic health effects language prescribed by Appendix A to this Part.

BOARD NOTE: Derived from 40 CFR 141.154 (2007), as amended at 72 Fed. Reg. 57782 (October 10, 2007) (2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

SUBPART W: INITIAL DISTRIBUTION SYSTEM EVALUATIONS

## Section 611.920 General Requirements

a) USEPA has designated that the requirements of this Subpart W constitute National Primary Drinking Water Regulations. The regulations in this Subpart W establish monitoring and other requirements for identifying Subpart Y compliance monitoring locations for determining compliance with maximum contaminant levels for TTHMs and HAA5. The supplier must use an initial distribution system evaluation (IDSE) to determine the locations in its distribution system that are representative of high TTHM and HAA5 concentrations throughout the supplier 's distribution system. An IDSE is used in conjunction with, but separate

### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

from, Subpart I compliance monitoring, to identify and select Subpart Y compliance monitoring locations.

- b) Applicability. A supplier is subject to the requirements of this Subpart W if it fulfills any of the following conditions:
  - 1) The supplier owns or operates a community water system that uses a primary or residual disinfectant other than ultraviolet light;
  - 2) The supplier delivers water that has been treated with a primary or residual disinfectant other than ultraviolet light; or
  - 3) The supplier owns or operates a non-transient non-community water system that serves at least 10,000 people, and it either uses a primary or residual disinfectant other than ultraviolet light, or it delivers water that has been treated with a primary or residual disinfectant other than ultraviolet light.
- c) Schedule. A supplier must comply with the requirements of this Subpart W on the schedule provided in subsection (c)(1) of this Section based on its system type, as set forth in the applicable of subsections (c)(1)(A) through (c)(1)(E) of this Section, subject to the conditions of subsections (c)(1)(F) through (c)(1)(H) of this Section:
  - 1) Compliance dates.
    - A) A supplier that is not part of a combined distribution system, or a supplier that serves the largest population in a combined distribution system, and which serves a population of 100,000 or more persons must is required to have either have submitted its standard monitoring plan, its system-specific study plan, or its 40/30 certification or must have obtained or have been subject to a very small system waiver before October 1, 2006. The supplier must is further complete required to have completed its standard monitoring or system-specific study before September 30, 2008 and submit submitted its IDSE report to the Agency before January 1, 2009.

## POLLUTION CONTROL BOARD

- B) A supplier that is not part of a combined distribution system, or a supplier that serves the largest population in a combined distribution system, and which serves a population of 50,000 to 99,999 persons must is required to have either have submitted its standard monitoring plan, its system-specific study plan, or its 40/30 certification or must have obtained or have been subject to a very small system waiver before April 1, 2007. The supplier must is further complete required to have completed its standard monitoring or system-specific study before March 31, 2009 and submit submitted its IDSE report to the Agency before July 1, 2009.
- C) A supplier that is not part of a combined distribution system, or a supplier that serves the largest population in a combined distribution system, and which serves a population of 10,000 to 49,999 persons must is required to have either submitted its standard monitoring plan, its system-specific study plan, or its 40/30 certification or must obtain obtained or be been subject to a very small system waiver before October 1, 2007. The supplier-must is further complete required to have completed its standard monitoring or system-specific study before September 30, 2009 and submit submitted its IDSE report to the Agency before January 1, 2010.
- D) A supplier that is not part of a combined distribution system, or a supplier that serves the largest population in a combined distribution system, and which serves a population of fewer than 10,000 persons (and which is a CWS) must submit is required to have either submitted its standard monitoring plan, its system-specific study plan, or its 40/30 certification or must obtain obtained or be been subject to a very small system waiver before April 1, 2008. The supplier must is further complete required to have completed its standard monitoring or system-specific study before March 31, 2010 and submit submitted its IDSE report to the Agency before July 1, 2010.
- E) A supplier that is part of a combined distribution system which does not serve the largest population in the combined system, which is a wholesale system supplier or a consecutive system

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

supplier, must submit is required to have either submitted its standard monitoring plan, its system-specific study plan, or its 40/30 certification or must obtain obtained or be been subject to a very small system waiver; must is further complete required to have completed its standard monitoring or system-specific study; and submit submitted its IDSE report to the Agency at the same time as the supplier in the combined system that has the earliest compliance date.

- F) If, within 12 months after the date when submission of the standard monitoring plan, the system-specific study plan, or the 40/30 certification or becoming subject to a very small system waiver is was due, as identified in the applicable of subsections (a)(1) through (a)(4) of this Section, the Agency does did not approve a supplier is plan or notify the supplier that it has had not yet completed its review, the supplier may consider the plan that it submitted as approved. The supplier must implement is required to have implemented that plan, and it must complete is required to have completed standard monitoring or a system-specific study no later than the date when completion of the standard monitoring or system-specific study is due, as identified in the applicable of subsections (a)(1) through (a)(4) of this Section.
- G) The supplier must submit is required to have submitted its 40/30 certification pursuant to Section 611.923 before the date indicated in the applicable of subsections (a)(1) through (a)(4) of this Section.
- H) If, within three months after the due date for submission of the IDSE report identified in this subsection (c)(1) (nine months after this date if the supplier must comply is required to have complied on the schedule in subsection (c)(1)(C) of this Section), the Agency does did not approve the supplier 's IDSE report or notify the supplier that it has had not yet completed its review, the supplier may could consider the report that it submitted to the Agency as approved, and the supplier must implement is required to have implemented the recommended Subpart Y monitoring as required.

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

- 2) For the purpose of determining the applicable compliance schedule in subsection (c)(1) of this Section, the Agency may, by a SEP issued pursuant to Section 611.110, determine that a combined distribution system does not include certain consecutive systems based on such factors as the receipt of water from a wholesale system only on an emergency basis or the receipt of only a small percentage and small volume of water from a wholesale system. The Agency may also determine, by a SEP issued pursuant to Section 611.110, that a combined distribution system does not include certain wholesale systems based on such factors as the delivery of water to a consecutive system only on an emergency basis or the delivery of only a small percentage and small volume of water to a consecutive system.
- d) A supplier must do one of the following: it must conduct standard monitoring that meets the requirements in Section 611.921; it must conduct a system-specific study that meets the requirements in Section 611.922; it must certify to the Agency that it meets the 40/30 certification criteria under Section 611.923; or it must qualify for a very small system waiver under Section 611.924.
  - 1) The supplier must have taken the full complement of routine TTHM and HAA5 compliance samples required of a system that serves the appropriate population and which uses the appropriate source water under Subpart I of this Part (or the supplier must have taken the full complement of reduced TTHM and HAA5 compliance samples required of a system with the supplier "s population and source water under Subpart I of this Part if the supplier meets reduced monitoring criteria under Subpart I of this Part) during the period specified in Section 611.923(a) to meet the 40/ 30 certification criteria in Section 611.923. The supplier must have taken TTHM and HAA5 samples under Sections 611.381 and 611.382 to be eligible for the very small system waiver in Section 611.924.
  - If the supplier has not taken the required samples, the supplier must conduct standard monitoring that meets the requirements in Section 611.921, or a system-specific study that meets the requirements in Section 611.922.
- e) The supplier must use only the analytical methods specified in Section 611.381, or otherwise approved by the Agency for monitoring under this Subpart W, to demonstrate compliance with the requirements of this Subpart W.

POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

f) IDSE results will not be used for the purpose of determining compliance with MCLs in Section 611.312.

BOARD NOTE: Derived from 40 CFR 141.600 (2007) (2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

## Section 611.923 40/30 Certification

- a) Eligibility. A supplier is eligible for 40/30 certification if it had no TTHM or HAA5 monitoring violations under Subpart I of this Part and no individual sample exceeded 0.040 mg/l for TTHM or 0.030 mg/l for HAA5 during an eight consecutive calendar quarter period beginning no earlier than the date specified in the applicable of subsections (a)(1) through (a)(4) of this Section, subject to the limitations of subsection (a)(5) of this Section.
  - If the supplier s 40/30 certification is was due no later than October 1, 2006, then its eligibility for 40/30 certification is was based on eight consecutive calendar quarters of Subpart I compliance monitoring results beginning that began no earlier than January 2004.
  - 2) If the supplier<sup>2</sup>'s 40/30 certification is was due no later than April 1, 2007, then its eligibility for 40/30 certification is was based on eight consecutive calendar quarters of Subpart I compliance monitoring results beginning that began no earlier than January 2004.
  - 3) If the supplier \$\$\$ 40/30 certification is was due no later than October 1, 2007, then its eligibility for 40/30 certification is was based on eight consecutive calendar quarters of Subpart I compliance monitoring results-beginning that began no earlier than January 2005.
  - 4) If the supplier s 40/30 certification is was due no later than April 1, 2008, then its eligibility for 40/30 certification is was based on eight consecutive calendar quarters of Subpart I compliance monitoring results beginning that began no earlier than January 2005.
  - 5) Eligibility for 40/30 certification is based on eight consecutive calendar quarters of Subpart I compliance monitoring results beginning no earlier than the date set forth in the applicable of subsections (a)(1) through (a)(4)

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

of this Section, unless the supplier is on reduced monitoring under Subpart I of this Part and was not required to monitor during the specified period. If the supplier did not monitor during the specified period, the supplier must base its eligibility on compliance samples taken during the 12 months preceding the specified period.

- b) 40/30 certification.
  - A supplier must certify to the Agency that every individual compliance sample taken under Subpart I of this Part during the applicable of the periods specified in subsection (a) of this Section were no more than 0.040 mg/l for TTHM and 0.030 mg/l for HAA5, and that the supplier has not had any TTHM or HAA5 monitoring violations during the period specified in subsection (a) of this Section.
  - 2) The Agency may require the supplier to submit compliance monitoring results, distribution system schematics, or recommended Subpart Y compliance monitoring locations in addition to the supplier 's certification. If the supplier fails to submit the requested information, the Agency may require standard monitoring under Section 611.921 or a system-specific study under Section 611.922.
  - 3) The Agency may still require standard monitoring under Section 611.921 or a system-specific study under Section 611.922 even if the supplier meets the criteria in subsection (a) of this Section.
  - 4) The supplier must retain a complete copy of its certification submitted under this Section for 10 years after the date that it submitted the supplier 's certification. The supplier must make the certification, all data upon which the certification is based, and any Agency notification available for review by the Agency or the public.

BOARD NOTE: Derived from 40 CFR 141.603 (2006) (2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

SUBPART Y: STAGE 2 DISINFECTION BYPRODUCTS REQUIREMENTS

## Section 611.970 General Requirements

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

- a) General. The requirements of this Subpart Y constitute NPDWRs. The regulations in this Subpart Y establish monitoring and other requirements for achieving compliance with MCLs based on LRAAs for TTHM and HAA5, and for achieving compliance with MRDLs for chlorine and chloramine for certain consecutive systems.
- b) Applicability. A supplier is subject to these requirements if its system is a CWS or a NTNCWS that uses a primary or residual disinfectant other than ultraviolet light or which delivers water that has been treated with a primary or residual disinfectant other than ultraviolet light.
- c) Schedule. A supplier must comply with the requirements in this Subpart Y on the applicable schedule set forth in subsections (c)(1) through (c)(6) of this Section based on the supplier 's system type, subject to the limitations of subsection (b)(7) of this Section.
  - A supplier that is not part of a combined distribution system, or a supplier whose system serves the largest population in a combined system, and whose system serves 100,000 or more persons must comply is required to have complied with the requirements of this Subpart Y before April 1, 2012.
  - 2) A supplier that is not part of a combined distribution system, or a supplier whose system serves the largest population in a combined system, and whose system serves 50,000 to 99,999 persons must comply is required to have complied with the requirements of this Subpart Y before October 1, 2012.
  - 3) A supplier that is not part of a combined distribution system, or a supplier whose system serves the largest population in a combined system, and whose system serves 10,000 to 49,999 persons must comply with the requirements of this Subpart Y before October 1, 2013.
  - 4) A supplier that is not part of a combined distribution system, or a supplier whose system serves the largest population in a combined system, and whose system serves fewer than 10,000 persons must comply with the requirements of this Subpart Y before October 1, 2013 if no

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

Cryptosporidium monitoring is required pursuant to Section 611.1001(a)(4).

- 5) A supplier that is not part of a combined distribution system, or a supplier whose system serves the largest population in a combined system, and whose system serves fewer than 10,000 persons must comply with the requirements of this Subpart Y before October 1, 2014 if Cryptosporidium monitoring is required pursuant to Section 611.1001(a)(4) or (a)(6).
- A supplier whose consecutive system or wholesale system is part of a combined system, other than a supplier that is subject to any of subsections (c)(1) through (c)(4) of this Section, must comply with the requirements of this Subpart Y before the earliest compliance date applicable to any segment of the combined distribution system.
- 7) The Agency must, by a SEP issued pursuant to Section 611.110, grant up to an additional 24 months for compliance with MCLs and operational evaluation levels if it finds that the additional time is needed because the supplier requires capital improvements to comply with an MCL.
- 8) The supplier  $\frac{1}{2}$ s monitoring frequency is specified in Section 611.971(a)(2).
  - A) If a supplier is required to conduct quarterly monitoring, it must begin monitoring in the first full calendar quarter that includes the applicable compliance date set forth in this subsection (c).
  - B) If a supplier is required to conduct monitoring less frequently than quarterly, it must begin monitoring in the calendar month recommended in the IDSE report prepared pursuant to Section 611.921 or Section 611.922 or in the calendar month identified in the Subpart Y monitoring plan developed pursuant to Section 611.972, but in no instance later than 12 months after the applicable compliance date set forth in this subsection (c).
- 9) If a supplier is required to conduct quarterly monitoring, it must make compliance calculations at the end of the fourth calendar quarter that follows the compliance date and at the end of each subsequent quarter (or earlier if the LRAA calculated based on fewer than four quarters of data would cause the MCL to be exceeded regardless of the monitoring results

. '

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

of subsequent quarters). If a supplier is required to conduct monitoring less frequently than quarterly, it must make compliance calculations beginning with the first compliance sample taken after the compliance date.

10) For the purpose of the schedule set forth in this subsection (c), the Agency may, by a SEP issued pursuant to Section 611.110, determine that the combined distribution system does not include certain consecutive systems based on factors such as receipt of water from a wholesale system only on an emergency basis or receipt of only a small percentage and small volume of water from a wholesale system. The Agency may also determine that the combined distribution system does not include certain wholesale systems based on factors such as delivery of water to a consecutive system only on an emergency basis or delivery of only a small percentage and small volume of water to a consecutive system.

BOARD NOTE: The Board found it necessary to deviate from the structure of 40 CFR 141.620(c) when incorporating this subsection (c). Subsections (c)(1) through (c)(4) of this Section correspond with 40 CFR 141.620(c)(1) through (c)(4). Subsections (c)(5) and (c)(6) of this Section correspond with the two segments of 40 CFR 141.620(c)(5). Subsection (c)(7) of this Section corresponds with the footnote to the table in 40 CFR 141.620(c). Subsections (c)(8) through (c)(10) of this Section correspond with 40 CFR 141.620(c)(6) through (c)(8).

- d) Monitoring and compliance.
  - 1) Suppliers required to monitor quarterly. To comply with Subpart Y MCLs in Section 611.312(b)(2), the supplier must calculate LRAAs for TTHM and HAA5 using monitoring results collected under this Subpart Y, and it must determine that each LRAA does not exceed the MCL. If the supplier fails to complete four consecutive quarters of monitoring, it must calculate compliance with the MCL based on the average of the available data from the most recent four quarters. If the supplier takes more than one sample per quarter at a monitoring location, it must average all samples taken in the quarter at that location to determine a quarterly average to be used in the LRAA calculation.
  - 2) Suppliers required to monitor yearly or less frequently. To determine compliance with Subpart Y MCLs in Section 611.312(b)(2), the supplier

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

must determine that each sample taken is less than the MCL. If any sample exceeds the MCL, the supplier must comply with the requirements of Section 611.975. If no sample exceeds the MCL, the sample result for each monitoring location is considered the LRAA for that monitoring location.

e) Violation for failure to monitor. A supplier is in violation of the monitoring requirements for each quarter that a monitoring result would be used in calculating an LRAA if the supplier fails to monitor.

BOARD NOTE: Derived from 40 CFR 141.620 (2006) (2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

## Section 611.974 Additional Requirements for Consecutive Systems

If a supplier has a consecutive system that does not add a disinfectant but which delivers water that has been treated with a primary or residual disinfectant other than ultraviolet light, it must comply with the analytical and monitoring requirements for chlorine and chloramines in Sections 611.381(c) and 611.382(c)(1) and with the compliance requirements in Section 611.383(c)(1) beginning April 1, 2009, unless the supplier is required to comply earlier by the Agency, and the supplier must report monitoring results pursuant to Section 611.384(c).

BOARD NOTE: Derived from 40 CFR 141.624 (2006) (2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_\_)

SUBPART Z: ENHANCED TREATMENT FOR CRYPTOSPORIDIUM

## Section 611.1001 Source Water Monitoring Requirements: Source Water Monitoring

- a) Initial round of source water monitoring. A supplier must conduct the following monitoring on the schedule in subsection (c) of this Section, unless it meets the monitoring exemption criteria in subsection (d) of this Section.
  - 1) A filtered system supplier that serves 10,000 or more people must sample its source water for Cryptosporidium, E. coli, and turbidity at least monthly for 24 months.

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

- 2) An unfiltered system supplier that serves 10,000 or more people must sample its source water for Cryptosporidium at least monthly for 24 months.
- 3) Smaller system suppliers monitoring for E. coli.
  - A) A filtered system supplier that serves fewer than 10,000 people must sample its source water for E. coli at least once every two weeks for 12 months.
  - B) A filtered system supplier that serves fewer than 10,000 people may avoid E. coli monitoring if the system notifies the Agency that it will monitor for Cryptosporidium as described in subsection (a)(4) of this Section. The system must notify the Agency no later than three months prior to the date before which the system is otherwise required to start E. coli monitoring pursuant to Section 611.1001(c).
- 4) Smaller system suppliers monitoring for Cryptosporidium. A filtered system supplier that serves fewer than 10,000 people must sample its source water for Cryptosporidium at least twice per month for 12 months or at least monthly for 24 months if it meets any of the conditions set forth in subsections (a)(4)(A) through (a)(4)(C) of this Section, subject to the limitations of subsection (a)(4)(D) of this Section, based on monitoring conducted pursuant to subsection (a)(3) of this Section.
  - A) For a supplier that uses a lake or reservoir source, the annual mean E. coli concentration is greater than 10 E. coli/100  $m\ell$ .
  - B) For a supplier that uses a flowing stream source, the annual mean E. coli concentration is greater than 50 E. coli/ 100 ml.
  - C) The supplier does not conduct E. coli monitoring as described in subsection (a)(3) of this Section.
  - D) A supplier that uses groundwater under the direct influence of surface water must comply with the requirements of subsection (a)(4) of this Section based on the E. coli level that applies to the nearest surface water body. If no surface water body is nearby, the

• '

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

system must comply based on the requirements that apply to a supplier that uses a lake or reservoir source.

- 5) For a filtered system supplier that serves fewer than 10,000 people, the Agency may, by a SEP issued pursuant to Section 611.110, approve monitoring for an indicator other than E. coli pursuant to subsection (a)(3) of this Section. The Agency may also, by a SEP issued pursuant to Section 611.110, approve an alternative to the E. coli concentration in subsection (a)(4)(A), (a)(4)(B) or (a)(4)(D) of this Section to trigger Cryptosporidium monitoring. This approval by the Agency must be provided to the supplier in writing, and it must include the basis for the Agency's determination that the alternative indicator or trigger level will provide a more accurate identification of whether a system will exceed the Bin 1 Cryptosporidium level set forth in Section 611.1010.
- 6) An unfiltered system supplier that serves fewer than 10,000 people must sample its source water for Cryptosporidium at least twice per month for 12 months or at least monthly for 24 months.
- 7) A supplier may sample more frequently than required by this Section if the sampling frequency is evenly spaced throughout the monitoring period.
- b) Second round of source water monitoring. A supplier must conduct a second round of source water monitoring that meets the requirements for monitoring parameters, frequency, and duration described in subsection (a) of this Section, unless it meets the monitoring exemption criteria in subsection (d) of this Section. The supplier must conduct this monitoring on the schedule set forth in subsection (c) of this Section.
- c) Monitoring schedule. A supplier must begin the monitoring required in subsections (a) and (b) of this Section no later than the month beginning with the applicable date listed in subsections (c)(1) through (c)(5) of this Section.
  - 1) A supplier that serves 100,000 or more persons must begin is required to have begun the first round of source water monitoring no later than the month beginning October 1, 2006, and it must begin the second round of source water monitoring no later than the month beginning April 1, 2015.

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

- 2) A supplier that serves 50,000 to 99,999 persons must begin is required to have begun the first round of source water monitoring no later than the month beginning April 1, 2007, and it must begin the second round of source water monitoring no later than the month beginning October 1, 2015.
- 3) A supplier that serves 10,000 to 49,999 persons must begin is required to have begun the first round of source water monitoring no later than the month beginning April 1, 2008, and it must begin the second round of source water monitoring no later than the month beginning October 1, 2016.
- 4) A supplier that serves fewer than 10,000 persons, that is a filtered system supplier, and which monitors for E. coli-must begin is required to have begun the first round of source water monitoring no later than the month beginning October 1, 2008, and it must begin the second round of source water monitoring no later than the month beginning October 1, 2017.
- 5) A supplier that serves fewer than 10,000 persons, that is an unfiltered system supplier, or that is a filtered system supplier which meets the conditions of subsection (a)(4) of this Section, and which monitors for Cryptosporidium, must begin is required to have begun the first round of source water monitoring no later than the month beginning April 1, 2010, and it must begin the second round of source water monitoring no later than the month beginning no later than the month beginning North Section (a) (4) and it must begin the second round of source water monitoring no later than the month beginning April 1, 2019.
- d) Monitoring avoidance.
  - 1) A filtered system supplier is not required to conduct source water monitoring pursuant to this Subpart Z if the system will provide a total of at least 5.5-log of treatment for Cryptosporidium, equivalent to meeting the treatment requirements of Bin 4 in Section 611.1011.
  - 2) An unfiltered system supplier is not required to conduct source water monitoring pursuant to this Subpart Z if the system will provide a total of at least 3-log Cryptosporidium inactivation, equivalent to meeting the treatment requirements for an unfiltered system supplier with a mean Cryptosporidium concentration of greater than 0.01 oocysts/l in Section 611.1012.

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

- 3) If a supplier chooses to provide the level of treatment set forth in subsection (d)(1) or (d)(2) of this Section, as applicable, rather than start source water monitoring, it must notify the Agency in writing no later than the date on which the system is otherwise required to submit a sampling schedule for monitoring pursuant to Section 611.1002. Alternatively, a supplier may choose to stop sampling at any point after it has initiated monitoring if it notifies the Agency in writing that it will provide this level of treatment. The supplier must install and operate technologies to provide this level of treatment before the applicable treatment compliance date set forth in Section 611.1013.
- e) Plants operating only part of the year. A supplier that has a Subpart B plant that operates for only part of the year must conduct source water monitoring in accordance with this Subpart Z, but with the following modifications:
  - The supplier must sample its source water only during the months that the plant operates, unless the Agency, by a SEP issued pursuant to Section 611.110, specifies another monitoring period based on plant operating practices.
  - 2) A supplier with plants that operate less than six months per year and which monitors for Cryptosporidium must collect at least six Cryptosporidium samples per year during each of two years of monitoring. Samples must be evenly spaced throughout the period during which the plant operates.
- f) New sources and new systems.
  - 1) New sources. A supplier that begins using a new source of surface water or groundwater under the direct influence of surface water after the supplier is required to begin monitoring pursuant to subsection (c) of this Section must monitor the new source on a schedule that the Agency has approved by a SEP issued pursuant to Section 611.110. Source water monitoring must meet the requirements of this Subpart Z. The supplier must also meet the bin classification and Cryptosporidium treatment requirements of Sections 611.1010 and 611.1011 or Section 611.1012, as applicable, for the new source on a schedule that the Agency has approved by a SEP issued pursuant to Section 611.110.

## POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

- 2) The requirements of Section 611.1001(f) apply to a Subpart B system supplier that begins operation after the applicable monitoring start date set forth in subsection (c) of this Section.
- 3) The supplier must begin a second round of source water monitoring no later than six years following initial bin classification pursuant to Section 611.1010 or determination of the mean Cryptosporidium level pursuant to Section 611.1012.
- g) Failure to collect any source water sample required under this Section in accordance with the sampling schedule, sampling location, analytical method, approved laboratory, and reporting requirements of Sections 611.1002 through 611.1006 is a monitoring violation.
- h) Grandfathering monitoring data. A supplier may use (grandfather) monitoring data collected prior to the applicable monitoring start date in subsection (c) of this Section to meet the initial source water monitoring requirements in subsection (a) of this Section. Grandfathered data may substitute for an equivalent number of months at the end of the monitoring period. All data submitted pursuant to this subsection must meet the requirements set forth in Section 611.1007.

BOARD NOTE: Derived from 40 CFR 141.701 (2006) (2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_\_)

## Section 611.1004 Source Water Monitoring Requirements: Analytical Methods

- a) Cryptosporidium. A supplier must analyze for Cryptosporidium using USEPA OGWDW Methods, Method 1623 (05), 1623.1, or USEPA OGWDW Methods, Method 1622 (05), each incorporated by reference in Section 611.102, or alternative methods approved by the Agency pursuant to Section 611.480.
  - 1) The supplier must analyze at least a 10  $\ell$  sample or a packed pellet volume of at least 2 m $\ell$  as generated by the methods listed in subsection (a) of this Section. A supplier unable to process a 10  $\ell$  sample must analyze as much sample volume as can be filtered by two filters approved by USEPA for the methods listed in subsection (a) of this Section, up to a packed pellet volume of at least 2 m $\ell$ .

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

- 2) Matrix spike (MS) samples.
  - A) MS samples, as required by the methods in subsection (a) of this Section, must be spiked and filtered by a laboratory approved for Cryptosporidium analysis pursuant to Section 611.1005.
  - B) If the volume of the MS sample is greater than 10  $\ell$ , the supplier may filter all but 10  $\ell$  of the MS sample in the field, and ship the filtered sample and the remaining 10  $\ell$  of source water to the laboratory. In this case, the laboratory must spike the remaining 10  $\ell$  of water and filter it through the filter used to collect the balance of the sample in the field.
- 3) Flow cytometer-counted spiking suspensions must be used for MS samples and ongoing precision and recovery samples.
- b) E. coli. A supplier must use methods for enumeration of E. coli in source water approved in 40 CFR 136.3(a), incorporated by reference in Section 611.102, or alternative methods approved by the Agency pursuant to Section 611.480.
  - The time from sample collection to initiation of analysis may not exceed 30 hours, unless the supplier meets the condition of subsection (b)(2) of this Section.
  - 2) The Agency may, by a SEP issued pursuant to Section 611.110, approve on a case-by-case basis the holding of an E. coli sample for up to 48 hours between sample collection and initiation of analysis if it determines that analyzing an E. coli sample within 30 hours is not feasible. E. coli samples held between 30 to 48 hours must be analyzed by the Autoanalysis Colilert System reagent version of Standard Methods, 18<sup>th</sup>, 19<sup>th</sup>, or 20<sup>th</sup> ed., Method 9223 B, as listed in 40 CFR 136.3(a), incorporated by reference in Section 611.102.
  - 3) A supplier must maintain the temperature of its samples between 0°C and 10°C during storage and transit to the laboratory.
  - 4) The supplier may use the membrane filtration, two-step procedure described in Standard Methods, 20<sup>th</sup> ed., Method 9222 D and G, incorporated by reference in Section 611.102.

## POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

BOARD NOTE: On June 3, 2008 (at 73 Fed. Reg. 31616), USEPA added appendix A to subpart C of 40 CFR 141, which authorized alternative methods to those listed for E. coli by multiple-tube technique at corresponding 40 CFR 141.402(c)(2) to allow the use of Standard Methods for the Examination of Water and Wastewater, 20<sup>th</sup> ed., Method 9222 D and G.

c) Turbidity. A supplier must use methods for turbidity measurement approved in Section 611.531(a).

BOARD NOTE: Derived from 40 CFR 141.704 and appendix A to 40 CFR 141 (2010) (2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

# Section 611.1012 Treatment Technique Requirements: Unfiltered System Cryptosporidium Treatment Requirements

- a) Determination of the mean Cryptosporidium level.
  - Following completion of the initial source water monitoring required by Section 611.1001(a), an unfiltered system supplier must calculate is required to have calculated the arithmetic mean of all Cryptosporidium sample concentrations reported pursuant to Section 611.1001(a). The supplier must report is required to have reported this value to the Agency for approval no later than six months after the month the supplier is required to complete have completed initial source water monitoring based on the applicable schedule set forth in Section 611.1001(c).
  - 2) Following completion of the second round of source water monitoring required by Section 611.1001(b), an unfiltered system supplier must calculate the arithmetic mean of all Cryptosporidium sample concentrations reported pursuant to Section 611.1001(b). The supplier must report this value to the Agency for approval no later than six months after the month the supplier is required to complete the second round of source water monitoring based on the applicable schedule set forth in Section 611.1001(c).

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

- 3) If the monthly Cryptosporidium sampling frequency varies, a supplier must first calculate a monthly average for each month of monitoring. The supplier must then use these monthly average concentrations, rather than individual sample concentrations, in the calculation of the mean Cryptosporidium level in subsection (a)(1) or (a)(2) of this Section.
- 4) The report to the Agency of the mean Cryptosporidium levels calculated pursuant to subsections (a)(1) and (a)(2) of this Section must include a summary of the source water monitoring data used for the calculation.
- 5) A failure to comply with the conditions of subsection (a) of this Section is a violation of the treatment technique requirement.
- b) Cryptosporidium inactivation requirements. An unfiltered system supplier must provide the level of inactivation for Cryptosporidium specified in this subsection, based on its mean Cryptosporidium levels, as determined pursuant to subsection (a) of this Section and according to the applicable schedule set forth in Section 611.1013.
  - 1) An unfiltered system supplier with a mean Cryptosporidium level of 0.01 oocysts/ $\ell$  or less must provide at least 2-log Cryptosporidium inactivation.
  - 2) An unfiltered system supplier with a mean Cryptosporidium level of greater than 0.01 oocysts/ $\ell$  must provide at least 3-log Cryptosporidium inactivation.
- c) Inactivation treatment technology requirements. An unfiltered system supplier must use chlorine dioxide, ozone, or UV, as described in Section 611.1020, to meet the Cryptosporidium inactivation requirements of this Section.
  - 1) A supplier that uses chlorine dioxide or ozone and fails to achieve the Cryptosporidium inactivation required in subsection (b) of this Section on more than one day in the calendar month is in violation of the treatment technique requirement.
  - 2) A supplier that uses UV light and fails to achieve the Cryptosporidium inactivation required in subsection (b) of this Section by meeting the criteria in Section 611.1020(d)(3)(B) is in violation of the treatment technique requirement.

# POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

d) Use of two disinfectants. An unfiltered system supplier must meet the combined Cryptosporidium inactivation requirements of this Section and Giardia lamblia and virus inactivation requirements of Section 611.241 using a minimum of two disinfectants, and each of two disinfectants must separately achieve the total inactivation required for any of Cryptosporidium, Giardia lamblia, or viruses.

BOARD NOTE: Derived from 40 CFR 141.712-(2006) (2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

# Section 611.1013 Treatment Technique Requirements: Schedule for Compliance with Cryptosporidium Treatment Requirements

- a) Following initial bin classification pursuant to Section 611.1010(c), a filtered system supplier must provide the level of treatment for Cryptosporidium required by Section 611.1011 according to the applicable schedule set forth in subsection (c) of this Section.
- b) Following initial determination of the mean Cryptosporidium level pursuant to Section 611.1012(a)(1), an unfiltered system supplier must provide the level of treatment for Cryptosporidium required by Section 611.1012 according to the applicable schedule set forth in subsection (c) of this Section.
- c) Cryptosporidium treatment compliance dates.
  - A supplier that serves 100,000 or more persons must comply is required to have complied with Cryptosporidium treatment requirements before April 1, 2012.
  - 2) A supplier that serves 50,000 to 99,999 persons must comply is required to have complied with Cryptosporidium treatment requirements before October 1, 2012.
  - 3) A supplier that serves 10,000 to 49,999 persons must comply with Cryptosporidium treatment requirements before October 1, 2013.
  - 4) A supplier that serves fewer than 10,000 persons must comply with Cryptosporidium treatment requirements before October 1, 2014.

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

- 5) The Agency may, by a SEP issued pursuant to Section 611.110, allow up to an additional two years from the applicable date set forth in this subsection (c) for complying with the treatment requirement if it determines that the additional time is necessary for the supplier to make capital improvements to implement the treatment.
- d) If the bin classification for a filtered system supplier changes following the second round of source water monitoring, as determined pursuant to Section 611.1010(d), the supplier must provide the level of treatment for Cryptosporidium required by Section 611.1011 on a schedule approved by the Agency by a SEP issued pursuant to Section 611.110.
- e) If the mean Cryptosporidium level for an unfiltered system supplier changes following the second round of monitoring, as determined pursuant to Section 611.1012(a)(2), and if the supplier must provide a different level of Cryptosporidium treatment pursuant to Section 611.1012 due to this change, the supplier must meet this treatment requirement on a schedule approved by the Agency by a SEP issued pursuant to Section 611.110.

BOARD NOTE: Derived from 40 CFR 141.713 (2006) (2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

## Section 611.1014 Treatment Technique Requirements: Requirements for Uncovered Finished Water Storage Facilities

- a) A supplier that uses uncovered finished water storage facilities must comply with the conditions of this Section.
- b) A supplier must notify is required to have notified the Agency in writing of the use of each uncovered finished water storage facility no later than April 1, 2008.
- c) A supplier must meet is required to have met either of the following conditions for each uncovered finished water storage facility, or it must be is required to have been in compliance with an Agency-approved schedule to meet these conditions, no later than April 1, 2009:
  - 1) The supplier must cover any uncovered finished water storage facility; or

POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

- 2) The supplier must treat the discharge from the uncovered finished water storage facility to the distribution system to achieve inactivation or removal of at least 4-log virus, 3-log Giardia lamblia, and 2-log Cryptosporidium using a protocol approved by the Agency.
- d) A failure to comply with the requirements of this Section is a violation of the treatment technique requirement.

BOARD NOTE: Derived from 40 CFR 141.714 (2006) (2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

# POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

### Section 611. Appendix 611. APPENDIX A Regulated Contaminants

Microbiological contaminants.

Contaminant (units): Total Coliform Bacteria

Traditional MCL in mg/ $\ell$ : MCL: (a supplier that collects 40 or more samples/month) five percent or fewer of monthly samples are positive; (systems that collect fewer than 40 samples/month) one or fewer positive monthly samples.

To convert for CCR, multiply by: = -

MCL in CCR units: MCL: (a supplier that collects 40 or more samples/month) five percent or fewer of monthly samples are positive; (a supplier that collects fewer than 40 samples/month) one or fewer positive monthly samples.

MCLG: 0

Major sources in drinking water: Naturally present in the environment.

Health effects language: Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

Contaminant (units): Fecal coliform and E. coli Traditional MCL in mg/l: 0 To convert for CCR, multiply by: =---MCL in CCR units: 0

MCLG: 0

Major sources in drinking water: Human and animal fecal waste.

Health effects language: Fecal coliforms and E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely-compromised immune systems.

Contaminant (units): Fecal Indicators (enterococci or coliphage). Traditional MCL in mg/l: TT. To convert for CCR, multiply by: \_\_\_\_ MCL in CCR units: TT. MCLG: N/A Major sources in drinking water: Human and animal fecal waste.

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

Health effects language: Fecal indicators are microbes whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term health effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.

Contaminant (units): Total organic carbon (ppm) Traditional MCL in mg/l: TT To convert for CCR, multiply by: \_\_\_\_ MCL in CCR units: TT MCLG: N/A Major sources in drinking water: Naturally present in the environment. Health effects language: Total organic carbon (TOC) has no health effects. However, total organic carbon provides a medium for the formation of disinfection byproducts. These byproducts include trihalomethanes (THMs) and

haloacetic acids (HAAs). Drinking water containing these byproducts in excess of the MCL may lead to adverse health effects, liver or kidney problems, or nervous system effects, and may lead to an increased risk of getting cancer.

Contaminant (units): Turbidity (NTU) Traditional MCL in mg/l: TT To convert for CCR, multiply by: \_\_\_\_\_ MCL in CCR units: TT MCLG: N/A Major sources in drinking water: Soil runoff. Health effects language: Turbidity has no hea

Health effects language: Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

Radioactive contaminants.

Contaminant (units): Beta/photon emitters (mrem/yr) Traditional MCL in mg/l: 4 mrem/yr To convert for CCR, multiply by: ----MCL in CCR units: 4 MCLG: 0 Major sources in drinking water: Decay of natural and man-made deposits.

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

Health effects language: Certain minerals are radioactive and may emit forms of radiation known as photons and beta radiation. Some people who drink water containing beta particle and photon radioactivity in excess of the MCL over many years may have an increased risk of getting cancer.

Contaminant (units): Alpha emitters (pCi/l)
Traditional MCL in mg/l: 15 pCi/l
To convert for CCR, multiply by: \_\_\_\_
MCL in CCR units: 15
MCLG: 0
Major sources in drinking water: Erosion of natural deposits.
Health effects language: Certain minerals are radioactive and may emit a form of radiation known as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer.

Contaminant (units): Combined radium (pCi/l) Traditional MCL in mg/l: 5 pCi/l To convert for CCR, multiply by: \_\_\_\_\_ MCL in CCR units: 5 MCLG: 0 Major sources in drinking water: Erosion of natural deposits. Health effects language: Some people who drink water containing radium-226 or \_228 in excess of the MCL over many years may have an increased risk of getting cancer.

Contaminant (units): Uranium (#gug/l)
Traditional MCL in mg/l: 30 µgug/l
To convert for CCR, multiply by: = MCL in CCR units: 30
MCLG: 0
Major sources in drinking water: Erosion of natural deposits.
Health effects language: Some people who drink water containing uranium in excess of the MCL over many years may have an increased risk of getting cancer and kidney

Inorganic contaminants.

toxicity.

Contaminant (units): Antimony (ppb) Traditional MCL in mg/l: 0.006

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

To convert for CCR, multiply by: 1000 MCL in CCR units: 6 MCLG: 6

Major sources in drinking water: Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder.

Health effects language: Some people who drink water containing antimony well in excess of the MCL over many years could experience increases in blood cholesterol and decreases in blood sugar.

Contaminant (units): Arsenic (ppb)

Traditional MCL in mg/l: 0.05 until January 23, 2006 or 0.010 effective January 23, 2006

To convert for CCR, multiply by: 1000

MCL in CCR units: 50

MCLG: 0 (effective January 26, 2006)

Major sources in drinking water: Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes.

Health effects language: Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

Contaminant (units): Asbestos (MFL)

Traditional MCL in mg/l: 7 MFL

To convert for CCR, multiply by:  $\equiv$  -

MCL in CCR units: 7

MCLG: 7

Major sources in drinking water: Decay of asbestos cement water mains; erosion of natural deposits.

Health effects language: Some people who drink water containing asbestos in excess of the MCL over many years may have an increased risk of developing benign intestinal polyps.

Contaminant (units): Barium (ppm) Traditional MCL in mg/l: 2 To convert for CCR, multiply by: =-MCL in CCR units: 2 MCLG: 2 Major sources in drinking water: Discharge of drilling wastes; discharge from metal

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

refineries; erosion of natural deposits.

Health effects language: Some people who drink water containing barium in excess of the MCL over many years could experience an increase in their blood pressure.

Contaminant (units): Beryllium (ppb) Traditional MCL in mg/l: 0.004 To convert for CCR, multiply by: 1000 MCL in CCR units: 4 MCLG: 4 Major sources in drinking water: Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries. Health effects language: Some people who drink water containing beryllium well in excess of the MCL over many years could develop intestinal lesions. Contaminant (units): Bromate (ppb) Traditional MCL in mg/l: 0.010 To convert for CCR, multiply by: 1000 MCL in CCR units: 10 MCLG: 0 Major sources in drinking water: By-product of drinking water disinfection. Health effects language: Some people who drink water containing bromate in excess of the MCL over many years may have an increased risk of getting cancer.

Contaminant (units): Cadmium (ppb) Traditional MCL in mg/l: 0.005 To convert for CCR, multiply by: 1000 MCL in CCR units: 5 MCLG: 5 Major sources in drinking water: Corrosion of galvanized pipes; erosion of natural

deposits; discharge from metal refineries; runoff from waste batteries and paints. Health effects language: Some people who drink water containing cadmium in excess of

the MCL over many years could experience kidney damage.

Contaminant (units): Chloramines (ppm) Traditional MCL in mg/l: MRDL=4 To convert for CCR, multiply by: ----MCL in CCR units: MRDL=4 MCLG: MRDLG=4 Major sources in drinking water: Water additive used to control microbes.

## POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

Health effects language: Some people who drink water containing chloramines well in excess of the MRDL could experience irritating effects to their eyes and nose. Some people who drink water containing chloramines well in excess of the MRDL could experience stomach discomfort or anemia.

Contaminant (units): Chlorine (ppm) Traditional MCL in mg/l: MRDL=4 To convert for CCR, multiply by: --= MCL in CCR units: MRDL=4 MCLG: MRDLG=4 Major sources in drinking water: Wate

Major sources in drinking water: Water additive used to control microbes.

Health effects language: Some people who drink water containing chlorine well in excess of the MRDL could experience irritating effects to their eyes and nose. Some people who drink water containing chlorine well in excess of the MRDL could experience stomach discomfort.

Contaminant (units): Chlorine dioxide (ppb) Traditional MCL in mg/l: MRDL=800 To convert for CCR, multiply by: 1000 MCL in CCR units: MRDL=800 MCLG: MRDLG=800 Major sources in drinking water: Water additive used to control microbes.

Health effects language: Some infants and young children who drink water containing chlorine dioxide well in excess of the MRDL could experience nervous system effects. Similar effects may occur in fetuses of pregnant women who drink water containing chlorine dioxide in excess of the MRDL. Some people may experience anemia.

Contaminant (units): Chlorite (ppm) Traditional MCL in mg/l: MRDL=1 To convert for CCR, multiply by: ----MCL in CCR units: MRDL=1 MCLG: MRDLG=0.8

Major sources in drinking water: By-product of drinking water disinfection.

Health effects language: Some infants and young children who drink water containing chlorite well in excess of the MCL could experience nervous system effects. Similar effects may occur in fetuses of pregnant women who drink water containing chlorite in excess of the MCL. Some people may experience anemia.

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

Contaminant (units): Chromium (ppb)

Traditional MCL in mg/l: 0.1

To convert for CCR, multiply by: 1000

MCL in CCR units: 100

MCLG: 100

Major sources in drinking water: Discharge from steel and pulp mills; erosion of natural deposits.

Health effects language: Some people who use water containing chromium well in excess of the MCL over many years could experience allergic dermatitis.

Contaminant (units): Copper (ppm)

Traditional MCL in mg/l: AL=1.3

To convert for CCR, multiply by: = --

MCL in CCR units: AL=1.3

MCLG: 1.3

Major sources in drinking water: Corrosion of household plumbing systems; erosion of natural deposits.

Health effects language: Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.

Contaminant (units): Cyanide (ppb)

Traditional MCL in mg/l: 0.2

To convert for CCR, multiply by: 1000

MCL in CCR units: 200

MCLG: 200

Major sources in drinking water: Discharge from steel/metal factories; discharge from plastic and fertilizer factories.

Health effects language: Some people who drink water containing cyanide well in excess of the MCL over many years could experience nerve damage or problems with their thyroid.

Contaminant (units): Fluoride (ppm) Traditional MCL in mg/l: 4 To convert for CCR, multiply by: =-MCL in CCR units: 4 MCLG: 4

## POLLUTION CONTROL BOARD

### NOTICE OF PROPOSED AMENDMENTS

Major sources in drinking water: Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.

Health effects language: Some people who drink water containing fluoride in excess of the MCL over many years could get bone disease, including pain and tenderness of the bones. Fluoride in drinking water at half the MCL or more may cause mottling of children is teeth, usually in children less than nine years old. Mottling, also known as dental fluorosis, may include brown staining or pitting of the teeth, and occurs only in developing teeth before they erupt from the gums.

Contaminant (units): Lead (ppb)

Traditional MCL in mg/*l*: AL=0.015

To convert for CCR, multiply by: 1000

MCL in CCR units: AL=15

MCLG: 0

Major sources in drinking water: Corrosion of household plumbing systems; erosion of natural deposits.

Health effects language: Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

Contaminant (units): Mercury (inorganic) (ppb)

Traditional MCL in mg/*l*: 0.002

To convert for CCR, multiply by: 1000

MCL in CCR units: 2

MCLG: 2

Major sources in drinking water: Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland.

Health effects language: Some people who drink water containing inorganic mercury well in excess of the MCL over many years could experience kidney damage.

Contaminant (units): Nitrate (ppm) Traditional MCL in mg/ $\ell$ : 10 To convert for CCR, multiply by: = -MCL in CCR units: 10

MCLG: 10

Major sources in drinking water: Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

Health effects language: Infants below the age of six months who drink water containing nitrate in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue baby syndrome.

Contaminant (units): Nitrite (ppm) Traditional MCL in mg/l: 1 To convert for CCR, multiply by: =-MCL in CCR units: 1 MCLG: 1

Major sources in drinking water: Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.

Health effects language: Infants below the age of six months who drink water containing nitrite in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue baby syndrome.

Contaminant (units): Selenium (ppb) Traditional MCL in mg/l: 0.05

To convert for CCR, multiply by: 1000

MCL in CCR units: 50

MCLG: 50

- Major sources in drinking water: Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines.
- Health effects language: Selenium is an essential nutrient. However, some people who drink water containing selenium in excess of the MCL over many years could experience hair or fingernail losses, numbress in fingers or toes, or problems with their circulation.

Contaminant (units): Thallium (ppb) Traditional MCL in mg/l: 0.002 To convert for CCR, multiply by: 1000 MCL in CCR units: 2

MCLG: 0.5

- Major sources in drinking water: Leaching from ore-processing sites; discharge from electronics, glass, and drug factories.
- Health effects language: Some people who drink water containing thallium in excess of the MCL over many years could experience hair loss, changes in their blood, or problems with their kidneys, intestines, or liver.

Synthetic organic contaminants including pesticides and herbicides.

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

Contaminant (units): 2,4-D (ppb)
Traditional MCL in mg/l: 0.07
To convert for CCR, multiply by: 1000
MCL in CCR units: 70
MCLG: 70
Major sources in drinking water: Runoff from herbicide used on row crops.
Health effects language: Some people who drink water containing the weed killer 2,4-D well in excess of the MCL over many years could experience problems with their kidneys, liver, or adrenal glands.

Contaminant (units): 2,4,5-TP (silvex) (ppb)

Traditional MCL in mg/l: 0.05

To convert for CCR, multiply by: 1000

MCL in CCR units: 50

MCLG: 50

Major sources in drinking water: Residue of banned herbicide.

Health effects language: Some people who drink water containing silvex in excess of the MCL over many years could experience liver problems.

Contaminant (units): Acrylamide Traditional MCL in mg/ $\ell$ : TT To convert for CCR, multiply by: = -MCL in CCR units: TT MCLG: 0

Major sources in drinking water: Added to water during sewage/wastewater treatment. Health effects language: Some people who drink water containing high levels of acrylamide over a long period of time could have problems with their nervous system

or blood, and may have an increased risk of getting cancer.

Contaminant (units): Alachlor (ppb) Traditional MCL in mg/l: 0.002 To convert for CCR, multiply by: 1000 MCL in CCR units: 2 MCLG: 0

Major sources in drinking water: Runoff from herbicide used on row crops.

Health effects language: Some people who drink water containing alachlor in excess of the MCL over many years could have problems with their eyes, liver, kidneys, or spleen, or experience anemia, and may have an increased risk of getting cancer.

## POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

Contaminant (units): Atrazine (ppb) Traditional MCL in mg/l: 0.003 To convert for CCR, multiply by: 1000 MCL in CCR units: 3 MCLG: 3 Major sources in drinking water: Runoff from herbicide used on row crops. Health effects language: Some people who drink water containing atrazine well in excess of the MCL over many years could experience problems with their cardiovascular system or reproductive difficulties. Contaminant (units): Benzo(a)pyrene (PAH) (nanograms/l) Traditional MCL in mg/l: 0.0002 To convert for CCR, multiply by: 1,000,000 MCL in CCR units: 200 MCLG: 0 Major sources in drinking water: Leaching from linings of water storage tanks and distribution lines. Health effects language: Some people who drink water containing benzo(a)pyrene in excess of the MCL over many years may experience reproductive difficulties and may have an increased risk of getting cancer. Contaminant (units): Carbofuran (ppb) Traditional MCL in mg/l: 0.04 To convert for CCR, multiply by: 1000 MCL in CCR units: 40 MCLG: 40 Major sources in drinking water: Leaching of soil furnigant used on rice and alfalfa.

Health effects language: Some people who drink water containing carbofuran in excess of the MCL over many years could experience problems with their blood, or nervous or reproductive systems.

Contaminant (units): Chlordane (ppb) Traditional MCL in mg/l: 0.002 To convert for CCR, multiply by: 1000 MCL in CCR units: 2 MCLG: 0 Major sources in drinking water: Residue of banned termiticide. Health effects language: Some people who drink water containing chlordane in excess of

### POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

the MCL over many years could experience problems with their liver or nervous system, and may have an increased risk of getting cancer.

Contaminant (units): Dalapon (ppb) Traditional MCL in mg/l: 0.2 To convert for CCR, multiply by: 1000 MCL in CCR units: 200 MCLG: 200 Major sources in drinking water: Runoff from herbicide used on rights of way. Health effects language: Some people who drink water containing dalapon well in excess of the MCL over many years could experience minor kidney changes. Contaminant (units): Di(2-ethylhexyl)adipate (ppb) Traditional MCL in mg/l: 0.4 To convert for CCR, multiply by: 1000 MCL in CCR units: 400 MCLG: 400 Major sources in drinking water: Discharge from chemical factories. Health effects language: Some people who drink water containing di(2-ethylhexyl)adipate well in excess of the MCL over many years could experience toxic effects, such as weight loss, liver enlargement, or possible reproductive difficulties. Contaminant (units): Di(2-ethylhexyl)phthalate (ppb) Traditional MCL in mg/l: 0.006 To convert for CCR, multiply by: 1000 MCL in CCR units: 6 MCLG: 0 Major sources in drinking water: Discharge from rubber and chemical factories. Health effects language: Some people who drink water containing di(2-ethylhexyl)phthalate well in excess of the MCL over many years may have problems with their liver or experience reproductive difficulties, and they may have an increased risk of getting cancer. Contaminant (units): Dibromochloropropane (DBCP) (ppt) Traditional MCL in mg/l: 0.0002 To convert for CCR, multiply by: 1,000,000 MCL in CCR units: 200 MCLG: 0

## POLLUTION CONTROL BOARD

### NOTICE OF PROPOSED AMENDMENTS

Major sources in drinking water: Runoff/leaching from soil fumigant used on soybeans, cotton, pineapples, and orchards.

Health effects language: Some people who drink water containing DBCP in excess of the MCL over many years could experience reproductive problems and may have an increased risk of getting cancer.

Contaminant (units): Dinoseb (ppb)
Traditional MCL in mg/l: 0.007
To convert for CCR, multiply by: 1000
MCL in CCR units: 7
MCLG: 7
Major sources in drinking water: Runoff from herbicide used on soybeans and vegetables.
Health effects language: Some people who drink water containing dinoseb well in excess of the MCL over many years could experience reproductive difficulties.
Contaminant (units): Diquat (ppb)
Traditional MCL in mg/l: 0.02

To convert for CCR, multiply by: 1000

MCL in CCR units: 20

MCLG: 20

Major sources in drinking water: Runoff from herbicide use.

Health effects language: Some people who drink water containing diquat in excess of the MCL over many years could get cataracts.

Contaminant (units): Dioxin (2,3,7,8-TCDD) (ppq) Traditional MCL in mg/ $\ell$ : 0.00000003 To convert for CCR, multiply by: 1,000,000,000 MCL in CCR units: 30

MCLG: 0

Major sources in drinking water: Emissions from waste incineration and other combustion; discharge from chemical factories.

Health effects language: Some people who drink water containing dioxin in excess of the MCL over many years could experience reproductive difficulties and may have an increased risk of getting cancer.

Contaminant (units): Endothall (ppb) Traditional MCL in mg/ $\ell$ : 0.1 To convert for CCR, multiply by: 1000

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

MCL in CCR units: 100MCLG: 100Major sources in drinking water: Runoff from herbicide use.Health effects language: Some people who drink water containing endothall in excess of the MCL over many years could experience problems with their stomach or intestines.

Contaminant (units): Endrin (ppb)
Traditional MCL in mg/l: 0.002
To convert for CCR, multiply by: 1000
MCL in CCR units: 2
MCLG: 2
Major sources in drinking water: Residue of banned insecticide.
Health effects language: Some people who drink water containing endrin in excess of the MCL over many years could experience liver problems.

Contaminant (units): Epichlorohydrin

Traditional MCL in mg/l: TT

To convert for CCR, multiply by: = -

MCL in CCR units: TT

MCLG: 0

Major sources in drinking water: Discharge from industrial chemical factories; an impurity of some water treatment chemicals.

Health effects language: Some people who drink water containing high levels of epichlorohydrin over a long period of time could experience stomach problems, and may have an increased risk of getting cancer.

Contaminant (units): Ethylene dibromide (ppt) Traditional MCL in mg/l: 0.00005 To convert for CCR, multiply by: 1,000,000 MCL in CCR units: 50 MCLG: 0 Major sources in drinking water: Discharge from petroleum refineries.

Health effects language: Some people who drink water containing ethylene dibromide in excess of the MCL over many years could experience problems with their liver, stomach, reproductive system, or kidneys, and may have an increased risk of getting cancer.

Contaminant (units): Glyphosate (ppb) Traditional MCL in mg/l: 0.7

### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

To convert for CCR, multiply by: 1000 MCL in CCR units: 700 MCLG: 700 Major sources in drinking water: Runoff from herbicide use. Health effects language: Some people who drink water containing glyphosate in excess of the MCL over many years could experience problems with their kidneys or reproductive difficulties.

Contaminant (units): Heptachlor (ppt) Traditional MCL in mg/l: 0.0004 To convert for CCR, multiply by: 1,000,000 MCL in CCR units: 400 MCLG: 0 Major sources in drinking water: Residue of banned pesticide.

Health effects language: Some people who drink water containing heptachlor in excess of the MCL over many years could experience liver damage and may have an increased risk of getting cancer.

Contaminant (units): Heptachlor epoxide (ppt)

Traditional MCL in mg/l: 0.0002

To convert for CCR, multiply by: 1,000,000

MCL in CCR units: 200

MCLG: 0

Major sources in drinking water: Breakdown of heptachlor.

Health effects language: Some people who drink water containing heptachlor epoxide in excess of the MCL over many years could experience liver damage, and may have an increased risk of getting cancer.

Contaminant (units): Hexachlorobenzene (ppb)

Traditional MCL in mg/l: 0.001

To convert for CCR, multiply by: 1000

MCL in CCR units: 1

MCLG: 0

Major sources in drinking water: Discharge from metal refineries and agricultural chemical factories.

Health effects language: Some people who drink water containing

hexachlorobenzene in excess of the MCL over many years could experience problems with their liver or kidneys, or adverse reproductive effects, and may have an increased risk of getting cancer.

## POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

Contaminant (units): Hexachlorocyclopentadiene (ppb) Traditional MCL in mg/l: 0.05 To convert for CCR, multiply by: 1000 MCL in CCR units: 50 MCLG: 50 Major sources in drinking water: Discharge from chemical factories. Health effects language: Some people who drink water containing hexachlorocyclopentadiene well in excess of the MCL over many years could experience problems with their kidneys or stomach. Contaminant (units): Lindane (ppt) Traditional MCL in mg/l: 0.0002 To convert for CCR, multiply by: 1,000,000 MCL in CCR units: 200 MCLG: 200 Major sources in drinking water: Runoff/leaching from insecticide used on cattle, lumber, gardens. Health effects language: Some people who drink water containing lindane in excess of the MCL over many years could experience problems with their kidneys or liver. Contaminant (units): Methoxychlor (ppb) Traditional MCL in mg/l: 0.04 To convert for CCR, multiply by: 1000 MCL in CCR units: 40 MCLG: 40 Major sources in drinking water: Runoff/leaching from insecticide used on fruits, vegetables, alfalfa, livestock. Health effects language: Some people who drink water containing methoxychlor in excess of the MCL over many years could experience reproductive difficulties. Contaminant (units): Oxamyl (vydate) (ppb) Traditional MCL in mg/l: 0.2 To convert for CCR, multiply by: 1000 MCL in CCR units: 200 MCLG: 200 Major sources in drinking water: Runoff/leaching from insecticide used on apples, potatoes and tomatoes. Health effects language: Some people who drink water containing oxamyl in excess of

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

the MCL over many years could experience slight nervous system effects.

Contaminant (units): PCBs (polychlorinated biphenyls) (ppt) Traditional MCL in mg/l: 0.0005 To convert for CCR, multiply by: 1,000,000 MCL in CCR units: 500 MCLG: 0 Major sources in drinking water: Runoff from landfills; discharge of waste chemicals. Health effects language: Some people who drink water containing PCBs in excess of the MCL over many years could experience changes in their skin, problems with their thymus gland, immune deficiencies, or reproductive or nervous system difficulties, and may have an increased risk of getting cancer. Contaminant (units): Pentachlorophenol (ppb) Traditional MCL in mg/l: 0.001 To convert for CCR, multiply by: 1000 MCL in CCR units: 1 MCLG: 0 Major sources in drinking water: Discharge from wood preserving factories. Health effects language: Some people who drink water containing pentachlorophenol in excess of the MCL over many years could experience problems with their liver or kidneys, and may have an increased risk of getting cancer. Contaminant (units): Picloram (ppb) Traditional MCL in mg/l: 0.5 To convert for CCR, multiply by: 1000 MCL in CCR units: 500 MCLG: 500 Major sources in drinking water: Herbicide runoff. Health effects language: Some people who drink water containing picloram in excess of the MCL over many years could experience problems with their liver. Contaminant (units): Simazine (ppb) Traditional MCL in mg/l: 0.004 To convert for CCR, multiply by: 1000 MCL in CCR units: 4 MCLG: 4 Major sources in drinking water: Herbicide runoff. Health effects language: Some people who drink water containing simazine in excess of

## POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

the MCL over many years could experience problems with their blood.

Contaminant (units): Toxaphene (ppb)
Traditional MCL in mg/l: 0.003
To convert for CCR, multiply by: 1000
MCL in CCR units: 3
MCLG: 0
Major sources in drinking water: Runoff/leaching from insecticide used on cotton and cattle.
Health effects language: Some people who drink water containing toxaphene in excess of

Health effects language: Some people who drink water containing toxaphene in excess of the MCL over many years could have problems with their kidneys, liver, or thyroid, and may have an increased risk of getting cancer.

Volatile organic contaminants.

Contaminant (units): Benzene (ppb) Traditional MCL in mg/l: 0.005 To convert for CCR, multiply by: 1000 MCL in CCR units: 5 MCLG: 0 Major sources in drinking water: Discharge from fact

Major sources in drinking water: Discharge from factories; leaching from gas storage tanks and landfills.

Health effects language: Some people who drink water containing benzene in excess of the MCL over many years could experience anemia or a decrease in blood platelets, and may have an increased risk of getting cancer.

Contaminant (units): Carbon tetrachloride (ppb) Traditional MCL in mg/l: 0.005 To convert for CCR, multiply by: 1000 MCL in CCR units: 5 MCLG: 0

Major sources in drinking water: Discharge from chemical plants and other industrial activities.

Health effects language: Some people who drink water containing carbon tetrachloride in excess of the MCL over many years could experience problems with their liver and may have an increased risk of getting cancer.

Contaminant (units): Chlorobenzene (ppb) Traditional MCL in mg/l: 0.1

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

To convert for CCR, multiply by: 1000

MCL in CCR units: 100

MCLG: 100

Major sources in drinking water: Discharge from chemical and agricultural chemical factories.

Health effects language: Some people who drink water containing chlorobenzene in excess of the MCL over many years could experience problems with their liver or kidneys.

Contaminant (units): o-Dichlorobenzene (ppb)

Traditional MCL in mg/l: 0.6

To convert for CCR, multiply by: 1000

MCL in CCR units: 600

MCLG: 600

Major sources in drinking water: Discharge from industrial chemical factories.

Health effects language: Some people who drink water containing o-dichlorobenzene well in excess of the MCL over many years could experience problems with their liver, kidneys, or circulatory systems.

Contaminant (units): p-Dichlorobenzene (ppb)

Traditional MCL in mg/l: 0.075

To convert for CCR, multiply by: 1000

MCL in CCR units: 75

MCLG: 75

Major sources in drinking water: Discharge from industrial chemical factories.

Health effects language: Some people who drink water containing p-dichlorobenzene in excess of the MCL over many years could experience anemia; damage to their liver, kidneys, or spleen; or changes in their blood.

Contaminant (units): 1,2-Dichloroethane (ppb) Traditional MCL in mg/l: 0.005

To convert for CCR, multiply by: 1000

MCL in CCR units: 5

MCLG: 0

Major sources in drinking water: Discharge from industrial chemical factories.

Health effects language: Some people who drink water containing 1,2-dichloroethane in excess of the MCL over many years may have an increased risk of getting cancer.

Contaminant (units): 1,1-Dichloroethylene (ppb)

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

Traditional MCL in mg/l: 0.007
To convert for CCR, multiply by: 1000
MCL in CCR units: 7
MCLG: 7
Major sources in drinking water: Discharge from industrial chemical factories.
Health effects language: Some people who drink water containing 1,1-dichloroethylene in excess of the MCL over many years could experience problems with their liver.

Contaminant (units): cis-1,2-Dichloroethylene (ppb) Traditional MCL in mg/l: 0.07 To convert for CCR, multiply by: 1000 MCL in CCR units: 70 MCLG: 70 Major sources in drinking water: Discharge from industrial chemical factories. Health effects language: Some people who drink water containing cis-1,2-dichloroethylene in excess of the MCL over many years could experience problems with their liver.

Contaminant (units): trans-1,2-Dichloroethylene (ppb) Traditional MCL in mg/l: 0.1 To convert for CCR, multiply by: 1000 MCL in CCR units: 100

MCL III CCK UIIIS.

MCLG: 100

Major sources in drinking water: Discharge from industrial chemical factories. Health effects language: Some people who drink water containing

trans-1,2-dichloroethylene well in excess of the MCL over many years could experience problems with their liver.

Contaminant (units): Dichloromethane (ppb) Traditional MCL in mg/l: 0.005

To convert for CCR, multiply by: 1000

MCL in CCR units: 5

MCLG: 0

Major sources in drinking water: Discharge from pharmaceutical and chemical factories. Health effects language: Some people who drink water containing dichloromethane in

excess of the MCL over many years could have liver problems and may have an increased risk of getting cancer.

Contaminant (units): 1,2-Dichloropropane (ppb)

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

Traditional MCL in mg/l: 0.005
To convert for CCR, multiply by: 1000
MCL in CCR units: 5
MCLG: 0
Major sources in drinking water: Discharge from industrial chemical factories.
Health effects language: Some people who drink water containing 1,2-dichloropropane in excess of the MCL over many years may have an increased risk of getting cancer.

Contaminant (units): Ethylbenzene (ppb) Traditional MCL in mg/l: 0.7 To convert for CCR, multiply by: 1000 MCL in CCR units: 700 MCLG: 700 Major sources in drinking water: Discharge from petroleum refineries. Health effects language: Some people who drink water containing ethylbenzene well in excess of the MCL over many years could experience problems with their liver or kidneys.

Contaminant (units): Haloacetic acids (HAA5) (ppb)
Traditional MCL in mg/l: 0.060
To convert for CCR, multiply by: 1000
MCL in CCR units: 60
MCLG: N/A
Major sources in drinking water: Byproduct of drinking water disinfection.
Health effects language: Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

Contaminant (units): Styrene (ppb)

Traditional MCL in mg/ $\ell$ : 0.1

To convert for CCR, multiply by: 1000

MCL in CCR units: 100

MCLG: 100

- Major sources in drinking water: Discharge from rubber and plastic factories; leaching from landfills.
- Health effects language: Some people who drink water containing styrene well in excess of the MCL over many years could have problems with their liver, kidneys, or circulatory system.

Contaminant (units): Tetrachloroethylene (ppb)

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

Traditional MCL in mg/l: 0.005
To convert for CCR, multiply by: 1000
MCL in CCR units: 5
MCLG: 0
Major sources in drinking water: Discharge from factories and dry cleaners.
Health effects language: Some people who drink water containing tetrachloroethylene in excess of the MCL over many years could have problems with their liver, and may have an increased risk of getting cancer.
Contaminant (units): 1,2,4-Trichlorobenzene (ppb)

Traditional MCL in mg/l: 0.07

To convert for CCR, multiply by: 1000

MCL in CCR units: 70

MCLG: 70

Major sources in drinking water: Discharge from textile-finishing factories.

Health effects language: Some people who drink water containing 1,2,4-trichlorobenzene well in excess of the MCL over many years could experience changes in their adrenal glands.

Contaminant (units): 1,1,1-Trichloroethane (ppb)

Traditional MCL in mg/l: 0.2

To convert for CCR, multiply by: 1000

MCL in CCR units: 200

MCLG: 200

- Major sources in drinking water: Discharge from metal degreasing sites and other factories.
- Health effects language: Some people who drink water containing 1,1,1-trichloroethane in excess of the MCL over many years could experience problems with their liver, nervous system, or circulatory system.

Contaminant (units): 1,1,2-Trichloroethane (ppb)

Traditional MCL in mg/l: 0.005

To convert for CCR, multiply by: 1000

MCL in CCR units: 5

MCLG: 3

Major sources in drinking water: Discharge from industrial chemical factories.

Health effects language: Some people who drink water containing 1,1,2-trichloroethane well in excess of the MCL over many years could have problems with their liver, kidneys, or immune systems.

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

Contaminant (units): Trichloroethylene (ppb) Traditional MCL in mg/l: 0.005 To convert for CCR, multiply by: 1000 MCL in CCR units: 5 MCLG: 0 Major sources in drinking water: Discharge from metal degreasing sites and other factories. Health effects language: Some people who drink water containing trichloroethylene in excess of the MCL over many years could experience problems with their liver and may have an increased risk of getting cancer. Contaminant (units): TTHMs (total trihalomethanes) (ppb) Traditional MCL in mg/l: 0.10/0.080 To convert for CCR, multiply by: 1000 MCL in CCR units: 100/80 MCLG: N/A Major sources in drinking water: Byproduct of drinking water disinfection. Health effects language: Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer. Contaminant (units): Toluene (ppm) Traditional MCL in mg/l: 1 To convert for CCR, multiply by: = --MCL in CCR units: 1 MCLG: 1 Major sources in drinking water: Discharge from petroleum factories. Health effects language: Some people who drink water containing toluene well in excess of the MCL over many years could have problems with their nervous system, kidneys, or liver. Contaminant (units): Vinyl Chloride (ppb) Traditional MCL in mg/l: 0.002 To convert for CCR, multiply by: 1000 MCL in CCR units: 2 MCLG: 0 Major sources in drinking water: Leaching from PVC piping; discharge from plastics factories.

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

Health effects language: Some people who drink water containing vinyl chloride in excess of the MCL over many years may have an increased risk of getting cancer.

Contaminant (units): Xylenes (ppm)
Traditional MCL in mg/l: 10
To convert for CCR, multiply by: - MCL in CCR units: 10
MCLG: 10
Major sources in drinking water: Discharge from petroleum factories; discharge from chemical factories.
Health effects language: Some people who drink water containing xylenes in excess of

the MCL over many years could experience damage to their nervous system.

Key.

Abbreviation	Meaning
AL	action level
MCL	maximum contaminant level
MCLG	maximum contaminant level goal
MFL	million fibers per liter
MRDL	maximum residual disinfectant level
MRDLG	maximum residual disinfectant level goal
mrem/year	millirems per year (a measure of radiation absorbed by
	the body)
N/A	not applicable
NTU	nephelometric turbidity units (a measure of water clarity)
pCi/l	picocuries per liter (a measure of radioactivity)
ppm	parts per million, or milligrams per liter $(mg/\ell)$
ppb	parts per billion, or micrograms per liter ( $\mu g \mu g / \ell$ )
ppt	parts per trillion, or nanograms per liter
ppq	parts per quadrillion, or picograms per liter
TT	treatment technique

BOARD NOTE: Derived from appendix A to subpart O to 40 CFR 141 (2006), as amended at 71 Fed. Reg. 65574 (Nov. 8, 2006) (2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

#### Section 611. Appendix 611. APPENDIX B Percent Inactivation of G. Lamblia Cysts

Table 1.1

CT-99.9 for 99.9 Percent Inactivation of Giardia Lamblia Cysts by Free Chlorine at 0.5° C-or Lower

These CT values achieve greater than a 99.99 percent inactivation of viruses. CT values between the indicated pH values may be determined by linear interpolation. CT values between the indicated temperatures of different tables may be determined by linear interpolation. If no interpolation is used, use the CT 99.9 value at the lower temperature and at the higher pH.

Free		PH					
Residual			<u>≤6.06.57.</u> (	)7. <u>58.08.5</u> ≥	9.0pH	_	
(mg/l)	<u>&lt; 6.0</u>	6.5	7.0	7.5	8.0	8.5	> 9.0
≤ <del>0.41</del>							
≤ 0.4	137	163	195	237	277	329	390
0.6	141	168	200	239	286	342	407
0.8	145	172	205	246	295	354	422
1.0	148	176	210	253	304	365	437
1.2	152	180	215	259	313	376	451
1.4	155	184	221	266	321	387	464
1.6	157	189	226	273	329	397	477
1.8	162	193	231	279	338	407	489
2.0	165	197	236	286	346	417	500
2.2	169	201	242	297	353	426	511
2.4	172	205	247	298	361	435	522
2.6	175	209	252	304	368	444	533
2.8	178	213	257	310	375	452	543
3.0	181	217	261	316	382	460	552

Table 1.2

#### CT-99.9 for 99.9 Percent Inactivation of Giardia Lamblia Cysts by Free Chlorine at 5.0° C

These CT values achieve greater than a 99.99 percent <u>inctivationinactivation</u> of viruses. CT values between the indicated pH values may be determined by linear interpolation. CT values between the indicated temperatures of different tables may be determined by linear interpolation. If no interpolation is used, use the CT 99.9 value at the lower temperature and at the higher pH.

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

Free Residual			<u>≤6.06.57.0</u>	₽ <del>Н</del> 7.58.08.5≥!	9.0pH		
(mg/l)	< 6.0	6.5	7.0	7.5	8.0	8.5	> 9.0
≤ 0.4	97	117	139	166	198	236	279
0.6	100	120	143	171	204	244	291
0.8	103	122	146	175	210	252	301
1.0	105	125	149	179	216	260	312
1.2	107	127	152	183	221	267	320
1.4	109	130	155	187	227	274	329
1.6	111	132	158	192	232	281	337
1.8	114	135	162	196	238	287	345
2.0	116	138	165	200	243	294	353
2.2	118	140	169	204	248	300	361
2.4	120	143	172	209	253	306	368
2.6	122	146	175	213	258	312	375
2.8	124	148	178	217	263	318	382
3.0	126	151	182	221	268	324	369

Table 1.3

CT-99.9 for 99.9 Percent Inactivation of Giardia Lamblia Cysts by Free Chlorine at 10.0° C

These CT values achieve greater than a 99.99 percent inactivation of viruses. CT values between the indicated pH values may be determined by linear interpolation. CT values between the indicated temperatures of different tables may be determined by linear interpolation. If no interpolation is used, use the CT 99.9 value at the lower temperature and at the higher pH.

Free Residual			<u>≤6.06.57.</u>	<del>PH</del> 07.58.08.5	<u>≥9.0pH</u>		
(mg/l)	< 6.0	6.5	7.0	7.5	8.0	8.5	> 9.0
≤0.4	73	88	104	125	149	177	209
0.6	75	90	107	128	153	183	218
0.8	78	92	110	131	158	189	226
1.0	79	94	112	134	162	195	234
1.2	80	95	114	137	166	200	240
1.4	82	98	116	140	170	206	247
1.6	83	99	119	144	174	211	253
1.8	86	101	122	147	179	215	259
2.0	87	104	124	150	182	221	265

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

2.2	89	105	127	153	186	225	271
2.4	90	107	129	157	190	230	276
2.6	92	110	131	160	194	234	281
2.8	93	111	134	163	197	239	287
3.0	95	113	137	166	201	243	292

Table 1.4

CT-99.9 for 99.9 Percent Inactivation of Giardia Lamblia Cysts by Free Chlorine at 15.0° C

These CT values achieve greater than a 99.99 percent inactivation of viruses. CT values between the indicated pH values may be determined by linear interpolation. CT values between the indicated temperatures of different tables may be determined by linear interpolation. If no interpolation is used, use the CT 99.9 value at the lower temperature and at the higher pH.

Free Residual			<u>≤6.06.57.</u>	<del>PH</del> 07.58.08.5	<u>≥9.0pH</u>		
(mg/ℓ)	< 6.0	6.5	7.0	7.5	8.0	8.5	> 9.0
$\leq 0.4$	49	59	70	83	99	118	140
0.6	50	60	72	86	102	122	146
0.8	52	61	73	88	105	126	151
1.0	53	63	75	<del>9</del> 0	108	130	156
1.2	54	64	76	92	111	134	160
1.4	55	65	78	94	114	137	165
1.6	56	66	79	96	116	141	169
1.8	57	68	81	98	119	144	173
2.0	58	69	83	100	122	147	177
2.2	59	70	85	102	124	150	181
2.4	60	72	86	105	127	153	184
2.6	61	73	88	107	129	156	188
2.8	62	74	89	109	132	159	191
3.0	63	76	91	111	134	162	195

Table 1.5

CT-99.9 for 99.9 Percent Inactivation of Giardia Lamblia Cysts by Free Chlorine at 20° C

These CT values achieve greater than a 99.99 percent inactivation of viruses. CT values between the indicated pH values may be determined by linear interpolation. CT values between the

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

indicated temperatures of different tables may be determined by linear interpolation. If no interpolation is used, use the CT 99.9 value at the lower temperature and at the higher pH.

Free Residual			<u>≤6.06.57</u>	<del>PH</del> .07.58.08.5	<u>≥9.0pH</u>		
(mg/l)	<u>&lt; 6.0</u>	6.5	7.0	7.5	8.0	8.5	<u>&gt; 9.0</u>
≤0.4	36	44	52	62	74	89	105
0.6	38	45	54	64	77	92	109
0.8	39	46	55	66	79	95	113
1.0	39	47	56	67	81	98	117
1.2	40	48	57	69	83	100	120
1.4	41	49	58	70	85	103	123
1.6	42	50	59	72	87	105	126
1.8	43	51	61	74	89	108	129
2.0	44	52	62	75	91	110	132
2.2	44	53	63	77	93	113	135
2.4	45	54	65	78	95	115	138
2.6	46	55	66	80	97	117	141
2.8	47	56	67	81	99	119	143
3.0	47	57	68	83	101	122	146

#### Table 1.6

#### CT-99.9 for 99.9 Percent Inactivation of Giardia Lamblia Cysts by Free Chlorine at 25° C and Higher

These CT values achieve greater than a 99.99 percent inactivation of viruses. CT values between the indicated pH values may be determined by linear interpolation. CT values between the indicated temperatures of different tables may be determined by linear interpolation. If no interpolation is used, use the CT 99.9 value at the lower temperature and at the higher pH.

Free Residual	<del>РН</del> <u>≤6.06.57.07.58.08.5≥9.0рН</u>						
(mg/l)	< 6.0	6.5	7.0	7.5	8.0	8.5	> 9.0
≤ 0.4	24	29	35	42	50	59	70
0.6	25	30	36	43	51	61	73
0.8	26	31	37	44	53	63	75
1.0	26	31	37	45	54	65	78
1.2	27	32	38	46	55	67	80

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

1.4	27	33	39	47	57	69	82
1.6	28	33	40	48	58	70	84
1.8	29	34	41	49	60	72	86
2.0	29	35	41	50	61	74	88
2.2	30	35	42	51	62	75	90
2.4	30	36	43	52	63	77	92
2.6	31	37	44	53	65	78	94
2.8	31	37	45	54	66	80	96
3.0	32	38	46	55	67	81	97

Table 2.1

CT-99.9 for 99.9 Percent Inactivation of Giardia Lamblia Cysts by Chlorine Dioxide and Ozone

These CT values achieve greater than a 99.99 percent inactivation of viruses. CT values between the indicated pH values may be determined by linear interpolation. If no interpolation is used, use the  $CT_{99.9}$  value at the lower temperature for determining  $CT_{99.9}$  values between indicated temperatures.

	≤l°C	5° C	10° C	1 <b>5° C</b>	20° C	≥25° C
Chlorine dioxide	63	26	23	19	15	11
Ozone	2.9	1.9	1.4	0.95	0.72	0.48

#### Table 3.1

CT-99.9 for 99.9 Percent Inactivation of Giardia Lamblia Cysts by Chloramines

These values are for pH values of 6 to 9. These CT values may be assumed to achieve greater than a 99.99 percent inactivation of viruses only if chlorine is added and mixed in the water prior to the addition of ammonia. If this condition is not met, the system must demonstrate, based on on-site studies or other information, as approved by the Agency, that the system is achieving at least a 99.99 percent inactivation of viruses. CT values between the indicated temperatures may be determined by linear interpolation. If no interpolation is used, use the  $CT_{99.9}$  value at the lower temperature for determining  $CT_{99.9}$  values between indicated temperatures.

	≤ 1° C	5° C	10° C	15° C	20° C	≥ 25° C
Chloramines	3800	2200	1850	1500	1100	750

BOARD NOTE: Derived from 40 CFR 141.74(b) Tables 1.1 through 3.1 (2002) (201220012).

· ·

.

POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

-)

(Source: Amended Added at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_\_

## POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

## Section 611. Appendix 611. APPENDIX C Common Names of Organic Chemicals

The following common names are used for certain organic chemicals:

Common Name	CAS No.	CAS Name
Aldrin	309-00-2	1,4,5,8-Dimethanonaphthalene, 1,2,3,4,10,10-hexachloro-1,4,4a,5,8,8a-hexahydro -, (1alpha, 4alpha, 4abeta, 5alpha, 8alpha, 8abeta)-
D	75.05.0	Mathema tellesense
Bromoform	75-25-2	Methane, tribromo-
Chlordane	57-74-9	4,7-Methano-1H-indene, 1,2,4,5,6,7,8,8-octachloro-2,3,3a,4,7,7a-hexahydro -
the state of the state of the		
Chloroform	67-66-3	Methane, trichloro-
2,4-D	94-75-7	Acetic acid, 2,4-dichlorophenoxy-
DDT	50-29-3	Benzene, 1,1 <sup>2</sup> -(2, 2, 22,2,2)-trichloroethylidene) bis(4-chloro-
Dieldrin	60-57-1	2,7:3,6-Dimethanonaphth(2,3-b)oxirene, 3,4,5,6,9,9-hexachloro-1a,2,2a,3,6,6a,7,7a-octahy dro-, (1aalpha, 2beta, 2aalpha, 3beta, 6beta, 6aalpha, 7beta, 7aalpha)-
Endrin	72-20-8	2,7:3,6-Dimethanonaphth(2,3-b)oxirene, 3,4,5,6,9,9-hexachloro-1a,2,2a,3,6,6a,7,7a-octahy dro-, (1aalpha, 2beta, 2abeta, 3alpha, 6alpha, 6abeta, 7beta, 7aalpha)-,
Heptachlor	76-44-8	4,7-Methano-1H-indene. 1,4,5,6,7,8,81,4,5,6.7. 8.8-heptachloro-3a,4,7,7a-tetrahydro-
	and the second	
Heptachlor epoxide	1024-57-3	$\frac{2, 52.5}{3, 4, 5, 6, 7, 72.3, 4, 5, 6, 7, 7}$ heptachloro-1a, 1b, 5, $\frac{55.5}{3, 6, 6, 6}$ hexahydro-, (1a alpha, 1b beta, 2

• •

## POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

		alpha, 5 alpha, 5a beta, 6 beta, 6a alpha)-
AL MESSALE ALL ALL		
Lindane	58-89-9	Cyclohexane, 1,2,3,4,5,6-hexachloro-, (1 alpha, 2 alpha, 3 beta, 4 alpha, 5 alpha, 6 beta)-
Methoxychlor	72-43-5	Benzene, 1,1 <sup>2</sup> -(2,2,2-trichloroethylidene)bis(4-methoxy-
Silvex (2,4,5-TP)	93-72-1	Propanoic acid, 2-(2,4,5-trichlorophenoxy)-
Toxaphene	8001-35-2	Toxaphene
TTHM	Total trihalomethanes (See Section 611.101)	

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

## Section 611. Appendix 611. APPENDIX D Defined Substrate Method for the Simultaneous Detection of Total Coliforms and Escherichia Coli from Drinking Water

Autoanalysis Colilert Presence-Absence (AC P-A) Method.

The AC P-A test format must be either a 100 m $\ell$  10-tube most probable number test (one tube positive denoting the presence of total coliforms in that sample) or a single vessel containing sufficient reagent to receive 100 m $\ell$  of sample. The reagent is available from Access Medical Systems, Branford Connecticut.

The AC P-A method must be performed as follows:

- 1. For the 10-tube method, add 10 ml of water sample to each test tube. For the single-vessel method, add 100 ml of water sample to the vessel.
- 2. Dissolve the reagent powder by agitation. (This should produce a colorless solution.)
- 3. Incubate the test tubes or vessel at 35° C for 24 hours.
- 4. Development of yellow during incubation denotes the presence of total coliforms in either the test tube or the vessel.
- 5. Expose each positive (yellow) test tube or vessel to a fluorescent (366 nm) light source. Fluorescence specifically demonstrates the presence of Escherichia coli.

BOARD NOTE: Derived from S. Edberg, M. Allen & D. Smith, ""National Field Evaluation of a Defined Substrate Method for the Simultaneous Detection of Total Coliforms and Escherichia coli from Drinking Water: Comparison with Presence-Absence Techniques," Applied and Environmental Microbiology, vol. 55, pp. 1003-1008, as incorporated by reference in Section 611.102(b) (2004) (2012). This method is for use in conjunction with the requirements of Section 611.526.

(Source: Amended at 37 Ill. Reg, effective)
---

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

# Section 611. Appendix 611. APPENDIX E Mandatory Lead Public Education Information for Community Water Systems

## 1) INTRODUCTION

The United States Environmental Protection Agency (USEPA) and (insert name of water supplier) are concerned about lead in your drinking water. Although most homes have very low levels of lead in their drinking water, some homes in the community have lead levels above the USEPA action level of 15 parts per billion (ppb), or 0.015 milligrams of lead per liter of water (mg/ $\ell$ ). Under Federal law we are required to have a program in place to minimize lead in your drinking water by (insert date when corrosion control will be completed for your system). This program includes corrosion control treatment, source water treatment, and public education. We are also required to replace the portion of each lead service line that we own if the line contributes lead concentrations of more than 15 ppb after we have completed the comprehensive treatment program. If you have any questions about how we are carrying out the requirements of the lead regulation please give us a call at (insert water system<sup>2</sup>)'s phone number). This brochure explains the simple steps you can take to protect you and your family by reducing your exposure to lead in drinking water.

## 2) HEALTH EFFECTS OF LEAD

Lead is a common metal found throughout the environment in lead-based paint; air; soil; household dust; food; certain types of pottery, porcelain, and pewter; and water. Lead can pose a significant risk to your health if too much of it enters your body. Lead builds up in the body over many years and can cause damage to the brain, red blood cells, and kidneys. The greatest risk is to young children and pregnant women. Amounts of lead that won<sup>2</sup>, thurt adults can slow down normal mental and physical development of growing bodies. In addition, a child at play often comes into contact with sources of lead contamination —: like dirt and dust —: that rarely affect an adult. It is important to wash children<sup>2</sup>, shands and toys often, and to try to make sure they only put food in their mouths.

## 3) LEAD IN DRINKING WATER

A) Lead in drinking water, although rarely the sole cause of lead poisoning, can significantly increase a person's total lead exposure, particularly the exposure of infants who drink baby formulas and concentrated juices that are mixed with water. The EPA estimates that drinking water can make up 20 percent or more of a person's total exposure to lead.

## POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

- B) Lead is unusual among drinking water contaminants in that it seldom occurs naturally in water supplies like rivers and lakes. Lead enters drinking water primarily as a result of the corrosion, or wearing away, of materials containing lead in the water distribution system and household plumbing. These materials include lead-based solder used to join copper pipe, brass and chrome plated brass faucets, and in some cases, pipes made of lead that connect your house to the water main (service lines). In 1986, Congress banned the use of lead solder containing greater than 0.2% lead, and restricted the lead content of faucets, pipes and other plumbing materials to 8.0%.
- C) When water stands in lead pipes or plumbing systems containing lead for several hours or more, the lead may dissolve into your drinking water. This means the first water drawn from the tap in the morning, or later in the afternoon after returning from work or school, can contain fairly high levels of lead.

## 4) STEPS YOU CAN TAKE IN THE HOME TO REDUCE EXPOSURE TO LEAD IN DRINKING WATER

- A) Despite our best efforts mentioned earlier to control water corrosivity and remove lead from the water supply, lead levels in some homes or buildings can be high. To find out whether you need to take action in your own home, have your drinking water tested to determine if it contains excessive concentrations of lead. Testing the water is essential because you cannot see, taste, or smell lead in drinking water. Some local laboratories that can provide this service are listed at the end of this booklet. For more information on having your water tested, please call (insert phone number of water system).
- B) If a water test indicates that the drinking water drawn from a tap in your home contains lead above 15 ppb, then you should take the following precautions:
  - i) Let the water run from the tap before using it for drinking or cooking any time the water in a faucet has gone unused for more than six hours. The longer water resides in your home's plumbing the more lead it may contain. Flushing the tap means running the cold water faucet until the water gets noticeably colder, usually about 15-30 seconds. If your house has a lead service line to the water main, you may have to flush the water for a longer time, perhaps one minute, before drinking. Although toilet flushing or showering flushes water through a portion of your home's plumbing system, you still need to flush the water in each faucet before

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

using it for drinking or cooking. Flushing tap water is a simple and inexpensive measure you can take to protect your family?'s health. It usually uses less than one or two gallons of water and costs less than (insert a cost estimate based on flushing two times a day for 30 days) per month. To conserve water, fill a couple of bottles for drinking water after flushing the tap, and whenever possible use the first flush water to wash the dishes or water the plants. If you live in a high-rise building, letting the water flow before using it may not work to lessen your risk from lead. The plumbing systems have more, and sometimes larger pipes than smaller buildings. Ask your landlord for help in locating the source of the lead and for advice on reducing the lead level.

- ii) Try not to cook with or drink water from the hot water tap. Hot water can dissolve more lead more quickly than cold water. If you need hot water, draw water from the cold tap and heat it on the stove.
- iii) Remove loose lead solder and debris from the plumbing materials installed in newly constructed homes, or homes in which the plumbing has recently been replaced, by removing the faucet strainers from all taps and running the water from 3 to 5 minutes. Thereafter, periodically remove the strainers and flush out any debris that has accumulated over time.
- iv) If your copper pipes are joined with lead solder that has been installed illegally since it was banned in 1986, notify the plumber who did the work and request that he or she replace the lead solder with lead-free solder. Lead solder looks dull gray, and when scratched with a key looks shiny. In addition, notify the Illinois Environmental Protection Agency about the violation.
- v) Determine whether or not the service line that connects your home or apartment to the water main is made of lead. The best way to determine if your service line is made of lead is by either hiring a licensed plumber to inspect the line or by contacting the plumbing contractor who installed the line. You can identify the plumbing contractor by checking the city?'s record of building permits which should be maintained in the files of the (insert name of department that issues building permits). A licensed plumber can at the same time check to see if your home?'s plumbing contains lead solder, lead pipes, or pipe fittings that contain lead. The public water system that delivers water to your home should also maintain

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

records of the materials located in the distribution system. If the service line that connects your dwelling to the water main contributes more than 15 ppb to drinking water, after our comprehensive treatment program is in place, we are required to replace the portion of the line that we own. If the line is only partially owned by the (insert name of the city, county, or water system that controls the line), we are required to provide the owner of the privately-owned portion of the line with information on how to replace the privately-owned portion of the service line, and offer to replace that portion of the line at the owner"s expense. If we replace only the portion of the line that we own, we also are required to notify you in advance and provide you with information on the steps that you can take to minimize exposure to any temporary increase in lead levels which may result from the partial replacement, to take a follow-up sample at our expense from the line within 72 hours after the partial replacement, and to mail or otherwise provide you with the results of that sample within three business days after receiving the results. Acceptable replacement alternatives include copper, steel, iron, and plastic pipes.

- vi) Have an electrician check your wiring. If grounding wires from the electrical system are attached to your pipes, corrosion may be greater.
   Check with a licensed electrician or your local electrical code to determine if your wiring can be grounded elsewhere. DO NOT attempt to change the wiring yourself because improper grounding can cause electrical shock and fire hazards.
- C) The steps described above will reduce the lead concentrations in your drinking water. However, if a water test indicates that the drinking water coming from your tap contains lead concentrations in excess of 15 ppb after flushing, or after we have completed our actions to minimize lead levels, then you may want to take the following additional measures:
  - i) Purchase or lease a home treatment device. Home treatment devices are limited in that each unit treats only the water that flows from the faucet to which it is connected, and all of the devices require periodic maintenance and replacement. Devices such as reverse osmosis systems or distillers can effectively remove lead from your drinking water. Some activated carbon filters may reduce lead levels at the tap, however all lead reduction claims should be investigated. Be sure to check the actual performance of a specific home treatment device before and after installing the unit.

## POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

- ii) Purchase bottled water for drinking and cooking.
- D) You can consult a variety of sources for additional information. Your family doctor or pediatrician can perform a blood test for lead and provide you with information about the health effects of lead. State and local government agencies that can be contacted include the following:
  - i) (Insert the name of city or county department of public utilities) at (insert phone number) can provide you with information about your community's water supply, and a list of local laboratories that have been certified by EPA for testing water quality;
  - ii) (Insert the name of city or county department that issues building permits) at (insert phone number) can provide you with information about building permit records that should contain the names of plumbing contractors that plumbed your home; and
  - iii) The Illinois Department of Public Health at 217-782-4977 or 312-814-2608 or the (insert the name of the city or county health department) at (insert phone number) can provide you with information about the health effects of lead and how you can have your child<sup>21</sup>/<sub>2</sub>s blood tested.
- E) The following is a list of some State-approved laboratories in your area that you can call to have your water tested for lead. (Insert names and phone numbers of at least two laboratories.)

BOARD NOTE: Derived from 40 CFR 141.85(a)(1) (2002) (2012).

(Source: Amended at 37 Ill. Reg	, effective	)
---------------------------------	-------------	---

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

# Section 611. Appendix 611. APPENDIX G NPDWR Violations and Situations Requiring Public Notice

See note 1 at the end of this Appendix G for an explanation of the Agency<sup>2</sup>'s authority to alter the magnitude of a violation from that set forth in the following table.

	MCL/MRD	DL/TT violations <sup>2</sup>	Monitoring & testing procedure violations		
Contaminant	Tier of public notice required	Citation	Tier of public notice required	Citation	

## I. Violations of National Primary Drinking Water Regulations (NPDWR):<sup>3</sup>

A.	Microbiological	Contaminants
----	-----------------	--------------

1. Total coliform	2	611.325(a)	3	611.521-611.52 5
2. Fecal coliform/E. coli	1	611.325(b)	41,3	611.525
3. Turbidity MCL	2	611.320(a)	3	611.560
<ul> <li>4. Turbidity MCL (average of two days<sup>⊥</sup> samples greater than 5 NTU)</li> </ul>	<sup>s</sup> 2, 1	611.320(b)	3	611.560
5. Turbidity (for TT violations resulting from a single exceedence of maximum allowable turbidity level)	<sup>6</sup> 2, 1	611.231(b), 611.233(b)(1), 611.250(a)(2), 611.250(b)(2), 611.250(c)(2), 611.250(d), 611.743(a)(2), 611.743(b), 611.955(b)(2)	3	611.531(a), 611.532(b), 611.533(a), 611.744,_ 611.956(a)(1)-( a)(3), 611.956(b)
<ul> <li>6. Surface Water Treatment Rule violations, other than violations resulting from single exceedence of max. allowable turbidity level (TT)</li> </ul>	2	611.211, 611.213, 611.220, 611.230-611.23 3, 611.240-611.24 2, 611.250	3	611.531-611.53 3

.

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

<ul> <li>7. Interim Enhanced Surface Water Treatment Rule violations, other than violations resulting from single exceedence of max. turbidity level (TT)</li> </ul>	2	7 611.740-611.74 3,_ 611.950-611.95 5	3	611.742, 611.744, 611.953, 611.954, 611.956
8. Filter Backwash Recycling Rule violations	2	611.276(c)	3	611.276(b), (d)
9. Long Term 1 Enhanced Surface Water Treatment Rule violations	2	611.950-611.95 5	3	611.953, 611.954, 611.956
10. LT2ESWTR violations	2	611.1010-611.1 020	<sup>221919</sup> 2, 3	611.1001-611.1 005 and 611.1008-611.1 009
11. Groundwater Rule violations	2	611.804	3	611.802(h)

## B. Inorganic Chemicals (IOCs)

1. Antimony	2	611.301(b)	3	611.600,
				611.601,
				611.603
2. Arsenic	2	<sup>8</sup> 611.301(b)	3	<sup>++</sup> 611.601,-
				611.612(a),
				611.612(b).
				611.603
3. Asbestos (fibers greater than	2	611.301(b)	3	611.600,
10 µm)				611.601,
				611.602
4. Barium	2	611.301(b)	3	611.600,
				611.601,
				611.603
5. Beryllium	2	611.301(b)	3	611.600,
		~		611.601,
				611.603
6. Cadmium	2	611.301(b)	3	611.600,
		- 12		611.601,
				611.603
7. Chromium (total)	2	611.301(b)	3	611.600,
				611.601,

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

				611.603
8. Cyanide	2	611.301(b)	3	611.600,
				611.601,
				611.603
9. Fluoride	2	611.301(b)	3	611.600,
				611.601,
				611.603
10. Mercury (inorganic)	2	611.301(b)	3	611.600,
4				611.601,
				611.603
11. Nitrate	1	611.301(b)	<sup>1288</sup> 1, 3	611.600,
				611.601,
				611.604,
			1.000	611.606
12. Nitrite	1	611.301(b)	<sup>1288</sup> 1, 3	611.600,
				611.601,
				611.605,
				611.606
13. Total Nitrate and Nitrite	1	611.301(b)	3	611.600,
1				611.601
14. Selenium	2	611.301(b)	3	611.600,
				611.601,
				611.603
15. Thallium	2	611.301(b)	3	611.600,
				611.601,
				611.603

## C. Lead and Copper Rule (Action Level for lead is 0.015 mg/l, for copper is 1.3 mg/l)

1. Lead and Copper Rule (TT)	2	611.350-611.35	3	611.356-611.35
		5		9

## D. Synthetic Organic Chemicals (SOCs)

		1		
1. 2,4-D	2	611.310(c)	3	611.648
2. 2,4,5-TP (silvex)	2	611.310(c)	3	611.648
3. Alachlor	2	611.310(c)	3	611.648
4. Atrazine	2	611.310(c)	3	611.648
5. Benzo(a)pyrene (PAHs)	2	611.310(c)	3	611.648
6. Carbofuran	2	611.310(c)	3	611.648

÷

.

.

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

7. Chlordane	2	611.310(c)	3	611.648
8. Dalapon	2	611.310(c)	3	611.648
9. Di(2-ethylhexyl)adipate	2	611.310(c)	3	611.648
10. Di(2-ethylhexyl)phthalate	2	611.310(c)	3	611.648
11. Dibromochloropropane (DBCP)	2	611.310(c)	3	611.648
12. Dinoseb	2	611.310(c)	3	611.648
13. Dioxin (2,3,7,8-TCDD)	2	611.310(c)	3	611.648
14. Diquat	2	611.310(c)	3	611.648
15. Endothall	2	611.310(c)	3	611.648
16. Endrin	2	611.310(c)	3	611.648
17. Ethylene dibromide	2	611.310(c)	3	611.648
18. Glyphosate	2	611.310(c)	3	611.648
19. Heptachlor	2	611.310(c)	3	611.648
20. Heptachlor epoxide	2	611.310(c)	3	611.648
21. Hexachlorobenzene	2	611.310(c)	3	611.648
22. Hexachlorocyclopentadiene	2	611.310(c)	3	611.648
23. Lindane	2	611.310(c)	3	611.648
24. Methoxychlor	2	611.310(c)	3	611.648
25. Oxamyl (Vydate)	2	611.310(c)	3	611.648
26. Pentachlorophenol	2	611.310(c)	3	611.648
27. Picloram	2	611.310(c)	3	611.648
28. Polychlorinated biphenyls (PCBs)	2	611.310(c)	3	611.648
29. Simazine	2	611.310(c)	3	611.648
30. Toxaphene	2	611.310(c)	3	611.648

## E. Volatile Organic Chemicals (VOCs)

1. Benzene	2	611.310(a)	3	611.646
2. Carbon tetrachloride	2	611.310(a)	3	611.646
3. Chlorobenzene	2	611.310(a)	3	611.646
(monochlorobenzene)				
4. o-Dichlorobenzene	2	611.310(a)	3	611.646
5. p-Dichlorobenzene	2	611.310(a)	3	611.646
6. 1,2-Dichloroethane	2	611.310(a)	3	611.646
7. 1,1-Dichloroethylene	2	611.310(a)	3	611.646
8. cis-1,2-Dichloroethylene	2	611.310(a)	3	611.646
9. trans-1,2-Dichloroethylene	2	611.310(a)	3	611.646

#### POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

10. Dichloromethane	2	611.310(a)	3	611.646
11. 1,2-Dichloropropane	2	611.310(a)	3	611.646
12. Ethylbenzene	2	611.310(a)	3	611.646
13. Styrene	2	611.310(a)	3	611.646
14. Tetrachloroethylene	2	611.310(a)	3	611.646
15. Toluene	2	611.310(a)	3	611.646
16. 1,2,4-Trichlorobenzene	2	611.310(a)	3	611.646
17. 1,1,1-Trichloroethane	2	611.310(a)	3	611.646
18. 1,1,2-Trichloroethane	2	611.310(a)	3	611.646
19. Trichloroethylene	2	611.310(a)	3	611.646
20. Vinyl chloride	2	611.310(a)	3	611.646
21. Xylenes (total)	2	611.310(a)	3	611.646

## F. Radioactive Contaminants

1. Beta/photon emitters	2	611.330(d)	3	611.720(a),
				611.732
2. Alpha emitters	2	611.330(c)	3	611.720(a),
				611.731
3. Combined radium (226 &	2	611.330(b)	3	611.720(a),
228)				611.731
4. Uranium	2	611.330(e)	3	611.720(a),
				611.731

G. Disinfection Byproducts (DBPs), Byproduct Precursors, Disinfectant Residuals. Where disinfection is used in the treatment of drinking water, disinfectants combine with organic and inorganic matter present in water to form chemicals called disinfection byproducts (DBPs). USEPA sets standards for controlling the levels of disinfectants and DBPs in drinking water, including trihalomethanes (THMs) and haloacetic acids (HAAs).<sup>13</sup>

1. Total trihalomethanes (TTHMs)	2	<sup>1411</sup> 611.312 <sup>11</sup> 611.3 12(b)	3	Subparts W and Y of this Part
2. Haloacetic Acids (HAA5)	2	611.312(b)	3	Subpart Y of this Part
3. Bromate	2	611.312(a)	3	611.382(a)-(b)
4. Chlorite	2	611.312(a)	3	611.382(a)-(b)
5. Chlorine (MRDL)	2	611.313(a)	3	611.382(a), (c)

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

6. Chloramine (MRDL)	2	611.313(a)	3	611.382(a), (c)
7. Chlorine dioxide (MRDL),	2	611.313(a),	2-1512-212. 3	611.382(a), (c),
where any two consecutive		611.383(c)(3)		611.383(c)(2)
daily samples at entrance to				
distribution system only are				
above MRDL				
8. Chlorine dioxide (MRDL),	1613 1131	611.313(a),	1	611.382(a), (c),
where samples in		611.383(c)(3)		611.383(c)(2)
distribution system the next				
day are also above MRDL				
9. Control of DBP precursors— TOC (TT)	2	611.385(a)-(b)	3	611.382(a), (d)
10. Benchmarking and	N/A	N/A	3	611.742,
disinfection profiling	L			611.953,
				611.954
11. Development of monitoring	N/A	N/A	3	611.382(f)
plan		·		

## H. Other Treatment Techniques

1. Acrylamide (TT)	2	611.296	N/A	N/A	
2. Epichlorohydrin (TT)	2	611.296	N/A	N/A	

## II. Unregulated Contaminant Monitoring: <sup>171414</sup>

B				
A. Unregulated contaminants	N/A	N/A	3	611.510
B. Nickel	N/A	N/A	3	611.603,
				611.611

## III. Public Notification for Relief Equivalent to a SDWA section 1415 Variance or a section 1416 Exemption.

A. Operation under relief equivalent to a SDWA section 1415 variance or a section 1416 exemption	3	<sup>1815</sup> 15 1416	N/A	N/A
B. Violation of conditions of relief equivalent to a SDWA section 1415 variance or a section 1416 exemption	2	1415, 1416, <sup>191616</sup> 611.111, 611.112	N/A	N/A

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

IV. Other Situations Requiring		ication.		
A. Fluoride secondary maximum contaminant level (SMCL) exceedence	3	611.858	N/A.	N/A
B. Exceedence of nitrate MCL for a non-CWS supplier, as allowed by the Agency	1	611.300(d)	N/A	N/A
C. Availability of unregulated contaminant monitoring data	3	611.510	N/A	N/A
D. Waterborne disease outbreak	1	611.101, 611.233(b)(2)	N/A	N/A
E. Other waterborne emergency <sup>2017</sup> <sup>17</sup>	1	N/A	N/A	N/A
F. Source water sample positive for Groundwater Rule fecal indicators: E. coli, enterococci, or coliphage	1	611.802(g)	N/A	N/A
G. Other situations as determined by the Agency by a SEP issued pursuant to Section 611.110	<sup>2118</sup> -1, <sup>18</sup> 1, 2, 3	N/A	N/A	N/A

#### untions Requiring Dublin Matification 117

Appendix G--Endnotes

- 1. Violations and other situations not listed in this table (e.g., failure to prepare Consumer Confidence Reports) do not require notice, unless otherwise determined by the Agency by a SEP issued pursuant to Section 611.110. The Agency may, by a SEP issued pursuant to Section 611.110, further require a more stringent public notice tier (e.g., Tier 1 instead of Tier 2 or Tier 2 instead of Tier 3) for specific violations and situations listed in this Appendix, as authorized under Sections 611.902(a) and 611.903(a).
- Definition of the abbreviations used: "MCL" means maximum contaminant level, 2. "MRDL" means maximum residual disinfectant level, and "TT" means treatment technique.
- 3. The term "violations of National Primary Drinking Water Regulations (NPDWR)" is used here to include violations of MCL, MRDL, treatment technique, monitoring, and testing procedure requirements.

#### POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

- 4. Failure to test for fecal coliform or E. coli is a Tier 1 violation if testing is not done after any repeat sample tests positive for coliform. All other total coliform monitoring and testing procedure violations are Tier 3 violations.
- 5. A supplier that violates the turbidity MCL of 5 NTU based on an average of measurements over two consecutive days must consult with the Agency within 24 hours after learning of the violation. Based on this consultation, the Agency may subsequently decide to issue a SEP pursuant to Section 611.110 that elevates the violation to a Tier 1 violation. If a supplier is unable to make contact with the Agency in the 24-hour period, the violation is automatically elevated to a Tier 1 violation.
- 6. A supplier with a treatment technique violation involving a single exceedence of a maximum turbidity limit under the Surface Water Treatment Rule (SWTR), the Interim Enhanced Surface Water Treatment Rule (IESWTR), or the Long Term 1 Enhanced Surface Water Treatment Rule are required to consult with the Agency within 24 hours after learning of the violation. Based on this consultation, the Agency may subsequently decide to issue a SEP pursuant to Section 611.110 that elevates the violation to a Tier 1 violation. If a supplier is unable to make contact with the Agency in the 24-hour period, the violation is automatically elevated to a Tier 1 violation.
- 7. The Surface Water Treatment Rule (SWTR) remains in effect for a supplier that serves at least 10,000 persons ; the Interim Enhanced Surface Water Treatment Rule adds additional requirements and does not in many cases supercede the SWTR.
- 8. This endnote 8 corresponds with the endnote to the table in appendix A to subpart Q of 40 CFR 141 (2006), which stated a past effective date. This statement maintains structural consistency with the federal regulations. Failure to take a confirmation sample within 24 hours for nitrate or nitrite after an initial sample exceeds the MCL is a Tier 1 violation. Other monitoring violations for nitrate are Tier 3.
- 9. This endnote 8 corresponds with the endnote to the table in appendix A to subpart Q of 40 CFR 141 (2006), which stated a past effective date. This statement maintains structural consistency with the federal regulations. Failure to take a confirmation sample within 24 hours for nitrate or nitrite after an initial sample exceeds the MCL is a Tier 1 violation. Other monitoring violations for nitrate are Tier 3.

108. Failure to take a confirmation sample within 24 hours for nitrate or nitrite after an initial-

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

sample exceeds the MCL is a Tier 1 violation. Other monitoring violations for nitrate are Tier 3.

- 11. This endnote 11 corresponds with the endnote to the table in appendix A to subpart Q of 40-CFR 141 (2006), which stated a past effective date. This statement maintains structuralconsistency with the federal regulations.
- 129. Failure to take a confirmation sample within 24 hours for nitrate or nitrite after an initial sample exceeds the MCL is a Tier 1 violation. Other monitoring violations for nitrate are Tier 3.
- 1310.10. A Subpart B community or non-transient non-community system supplier must comply with new DBP MCLs, disinfectant MRDLs, and related monitoring requirements. A Subpart B transient non-community system supplier that serves 10,000 or more persons that uses chlorine dioxide as a disinfectant or oxidant or a Subpart B transient non-community system supplier that serves fewer than 10,000 persons, which uses only groundwater not under the direct influence of surface water, and which uses chlorine dioxide as a disinfectant or oxidant must comply with the chlorine dioxide MRDL.
- 1411-11. Sections 611.312(b)(1) and 611.382(a) and (b) apply until Subpart Y of this Part takes effect under the schedule set forth in Section 611.970(c).
- 1512.12. Failure to monitor for chlorine dioxide at the entrance to the distribution system the day after exceeding the MRDL at the entrance to the distribution system is a Tier 2 violation.
- 1613.13. If any daily sample taken at the entrance to the distribution system exceeds the MRDL for chlorine dioxide and one or more samples taken in the distribution system the next day exceed the MRDL, Tier 1 notification is required. A failure to take the required samples in the distribution system after the MRDL is exceeded at the entry point also triggers Tier 1 notification.
- 1714.14. Some water suppliers must monitor for certain unregulated contaminants listed in Section 611.510.
- 1815.15. This citation refers to sections 1415 and 1416 of the federal Safe Drinking Water Act. sections 1415 and 1416 require that "a schedule prescribed . . . for a public water system granted relief equivalent to a SDWA section 1415 variance or a section 1416 exemption must require compliance by the system . ...."..."

## POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

- 1916.16. In addition to sections 1415 and 1416 of the federal Safe Drinking Water Act, 40 CFR 142.307 specifies the items and schedule milestones that must be included in relief equivalent to a SDWA section 1415 small system variance. In granting any form of relief from an NPDWR, the Board will consider all applicable federal requirements for and limitations on the State-'s ability to grant relief consistent with federal law.
- 2017.17. Other waterborne emergencies require a Tier 1 public notice under Section 611.902(a) for situations that do not meet the definition of a waterborne disease outbreak given in Section 611.101, but which still have the potential to have serious adverse effects on health as a result of short-term exposure. These could include outbreaks not related to treatment deficiencies, as well as situations that have the potential to cause outbreaks, such as failures or significant interruption in water treatment processes, natural disasters that disrupt the water supply or distribution system, chemical spills, or unexpected loading of possible pathogens into the source water.
- 2118.18. The Agency may place any other situation in any tier it deems appropriate in writing, based on the prospective threat which it determines that the situation poses to public health, and subject to Board review pursuant to Section 40 of the Act [415 ILCS 5/40].
- 2219.19. A failure to collect three or more samples for Cryptosporidium analysis is a Tier 2 violation requiring special notice, as specified in Section 611.911. All other monitoring and testing procedure violations are Tier 3.
- BOARD NOTE: Derived from Appendix A to Subpart Q to 40 CFR 141 (2006) (2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

. •

.

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

# Section 611. Appendix <u>611.</u> APPENDIX H Standard Health Effects Language for Public Notification

Contaminant	MCLG <sup>1</sup>	MCL <sup>2</sup> mg/l	
	mg/l		public notification
National P	rimary Drinkir	ig Water Regul	ations (NPDWR):
	A. Microbiol	ogical Contam	inants
1a. Total coliform	Zero	See footnote	Coliforms are bacteria that are
		3	naturally present in the
			environment and are used as an
			indicator that other,
			potentially-harmful, bacteria may
			be present. Coliforms were found
			in more samples than allowed and
			this was a warning of potential
			problems.
1b. Fecal coliform/E. coli	Zero	Zero	Fecal coliforms and E. coli are
			bacteria whose presence indicates
		Ţ	that the water may be contaminated
			with human or animal wastes.
			Microbes in these wastes can cause
			short-term effects, such as diarrhea,
			cramps, nausea, headaches, or other
			symptoms. They may pose a special
			health risk for infants, young
			children, some of the elderly, and
			people with severely compromised
			immune systems.
1c. Fecal indicators (GWR):			Fecal indicators are microbes
i. E. coli	Zero	TT	whose presence indicates that the
ii. enterococci	None	TT	water may be contaminated with
iii. coliphage	None	TT	human or animal wastes. Microbes
			in these wastes can cause
			short-term health effects, such as
]			diarrhea, cramps, nausea,
			headaches, or other symptoms.
			They may pose a special health risk
			for infants, young children, some of
			the elderly, and people with

## POLLUTION CONTROL BOARD

			severely compromised immune systems.
1d. Groundwater Rule TT violations	None	TT	Inadequately treated or inadequately protected water may contain disease-causing organisms. These organisms can cause symptoms such as diarrhea, nausea,
2a. Turbidity (MCL) <sup>4</sup>	None	1 NTU <sup>5</sup> / 5 NTU	<ul> <li>cramps, and associated headaches.</li> <li>Turbidity has no health effects.</li> <li>However, turbidity can interfere with disinfection and provide a medium for microbial growth.</li> <li>Turbidity may indicate the presence of disease-causing organisms.</li> <li>These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.</li> </ul>
2b. Turbidity (SWTR TT)	None	TT 7	Turbidity has no health effects. However, <sup>6</sup> turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.
2c. Turbidity (IESWTR TT and LT1ESWTR TT)	None	TT	Turbidity has no health effects. However, <sup>8</sup> turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

• •

.

## POLLUTION CONTROL BOARD

	Enhanced Surfa	ace Water Tre	nced Surface Water Treatment Rule eatment Rule (LT1ESWTR), and Filter
3. Giardia lamblia (SWTR/IESWTR/ LT1ESWTR)	Zero	TT 10	Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.
4. Viruses (SWTR/IESWTR/ LT1ESWTR)			Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.
5. Heterotrophic plate count (HPC) bacteria <sup>9</sup> (SWTR/IESWTR/ LT1ESWTR)			Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.
6. Legionella (SWTR/IESWTR/ LT1ESWTR)			Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.
7. Cryptosporidium (IESWTR/FBRR/ LT1ESWTR)			Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.
		Chemicals (	IOCs)
8. Antimony	0.006	0.006	Some people who drink water containing antimony well in excess of the MCL over many years could experience increases in blood cholesterol and decreases in blood

• •

## POLLUTION CONTROL BOARD

			sugar.
9. Arsenic <sup>11</sup>	0	0.010	Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.
10. Asbestos (10 µmµm)	7 MFL <sup>+2++11</sup>	7 MFL	Some people who drink water containing asbestos in excess of the MCL over many years may have an increased risk of developing benign intestinal polyps.
11. Barium	2	2	Some people who drink water containing barium in excess of the MCL over many years could experience an increase in their blood pressure.
12. Beryllium	0.004	0.004	Some people who drink water containing beryllium well in excess of the MCL over many years could develop intestinal lesions.
13. Cadmium	0.005	0.005	Some people who drink water containing cadmium in excess of the MCL over many years could experience kidney damage.
14. Chromium (total)	0.1	0.1	Some people who use water containing chromium well in excess of the MCL over many years could experience allergic dermatitis.
15. Cyanide	0.2	0.2	Some people who drink water containing cyanide well in excess of the MCL over many years could experience nerve damage or problems with their thyroid.
16. Fluoride	4.0	4.0	Some people who drink water containing fluoride in excess of the MCL over many years could get

.

.

## POLLUTION CONTROL BOARD

			bone disease, including pain and tenderness of the bones. Fluoride in drinking water at half the MCL or more may cause mottling of children''s teeth, usually in children less than nine years old. Mottling, also known as dental fluorosis, may include brown staining or pitting of the teeth, and occurs only in developing teeth before they erupt from the gums.
17. Mercury (inorganic)	0.002	0.002	Some people who drink water containing inorganic mercury well in excess of the MCL over many years could experience kidney damage.
18. Nitrate	10	10	Infants below the age of six months who drink water containing nitrate in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue baby syndrome.
19. Nitrite	1	1	Infants below the age of six months who drink water containing nitrite in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue baby syndrome.
20. Total Nitrate and Nitrite	10	10	Infants below the age of six months who drink water containing nitrate and nitrite in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue baby syndrome.
21. Selenium	0.05	0.05	Selenium is an essential nutrient. However, some people who drink

## POLLUTION CONTROL BOARD

22. Thallium	0.0005	0.002	water containing selenium in excess of the MCL over many years could experience hair or fingemail losses, numbness in fingers or toes, or problems with their circulation. Some people who drink water containing thallium in excess of the MCL over many years could experience hair loss, changes in
			their blood, or problems with their kidneys, intestines, or liver.
	D. Lead a	and Copper Ru	
23. Lead	Zero	TT <sup>1312</sup> 12	Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.
24. Copper	1.3	TT <sup>4413</sup> 13	Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson''s Disease should consult their personal doctor.
	E. Synthetic Org	anic Chemica	ls (SOCs)
25. 2,4-D	0.07	0.07	Some people who drink water containing the weed killer 2,4-D well in excess of the MCL over many years could experience

•

## POLLUTION CONTROL BOARD

			problems with their kidneys, liver, or adrenal glands.
26. 2,4,5-TP (silvex)	0.05	0.05	Some people who drink water containing silvex in excess of the MCL over many years could experience liver problems.
27. Alachlor	Zero	0.002	Some people who drink water containing alachlor in excess of the MCL over many years could have problems with their eyes, liver, kidneys, or spleen, or experience anemia, and may have an increased risk of getting cancer.
28. Atrazine	0.003	0.003	Some people who drink water containing atrazine well in excess of the MCL over many years could experience problems with their cardiovascular system or reproductive difficulties.
29. Benzo(a)pyrene (PAHs).	Zero	0.0002	Some people who drink water containing benzo(a)pyrene in excess of the MCL over many years may experience reproductive difficulties and may have an increased risk of getting cancer.
30. Carbofuran	0.04	0.04	Some people who drink water containing carbofuran in excess of the MCL over many years could experience problems with their blood, or nervous or reproductive systems.
31. Chlordane	Zero	0.002	Some people who drink water containing chlordane in excess of the MCL over many years could experience problems with their liver or nervous system, and may have an increased risk of getting cancer.
32. Dalapon	0.2	0.2	Some people who drink water

•

# POLLUTION CONTROL BOARD

			containing dalapon well in excess of the MCL over many years could experience minor kidney changes.
33. Di(2-ethylhexyl)adipate	0.4	0.4	Some people who drink water containing di(2-ethylhexyl)adipate well in excess of the MCL over many years could experience toxic effects, such as weight loss, liver enlargement, or possible reproductive difficulties.
34. Di(2-ethylhexyl) phthalate	Zero	0.006	Some people who drink water containing di(2-ethylhexyl) phthalate well in excess of the MCL over many years may have problems with their liver or experience reproductive difficulties, and they may have an increased risk of getting cancer.
35. Dibromochloropropane (DBCP)	Zero	0.0002	Some people who drink water containing DBCP in excess of the MCL over many years could experience reproductive difficulties and may have an increased risk of getting cancer.
36. Dinoseb	0.007	0.007	Some people who drink water containing dinoseb well in excess of the MCL over many years could experience reproductive difficulties.
37. Dioxin (2,3,7,8-TCDD)	Zero	3 x 10 <sup>-8</sup>	Some people who drink water containing dioxin in excess of the MCL over many years could experience reproductive difficulties and may have an increased risk of getting cancer.
38. Diquat	0.02	0.02	Some people who drink water containing diquat in excess of the MCL over many years could get cataracts.

.

. .

# POLLUTION CONTROL BOARD

39. Endothall	0.1	0.1	Some people who drink water
			containing endothall in excess of
			the MCL over many years could
			experience problems with their
			stomach or intestines.
40. Endrin	0.002	0.002	Some people who drink water
			containing endrin in excess of the
			MCL over many years could
			experience liver problems.
41. Ethylene dibromide	Zero	0.00005	Some people who drink water
			containing ethylene dibromide in
	1		excess of the MCL over many years
			could experience problems with
			their liver, stomach, reproductive
	1	1	system, or kidneys, and may have
			an increased risk of getting cancer.
42. Glyphosate	0.7	0.7	Some people who drink water
		2276	containing glyphosate in excess of
			the MCL over many years could
	1		experience problems with their
			kidneys or reproductive difficulties.
43. Heptachlor	Zero	0.0004	Some people who drink water
	2010	0.0001	containing heptachlor in excess of
			the MCL over many years could
			experience liver damage and may
		1	have an increased risk of getting
			cancer.
44. Heptachlor epoxide	I Zero	0.0002	Some people who drink water
44. Heptaemor epoxide		0.0002	containing heptachlor epoxide in
			excess of the MCL over many years
	ĺ		could experience liver damage, and
			may have an increased risk of
45 11 33 1		1 0.001	getting cancer.
45. Hexachlorobenzene	Zero	0.001	Some people who drink water
			containing hexachlorobenzene in
			excess of the MCL over many years
			could experience problems with
			their liver or kidneys, or adverse
	J	ļ	reproductive effects, and may have

. .

# POLLUTION CONTROL BOARD

			an increased risk of getting cancer.
46. Hexachlorocyclopentadi eneHexachlorocyclo-pe ntadiene	0.05	0.05	Some people who drink water containing hexachlorocyclopentadiene well in excess of the MCL over many years could experience problems with their kidneys or stomach.
47. Lindane	0.0002	0.0002	Some people who drink water containing lindane in excess of the MCL over many years could experience problems with their kidneys or liver.
48. Methoxychlor	0.04	0.04	Some people who drink water containing methoxychlor in excess of the MCL over many years could experience reproductive difficulties.
49. Oxamyl (Vydate)	0.2	0.2	Some people who drink water containing oxamyl in excess of the MCL over many years could experience slight nervous system effects.
50. Pentachlorophenol	Zero	0.001	Some people who drink water containing pentachlorophenol in excess of the MCL over many years could experience problems with their liver or kidneys, and may have an increased risk of getting cancer.
51. Picloram	0.5	0.5	Some people who drink water containing picloram in excess of the MCL over many years could experience problems with their liver.
52. Polychlorinated biphenyls (PCBs)	Zero	0.0005	Some people who drink water containing PCBs in excess of the MCL over many years could experience changes in their skin, problems with their thymus gland, immune deficiencies, or

. ،

## POLLUTION CONTROL BOARD

			reproductive or nervous system difficulties, and may have an increased risk of getting cancer.
62. Simular	0.004	0.004	
53. Simazine	0.004	0.004	Some people who drink water containing simazine in excess of the MCL over many years could experience problems with their blood.
54. Toxaphene	Zero	0.003	Some people who drink water containing toxaphene in excess of the MCL over many years could have problems with their kidneys, liver, or thyroid, and may have an increased risk of getting cancer.
	F. Volatile Orga	anic Chemica	ls (VOCs)
55. Benzene	Zero	0.005	Some people who drink water containing benzene in excess of the MCL over many years could experience anemia or a decrease in blood platelets, and may have an increased risk of getting cancer.
56. Carbon tetrachloride	Zero	0.005	Some people who drink water containing carbon tetrachloride in excess of the MCL over many years could experience problems with their liver and may have an increased risk of getting cancer.
57. Chlorobenzene (monochlorobenzene)	0.1	0.1	Some people who drink water containing chlorobenzene in excess of the MCL over many years could experience problems with their liver or kidneys.
58. o-Dichlorobenzene	0.6	0.6	Some people who drink water containing o-dichlorobenzene well in excess of the MCL over many years could experience problems with their liver, kidneys, or circulatory systems.
59. p-Dichlorobenzene	0.075	0.075	Some people who drink water

· ·

# POLLUTION CONTROL BOARD

(0.1.2 Disklargethere	Zero	0.005	containing p-dichlorobenzene in excess of the MCL over many years could experience anemia, damage to their liver, kidneys, or spleen, or changes in their blood.
60. 1,2-Dichloroethane	Zero	0.005	Some people who drink water containing 1,2-dichloroethane in excess of the MCL over many years may have an increased risk of getting cancer.
61. 1,1-Dichloroethylene	0.007	0.007	Some people who drink water containing 1,1-dichloroethylene in excess of the MCL over many years could experience problems with their liver.
62. cis-1,2-Dichloroethylen e	0.07	0.07	Some people who drink water containing cis-1,2-dichloroethylene in excess of the MCL over many years could experience problems with their liver.
63. trans-1,2-Dichloroethyle ne	0.1	0.1	Some people who drink water containing trans-1,2-dichloroethylene well in excess of the MCL over many years could experience problems with their liver.
64. Dichloromethane	Zero	0.005	Some people who drink water containing dichloromethane in excess of the MCL over many years could have liver problems and may have an increased risk of getting cancer.
65. 1,2-Dichloropropane	Zero	0.005	Some people who drink water containing 1,2-dichloropropane in excess of the MCL over many years may have an increased risk of getting cancer.
66. Ethylbenzene	0.7	0.7	Some people who drink water containing ethylbenzene well in

.

### POLLUTION CONTROL BOARD

		-	
			excess of the MCL over many years could experience problems with their liver or kidneys.
67. Styrene	0.1	0.1	Some people who drink water containing styrene well in excess of the MCL over many years could have problems with their liver, kidneys, or circulatory system.
68. Tetrachloroethylene	Zero	0.005	Some people who drink water containing tetrachloroethylene in excess of the MCL over many years could have problems with their liver, and may have an increased risk of getting cancer.
69. Toluene	1	1	Some people who drink water containing toluene well in excess of the MCL over many years could have problems with their nervous system, kidneys, or liver.
70. 1,2,4-Trichlorobenzene	0.07	0.07	Some people who drink water containing 1,2,4-trichlorobenzene well in excess of the MCL over many years could experience changes in their adrenal glands.
71. [,[,[-Trichloroethane	0.2	0.2	Some people who drink water containing 1,1,1-trichloroethane in excess of the MCL over many years could experience problems with their liver, nervous system, or circulatory system.
72. 1,1,2-Trichloroethane	0.003	0.005	Some people who drink water containing 1,1,2-trichloroethane well in excess of the MCL over many years could have problems with their liver, kidneys, or immune systems.
73. Trichloroethylene	Zero	0.005	Some people who drink water containing trichloroethylene in excess of the MCL over many years

· ·

#### POLLUTION CONTROL BOARD

			could experience problems with their liver and may have an increased risk of getting cancer.
74. Vinyl chloride	Zero	0.002	Some people who drink water containing vinyl chloride in excess of the MCL over many years may have an increased risk of getting cancer.
75. Xylenes (total)	10	10	Some people who drink water containing xylenes in excess of the MCL over many years could experience damage to their nervous system.
	G. Radio	active Contamina	ants
76. Beta/photon emitters	Zero	4 mrem/yr <sup>1514</sup>	Certain minerals are radioactive and may emit forms of radiation known as photons and beta radiation. Some people who drink water containing beta and photon emitters in excess of the MCL over many years may have an increased risk of getting cancer.
77. Alpha emitters	Zero	15 pCi/ℓ <sup>+715</sup>	Certain minerals are radioactive and may emit a form of radiation known as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer.
78. Combined radium (226 & 228)	Zero	5 pCi/ℓ	Some people who drink water containing radium 226 or 228 in excess of the MCL over many years may have an increased risk of getting cancer.
79. Uranium	Zero	30 <del>µg</del> µg/ℓ	Some people who drink water containing uranium in excess of the MCL over many years may have an increased risk of getting cancer and kidney toxicity.

.

# POLLUTION CONTROL BOARD

disinfection is used in the and inorganic matter prese (DBPs). USEPA sets star drinking water, including	treatment of drir ent in water to fo idards for contro trihalomethanes	uking water, disi rm chemicals ca lling the levels c (THMs) and hal	nd Disinfectant Residuals: Where nfectants combine with organic lled disinfection byproducts of disinfectants and DBPs in oacetic acids (HAA5) <sup>1816</sup> 16
80. Total trihalomethanes (TTHMs)	N/A	0.080 <sup>19,2017,</sup> <sup>18</sup> 0.080 <sup>17,18</sup>	Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer.
81. Haloacetic Acids (HAA5)	N/A	0.060 <sup>2119</sup> 0.060	Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.
82. Bromate	Zero	0.010	Some people who drink water containing bromate in excess of the MCL over many years may have an increased risk of getting cancer.
83. Chlorite	0.08	1.0	Some infants and young children who drink water containing chlorite in excess of the MCL could experience nervous system effects. Similar effects may occur in fetuses of pregnant women who drink water containing chlorite in excess of the MCL. Some people may experience anemia.
84. Chlorine	4 (MRDLG) <sup>22202</sup>	4.0 (MRDL) <sup>232121</sup>	Some people who use water containing chlorine well in excess of the MRDL could experience irritating effects to their eyes and nose. Some people who drink water containing

.

## POLLUTION CONTROL BOARD

			chlorine well in excess of the MRDL could experience stomach discomfort.
85. Chloramines	4 (MRDLG)	4.0 (MRDL)	Some people who use water containing chloramines well in excess of the MRDL could experience irritating effects to their eyes and nose. Some people who drink water containing chloramines well in excess of the MRDL could experience stomach discomfort or anemia.
85a. Chlorine dioxide, where any two consecutive daily samples taken at the entrance to the distribution system are above the MRDL	0.8 (MRDLG)	0.8 (MRDL)	Some infants and young children who drink water containing chlorine dioxide in excess of the MRDL could experience nervous system effects. Similar effects may occur in fetuses of pregnant women who drink water containing chlorine dioxide in excess of the MRDL. Some people may experience anemia. Add for public notification only: The chlorine dioxide violations reported today are the result of exceedences at the treatment facility only, not within the distribution system that delivers water to consumers. Continued compliance with chlorine dioxide levels within the distribution system minimizes the potential risk of these violations to consumers.
		T F e	Add for public notification only: The chlorine dioxide violations eported today are the result of exceedences at the treatment acility only, not within the

· ·

## POLLUTION CONTROL BOARD

			distribution system that delivers- water to consumers. Continued- compliance with chlorine dioxide- levels within the distribution system minimizes the potential risk- of these violations to consumers.
86a. Chlorine dioxide, where one or more distribution system samples are above the MRDL	<del>0.8</del> (MRDLG)	<del>0.8 (MRDL)</del>	Some infants and young children who drink water containing chlorine dioxide in excess of the MRDL could experience nervous system effects. Similar effects may occur in fetuses of pregnant women- who drink water containing chlorine dioxide in excess of the MRDL. Some people may experience anemia.
86a. Chlorine dioxide. where one or more distribution system samples are above the MRDL	0.8 (MRDLG)	<u>0.8 (MRDL</u>	Some infants and young children who drink water containing chlorine dioxide in excess of the MRDL could experience nervous system effects. Similar effects may occur in fetuses of pregnant women who drink water containing chlorine dioxide in excess of the MRDL. Some people may experience anemia. Add for public notification only: The chlorine dioxide violations reported today include exceedences of the USEPA standard within the distribution system that delivers water to consumers. Violations of the chlorine dioxide standard within the distribution system may harm human health based on short-term exposures. Certain groups, including fetuses,

## POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

			infants, and young children, may be especially susceptible to nervous system effects from excessive chlorine dioxide exposure.
87. Control of DBP precursors (TOC)	None	TT	Total organic carbon (TOC) has no health effects. However, total organic carbon provides a medium for the formation of disinfection byproducts. These byproducts include trihalomethanes (THMs) and haloacetic acids (HAAs). Drinking water containing these byproducts in excess of the MCL may lead to adverse health effects, liver or kidney problems, or nervous system effects, and may lead to an increased risk of getting cancer.
	I. Other Trea		iques:
88. Acrylamide	Zero	TT	Some people who drink water containing high levels of acrylamide over a long period of time could have problems with their nervous system or blood, and may have an increased risk of getting cancer.
89. Epichlorohydrin	Zero	TT	Some people who drink water containing high levels of epichlorohydrin over a long period of time could experience stomach problems, and may have an increased risk of getting cancer.

## Appendix H-\_Endnotes

1. <u>"MCLG<sup>2</sup>" means maximum contaminant level goal.</u>

## POLLUTION CONTROL BOARD

- 2. "MCL?" means maximum contaminant level.
- 3. For a water supplier analyzing at least 40 samples per month, no more than 5.0 percent of the monthly samples may be positive for total coliforms. For a supplier analyzing fewer than 40 samples per month, no more than one sample per month may be positive for total coliforms.
- 4. There are various regulations that set turbidity standards for different types of systems, including Section 611.320, the 1989 Surface Water Treatment Rule (SWTR), the 1998 Interim Enhanced Surface Water Treatment Rule (IESWTR), and the 2002 Long Term 1 Enhanced Surface Water Treatment Rule (LT1ESWTR). The MCL for the monthly turbidity average is 1 NTU; the MCL for the 2-day average is 5 NTU for a supplier that is required to filter but has not yet installed filtration (Section 611.320).
- 5. ""NTU" means nephelometric turbidity unit.
- 6. There are various regulations that set turbidity standards for different types of systems, including Section 611.320, the 1989 SWTR, the 1998 IESWTR, and the 2002 LT1ESWTR. A supplier subject to the SWTR (both filtered and unfiltered) may not exceed 5 NTU. In addition, in filtered systems, 95 percent of samples each month must not exceed 0.5 NTU in systems using conventional or direct filtration and must not exceed 1 NTU in systems using slow sand or diatomaceous earth filtration or other filtration technologies approved by the Agency.
- 7. "TT" means treatment technique.
- 8. There are various regulations that set turbidity standards for different types of systems, including Section 611.320, the 1989 SWTR, the 1998 IESWTR, and the 2002 LT1ESWTR. For a supplier subject to the IESWTR (a supplier that serves at least 10,000 people, using surface water or groundwater under the direct influence of surface water), that use conventional filtration or direct filtration, the turbidity level of a system<sup>2</sup>'s combined filter effluent may not exceed 0.3 NTU in at least 95 percent of monthly measurements, and the turbidity level of a system<sup>2</sup>'s combined filter effluent must not exceed 1 NTU at any time. A supplier subject to the IESWTR using technologies other than conventional, direct, slow sand, or diatomaceous earth filtration must meet turbidity limits set by the Agency. For a supplier subject to the LT1ESWTR (a supplier that serves fewer than 10,000 people, using surface water or groundwater under the direct influence of surface water) that uses conventional filtration or direct filtration, after January 1, 2005, the turbidity level of the supplier<sup>2</sup>'s combined filter effluent may not exceed 0.3 NTU in at least 95 percent of monthly measurements, and the turbidity level of the supplier<sup>2</sup>'s combined filter effluent may not exceed 0.3 NTU in at least 95 percent of monthly measurements, and the turbidity level of the supplier<sup>2</sup>'s combined filter effluent may not exceed 0.3 NTU in at least 95 percent of monthly measurements, and the turbidity level of the supplier<sup>2</sup>'s combined filter effluent may not exceed 0.3 NTU in at least 95 percent of monthly measurements, and the turbidity level of the supplier<sup>2</sup>'s combined filter effluent may not exceed 0.3 NTU in at least 95 percent of monthly measurements, and the turbidity level of the supplier<sup>2</sup>'s combined filter effluent may not exceed 0.3 NTU in at least 95 percent of monthly measurements, and the turbidity level of the supplier<sup>2</sup>'s combined filter effluent must not

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

exceed 1 NTU at any time. A supplier subject to the LT1ESWTR using technologies other than conventional, direct, slow sand, or diatomaceous earth filtration must meet turbidity limits set by the Agency.

- 9. The bacteria detected by heterotrophic plate count (HPC) are not necessarily harmful. HPC is simply an alternative method of determining disinfectant residual levels. The number of such bacteria is an indicator of whether there is enough disinfectant in the distribution system.
- 10. SWTR, IESWTR, and LT1ESWTR treatment technique violations that involve turbidity exceedences may use the health effects language for turbidity instead.

11. These arsenic values are effective January 23, 2006. Until then, the MCL is 0.05 mg/l and there is no MCLG.12. <u>11.</u>Millions of fibers per liter.

- 13.12. Action Level = 0.015 mg/l.
- <u>14. <u>13.</u></u>

13. Action Level =  $1.3 \text{ mg/}\ell$ .

15.14. Millirems per year.

16.15. Picocuries per liter.

17. This endnote 17 corresponds with the endnote to the table in appendix B to subpart Q of 40-CFR 141 (2006), which stated a past effective date. This statement maintains structural consistency with the federal regulations.

# <u>18. <u>16.</u></u>

- 16. A surface water system supplier or a groundwater system supplier under the direct influence of surface water is regulated under Subpart B of this Part. A Supbart B community water system supplier or a non-transient non-community system supplier must comply with Subpart I DBP MCLs and disinfectant maximum residual disinfectant levels (MRDLs). A Subpart B transient non-community system supplier that uses chlorine dioxide as a disinfectant or oxidant must comply with the chlorine dioxide MRDL.
- 19.17. Community and non-transient non-community systems must comply with Subpart Y TTHM and HAA5 MCLs of 0.080 mg/ $\ell$  and 0.060 mg/ $\ell$ , respectively (with compliance calculated as a locational running annual average) on the schedule in Section 611.970.

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

- 20.18. The MCL for total trihalomethanes is the sum of the concentrations of the individual trihalomethanes.
- 21. 19. The MCL for haloacetic acids is the sum of the concentrations of the individual haloacetic acids.

22.-20. "MRDLG" means maximum residual disinfectant level goal.

23.21. "MRDL" means maximum residual disinfectant level.

BOARD NOTE: Derived from appendix B to subpart Q to 40 CFR 141 (2006), as amended at 71-Fed. Reg. 65574 (Nov. 8, 2006) (2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_\_)

,

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

# Section 611. Appendix 611. APPENDIX I Acronyms Used in Public Notification Regulation

CCR	Consumer Confidence Report
CWS	Community Water System
DBP	Disinfection Byproduct
GWR	Groundwater Rule
HPC	Heterotrophic Plate Count
<b>IESWTR</b>	Interim Enhanced Surface Water Treatment Rule
IOC	Inorganic Chemical
LCR	Lead and Copper Rule
MCL	Maximum Contaminant Level
MCLG	Maximum Contaminant Level Goal
MRDL	Maximum Residual Disinfectant Level
MRDLG	Maximum Residual Disinfectant Level Goal
NCWS	Non-Community Water System
NPDWR	National Primary Drinking Water Regulation
NTNCWS	Non-Transient Non-Community Water System
NTU	Nephelometric Turbidity Unit
<b>OGWDW</b>	USEPA, Office of Ground Water and Drinking Water
₩O	USEPA, Office of Water
PN	Public Notification
PWS	Public Water System
SDWA	Safe Drinking Water Act
SMCL	Secondary Maximum Contaminant Level
SOC	Synthetic Organic Chemical
SWTR	Surface Water Treatment Rule
TCR	Total Coliform Rule
TT	Treatment Technique
TWS	Transient Non-Community Water System
USEPA	United States Environmental Protection Agency
VOC	Volatile Organic Chemical
CCR	Consumer Confidence Report
CWS	Community Water System
DBP	Disinfection Byproduct
GWR	Groundwater Rule
HPC	Heterotrophic Plate Count
IESWIR	Interim Enhanced Surface Water Treatment Rule
IOC	Inorganic Chemical

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

LCR	Lead and Copper Rule
MCL	Maximum Contaminant Level
MCLG	Maximum Contaminant Level Goal
MRDL	Maximum Residual Disinfectant Level
MRDLG	Maximum Residual Disinfectant Level Goal
NCWS	Non-Community Water System
NPDWR	National Primary Drinking Water Regulation
NTNCWS	Non-Transient Non-Community Water System
NTU	Nephelometric Turbidity Unit
OGWDW	USEPA, Office of Ground Water and Drinking Water
OW	USEPA. Office of Water
PN	Public Notification
PWS	Public Water System
SDWA	Safe Drinking Water Act
SMCL	Secondary Maximum Contaminant Level
SOC	Synthetic Organic Chemical
SWTR	Surface Water Treatment Rule
TCR	Total Coliform Rule
TT	Treatment Technique
TWS	Transient Non-Community Water System
USEPA	United States Environmental Protection Agency
VOC	Volatile Organic Chemical

BOARD NOTE: Derived from Appendix C to Subpart Q to 40 CFR 141 (2006), as amended at 71 Fed. Reg. 65574 (Nov. 8, 2006) (2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_, effective \_\_\_\_\_)

# POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

## Section 611. TABLE A Total Coliform Monitoring Frequency

# TOTAL COLIFORM MONITORING FREQUENCY FOR CWSs

	Population Ser	ved	Minimum Number of Samples per Month
25	to	<del>25 to</del> -1000	1
1001	to	1001 to	2
		2500	
2501	to	2501 to	3
		3300	
3301	to	3301 to	4
		4100	
4101	to	4101 to	5
10.2		4900	
4901	to	4901 to	6
		5800	
5801	to	5801 to	7
		6700	
6701	to	6701 to	8
		7600	
7601	to	<del>7601 to</del>	9
		8500	
<u>8501</u>	to	8501 to-	10
10.001		12,900	
12.901	to	12,901 to	15
17 001		17,200	20
17.201	to	17,201 to	20
21 501		21,500	25
21.501	to	21,501 to	25
25.001		25,000	20
25.001	to	25,001 to	30
22 001		33,000	40
33.001	<u>to</u>	33,001 to	40
41.001	to	41,000 41,001 to	50
41.001	to	50,000	20
50.001	to	50,000 50,001 to	60
20.001	102	59,000	00
		,000	

## POLLUTION CONTROL BOARD

59.001	to	<del>59,001 to</del>	70
		70,000	
70.001	to	<del>70,001 to</del>	<b>8</b> 0
		83,000	
83.001	to	83,001 to	90
		96,000	
96.001	to	<del>96,001 to</del>	100
		130,000	
130.001	to	130,001 to	120
		220,000	
220.001	to	220,001 to	150
		320,000	
320.001	to	320,001 to	180
		450,000	
450.001	to	450,001 to	210
		600,000	
600.001	to	600,001 to	240
		780,000	
780.001	to	780,001 to	270
		970,000	
970.001	to	970,001 to	300
		1,230,000	
1.230.001	to	1,230,001	330
		to-	
and the state		1,520,000	
1.520.001	to	1,520,001	360
		to-	
and the section		1,850,000	
1.850.001	to	1,850,001	390
		to-	
		2,270,000	
2.270.001	to	2,270,001	420
		to-	
		3,020,000	
3.020.001	to	3,020,001	450
		to-	
		3,960,000	
3.960.001	or more	3,960,001	480
R San Andre		or more	

POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

PWSs that have at least 15 service connections, but serve fewer than 25 persons are included are included in the entry for 25 to 1000 persons served. BOARD NOTE: Derived from 40 CFR 141.21(a)(2) ( $\frac{2002}{2}$ (2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

#### POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

## Section 611. Table 611. TABLE B Fecal or Total Coliform Density Measurements

System	Size (Perso	ons Served)	Samples per Week
500 <del>-or</del> -	or fewer		i î
fewer			
501- <del>to</del> -	to	3300	2
3300	7		
3301 <del>-to</del> -	to	10.000	3
10,000			
10,001- <del>to</del> -	to	25.000	4
25,000			
More than-	25.000		5
25,000			

Samples must be taken on separate days.

BOARD NOTE: Derived from 40 CFR 141.74(b)(1) (1991)(2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_, effective \_\_\_\_\_)

## POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

#### Section 611. Table 611. TABLE C Frequency of RDC Measurement

Syster	m Size (Person	ns Served)	Samples per Day
500 <del>-or</del> - <del>fewer</del>	or fewer		1
501 <del>-to-</del> 1000	to	1.000	2
1001 <del>-to-</del> <del>2,500</del>	to	2.500	3
2501-to- 3,300	<u>to</u>	3.300	4

The day<sup>2</sup>'s samples cannot be taken at the same time. The sampling intervals are subject to Agency review and approval by a SEP issued pursuant to Section <u>611.110.611.110</u>.

BOARD NOTE: Derived from 40 CFR 141.74(b)(5) and (c)(2) (2002) (2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_\_)

### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

## Section 611. TABLE D Number of Lead and Copper Monitoring Sites

System Size (Persons Served)	Number of Sites (Standard Monitoring)	Number of Sites (Reduced Monitoring)
More than 100,000	100	50
10,001-100,000	60	30
3,301 to 10,000	40	20
501 to 3,300	20	10
101 to 500	10	5
100 or fewer	5	5

BOARD NOTE: Derived from 40 CFR 141.86(c) (1992)(2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_, effective \_\_\_\_\_)

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

## Section-611.Table 611.TABLE E Lead and Copper Monitoring Start Dates

System Size (Persons served)

First Six-month Monitoring Period Begins

more than 50,000 3,301 to 50,000 3,300 or fewer January 1, 1992 July 1, 1992 July 1, 1993

BOARD NOTE: Derived from 40 CFR 141.86(d)(1) (2002)(2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_\_)

## POLLUTION CONTROL BOARD

# NOTICE OF PROPOSED AMENDMENTS

## Section-611.Table 611.TABLE F Number of Water Quality Parameter Sampling Sites

System Size- (Persons Served)	Number	of Sites
(Persons Served)	(Standard Monitoring)	(Reduced Monitoring)
more than 100,000	25	10
10,001 to 100,000	10	7
3,301 to 10,000	3	3
501 to 3,300	2	2
101 to 500	1	1
100 or fewer	1	1

BOARD NOTE: Derived from 40 CFR 141.87(a)(2) and (e) (1992) (2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_, effective \_\_\_\_\_)

#### POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

# Section 611. TABLE G Summary of Section 611.357 Monitoring Requirements for Water Quality Parameters

See end note 1 below.

Monitoring Period	Parameters <sup>2</sup>	Location	Frequency
Initial Monitoring	pH, alkalinity, orthophosphate or silica <sup>3</sup> , calcium, conductivity, temperature	Taps and at entry points to the distribution system	Every six months
	NULLAND SELECTION		Selection of the last
After installation of corrosion control	pH, alkalinity, orthophosphate or silica <sup>3</sup> , calcium <sup>4</sup>	Taps	Every six months
	pH, alkalinity dosage- rate and concentration- (if alkalinity is adjusted- as part of corrosion- control), inhibitor- dosage rate, and- inhibitor residual <sup>5</sup>	Entry points- to the distribution- system <sup>6</sup>	No less frequently than- every two weeks
	pH. alkalinity dosage rate and concentration (if alkalinity is adjusted as part of corrosion control), inhibitor dosage rate and inhibitor residual <sup>5</sup>	Entry points to the distribution system <sup>6</sup>	No less frequently than every two weeks
After the Agency specifies parameter values for optimal corrosion control	pH, alkalinity, orthophosphate or silica <sup>3</sup> , calcium <sup>4</sup>	Taps	Every six months
	pH, alkalinity dosage rate and concentration (if alkalinity is adjusted	Entry points to the distribution	No less frequently than every two weeks

#### POLLUTION CONTROL BOARD

	as part of corrosion control), inhibitor dosage rate, and inhibitor residual <sup>5</sup>	system <sup>6</sup>	
Reduced monitoring	pH, alkalinity, orthophosphate or sílica <sup>3</sup> , calcium <sup>4</sup>	Taps	Every six months, annually <sup>7</sup> or every three years <sup>8</sup> ; reduced number of sites
	pH, alkalinity dosage rate and concentration (if alkalinity is adjusted- as part of corrosion control), inhibitor- dosage rate, and inhibitor residual <sup>5</sup>	Entry points to the- distribution- system <sup>6</sup>	No less frequently than every two weeks
	pH. alkalinity dosage rate and concentration (if alkalinity is adjusted as part of corrosion control), inhibitor dosage rate and inhibitor residual <sup>5</sup>	Entry points to the distribution system <sup>6</sup>	No less frequently than every two weeks

- + This Table G is for illustrative purposes; consult the text of Section 611.357 for precise regulatory requirements.
- 2.2 Small- and medium-sized systems have to monitor for water quality parameters only during monitoring periods in which the system exceeds the lead or copper action level.
- 3.3 Orthophosphate must be measured only when an inhibitor containing a phosphate compound is used. Silica must be measured only when an inhibitor containing silicate compound is used.
- 4.4 Calcium must be measured only when calcium carbonate stabilization is used as part of corrosion control.
- 5. Inhibitor dosage rates and inhibitor residual concentrations (orthophosphate or silica) must be measured only when an inhibitor is used.

## POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

- 6.6 A groundwater system supplier may limit monitoring to representative locations throughout the system.
- $\mathcal{F}_{2}^{7}$  A water supplier may reduce frequency of monitoring for water quality parameters at the tap from every six months to annually if it has maintained the range of values for water quality parameters reflecting optimal corrosion control during three consecutive years of monitoring.
- A water supplier may further reduce the frequency of monitoring for water quality parameters at the tap from annually to once every three years if it has maintained the range of values for water quality parameters reflecting optimal corrosion control during three consecutive years of annual monitoring. A water supplier may accelerate to triennial monitoring for water quality parameters at the tap if it has maintained 90<sup>th</sup> percentile lead levels less than or equal to 0.005 mg/ $\ell$ , 90<sup>th</sup> percentile copper levels less than or equal to 0.65 mg/ $\ell$ , and the range of water quality parameters designated by the Agency under Section 611.352(f) as representing optimal corrosion control during two consecutive six-month monitoring periods.

BOARD NOTE: Derived from the table to 40 CFR 141.87 (2002)(2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

# Section 611. Table 611. TABLE H CT Values (mg·min/l) for Cryptosporidium Inactivation by Chlorine Dioxide

		Water Temperature (°C)									
Log Credit	≤0.5	1	2	3	5	7	10	15	20	25	30
0.25	159	153	140	128	107	90	69	45	29	19	12
0.5	319	305	279	256	214	180	138	89	58	38	24
1.0	637	610	558	511	429	360	277	179	116	75	49
1.5	956	915	838	767	643	539	415	268	174	113	73
2.0	1275	1220	1117	1023	858	719	553	357	232	150	98
2.5	1594	1525	1396	1278	1072	899	691	447	289	188	122
3.0	1912	1830	1675	1534	1286	1079	830	536	347	226	147

A supplier may use the following equation to determine log credit between the indicated values:

Log credit =  $(0.001506 \times (1.09116)^{\text{Temp(in °C)}}) \times CT$ .

BOARD NOTE: Derived from the table at 40 CFR 141.720(b)(1) (2006), which correspondswith Section 611.1020(b)(1) (2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_\_)

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

# Section 611. Table <u>611.</u> TABLE I CT Values (mg·min/l) for Cryptosporidium Inactivation by Ozone

1		Water Temperature (°C)									
Log Credit	≤ 0.5	1	2	3	5	7	10	15	20	25	30
0.25	6.0	5.8	5.2	4.8	4.0	3.3	2.5	1.6	1.0	0.6	0.39
0.5	12	12	10	9.5	7.9	6.5	4.9	3.1	2.0	1.2	0.78
1.0	24	23	21	19	16	13	9.9	6.2	3.9	2.5	1.6
1.5	36	35	31	29	24	20	15	9.3	5.9	3.7	2.4
2.0	48	46	42	38	32	26	20	12	7.8	4.9	3.1
2.5	60	58	52	48	40	33	25	16	9.8	6.2	3.9
3.0	72	69	63	57	47	39	30	19	12	7.4	4.7

A supplier may use the following equation to determine log credit between the indicated values:

Log credit =  $(0.0397 \times (1.09757)^{\text{Temp(in °C)}}) \times CT_{\pi}$ 

BOARD NOTE: Derived from the table at 40 CFR 141.720(b)(2) (2006), which correspondswith Section 611.1020(b)(2) (2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

# Section 611. Table <u>611.</u> TABLE J UV Dose Table for Cryptosporidium, Giardia lamblia, and Virus Inactivation Credit

UV dose (mJ/cm <sup>2</sup> )					
CryptosporidiumL credit	og <u>Cryptosp</u>	oridium	Giar	dia lamblia	Virus
0.5	1.60.5	1.6		1.5	39
1.0	2.51.0	2.5		2.1	58
1.5	<u>3.91.5</u>	3.9		3.0	79
2.0	5.82.0	5.8		5.2	100
2.5	8.52.5	8.5		7.7	121
3.0	123.0	12		11	143
3.5	153.5	15		15	163
4.0	224.0	22		22	186

BOARD NOTE: Derived from the table at 40 CFR 141.720(d)(1) (2006), which corresponds with Section 611.1020(d)(1) (2012).

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

#### POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

## Section 611. Table 611. TABLE Z Federal Effective Dates

The following are the effective dates of the various federal NPDWRs:

Fluoride (40 CFR 141.60(b)(1) <u>141.62(b)(1)</u> ) (corresponding with Section 611.301(b))	October 2, 1987
Phase I VOCs (40 CFR 141.60(a)(1) <u>141.61(a)(1) through (a)(8)</u> ) (corresponding with Section 611.311(a))	July January 9, 1989
(benzene, carbon tetrachloride, p-dichlorobenzene, 1,2-dichlorobenzene,	proethane,
1,1-dichloroethylene, 1,1,1-trichloroethane, trichloroethylene	, and vinyl chloride)
Lead and Copper (40 CFR 141, subpart I)	July 7, 1991
(corresponding with Subpart G of this Part)	
(lead and copper monitoring, reporting, and recordkeeping re 141.86 through 141.91)	quirements of 40 CFR-
Phase II IOCs (40 CFR 141.60(b)(2) 141.62(b)(2) and (b)(4) through	(b)(10)) July 30, 1992
(corresponding with Section 611.301(b))	
(asbestos, cadmium, chromium, mercury, nitrate, nitrite, and	selenium)
Phase II VOCs (40 CFR 141.60(a)(2) 141.61(a)(9) through (a)(18))	July 30, 1992
(corresponding with Section 611.311(a))	
(o-dichlorobenzene, cis-1,2-dichloroethylene, trans-1,2-dichloroethylene, trans-1,2-di	oroethylene,
1,2 dichloropropane, ethylbenzene, monochlorobenzene, styr	<del>ene,</del>
tetrachloroethylene, toluene, and xylenes (total))	
Phase II SOCs (40 CFR 141.60(a)(2) 141.61(c)(1) through (c)(18)) (corresponding with Section 611.311(c))	July 30, 1992
(alachlor, atrazine, carbofuran, chlordane, dibromochloropror	oane, ethylene-
dibromide, heptachlor, heptachlor epoxide, lindane, methoxy biphenyls, toxaphene, 2,4-D, and 2,4,5-TP (silvex))	
Phase V SOC (40 CFR 141.61(c)(3))	August 17, 1992
(corresponding with Section 611.311(c)) (endrin)	
Lead and Copper (40 CFR 141, subpart I)	December 7, 1992
(corresponding with Subpart G of this Part)	Sector Sector Sector

## POLLUTION CONTROL BOARD

(lead and copper corrosion control, water treatment, public ec service line replacement requirements of 40 CFR 141.81 thro	
Phase IIB IOC (40 CFR 141.60(a)(2) 141.62(b)(3)) (corresponding with Section 611.301(b)) (barium)	January 1, 1993
Phase IIB SOCs (40 CFR 141.60(a)(2) 141.61(a)(9) through (a)(18)) (corresponding with Section 611.311(c))	January 1, 1993
(aldicarb, aldicarb sulfone, aldicarb sulfoxide, and pentachlor	
Board note appended to Section 611.311(c) for information	relating to
implementation of requirements relating to aldicarb, aldicar sulfoxide.)	<del>b sulfone, and aldicarb</del>
Phase V IOCs (40 CFR 141.60(b)(3) 141.62(b)(11) through (b)(15)) (corresponding with Section 611.301(b))	January 17, 1994
(antimony, beryllium, cyanide, nickel, and thallium)	
Phase V VOCs (40 CFR 141.60(a)(3) 141.61(b)(19) through (b)(21))	January 17, 1994
(corresponding with Section 611.311(a))	den de
(dichloromethane, 1,2,4-trichlorobenzene, and 1,1,2-trichloro	ethane)
Phase V SOCs (40 CFR 141.60(a)(3) 141.61(c)(19) through (c)(25))	January 17, 1994
(corresponding with Section 611.311(c))	
(benzo(a)pyrene, dalapon, di(2 ethylhexyl)adipate, di(2 ethyl	
dinoseb, diquat, endothall, endrin, glyphosate, hexachloroben	
hexachlorocyclopentadiene, oxamyl, picloram, simazine, and	<del>2,5,7,8-1CDD)</del>
Consumer Confidence Report Rule (40 CFR 141, subpart Q)	September 18, 1998
(corresponding with Subpart O of this Part)	
(notification to public of drinking water quality)	
Interim Enhanced Surface Water Treatment Rule (40 CFR 141, sub	part P)
interim Emaneed Surface water Treatment Rule (10 Cr R 141, 500	February 16, 1999
(corresponding with Subpart R of this Part)	1 columy 10, 1999
(applicable to suppliers providing water to fewer than 10,00	0 persons)
(Giardia lamblia, viruses, heterotrophic plate count bacteria,	
Cryptosporidium, and turbidity)	

# POLLUTION CONTROL BOARD

Public Notification Rule (40 CFR 141, subpart Q) (corresponding with Subpart V of this Part)	June 5, 2000
(notification to public of NPDWR violations, variances of situations that could bear on public health)	or exemptions, or other-
Filter Backwash Rule (40 CFR 141.76)	August 7, 2001
(corresponding with Section 611.276)	
(reuse of spent filter backwash water, thickener supernat	ant, or liquids from
dewatering processes)	
Disinfection/Disinfectant Byproducts Rule (40 CFR 141.64, 141	65 & 141 subpart I.)
Smaller Systems (serving 10,000 or fewer persons)	December 16, 2001
Larger Systems (serving more than 10,000 persons)	December 16, 2003
(corresponding with Sections 611.312 & 611.313)	CALCULATION OF CALCUL
(total trihalomethanes, haloacetic acids (five), bromate, ch	lorite, chlorine,
chloramines, and chlorine dioxide)	
Long Term 1 Enhanced Surface Water Treatment Rule (40 CFR	141 subpart T)
Long Term T Emilanced Surface water Treatment Rule (40 CFR	February 13, 2002
(corresponding with Subpart X of this Part)	reordary 13, 2002
(applicable to suppliers providing water to 10,000 or mo	re persons)
(Giardia lamblia, viruses, heterotrophic plate count bacte	
Cryptosporidium, and turbidity)	,
Radionuclides (40 CFR 141.66)	December 8, 2003
(corresponding with Section 611.330)	200011001 0, 2003
(combined radium (Ra-226 + Ra-228), gross alpha particle	activity, beta particle and
photon activity, and uranium)	
Arsenic (40 CFR 141.62(b)(16))	January 23, 2006
(corresponding with Section 611.301(b))	Juliui j 23, 2000
(arsenic)	
Stage 2 Disinfection/Disinfectant Byproducts Rule (40 CFR 141	subparts II & V)
Systems that serve fewer than 10,000 persons)	, ouopurto e te ()
Submit plan	April 1, 2008
Complete monitoring or study	March 31, 2010
Submit IDSE report	July 1, 2010
Compliance with monitoring requirements	

# POLLUTION CONTROL BOARD

If no Cryptosporidium monitoring is required	October 1, 2013
If Cryptosporidium monitoring is required	October 1, 2014
Systems that serve 10,000 to 49,999 persons)	
Submit plan	October 1, 2007
Complete monitoring or study	September 30, 2009
Submit IDSE report	January 1, 2010
Compliance with monitoring requirements	October 1, 2013
Systems that serve 50,000 to 99,999 persons)	
Submit plan	April 1, 2007
Complete monitoring or study	March 31, 2009
Submit IDSE report	July 1, 2009
Compliance with monitoring requirements	October 1, 2012
Systems that serve 100,000 or more persons)	
Submit plan	October 1, 2006
Complete monitoring or study	September 30, 2008
Submit IDSE report	January 1, 2009
Compliance with monitoring requirements	April 1, 2012
(corresponding with Subparts W & Y of this Part)	
(total trihalomethanes and haloacetic acids (five))	

Long Term 2 Enhanced Surface Water Treatment Rule (40 CFR 14	1, subpart W)
Systems that serve fewer than 10,000 persons)	
And which monitor for E. coli	
Begin first round of monitoring	October 1, 2008
Begin treatment for Cryptosporidium	October 1, 2014
Begin second round of monitoring	October 1, 2017
And which monitor for cryptosporidium	
Begin first round of monitoring	April 1, 2010
Begin treatment for Cryptosporidium	October 1, 2014
Begin second round of monitoring	April 1, 2019
Systems that serve 10,000 to 49,999 persons)	
Begin first round of monitoring	April 1, 2008
Begin treatment for Cryptosporidium	October 1, 2013
Begin second round of monitoring	October 1, 2016
Systems that serve 50,000 to 99,999 persons)	
Begin first round of monitoring	April 1, 2007
Begin treatment for Cryptosporidium	October 1, 2012
Begin second round of monitoring	October 1, 2015
Systems that serve 100,000 or more persons)	Carl Constant and

#### POLLUTION CONTROL BOARD

Begin first round of monitoring Begin treatment for Cryptosporidium	October 1, 2006 April 1, 2012
Begin second round of monitoring (corresponding with Subpart Z of this Part) (E. coli, Cryptosporidium, Giardia lamblia, viruses,	April 1, 2015 and turbidity)
Groundwater Rule (40 CFR 141, subpart S) (corresponding with Subpart S of this Part) (E. coli, enterococci, and coliphage)	December 1, 2009
Fluoride (40 CFR 141.62(b)(1)) (corresponding with Section 611.301(b))	October 2, 1987
Phase I VOCs (40 CFR 141.61(a) through (a)(8)) (corresponding with Section 611.311(a)) (benzene, carbon tetrachloride, p-dichlorobenzene, 1.2-dichloroethane, 1.1-dichloroethylene, 1.1.1-trichloroethane, trichloroethylene, and vinyl chloride)	<u>January 9, 1989</u>
Lead and Copper (40 CFR141. subpart I) (corresponding with Subpart G of this Part) (lead and copper monitoring, reporting, and recordkeeping requirements of 40 CFR 141.86 through 141.91).	<u>July 7, 1991</u>
Phase II IOCs (40 CFR 141.62(b)(2) and (b)(4) through (b)(10)) (corresponding with Section 611.301(b)) (asbestos, cadmium, chromium, mercury, nitrate, nitrite, and selenium)	<u>July 30. 1992</u>
Phase II VOCs (40 CFR 141.61(a)(9) through (a)(18)) (o-dichlorobenzene, cis-1.2-dichloroethylene, trans-1.2-dichloroethylene, 1.2-dichloropropane, ethylbenzene, monochlorobenzene, styrene, tetrachloroethylene, toluene, and xylenes (total))	<u>July 30. 1992</u>
Phase II SOCs (40 CFR 141.61(c)(1) through (c)(18)) (alachlor, atrazine, carbofuran, chlordane, dibromochloropropane, ethylene dibromide, heptachlor,	<u>July 30, 1992</u>

## POLLUTION CONTROL BOARD

heptachlor epoxide. lindane. methoxychlor. polychlorinated biphenyls. toxaphene. 2.4-D. and 2.4.5-TP (silvex)) Phase V SOC (40 CFR 141.61(c)(3)) (corresponding with Section 611.311(c)) (endrin)	<u>August 17, 1992</u>
Lead and Copper (40 CFR141, subpart I) (corresponding with Subpart G of this Part) (lead and copper corrosion control, water treatment, public, education, and lead service line replacement requirements of 40 CFR 141.81 through 141.85)	<u>December 7, 1992</u>
Phase IIB IOC (40 CFR 141.62(b)(3)) (corresponding with Section 611.301(b)) (barium)	January 1, 1993
Phase IIB SOCs (40 CFR 141.61(a)(9) through (a)(18)) (corresponding with Section 611.311(c)) (aldicarb. aldicarb sulfone. aldicarb sulfoxide. and pentachlorophenol. See the Board note appended to Section 611.311(c) for information relating to implementation of requirements relating to aldicarb. aldicarb sulfone. and aldicarb sulfoxide.)	<u>January 1, 1993</u>
Phase V IOCs (40 CFR 141.62(b)(11) through (b)(15)) (corresponding with Section 611.301(b)) (antimony, beryllium, cyanide, nickel, and thallium)	January 17, 1994
Phase V VOCs (40 CFR 141.61(b)(19) through (b)(21)) (corresponding with Section 611.311(a)) (dichloromethane, 1.2.4-trichlorobenzene, and 1.1.2-trichloroethane)	<u>January 17, 1994</u>

## POLLUTION CONTROL BOARD

Phase V SOCs (40 CFR 141.61(c)(19) through (c)(25)) (corresponding with Section 611.311(c)) (benzo(a)pyrene, dalapon, di(2-ethylhexyl)adipate, di(2-ethylhexyl)phthalate dinoseb, diquat, endothall, endrin, glyphosate, hexachlorobenzene, hexachlorocyclopentadiene, oxamyl, picloram, simazine, and 2.3.7.8-TCDD)	<u>January 17. 1994</u>
Consumer Confidence Report Rule (40 CFR 141, subpart O) (corresponding with Subpart O of this Part) (notification to public of drinking water quality)	September 18, 1998
Interim Enhanced Surface Water Treatment Rule (40 CFR 141. subpart P) (corresponding with Subpart R of this Part) (applicable to suppliers providing water to fewer than 10.000 persons) (Giardia lamblia, viruses, heterotrophic plate count bacteria, Legionella, Cryptosporidium, and turbidity)	<u>February 16. 1999</u>
Public Notification Rule (40 CFR 141. subpart O) (corresponding with Subpart V of this Part) (notification to public of NPDWR violations, variances or exemptions, or other situations that could bear on public health)	<u>June 5. 2000</u>
Filter Backwash Rule (40 CFR 141.76) (corresponding with Section 611.276) (reuse of spent filter backwash water, thickener supernatant, or liquids from dewatering processes)	<u>August 7, 2001</u>
Disinfection/Disinfectant Byproducts Rule (40 CFR 141.64. 141.65 & 141. subpart L) Smaller Systems (serving 10.000 or fewer persons) Larger Systems (serving more than 10.000 persons) (corresponding with Sections 611.312 & 611.313) (total trihalomethanes, haloacetic acids (five), bromate, chlorite, chlorine, chloramines, and chlorine dioxide).	December 16, 2001 December 16, 2003
Long Term 1 Enhanced Surface Water Treatment Rule (40 CFR 141, Subpart T)	February 13, 2002

#### POLLUTION CONTROL BOARD

#### NOTICE OF PROPOSED AMENDMENTS

(corresponding with Subpart X of this Part) (applicable to suppliers providing water to 10.000 or more persons) (Giardia lamblia, viruses, heterotrophic plate count bacteria, Legionella, Cryptosporidium, and turbidity)

Radionuclides (40 CFR 141.66)

(corresponding with Section 611.330) (combined radium (Ra-226 + Ra-228), gross alpha particle activity, beta particle and photon activity, and uranium)

Stage 2 Disinfection/Disinfectant Byproducts Rule (40 CFR 141, subparts U & V)

Arsenic (40 CFR 141.62(b)(16)) (corresponding with Section 611.301(b)) (arsenic) December 8, 2003

January 23, 2006

April 1. 2008 March 31. 2010 July 1. 2010

October 1. 2013 October 1. 2014

October 1. 2007 September 30. 2009 January 1. 2010 October 1. 2013

April 1. 2007 March 31. 2009 July 1. 2009 October 1. 2012

October 1, 2006 September 30, 2008 January 1, 2009 April 1, 2012

Systems that serve fewer than 10,000 persons Submit plan Complete monitoring or study Submit IDSE report Compliance with monitoring requirements If no Cryptosporidium monitoring is required If Cryptosporidium monitoring is required Systems that serve 10,000 to 49,999 persons Submit plan Complete monitoring or study Submit IDSE report Compliance with monitoring requirements Systems that serve 50,000 to 99,999 persons Submit plan Complete monitoring or study Submit IDSE report Compliance with monitoring requirements Systems that serve 100.000 or more persons Submit plan Complete monitoring or study Submit IDSE report Compliance with monitoring requirements

(corresponding with Subparts W & Y of this Part)

#### POLLUTION CONTROL BOARD

## NOTICE OF PROPOSED AMENDMENTS

# (total trihalomethanes and haloacetic acids (five))

41. subpart W)	
Systems that serve fewer than 10.000 persons	
And which monitor for E. coli	
Begin first round of monitoring	October 1, 2008
Begin treatment for Cryptosporidium	October 1. 2014
Begin second round of monitoring	October 1, 2017
And which monitor for cryptosporidium	
Begin first round of monitoring	April 1, 2010
Begin treatment for Cryptosporidium	October 1, 2014
Begin second round of monitoring	April 1, 2019
Systems that serve 10.000 to 49.999 persons	
Begin first round of monitoring	April 1, 2008
Begin treatment for Cryptosporidium	October 1, 2013
Begin second round of monitoring	October 1, 2016
Systems that serve 50,000 to 99,999 persons	
Begin first round of monitoring	April 1, 2007
Begin treatment for Cryptosporidium	October 1, 2012
Begin second round of monitoring	October 1, 2015
Systems that serve 100,000 or more persons	
Begin first round of monitoring	October 1, 2006
Begin treatment for Cryptosporidium	April 1. 2012
Begin second round of monitoring	April 1, 2015
(corresponding with Subpart Z of this Part)	and the second second
(E. coli, Cryptosporidium, Giardia lamblia, viruses, and	
turbidity)	
roundwater Rule (40 CFR 141, subpart S)	December 1, 2009
(corresponding with Subpart S of this Part)	
(E. coli, enterococci, and coliphage)	

(Source: Amended at 37 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

Document comparison by Workshare Compare on Monday, November 05, 2012 10:10:28 AM

Input:	and the second
Document 1 ID	file://l:\Input\Agency Rulemakings - Files Received\2012\11Nov2012\35-611-Agency(issue45).docx
Description	35-611-Agency(issue45)
Document 2 iD	file://I:\Input\Agency Rulemakings - Files Received\2012\11Nov2012\35-611-JCARr01(issue45).doc x
Description	35-611-JCARr01(issue45)
Rendering set	Standard

Legend:	and the second second
Insertion	
Deletion-	
Moved from	
Moved to	
Style change	
Format change	
Moved deletion	
Inserted cell	
Deleted cell	
Moved ceil	
Split/Merged cell	
Padding cell	

Statistics:	
	Count
Insertions	2091
Deletions	2370
Moved from	1
Moved to	1
Style change	0
Format changed	0
Total changes	4463