

ILLINOIS POLLUTION CONTROL BOARD
April 18, 1985

CITY OF DIXON, An)
Illinois Municipal Corporation,)
)
Petitioner,)
)
v.) PCB 85-47
)
ILLINOIS ENVIRONMENTAL)
PROTECTION AGENCY,)
)
Respondent.)


ORDER OF THE BOARD (by J. D. Dumelle):

This matter comes before the Board upon April 16, 1985, petition for variance filed on behalf of the City of Dixon requesting variance from the total suspended solids and five-day biochemical oxygen demand limitations applicable to its wastewater treatment facility. That petition fails to discuss the possible use of stilling wells or cantilevered weirs in the final clarifiers as a compliance alternative. These devices direct the density currents temporarily so as not to short circuit the settling path and increase clarifier efficiency.

Unless the City files an amended petition within 45 days of the date of this Order correcting that defect, this proceeding will be subject to dismissal.

IT IS SO ORDERED.

I, Dorothy M. Gunn, Clerk of the Illinois Pollution Control Board, hereby certify that the above Order was adopted on the 18th day of April, 1985, by a vote of 5-0.



Dorothy M. Gunn, Clerk
Illinois Pollution Control Board