

ILLINOIS POLLUTION CONTROL BOARD
February 26, 1976

RICHARD D. MILLER,
Petitioner,
v.
PCB 76-46
ENVIRONMENTAL PROTECTION AGENCY,
Respondent.


ORDER OF THE BOARD (by Mr. Dumelle):

Petition filed February 18, 1976 is inadequate in that no information is given as to the present effects upon the receiving stream of the discharge from the South Addison sewage treatment plant. Data should be presented as to dissolved oxygen levels; bottom deposits, if any; coliform levels; algae growth; unbalanced benthic populations, if any; etc.

The Petition shall be amended within 30 days of the date of this order by providing the above listed information. A waiver shall be filed at the same time to make the 90-day decision period set by statute run from the date of filing of the Amended Petition. Failure to timely file the Amended Petition shall make the Petition liable to dismissal for inadequacy.

IT IS SO ORDERED.

I, Christan L. Moffett, Clerk of the Illinois Pollution Control Board, hereby certify the above Order was adopted on the 26th day of February, 1976 by a vote of 5-0.


Christan L. Moffett, Clerk
Illinois Pollution Control Board