ILLINOIS POLLUTION CONTROL BOARD May 31, 1973

CITY OF WHITE HALL

v.

PCB 73-153

ENVIRONMENTAL PROTECTION AGENCY
)

ORDER OF THE BOARD (by Mr. Dumelle)

Variance is granted from Rule 203(f) of the Water Pollution Regulations to permit copper levels in excess of 0.02 mg/l subject to the following conditions;

- 1. Treatments with copper sulfate shall be limited to one per month for the months of May through and including August, 1973.
- 2. Dosage with copper sulfate shall not exceed 1400 lbs. per treatment.
- 3. Copper concentrations at the raw water intake to the water treatment plant shall never exceed 1.0 mg/l.
- 4. Copper concentrations in the reservoir shall be measured immediately prior to and after each copper sulfate treatment and the result submitted to the Agency on a monthly basis.

IT IS SO ORDERED.

I, Christan L. Moffett, Clerk of the Illinois Pollution Control Board, hereby certify the above Order was adopted on the day of May, 1973 by a vote of

Christan L. Moffett, Clerk Illinois Pollution Control Board

citinois rollacion policioi boate