



DATE: January 18, 1985
 TO: John Shrock - DAPC/AQPS
 FROM: Jeff Benbenek - DAPC/Region III-FOS
 SUBJECT: SO2 Excursions at the Barton Monitor in Alton on 6/7 and 25/26 of November, 1984

RECEIVED

JAN 21 1985

DAPC-D-10-585

Pursuant to your request of December 4, 1984, the following information is submitted with regard to the monitored excursions of the N.A.A.Q.S. for SO2 at the Barton Monitor in Alton in November, 1984.

Alton Packaging Corporation (I.D. 119010AAL), Illinois Power Co. - Wood River (I.D. 119020AAE), Kilgas, R & D (I.D. 119020AAX), and Laclede Steel Company (I.D. 119010AAE) were all contacted and were requested to check their potential SO2 sources' operational status for the subject time periods.

Alton Packaging Corporation

Ed Pyatt, Director of Environmental Control at this facility, provided me with steam production data for the facility's #6 and #7 coal-fired boilers. Both units were in operation the entire time periods of both excursions. Utilizing this information and a conversion factor of 8 lbs. steam/lb. of coal, which is Mr. Pyatt's estimate, I was able to approximate coal usage on an hourly basis. Sulfur dioxide emissions were then calculated using a factor of 38 (S) lbs. SO2/ton of coal, where "S" is the weight percent sulfur in the coal. Mr. Pyatt indicated that the coal being burned during these time periods was from Peabody and had the following characteristics:

- Btu/lb. - 10554
- Moisture - 14.34
- Ash % - 11.64
- Sulfur % - 3.46

Stack exhaust flowrate was estimated based on comparison of the heat input for each hour to the boilers' rated heat input and maximum exhaust flowrate. Refer to attachments #1 - #4 for this information.

The #6 boiler has a stack height of 192 ft. and a diameter of 4.6 ft. Exhaust temperature can be assumed to be 350°F.

The #7 boiler has the same stack height of 192 ft. and a diameter of 8.8 ft. Exhaust temperature can be assumed to be 410°F.

The U.T.M. coordinates for both boilers of 747.8 E and 4307.1 N are correct.

Mr. Pyatt also provided me with the following dimensions for the "Most Significant Tier" developed by Murray & Trettel for downwash evaluation at this facility:

- Height - 52.7 meters
- Length - 14.6 meters
- Width - 9.8 meters

S02 Excursions - Page 2
1/18/85

Illinois Power Company

According to information I received from Don Mathias, Manager of Operations, and Dave Dorion, Results Supervisor, at this facility, coal-fired boiler #5 operated during the excursion period on 11/6-7, but not on 11/25-26. Coal-fired boiler #4 did not operate during either excursion period.

I was provided with information on half-hour instantaneous loads, in megawatts, for the #5 boiler during the period on 11/6-7. Utilizing that data and knowing the boilers rated loading and heat input, I estimated hourly heat input to the boiler for the subject time period. I was informed by Mr. Mathias that a test of a sample of the coal burned in the unit on 11/5/84 resulted in a Btu/lb. of 10977 and a weight percent of sulfur of 0.47. Utilizing the previously mentioned emission factor, hourly SO2 emissions from the boiler were calculated. Results are tabulated in attachment #5.

Stack exhaust flowrate was estimated in the same manner as that for Alton Packaging Corporation.

The #5 boiler stack has a height of 350 ft. and a diameter of 15 ft. An exhaust temperature of 285°F can be assumed.

Kilngas R & D

Mr. Larry McCormick, Plant Manager of this facility, provided me with estimates of SO2 emissions from the flare at this facility during both excursion periods. All gas generated was sent to the flare, whether desulfurized or not. No gas was sent, during either excursion period, to Illinois Power's #3 boiler. Refer to attachments #6 and #7 for these hourly estimates. As is shown, on 11/6-7, significant SO2 was emitted during only a four hour period. During 11/25-26, however, SO2 emissions from the flare ranged from 3 lbs/hr to 487 lbs/hr for the entire period.

The flare has a height of 80 ft. and a tip diameter of 25 ft. The exit temperature can be assumed as 1600°F.

Laclede Steel Co.

According to information received from Mr. Dale Eisenreich, Senior Environmental Engineer at this facility, no significant emission of SO2 was occurring at this plant. Combustion sources were utilizing natural gas.

Attachments #8, #9, #10 and #11 show the relationships with regard to location between Illinois Power and Kilngas and also indicate the sizes of the various buildings in the two facilities. Note that the Illinois Power Building is not within five stack heights of the flare at Kilngas.

S02 Excursions - Page 3
1/18/85

From these drawings and plot plans, I have estimated dimensions of Illinois Power's boilerhouse and Kingas' plant buildings.

Attachment #10, lays out the boilerhouse building and the dimensions are as follows:

| <u>Section</u> | <u>Length</u> | <u>Width</u> | <u>Height</u> |
|----------------|---------------|--------------|---------------|
| A | 50 | 44 | 41 |
| B | 220 | 44 | 41 |
| C | 220 | 75 | 51.5 |
| D | 194 | 31 | 84 |
| E | 187.5 | 69 | 97.5 |
| F | 169 | 31 | 81.5 |
| G | 156 | 87 | 49 |
| H | 106 | 87 | 132 |
| I | 189 | 112.5 | 94 |
| J | 189 | 31 | 142 |
| K | 189 | 109 | 190 |

On Attachment #11, the dimensions of the buildings in the Kingas plant are as follows:

| <u>Building #</u> | <u>Length</u> | <u>Width</u> | <u>Height</u> |
|-------------------|---------------|--------------|---------------|
| 1 | (See Notes) | | |
| 2 | 140 | 64 | 16 |
| 3 | 50 | 40 | 16 |
| 4 | 54 | 26 | 30.5 |
| 5 | 230 | 44 | 72 |
| 6 | 44 | 26 | 157 |
| 7 | 44 | 40 | 187 |
| 8 | 150 | 45 | 37 |
| 9 | 97.5 | 40 | 20 |
| 10 | 100 | 40 | 20 |
| 11 | 80 | 40 | 14 |
| 12 | 70 | 47.5 | 34.5 |

Note: #1 is Illinois Power's boilerhouse.

Also from this attachment, it can be seen that the distance between building #1 and building #12 is 35 ft.

JJB:pbo

cc: Region III

7/11/68 #1

Alton Packaging Corporation - I.D. 119 010 AAL

Boiler #6

| Time [Interval beginning @] | Steam Flow x 1000 lbs/hr | Coal lbs/hr. | Coal tons/hr. | SO ₂ lbs/hr. | Stack acfm | |
|-----------------------------------|-----------------------------|-----------------|------------------|----------------------------|---------------|-------|
| 11/6 | 2000 | 65 | 8125 | 4.063 | 534.2 | 29850 |
| | 2100 | 68 | 8500 | 4.2500 | 558.8 | 31230 |
| | 2200 | 66 | 8250 | 4.125 | 542.4 | 30310 |
| | 2300 | 67 | 8375 | 4.188 | 550.6 | 30770 |
| 11/7 | 2400 | 64 | 8000 | 4.000 | 525.9 | 29390 |
| | 100 | 63 | 7875 | 3.938 | 517.8 | 28930 |
| | 200 | 67 | 8375 | 4.188 | 550.6 | 30770 |
| | 300 | 70 | 8750 | 4.375 | 575.2 | 32140 |
| | 400 | 72 | 9000 | 4.500 | 591.7 | 33060 |
| | 500 | 76 | 9500 | 4.750 | 588.4 | 34900 |
| | 600 | 69 | 8625 | 4.313 | 567.1 | 31690 |
| | 700 | 72 | 9000 | 4.500 | 591.7 | 33060 |
| | 800 | 71 | 8875 | 4.438 | 583.5 | 32610 |
| | 900 | 69 | 8625 | 4.313 | 567.1 | 31690 |
| | 1000 | 64 | 8000 | 4.000 | 525.9 | 29390 |
| | 1100 | 65 | 8125 | 4.063 | 534.2 | 29850 |
| | 1200 | 62 | 7750 | 3.875 | 509.5 | 28470 |
| | 1300 | 60 | 7500 | 3.750 | 493.1 | 27550 |
| | 1400 | 63 | 7875 | 3.938 | 517.8 | 28930 |
| | 1500 | 55 | 8125 | 4.063 | 534.2 | 29850 |
| | 1600 | 65 | 8125 | 4.063 | 534.2 | 29850 |
| | 1700 | 62 | 7750 | 3.875 | 509.5 | 28470 |
| | 1800 | 62 | 7750 | 3.875 | 509.5 | 28470 |
| | 1900 | 65 | 8125 | 4.063 | 534.2 | 29850 |

11. ent #2

Alton Packaging Corporation - P.O. 119 010 AAL

Boiler #7

| | Time [Interval beginning @] | Steam Flow x 1000 lbs/hr | Coal lbs/hr. | Coal tons/hr. | SO ₂ lbs/hr. | Stack acfm |
|------|-----------------------------------|-----------------------------|-----------------|------------------|----------------------------|---------------|
| 11/6 | 2000 | 180 | 22500 | 11.250 | 1479.2 | 94130 |
| | 2100 | 165 | 20625 | 10.313 | 1356.0 | 86290 |
| | 2200 | 180 | 22500 | 11.250 | 1479.2 | 94130 |
| | 2300 | 178 | 22250 | 11.125 | 1462.7 | 93090 |
| 11/7 | 000 | 200 | 25000 | 12.500 | 1643.5 | 104590 |
| | 100 | 185 | 23125 | 11.563 | 1520.3 | 96750 |
| | 200 | 175 | 21875 | 10.938 | 1438.1 | 91520 |
| | 300 | 180 | 22500 | 11.250 | 1479.2 | 94130 |
| | 400 | 180 | 22500 | 11.250 | 1479.2 | 94130 |
| | 500 | 183 | 22875 | 11.438 | 1503.9 | 95710 |
| | 600 | 170 | 21250 | 10.625 | 1397.0 | 88900 |
| | 700 | 190 | 23750 | 11.875 | 1561.3 | 99360 |
| | 800 | 190 | 23750 | 11.875 | 1561.3 | 99360 |
| | 900 | 170 | 21250 | 10.625 | 1397.0 | 88900 |
| | 1000 | 180 | 22500 | 11.250 | 1479.2 | 94130 |
| | 1100 | 180 | 22500 | 11.250 | 1479.2 | 94130 |
| | 1200 | 190 | 23750 | 11.875 | 1561.3 | 99360 |
| | 1300 | 200 | 25000 | 12.500 | 1643.5 | 104590 |
| | 1400 | 195 | 24375 | 12.188 | 1602.5 | 101980 |
| | 1500 | 190 | 23750 | 11.875 | 1561.3 | 99360 |
| 1600 | 190 | 23750 | 11.875 | 1561.3 | 99360 | |
| 1700 | 190 | 23750 | 11.875 | 1561.3 | 99360 | |
| 1800 | 190 | 23750 | 11.875 | 1561.3 | 99360 | |
| 1900 | 190 | 23750 | 11.875 | 1561.3 | 99360 | |

Aluminum Packaging Corporation - I.D. 19 010 AAL

Boiler #6

11/25

Time
[Interval
beginning @] Steam Flow
 x 1000 lbs/hr Coal
 lbs/hr. Coal
 tons/hr. SO₂
 lbs/hr. Stack
 acfm

11/25

| | | | | | |
|------|----|------|-------|-------|-------|
| 1000 | 63 | 7875 | 3.938 | 517.8 | 28930 |
| 1100 | 62 | 7750 | 3.875 | 509.5 | 28470 |
| 1200 | 61 | 7625 | 3.813 | 501.3 | 28020 |
| 1300 | 55 | 6875 | 3.438 | 452.0 | 25260 |
| 1400 | 55 | 6875 | 3.438 | 452.0 | 25260 |
| 1500 | 52 | 6500 | 3.250 | 427.3 | 23880 |

| | | | | | |
|------|----|------|-------|-------|-------|
| 1600 | 55 | 6875 | 3.438 | 452.0 | 25260 |
| 1700 | 54 | 6750 | 3.375 | 443.7 | 24800 |
| 1800 | 52 | 6500 | 3.250 | 427.3 | 23880 |
| 1900 | 53 | 6625 | 3.313 | 435.6 | 24340 |
| 2000 | 55 | 6875 | 3.438 | 452.0 | 25260 |
| 2100 | 58 | 7250 | 3.625 | 476.6 | 26630 |
| 2200 | 58 | 7250 | 3.625 | 476.6 | 26630 |
| 2300 | 57 | 7125 | 3.563 | 468.5 | 26180 |

11/26

| | | | | | |
|------|----|------|-------|-------|-------|
| 00 | 58 | 7250 | 3.625 | 476.6 | 26630 |
| 100 | 62 | 7750 | 3.875 | 509.5 | 28470 |
| 200 | 59 | 7375 | 3.688 | 484.9 | 27100 |
| 300 | 57 | 7125 | 3.563 | 468.5 | 26180 |
| 400 | 56 | 7000 | 3.500 | 460.2 | 25720 |
| 500 | 59 | 7375 | 3.688 | 484.9 | 27100 |
| 600 | 56 | 7000 | 3.500 | 460.2 | 25720 |
| 700 | 62 | 7750 | 3.875 | 509.5 | 28470 |
| 800 | 58 | 7250 | 3.625 | 476.6 | 26630 |
| 900 | 62 | 7750 | 3.875 | 509.5 | 28470 |
| 1000 | 53 | 6625 | 3.313 | 435.6 | 24340 |
| 1100 | 52 | 6500 | 3.250 | 427.3 | 23880 |
| 1200 | 60 | 7500 | 3.750 | 493.1 | 27550 |
| 1300 | 63 | 7875 | 3.938 | 517.8 | 28930 |
| 1400 | 64 | 8000 | 4.000 | 525.9 | 29390 |
| 1500 | 61 | 7625 | 3.813 | 501.3 | 28020 |

| | | | | | |
|------|----|------|-------|-------|-------|
| 1600 | 64 | 8000 | 4.000 | 525.9 | 29390 |
| 1700 | 64 | 8000 | 4.000 | 525.9 | 29390 |
| 1800 | 61 | 7625 | 3.813 | 501.3 | 28020 |
| 1900 | 59 | 7375 | 3.688 | 484.9 | 27100 |

Alton Packaging Corporation - I.D. 119 010 AAL

Boiler #7

| | Time [Interval beginning @] | Steam Flow x 1000 lbs/hr | Coal lbs/hr. | Coal tons/hr. | SO ₂ lbs/hr. | Stack acfm |
|-------|-----------------------------------|-----------------------------|-----------------|------------------|----------------------------|---------------|
| 11/25 | 1000 | 190 | 23750 | 11.875 | 1561.3 | 99360 |
| | 1100 | 195 | 24375 | 12.188 | 1602.5 | 101980 |
| | 1200 | 190 | 23750 | 11.875 | 1561.3 | 99360 |
| | 1300 | 195 | 24375 | 12.188 | 1602.5 | 101980 |
| | 1400 | 190 | 23750 | 11.875 | 1561.3 | 99360 |
| | 1500 | 180 | 22500 | 11.250 | 1479.2 | 94130 |
| | 1600 | 175 | 21875 | 10.938 | 1438.1 | 91520 |
| | 1700 | 175 | 21875 | 10.938 | 1438.1 | 91520 |
| | 1800 | 165 | 20625 | 10.313 | 1356.0 | 86290 |
| | 1900 | 165 | 20625 | 10.313 | 1356.0 | 86290 |
| | 2000 | 180 | 22500 | 11.250 | 1479.2 | 94130 |
| | 2100 | 190 | 23750 | 11.875 | 1561.3 | 99360 |
| | 2200 | 195 | 24375 | 12.188 | 1602.5 | 101980 |
| | 2300 | 195 | 24375 | 12.188 | 1602.5 | 101980 |
| | 11/26 | 000 | 200 | 25000 | 12.500 | 1643.5 |
| 100 | | 205 | 25625 | 12.813 | 1684.7 | 107210 |
| 200 | | 200 | 25000 | 12.500 | 1643.5 | 104590 |
| 300 | | 195 | 24375 | 12.188 | 1602.5 | 101980 |
| 400 | | 190 | 23750 | 11.875 | 1561.3 | 99360 |
| 500 | | 190 | 23750 | 11.875 | 1561.3 | 99360 |
| 600 | | 175 | 21875 | 10.938 | 1438.1 | 91520 |
| 700 | | 195 | 24375 | 12.188 | 1602.5 | 101980 |
| 800 | | 180 | 22500 | 11.250 | 1479.2 | 94130 |
| 900 | | 190 | 23750 | 11.875 | 1561.3 | 99360 |
| 1000 | | 165 | 20625 | 10.313 | 1356.0 | 86290 |
| 1100 | | 165 | 20625 | 10.313 | 1356.0 | 86290 |
| 1200 | | 195 | 24375 | 12.188 | 1602.5 | 101980 |
| 1300 | | 195 | 24375 | 12.188 | 1602.5 | 101980 |
| 1400 | | 195 | 24375 | 12.188 | 1602.5 | 101980 |
| 1500 | 180 | 22500 | 11.250 | 1479.2 | 94130 | |
| 1600 | 195 | 24375 | 12.188 | 1602.5 | 101980 | |
| 1700 | 200 | 25000 | 12.500 | 1643.5 | 104590 | |
| 1800 | 180 | 22500 | 11.250 | 1479.2 | 94130 | |
| 1900 | 180 | 22500 | 11.250 | 1479.2 | 94130 | |

Attachment 4

Illinois Power Company - Wood River I.D. 119 020 AAE
Unit #5

| Time [Interval beginning @] | Megawatts | Btu/hr x 10 ⁶ | Coal lbs/hr. | Coal tons/hr. | SO ₂ lbs/hr. | Stack acfm |
|-----------------------------------|-----------|--------------------------|-----------------|------------------|----------------------------|---------------|
| 11/6 2000 | 188.5 | 1847.3 | 168288 | 84.144 | 1502.8 | 567750 |
| 2100 | 160.0 | 1568.0 | 142844 | 71.422 | 1275.6 | 481910 |
| 2200 | 146.0 | 1430.8 | 130345 | 65.173 | 1164.0 | 439740 |
| 2300 | 130 | 1274.0 | 116061 | 58.031 | 1036.4 | 391550 |
| 11/7 000 | 130 | 1274.0 | 116061 | 58.031 | 1036.4 | 391550 |
| 100 | 130 | 1274.0 | 116061 | 58.031 | 1036.4 | 391550 |
| 200 | 130 | 1274.0 | 116061 | 58.031 | 1036.4 | 391550 |
| 300 | 130 | 1274.0 | 116061 | 58.031 | 1036.4 | 391550 |
| 400 | 130 | 1274.0 | 116061 | 58.031 | 1036.4 | 391550 |
| 500 | 130 | 1274.0 | 116061 | 58.031 | 1036.4 | 391550 |
| 600 | 145 | 1421.0 | 129452 | 64.726 | 1156.0 | 436730 |
| 700 | 162.5 | 1592.5 | 145076 | 72.538 | 1295.5 | 489440 |
| 800 | 257.5 | 2523.5 | 229890 | 114.945 | 2052.9 | 775570 |
| 900 | 322.5 | 3160.5 | 287920 | 143.960 | 2571.1 | 971340 |
| 1000 | 272.5 | 2670.5 | 243281 | 121.641 | 2172.5 | 820750 |
| 1100 | 217.5 | 2131.5 | 194179 | 97.090 | 1734.0 | 655090 |
| 1200 | 185.0 | 1813.0 | 165164 | 82.582 | 1474.9 | 557200 |
| 1300 | 155.0 | 1519.0 | 138380 | 69.190 | 1235.7 | 466850 |
| 1400 | 232.5 | 2278.5 | 207570 | 103.785 | 1853.6 | 700270 |
| 1500 | 247.5 | 2425.5 | 220962 | 110.481 | 1973.2 | 745450 |
| 1600 | 281.5 | 2758.7 | 251316 | 125.658 | 2244.3 | 847850 |
| 1700 | 363.0 | 3557.4 | 324078 | 162.039 | 2894.0 | 1093320 |
| 1800 | 357.0 | 3498.6 | 318721 | 159.361 | 2846.2 | 1075250 |
| 1900 | 227.0 | 2224.6 | 202660 | 101.330 | 1809.8 | 683700 |

Hour-by-Hour SO₂ Emission Estimates

11/6 2000 hours → 11/7 2100 hours

| Hour | SO ₂ Emission Estimate, Lb/Hr | | |
|-----------|--|-------|------|
| 2000-2100 | 0 | | |
| -2200 | 0 | | |
| -2300 | 0 | | |
| -2400 | 0 | | |
| -0100 | 0 | | |
| -0200 | 0 | | |
| -0300 | 0 | | |
| -0400 | 0 | | |
| -0500 | 0 | | |
| -0600 | 0 | | |
| -0700 | 0 | | |
| -0800 | 0 | | |
| -0900 | 0 | | |
| -1000 | 0 | (Y13) | P.23 |
| 11 -1100 | 21 | 2.65 | 0.47 |
| 11 -1200 | 59 | 7.43 | 1.33 |
| 11 -1300 | 80 | 10.07 | 1.80 |
| 11 -1400 | 56 | 7.05 | 1.26 |
| 11 -1500 | 6 | 2.74 | 0.17 |
| -1600 | 0 | | |
| -1700 | 0 | | |
| -1800 | 0 | | |
| -1900 | 0 | | |
| -2000 | 0 | | |
| -2100 | 0 | | |

RECEIVED
Environmental Protection Agency

NOV 20 1984

116A W. MAIN ST.
COLLINSVILLE, ILL.

Product Gas was routed to Flare for entire period.
Coal feed off until ~ 1000 on 11/87.
Sturford off until ~ 1300 on 11/87.

ESTIMATED PM 2.5 EMISSIONS CALCULATION

| DATE | TIME | COAL FEED LBS HR | PRODUCT SAS FEED LBS HR | PROD. GAS MOLE WT LBS MOLE | PRODUCT GAS MOLE | CONCENTRATIONS COSE Note 1 | CONCENTRATIONS NOSE Note 2 | PRODUCT GAS FLOW LBS HR | EQUIV. SO2 EMISSIONS LBS. LBS HR | PRODUCT GAS TEMP. | STRETFORI SYSTEM STATUS |
|-------|-------|---------------------|-------------------------------|----------------------------------|---------------------|----------------------------------|----------------------------------|-------------------------------|--|-------------------------|-------------------------------|
| 25/84 | 10:00 | 0 | 9,307 | 27.87 | 0.00 | .04 | .04 | 374 | 27 | 1000 | On-Line |
| | 11:00 | 0 | 9,836 | 27.90 | 0.00 | .04 | .04 | 385 | 29 | " | " |
| | 12:00 | 0 | 10,357 | 28.06 | 0.00 | .04 | .04 | 397 | 29 | " | " |
| | 13:00 | 0 | 9,914 | 28.07 | 0.00 | .04 | .04 | 387 | 28 | " | " |
| | 14:00 | 0 | 9,872 | 28.03 | 0.00 | .04 | .04 | 380 | 28 | " | " |
| | 15:00 | 0 | 10,537 | 28.25 | 0.00 | .04 | .04 | 395 | 29 | " | " |
| | 16:00 | 0 | 10,625 | 28.34 | 0.00 | .04 | .04 | 395 | 30 | " | Off at 16:00 |
| | 17:00 | 0 | 9,831 | 28.75 | 0.00 | .04 | .04 | 380 | 16 | " | Off-Line |
| | 18:00 | 0 | 9,433 | 28.76 | 0.00 | .04 | .04 | 380 | 7 | " | " |
| | 19:00 | 0 | 7,761 | 27.99 | 0.00 | .04 | .04 | 334 | 11 | " | " |
| | 20:00 | 0 | 7,291 | 27.91 | 0.00 | .04 | .04 | 319 | 9 | " | " |
| | 21:00 | 0 | 8,461 | 28.20 | 0.00 | .04 | .04 | 361 | 16 | " | " |
| | 22:00 | 0 | 11,370 | 28.34 | 0.00 | .04 | .04 | 416 | 33 | " | " |
| | 23:00 | 0 | 12,005 | 28.69 | 0.00 | .04 | .04 | 419 | 37 | " | " |
| | 24:00 | 0 | 1,117 | 28.58 | 0.00 | .04 | .04 | 37 | 3 | " | " |
| 26/84 | 01:00 | 1,396 | 10,891 | 28.62 | 0.00 | .04 | .04 | 369 | 29 | " | On at 00:18 |
| | 02:00 | 9,434 | 14,668 | 28.48 | 0.00 | .04 | .04 | 515 | 41 | " | On-Line |
| | 03:00 | 1,750 | 15,189 | 28.43 | 0.00 | .04 | .04 | 534 | 42 | " | " |
| | 04:00 | 17,512 | 16,139 | 28.45 | 0.00 | .04 | .04 | 567 | 45 | " | " |
| | 05:00 | 19,074 | 41,256 | 27.62 | 0.00 | .04 | .04 | 1,494 | 118 | " | " |
| | 06:00 | 19,464 | 47,577 | 28.76 | 0.00 | .04 | .04 | 1,776 | 114 | " | " |
| | 07:00 | 20,446 | 57,107 | 28.30 | 0.00 | .04 | .04 | 2,197 | 140 | " | Off at 07:23 |
| | 08:00 | 21,067 | 67,560 | 28.33 | .19 | .07 | .04 | 2,627 | 487 | " | Off-Line |
| | 09:00 | 17,894 | 44,238 | 28.74 | 0.00 | .04 | .04 | 1,854 | 106 | " | On 07:5:03 |
| | 10:00 | 6,612 | 22,900 | 28.39 | .72 | .07 | .04 | 531 | 42 | " | Off-Line |
| | 11:00 | 6 | 9,352 | 28.59 | .61 | .07 | .04 | 371 | 158 | " | " |
| | 12:00 | 6 | 8,757 | 28.69 | .22 | .07 | .04 | 350 | 52 | " | " |
| | 13:00 | 1,940 | 8,879 | 28.17 | .13 | .07 | .04 | 283 | 36 | " | " |
| | 14:00 | 3,255 | 8,647 | 28.25 | .07 | .07 | .04 | 284 | 19 | " | " |
| | 15:00 | 3,733 | 8,140 | 28.97 | .05 | .07 | .04 | 246 | 24 | " | " |
| | 16:00 | 11 | 8,320 | 28.33 | .04 | .07 | .04 | 220 | 20 | " | " |
| | 17:00 | 17 | 11,491 | 29.40 | .04 | .07 | .04 | 290 | 38 | " | " |
| | 18:00 | 18 | 8,413 | 28.70 | .09 | .07 | .04 | 328 | 40 | " | " |
| | 19:00 | 11 | 8,959 | 28.68 | 0.00 | .07 | .04 | 243 | 16 | " | " |
| | 20:00 | 10 | 7,574 | 28.68 | 0.00 | .07 | .04 | 234 | 17 | " | " |
| | | 4,296 | 15,110 | 27.61 | .05 | .07 | .04 | 537 | 57 | " | " |

ER: COSE NOSE Concentrations are based on grab samples taken at 10:16 on 1/25/84 and 08:15 on 1/26/84

RECEIVED
Environmental Protection Agency


DEC 21 1994

115A W. MAIN ST.
COLLINSVILLE, ILL.

Attachment #8

MISSISSIPPI RIVER


SCALE 1" = 200'



- ① OILDER VENTS
- ② CONTROL BUILDING
- ③ AFTERBURNER / STACK
- ④ FLARE STACK
- ⑤ TAR/WATER SEPARATOR
- ⑥ PUMP/DRIVE RAN/DOWN TANK
- ⑦ SOLAR WATER STORAGE TANK
- ⑧ TAR STORAGE TANK
- ⑨ GASIFICATION BUILDING
- ⑩ COAL PILE

| | | | |
|---|---------------------|---|---------------------|
| ENGINEERING DEPARTMENT OF KUANGAS R/D INC. SHEET NO. 1 | | TITLE FLAT PLAN OF KUANGAS COMMERCIAL MODULE | |
| DRAWN BY CHECKED BY DATE | DESIGNED BY DATE | PROJECT NO. 11111111 | SHEET NO. 1 OF 2 |
| PROJECT LOCATION 11111111 Power Company | | SCALE 1" = 200' | |

SEE 44 OF 70



RECEIVED
Environmental Protection Agency

1934

COLLEGEVILLE