

ILLINOIS POLLUTION CONTROL BOARD
May 31, 1973

CITY OF MOUNT OLIVE)
)
)
 v.) PCB 73-124
)
)
 ENVIRONMENTAL PROTECTION AGENCY)
)

ORDER OF THE BOARD (by Mr. Dumelle)

Variance is granted from Rule 203(f) of the Water Pollution Regulations to permit copper levels in excess of 0.02 mg/l subject to the following conditions;

1. Treatments with copper sulfate shall be limited to one per month for the months of May through and including October 1973.
2. Dosage with copper sulfate shall not exceed 1000 lbs. per treatment in the main reservoir and 400 lbs. per treatment in the supplemental reservoir.
3. The copper concentrations at the raw water intake to the water treatment plant shall never exceed 1.0 mg/l.
4. Copper concentration in the reservoirs shall be measured immediately prior to and after each copper sulfate treatment and the results submitted to the Agency on a monthly basis.

IT IS SO ORDERED.

I, Christan L. Moffett, Clerk of the Illinois Pollution Control Board, hereby certify the above Order was adopted on the 30/31 day of May, 1973 by a vote of 4-0.

Christan L. Moffett, Clerk
Illinois Pollution Control Board