

ILLINOIS POLLUTION CONTROL BOARD
June 14, 1973

VILLAGE OF ASHLEY)

v.)

PCB 73-162)

ENVIRONMENTAL PROTECTION AGENCY)

ORDER OF THE BOARD (by Mr. Dumelle)

Variance is granted from Rule 203(f) of the Water Pollution Regulations to permit copper levels in excess of 0.02 mg/l subject to the following conditions;

1. Treatments with copper sulfate shall be limited to one per month for the months of June through and including September, 1973.
2. Dosage with copper sulfate shall not exceed 350 lbs. per treatment.
3. Copper concentrations at the raw water intake to the water treatment plant shall never exceed 1.0 mg/l.
4. Copper concentrations in the reservoir shall be measured immediately prior to and after each copper sulfate treatment and the results submitted to the Agency on a monthly basis.

IT IS SO ORDERED.

I, Christan L. Moffett, Clerk of the Illinois Pollution Control Board, hereby certify the above Order was adopted on the 14th day of June, 1973 by a vote of 3-0.


Christan L. Moffett, Clerk
Illinois Pollution Control Board