

ILLINOIS POLLUTION CONTROL BOARD  
June 28, 1973

CITY OF NASHVILLE )  
 )  
 )  
 v. ) PCB 73-227  
 )  
 )  
 ENVIRONMENTAL PROTECTION AGENCY )  
 )


ORDER OF THE BOARD (by Mr. Dumelle)

Variance is granted from Rule 203(f) of the Water Pollution Regulations to permit the use of copper sulfate in the water supply reservoir to control algae subject to the following conditions.

1. Treatments with copper sulfate shall be limited to one per month for the months of June through and including October, 1973.
2. The dosage with copper sulfate shall not exceed 350 lbs. per treatment.
3. Copper concentrations at the raw water intake to the water treatment plant shall not exceed 1.0 mg/l.
4. Copper concentrations in the reservoir shall be measured before and after each treatment and reported to the Agency on a monthly basis.

IT IS SO ORDERED.

I, Christan L. Moffett, Clerk of the Illinois Pollution Control Board, hereby certify the above Order was adopted on the 28<sup>th</sup> day of June, 1973 by a vote of 5-0.

  
\_\_\_\_\_  
Christan L. Moffett, Clerk  
Illinois Pollution Control Board