

ILLINOIS POLLUTION CONTROL BOARD
May 31, 1973

VILLAGE OF SORRENTO

v.

ENVIRONMENTAL PROTECTION AGENCY

PCB 73-170


ORDER OF THE BOARD (by Mr. Dumelle)

Variance is granted from Rule 203(f) of the Water Pollution Regulations to permit copper levels in excess of 0.02 mg/l subject to the following conditions;

1. Treatments with copper sulfate shall be limited to two treatments per months for the months of June through and including August, 1973.
2. Dosage with copper sulfate shall not exceed 100 lbs. per treatment.
3. Copper concentrations at the raw water intake to the water treatment plant shall never exceed 1.0 mg/l.
4. Copper concentrations in the reservoir shall be measured immediately prior to and after each copper sulfate treatment and the results submitted to the Agency on a monthly basis.

IT IS SO ORDERED.

I, Christan L. Moffett, Clerk of the Illinois Pollution Control Board, hereby certify the above Order was adopted on the 31st day of May, 1973 by a vote of 4-0.


Christan L. Moffett, Clerk
Illinois Pollution Control Board