

ILLINOIS POLLUTION CONTROL BOARD
April 12, 1973

ANNA STATE HOSPITAL)	
)	
v.)	PCB 73-129
)	
ENVIRONMENTAL PROTECTION AGENCY)	
)	
CITY OF CARRIER MILLS)	
)	
v.)	PCB 73-131
)	
ENVIRONMENTAL PROTECTION AGENCY)	
)	
VILLAGE OF NORRIS CITY)	
)	
v.)	PCB 73-132
)	
ENVIRONMENTAL PROTECTION AGENCY)	
)	
CITY OF HARRISBURG)	
)	
v.)	PCB 73-133
)	
ENVIRONMENTAL PROTECTION AGENCY)	
)	

INTERIM OPINION AND ORDER OF THE BOARD (by Mr. Dumelle)

All four of these cases are variance requests to add copper sulfate to a water reservoir. All are inadequate to enable the Board to decide them since they do not specify frequency and amount of dosages and the resulting copper concentration in the drinking water nor do they tell us (except for Norris City) if the reservoir


is used for fishing. None give reasons why biodegradable algicides may not be used nor whether upstream phosphorus control to prevent algae is feasible.

Petitioners are given 35 days to file amended petitions with the Board. The amended petitions shall include a waiver for 35 days of the 90 day period in which the Board has to decide a variance. Failure to file additional information within the time limit shall constitute grounds for dismissal.

The Agency is asked to provide each petitioner with copies of previous Board opinions for their guidance (City of LaHarpe, et al, PCB 72-168, August 8, 1972 and City of Paris, et al, PCB 72-277, August 15, 1972).

IT IS SO ORDERED.

I, Christan L. Moffett, Clerk of the Illinois Pollution Control Board, hereby certify the above Interim Opinion and Order were adopted on the 12th day of April, 1973 by a vote of 4-0.


Christan L. Moffett, Clerk
Illinois Pollution Control Board