

ILLINOIS POLLUTION CONTROL BOARD
May 31, 1973

ILLINOIS STATE FARM

v.

ENVIRONMENTAL PROTECTION AGENCY

PCB 73-154

ORDER OF THE BOARD (by Mr. Dumelle)

Variance is granted from Rule 203(f) of the Water Pollution Regulations to permit copper levels in excess of 0.02 mg/l subject to the following conditions;

1. Treatments with copper sulfate shall be limited to one per month for the months of May through and including October, 1973.
2. Dosage with copper sulfate shall not exceed 10 lbs. per treatment.
3. Copper concentrations at the raw water intake to the water treatment plant shall never exceed 1.0 mg/l.
4. Copper concentrations in the reservoir shall be measured immediately prior to and after each copper sulfate treatment and the results submitted to the Agency on a monthly basis.

IT IS SO ORDERED.

I, Christan L. Moffett, Clerk of the Illinois Pollution Control Board, hereby certify the above Order was adopted on the 31st day of May, 1973 by a vote of 4-0.

Christan L. Moffett, Clerk
Illinois Pollution Control Board