



OFFICE OF THE SECRETARY OF STATE

JESSE WHITE • Secretary of State

November 16, 2015



POLLUTION CONTROL BOARD
DON BROWN
100 W RANDOLPH ST
STE 11-500
CHICAGO, IL 60601

Dear DON BROWN

Your rules Listed below met our codification standards and have been published in Volume 39, Issue 47 of the Illinois Register, dated 11/20/2015.

ADOPTED RULES

Primary Drinking Water Standards
35 Ill. Adm. Code 611 15144
Point of Contact: Nancy Hoepfner

PROPOSED RULES

Permits
35 Ill. Adm. Code 309 15103
Point of Contact: Nancy Hoepfner

If you have any questions, you may contact the Administrative Code Division at (217) 782 - 7017.

ILLINOIS REGISTER

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENT

- 1) Heading of the Part: Primary Drinking Water Standards
- 2) Code Citation: 35 Ill. Adm. Code 611
- 3) Section Numbers: 611.125 Adopted Action: Amendment
- 4) Statutory Authority: Implementing Sections 9, 12, 13, 21, and 22 and authorized by Sections 27 of the Environmental Protection Act [415 ILCS 5/9, 12, 13, 21, 22, and 27].
- 5) Effective Date of Amendment: NOV - 9 2015
- 6) Does this rulemaking contain an automatic repeal date? No.
- 7) Does this amendment contain incorporations by reference? No.
- 8) The text of the adopted amendment is on file in the Board's Chicago office at the James R. Thompson Center, 100 W. Randolph Street, Suite 11-500, and is available there for public inspection.
- 9) Notice of Proposal Published in Illinois Register: June 26, 2015; 39 Ill. Reg. 8691.
- 10) Has JCAR issued a Statement of Objections to this amendment? No.
- 11) Differences between proposal and final version: Section 611.858 was not reinstated and remains repealed.
- 12) Have all the changes agreed upon by the agency and JCAR been made as indicated in the agreements letter issued by JCAR? Yes.
- 13) Will this amendment replace emergency amendments currently in effect? No.
- 14) Are there any amendments pending on this Part? Yes

<u>Section Number</u>	<u>Proposed Action</u>	<u>Illinois Register Citation</u>
611.102	Amendment	39 Ill. Reg. 12078; September 4, 2015
611.261	Amendment	39 Ill. Reg. 12078; September 4, 2015
611.262	Amendment	39 Ill. Reg. 12078; September 4, 2015
611.351	Amendment	39 Ill. Reg. 12078; September 4, 2015

RECEIVED

NOV 9 2015

SOS-CODE DIV.

ILLINOIS REGISTER

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENT

611.357	Amendment	39 Ill. Reg. 12078; September 4, 2015
611.358	Amendment	39 Ill. Reg. 12078; September 4, 2015
611.383	Amendment	39 Ill. Reg. 12078; September 4, 2015
611.609	Amendment	39 Ill. Reg. 12078; September 4, 2015
611.732	Amendment	39 Ill. Reg. 12078; September 4, 2015
611.745	Amendment	39 Ill. Reg. 12078; September 4, 2015
611.901	Amendment	39 Ill. Reg. 12078; September 4, 2015
611.902	Amendment	39 Ill. Reg. 12078; September 4, 2015
611.903	Amendment	39 Ill. Reg. 12078; September 4, 2015
611.904	Amendment	39 Ill. Reg. 12078; September 4, 2015
611.908	Amendment	39 Ill. Reg. 12078; September 4, 2015
611.909	Amendment	39 Ill. Reg. 12078; September 4, 2015
611.956	Amendment	39 Ill. Reg. 12078; September 4, 2015
611.976	Amendment	39 Ill. Reg. 12078; September 4, 2015
611.APPENDIX G	Amendment	39 Ill. Reg. 12078; September 4, 2015
611.APPENDIX H	Amendment	39 Ill. Reg. 12078; September 4, 2015

15) Summary and Purpose of Amendment: This rule updates the current fluoride standard to reflect a recent recommendation by the U.S. Department of Health and Human Services, as required by the Public Water Supply Regulation Act (415 ILCS 40). A more complete description of this proposal may be found in the Board's opinion and order of November 5, 2015 (R15-23), which is available at <http://www.ipcb.state.il.us/documents/dsweb/Get/Document-91049>.

16) Information and questions regarding this adopted amendment shall be directed to:

Marie Tipsord
Illinois Pollution Control Board
100 W. Randolph Street, Suite 11-500
Chicago, IL 60601

312-814-4925
marie.tipsord@illinois.gov

Copies of the Board's opinions and orders may be requested from the Clerk of the Board at the address listed in #8 above or by calling 312/814-3620. Please refer to the docket number R15-23 in your request. The Board order is also available from the Board's Web site (www.ipcb.state.il.us).

The full text of the Adopted Amendment begins on the next page:

ILLINOIS REGISTER

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENT

TITLE 35: ENVIRONMENTAL PROTECTION

SUBTITLE F: PUBLIC WATER SUPPLIES

CHAPTER I: POLLUTION CONTROL BOARD

PART 611

PRIMARY DRINKING WATER STANDARDS

SUBPART A: GENERAL

Section	
611.100	Purpose, Scope, and Applicability
611.101	Definitions
611.102	Incorporations by Reference
611.103	Severability
611.105	Electronic Reporting
611.107	Agency Inspection of PWS Facilities
611.108	Delegation to Local Government
611.109	Enforcement
611.110	Special Exception Permits
611.111	Relief Equivalent to SDWA Section 1415(a) Variances
611.112	Relief Equivalent to SDWA Section 1416 Exemptions
611.113	Alternative Treatment Techniques
611.114	Siting Requirements
611.115	Source Water Quantity
611.120	Effective Dates
611.121	Maximum Contaminant Levels and Finished Water Quality
611.125	Fluoridation Requirement
611.126	Prohibition on Use of Lead
611.130	Special Requirements for Certain Variances and Adjusted Standards
611.131	Relief Equivalent to SDWA Section 1415(e) Small System Variance
611.160	Composite Correction Program
611.161	Case-by-Case Reduced Subpart Y Monitoring for Wholesale and Consecutive Systems

SUBPART B: FILTRATION AND DISINFECTION

Section	
611.201	Requiring a Demonstration
611.202	Procedures for Agency Determinations
611.211	Filtration Required
611.212	Groundwater under Direct Influence of Surface Water

ILLINOIS REGISTER

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENT

611.213	No Method of HPC Analysis
611.220	General Requirements
611.230	Filtration Effective Dates
611.231	Source Water Quality Conditions
611.232	Site-Specific Conditions
611.233	Treatment Technique Violations
611.240	Disinfection
611.241	Unfiltered PWSs
611.242	Filtered PWSs
611.250	Filtration
611.261	Unfiltered PWSs: Reporting and Recordkeeping
611.262	Filtered PWSs: Reporting and Recordkeeping
611.271	Protection during Repair Work
611.272	Disinfection Following Repair
611.276	Recycle Provisions

SUBPART C: USE OF NON-CENTRALIZED TREATMENT DEVICES

Section	
611.280	Point-of-Entry Devices
611.290	Use of Point-of-Use Devices or Bottled Water

SUBPART D: TREATMENT TECHNIQUES

Section	
611.295	General Requirements
611.296	Acrylamide and Epichlorohydrin
611.297	Corrosion Control

SUBPART F: MAXIMUM CONTAMINANT LEVELS (MCLs) AND MAXIMUM RESIDUAL
DISINFECTANT LEVELS (MRDLs)

Section	
611.300	Old MCLs for Inorganic Chemical Contaminants
611.301	Revised MCLs for Inorganic Chemical Contaminants
611.310	State-Only Maximum Contaminant Levels (MCLs) for Organic Chemical Contaminants
611.311	Revised MCLs for Organic Chemical Contaminants
611.312	Maximum Contaminant Levels (MCLs) for Disinfection Byproducts (DBPs)
611.313	Maximum Residual Disinfectant Levels (MRDLs)

ILLINOIS REGISTER

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENT

- 611.320 Turbidity (Repealed)
- 611.325 Microbiological Contaminants
- 611.330 Maximum Contaminant Levels for Radionuclides
- 611.331 Beta Particle and Photon Radioactivity (Repealed)

SUBPART G: LEAD AND COPPER

- Section
- 611.350 General Requirements
- 611.351 Applicability of Corrosion Control
- 611.352 Corrosion Control Treatment
- 611.353 Source Water Treatment
- 611.354 Lead Service Line Replacement
- 611.355 Public Education and Supplemental Monitoring
- 611.356 Tap Water Monitoring for Lead and Copper
- 611.357 Monitoring for Water Quality Parameters
- 611.358 Monitoring for Lead and Copper in Source Water
- 611.359 Analytical Methods
- 611.360 Reporting
- 611.361 Recordkeeping

SUBPART I: DISINFECTANT RESIDUALS, DISINFECTION BYPRODUCTS, AND
DISINFECTION BYPRODUCT PRECURSORS

- Section
- 611.380 General Requirements
- 611.381 Analytical Requirements
- 611.382 Monitoring Requirements
- 611.383 Compliance Requirements
- 611.384 Reporting and Recordkeeping Requirements
- 611.385 Treatment Technique for Control of Disinfection Byproduct (DBP) Precursors

SUBPART K: GENERAL MONITORING AND ANALYTICAL REQUIREMENTS

- Section
- 611.480 Alternative Analytical Techniques
- 611.490 Certified Laboratories
- 611.491 Laboratory Testing Equipment
- 611.500 Consecutive PWSs
- 611.510 Special Monitoring for Unregulated Contaminants (Repealed)

ILLINOIS REGISTER

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENT

SUBPART L: MICROBIOLOGICAL MONITORING
AND ANALYTICAL REQUIREMENTS

Section

611.521	Routine Coliform Monitoring
611.522	Repeat Coliform Monitoring
611.523	Invalidation of Total Coliform Samples
611.524	Sanitary Surveys
611.525	Fecal Coliform and E. Coli Testing
611.526	Analytical Methodology
611.527	Response to Violation
611.528	Transition from Subpart L to Subpart AA Requirements
611.531	Analytical Requirements
611.532	Unfiltered PWSs
611.533	Filtered PWSs

SUBPART M: TURBIDITY MONITORING AND ANALYTICAL REQUIREMENTS

Section

611.560	Turbidity
---------	-----------

SUBPART N: INORGANIC MONITORING AND ANALYTICAL REQUIREMENTS

Section

611.591	Violation of a State MCL
611.592	Frequency of State Monitoring
611.600	Applicability
611.601	Monitoring Frequency
611.602	Asbestos Monitoring Frequency
611.603	Inorganic Monitoring Frequency
611.604	Nitrate Monitoring
611.605	Nitrite Monitoring
611.606	Confirmation Samples
611.607	More Frequent Monitoring and Confirmation Sampling
611.608	Additional Optional Monitoring
611.609	Determining Compliance
611.610	Inorganic Monitoring Times
611.611	Inorganic Analysis
611.612	Monitoring Requirements for Old Inorganic MCLs

ILLINOIS REGISTER

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENT

- 611.630 Special Monitoring for Sodium
- 611.631 Special Monitoring for Inorganic Chemicals (Repealed)

SUBPART O: ORGANIC MONITORING AND ANALYTICAL REQUIREMENTS

- Section
- 611.640 Definitions
- 611.641 Old MCLs
- 611.645 Analytical Methods for Organic Chemical Contaminants
- 611.646 Phase I, Phase II, and Phase V Volatile Organic Contaminants
- 611.647 Sampling for Phase I Volatile Organic Contaminants (Repealed)
- 611.648 Phase II, Phase IIB, and Phase V Synthetic Organic Contaminants
- 611.650 Monitoring for 36 Contaminants (Repealed)
- 611.657 Analytical Methods for 36 Contaminants (Repealed)
- 611.658 Special Monitoring for Organic Chemicals (Repealed)

SUBPART P: THM MONITORING AND ANALYTICAL REQUIREMENTS

- Section
- 611.680 Sampling, Analytical, and other Requirements (Repealed)
- 611.683 Reduced Monitoring Frequency (Repealed)
- 611.684 Averaging (Repealed)
- 611.685 Analytical Methods (Repealed)
- 611.686 Modification to System (Repealed)
- 611.687 Sampling for THM Potential (Repealed)
- 611.688 Applicability Dates (Repealed)

SUBPART Q: RADIOLOGICAL MONITORING AND ANALYTICAL REQUIREMENTS

- Section
- 611.720 Analytical Methods
- 611.731 Gross Alpha
- 611.732 Beta Particle and Photon Radioactivity
- 611.733 General Monitoring and Compliance Requirements

SUBPART R: ENHANCED FILTRATION AND DISINFECTION: SYSTEMS THAT
SERVE 10,000 OR MORE PEOPLE

- Section
- 611.740 General Requirements

ILLINOIS REGISTER

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENT

611.741	Standards for Avoiding Filtration
611.742	Disinfection Profiling and Benchmarking
611.743	Filtration
611.744	Filtration Sampling Requirements
611.745	Reporting and Recordkeeping Requirements

SUBPART S: GROUNDWATER RULE

Section	
611.800	General Requirements and Applicability
611.801	Sanitary Surveys for GWS Suppliers
611.802	Groundwater Source Microbial Monitoring and Analytical Methods
611.803	Treatment Technique Requirements for GWS Suppliers
611.804	Treatment Technique Violations for GWS Suppliers
611.805	Reporting and Recordkeeping for GWS Suppliers

SUBPART T: REPORTING AND RECORDKEEPING

Section	
611.830	Applicability
611.831	Monthly Operating Report
611.832	Notice by Agency (Repealed)
611.833	Cross Connection Reporting
611.840	Reporting
611.851	Reporting MCL, MRDL, and other Violations (Repealed)
611.852	Reporting other Violations (Repealed)
611.853	Notice to New Billing Units (Repealed)
611.854	General Content of Public Notice (Repealed)
611.855	Mandatory Health Effects Language (Repealed)
611.856	Fluoride Notice (Repealed)
611.858	Fluoride Secondary Standard (Repealed)
611.860	Record Maintenance
611.870	List of 36 Contaminants (Repealed)

SUBPART U: CONSUMER CONFIDENCE REPORTS

Section	
611.881	Purpose and Applicability
611.882	Compliance Dates
611.883	Content of the Reports

ILLINOIS REGISTER

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENT

- 611.884 Required Additional Health Information
- 611.885 Report Delivery and Recordkeeping

SUBPART V: PUBLIC NOTIFICATION OF DRINKING WATER VIOLATIONS

- Section
- 611.901 General Public Notification Requirements
- 611.902 Tier 1 Public Notice: Form, Manner, and Frequency of Notice
- 611.903 Tier 2 Public Notice: Form, Manner, and Frequency of Notice
- 611.904 Tier 3 Public Notice: Form, Manner, and Frequency of Notice
- 611.905 Content of the Public Notice
- 611.906 Notice to New Billing Units or New Customers
- 611.907 Special Notice of the Availability of Unregulated Contaminant Monitoring Results
- 611.908 Special Notice for Exceedence of the Fluoride Secondary Standard
- 611.909 Special Notice for Nitrate Exceedences above the MCL by a Non-Community Water System
- 611.910 Notice by the Agency on Behalf of a PWS
- 611.911 Special Notice for Cryptosporidium

SUBPART W: INITIAL DISTRIBUTION SYSTEM EVALUATIONS

- Section
- 611.920 General Requirements
- 611.921 Standard Monitoring
- 611.922 System-Specific Studies
- 611.923 40/30 Certification
- 611.924 Very Small System Waivers
- 611.925 Subpart Y Compliance Monitoring Location Recommendations

SUBPART X: ENHANCED FILTRATION AND DISINFECTION-SYSTEMS SERVING
FEWER THAN 10,000 PEOPLE

- Section
- 611.950 General Requirements
- 611.951 Finished Water Reservoirs
- 611.952 Additional Watershed Control Requirements for Unfiltered Systems
- 611.953 Disinfection Profile
- 611.954 Disinfection Benchmark
- 611.955 Combined Filter Effluent Turbidity Limits
- 611.956 Individual Filter Turbidity Requirements

ILLINOIS REGISTER

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENT

611.957 Reporting and Recordkeeping Requirements

SUBPART Y: STAGE 2 DISINFECTION BYPRODUCTS REQUIREMENTS

Section

611.970 General Requirements
611.971 Routine Monitoring
611.972 Subpart Y Monitoring Plan
611.973 Reduced Monitoring
611.974 Additional Requirements for Consecutive Systems
611.975 Conditions Requiring Increased Monitoring
611.976 Operational Evaluation Levels
611.977 Requirements for Remaining on Reduced TTHM and HAA5 Monitoring Based on Subpart I Results
611.978 Requirements for Remaining on Increased TTHM and HAA5 Monitoring Based on Subpart I Results
611.979 Reporting and Recordkeeping Requirements

SUBPART Z: ENHANCED TREATMENT FOR CRYPTOSPORIDIUM

Section

611.1000 General Requirements
611.1001 Source Water Monitoring Requirements: Source Water Monitoring
611.1002 Source Water Monitoring Requirements: Sampling Schedules
611.1003 Source Water Monitoring Requirements: Sampling Locations
611.1004 Source Water Monitoring Requirements: Analytical Methods
611.1005 Source Water Monitoring Requirements: Approved Laboratories
611.1006 Source Water Monitoring Requirements: Reporting Source Water Monitoring Results
611.1007 Source Water Monitoring Requirements: Grandfathering Previously Collected Data
611.1008 Disinfection Profiling and Benchmarking Requirements: Requirements When Making a Significant Change in Disinfection Practice
611.1009 Disinfection Profiling and Benchmarking Requirements: Developing the Disinfection Profile and Benchmark
611.1010 Treatment Technique Requirements: Bin Classification for Filtered Systems
611.1011 Treatment Technique Requirements: Filtered System Additional Cryptosporidium Treatment Requirements
611.1012 Treatment Technique Requirements: Unfiltered System Cryptosporidium Treatment Requirements

ILLINOIS REGISTER

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENT

- 611.1013 Treatment Technique Requirements: Schedule for Compliance with Cryptosporidium Treatment Requirements
- 611.1014 Treatment Technique Requirements: Requirements for Uncovered Finished Water Storage Facilities
- 611.1015 Requirements for Microbial Toolbox Components: Microbial Toolbox Options for Meeting Cryptosporidium Treatment Requirements
- 611.1016 Requirements for Microbial Toolbox Components: Source Toolbox Components
- 611.1017 Requirements for Microbial Toolbox Components: Pre-Filtration Treatment Toolbox Components
- 611.1018 Requirements for Microbial Toolbox Components: Treatment Performance Toolbox Components
- 611.1019 Requirements for Microbial Toolbox Components: Additional Filtration Toolbox Components
- 611.1020 Requirements for Microbial Toolbox Components: Inactivation Toolbox Components
- 611.1021 Reporting and Recordkeeping Requirements: Reporting Requirements
- 611.1022 Reporting and Recordkeeping Requirements: Recordkeeping Requirements
- 611.1023 Requirements to Respond to Significant Deficiencies Identified in Sanitary Surveys Performed by USEPA or the Agency

SUBPART AA: REVISED TOTAL COLIFORM RULE

Section

- 611.1051 General
 - 611.1052 Analytical Methods and Laboratory Certification
 - 611.1053 General Monitoring Requirements for all PWSs
 - 611.1054 Routine Monitoring Requirements for Non-CWSs That Serve 1,000 or Fewer People Using Only Groundwater
 - 611.1055 Routine Monitoring Requirements for CWSs That Serve 1,000 or Fewer People Using Only Groundwater
 - 611.1056 Routine Monitoring Requirements for Subpart B Systems That Serve 1,000 or Fewer People
 - 611.1057 Routine Monitoring Requirements for PWSs That Serve More Than 1,000 People
 - 611.1058 Repeat Monitoring and E. coli Requirements
 - 611.1059 Coliform Treatment Technique Triggers and Assessment Requirements for Protection Against Potential Fecal Contamination
 - 611.1060 Violations
 - 611.1061 Reporting and Recordkeeping
- 611.APPENDIX A Regulated Contaminants

ILLINOIS REGISTER

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENT

611.APPENDIX B	Percent Inactivation of G. Lamblia Cysts
611.APPENDIX C	Common Names of Organic Chemicals
611.APPENDIX D	Defined Substrate Method for the Simultaneous Detection of Total Coliforms and Eschericia Coli from Drinking Water
611.APPENDIX E	Mandatory Lead Public Education Information for Community Water Systems
611.APPENDIX F	Mandatory Lead Public Education Information for Non-Transient Non-Community Water Systems
611.APPENDIX G	NPDWR Violations and Situations Requiring Public Notice
611.APPENDIX H	Standard Health Effects Language for Public Notification
611.APPENDIX I	Acronyms Used in Public Notification Regulation
611.TABLE A	Total Coliform Monitoring Frequency
611.TABLE B	Fecal or Total Coliform Density Measurements
611.TABLE C	Frequency of RDC Measurement
611.TABLE D	Number of Lead and Copper Monitoring Sites
611.TABLE E	Lead and Copper Monitoring Start Dates
611.TABLE F	Number of Water Quality Parameter Sampling Sites
611.TABLE G	Summary of Section 611.357 Monitoring Requirements for Water Quality Parameters
611.TABLE H	CT Values (mg·min/ℓ) for Cryptosporidium Inactivation by Chlorine Dioxide
611.TABLE I	CT Values (mg·min/ℓ) for Cryptosporidium Inactivation by Ozone
611.TABLE J	UV Dose Table for Cryptosporidium, Giardia lamblia, and Virus Inactivation Credit
611.TABLE Z	Federal Effective Dates

AUTHORITY: Implementing Sections 7.2, 17, and 17.5 and authorized by Section 27 of the Environmental Protection Act [415 ILCS 5/7.2, 17, 17.5, and 27].

SOURCE: Adopted in R88-26 at 14 Ill. Reg. 16517, effective September 20, 1990; amended in R90-21 at 14 Ill. Reg. 20448, effective December 11, 1990; amended in R90-13 at 15 Ill. Reg. 1562, effective January 22, 1991; amended in R91-3 at 16 Ill. Reg. 19010, effective December 1, 1992; amended in R92-3 at 17 Ill. Reg. 7796, effective May 18, 1993; amended in R93-1 at 17 Ill. Reg. 12650, effective July 23, 1993; amended in R94-4 at 18 Ill. Reg. 12291, effective July 28, 1994; amended in R94-23 at 19 Ill. Reg. 8613, effective June 20, 1995; amended in R95-17 at 20 Ill. Reg. 14493, effective October 22, 1996; amended in R98-2 at 22 Ill. Reg. 5020, effective March 5, 1998; amended in R99-6 at 23 Ill. Reg. 2756, effective February 17, 1999; amended in R99-12 at 23 Ill. Reg. 10348, effective August 11, 1999; amended in R00-8 at 23 Ill. Reg. 14715, effective December 8, 1999; amended in R00-10 at 24 Ill. Reg. 14226, effective September 11, 2000; amended in R01-7 at 25 Ill. Reg. 1329, effective January 11, 2001; amended in R01-20 at 25 Ill.

ILLINOIS REGISTER

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENT

Reg. 13611, effective October 9, 2001; amended in R02-5 at 26 Ill. Reg. 3522, effective February 22, 2002; amended in R03-4 at 27 Ill. Reg. 1183, effective January 10, 2003; amended in R03-15 at 27 Ill. Reg. 16447, effective October 10, 2003; amended in R04-3 at 28 Ill. Reg. 5269, effective March 10, 2004; amended in R04-13 at 28 Ill. Reg. 12666, effective August 26, 2004; amended in R05-6 at 29 Ill. Reg. 2287, effective January 28, 2005; amended in R06-15 at 30 Ill. Reg. 17004, effective October 13, 2006; amended in R07-2/R07-11 at 31 Ill. Reg. 11757, effective July 27, 2007; amended in R08-7/R08-13 at 33 Ill. Reg. 633, effective December 30, 2008; amended in R10-1/R10-17/R11-6 at 34 Ill. Reg. 19848, effective December 7, 2010; amended in R12-4 at 36 Ill. Reg. 7110, effective April 25, 2012; amended in R13-2 at 37 Ill. Reg. 1978, effective February 4, 2013; amended in R14-8 at 38 Ill. Reg. 3608, effective January 27, 2014; amended in R14-9 at 38 Ill. Reg. 9792, effective April 21, 2014; amended in R15-6 at 39 Ill. Reg. 3713, effective February 24, 2015; amended in R15-23 at 39 Ill. Reg. _____, effective _____.

SUBPART A: GENERAL

Section 611.125 Fluoridation Requirement

All CWSs that are required to add fluoride to the water must maintain a fluoride ion concentration, reported as F, of 0.7 to 1.2 mg/ℓ in its distribution system, ~~as required by Section 7a of the Public Water Supply Regulation Act [415 ILCS 40/7a].~~

BOARD NOTE: This is an additional State requirement.

(Source: Amended at 39 Ill. Reg. _____, effective _____)