

BEFORE THE ILLINOIS POLLUTION CONTROL BOARD

SIERRA CLUB, )  
)  
Complainant, ) PCB 2014-134  
) (Enforcement-Air)  
v. )  
)  
AMEREN ENERGY MEDINA VALLEY ) NOTICE OF FILING  
COGEN, LLC )  
)  
and )  
)  
FUTUREGEN INDUSTRIAL ALLIANCE INC., )  
)  
Respondents. )

---

**NOTICE OF FILING**

To:

Eric M. Schwing  
1100 South 5th Street  
Springfield, IL 62703  
T: 217-544-4440  
E: eric.scwing@comcast.net

Eva Schueller  
Sierra Club Environmental Law Program  
85 Second St., Second Floor  
San Francisco, CA 94105  
T: 415-977-5637  
E: eva.schueller@sierraclub.org

Dale N. Johnson  
Van Ness Feldman LLP  
719 Second Avenue, Suite 1150  
Seattle, WA 98104  
T: 206-623-9372  
E: dnj@vnf.com

Christopher D. Zentz  
Van Ness Feldman LLP  
719 Second Avenue, Suite 1150  
Seattle, WA 98104  
T: 206-623-9372  
E: cdz@vnf.com

Pollution Control Board, Attn: Clerk  
100 West Randolph Street  
James R. Thompson Center, Suite 11-500  
Chicago, IL 60601-3218

PLEASE TAKE NOTICE that I have today filed with the Illinois Pollution Control Board **DEFENDANTS' MOTION FOR SUMMARY JUDGMENT, MEMORANDUM IN SUPPORT OF DEFENDANTS' MOTION FOR SUMMARY JUDGMENT, AND DECLARATION OF RENEE CIPRIANO.**

Date: July 15, 2014



---

Ashley L. Thompson  
Schiff Hardin LLP  
233 South Wacker Drive, Suite 6600  
Chicago, Illinois 60606  
Tel: 312-258-5500

Attorney for Defendant  
AmerenEnergy Medina Valley Cogen, LLC

26787-0060  
CH2\14975652.1

BEFORE THE ILLINOIS POLLUTION CONTROL BOARD

SIERRA CLUB,	)		
	)		
Complainant,	)	PCB 2014-134	
	)	(Enforcement-Air)	
v.	)		
	)		
AMEREN ENERGY MEDINA VALLEY	)	DEFENDANTS' MOTION	FOR
COGEN, LLC	)	SUMMARY JUDGMENT	
	)		
and	)		
	)		
FUTUREGEN INDUSTRIAL ALLIANCE INC.,	)		
	)		
Respondents.	)		

---

**DEFENDANTS' MOTION FOR SUMMARY JUDGMENT**

Defendant AmerenEnergy Medina Valley Cogen, LLC ("Ameren") and FutureGen Industrial Alliance, Inc. ("FutureGen") (collectively, "Defendants") bring this Motion for Summary Judgment pursuant to Section 101.56 of the Illinois Pollution Control Board's ("Board") Procedural Regulations, 35 Ill. Adm. Code 101.516 and Section 2-1005 of the Illinois Code of Civil Procedure, 735 ICLS 5/2-1005. Said motion should be granted for the following reasons:

1. Sierra Club's Complaint is premised on Defendants' Project not being appropriately permitted.
2. However, Defendants' Project is appropriately permitted, as Sierra Club knows from having participated in the permitting process overseen by IEPA and U.S. EPA.
3. Sierra Club filed a lawsuit in U.S. District Court alleging violations of the federal Clean Air Act ("CAA"), 42 U.S.C. § 7401 *et seq.*
4. The U.S. District Court dismissed Sierra Club's claim on June 10, 2014.

5. Sierra Club now brings its claim against Defendants, contending that Defendants have violated and continue to violate Section 9.1(d) of the Illinois Environmental Protection Act by proposing and constructing the FutureGen 2.0 Project. 415 ILCS 5/9.1(d).

6. IEPA has issued a Minor Source Construction Permit for the Project.

7. Defendants' construction of the Project is pursuant to the terms of this Permit and is lawful, and Sierra Club presents no arguments to the contrary.

8. A memorandum of law accompanies this motion and is incorporated herein.

9. Defendants accordingly move to have this Board enter summary judgment in favor of Defendants and for any other such relief as the Board deems just and proper.

DATED this 15th day of July, 2014.

*/s/ Dale N. Johnson (by consent)*

---

Dale N. Johnson  
Christopher D. Zentz  
Van Ness Feldman LLP  
719 Second Avenue, Suite 1150  
Seattle, WA 98104-1728  
Tel: 206-623-9372

Attorneys for Defendant  
FutureGen Industrial Alliance, Inc.



Renee Cipriano, *Lead Counsel*  
J. Michael Showalter  
Ashley L. Thompson  
Schiff Hardin LLP  
233 South Wacker Drive, Suite 6600  
Chicago, Illinois 60606  
Tel: 312-258-5500

Attorneys for Defendant  
AmerenEnergy Medina Valley Cogen, LLC

BEFORE THE ILLINOIS POLLUTION CONTROL BOARD

SIERRA CLUB,	)	
	)	
Complainant,	)	PCB 2014-134
	)	(Enforcement-Air)
v.	)	
	)	
AMEREN ENERGY MEDINA VALLEY	)	DEFENDANTS' MEMORANDUM
COGEN, LLC	)	IN SUPPORT OF THEIR MOTION
	)	FOR SUMMARY JUDGMENT
and	)	
	)	
FUTUREGEN INDUSTRIAL ALLIANCE INC.,	)	
	)	
Respondents.	)	

---

**DEFENDANTS' MEMORANDUM IN SUPPORT OF THEIR  
MOTION FOR SUMMARY JUDGMENT**

**I. INTRODUCTION**

FutureGen Industrial Alliance Inc. ("Futuregen"), Ameren Energy Medina Valley Cogen, LLC ("Ameren") [collectively "Defendants"], the United States Department of Energy, federal and state elected officials and others have long worked to support and construct a state-of-the-art clean coal demonstration project called FutureGen 2.0 Project ("Project") at Ameren's existing Meredosia Energy Center in Meredosia, Illinois. The Project is designed to capture at least 90 percent of the power plant's carbon dioxide (CO<sub>2</sub>) emissions and reduce other conventional emissions to levels far lower than existing, conventional coal-fired power plants currently can achieve. IEPA has already issued the necessary air-related construction permits for the Project and the Defendants are in compliance with all applicable state and federal statutes and regulations.

Sierra Club's challenge before this Board is a third attempt to derail the Project. Sierra Club's first attempt to stop the Project was rejected by the Illinois Environmental Protection Agency ("IEPA") during the permitting process. After that, Sierra Club filed a lawsuit in U.S. District Court alleging violations of the federal Clean Air Act ("CAA"). 42 U.S.C. § 7401 *et seq.* The U.S. District Court dismissed Sierra Club's claim on June 10, 2014. Sierra Club now brings

its claim against Defendants, contending that Defendants have violated and continue to violate Section 9.1(d) of the Illinois Environmental Protection Act by proposing and constructing the FutureGen 2.0 Project. 415 ILCS 5/9.1(d). Specifically, Sierra Club asserts that Defendants are violating the Act by proposing and constructing the Project without a Prevention of Significant Deterioration (“PSD”) Permit. Defendants are not violating the Act because Defendants have the legally required permit to construct.

The questions present in this case are questions of law, not fact. There is no dispute that IEPA has issued a Minor Source Construction Permit for the Project. (Construction Permit, attached to the Cipriano Declaration filed herewith as Exh. 1.) Defendants’ construction of the Project pursuant to the terms of this Permit is lawful and Sierra Club presents no arguments to the contrary. The Project is not subject to federal PSD permit requirements under 42 U.S.C. § 7475 and 40 C.F.R. § 52.21, Sierra Club’s assertions to the contrary are without merit, and its claim should be summarily denied.

## **II. STATUTORY AND REGULATORY BACKGROUND**

The CAA involves a complex and comprehensive legislative scheme to protect and improve the nation’s air quality. *See Sierra Club v. Larson*, 2 F.3d 462, 464 (1st Cir. 1993). Under the CAA, states retain “the primary responsibility for formulating pollution control strategies.” *Union Elec. Co. v. Envtl. Prot. Agency*, 427 U.S. 246, 256 (1976); *see also* 42 U.S.C. § 7410(a). But the CAA subjects “the States to strict minimum compliance requirements.” *Union Elec.*, 427 U.S. at 256-57.

Broadly speaking, Title I of the CAA regulates stationary sources of pollution, and Title II regulates mobile sources, including motor vehicles and transportation fuels. For criteria air pollutants, national ambient air quality standards (“NAAQS”) are promulgated by the United States Environmental Protection Agency (“USEPA”) to ensure the protection of health with an adequate margin of safety. 42 U.S.C. § 7409. The type of new construction at a major stationary source of air pollution permitted in an area, and what kind of controls are required, depends on

whether the area has attained the NAAQS set for each specified pollutant; that is, whether it is an “attainment” area or a “non-attainment” area. *Id.*

Part C of subchapter I of the CAA (“Part C”), 42 U.S.C. §§ 7470-7492, governs permit requirements in geographical areas where the NAAQS standards have been attained (attainment areas).<sup>1</sup> Among other things, Part C prohibits the construction of a new or modified “Major Emitting Facility” in an attainment or unclassifiable area, unless a permit has been issued. *See* 42 U.S.C. § 7475(a); *see also* 40 C.F.R. §§ 52.21 & 51.166. Power plants such as the Meredosia Energy Center are classified as “Major Emitting Facilities” and “Major Stationary Sources” for the purpose of federal implementing regulations. 42 U.S.C. § 7479(1); 40 C.F.R. § 52.21(b)(1)(i)(a).

To comply with Part C, a “Major Emitting Facility” or “Major Stationary Source” must obtain a Prevention of Significant Deterioration or “PSD” permit before commencing on-site construction of a new major stationary source at an entirely new site or before commencing construction to modify an existing major stationary source. *See* 42 U.S.C. § 7479(2). A two-part test is used to determine when modification of an existing major source requires a PSD permit. First, there must be a physical change or change in the method of operation that is not categorically exempt by regulation from the PSD permitting program, such as “routine maintenance, repair and replacement” projects, or an increase in hours of operation or rate of production. 40 C.F.R. § 52.21(b)(2)(iii). Second, the non-exempt physical or operational change must result in a “significant net emissions increase” above baseline actual emissions levels for any particular regulated air pollutant. 40 C.F.R. § 52.21(a)(2)(iv)(a).<sup>2</sup>

---

<sup>1</sup> Part D of subchapter I of the Act (“Part D”), 42 U.S.C. §§ 7501-7515, applies to “nonattainment” areas. The CAA requires that each state designate those areas within its boundaries where the air quality is better or worse than the ambient air quality standard for each type of pollutant, or where the air quality cannot be classified because of insufficient data. *See* 42 U.S.C. § 7407(d). Areas that do not meet the applicable standard for a particular pollutant are classified as “nonattainment”; areas that do are classified as “attainment”; and, areas that cannot be classified because of insufficient data are designated “unclassified.” *Id.* at (i)-(iii).

<sup>2</sup> Baseline actual emissions means the average rate, in tons per year, at which the unit actually emitted during any consecutive 24-month period within the 5-year period immediately preceding the commencement of construction of the project. 40 C.F.R. § 52.21(b)(48)(i). When a project involves only changes to existing emission units, then the

USEPA delegated its authority to issue PSD permits to IEPA in 1980 and IEPA has implemented the PSD permitting process since then. 46 Fed. Reg. 9582 (Jan. 29, 1981). Because IEPA has the authority to administer the federal PSD program, IEPA is authorized to determine whether a PSD permit is required. *Id. See also* 40 C.F.R. § 52.21(u). In addition, IEPA has properly obtained full authority to issue CAA permits for those stationary sources that are not subject to the PSD permitting requirements. *See, e.g.*, 35 Ill. Adm. Code § 201.142.

### III. UNDISPUTED MATERIAL FACTS

The FutureGen Industrial Alliance (“Alliance”) will modify a portion of Ameren’s existing Meredosia Energy Center in Meredosia, Illinois, by constructing a coal-fired oxy-combustion system equipped with carbon capture and sequestration technology. The Alliance and Ameren submitted an initial application to IEPA for a CAA permit to authorize the construction of the Project on February 9, 2012, and then submitted a revised permit application on June 18, 2013. IEPA issued a draft construction permit in August 2013. From August 24, 2013 through November 8, 2013, IEPA held a public comment period to hear concerns about the draft construction permit.<sup>3</sup> On October 9, 2013, IEPA held a public hearing, and on December 13, 2013, the IEPA issued a final Construction Permit for the Project. (*See generally* Construction Permit.) IEPA issued a construction permit for the Project pursuant to its authority

---

emissions increase determination is based on comparing actual emissions to projected actual emissions. 40 C.F.R. § 52.21(a)(2)(iv)(c); *see also* 40 C.F.R. § 52.21(b)(41). For projects that involve only the construction of new emissions units, actual emissions are compared to potential emissions. 40 C.F.R. § 52.21(a)(2)(iv)(d); *see also* 40 C.F.R. § 52.21(b)(4). Finally, for projects that include both changes to existing units and the construction of new emissions units, the determination depends on the sum of the emissions increases as determined using the actual-to-projected-actual test for the changes to existing units and the actual-to-potential test for new units. 40 C.F.R. § 52.21(a)(2)(iv)(f). This is known as the “hybrid test.”

<sup>3</sup> The Sierra Club provided extensive comments about the Project during the IEPA permit review process. Sierra Club’s written comments (“Sierra Club Comments”) are filed with the Cipriano Declaration filed herewith as Exhibit 2. The Sierra Club comments included claims that the Project was subject to the PSD permit requirements. (*See* Sierra Club Comments at 2.) IEPA considered and addressed in detail the Sierra Club comments when it issued the final Construction Permit for the Project and, in so doing, revised the draft construction permit to account for relevant comments raised by the Sierra Club and other commenters. (*See generally* Responsiveness Summary for Public Questions and Comments on the Applications for Air Pollution Control (“Responsiveness Summary”), filed with the Cipriano Declaration filed herewith as Exhibit 3.)



to issue such permits. *See* 42 U.S.C. § 7410(a)(2)(C); 35 Ill. Adm. Code § 201.142; 46 Fed. Reg. 9582 (Jan. 29, 1981).

The Construction Permit for the Project was issued by IEPA under the State of Illinois' Minor Source Permit Program. 35 Ill. Adm. Code § 201.142.<sup>4</sup> The Construction Permit specifies that the permit shall expire on August 31, 2014 if commencement of construction of the oxy-combustion boiler does not begin before this date. (Construction Permit at ¶ 1.2a.) The Construction Permit requires that upon startup of the oxy-combustion boiler, Boilers 1 through 6 at the Meredosia Energy Center must be permanently shut down. (Construction Permit at ¶ 1.2b.) The Construction Permit establishes general and specific New Source Performance Standards ("NSPS") pursuant to 40 C.F.R. Part 60, for new emissions units that are part of the Project, including the oxy-combustion boiler, the auxiliary boiler, and the new coal handling operations and establishes other requirements, limitations and other Project operational standards. (Construction Permit at ¶¶ 1.4, 2.1, 2.2, 2.3, 2.4, 2.6.)<sup>5</sup>

#### IV. ARGUMENT

##### A. Summary Judgment Standard.

"If the record, including pleadings, depositions and admissions on file, together with any affidavits, shows that there is no genuine issue of material fact, and that the moving party is entitled to judgment as a matter of law, the Board will enter summary judgment." 35 Ill. Adm. Code § 101.516(b). "Summary judgment is proper where, when viewed in the light most favorable to the nonmoving party, the pleadings, depositions, admissions, and affidavits on file reveal that there is no genuine issue as to any material fact and that the moving party is entitled

---

<sup>4</sup> 42 U.S.C. § 7410(a)(2)(C); 40 C.F.R. § 52.23.

<sup>5</sup> IEPA applied the PSD netting rules to the Project. (Construction Permit at 3-5; Responsiveness Summary at ¶¶ 6, 18, 20, 21, 22, 23, 34, 35, 36, 44, 45, 49, 61.) IEPA determined that the Project will result in a "significant emissions increase" of PSD regulated pollutants, but that the Project will not result in a significant "net emissions increase" of those pollutants under the PSD netting rules. (Construction Permit at 3.) Although IEPA's decision-making process is not at issue in this case, IEPA concluded that a PSD permit is not necessary to authorize the construction of the Project. (Construction Permit at 3.)

to judgment as a matter of law.” *Gen. Cas. Ins. Co. v. Lacey*, 199 Ill.2d 281, 284, 263 Ill.Dec. 816, 769 N.E.2d 18 (Ill. 2002). “[U]nsupported conclusions, opinions, or speculation are insufficient to raise a genuine issue of material fact.” *Outboard Marine Corp. v. Liberty Mut. Ins. Co.*, 154 Ill.2d 90, 132, 180 Ill.Dec. 691, 607 N.E.2d 1204 (Ill. 1992).

**B. Defendants have the Permits Required to Construct the FutureGen 2.0 Project because No PSD Permit is Required.**

Illinois regulations implementing the Illinois Environmental Protection Act provide that “[n]o person shall cause or allow the construction of any new emission source or any new air pollution control equipment, or cause or allow the modification of any existing emission source or air pollution control equipment, without first obtaining a construction permit from the Agency. . .” 35 Ill. Admin. Code § 201.142. In this case, a permitting process existed, which was in fact overseen by USEPA, and it is through this permit process that IEPA awarded Defendants the appropriate construction permit for the Project. Thus, Defendants have obtained the required permit. Sierra Club’s allegation that Defendants are proposing to construct or are constructing without a PSD Permit ignores both (1) IEPA’s explicit conclusion that no PSD permit is required for this Project; and (2) that U.S. EPA did not object to the Agency’s draft construction permit or final permit decision.

IEPA is the appropriate agency to address Sierra Club’s concerns and it has already determined that a PSD permit is not required for the Project. A project is subject to PSD review only if the modification will result in both (1) a “significant emissions increase” of a regulated pollutant, and (2) a “significant net emissions increase” of that pollutant from the major stationary source. 40 C.F.R. § 52.21(b)(2), (b)(3), (b)(40), and (b)(50). Because IEPA has determined that there is no significant net emissions increase resulting from the proposed modifications to the Meredosia Energy Center, the Project does not require a PSD permit. This determination was specifically documented in the Responsiveness Summary that IEPA prepared in support of its permit decision. (Responsiveness Summary at 17) (stating that “net increases in emissions of regulated NSR pollutants from this Project will not be significant.”)

In making the determination as to whether the Project would result in a significant net emissions increase, the IEPA was required to consider all “contemporaneous” emissions increases and decreases that have occurred for each PSD-regulated pollutant within the entire Meredosia Energy Center facility, which was largely shut down contemporaneous with the Project’s projected construction. (Responsiveness Summary at 17) (concluding that emissions decreases for “the shutdown of the existing boilers at the Meredosia Energy Center . . . are creditable and may be considered in the netting analysis for the proposed project.”). When past emissions at the Meredosia Energy Center are considered under applicable USEPA approved “netting” rules, the Project will not result in a significant net increase in emissions for any PSD-regulated pollutant. IEPA correctly determined that the Defendants were not required to obtain a PSD permit for the Project. (Construction Permit at ¶ 3; Source-Wide Condition 1.2.b.)

This conclusion is evident in the Construction Permit, where IEPA provided a thorough explanation of its decision. Paragraph 3 of the Construction Permit provides:

This project is not subject to federal [PSD] rules . . . because the project will not be accompanied by significant increases in emissions of PSD pollutants, considering the past actual emissions of the Meredosia Energy Center . . . . For this purpose, emissions from the sequestration facility have also been considered because this facility is considered to be a support facility for this new oxycombustion power plant under the PSD rules.

(Construction Permit at ¶ 3.) Similarly, source-wide condition 1.2.b of the Construction Permit provides:

This permit is issued based on this project not being a major modification subject to PSD because it will be accompanied by contemporaneous decreases in emissions such that the increases or net increases in emissions of PSD pollutants are not significant, as further described in Attachment 1, Tables 1A and 1B.

(Construction Permit at Source-Wide Condition 1.2.b.) Sierra Club’s claims, already rejected by IEPA and USEPA, should not be re-evaluated by the IPCB when the relevant, appropriate legal decision makers have already reached a contrary determination.

V. CONCLUSION

Based on the foregoing, there is no factual or legal basis to conclude that Defendants are in violation of state or federal law. IEPA has issued the required Construction Permit for the Project. Proceeding with Project construction pursuant to this lawfully issued permit does not constitute a violation of the Illinois Environmental Protection Act. Defendants therefore move to have this Board enter summary judgment in favor of Defendants and for any other such relief as the Board deems just and proper.


DATED this 15th day of July, 2014.

*Dale N. Johnson (by consent)*

---

Dale N. Johnson  
Christopher D. Zentz  
Van Ness Feldman LLP  
719 Second Avenue, Suite 1150  
Seattle, WA 98104-1728  
Tel: 206-623-9372

Attorneys for Defendant  
FutureGen Industrial Alliance, Inc.



Renee Cipriano, *Lead Counsel*  
J. Michael Showalter  
Ashley L. Thompson  
Schiff Hardin LLP  
233 South Wacker Drive, Suite 6600  
Chicago, Illinois 60606  
Tel: 312-258-5500

Attorneys for Defendant  
AmerenEnergy Medina Valley Cogen, LLC

**BEFORE THE ILLINOIS POLLUTION CONTROL BOARD**

SIERRA CLUB, )  
)  
Complainant, ) PCB 2014-134  
) (Enforcement-Air)  
v. )  
)  
AMEREN ENERGY MEDINA VALLEY ) DECLARATION  
COGEN, LLC )  
)  
and )  
)  
FUTUREGEN INDUSTRIAL ALLIANCE INC., )  
)  
Respondents. )

---

**DECLARATION OF RENEE CIPRIANO IN SUPPORT OF DEFENDANTS'  
MOTION FOR SUMMARY JUDGMENT**

I, Renee Cipriano, declare, under penalty of perjury, that the following statements are true and correct:

1. I am an attorney licensed to practice in the State of Illinois. I am a partner with the firm of Schiff Hardin LLP. The firm has been retained by AmerenEnergy Medina Valley Cogen, LLC ("Ameren") to defend it in this matter. I declare under penalty of perjury that the foregoing is true and correct.

2. Based on my personal knowledge, attached hereto as Exhibit 1 is a true-and-correct copy of the final Construction Permit issued by the Illinois Environmental Protection Agency to Ameren and FutureGen, dated December 13, 2013.

3. Based on my personal knowledge, attached hereto as Exhibit 2 is a true-and-correct copy of Sierra Club's written comments on the Draft Construction Permit, dated November 8, 2013.

4. Based on my personal knowledge, attached hereto as Exhibit 3 is a true-and-correct copy of the Illinois Environmental Protection Agency's Responsiveness Summary for Public Questions and Comments on the Applications for Air Pollution Control, dated December 2013.

5. Further the declarant say naught.

Respectfully submitted this 15th day of July, 2014.

A handwritten signature in black ink, appearing to read "Renee Cipriano", written over a horizontal line.

Renee Cipriano

26787-0060

CH2\14975316.1

BEFORE THE ILLINOIS POLLUTION CONTROL BOARD

SIERRA CLUB, )  
)  
Complainant, ) PCB 2014-134  
) (Enforcement-Air)  
v. )  
)  
AMEREN ENERGY MEDINA VALLEY ) CERTIFICATE OF SERVICE  
COGEN, LLC )  
)  
and )  
)  
FUTUREGEN INDUSTRIAL ALLIANCE INC., )  
)  
Respondents. )

---

**CERTIFICATE OF SERVICE**

I, the undersigned attorney at law, hereby certify that on July 15, 2014, I served true and correct copies of **DEFENDANTS' MOTION FOR SUMMARY JUDGMENT, MEMORANDUM IN SUPPORT OF DEFENDANTS' MOTION FOR SUMMARY JUDGMENT, AND DECLARATION OF RENEE CIPRIANO**, upon the following by First Class U.S. Mail:

Eric M. Schwing  
1100 South 5th Street  
Springfield, IL 62703  
T: 217-544-4440  
E: eric.scwing@comcast.net

Eva Schueller  
Sierra Club Environmental Law Program  
85 Second St., Second Floor  
San Francisco, CA 94105  
T: 415-977-5637  
E: eva.schueller@sierraclub.org

Dale N. Johnson  
Van Ness Feldman LLP  
719 Second Avenue, Suite 1150  
Seattle, WA 98104  
T: 206-623-9372  
E: dnj@vnf.com

Christopher D. Zentz  
Van Ness Feldman LLP  
719 Second Avenue, Suite 1150  
Seattle, WA 98104  
T: 206-623-9372  
E: cdz@vnf.com

Pollution Control Board, Attn: Clerk  
100 West Randolph Street  
James R. Thompson Center, Suite 11-500  
Chicago, IL 60601-3218

Date: July 15, 2014



---


Ashley L. Thompson  
Schiff Hardin LLP  
233 South Wacker Drive, Suite 6600  
Chicago, Illinois 60606  
Tel: 312-258-5500

Attorney for Defendant  
AmerenEnergy Medina Valley Cogen, LLC

26787-0060  
CH2\14975656.1



# Exhibit 1



ILLINOIS ENVIRONMENTAL PROTECTION AGENCY

1021 NORTH GRAND AVENUE EAST, P.O. BOX 19506, SPRINGFIELD, ILLINOIS 62794-9506-(217) 782-2113

PAT QUINN, GOVERNOR

LISA BONNETT, DIRECTOR

217/785-1705

CONSTRUCTION PERMIT

PERMITTEE

Owner

Ameren Energy Medina Valley  
Cogen, LLC  
1901 Chouteau Avenue  
St. Louis, Missouri 63103

Attn: Steven Whitworth

Operator

FutureGen Industrial  
Alliance, Incorporated  
73 Central Park Plaza East  
Jacksonville, Illinois 62650

Attn: Mark Williford

Application No.: 12020013

Applicant's Designation: FG2.0

Subject: FutureGen Project

Date Issued: December 13, 2013

1.2(a)

Location: 800 South Washington Street, Meredosia, Morgan County

I.D. No.: 137805AAA

Date Received: February 9, 2012

Expiration Date: See Condition

Permit is hereby granted to the above-designated Permittee to CONSTRUCT emission source(s) and air pollution control equipment consisting of a coal-fired, oxy-combustion power plant as described in the above-referenced application. This Permit is subject to standard conditions attached hereto and the following special conditions.

If you have any questions on this permit, please call Bob Smet at 217/785-9250 (TTD 217/782-9143).

*Raymond E. Pilapila*

Raymond E. Pilapil  
Acting Manager, Permit Section  
Division of Air Pollution Control

Date Signed: December 13, 2013

REP:RPS:psj

cc: Region 2  
USEPA Region V

TABLE OF CONTENTS

	Page
FINDINGS	3
SECTION 1: SOURCE-WIDE CONDITIONS	4
1.1 Effect of Permit	
1.2 Permanent Shutdown of Boilers 1 through 6	
1.3 Emissions of Hazardous Air Pollutants (HAPs)	
1.4 General Requirements of the New Source Performance Standards (NSPS)	
1.5 Miscellaneous Ancillary Equipment	
1.6 Good Air Pollution Control Practices	
1.7 Compliance with Emission Standards and Emission Limits	
1.8 General Records for Monitoring Systems and Instrumentation	
1.9 Retention and Availability of Records	
1.10 Addresses for the Illinois EPA	
1.11 Authorization for Operation	
1.12 Standard Permit Conditions	
SECTION 2: UNIT-SPECIFIC CONDITIONS FOR PARTICULAR EMISSION UNITS	10
2.1 Oxy-Combustion Boiler	
2.2 Auxiliary Boiler	
2.3 New and Modified Coal Handling Operations	
2.4 Bulk Material Handling Operations	
2.5 Cooling Towers	
2.6 Roadways	
SECTION 3: GENERAL PERMIT CONDITIONS	50
3.1 General Requirements for Emission Testing	
3.2 General Requirements for "Logs" or Similar Records	
3.3 General Requirements for Records for Deviations	
3.4 General Requirements for Reporting of Deviations	
ATTACHMENTS	
1 Summary of Project Emissions	1-1
2 Standard Permit Conditions	2-1

FINDINGS

- 1a. Ameren Energy Medina Valley Cogen, LLC and the FutureGen Industrial Alliance have requested a construction permit for the FutureGen 2.0 project, a full-scale coal-fired oxy-combustion power plant at the Meredosia Energy Center, the existing electric power plant in Meredosia. The project will include construction of a coal-fired oxy-combustion boiler, auxiliary boiler, three cooling towers and other ancillary operations and modification of existing coal handling operations and other ancillary operations at the source. The new plant will replace the existing boilers at the existing Meredosia Energy Center.
- b. The plant will be designed to separate carbon dioxide (CO<sub>2</sub>) from the flue gas of the oxy-combustion boiler to be sequestered geologically. Sequestration would occur at a separate facility that would be located about 30 miles east of Meredosia.
2. Meredosia is located in Morgan County, which is designated attainment for all criteria air pollutants.
3. This project is not subject to the federal rules for Prevention of Significant Deterioration of Air Quality (PSD), 40 CFR 52.21. This is because this project will not be accompanied by significant net increases in emissions of PSD pollutants, considering the past actual emissions of the existing Meredosia Energy Center. (See Attachment 1, Table 1B.) For this purpose, emissions from the sequestration facility have also been considered because this facility is considered to be a support facility for this new oxy-combustion power plant under the PSD rules.
4. After reviewing the application, the Illinois EPA has determined that this project is being designed to comply with applicable state and federal emission standards and requirements.
5. A copy of the application, the project summary prepared by the Illinois EPA, and a draft of this permit were placed in a public repository near the source, and the public was given notice and an opportunity to examine this material and to participate in a public hearing and to submit comments on these matters.

SECTION 1: SOURCE-WIDE CONDITIONS

1.1 Effect of Permit

- a. This permit does not relieve the Permittee of the responsibility to comply with all local, state and federal regulations that are part of the applicable Illinois' State Implementation Plan, as well as all other applicable federal, state and local requirements.
- b. In particular, this permit does not relieve the Permittee from the responsibility to carry out practices during the construction and operation of the plant, such as application of water sprays to unpaved traffic areas, as necessary to prevent an air pollution nuisance from fugitive dust, as prohibited by 35 IAC 201.141.

1.2 Source Requirements Related to Netting

a. Expiration of Permit

This permit shall expire on August 31, 2014 if commencement of construction of the oxy-combustion boiler does not begin before this date. This condition supersedes Standard Condition 1.

b. Permanent Shutdown of Boilers 1 through 6

Upon initial startup of the oxy-combustion boiler, Boilers 1 through 6 at the Meredosia Energy Center shall be permanently shutdown.

Note: This permit is issued based on this project not being a major modification subject to PSD because it will be accompanied by contemporaneous decreases in emissions such that the increases or net increases in emissions of PSD pollutants are not significant, as further described in Attachment 1, Tables 1A and 1B.

c. Emissions of the Existing Emergency Diesel Electric Generator

i. The emissions of sulfuric acid mist of the existing emergency diesel electric generator, which was constructed pursuant to Construction Permit 08100029, shall not exceed 0.008 tons/year.

2. The Permittee shall keep the following records for the existing emergency diesel electric generator:

A. A file containing the factor used by the Permittee to determine emissions of sulfuric acid mist from this unit based on the sulfur content of the fuel fired in this unit and other operating information for this unit, with supporting documentation.

- B. Records for the maximum sulfur content of the fuel fired in this unit (ppm, by weight) and the fuel consumption of this unit (gallons/month and gallons/year).
- C. Records of emissions of sulfuric acid mist (tons/month and tons/year) with supporting calculations.

1.3 Emissions of Hazardous Air Pollutants (HAPs)

- a. This permit is issued based on this plant not being a major source of hazardous air pollutants (HAPs), for purposes of applicability of 40 CFR 63 to this project. That is, the emissions of individual HAPs will each be less than 10 tons per year and the total emissions of HAPs will be less than 25 tons per year so that the plant is not subject to the provisions of 40 CFR Part 63 that are applicable to major sources of HAPs.
- b. The Permittee shall keep records of the annual emissions of HAPs from the plant to demonstrate that the plant is not a major source of emissions of HAPs. These records shall be compiled on at least an annual basis.

1.4 General Requirements of the New Source Performance Standards (NSPS)

- a. New Source Performance Standards (NSPS), 40 CFR Part 60, will apply to certain new emission units that are part of the proposed project, including the oxy-combustion boiler (40 CFR 60 Subpart Da), the auxiliary boiler (40 CFR 60 Subpart Dc) and the new coal handling operations (40 CFR 60 Subpart Y).
- b. The Permittee shall at all times, maintain and operate the boilers and other emission units that are subject to the NSPS, including associated air pollution control equipment, in a manner consistent with good air pollution control practice for minimizing emissions, pursuant to 40 CFR 60.11(d).
- c. For the boilers and other emission units that are subject to NSPS, the Permittee shall fulfill applicable notification requirements of the NSPS, 40 CFR 60.7(a), including:
  - i. Written notification of commencement of construction, no later than 30 days after such date. [40 CFR 60.7(a)(1)]
  - ii. Written notification of the actual date of initial startup, within 15 days after such date. [40 CFR 60.7(a)(3)]
- d. i. For the boilers and other emission units that are subject to NSPS, the Permittee shall fulfill applicable performance testing requirements of the NSPS, including 40 CFR 60.8(a), (c) and (d).

ii. For each performance evaluation conducted to demonstrate compliance with the NSPS, in addition to submitting a test report to the Illinois EPA, the Permittee shall electronically submit the test data to USEPA or, for opacity performance tests, mail a summary copy to the USEPA as required by the NSPS (e.g., 40 CFR 60.258(d)).

e. As this permit addresses emission standards and requirements of the NSPS, the applicable provisions of the NSPS, 40 CFR Part 60, as adopted by USEPA, shall govern in the event of any inconsistency or conflict between the terms of this permit and the provisions of the NSPS.

#### 1.5 Miscellaneous Ancillary Equipment

a. This permit is issued based on negligible emissions of VOM from storage tanks at the plant, including storage tanks for diesel fuel. For this purpose, VOM emissions from each tank shall not exceed nominal emission rates of 0.1lb/hour and 0.44 ton/year.

b. i. Ancillary equipment shall comply with all applicable emission standards and control requirements of the applicable NSPS, 40 CFR Part 60.

ii. Ancillary equipment shall comply with all applicable emission standards and control requirements of the applicable state emission regulations at Title 35, Subtitle B, Chapter I, Subchapter c.

iii. For ancillary equipment, the Permittee shall fulfill applicable requirements of applicable regulations, including provisions for testing, monitoring, recordkeeping, notification and reporting.

#### 1.6 Good Air Pollution Control Practice

a. The Permittee shall operate and maintain all emission units at this plant, including associated air pollution control equipment, in a manner consistent with good air pollution control practice for minimizing emissions.

b. The Permittee shall operate and maintain required monitoring devices and instrumentation in accordance with good monitoring practices, following the manufacturer's recommended operating and maintenance procedures or such other procedures as otherwise necessary to assure reliable operation of such devices.

#### 1.7 Compliance with Emission Standards and Emission Limits

a. The emission limits set by this permit apply at all times unless otherwise specified in a particular provision of this permit.

- b. i. Unless otherwise provided by the applicable rule, the emission standards for particulate matter that are addressed in the conditions of this permit only restrict filterable particulate, as would be measured by USEPA Method 5 or other appropriate USEPA Test Methods.
- ii. Unless otherwise provided by applicable provisions of this permit, emissions limits for PM<sub>10</sub> and PM<sub>2.5</sub> set by this permit address both filterable and condensable particulate.
- c. Emission limits set by this permit in lbs/million Btu (lbs/mmBtu) shall apply based on the higher heating value (HHV) of the fuel.
- d. When emission testing is conducted, compliance with hourly limits set by this permit shall be determined from the average of the test results, commonly three runs, each nominally one hour in duration.
- e. i. Except as provided below or unless otherwise specified in a particular provision, compliance with annual limits established by this permit shall be determined from a rolling total of 12 months of data, i.e., from the sum of the data for the current month and data for the preceding 11 months (12 month total), and shall consider all emissions, including emissions during startup, shutdown, and malfunction and breakdown.
- ii. For the first year (12 months) of operation, compliance shall be determined for a cumulative total of monthly data, i.e. from the sum of the data for the current month and data for all preceding months.

1.8 General Records for Monitoring Systems and Instrumentation

- a. The Permittee shall keep records of the data measured by required monitoring systems and instrumentation. Unless otherwise provided in a particular condition of this permit, the following requirements shall apply to such recordkeeping:
  - i. For required monitoring systems, data shall be automatically recorded by a central data system, dedicated data logging system, chart recorder or other data recording device. If an electronic data logging system is used, the recorded data shall be the hourly average value of the particular parameter for each hour.
  - ii. For required instrumentation, the measured data shall be recorded manually at least once per day, unless otherwise specified, with data and time both recorded, for periods when the associated emission unit(s) are in service, provided, however, if data from an instrument is recorded automatically, the above provisions for recording of data



from monitoring systems shall apply and manual recording of data is not required.

- b. The Permittee shall keep records for the operation, calibration maintenance and repair of required monitoring systems and instrumentation. These operating records shall, at a minimum, identify the date and duration of any time when a required monitoring instrument or device was not in operation, with explanation; the performance of manual quality control and quality assurance procedures for the system; and maintenance and repair activities performed for the system.
- c. The Permittee shall maintain a file containing a copy of the specifications for each required monitoring device or instrument and the recommended operating and maintenance procedures for the device as provided in writing by its manufacturer, which information shall be kept until a monitoring device or instrument is replaced.

1.9 Retention and Availability of Records

- a. The Permittee shall retain all records and logs required by this permit for at least five years from the date of entry (unless a longer retention period is specified by a particular provision), keep the records at a location at the plant that is readily accessible to the Illinois EPA or USEPA, and make records available for inspection and copying by the Illinois EPA or USEPA upon reasonable request.
- b. The Permittee shall retrieve and print on paper during normal plant office hours any records retained in an electronic format (e.g., computer) in response to an Illinois EPA or USEPA request for records during the course of a plant inspection.

1.10 Addresses for the Illinois EPA

- a. Any required reports and notifications required by this permit shall be sent to the Illinois EPA Air Compliance Section in Springfield.
- b. A copy of all required reports and notifications shall also be sent to the Illinois EPA's Regional Field Office for Central Illinois.

1.11 Authorization for Operation

This oxy-combustion power plant may be operated pursuant to this permit until a Clean Air Act Permit Program (CAAPP) permit is issued for the source that addresses this project provided that the initial performance testing required by the NSPS and NESHAP for the oxy-combustion boiler is completed in a timely manner and a timely application for modification of the CAAPP permit for this source is submitted to address this project in accordance with Section 39.5(5)(x) of the Act. This condition supersedes Standard Condition 6.

1.12 Standard Permit Conditions

Standard conditions for issuance of construction permits, attached hereto and incorporated herein by reference, shall apply to this project, unless superseded by other conditions in the permit.  
(Refer to Attachment 2.)

SECTION 2: UNIT-SPECIFIC CONDITIONS FOR PARTICULAR EMISSION UNITS

SECTION 2.1: UNIT-SPECIFIC CONDITIONS FOR THE OXY-COMBUSTION BOILER

2.1.1 Description

The affected boiler for the purpose of these unit-specific conditions is the new oxy-combustion boiler and its control train and the associated Compression Purification Unit (CPU). The control train for the boiler will include a circulating dry scrubber (for SO<sub>2</sub>) and a baghouse (for PM). The CPU will be preceded by a polishing scrubber and include another baghouse to prepare the gas for CO<sub>2</sub> separation in the CPU. These devices will act to further control SO<sub>2</sub> and PM emissions of the boiler.

This boiler will have two modes of normal operation, air firing and oxy-combustion. Startup of this boiler will begin on oil using air for combustion like a typical coal-fired boiler. The oil-fired igniters will maintain stable combustion until the boiler can sustain firing of coal. Emissions will occur through the boiler stack. Startup on air will continue until stable operation is achieved with air. The boiler can then transition to the oxy-combustion mode. The oxygen stream from the Air Separation Unit and recycled flue gas will then be substituted for air beginning the transition to oxy-combustion. At this point, the flue gas from the boiler can begin to be processed in the CPU and emissions will occur through the CPU stack. The CO<sub>2</sub> stream from the CPU can then begin to be sequestered when it meets the specifications for sequestration. In the event of an upset in the operation of the boiler or an outage or upset in the CO<sub>2</sub> pipeline or the sequestration facility, the boiler can transition back into air firing mode.

2.1.2 List of Emission Units and Air Pollution Control Equipment

Emission Unit	Description	Emission Control Equipment
Oxy-Combustion Utility Boiler	Pulverized Coal-Fired Boiler, with Supplemental Oil	Low-NOx Burners, Advanced Combustion Management System, Circulating Dry Scrubber and Baghouse
	Compression Purification Unit, with Polishing Scrubber and Polishing Baghouse	

2.1.3-1 Applicable Federal Emission Standards

- a. The affected boiler is subject to the New Source Performance Standard (NSPS) for Electric Utility Steam Generating Units, 40 CFR 60 Subpart Da, and the general Provisions of the NSPS, 40 CFR 60 Subpart A. The emissions from the affected boiler are subject to the following standards, pursuant to the NSPS on and after the date the applicable performance test required to be conducted under 40 CFR 60.8 is or should be completed. As provided by 40 CFR 60 48Da(a), the standards for SO<sub>2</sub> and NOx or NOx plus CO apply at all times; the standards for PM and

opacity apply at all times except during periods of startup and shutdown.

- i. SO<sub>2</sub>: 1.0 lbs/MWh gross energy output or, alternatively, overall 97 percent reduction, on a 30-day rolling average, pursuant to 40 CFR 60.43Da(1)(1)(i) or (iii).
  - ii. A. NO<sub>x</sub> (expressed as NO<sub>2</sub>): 0.70 lb/MWh of gross energy output, on a 30-day rolling average, pursuant to 40 CFR 60.44Da(g)(1)(i); or alternatively,  
B. NO<sub>x</sub> (expressed as NO<sub>2</sub>) plus CO: 1.1 lbs/MWh gross energy output, on a 30-day rolling average, pursuant to 40 CFR 60.45Da(b)(1)(i).
  - iii. PM: 0.09 lb/MWh of gross energy output pursuant to 40 CFR 60.42Da(e)(1)(i)(A). During periods of startup and shutdown, the Permittee shall meet the work practice standards of 40 CFR 63 Subpart UUUUU, pursuant to 40 CFR 60.42Da(e)(2).
  - iv. Opacity: 20 percent (6-minute average) except for one 6-minute period per hour of not more than 27 percent opacity, unless the Permittee conducts continuous emissions monitoring for PM according to the requirements of this NSPS, as provided for by 40 CFR 60.42Da(b).
- b. The affected boiler is an "electrical generating unit" (EGU) that is subject to the National Emission Standards for Hazardous Air Pollutants (NESHAP) from Coal and Oil-Fired Electric Utility Steam Generating Units, 40 CFR 63 Subpart UUUUU and related provisions in 40 CFR 63 Subpart A (see 40 CFR 63.10040 and Table 9 of 40 CFR 63 Subpart UUUUU for applicable provisions).
- i. At all times, except for periods that meet the definitions of startup and shutdown in 40 CFR 63.10042, the emissions from the affected boiler shall not exceed the following standards pursuant to the NESHAP, 40 CFR 63.9991, on and after the date the applicable performance test required to be conducted under 40 CFR 63.7 is or should be completed. Compliance with these limitations shall be demonstrated in accordance with the applicable provisions of this NESHAP, including 40 CFR 63.10000, 63.10005 and 63.10011.
    - A. Particulate HAP:  
  
PM (Filterable): 0.090 lb/MWh of gross electric output, on a 30-day rolling average basis; or  
  
Total non-mercury HAP Metals: 0.06 lb/GWh; or

Individual non-mercury HAP Metals: Limits set in 40 CFR 63 Subpart UUUUU, Table 1.

B. Acid Gas:

Hydrogen chloride (HCl): 0.010 lb/MWh, or

SO<sub>2</sub>: 1.0 lb/MWh

C. Mercury:

0.003 lb/GWh,

- ii. For startup of the affected boiler, the Permittee must comply with applicable requirements of this NESHAP, including the following requirements pursuant to 40 CFR 63.9991 and 63.10000 and Table 3 of 40 CFR 63 Subpart UUUUU.
- A. Operate all continuous monitoring systems (CMS) during startup.
  - B. For startup of a unit, the Permittee must use clean fuels, either natural gas or distillate oil or a combination of clean fuels for ignition.
  - C. Once the Permittee converts to firing coal, the Permittee must engage all of the applicable control technologies for the coal-boiler except the dry scrubber.
  - D. The Permittee must start the dry scrubber appropriately to comply with relevant standards applicable during normal operation.
  - E. The Permittee must keep records during periods of startup.
  - F. The Permittee must provide reports concerning activities and periods of startup, as specified in 40 CFR 63.10011(g) and 63.10021(h) and (i).
- iii. For shutdown of the affected boiler, the Permittee must comply with applicable requirements of this NESHAP, including the following requirements pursuant to 40 CFR 63.9991 and 63.10000 and Table 3 of the 40 CFR 63 Subpart UUUUU.
- A. The Permittee must operate all CMS during shutdown.
  - B. During shutdown, the Permittee must operate all applicable control technologies for the coal-boiler while firing coal.

- C. The Permittee must keep records during periods of shutdown.
  - D. The Permittee must provide reports concerning activities and periods of shutdown, as specified in 40 CFR 63.10011(g) and 40 CFR 63.10021(h) and (i).
- c. Under Title IV of the Clean Air Act, Acid Deposition Control, and 40 CFR 76.7(a)(2), the NO<sub>x</sub> emissions of the affected boiler are subject to an annual average limit of 0.46 lb/mmBtu.

2.1.3-2 Applicable State Emission Standards

- a. Pursuant to 35 IAC 212.122(a), the emission of smoke or other particulate matter from the affected boiler shall not have opacity greater than 20 percent, 6-minute average, except as provided for by 35 IAC 212.122(b) or 35 IAC Part 201 Subpart I.
- b. Pursuant to 35 IAC 212.204 and 212.206, no person shall cause or allow the emission of PM into the atmosphere from the affected boiler to exceed 0.15 kg of particulate matter per MW-hour of actual heat input (0.1 lbs/mmBtu) in any one hour period.
- c.
  - i. Pursuant to 35 IAC 214.182, the total emissions of SO<sub>2</sub> into the atmosphere in any one hour period from the affected boiler shall not exceed the emission rate determined by the equation in 35 IAC 214.183(a).
  - ii. Pursuant to 35 IAC 214.121, the sulfur content of fuel oil fired in the affected boiler shall not exceed 0.15 lbs/mmBtu.
- d. Pursuant to 35 IAC 216.121, when operating in air firing mode, the CO emissions into the atmosphere from the affected boiler shall not exceed 200 ppm, corrected to 50 percent excess air.
- e. Pursuant to 35 IAC 217.706, the NO<sub>x</sub> emissions of the affected boiler shall not exceed 0.25 lbs/mmBtu of actual heat input during each ozone control period, based on a control period average for that unit (May 1 - September 30).
- f. Pursuant to 35 IAC 225.230(a)(1), the emissions of mercury from the affected boiler shall comply with one of the following standards on a rolling 12-month basis:
  - i. An emissions standard of 0.0080 lbs/GWh gross electrical output; or
  - ii. A minimum 90 percent reduction of input mercury.

2.1.4 Non-Applicability Provisions

- a. For emissions of CO, the affected boiler is not subject to 35 IAC 216.121 during oxy-combustion firing mode.
- b.
  - i. For emissions of NOx, the affected boiler is not subject to 35 IAC Part 217 Subpart M. This is because the affected boiler does not meet the applicability criteria in 35 IAC 217.150, i.e., the affected boiler is not located in an area in which these rules may apply.
  - ii. For emissions of NOx, the Permittee is not eligible to comply with 35 IAC 217.706 in 35 IAC Part 217 Subpart V for the affected boiler by NOx averaging. This is because the affected boiler does not meet the eligibility criteria for 35 IAC 217.708, i.e., the affected boiler is a new unit and is not listed in 35 IAC Part 217, Appendix F.
- c. For emissions of mercury, the affected boiler is not eligible to comply with 35 IAC Part 225 by means of the multi-pollutant standard under 35 IAC 225.233. This is because the affected boiler is a "new boiler" and does not meet the eligibility criteria in 35 IAC 225.233(a)(2)(A).

2.1.5 Operational Requirements

- a. Pursuant to the NESHAP, 40 CFR 63.9991 and Table 4 of 40 CFR 63 Subpart UUUUU, if the Permittee elects to use a continuous particulate monitoring system (CPMS) to demonstrate compliance with the NESHAP for PM, the Permittee shall maintain the 30-boiler operating day rolling average PM (CPMS) output determined in accordance with the requirements of 40 CFR 63.10023(b)(2) at or below the highest 1-hour average measured during the most recent performance test run demonstrating compliance with the emissions limit(s) of 40 CFR 63 Subpart UUUUU for filterable PM, total non-mercury HAP metals or individual non-mercury HAP metals.
- b.
  - i. Pursuant to the NESHAP, 40 CFR 63.9991 and Table 3 of 40 CFR 63 Subpart UUUUU, the Permittee shall conduct a tune-up of the burner(s) and combustion controls of the affected boiler at least each 36 calendar months, or each 48 calendar months if neural network combustion optimization software is employed, as specified in 40 CFR 63.10021(e).
  - ii. Subsequent tune-ups shall be conducted as specified in 40 CFR 63.10006.
- c. The affected boiler shall not be operated at a load that is higher than the maximum load (hourly average) for air-firing or oxy-combustion, as applicable, at which emission testing has demonstrated compliance with the hourly emission limits in Condition 2.1.6(b) for emissions of sulfuric acid mist and

fluorides, provided, however, that this requirement shall not apply during emission testing for sulfuric acid mist and fluorides and during operation that is conducted in conjunction with such testing if the Permittee notifies the Illinois EPA prior to conducting such activities.

2.1.6 Operational and Emission Limits

- a. i. The heat input to the affected boiler from fuel shall not exceed 14,100,000 mmBtu/year.
- ii. The amount of coal combusted by the affected boiler, determined as coal fed to the boiler, shall not exceed 744,600 tons/year.

Note: Compliance with this limit will be determined from the operation of the equipment that feeds coal to the boiler. (See Condition 2.3.8(b).)

- iii. The affected boiler shall not operate in air-firing mode (i.e., other than in oxy-combustion mode) for more than 4800 hours/year.

- b. The emissions of the affected boiler shall not exceed the following limits:

Pollutant	Limits	
	Pounds/Hour <sup>a</sup>	Tons/Year
NOx	--- <sup>b</sup>	1,691.7
SO <sub>2</sub>	--- <sup>b</sup>	196.4
PM	7.45	27.8
PM <sub>10</sub> /PM <sub>2.5</sub>	14.72	45.3
VOM	2.65	9.9
CO	110	281.2
Sulfuric Acid Mist	1.70/2.97 <sup>c</sup>	10.5
Lead	0.034	0.15
Fluorides	0.63	1.6
CO <sub>2</sub>	--- <sup>b</sup>	1,448,759
GHG (as CO <sub>2</sub> e)	331,947	1,453,928
Individual HAP	---	4.5
Total HAP	---	19.86

Notes:

- a. Limits apply as three-hour averages, except for the limit for CO<sub>2</sub>e, which applies as an annual average, rolled monthly.
- b. Short-term emission limits are not set because continuous monitoring is required for this pollutant.



- c. The limits of 1.70 and 2.97 pounds/hour apply for oxy-combustion mode and other modes of operation, respectively.

2.1.7 Emission Testing

a. NSPS Testing

For the affected boiler, for emissions of pollutants that are subject to the NSPS (PM, SO<sub>2</sub>, NO<sub>x</sub> and, if applicable, CO), the Permittee shall fulfill applicable requirements for performance testing in the NSPS, 40 CFR 60.8 and 60.50Da, using the methods and procedures specified by the NSPS.

Note: It is expected that the Permittee will need to obtain approval from USEPA for use of alternative test methods, as provided for by 40 CFR 60.8(b). This is because established methods were not designed for testing of oxy-combustion boilers.

b. NESHAP Testing

For the affected boiler, the Permittee shall also fulfill applicable requirements of the NESHAP, 40 CFR 63.10006, for emissions testing, using the methods and procedures specified by the NESHAP (see 40 CFR 63.10007).

Note: It is expected that the Permittee will need to obtain approval from USEPA for use of alternative test methods, as provided for by 40 CFR 63.7(e) and (f).

c. Other Emission Testing

- i. The Permittee shall conduct emissions testing for the affected boiler for filterable PM, PM<sub>10</sub> and PM<sub>2.5</sub>, condensable PM, CO, VOM, sulfuric acid mist, fluorides, methane and nitrous oxide as specified below, provided, however, that:
  - A. If the Permittee considers all PM emissions to be emissions of filterable PM<sub>10</sub> and PM<sub>2.5</sub>, testing for emissions of filterable PM<sub>10</sub> and PM<sub>2.5</sub> need not be performed unless specifically requested by the Illinois EPA.
  - B. As an alternative to testing for CO, the Permittee may provide emission data for CO that is derived from monitored CO data collected by a CEMS.
  - C. As an alternative to testing for emissions of methane and nitrous oxide, the Permittee may provide data for these pollutants in accordance with 40 CFR Part 98.

- ii. This testing shall be conducted as follows:
  - A. Within one year (365 days) after achieving the maximum production rate at which the affected boiler will be operated, the Permittee shall have initial emission tests conducted while the affected boiler is operating in air-firing and in oxy-combustion modes while the boiler is operating at maximum rates and other representative operating conditions.
  - B. Thereafter, the Permittee shall perform emission tests as provided below as requested by the Illinois EPA within 90 days of a written request by the Illinois EPA or such later date agreed to by the Illinois EPA.

Note: Testing may be required for emissions of regulated pollutants for which testing was not initially required, including lead, using applicable USEPA Test Methods.

- iii. The following methods and procedures shall be used for this testing, unless other methods adopted by or being developed by USEPA or other alternative test methods are approved by the Illinois EPA.

Filterable PM	Method 5
Filterable PM <sub>10</sub> & PM <sub>2.5</sub>	Method 201A
Condensable PM	Method 202
Carbon Monoxide	Method 10
Volatile Organic Material	Method 25A
Sulfuric Acid Mist	Method 8
Fluorides	Method 13A or 13B
Methane and Nitrous Oxide	Method 320

- iv. Test plans, test notifications, and test reports shall be submitted to the Illinois EPA in accordance with Condition 3.1. In addition to other required information, if test runs that are longer than one-hour in duration are planned, the expected duration of the runs and the reason for extended runs shall be explained.
- v. In addition to other information required in a test report, test reports shall include detailed information on the operating conditions of the affected boiler during testing, including:
  - A. Representative analys(es) of the coal being fired in the affected boiler.
  - B. Firing rate (mmBtu/hour).
  - C. Significant operating parameters of the affected boiler and the control train.

- D. Opacity of the exhaust from the affected boiler, 6-minute averages and 1-hour averages.
- E. Turbine/Generator output rate ( $MW_e$  gross).
- F. The loads of the affected boiler during testing and the maximum loads for air-firing and oxy-combustion at which the Permittee considers compliance with applicable emission limits has been demonstrated, with supporting analysis.

2.1.8 Fuel Sampling and Analysis

If the Permittee is complying with the removal standard for mercury in 35 IAC 225.230(a)(1), the Permittee shall conduct sampling and analysis of the coal supply to the affected boiler for mercury content in accordance with the requirements of 35 IAC Part 225.265.

2.1.9-1 Emissions Monitoring for  $SO_2$  and  $NO_x$

- a. The Permittee shall install, calibrate, maintain, and operate continuous emissions monitoring systems (CEMS) for the  $SO_2$  and  $NO_x$  emissions of the affected boiler. These CEMS shall be operated in accordance with the applicable requirements of the NSPS, 40 CFR 60.13 and 60.49Da, the federal Acid Rain Program and Title IV provisions, 40 CFR Part 75, and the CAIR  $NO_x$  and  $SO_2$  Trading Programs, 40 CFR 96 Subpart H (See also 35 IAC 217.710(a), 225.310(c), 225.410(c) and 225.510(c)).

Note: It is expected that the Permittee will need to obtain approval from USEPA for use of alternative monitoring methods, for this monitoring and other monitoring addressed by Conditions 2.1.9-2 through 2.1.9-8, as provided for by 40 CFR 60.13(i), 40 CFR 75 Subpart E, and 40 CFR 96.75. As USEPA approves any such alternative monitoring, it would substitute for the monitoring requirements identified in this permit.

- b. Pursuant to 40 CFR 60.49Da(s), the Permittee shall prepare and submit to the Illinois EPA for approval a unit-specific monitoring plan for the  $SO_2$  and  $NO_x$  monitoring systems and other emission monitoring systems on the affected boiler required by the NSPS, at least 45 days before commencing certification testing of these monitoring systems. The Permittee shall operate and maintain the monitoring systems in accordance with this plan.

2.1.9-2 Monitoring for PM

- a. Pursuant to 40 CFR 60.49Da(t), because the Permittee is demonstrating compliance with the output-based emission limits under 40 CFR 60.42Da, for the affected boiler, the Permittee shall either:

- i. Install, certify, operate, and maintain a CEMS for measuring PM emissions according to the requirements of 40 CFR 60.49Da(v); or
- ii. Install, calibrate, operate, and maintain a PM CPMS according to the requirements for new facilities specified in 40 CFR 63 Subpart UUUUU.

Note: If the Permittee were demonstrating compliance with the input-based emissions limit in 40 CFR 60.42Da, it could conduct monitoring for PM emissions according to the requirements of 40 CFR 60.49Da(v).

- b. Pursuant to 40 CFR 63.10010, the Permittee shall install, certify, operate, and maintain the CEMS or CPMS for PM emissions of the affected boiler as specified in 40 CFR 63.10010.

#### 2.1.9-3 Emissions Monitoring for CO

Pursuant to 40 CFR 60.49Da(u), for the affected boiler, if the Permittee elects to comply with the alternative NSPS standard for NOx plus CO, the Permittee shall install, certify, operate, and maintain a CEMS for CO emissions as specified in 40 CFR 60.49Da (u)(1) through (4).

#### 2.1.9-4 Emissions Monitoring for Mercury

- a.
  - i. Pursuant to NESHAP, 40 CFR 63.10000(c)(1)(vi), for the affected boiler, the Permittee shall install, certify, operate, and maintain a CEMS or sorbent trap monitoring system for mercury as specified in 40 CFR 60 Subpart UUUUU, Appendix A.
  - ii. Pursuant to 35 IAC 225.240, for this monitoring, the Permittee shall also comply with applicable requirements of 35 IAC 225.240, 225.250, 225.260 225.270 and 225.290.
- b. The Permittee shall fulfill other applicable requirements of 35 IAC 225.261 and 225.263 for the affected boiler.

#### 2.1.9-5 Emissions Monitoring for HCl and HF or SO<sub>2</sub>

Based upon the emission standard(s) with which the Permittee elects to comply, the Permittee shall fulfill all applicable requirements of the NESHAP, 40 CFR 63 Subpart UUUUU, for monitoring of HCl and HF emissions or monitoring of SO<sub>2</sub> emissions of the affected boiler, including requirements in either 40 CFR 63.10010(e) or (f), respectively, and 40 CFR 63.10020.

#### 2.1.9-6 Emissions Monitoring for CO<sub>2</sub>

For the affected boiler, the Permittee shall install, certify, operate and maintain CEMS for CO<sub>2</sub> emissions. The CEMS shall be

operated in accordance with applicable requirements of 40 CFR 75, including 40 CFR 75.10(a)(3).

2.1.9-7 Monitoring for Stack Flow Rate

- a. i. Pursuant to 40 CFR 60.49Da(1), for the affected boiler, the Permittee, as the owner or operator of an affected facility demonstrating compliance with an output-based standard, shall install, certify, operate, and maintain a continuous flow monitoring system meeting the requirements of Performance Specification 6 of Appendix B of 40 CFR Part 60 and the calibration drift (CD) assessment, relative accuracy test audit (RATA), and reporting provisions of procedure 1 of Appendix F of 40 CFR Part 60, and record the output of the system, for measuring the volumetric flow rate of exhaust gases discharged to the atmosphere; or
- ii. Alternatively, pursuant to 40 CFR 60.49Da(m), the Permittee may use data from a continuous flow monitoring system certified according to the requirements of 40 CFR 75.20(c) and Appendix A to 40 CFR Part 75 and continuing to meet the applicable quality control and quality assurance requirements of 40 CFR 75.21 and Appendix B to Part 75. Flow rate data reported to meet the requirements of 40 CFR 60.51Da shall not include substitute data values derived from the missing data procedures in Subpart D of 40 CFR Part 75, nor shall the data have been bias adjusted according to the procedures of 40 CFR Part 75.

2.1.9-8 Opacity Monitoring

Pursuant to 40 CFR 60.49Da(a), if the affected boiler is subject to the opacity standard of the NSPS, 40 CFR 60.42Da(b), the Permittee shall monitor the opacity of emissions discharged from the affected boiler to the atmosphere with a continuous opacity monitoring system in accordance with the applicable requirements of the NSPS, including 40 CFR 60.49Da(a).

Note: Pursuant to 40 CFR 60.42Da(b), the affected boiler would not be subject to the opacity standard of the NSPS if the Permittee operates a CEMS for PM emissions. (See also Conditions 2.1.3-1(a)(iv) and 2.1.9-2(a)(i).)

2.1.10 Recordkeeping

- a. The Permittee shall maintain the following records for the affected boiler:
  - i. Records of all information needed to demonstrate compliance with the NSPS, including performance tests, opacity observations, monitoring data, fuel analysis, and

- calculations, consistent with the requirements of 40 CFR 60.7(f) and 60.52Da.
- ii. Records of all information needed to demonstrate compliance with the NESHAP, including performance tests, monitoring data, fuel analysis, and calculations, consistent with the requirements of 40 CFR 63.10, 63.10032, 63.10033 and Table 8 of the NESHAP.
  - iii. Pursuant to 35 IAC 217.712, records of NOx emissions during the ozone control period, as required by 40 CFR Part 75 including, but not limited to, 40 CFR 75.54(b) and (d).
  - iv. Records of all information required by applicable recordkeeping provisions of 35 IAC Part 225, Subpart B.
- b. The Permittee shall maintain the following records with respect to operation and maintenance of the affected boiler and associated control equipment:
- i. The following data for the affected boiler on a monthly and annual basis:
    - A. Fuel consumption, in tons.
    - B. Heat input to the boiler, in mmBtu.
    - C. Total operating hours.
    - D. Operating hours in air-firing mode (i.e., operation in a mode other than oxy-combustion).
    - E. Number of startups.
  - ii. Daily records of electricity generation.
  - iii. Hourly records of the mode of operation of the boiler (i.e., air-firing or oxy-combustion) and the load of the boiler.
  - iv. An operating log for the affected boiler that, at a minimum, shall address:
    - A. Each startup of the boiler, including the date and time, and description.
    - B. Each shutdown of the boiler, including the date and time, and description.
    - C. For normal operation, the mode of operation of the boiler, i.e., oxy-combustion or air-firing.

- D. Each malfunction or breakdown of the affected boiler that significantly impaired emission performance, including a description of the event, corrective actions taken, and preventative actions taken to address similar events.
- v. Inspection, maintenance and repair log(s) for the affected boiler and associated control system that, at a minimum, shall identify dates and nature of activities performed related to components that may affect emissions; the reason for such activities, i.e., whether planned or initiated due to a specific event or condition; and any failure to carry out the established maintenance procedures, with explanation.
- c. For the affected boiler, the Permittee shall maintain records of the following items related to emissions:
  - i. Daily emissions of NOx, SO<sub>2</sub>, PM, CO<sub>2</sub> and if monitoring is conducted, CO, based on CEMS data.
  - ii. Emissions of NOx, SO<sub>2</sub> and CO<sub>2</sub>, recorded hourly in units of lbs/mmBtu, lbs/hour or tons/hour, which shall be calculated based on the pollutant concentration according to the applicable procedures pursuant to 40 CFR Part 75.
  - iii. Monthly and annual emissions of NOx, SO<sub>2</sub>, PM, CO<sub>2</sub> and, if monitoring is conducted, CO, with supporting data.
  - iv. A file containing calculations for the maximum hourly emission rates of PM<sub>10</sub>/PM<sub>2.5</sub>, sulfuric acid mist, fluorides, lead, VOM, methane, N<sub>2</sub>O, individual HAP, total HAPs and, if monitoring is not conducted, CO (lbs/mmBtu and lbs/hour), with supporting documentation.
  - v. Monthly and annual emissions of PM<sub>10</sub>/PM<sub>2.5</sub>, sulfuric acid mist, fluorides, lead, VOM, GHG (as CO<sub>2</sub>e), individual HAP, total HAPs and, if monitoring is not conducted, CO, with supporting calculations.
- d. The Permittee shall keep records for opacity determinations for the affected boiler made in accordance with Method 9 that it makes or that are made on its behalf.
- e. The Permittee shall record the information specified by Condition 3.3 for any period during which the affected boiler deviated from an applicable emission standard, emission limit or other requirement.
- f. The Permittee shall maintain records of the amount of CO<sub>2</sub> from the affected boiler that is sequestered (tons/month).

2.1.11 Notification and Reporting

- a. For the affected boiler, the Permittee shall fulfill all applicable notification and reporting requirements in the NSPS, 40 CFR 60.7(c) and 60.51Da.
- b. For the affected boiler, the Permittee shall fulfill all applicable notification and reporting requirements in the NESHAP, including 40 CFR 63.9, 63.10, 63.10030 and 63.10031.
- c.
  - i. Either as part of the periodic NSPS report or accompanying such report, the Permittee shall report to the Illinois EPA any and all emissions and opacity measurements for the affected boiler that are in excess of the applicable standards or limits set by this permit. These reports shall provide for each such incident, the pollutant emission rate, the date and duration of the incident, and whether it occurred during startup, malfunction, breakdown or shutdown. If an incident did not occur during startup, the corrective actions and actions taken to prevent or minimize future reoccurrences shall also be reported.
  - ii. These reports shall also be submitted for each occurrence of excess emissions from the affected boiler due to malfunction or breakdown, as addressed by the records required by Condition 2.1.10(e), when corrective actions did not promptly restore acceptable emission levels and the shutdown of the affected boiler was not then immediately initiated but was deferred. This report shall include a copy of the relevant records and additional explanation by the Permittee.
- d. The Permittee, as the owner or operator of an electricity generating unit (EGU) subject to the requirements of 35 IAC Part 217 Subpart V, shall comply with the following reporting requirements for the affected boiler, pursuant to 35 IAC 217.712:
  - i. Comply with the reporting requirements of 40 CFR 75 applicable to NOx emissions during the ozone control period, including, but not limited to, 40 CFR 75.54(b) and (d).
  - ii. Submit the certification statement specified by 35 IAC 217.712(c), signed by a responsible official.
  - iii. By November 30 of each year, submit to the Illinois EPA a report that demonstrates each EGU has not exceeded a NOx emission rate of 0.25 lbs/mmBtu during the ozone control period.
  - iv. Keep and maintain, for 5 years, all records and data necessary to demonstrate compliance with the



requirements, and upon request make such records and data available to Illinois EPA and USEPA representatives for inspection and copying during working hours.

- v. Submit copies of any records and data required by 35 IAC 217.712 to the Illinois EPA within 30 days after receipt of a written request by the Illinois EPA.
- e. The Permittee shall fulfill the applicable notification and reporting requirements of 35 IAC Part 225 Subpart B.
- f. The Permittee shall notify the Illinois EPA of deviations from applicable requirements for the affected boiler as follows. These notifications shall include the information specified by Condition 3.4.
  - i. Deviations from applicable emission standards or work practices of the NSPS, NESHAP, 35 IAC Part 217 Subpart V, or 35 IAC Part 225 shall be reported in the compliance reports required by these rules.
  - ii. Other deviations from applicable requirements shall be reported in a quarterly report.

SECTION 2.2: UNIT-SPECIFIC CONDITIONS FOR THE AUXILIARY BOILER

2.2.1 Description

The affected boiler for the purpose of these unit-specific conditions is the distillate oil-fired auxiliary boiler that will supply steam to support the operation of the plant. Unlike the oxy-combustion boiler, the steam from this auxiliary boiler will not be sent to the steam turbine generator to produce electricity for sale to the grid.

2.2.2 List of Emission Units

Emission Unit	Description	Control Measures
Auxiliary Boiler	Distillate oil-fired boiler	Low-NOx Combustion

2.2.3-1 Applicable Federal Emission Standards

- a. i. The affected boiler is an affected facility under the federal NSPS for Small Industrial-Commercial-Institutional Steam Generating Units, 40 CFR 60 Subpart Dc. For the affected boiler, the Permittee must comply with applicable requirements of this NSPS and applicable requirements of 40 CFR 60 Subpart A, General Provisions.
- ii. Pursuant to the NSPS, 40 CFR 60.43c(c), opacity from the affected boiler shall not exceed 20 percent, as measured on a six minute average, except for one six-minute period per hour of not more than 27 percent opacity. As provided by 40 CFR 60.43c(d), this limit applies at all times except during periods of startup, shutdown, or malfunction, as defined at 40 CFR 60.2. However, exceedances during such periods shall be reported as deviations.
- iii. A. Pursuant to the NSPS, 40 CFR 60.42c(d), the sulfur content of the fuel oil burned in the affected boiler shall not be greater than 0.5 percent by weight (30-day rolling average). This limit applies at all times, including periods of startup, shutdown and malfunction.
- B. Pursuant to 40 CFR 60.42c(h), compliance with the SO<sub>2</sub> emission limit or the fuel oil sulfur limit may be determined based on a certification from the fuel supplier as provided by 40 CFR 60.48c(f).
- b. i. The affected boiler is an affected facility under the federal NESHAP for Industrial, Commercial, and Institutional Boilers Area Sources, 40 CFR 63 Subpart JJJJJJ. For the boiler, the Permittee must comply with applicable requirements of this NESHAP, including the following. The Permittee must comply with applicable requirements of 40 CFR 63 Subpart A, General Provisions,

(see 40 CFR 63.11235 and Table 8 of 40 CFR 63 Subpart JJJJJJ for specific applicable general provisions).

- ii. Pursuant to 40 CFR 63.11205(a), at all times the Permittee must operate and maintain the affected boiler, including associated air pollution control equipment and monitoring equipment, in a manner consistent with safety and good air pollution control practices for minimizing emissions. The general duty to minimize emissions does not require further efforts to reduce emissions if levels required by this standard have been achieved.
- iii. Pursuant to 40 CFR 63.11210(f), the Permittee shall complete biennial or 5-year tune-ups of the affected boiler, as applicable, as specified in 40 CFR 63.11223 beginning no later than 25 months or 61 months, respectively, after the initial startup of the affected boiler.

2.2.3-2 Applicable State Emission Standards

- a. Pursuant to 35 IAC, Chapter B, Subchapter c, emissions from the affected boiler shall not exceed the following standards, which apply on an hourly basis:

Pollutant	Standard	Limit
PM	35 IAC 212.206	0.10 lbs/mmBtu
SO <sub>2</sub>	35 IAC 214.122(b) (2)	0.3 lb/mmBtu
CO	35 IAC 216.121	200 ppm, @50% excess air

- b. Pursuant to 35 IAC 212.123(a), the emission of smoke or other particulate matter from the affected boiler shall not have an opacity greater than 30 percent, 6-minute average, except as provided by 35 IAC 212.123(b) or Part 201 Subpart I.

2.2.4 Non-Applicability Provisions

- a.
  - i. This permit does not address the standards of the NSPS for PM and SO<sub>2</sub> emissions because the affected boiler is not subject to such standards as low-sulfur oil that meets the criteria in 40 CFR 60.43c(e)(4) and 63.11210(e) must be used in the affected boiler. (See Condition 2.2.5(b).)
  - ii. As provided by the NSPS, 40 CFR 60.47c(c), the Permittee is not required to operate a continuous opacity monitor for the affected boiler pursuant to the NSPS. This is because the fuel oil burned in the boiler will have a sulfur content of no more than 0.5 percent by weight, the boiler will not use post-combustion technology to reduce SO<sub>2</sub> or PM emissions, and the applicable procedures in 40 CFR 60.48c(f) will be followed.
- b. For emissions of NO<sub>x</sub>, the affected boiler is not subject to 35 IAC Part 217 Subpart E. This is because the source is not

located in one of the designated areas listed in 35 IAC 217.150(a)(1)(A).

- c. The affected boiler is not subject to the provisions of Title IV of the federal Clean Air Act (Acid Program) because the boiler does not qualify as a utility unit or an electrical generating unit for the purpose of these provisions.

2.2.5 Operational Requirements, Work Practices and Production Limits

- a. The nominal rated heat input capacity of the affected boiler shall not exceed 95 mmBtu/hour.
- b. The fuel fired in the affected boiler shall:
  - i. Meet the specifications for sulfur content in 40 CFR 60.43c(e)(4) and 63.11210(e); and
  - ii. Be ultra-low sulfur diesel fuel, as addressed by 40 CFR 80.520(a), which requires that sulfur content not exceed 15 ppm maximum, provided, however, that 40 CFR 80.520(c) shall not be applicable.
- c. Pursuant to 40 CFR 63.11223 and Table 2 of 40 CFR 63 Subpart JJJJJJ, the Permittee shall conduct biannually tune-ups of the affected boiler as specified in 40 CFR 63.11223.
- d. The steam from the affected boiler shall not be used to produce electricity for commercial sale.

2.2.6 Emission Limits

The emissions of the affected boiler shall not exceed the following limits.

Pollutant	Limit	
	Pounds/Hour	Tons/Year
NOx	9.5	41.6
CO	3.5	15.4
PM	2.9	12.5
PM <sub>10</sub> /PM <sub>2.5</sub>	3.8/1.12	16.6/4.9
VOM	0.4	1.66
SO <sub>2</sub>	---	0.62
GHG, as CO <sub>2</sub> e	15,542	68,075
Sulfuric Acid Mist	---	0.0124
Total HAP	---	0.14

2.2.7-1 Performance Tests Pursuant to the NSPS

- a. The Permittee shall conduct an initial performance test related to the SO<sub>2</sub> emissions of the affected boiler pursuant to 40 CFR 60.44c(g) (fuel sampling and analysis) or 40 CFR 60.44c(h) (fuel supplier certification).

- b. Pursuant to 40 CFR 60.47c(a), if the Permittee elects not to use a continuous opacity monitoring system (COMS) (see Condition 2.2.8-2(a)), the Permittee shall conduct a performance test using USEPA Method 9 and the procedures in 40 CFR 60.11 to demonstrate compliance with the applicable opacity limit in 40 CFR 60.43c within 180 days after initial startup of the affected unit. The Permittee shall follow appropriate procedures of the NSPS for this performance test, including notification and reporting in accordance with 40 CFR 60.8.

2.2.7-2 Emission Testing Requirements

- a. The Permittee shall have emissions testing performed for the affected boiler as follows at its expense by a qualified testing service under representative operating conditions:
  - i. Within one year after initial startup of the oxy-combustion boiler, the Permittee shall have tests conducted for emissions of NOx, CO, filterable PM, PM<sub>10</sub> and PM<sub>2.5</sub>, condensable PM, as specified below, provided, however, that if the Permittee considers all PM emissions to be emissions of filterable PM<sub>10</sub> and PM<sub>2.5</sub>, testing for emissions of filterable PM<sub>10</sub> and PM<sub>2.5</sub> need not be performed unless specifically requested by the Illinois EPA.
  - ii. Thereafter, the Permittee shall have tests conducted as requested by the Illinois EPA within 90 days of a written request by the Illinois EPA or such later date agreed to by the Illinois EPA.
- b. USEPA test methods and procedures, including the following test methods shall be used for this testing unless use of other methods adopted or endorsed by USEPA or being developed by USEPA are approved by the Illinois EPA.

Nitrogen Oxide	Method 19
Carbon Monoxide	Method 10
Filterable PM	Method 5
Filterable PM <sub>10</sub> & PM <sub>2.5</sub>	Method 201A
Condensable PM	Method 202

- c.
  - i. Test plans, test notifications, and test reports shall be submitted to the Illinois EPA in accordance with the Condition 3.1.
  - ii. In addition to other information required in a test report, these test reports shall include detailed information on the operating conditions of an affected boiler during testing, including:
    - A. Fuel consumption;
    - B. Firing rate (mmBtu/hour) and other significant operating parameters of the affected boiler;

- C. Opacity of the exhaust, 6-minute averages, as determined by USEPA Method 9 or by continuous opacity monitoring.

2.2.8-1 Fuel Sampling

If the Permittee does not demonstrate compliance with the requirements of Condition 2.2.5(b)) by supplier certification in accordance with 40 CFR 60.48c(e)(11) and (f)(1), the Permittee shall conduct sampling and analysis of the fuel supply for the affected boiler in accordance with 40 CFR 60.46c(d).

2.2.8-2 Opacity Monitoring

Pursuant to 40 CFR 60.47c, for the affected boiler, the Permittee shall comply with the requirements of the NSPS for monitoring of opacity by either:

- a. Installing, calibrating, maintaining and operating a continuous opacity monitoring system in accordance with 40 CFR 60.47c(a) and (b); or
- b. Conducting performance tests for opacity by USEPA Method 9 in accordance with 40 CFR 60.47c(a) (initial testing) and 40 CFR 60.47c(a)(1), (a)(2) or (a)(3), as applicable (subsequent periodic testing) and either:
  - i. Operating according to a written site-specific monitoring plan approved by the Illinois EPA that addresses operating parameters for the affected boiler are indicative of compliance with the opacity standard, in accordance with 40 CFR 60.47c(f)(3); or
  - ii. Calibrating, maintaining and operating a continuous PM CEMS in accordance with 40 CFR 60.47c(d).

2.2.9 Recordkeeping Requirements

- a. The Permittee shall keep the applicable records required by the NSPS, 40 CFR 60 Subpart Dc, for the affected boiler, including:
  - i. Records of oil supplier certification used to demonstrate compliance with the NSPS SO<sub>2</sub> standard in Condition 2.2.3-1(a)(iii) and the requirements in Condition 2.2.5(b), including the information described under 40 CFR 60.48c(f)(1).
  - ii. Records of the amount of each fuel combusted during each calendar month, pursuant to 40 CFR 60.48c(g).
- b. The Permittee shall keep the applicable records required by the NESHAP, 40 CFR 63 Subpart JJJJJJ, for the affected boiler, including records as required to demonstrate continuous

compliance with the work practice and management practice standards of 40 CFR 63.11223, pursuant to 40 CFR 63.11225(c).

- c. The Permittee shall maintain a file with the maximum design heat input capacity of the affected boiler, in mmBtu/hour, with supporting documentation.
- d. The Permittee shall maintain an operating log or other records for the affected boiler that, at a minimum, shall include the information specified by Condition 3.2(a) and the following information:
  - i. Information for each startup and shutdown, including date, time and duration, as required by 40 CFR 60.7(c).
  - ii. Information for any incident in which the operation of the affected boiler continued during malfunction or breakdown, including: date, time, and duration; a description of the incident; whether emissions exceeded or may have exceeded any applicable standard; a description of the corrective actions taken to reduce emissions and the duration of the incident; and a description of the preventative actions taken, as addressed by 40 CFR 60.7(b).
- e. The Permittee shall keep inspection, maintenance, and repair logs for the affected boiler that include the information specified by Condition 3.2(b).
- f. The Permittee shall record the information specified by Condition 3.3 for any period during which the affected boiler deviated from an applicable emission standard, emission limit or other requirement.
- g. The Permittee shall maintain the following records related to emissions from the affected boiler:
  - i. A file containing calculations for the maximum hourly emission rates of NO<sub>x</sub>, CO, PM, PM<sub>10</sub>, PM<sub>2.5</sub>, VOM, SO<sub>2</sub>, sulfuric acid mist, GHG and total HAPs (lbs/mmBtu and lbs/hour), with supporting documentation.
  - ii. Records of other data, not addressed above, used or relied upon by the Permittee to determine emissions.
  - iii. Records of emissions of NO<sub>x</sub>, CO, PM, PM<sub>10</sub>, PM<sub>2.5</sub>, VOM, SO<sub>2</sub>, sulfuric acid mist, GHG, and total HAPs (tons/month and tons/year) with supporting calculations.
- h. The Permittee shall keep records for opacity determinations for the affected boiler made in accordance with Method 9 that it makes or that are made on its behest.

2.2.10 Notification and Reporting Requirements

- a. For the affected boiler, the Permittee shall provide all notifications and reports required by the NSPS, including:
  - i. The date construction of the affected boiler commenced, postmarked no later than 30 days after such date, pursuant to 40 CFR 60.7(a)(1).
  - ii. Notification of the actual date of initial startup of the affected boiler, postmarked within 15 days after such date, pursuant to 40 CFR 60.7(a)(3) and 60.48c(a), which shall include information on the design heat input capacity and expected annual capacity factor of the boiler pursuant to 60.48c(a).
  - iii. Reports for exceedances of the NSPS opacity standard, pursuant to 40 CFR 60.48c(c).
  - iv. Reports related to the sulfur content of the fuel oil used in the affected boiler, pursuant to 40 CFR 60.48c(d) and (e).
- b. For the affected boiler, the Permittee shall provide all notifications and reports required by the NESHAP, including:
  - i. Pursuant to 40 CFR 63.11222(b), the Permittee must report each instance in which the affected boiler did not meet each emission limit and operating limit in Tables 1 and 3 of the NESHAP, 40 CFR 63 Subpart JJJJJJ, that applies. These instances are deviations from the emission limits in this NESHAP. These deviations must be reported according to the requirements in 40 CFR 63.11225.
  - ii. Pursuant to 40 CFR 63.11214(b), the Permittee shall submit a signed statement in the Notification of Compliance Status report that indicates that the performance tune-up under 40 CFR 63.11223(b) was conducted on the affected boiler.
- c. The Permittee shall notify the Illinois EPA of deviations from applicable requirements for the affected boilers as follows. These notifications shall include the information specified by Condition 3.4.
  - i. Deviations from applicable emission standards or work practices of the NSPS or NESHAP, shall be reported in the compliance reports required by these rules.
  - ii. Other deviations from applicable requirements shall be reported in the quarterly report.



SECTION 2.3: UNIT-SPECIFIC CONDITIONS FOR NEW AND MODIFIED COAL HANDLING

2.3.1 Description of Emission Units

The affected units for the purpose of these unit-specific conditions are the new and modified emission units at the source that will handle coal for the oxy-combustion boiler.

With this project, the amount of coal handled by the existing coal handling operations at the source will decrease due to the shutdown of the existing coal-fired boilers. Coal will continue to be received by barge and truck. Therefore requirements for existing coal-handling operations, which are unchanged and are addressed by existing permits, are not addressed in this permit.

2.3.2 Listing of Emission Units and Air Pollution Control Equipment

Unit	Description	Control Measures
Modified Emission Unit		
Existing Conveyor	Extended to connect to new conveyor	Enclosure/Baghouse
New Emission Units		
New Conveyor	Transfers coal to bin for boiler	Baghouse
Coal Bin	Holds coal supply to boiler	

2.3.3-1 Applicable Federal Emission Standards for Coal Handling Operations

- a. The affected units are "affected facilities" subject to the NSPS for Coal Preparation Plants, 40 CFR Part 60 Subpart Y and the General Provisions of the NSPS, 40 CFR 60 Subpart A.
- b. Pursuant to the NSPS, the Permittee shall meet the following opacity and emission limits for the affected units:
  - i. The gases discharged from the affected units shall not exhibit 10 percent opacity or greater. [40 CFR 60.254(b)(1)]
  - ii. The emissions into the atmosphere from the mechanical vents on the affected units shall not contain particulate matter in excess of 0.023 gram/dscm (0.010 grain/dscf). [40 CFR 60.254(b)(2)]
- c. At all times, the Permittee shall maintain and operate the affected units, including associated air pollution control equipment, in a manner consistent with good air pollution control practices for minimizing emissions, pursuant to 40 CFR 60.11(d).

2.3.3-2 Applicable State Emission Standards

- a. Pursuant to 35 IAC 212.123(a), the emission of smoke or other PM from affected units shall not have an opacity greater than 30 percent, 6-minute average, except as provided by 35 IAC

212.123(b) or 35 IAC Part 201 Subpart I. Compliance with this limit shall be determined in accordance with 35 IAC 212.109, including use of USEPA Method 9.

- b. With respect to emissions of fugitive PM, affected units shall comply with 35 IAC 212.301, which provides that emissions of fugitive PM shall not be visible from any process, including any material handling or storage activity, when looking generally toward the zenith at a point beyond the property line of the source, except when the wind speed exceeds 25 miles per hour, as provided by 35 IAC 212.314.

2.3.4 Non-Applicability Provisions

- a. This permit is issued based on the affected units not being subject to 35 IAC 212.321 pursuant to 35 IAC 212.323, which provides that 35 IAC 212.321 shall not apply to emission units, such as stock piles, to which, because of the disperse nature of such emission units, such rules cannot reasonably be applied.
- b. This permit is issued based on the affected units not being subject to the requirements of the NSPS, 40 CFR 60.256(b) and (c), for operational monitoring because the potential PM emissions of each unit are less than 25 Mg (28 tons) per year, as provided by 40 CFR 60.256(b) (1).

2.3.5 Operating Requirements

- a. The Permittee shall implement and maintain control measures for the affected units that minimize visible emissions of PM and provide assurance of compliance with the applicable limits and standards in Conditions 2.3.3-1 and 2.3.3-2.
- b. The affected units, including associated control equipment shall be operated and maintained in accordance with good air pollution control practices to minimize emissions.

2.3.6 Emission Limits

The emissions of the affected units shall not exceed the following limits:

Emission Unit	Emission Limits			
	PM		PM <sub>10</sub> /PM <sub>2.5</sub>	
	Lbs/Ton Coal	Tons/Yr	Lbs/Ton Coal	Tons/Yr
Modified Conveyor (transfer point)	0.01	3.72	0.0047	1.75
New Conveyor and Coal Bins	0.01	3.72	0.0047	1.75
Total	-	7.45	-	3.5

2.3.7 Performance Testing for PM Emissions and Opacity

- a. i. For the affected units, for PM emissions and opacity, the Permittee shall fulfill applicable requirements in the NSPS, 40 CFR 60.8 and 60.255(b) for initial performance testing using the methods and procedures specified by the NSPS.
- ii. With the report for these performance tests, the Permittee shall notify the Illinois EPA of the approach that it intends to subsequently follow for periodic performance testing or compliance monitoring under the NSPS for PM emissions and opacity.
- b. Following the initial performance tests, as addressed above, the Permittee shall conduct subsequent performance tests or demonstrate compliance with the NSPS as follows. The Permittee shall notify the Illinois EPA within 30 days if it decides to change its approach to ongoing testing or compliance.
  - i. Subsequent performance tests for PM emissions shall be conducted according to the requirements of 40 CFR 60.255(b)(1)(i) through (iii), as applicable, or the Permittee shall comply with the requirements of 40 CFR 60.255(d), (e) or (f).
  - ii. Subsequent performance tests for opacity shall be conducted according to the applicable requirements of 40 CFR 60.255(b)(2)(i) through (iii) or the Permittee shall comply with 40 CFR 60.255(f) or (g).

2.3.8 Recordkeeping

- a. For the affected units, the Permittee shall keep the applicable records required by the NSPS, 40 CFR 60 Subpart Y, including maintaining a logbook that includes the applicable information specified by 40 CFR 60.258(a).
- b. The Permittee shall keep records for the total amount of material handled by the affected units, as measured at a point before the oxy-combustion boiler (tons/month and tons/year).
- c. The Permittee shall record the information specified by Condition 3.3 for any period during which an affected unit deviated from an applicable emission standard, emission limit or other requirement.
- d. The Permittee shall maintain the following records for the emissions of the affected units:
  - i. A file containing calculations for the maximum emission rates of each affected unit for PM and PM<sub>10</sub>/PM<sub>2.5</sub>, in pounds/ton of coal handled, with supporting documentation and calculations.

- ii. Records of PM and PM<sub>10</sub>/PM<sub>2.5</sub> emissions (tons/month and tons/year), with supporting calculations.
- e. The Permittee shall keep records for opacity determinations for the affected units made in accordance with Method 9 that it makes or that are made on its behest.

2.3.9 Reporting Requirements

- a. For the affected units, the Permittee shall provide all notifications and reports required by the NSPS, including reports of excess emissions in accordance with 40 CFR 60.258(b).
- b. The Permittee shall promptly notify the Illinois EPA of deviations from permit requirements for the affected units, as follows. These notifications shall include the information specified by Condition 3.4.
  - i. The Permittee shall notify the Illinois EPA within 30 days of deviations that continue for more than 24 hours.
  - ii. The Permittee shall report other deviations with the quarterly compliance reports required for the oxy-combustion boiler.

SECTION 2.4: UNIT-SPECIFIC CONDITIONS FOR BULK MATERIAL HANDLING OPERATIONS

2.4.1 Description of Emission Units

The affected units for the purpose of these unit-specific conditions are the new emission units at the plant that will handle bulk materials other than fuel that are involved with the operation of the plant. Hydrated lime and Trona (mineral sodium carbonate) are received, handled and stored as a raw material for the scrubbers on the oxy-combustion boiler. Fly ash and dry residue from the baghouses and the dry scrubber on the boiler are also handled, temporarily stored, and loaded out from the plant by truck.

2.4.2 Listing of Emission Units and Air Pollution Control Equipment

Unit	Description	Control Measures
Lime System	Handling of Hydrated Lime	Baghouse
Trona System	Handling of Trona	Baghouse
Ash System	Handling of Ash and Residue	Baghouse/Wetting

2.4.3 Applicable State Emission Standards

- a. Pursuant to 35 IAC 212.123(a), the emission of smoke or other PM from affected units shall not have an opacity greater than 30 percent, 6-minute average except as provided by 35 IAC 212.123(b) or 35 IAC Part 201 Subpart I. Compliance with this limit shall be determined in accordance with 35 IAC 212.109, including use of USEPA Method 9.
- b. With respect to emissions of fugitive PM, affected units shall comply with 35 IAC 212.301, which provides that emissions of fugitive PM shall not be visible from any process, including any material handling or storage activity, when looking generally toward the zenith at a point beyond the property line of the source, except when the wind speed exceeds 25 miles per hour, as provided by 35 IAC 212.314.
- c. The affected units shall comply with the applicable limit of 35 IAC 212.321, which rule limits emissions based on the process weight rate of emission units and allows a minimum emission rate of 0.55 lb/hour for any individual unit.

2.4.4 Non-Applicability Provisions

This permit is issued based on the affected units that handle nonmetallic minerals as defined by 40 CFR 60.671 not being subject to the NSPS for Nonmetallic Mineral Processing Plants, 40 CFR 60 Subpart 000, as these materials are not ground or crushed at the plant.

2.4.5 Operating Requirements

- a. The control devices on the affected units shall be designed to emit no more than 0.02 grains/dry standard cubic foot (gr/dscf).
- b. The moisture content of dry ash from the oxy-combustion boiler, including the dry solids from the circulating dry scrubber (CDS), as loaded out from the facility, shall be at least 15 percent, by weight.

2.4.6 Emission Limits

The emissions of PM and PM<sub>10</sub>/PM<sub>2.5</sub> from the affected units, in total, shall each not exceed the following limits:

Emission Units	Emission Limits			
	PM		PM <sub>10</sub> /PM <sub>2.5</sub>	
	Lbs/Ton	Tons/Yr	Lbs/Ton	Tons/Yr
Lime System	0.09	3.06	0.09	3.06
Trona System	0.012	0.02	0.012	0.02
Ash System	0.03	2.60	0.03	2.59
Total	-	5.7	-	5.7

2.4.7 Emission Testing

- a. Within 90 days of a written request from the Illinois EPA, the Permittee shall have the PM emissions at the stacks or vents of affected units, as specified in such request, measured during representative operating conditions, as set forth below.
- b.
  - i. Testing shall be conducted using appropriate USEPA Methods, including either Method 5 or 17.
  - ii. Compliance may be determined from the average of three valid test runs, subject to the limitations and conditions contained in 35 IAC Part 283.
- c. For this testing, the Permittee shall fulfill requirements in Condition 3.1. In addition, the test report shall indicate whether visible emission were present during testing and, if present, include representative data for the opacity or emissions, as determined by USEPA Method 9, for the period of testing.

2.4.8-1 Operational Monitoring

For the pugmill in the ash system, which mixes water with dry ash from the oxy-combustion boiler, the Permittee shall install, operate and maintain instrumentation to measure and record the amount of water mixed with the ash to confirm compliance with the requirement in Condition 2.4.5(b).

2.4.8-2 Inspections

- a. i. The Permittee shall conduct inspections of affected units while they are in operation for the specific purpose of verifying that the control measures for the affected units are being properly operated and maintained. These inspections shall be conducted by supervisory or management personnel or shall be overseen by such personnel. The inspections of the units that handle dry ash (i.e., ash to which water has not been introduced) shall be conducted at least weekly and the inspections of other units shall be conducted at least monthly, provided however, inspections are not required during weeks or months when the oxy-combustion boiler is not in service.
- ii. These inspections shall include observation for the presence of visible emissions from buildings in which affected units are located, which observations shall generally be performed in accordance with USEPA Method 22 except that the duration of observations shall only be one minute.
- b. The Permittee shall perform detailed inspections of the filter control devices for affected units while the affected units are out of service. These inspections shall be conducted at least every 24 months.

2.4.9 Recordkeeping

- a. For the affected units, the Permittee shall maintain file(s), which shall be kept current, that contain:
  - i. For the filters associated with affected units, the design specifications for each device (type of unit, maximum design exhaust flow (acfm and dscfm), filter area, type of filter cleaning, performance guarantee for particulate exhaust loading in gr/dscf) and the manufacturer's recommended operating and maintenance procedures for the device.
  - ii. The maximum operating capacity of the units or group of related units (tons/hour) and a demonstration that the units comply with 35 IAC 212.321 at the maximum process weight rate at which they will be operated (tons/hour), with supporting documentation for the emission factors and the efficiency or performance of control devices being relied upon by the Permittee.
- b. For the affected units, the Permittee shall keep records for the amount of material received by or loaded out from the plant by category or type of material (tons/month and tons/year).
- c. i. The Permittee shall keep inspection and maintenance log(s) or other records for the control measures

associated with the affected units, including control devices and buildings and enclosures, which include the information specified by Condition 3.2(b).

- ii. These records shall include the following information for the inspections required by Condition 2.4.8-2(a):
  - A. Date and time the inspection was performed and name(s) of inspection personnel.
  - B. The observed condition of the control measures for each affected unit.
  - C. A description of any maintenance or repairs associated with established control measures that are recommended as a result of the inspection.
  - D. A summary of the observed implementation or status of control measures.
- iii. These records shall include the following information for the inspections of control devices required by Condition 2.4.8-2(b):
  - A. Date and time the inspection was performed and name(s) of inspection personnel.
  - B. The observed condition of the control device.
  - C. A summary of any maintenance or repairs that is recommended as a result of the inspection.
  - D. A summary of the observed condition of the device as related to its ability to reliably and effectively control PM emissions.
- d. The Permittee shall record the information specified by Condition 3.3 for any period during which an affected unit deviated from an applicable emission standard, emission limit or other requirement.
- e. The Permittee shall maintain the following records for the emissions of the affected units:
  - i. A file containing calculations for the maximum emission rates of each system for PM and PM<sub>10</sub>/PM<sub>2.5</sub>, in pounds/ton of material handled, with supporting documentation and calculation
  - ii. Records of emissions of PM and PM<sub>10</sub>/PM<sub>2.5</sub> based on operating data for the unit(s) and appropriate emission factors, with supporting documentation and calculations.



- f. The Permittee shall keep records for opacity determinations for the affected unit made in accordance with Method 9 that it makes or that are made on its behest.

2.4.10 Reporting Requirements

- a. The Permittee shall promptly notify the Illinois EPA of deviations from permit requirements for the affected units, as follows. These notifications shall include the information specified by Condition 3.4.
  - i. The Permittee shall notify the Illinois EPA within 30 days of deviations that continue for more than 24 hours.
  - ii. The Permittee shall notify the Illinois EPA of other deviations with the quarterly reports required for the oxy-combustion boiler.

SECTION 2.5 UNIT-SPECIFIC CONDITIONS FOR THE COOLING TOWERS

2.5.1 Description of Emission Units

The affected units for the purpose of these unit-specific conditions are the main cooling tower at the source, which will be rebuilt, and two new cooling towers, which will supply the cooling water now needed by the plant.

The cooling towers are sources of particulate emissions because of mineral material present in the water supply for the towers. This material is emitted to the atmosphere with water droplets that escape from the cooling tower or completely evaporate. These particulate emissions are controlled by the drift eliminators on the towers, which collect water droplets entrained in the air passing through the tower.

2.5.2 List of Emission Units and Air Pollution Control Equipment

Unit	Description	Control Measures
DCCPS Cooling Tower	New cooling tower serving the Direct Contact Cooler Polishing Scrubber (DCCPS)	Drift Eliminator
ASU/CPU Cooling Tower	New cooling tower serving the Air Separation Unit and Compression Purification Unit	Drift Eliminator
Main Cooling Tower	Rebuilt cooling tower serving the Steam Turbine Generator	Drift Eliminators

2.5.3 Applicable Emission Standards

- a. Pursuant to 35 IAC 212.123(a), the emission of smoke or other PM from each affected unit shall not have opacity greater than 30 percent, 6-minute average, except as provided by 35 IAC 212.123(b) and 35 IAC Part 201 Subpart I. Compliance with this limit shall be determined in accordance with 35 IAC 212.109, including use of USEPA Method 9.
- b. Each affected unit shall comply with 35 IAC 212.301, which provides that emissions of fugitive PM shall not be visible from any process, including any material handling or storage activity, when looking generally toward the zenith at a point beyond the property line of the source, except when the wind speed exceeds 25 miles per hour, as provided by 35 IAC 212.314.
- c. The emissions of PM from each affected unit shall comply with the applicable limit pursuant to 35 IAC 212.321.

2.5.4 Non-Applicability Provisions

This permit is issued based on the affected units not being subject to the NESHAP for Industrial Process Cooling Towers (40 CFR 63 Subpart Q) because chromium-based water treatment chemicals will not be used.

2.5.5 Operating Requirements

- a. Chromium-based water treatment chemicals, as defined in 40 CFR 63.401, shall not be used in the affected units.
- b.
  - i. Only non-VOM additives shall be used in the affected units.
  - ii. Plant process wastewater shall not be introduced into cooling water for the Main Cooling Tower, other than through unintentional leaks, which shall promptly be repaired.
- c. The Permittee shall operate and maintain the affected units, including the drift eliminators, in a manner consistent with good air pollution control practices for minimizing emissions. For this purpose, the Permittee shall operate and maintain the affected units in accordance with written procedures, which procedures shall be kept current.

2.5.6 Emission Limits

- a. The emissions of the affected units shall not exceed the following limits, as determined by appropriate emission determination methodology and calculations.

Emission Units	Emission Limits (Tons/Year)	
	PM	PM <sub>10</sub> /PM <sub>2.5</sub>
DCCPS Cooling Tower	2.47	2.35
ASU/CPU Cooling Tower	1.05	1.00
Main Cooling Tower	1.07	1.01
Total	4.59	4.36

2.5.7 Sampling and Analysis of Cooling Water

- a. The Permittee shall sample and analyze the water being circulated in each affected unit for total dissolved solids content on at least a monthly basis. Measurements of the total dissolved solids content in the wastewater discharge associated with an affected unit, as required by a National Pollution Discharge Elimination System permit, may be used to satisfy this requirement if the effluent has not been diluted or otherwise treated in a manner that would significantly reduce its total dissolved solids content.
- b. Upon written request by the Illinois EPA, the Permittee shall promptly have the water circulating in an affected unit sampled and analyzed for the presence of hexavalent chromium in accordance with the procedures of 40 CFR 63.404(a) and (b).
- c. The Permittee shall keep records for this sampling and analysis activity, including documentation for sampling and analysis as well as the resulting data that is collected.

2.5.8 Records

- a. The Permittee shall keep a file that contains the following information for each affected unit:
  - i. The design loss specification for the drift eliminators installed in the unit, with supporting documentation.
  - ii. The supplier's recommended procedures for inspection and maintenance of the drift eliminators.
  - iii. The operating factors, if any, used to determine the amount of water circulated in the unit and the PM and PM<sub>10</sub>/PM<sub>2.5</sub> emissions from the unit, with supporting documentation.
  - iv. Copies of the Material Safety Data Sheets or other comparable information from the suppliers of the various water treatment chemicals that are added to the water circulated in the units.
- b. The Permittee shall keep the records for the amount of water circulated in each affected unit (gallons/month). As an alternative to direct data for water flow, these records may contain other relevant operating data for a unit (e.g., water flow to the unit) from which the amount of water circulated in the unit may be reasonably determined.
- c. The Permittee shall maintain an operating log or other similar records for the affected units that include the information specified in Condition 3.2(a).
- d. The Permittee shall keep inspection and maintenance logs or other records for the affected units, including the drift eliminators in the units, which shall include the information specified in Condition 3.2(b).
- e. The Permittee shall record the information specified by Condition 3.3 for any period during which an affected unit deviated from an applicable emission standard, emission limit or other requirement.
- f. The Permittee shall maintain records for the PM and PM<sub>10</sub>/PM<sub>2.5</sub> emissions of the affected units (tons/month and tons/year), with supporting calculations.

2.5.9 Reporting Requirements

- a. The Permittee shall promptly notify the Illinois EPA of deviations of an affected unit with permit requirements, as follows. These notifications shall include the information specified by Condition 3.4.

- i. If a cooling tower is damaged so there is a deviation from an applicable requirement that is not repaired or otherwise corrected within 48 operating hours, the Permittee shall notify the Illinois EPA as soon as possible during normal working hours, but no later than seven days after the event occurred.
- ii. All other deviations shall be reported in a quarterly report, which reports shall be submitted with the periodic compliance reports required for the oxy-combustion boiler.

SECTION 2.6: UNIT-SPECIFIC CONDITIONS FOR ROADWAYS

2.6.1 Description of Emission Units

The affected units for the purpose of these unit-specific conditions are roadways and parking areas at the source, which emit fugitive particulate due to vehicle traffic and windblown dust. As part of this project, certain existing roads will be paved so that in the future, the principal roadways at the source will all be paved.

2.6.2 Applicable State Emission Standards

- a. Pursuant to 35 IAC 212.123(a), the emission of smoke or other PM from the affected units shall not have an opacity greater than 30 percent, except as provided by 35 IAC 212.124. Compliance with this limit shall be determined in accordance with 35 IAC 212.104, including use of USEPA Method 9.
- b. Pursuant to 35 IAC 212.301, emissions of fugitive PM shall not be visible from any process, including any material handling or storage activity, when looking generally toward the zenith at a point beyond the property line of the source, except when the wind speed exceeds 25 miles per hour, as provided by 35 IAC 212.314.

2.6.3 Operating Requirements

- a. Principal roadways at the source shall be paved and paving shall be maintained in good condition. For this purpose, the principal roadways are the haul roads for coal, lime, trona and ash and the roads serving the employee and visitor parking lots. This requirement shall take effect upon initial startup of the oxy-combustion boiler, provided however that the portions of principal roadways in areas where they might be damaged by the continuing presence of heavy construction equipment (e.g., cranes and tracked vehicles) must promptly be paved after that equipment is removed and paving would no longer be at risk of being damaged and in no case later than 90 days after the initial startup of the oxy-combustion boiler.
- b. If compliance with the requirements in Conditions 2.6.2 and 2.6.4 necessitates more than implementation of normal housekeeping practices to reduce PM emissions from the affected units, the Permittee shall treat the affected units (e.g., flushing or vacuuming) or carry out other practices for affected units as necessary to assure compliance in accordance with a written operating program that it prepares.
  - i. This program, if required, shall include the following at a minimum:
    - A. Maps or diagrams with the location of affected units, descriptions of the units (length, width and

surface material) and volume and nature of expected vehicle traffic.

- B. Descriptions of the various practices that are implemented for the various affected units to reduce PM emissions of the affected units, including: type of treatment; normal frequency of treatment; for use of dust suppressant, type and concentration of suppressant; the expected effectiveness of the practice(s) in reducing PM emissions, with supporting documentation; the circumstances in which particular practice(s) would not be implemented (e.g., recent precipitation or freezing temperatures); and circumstances in which additional or alternative measures would be implemented (extended hot weather).
- ii. The program shall be prepared and maintained by the Permittee as follows, so the program is kept current:
  - A. An initial program shall be submitted to the Illinois EPA within 30 days of the date that it is determined that such a program is needed.
  - B. Revisions to the program initiated by the Permittee shall be submitted to the Illinois EPA within ten days of the date that the revision takes effect.
  - C. A revised operating program shall be submitted to the Illinois EPA for review within 90 days of a request from the Illinois EPA for revision to address observed deficiencies in control of PM emissions of affected unit(s).
- c. The handling of material collected from the affected units by sweeping or vacuuming trucks shall be enclosed or shall utilize spraying, pelletizing, screw conveying or other equivalent methods to control PM emissions.
- d. The amount of coal received at the plant by truck shall not exceed 446,760 tons/year.

#### 2.6.4 Emission Limits

The emissions of PM and PM<sub>10</sub>/PM<sub>2.5</sub> from the affected units, in total, shall not exceed 9.6 and 1.9 tons/year, respectively. Compliance with these limits shall be determined from the amount and nature of vehicle traffic associated with the operation of the plant, specific operating information for affected units and information for the operating program, using a credible emission estimation methodology as developed by USEPA or other recognized authority.

2.6.5-1 Inspections

- a. i. The Permittee shall conduct inspections of affected units on at least a quarterly basis for the specific purpose of verifying that normal housekeeping practices are being properly implemented, or if applicable, that the operating program required by Condition 2.6.3(b) for the affected units is being implemented. These inspections shall be conducted by supervisory or management personnel or shall be overseen by such personnel.
- ii. As part of these inspections, the Permittee shall verify compliance with Condition 2.6.3(a).
- b. The Permittee shall keep records for these inspections, which shall include the following information, at a minimum:
  - i. Date and time the inspection was performed and the name(s) and position(s) of inspection personnel.
  - ii. The observed condition of the control practices for the affected units.
  - iii. A description of any changes to control practices that are recommended as a result of the inspection.
  - iv. A summary of the observed implementation or status of the operating program.
  - v. If the inspection was not performed by supervisory or management personnel, the name(s) and position(s) of the supervisory or management personnel who oversaw the inspection.
  - vi. The condition of the pavement on principal roadways.

2.6.5-2 Operational Measurements

- a. The Permittee shall conduct measurements of the silt loading on various affected roadway segments as follows. This sampling and analysis shall be conducted using the "Procedures for Sampling Surface/Bulk Dust Loading," Appendix C.1 in Compilation of Air Pollutant Emission Factors, USEPA, AP-42. A series of samples shall be taken to determine the average silt loading.
- b. Measurements shall be performed by the following dates:
  - i. Measurements shall first be completed no later than 30 days after initial startup of the oxy-combustion boiler.
  - ii. Measurements shall be repeated within 30 days of a change involving affected units that would act to increase silt loading, including changes in the housekeeping practices



or operating program for affected units, so data representative of the current circumstances of the affected units has been collected.

- iii. Upon written request by the Illinois EPA, the Permittee shall conduct measurements, as specified in the request, which shall be completed within 75 days of the Illinois EPA's request.
- c. The Permittee shall submit test plans, test notifications and test reports for these measurements as specified by General Condition 3.1(a), provided, however, that once a test plan has been accepted by the Illinois EPA, a new test plan need not be submitted if the accepted plan will be followed unless a new test plan is requested by the Illinois EPA.

#### 2.6.6 Records

- a. The Permittee shall keep a file that contains:
  - i. The conversion factors used by the Permittee to determine the nature and amount of vehicle traffic associated with the affected units based on the amounts of various materials handled and the PM and PM<sub>10</sub>/PM<sub>2.5</sub> emissions of the affected units, with supporting documentation.
  - ii. The design PM and PM<sub>10</sub>/PM<sub>2.5</sub> emission rates, in tons/year, from the plant considering maximum amounts of vehicle traffic needed to support the operation of the plant, with supporting calculations and documentation, a description of the control measures that are needed to ensure compliance with the emission limits in Condition 2.6.4, and a determination whether or not control measures must be conducted in accordance with a written operating program, in accordance with Condition 2.6.3(b).
- b. If the Permittee must implement an operating program pursuant to Condition 2.6.3(b), the Permittee shall maintain records documenting implementation of the operating program, including:
  - i. For each treatment of an affected unit or units that is not automated, identification of the affected unit(s) and the date, time and type of treatment.
  - ii. Records for incidents when the standard practices in the operating program were not implemented and for incidents when additional treatments or control practices were implemented due to particular circumstances, including description, date, explanation, and expected duration of such circumstances.
- c. The Permittee shall keep records of amount of coal (truck only), lime and trona received by the plant and the amount of ash loaded out from the plant (tons/month and tons/year).

- d. The Permittee shall maintain records of the PM and PM<sub>10</sub>/PM<sub>2.5</sub> emissions of the affected units (tons/month and tons/year), with supporting calculations.

2.6.7 Notification and Reporting Requirements

The Permittee shall notify the Illinois EPA of deviations of permit requirements for the affected units in a quarterly report, which report shall be submitted with the periodic compliance reports required for the oxy-combustion boiler. These notifications shall include the information specified by Condition 3.4.

SECTION 3: GENERAL PERMIT CONDITIONS

3.1 General Requirements for Emission Testing

- a. At least 60 days prior to the actual date of initial emission testing required by this permit, a written test plan shall be submitted to the Illinois EPA for review. This plan shall describe the specific procedures for testing and shall include at a minimum:
  - i. The person(s) who will be performing sampling and analysis and their experience with similar tests.
  - ii. The specific conditions, e.g., operating rate and control device operating conditions, under which testing shall be performed including a discussion of why these conditions will be representative and the means by which the operating parameters will be determined.
  - iii. The specific determinations of emissions that are intended to be made, including sampling and monitoring locations.
  - iv. The test method(s) that will be used, with the specific analysis method if the method can be used with different analysis methods.
- b.
  - i. The Permittee shall notify the Illinois EPA prior to performing emissions testing required by this permit to enable the Illinois EPA to observe the tests. Notification for the expected date of testing shall be submitted a minimum of 30 days prior to the expected date, and identify the testing that will be performed. Notification of the actual date and expected time of testing shall be submitted a minimum of 5 working days prior to the actual date of testing. Notwithstanding applicable rules, the Illinois EPA may at its discretion accept notifications with shorter advance notice provided that the Illinois EPA will not accept such notifications if it interferes with the Illinois EPA's ability to observe testing.
  - ii. This notification shall also identify the parties that will be performing testing and the set or sets of operating conditions under which testing will be performed.
- c. Three copies of the Final Reports for emission tests shall be forwarded to the Illinois EPA within 30 days after the test results are compiled and finalized but not later than 90 days after the date of testing. At a minimum, the Final Report for testing shall contain the following. Copies of emission test reports shall be retained for at least five years after the date that an emission test is superseded by a more recent test.
  - i. A tabular summary of results which includes:

- Process rates (e.g., fuel usage rate or firing rate)
  - Measured emission rates for different pollutants tested
  - Emission factor, calculated using the average test results in the terms of the applicable limits, for example, in units of lbs pollutant emitted per mmBtu
  - Compliance demonstrated - Yes/No.
- ii. Description of test method(s) and procedures, including a description of sampling points, sampling train, analysis equipment, and test schedule.
- iii. Detailed description of test conditions, including:
- Pertinent process information (e.g., the usage and type of fuel or raw material and the firing or operating rate.)
  - Control equipment information (i.e., monitored data and other relevant operating parameters during testing).
- iv. Data and calculations, including copies of all raw data sheets and records of laboratory analysis, sample calculations, and data on equipment calibration.

3.2 General Requirements for "Logs" or Similar Records

- a. Operating logs or other similar records required by this permit shall, at a minimum, include the following information related to the emission units and associated control system:
- i. Information identifying periods when an emission unit or group of related emission units was not in service.
  - ii. For periods when a unit or group of related units is in service and operating normally, relevant process and control system information to generally confirm normal operation.
  - iii. For periods when a unit or group of related units is in service and is not operating normally, identification of each such period, with detailed information describing the operation of the unit(s), the potential consequences for additional emissions from the unit(s), the potential of any excess emissions from the affected unit(s), the actions taken to restore normal operation, and any actions taken to prevent similar events in the future.
  - iv. Other information as may be appropriate to show that the emission unit or group of related emission units is operated in accordance with good air pollution control practices.

- b. Inspection, maintenance and repair logs or other similar information required by this permit shall, at a minimum, include the following information related to the emission units and associated control system:
  - i. Identification of equipment, with date, time, responsible employee and type of activity.
  - ii. For inspections, a description of the inspection, findings, and any recommended actions, with reason.
  - iii. For maintenance and repair activity, a description of actions taken, reason for action (e.g., preventative measure or corrective action as a result of inspection), probable cause for requiring maintenance or repair if not routine or preventative, and the condition of equipment following completion of the activity.
  - iv. Other information as may be appropriate to show that the emission unit or group of related emission units is maintained in accordance with good air pollution control practices, including prompt repair of defects that interfere with effective control of emissions.
- c. All records and logs required by this permit shall be retained at a readily accessible location at the source for at least five years from the date of entry and shall be available for inspection and copying by the Illinois EPA upon request. Any record retained in an electronic format (e.g., computer) shall be capable of being retrieved and printed on paper during normal source office hours so as to be able to respond to an Illinois EPA request for records during the course of an on-site inspection. The logs required by this permit may be part of a larger database maintained by the Permittee provided that the information that is required to be kept is readily accessible.

### 3.3 General Requirements for Records for Deviations

- a. Except as specified in a particular provision of this permit or in a subsequent CAAPP Permit for the plant, records for deviations from applicable requirements shall include at least the following information: the date, time and estimated duration of the deviation; a description of the deviation; the manner in which the deviation was identified, if not readily apparent; the probable cause for deviation, if known, including a description of any equipment malfunction or breakdown associated with the deviation; information on the magnitude of the deviation, including actual emissions or performance in terms of the applicable standard if measured or readily estimated; confirmation that standard procedures were followed or a description of any event-specific corrective actions

taken; and a description of any preventative measures taken to prevent future occurrences, if appropriate.

3.4 General Requirements for Reporting of Deviations

- a. The Permittee shall include the following information in records and reports for deviations:
  - i. Identity of the deviation, with date, time, duration and description.
  - ii. Describe the effect of the deviation on compliance, with an estimate of the excess emissions that accompanied the deviation, if any.
  - iii. Describe the probable cause of the deviation and any corrective actions or preventive measures taken.
- b. Unless otherwise specified in a particular condition of this permit, if deviation(s) from requirements of this permit occurs during a calendar quarter, a report shall be submitted no later than 45 days after the end of the quarter. This report shall also provide a listing of all deviations for which earlier reporting was required, but need not include copies of the previously submitted information.
- c. For the purpose of determining whether a deviation must be reported prior to a periodic compliance report, a deviation shall be considered to continue even if operation of an emission unit is interrupted if the deviation is still present when operation of the unit is resumed.

## ATTACHMENT 1: SUMMARY OF PROJECT EMISSIONS

Table 1A: Summary of Project Emissions (Tons/Year)

Emission Unit(s)	NOx	CO	VOM	SO <sub>2</sub>	PM	PM <sub>10</sub> / PM <sub>2.5</sub> <sup>a</sup>	GHG (as CO <sub>2</sub> e)	Acid Mist	Lead	Fluorides	Indiv.HAP/ Total HAPS
Meredosia Energy Center (New and Modified Units) <sup>b</sup>											
Oxy-Combustion Boiler	1,691.7	281.2	9.9	196.4	27.8	45.3/45.3	1,453,928	10.5	0.15	1.6	4.5/19.86
Auxiliary Boiler	41.6	15.4	1.7	0.6	12.5	16.6/4.9	68,075	0.012	0.004	-	-/0.14
New & Modified Coal Handling	-	-	-	-	7.5	3.5	-	-	-	-	-
Other Material Handling	-	-	-	-	5.7	5.7	-	-	-	-	-
Cooling Towers	-	-	-	-	4.6	4.4	-	-	-	-	-
Roadways	-	-	-	-	9.6	1.9	-	-	-	-	-
Sub-Total:	1733.3	296.6	11.6	197.0	67.7	77.4/65.7	1,522,003	10.5	0.154	1.6	4.5/20
Sequestration Facility <sup>c</sup>	1.1	0.4	0.4	0.44	0.4	0.4	500	0.0088	-	-	-
Total	1734.4	297.0	12.0	197.4	68.1	77.8/66.1	1,522,503	10.521	0.154	1.6	4.5/20
Significance Threshold:	40	100	40	40	25	15/10	75,000	7	0.6	3.0	-
Greater Than Significant?	Yes	Yes	No	Yes	Yes	Yes	Yes	Yes	No	No	-

## Notes:

- PM<sub>10</sub> and PM<sub>2.5</sub> emissions include condensable particulate, as well as filterable particulate.
- This summary does not consider existing coal handling operations at the Meredosia Energy Center. With this project, there will be a reduction in the amount of coal that is handled by these existing operations, with an accompanying reduction in the PM emissions of these operations.
- Even though the sequestration facility will have negligible or minimal emissions of different pollutants, this facility is being addressed as part of the permitting of this new oxy-combustion power plant. This is because the sequestration facility is considered a support facility for this new power plant under the PSD rules. In this regard, a separate air pollution control construction permit has been issued to the FutureGen Industrial Alliance for an engine-generator to provide emergency power for the buildings at the sequestration facility (Construction Permit No. 12020051).

Table 1B: Analysis of Net Changes in Emissions (Tons/Year)

	NOx	CO	SO <sub>2</sub>	PM	PM <sub>10</sub> /PM <sub>2.5</sub>	GHG (as CO <sub>2</sub> e)	Acid Mist
Project Potential Emissions	1734.4	297.0	197.4	68.1	77.8/66.1	1,522,503	10.521
Contemporaneous Increases and Decreases in Emissions <sup>a</sup>							
Increases							
Emergency Engine-Generator <sup>b</sup>	32	39.4	0.4	1.9	0.8/0.8	2280	0.008
Decreases							
Shutdown of Existing Boilers <sup>c</sup>	-2813	-1369	-9541	-310	-310/-186	-1,937,858	-3.58
Existing Main Cooling Tower	-	-	-	-3	-3/-3	-	-
Subtotal	-2781	-1329.6	-9540.2	-311.1	-312.2/-188.2	-1,935,578	-3.58
Net Emission Change <sup>d</sup>	-1047.6	-1032.6	-9343.2	-243.0	-234.4/-119.9	-413,075	6.949
Significance Threshold:	40	100	40	25	15/10	75,000	7.00
Greater Than Significant?	No	No	No	No	No	No	No

## Notes:

- a. This netting analysis is based on the contemporaneous time period for this project beginning in July 2009, which is five years before July 2014, when the application indicates that construction on the new oxy-combustion boiler would commence.
- b. Emergency diesel engine-generator installed at the Meredosia Energy Center pursuant to Construction Permit 08100029.
- c. The contemporaneous decreases in emissions are the actual emissions from the existing boilers that are being permanently shut down (Meredosia Boilers 1 through 6). The project would also be accompanied by decreases in emissions of VOM, estimated at 374 tons/year, and decreases in emissions of lead and fluorides, which were not quantified in the application.
- d. The change in emissions is the difference between the past emissions and the future emissions. As shown, Ameren's application indicates that there will not be a significant increase for any PSD pollutant.



ATTACHMENT 2: STANDARD PERMIT CONDITIONS

STANDARD CONDITIONS FOR CONSTRUCTION/DEVELOPMENT PERMITS  
ISSUED BY THE ILLINOIS ENVIRONMENTAL PROTECTION AGENCY

The Illinois Environmental Protection Act (Illinois Revised Statutes, Chapter 111-1/2, Section 1039) authorizes the Environmental Protection Agency to impose conditions on permits, which it issues.

The following conditions are applicable unless superseded by special condition(s).

1. Unless this permit has been extended or it has been voided by a newly issued permit, this permit will expire one year from the date of issuance, unless a continuous program of construction or development on this project has started by such time.
2. The construction or development covered by this permit shall be done in compliance with applicable provisions of the Illinois Environmental Protection Act and Regulations adopted by the Illinois Pollution Control Board.
3. There shall be no deviations from the approved plans and specifications unless a written request for modification, along with plans and specifications as required, shall have been submitted to the Illinois EPA and a supplemental written permit issued.
4. The Permittee shall allow any duly authorized agent of the Illinois EPA upon the presentation of credentials, at reasonable times:
  - a. To enter the Permittee's property where actual or potential effluent, emission or noise sources are located or where any activity is to be conducted pursuant to this permit,
  - b. To have access to and to copy any records required to be kept under the terms and conditions of this permit,
  - c. To inspect, including during any hours of operation of equipment constructed or operated under this permit, such equipment and any equipment required to be kept, used, operated, calibrated and maintained under this permit,
  - d. To obtain and remove samples of any discharge or emissions of pollutants, and
  - e. To enter and utilize any photographic, recording, testing, monitoring or other equipment for the purpose of preserving, testing, monitoring, or recording any activity, discharge, or emission authorized by this permit.

5. The issuance of this permit:
  - a. Shall not be considered as in any manner affecting the title of the premises upon which the permitted facilities are to be located;
  - b. Does not release the Permittee from any liability for damage to person or property caused by or resulting from the construction, maintenance, or operation of the proposed facilities;
  - c. Does not release the Permittee from compliance with other applicable statutes and regulations of the United States, of the State of Illinois, or with applicable local laws, ordinances and regulations;
  - d. Does not take into consideration or attest to the structural stability of any units or parts of the project; and
  - e. In no manner implies or suggests that the Illinois EPA (or its officers, agents or employees) assumes any liability, directly or indirectly, for any loss due to damage, installation, maintenance, or operation of the proposed equipment or facility.
- 6a. Unless a joint construction/operation permit has been issued, a permit for operation shall be obtained from the Illinois EPA before the equipment covered by this permit is placed into operation.
- b. For purposes of shakedown and testing, unless otherwise specified by a special permit condition, the equipment covered under this permit may be operated for a period not to exceed thirty (30) days.
7. The Illinois EPA may file a complaint with the Board for modification, suspension or revocation of a permit.
  - a. Upon discovery that the permit application contained misrepresentations, misinformation or false statement or that all relevant facts were not disclosed, or
  - b. Upon finding that any standard or special conditions have been violated, or
  - c. Upon any violations of the Environmental Protection Act or any regulation effective thereunder as a result of the construction or development authorized by this permit.

# Exhibit 2



**VIA EMAIL**

November 8, 2013

Dean Studer - Hearing Officer,  
1021 N. Grand Ave. E.,  
P.O. Box 19276,  
Springfield, IL 62794-9276  
[Dean.Studer@illinois.gov](mailto:Dean.Studer@illinois.gov)  
[epa.publichearingcom@illinois.gov](mailto:epa.publichearingcom@illinois.gov)

Re: Ameren Energy Resources and FutureGen Industrial Alliance Construction Permit for the FutureGen 2.0 Project (137805AAA) Application No.: 12020013

Dear Mr. Studer:

On behalf of the Sierra Club and the Natural Resources Defense Council (NRDC), we write to submit comments on the draft Clean Air Act minor source permit that the Illinois Environmental Protection Agency (Illinois EPA) has proposed to issue for FutureGen 2.0 coal-fired power plant, 137805AAA. Adding a new coal-fired power plant to Illinois is extremely ill advised. The Applicant's own analysis shows that the area in which this new coal-fired power plant is proposed is already riddled with sulfur dioxide pollution levels that exceed the health-based national ambient air quality standard by more than ten times. While there are no ozone monitors in Morgan County where the new coal-fired unit is proposed, lack of data regarding pollution levels does not make anyone safe. What we do know is that the nearby Jersey County ozone monitor has a 2010 – 2012 design value of 79 parts per billion (ppb) thus exceeding the health based ambient air quality standard of 75 ppb. Neighboring Sangamon County has an ozone monitor that appears to have been installed in 2011. Its 2011 4<sup>th</sup> highest value was 79 ppb and its 2012 4<sup>th</sup> highest was 76 ppb. Thus, Sangamon County also appears to be headed for a nonattainment designation for the 2008 ozone standard. Permitting the addition of over 3,468,000 pounds per year of nitrogen dioxide, an ozone precursor, and the addition of over 646,000 pounds per year of sulfur dioxide to this area that is already violating health based air quality standards is wrong.

It is in this context that we submit the following comments explaining why it would be illegal for IEPA to issue its proposed air pollution permit to Ameren's proposed new coal-fired power plant.

**I. THE DRAFT PERMIT VIOLATES THE CLEAN AIR ACT'S PREVENTION OF SIGNIFICANT DETERIORATION REQUIREMENTS BECAUSE THE PROPOSED COAL-FIRED UNIT TRIGGERS PREVENTION OF SIGNIFICANT DETERIORATION.**

The Prevention of Significant Deterioration (PSD) program found in Part C of Title I of the federal Clean Air Act establishes the statutory framework for protecting public health and welfare from adverse effects of air pollution in areas designated attainment. Congress specified that the PSD program is intended to:

insure that economic growth will occur in a manner consistent with the preservation of existing clean air resources"; and (2) "assure that any decision to permit increased air pollution . . . is made only after careful evaluation of all the consequences of such a decision and after adequate procedural opportunities for informed public participation in the decisionmaking process.

42 U.S.C. § 7470.

To accomplish these purposes, the Clean Air Act relies primarily on a pre-construction permitting program as the mechanism for reviewing proposals to increase air pollution in areas meeting the National Ambient Air Quality Standards (NAAQS). The Clean Air Act generally requires PSD permits prior to construction and/or operation of new major stationary sources and major modifications to stationary sources in areas designated attainment or unclassified for the pollutants to be emitted by the sources. *See* 42 U.S.C. §§ 7475 (a) and 7479(2)(C). "Modification" is defined to include, "any physical change in, or change in the method of operation of, a stationary source which increases the amount of any air pollutant emitted by such source or which results in the emission of any air pollutant not previously emitted." 42 U.S.C. § 7411(a)(4).

IEPA and the Applicant agree that the new oxy-boiler and most of the other changes occurring because of the FutureGen 2.0 project are new construction and/or

physical changes or changes of operation. *See e.g.* Ex. 1 at 23, Table 3-1.<sup>1</sup> Furthermore, IEPA and the Applicant agree that these activities will create significant emission increases for NSR regulated pollutants. The Applicant states:

FutureGen 2.0 emissions increases are greater than the significant emissions rates so the Project will result in a significant emissions increase as that term is defined in the US EPA regulations.

Ex. 1 at 31, 33. *See also* Draft Permit at Attachment 1. Actually, the Applicant claims its emission increases are not significant for lead and fluorides. *See* Ex. 1 at 38. However, as explained below, fluorides are significant.

Therefore, except for fluorides, the only issue with regard to PSD applicability is whether the changes cause significant net emission increases. The Applicant and IEPA claim that they do not. *See e.g.* Draft Permit at Finding 3 (“this project will not be accompanied by significant net increases in emissions of PSD pollutants”). However, as detailed below, the changes do cause significant net emission increases for Particulate Matter (PM), Particulate Matter smaller than 10 microns in diameter (PM10), Particulate Matter smaller than 2.5 microns in diameter (PM2.5), sulfur dioxide (SO<sub>2</sub>), nitrogen oxides (NO<sub>x</sub>), Sulfuric Acid Mist (SAM), fluorides, and Greenhouse Gases. Thus, PSD is an applicable requirement for these pollutants which requires the Applicant to obtain a PSD permit.

**A. SHUTDOWN OF UNITS 1 – 6 ARE NOT CREDITABLE EMISSION DECREASES FOR PM, PM10, PM2.5, NO<sub>x</sub> AND SO<sub>2</sub> BECAUSE THEY OCCURRED BEFORE THE MINOR SOURCE BASELINE DATE**

The Applicant admits that for a decrease to be creditable under the PSD regulations the following must be true. “All increases and decreases have occurred after the applicable minor source baseline date.” Ex. 1 at 33. *See also* 40 C.F.R. § 52.21(b)(3)(iv). While the Applicant clearly acknowledges that a decrease must occur after the minor source baseline date, the Applicant and IEPA completely fail to discuss this requirement, much less demonstrate that it is met.

The decreases in PM2.5 emissions from the shutdown of existing boilers did not occur after the PM2.5 minor source baseline date. The trigger date must occur before the minor source baseline date. *See e.g.* 75 Fed. Reg. 64,864, 64,868 (Oct. 20, 2010). After the trigger date, the minor source baseline date is established when

---

<sup>1</sup> Exhibit 1 is a compilation of documents provided by IEPA. Since it does not include sequential page numbers throughout, we refer to the page numbers in the pdf reader.

the first complete PSD permit application covering the pollutant in question is filed for the area at issue. *Id.*

The trigger date for PM<sub>2.5</sub> is October 20, 2011. 75 Fed. Reg. at 64,887. Therefore, by definition, the minor source baseline date for PM<sub>2.5</sub> cannot be before October 20, 2011. According to the Applicant, the decrease at Units 1 – 4 happened on November 9, 2009 when the units were removed from service. Ex. 1 at 34. Thus, this decrease from Units 1-4 is not creditable because it happened before the PM<sub>2.5</sub> minor source baseline date.

Units 5 & 6 were removed from service and thus created decreases, according to the Applicant, on January 1, 2012. Ex. 1 at 34. However, the Applicant and IEPA did not claim, nor do we think they could, that a complete PSD application covering Morgan County, Illinois, was filed between October 21, 2011 and December 31, 2011. Thus, the PM<sub>2.5</sub> reductions from Units 5 & 6 are also not creditable. The fact that increase from the 2008 emergency engine generator is not creditable does not change the conclusion. The new equipment for FutureGen 2.0 will create an increase of 97 tpy of PM<sub>2.5</sub>. There are no creditable increases or decreases so the net increase is also 97 tpy of PM<sub>2.5</sub>. This is above the significance threshold of 10 tpy so FutureGen 2.0 triggers PSD for PM<sub>2.5</sub>.

A similar analysis should apply to PM, PM<sub>10</sub>, SO<sub>2</sub> and NO<sub>x</sub>. Neither the Applicant nor IEPA claim that the minor source baseline date was established for PM, PM<sub>10</sub>, SO<sub>2</sub> or NO<sub>x</sub> in Morgan County before November 9, 2009 or January 1, 2012. We have no reason to believe that the minor source baseline date was triggered for PM, PM<sub>10</sub>, SO<sub>2</sub> or NO<sub>x</sub> in Morgan County before November 9, 2009 or January 1, 2012. Thus, the decreases from the shutdown of Boilers 1-6 are not creditable for PM, PM<sub>10</sub>, SO<sub>2</sub> or NO<sub>x</sub>. Therefore, FutureGen 2.0 causes a significant net emission increase for these pollutants as well as a significant emission increase, triggering PSD.

## **B. THE APPLICANT AND IEPA UNDERESTIMATE THE EMISSION INCREASES**

In calculating the net emissions, IEPA and the Applicant under-calculated the emission increases from the new equipment. First, they failed to consider CO<sub>2</sub> from the scrubbers, that is the hydrated lime using circulating dry scrubber (CDS) and the trona using direct contact cooling/polishing system (DCCPS). Both of these systems produce CO<sub>2</sub> as a byproduct of the reaction with SO<sub>2</sub>. However, this CO<sub>2</sub> was not considered.

IEPA and the Applicant also failed to consider fugitive emissions from the coal in the coal trucks. We do not mean the emissions that the coal trucks generate

off the road but rather coal that is blown out of the back of the coal truck while the coal trucks are on-site. IEPA and the Applicant also underestimate fugitive emissions from the haul roads. *See* Victoria R. Stamper, Evaluation of Particulate Matter Emissions from Haul Road at the Proposed FutureGen 2.0 Project at the Meredosia Energy Center, Nov. 7, 2013 at 6, attached as Ex. 2.<sup>2</sup>

In addition, the application assumes only N<sub>2</sub> is the output from the air separation unit. Ex. 1 at 16. The draft permit does not requiring any testing and monitoring to see if any NO<sub>x</sub>, N<sub>2</sub>O, ozone, methane, or carbon dioxide is emitted from the air separation unit. All of these pollutants could be formed and emitted in the air separation unit because they are constituents of ambient air.

### **C. FUTUREGEN 2.0 IS A MAJOR SOURCE FOR SULFURIC ACID MIST, FLOURIDES AND NO<sub>x</sub>**

The draft permit claims that the net emission increase of sulfuric acid mist (SAM) is 6.92 tons per year (tpy), which is just 0.08 tpy below the 7 tpy major source threshold. Draft Permit at Table 1B. However, the Applicant left out SAM from the installation of the diesel engine permitted on November 21, 2008, IEPA Permit No. 08100029, in its calculations. *Id.*; Project Summary at 5. Of course, diesel fuel permitted to be burned in the emergency diesel generator permitted in 2008 contained sulfur. Therefore, the Applicant must quantify that emergency diesel generators sulfuric acid mist potential to emit PTE in 2008 to see if, accepting all other premises, which we don't, that diesel engine, would push the facility over the major source threshold for sulfuric acid mist.

However, as mentioned above, we do not accept all of the Applicant's other premises in calculating the significant net emission increases. The Applicant assumed that the oxy-boiler's SAM emission rate while air firing is 2.97 lb/hr. Ex. 1 at 25. However, the Applicant also assumed that the oxy-boiler would only operate at air firing up to 45% load and only for 4800 hours per year. Ex. 1 at 24.

This assumption is not enforceable as a practical matter. The draft permit does not limit the oxy-boiler to 4800 hours per year of air firing and does not limit it to only air firing below 45% load. Rather, the draft permit says the opposite. The draft permit explains: "In the event of an upset in the operation of the boiler or an outage or upset in the CO<sub>2</sub> pipeline or the sequestration facility, the boiler can transition back into air firing mode." Draft Permit 2.1.1. This is true. But it is equally true that as the permit is currently written, the Applicant is permitted to

---

<sup>2</sup> This report identified other flaws in the Applicant and draft permit which are hereby incorporated herein by reference.



operate the oxy-boiler in air-firing mode all the time. Air-firing mode is much more economical and efficient. The owners or operators could choose to operate in air firing mode for a variety of reasons such as outage or upset in the boiler, including the air separation unit, the pipeline or the sequestration site. *See* Project Summary at 2. In addition, because the permit does not require carbon capture, it could be simply that the operator chooses to operate the plant as a “traditional” pulverized coal plant. The air separation unit is very expensive to operate so the owners and operators have a tremendous financial incentive to operate this unit air firing as much as possible. It is also critical to keep in mind that the conditions in this permit are permanent. The owners and operators current intent can certainly change in the decades to come. Operating at full load air firing, this would be the only pulverized coal unit permitted in the last decade or longer without SCR.

Minor source status to avoid PSD, that is a source’s potential to emit, must be calculated based on the maximum output, that is 100% load, and every hour of the year unless there is a physical or legal restriction. *See* 40 C.F.R. § 52.21(b)(4). Thus, the SAM emission factor for air-firing should be 6.6 lb/hr ( $2.97 * 1/.45 = 6.6$ ) as there is no physical or legal restriction on operating the oxy-boiler in air-firing mode above 45% load. There is also no enforceable limit on hours of operation firing air. Therefore, the potential to emit must be based on 8,760 hours per year which results in the following calculation.  $6.6 \text{ lb/hr} * 8,760 \text{ hours per year} = 28.9 \text{ tons per year}$ . The Applicant claims a contemporaneous emission decrease of 3.58 tons per year of SAM. Ex. 1 at 38. As explained elsewhere, we dispute this claim but even if you accepted the decrease as true, that would still result in a SAM net increase of 25.3 tpy based on increases from the oxy-boiler alone. This is above the SAM significance threshold of 7 tpy, making FutureGen 2.0 a PSD major source for SAM.

The SAM emission limits in Draft Permit Condition 2.1.6(b) does not change this conclusion. The Draft Permit lacks testing, monitoring and reporting for SAM emissions. It does not even have a one-time stack test, much less continuous monitoring that applies at all times including startup, shutdown or malfunction. Thus, those limits do not change the potential to emit 28.9 tpy or the significant net increase of 25.3 tpy. *See* 40 C.F.R. § 52.21(b)(4).

We note that FutureGen 2.0 would be a major source based on removing either one of the unenforceable assumptions alone. That is if one accepted the Applicant’s emission rate of 2.97 lb/hr but calculated PTE based on the permitted 8760 hours per year, that would be 13 tpy SAM. Minus the disputed 3.58 contemporaneous decrease, the net increase would still be 9.4 tpy which is above the SAM significance threshold.

Similar, if one accepts the 4800 hour per year limitation but corrects the load to the allowable 100% while air firing, the emission rate is  $6.6 \text{ lb/hr} * 4800 \text{ hr/yr} = 15.84 \text{ tpy year}$ . Subtracting the disputed decrease of 3.58 leaves a net increase of 12.26 tpy which is above the 7 tpy significance threshold.

We also note that the Applicant did not actually provide the SAM emission rate estimates from Babcock and Wilcox. *See* Ex. 1 at 25, ftnt 3. However, to the extent they are based on the nominal heat input of 1,605 mmbtu/hr, Ex. 1 at 24, it under-predicts potential to emit. The only enforceable limit is 14,500,000 mmbtu/yr. Draft permit at 13, Condition 2.1.6.a. That works out to an hourly maximum heat input of 1,655 mmbtu/hr maximum. ( $14,500,000/8760 = 1,655.25$ ).

Finally, we note that in the original permit application, the Applicant stated that SO<sub>3</sub> emissions would be 26 tons per year when air firing at 45% load. Ex. 1 at 215. Even at 4800 hours per year/ that is 14.2 tpy which would make the source major for sulfuric acid mist. ( $26 * 4800/8760 = 14.247$ ). The Applicant has not explained why the revised application assumed less SAM emissions.

The same basic problems apply to NO<sub>x</sub>. The Applicant claimed the oxy-boiler's NO<sub>x</sub> emissions while air firing is 319 lb/hr based on a 45% load. Ex. 1 at 25. However, at the permitted 100% load air firing, this would be 708.9 lb/hr. ( $1/.45 * 319 = 708.88$ ).  $708.9 \text{ lb/hr} * 8760 \text{ hr/yr} = 3104.9 \text{ tpy}$ . ( $708.9 * 8760 / 2000 = 3104.93$ ). Even accepting the Applicant's disputed contemporaneous decrease of 2,813 tpy, the net increase for just the main boiler would be 291.9 tpy which is above the 40 ton per year significance threshold for NO<sub>x</sub>. The annual limit in Draft Permit Condition 2.1.6(b) is not enforceable as a practical matter because the Draft Permit does not say that CEMs have to operate all the time and that compliance with the annual limit has to be determined based on NO<sub>x</sub> emissions during every hour of operation.

Fluorides are also above the significance level. The Applicant claims a 0.63 lb/hr emission factor at 45% load. Ex. 1 at 25. This translates to 1.4 lb/hr at the permitted 100% load. ( $1/.45 * 0.63 = 1.4$ ). 1.4 lb/hr for a full year is 6.1 tpy. ( $1.4 * 8760 / 2000 = 6.132$ ). This is above the 3 tpy significance threshold. The Applicant did not claim that there was a contemporaneous decrease so the new boiler triggers PSD for fluorides also.

Again, the fluorides emission limit in Draft Permit Condition 2.1.6(b) does not change this conclusion. The Draft Permit is completely devoid of any monitoring, testing or reporting for fluorides. Thus, the fluorides emission limit is

not federally or practically enforceable and therefore does not impact the potential to emit calculation. *See* 40 C.F.R. § 52.21(b)(4).

**D. FUTUREGEN 2.0 IS ALSO A PSD MAJOR SOURCE BECAUSE THE APPLICANT USED AN IMPREMISSIBLE BASELINE PERIOD FOR EMISSION DECREASES.**

FutureGen 2.0 also triggers PSD for all pollutants but sulfur dioxide and PM10, because the Applicant's analysis incorrectly used a baseline for calculating the emission decreases from the shutdown of Boilers 1 – 6 that is more than 5 years prior to commencing construction on the FutureGen 2.0 project. The Applicant used a baseline for calculating the decreases from the Boilers 1 – 6 of March 2007 to February 2009. However, the Applicant indicates it intends to commence construction in July 2014. *See* Draft Permit, Table 1B, Note A. Thus, the baseline period can begin no earlier than August 2009.

40 C.F.R. § 52.21(b)(3)(i)(B) says baseline “actual emissions for calculating increases and decreases under this paragraph (b)(3)(i)(b) shall be determined as provided in paragraph (b)(48) of this section, except that paragraphs (b)(48)(i)(c) and (b)(48)(ii)(d) of this section shall not apply.”

Paragraph (b)(48) provides the baseline is the:

average rate, in tons per year, at which the unit actually emitted the pollutant during any consecutive 24-month period selected by the owner or operator within the 5-year period immediately preceding when **the owner or operator begins actual construction of the project.**

40 C.F.R. § 52.21(b)(48)(emphasis added).

The Applicant goes on to claim, without any citation, that “US EPA has determined that the baseline period for contemporaneous emissions changes is based on the date the change occurred.” Ex. 1 at 34. This claim contradicts the plain language of 52.21(b)(48) which says the baseline for contemporaneous increases and decreases is “*any consecutive 24-month period selected by the owner or operator within the 5-year period immediately preceding when the owner or operator begins actual construction of the project.*” The plain language controls. Thus, the baseline period can thus start no earlier than August 2009, which is five years prior to when the Applicant will begin actual construction. *See* Ex. 1 at 61.

If the correct baseline is used, FutureGen 2.0 will result in significant net emission increases for GHG, PM<sub>2.5</sub>, and NO<sub>x</sub>. The following calculations rely on the project's potential emissions from the Draft Permit, Attachment 1, Table 1B and data from the EPA's Clean Air Markets database, attached as Ex. 3. We exclude the increase from the emergency engine-generator permitted in 2008 as this was before the baseline period. However, we accept the Applicant's PTE calculations for the sake of this analysis even though we dispute them elsewhere.

Using the proper baseline, the creditable decrease in NO<sub>x</sub> emissions from the shutdown of boilers at Meredosia should be 882 tpy (Ex. 3, cell H146,  $1,764 / 2 = 882$ ), resulting in net emissions increase of 852 tpy ( $1,734.4 - 882$ ), far above the threshold of 40 tpy. For PM<sub>2.5</sub>, using the Draft Permit's emission factor, the proper baseline results in a creditable decrease of 72 tpy (Ex. 3, cell L146,  $287,363.2 \text{ lbs}/24 \text{ months} / 2 = 14,3681.6/2,000 = 71.8 \text{ tpy}$ ), which results in a net emissions increase of 25 tpy ( $97 - 72 = 25$ ). This is over the PM<sub>2.5</sub> significance threshold of 10 tpy. Finally, for CO<sub>2</sub>, the proper baseline calculation results in a creditable decrease of 935,848 tpy (Ex. 3, cell I146,  $1,871,695 / 2 = 935,847.5$ ), resulting in a net emissions increase of 586,655 tpy ( $1,522,503 - 935,848 = 586,655$ ). This exceeds the 75,000 tpy significance threshold to an extent that easily covers any potential creditable decrease from NO<sub>x</sub> or methane that may not have been included in the Applicant's calculation.

#### **E. THE APPLICANT CANNOT NET OUT BECAUSE THE EMISSION INCREASE WILL CAUSE VIOLATIONS OF THE NAAQS**

The PSD regulations restrict the creditability of some decreases in emissions for the purpose of emissions netting. In particular, one provision allows credit for a reduction only to the extent that it has approximately the same qualitative significance for public health and welfare as the increase from the proposed change [see 52.21(b)(3)(vi)(c)]. Where there is reason to believe that the reduction in ambient concentrations from the decrease will not be sufficient to prevent the proposed emissions increase from causing or contributing to a violation of any NAAQS or PSD increment, this provision requires an applicant to demonstrate that the proposed netting transaction (despite the absence of a significant net increase in emissions) will not cause or contribute to such a violation (see 54 FR 27298). Even if EPA found the proffered reductions otherwise quantitatively acceptable in this case--where the existing emissions units have not contributed to ambient concentrations for the last 10 years-- Cyprus would have to perform sufficient air quality modeling to demonstrate that the

emissions increase from the new units would not violate the applicable NAAQS and PSD increments before the reductions could be credited (see 54 FR 27298).

Aug. 11, 1992 Memorandum from John Calcagni to David Kee, re: Proposed Netting for Modifications at Cyprus Northshore Mining Corporation, Silver Baym Minnesota, attached as Ex. 4 at 6.

FutureGen 2.0 modeling establishes that it violates the 1-hour SO<sub>2</sub> and NO<sub>x</sub> NAAQS. Ex. 1 at 6-7. Therefore, FutureGen 2.0 cannot net out of PSD.

The Applicant tries to excuse its violations of the NAAQS by claiming that because its contribution to the NAAQS violation was below what it claims is the significant impact level, there is no problem. However, the U.S. Court of Appeals for the District of Columbia has recently rejected the use of significant impact levels. *See Sierra Club v. EPA*, 705 F.3d 458 (D.C. Cir. 2013).

Moreover, even before that decision, US EPA had determined that if a source causes any NAAQS violations, regardless of the level of contribution, the violation cannot be forgive. The Applicant failed to do any this analysis.

We also note that the modeling determined there would be NAAQS violations even though the modeling was not conservative, that is it under-predicted violations or ignored violations. For example, the Applicant only modeled the oxy-boiler air firing as low power operations, which we assume is limited to 45% load based on the assumptions about air firing that the Applicant made in calculating PTE. Ex. 1 at 46. However, as explained above, the permit allows and even says that the oxy-boiler can and will operate in air firing mode outside of startups and shutdowns. Thus, NO<sub>x</sub> and SO<sub>2</sub> modeling must be done for air firing at 100% load. This is particularly important because a mere 4 or 8 hours of emissions per year can cause NAAQS violations of the 1-hour NAAQS.

Furthermore, the Applicant did not model the haul roads or new emergency diesel generator at sequestration site and old generator at old site and coal pile fugitives for PM<sub>10</sub> and PM<sub>2.5</sub>. There are new haul roads and also there is much more activity on the haul roads as trona and lime were not used on site and the ash used to be disposed of on-site rather than being hauled off-site. Ex. 1 at 22. In modeling the haul roads, the Applicant must use worst day emissions which we provided in the Stamper report. *See Ex. 2 at 7*. Also, the Applicant failed to consider coal blown out of the coal trucks while they are hauling the coal in.

## II. THE EMISSION LIMITS FOR THE NEW UNIT ARE NOT ENFORCEABLE

There are numerous provisions of the application and draft permit which are not federally enforceable or not enforceable as a practical matter. For example, lead PTE was based on AP42 emission factors. Ex. 1 at 25, fn 8. VOC was based on vendor estimates. *Id.* at fn 4. The draft permit does not require any testing to confirm these emission factor estimates are not actually exceeded. Thus, the claim that the source is minor for these pollutants is not enforceable. In order to make these enforceable, the permit needs to require a CEMS or annual stack testing at various loads and all operating scenarios including air firing coupled with parametric monitoring.

CH<sub>4</sub> and N<sub>2</sub>O PTE was from default emission factors from the 40 C.F.R. § 98 mandatory greenhouse gas reporting rule. *Id.* at 25, fn 6. The permit needs adequate testing for these to confirm. The Draft Permit requires one time testing. That is not enough.

Furthermore, the permit must require commencement of construction by not later than 8/14 in order for the Applicant's disputed claim of contemporaneous reductions to be valid under the Applicant's own theory. This is so because the last time Unit 1-4 emitted pollution was 8/09. *See* Ex. 3.

NO<sub>x</sub> and SO<sub>2</sub> monitoring must apply all the time for netting to be valide including during startups, shutdowns and malfunctions (SSM). Alternative monitoring or NSPS monitoring is not sufficient as it does not require emission data from every hour of operations.

The application claims that the "auxiliary boiler will utilize ultra low sulfur diesel oil[.]" Ex. 1 at 21. This is 15 ppm sulfur. Ex. 1 at 27, ftnt. 13. However, the draft permit only limits the auxiliary boiler to 5000 ppm sulfur oil. Draft permit at 2.2.3-1(a)(iii)(A). Therefore, the permit needs a condition limiting the auxiliary boiler to 15 ppm sulfur diesel as well as monitoring and reporting to make this condition enforceable as a practical matter. The reporting must ensure that the source does not use diesel currently on site that is above 15 ppm sulfur or transmix diesel.

The application claims that the oxy-boiler will have a total HAP emission of no greater than 1.09 lb/hr at all times including startup, shutdown and malfunction. Ex. 1 at 59. Therefore, the permit needs a total HAP emission limit of 1.09 lb/hr

that applies at all times including startup, shutdown and malfunction. The permit should also include a HAPs CEM which monitors HCL and other HAPs at all times including during startup, shutdown, and malfunction.

This is critical because AP-42 reports a HCL emission factor of 1.2 lb/ton. This means that burning a mere 16,666 tons of coal in the oxy boiler uncontrolled would put the source over the 10 tons per year HAPs major source threshold.

The application assumes 95% control for two transfer points for the coal handling equipment: (1) Conveyor C to Chain Conveyor and, (2) Chain Conveyor to Coal Silos. Ex. 1 at 52. Therefore the permit must have emission limits, testing and monitoring to ensure that these emission limits, that is 0.85 lb/hr PM, 0.38 lb/hr PM10 and 0.0425 lb/hr PM2.5 for each of these transfer points, is not exceeded. In addition, the permit must require there be zero fugitive emissions from these transfer points and monitoring, testing and report to ensure compliance with the absolute restriction on fugitives from the transfer points.

Similarly, the application assumes 0.02 grains per dry standard cubic feet PM emissions from the ash silo bin vent, lime transfer and trona transfer. Ex. 1 at 53, 54, 55. The permit needs to have an emission limit of 0.02 grains per dry standard cubic feet for these emission sources and monitoring, testing and reporting to ensure this 0.02 grains limit is enforceable as a practical matter. Similarly, the permit needs to limit the trona transfer flow to no more than 700 scfm, the lime flow to 1,500 scfm, the ash flow to 2,500 scfm. *Id.* The permit needs testing, monitoring and reporting to ensure that these flow limits are not violated. In the alternative, these emission points could have PM CEMs.

The permit also needs to limit coal to 744,600 tons per year of coal as many of the emission calculations are based on this assumption. The 14,500,000 mmbtu/yr limit is important for other calculations but it is not sufficient for all calculations such as the coal transfer equipment and the haul roads. The permit must also include monitoring and reporting to ensure that the 744,600 tons per year of coal limit is enforceable as a practical matter.

As to the Pugmill to trucks droppoint, the application assumes the ash is wetted to 15% moisture. Ex. 1 at 53. The permit must have an enforceable requirement that the ash be wetted to 15% moisture content and testing, monitoring and reporting for this requirement.

The permit must limit the drift flow for the Unit 4 main cooling tower to 0.94 gpm, for the ASU/CPU cooling tower to 0.23 gpm and the DCCPS cooling tower to

0.16 gpm. *See* Ex. 1 at 56. The permit must also limit the total dissolved solids (TDS) to 518 ppm for the Unit 4 main cooling tower, 2090 ppm for the ASU/CPU cooling tower and 7043 ppm for the DCCPS cooling tower. The permit must have testing, monitoring and report requirements to ensure these gpm and TDS limits are not exceeded.

The annual NO<sub>x</sub>, CO, PM, PM<sub>10</sub>, PM<sub>2.5</sub> and GHG limits for the auxiliary boiler are not enforceable as a practical matter. One time testing tells nothing about annual emissions. While Draft Permit Condition 2.2.9(g)(iii) states that the Applicant should keep records of these pollutants in tons/month and tons/year, there is no data for the Applicant to keep these records. In addition, the initial test for NO<sub>x</sub> and CO is within one year of startup of the oxy-boiler. *See* Draft Permit Condition 2.2.7-2(a)(i). There is no reason to allow a year of operations to go by before determining initial compliance.

### **III. THE ILLINOIS CLEAN COAL PORTFOLIO STANDARD LAW DOES NOT ABDICATE ILLINOIS EPA OF ITS RESPONSIBILITY TO ISSUE A PERMIT FOR THIS FACILITY THAT IS COMPLIANT WITH THE CLEAN AIR ACT.**

IEPA should include permit terms requiring carbon capture in this construction permit. The Illinois Administrative Code expressly recognizes the IEPA's discretion in setting permit terms and conditions. *See* 35 IAC Section 201.156 ("The Agency may impose such conditions in a construction permit as may be necessary to accomplish the purposes of the Act, and as are not inconsistent with the regulations promulgated by the Board thereunder.").

During the public hearing on the draft permit, the Applicant suggested that the Illinois Public Agency Act's definition of a clean coal facility may somehow preclude inclusion of carbon capture requirements in this construction permit. The Public Agency Act, however, does not include any such limitation. The law's purpose is to create an independent state agency, the Illinois Public Agency (IPA), to develop and administer electricity procurement plans for investor-owned electric utilities supplying over 100,000 Illinois customers. *See* Public Act 95-0481. Under the law, plans must include the procurement of cost-effective renewable energy resources. The law also states that "the goal of the State [is] that by January 1, 2025, 25% of the electricity used in the State shall be generated by cost-effective clean coal facilities." The Illinois Commerce Commission (ICC) has stated that the law then "set[s] forth a framework for evaluation and approval of certain clean coal sourcing agreements," and "provides that the IPA and the ICC may approve such sourcing agreements, as long as they do not exceed cost-based benchmarks." *Re* FutureGen



Industrial Alliance, Inc., 13-0034, June 26, 2013 (Ill.C.C.). As such, “clean coal” facilities are defined in the law.

In relevant part, the Public Agency Act defines a “clean coal facility” as “an electric generating facility that uses primarily coal as a feedstock and that captures and sequesters carbon dioxide emissions at ... at least 70% of the total carbon dioxide emissions that the facility would otherwise emit if, at the time construction commences, the facility is scheduled to commence operation during 2016 or 2017...” The definition also limits emissions from such facilities to the “allowable emission rates for sulfur dioxide, nitrogen oxides, carbon monoxide, particulates and mercury for a natural gas-fired combined-cycle facility the same size as and in the same location as the clean coal facility at the time the clean coal facility obtains an approved air permit.” 20 ILCS 3855/1-10.

The law does not, however, discuss requirements for “clean coal” construction permits, nor does it limit IEPA’s authority with respect to issuing a robust permit in accordance with the purposes of Illinois’ Environmental Protection Act. Indeed, there is nothing in the Public Agency Act suggesting that carbon capture should not also be included in the construction permit. Whether the restrictions included in the Public Agency Act’s definition of a “clean coal facility” are included in any financing, cooperation, or purchasing agreements that the permittee has entered into should not insulate the air permit from including similar restrictions.

The hearing officer made clear that this permit is governed by the Illinois Environmental Protection Act rather than the Public Agency Act. At the hearing, he explained: “And I can tell you that our authority to issue permits is not based on the act that you stated, it's based on the Environmental Protection Act.” Public Hearing Transcript at 32:9-18.

#### **IV. ILLINOIS EPA SHOULD CONSIDER THE PROPOSED NEW SOURCE PERFORMANCE STANDARD FOR GREENHOUSE GAS EMISSIONS.**

New electric generating units are affected units under the US EPA’s proposed new source performance standard (NSPS) for emissions of carbon dioxide. According to the US EPA’s new proposed rule, the NSPS “will apply to both a new, greenfield EGU facility or an existing facility that adds EGU capacity by adding a new EGU that is an affected facility under this NSPS.” Standards of Performance for Greenhouse Gas Emissions from New Stationary Sources: Electric Utility Generating Units, [EPA-HQ-OAR-2013-0495; RL-9839-4], at 309-10 (September 20, 2013).

The draft permit states that the oxy-combustion boiler is a new unit under 40 C.F.R. 60 subpart Da. Draft Permit at 4; *see also* Ex. 1 at 181, 189; Draft Permit at Condition 2.1.4(b)(ii)(the affected boiler is a “new” unit). As such, the NSPS for carbon dioxide will apply to FutureGen’s oxy-combustion boiler. The draft permit’s project summary section also appears to acknowledge that the proposed rule will apply to FutureGen 2.0’s oxy-combustion boiler, but states that the new limitations are not included in the permit “because USEPA has not completed this rulemaking.” Draft Permit at 6, fn. 12 (stating that the unit will satisfy the new rule because “the plant would be designed to sequester CO<sub>2</sub>, as the USEPA proposed for new coal-fired generating units.)

Under the Clean Air Act, however, the emission limits in the proposed rule will apply from the date of the proposal once the rule is finalized. 42 U.S.C. §§ 7411(a)(2). And as a major source of carbon dioxide, as shown above, FutureGen 2.0 will be required to comply with the best available control technology (BACT) for that pollutant. The proposed rule establishes limits which will form the “floor” with this requirement. As such, the Illinois EPA should use its discretion to include the proposed rule’s CO<sub>2</sub> limits in the draft permit.

## V. MISCELLANEOUS ISSUES

### A. THE DRAFT PERMIT CONTAINS THE INCORRECT NSPS EMISSION LIMITS FOR THE OXY-BOILER

Both the Applicant and IEPA agree that the latest NSPS Subpart Da applies to the oxy-boiler. However, the application incorrectly cites to 40 C.F.R. § 60.44Da(f)(1)(i) & (ii) and incorrectly states that the oxy-boiler has to comply with a 0.07 lb/MWhr (gross) or 0.76 lb/MWhr (net) NO<sub>x</sub> emission limit based on a 30 day rolling averaging. Ex. 1 at 40. 40 C.F.R. § 66.44Da(f) applies to IGCC units that commence construction, reconstruction or modification before May 4, 2011. The oxy-boiler is not an IGCC unit and did not commence construction, reconstruction, or modification before May 4, 2011.

Condition 2.1.3-1(a)(ii) correctly cites to 40 C.F.R. § 60.44Da(g)(1) but ignores half the standard. 40 C.F.R. § 60.44Da(g)(1) provides:

(g) Except as provided in paragraphs (h) of this section and § 60.45Da, on and after the date on which the initial performance test is completed or required to be completed under § 60.8, whichever date comes first, no owner or operator of an affected facility that commenced construction, reconstruction, or modification after May 3, 2011, **shall cause to be discharged into the atmosphere** from that affected facility

**any gases** that contain NOX (expressed as NO<sub>2</sub>) **in excess of the applicable emissions limit** specified in paragraphs (g)(1) through (3) of this section.

(1) For an affected facility which commenced construction or reconstruction, any gases that contain NOX **in excess of either:**

- (i) 88 ng/J (0.70 lb/MWh) gross energy output; **or**
- (ii) 95 ng/J (0.76 lb/MWh) net energy output.

40 C.F.R. § 60.44Da(g)(1)(2013)(emphasis added).

Similarly, the alternative standards for combined NO<sub>x</sub> and CO provides:

b) On and after the date on which the initial performance test is completed or required to be completed under § 60.8 no owner or operator of an affected facility that commenced construction, reconstruction, or modification after May 3, 2011, shall cause to be discharged into the atmosphere from that affected facility any gases that contain NOX (expressed as NO<sub>2</sub>) plus CO in excess of the applicable emissions limit specified in paragraphs (b)(1) through (3) of this section as determined on a 30-boiler operating day rolling average basis.

(1) For an affected facility which commenced construction or reconstruction, any gases that contain NOX plus CO **in excess of either:**

- (i) 140 ng/J (1.1 lb/MWh) gross energy output; **or**
- (ii) 150 ng/J (1.2 lb/MWh) net energy output.

40 C.F.R. § 60.45Da(b)(2013)(emphasis added). Thus condition 2.1.3-1(a)(ii) must include both the gross and net energy standards and clearly provide that the source has to comply with both.

The same is true for the SO<sub>2</sub> emission limit in permit condition 2.1.3-1(a)(i). It fails to include the net energy emission limit even though that limit is applicable. 40 C.F.R. § 60.45Da(l)(1) provides:

(l) Except as provided in paragraphs (j) and (m) of this section, on and after the date on which the initial performance test is completed or required to be completed under § 60.8, whichever date comes first, no owner or operator of an affected facility for which construction,

reconstruction, or modification commenced after May 3, 2011, shall cause to be discharged into the atmosphere from that affected facility, any gases that contain SO<sub>2</sub> in excess of the applicable emissions limit specified in paragraphs (1)(1) and (2) of this section.

(1) For an affected facility which commenced construction or reconstruction, any gases that contain SO<sub>2</sub> in **excess of either:**

(i) 130 ng/J (1.0 lb/MWh) gross energy output; **or**

(ii) 140 ng/J (1.2 lb/MWh) net energy output; **or**

(iii) 3 percent of the potential combustion concentration (97 percent reduction).

40 C.F.R. § 60.43Da(1)(1)(2013)(emphasis added). Thus, permit condition 2.1.3-1(a)(i) must require to the source to comply with the NSPS gross, net **and** percentage reduction standard.

The same is also true for PM. The NSPS provides:

(e) Except as provided in paragraph (f) of this section, the owner or operator of an affected facility that commenced construction, reconstruction, or modification commenced after May 3, 2011, shall meet the requirements specified in paragraphs (e)(1) and (2) of this section.

(1) On and after the date on which the initial performance test is completed or required to be completed under § 60.8, whichever date comes first, the owner or operator **shall not cause to be discharged** into the atmosphere from that affected facility **any gases that contain PM in excess of** the applicable emissions limit specified in paragraphs (e)(1)(i) **or** (ii) of this section.

(i) For an affected facility which commenced construction or reconstruction:

(A) 11 ng/J (0.090 lb/MWh) gross energy output; **or**

(B) 12 ng/J (0.097 lb/MWh) net energy output.

40 C.F.R. § 60.42Da(e)(1)(i)(2013)(emphasis added). Thus, permit condition 2.1.3-1(a)(iii) must require compliance with both the gross and net PM limits.

Moreover, 40 C.F.R. § 60.48Da(a) provides that: “For affected facilities for which construction, modification, or reconstruction commenced after May 3, 2011, the applicable SO<sub>2</sub> emissions limit under § 60.43Da, NO<sub>x</sub> emissions limit under § 60.44Da, and NO<sub>x</sub> plus CO emissions limit under § 60.45Da apply at all times.” Thus, the permit should make clear that these limits apply during startup, shutdown and malfunction and ensure that the permit has monitoring and reporting to ensure compliance at all times including monitoring and reporting of net electricity production.

IEPA must make a determination of whether this facility, with its huge parasitic loads and energy penalties from the ASU, CPU and double scrubbers can comply with the net energy emission standards. If the facility cannot, IEPA must deny the permit.

Finally, we note that the NSPS is self-executing and there can be no permit shield in this minor source permit. Thus, even if IEPA does not correct these errors in this permit, we can and will enforce the net energy emission limits if the Applicant violates them.

**B. THE PERMIT MUST REQUIRE THE OPERATION OF THE CO<sub>2</sub> CEMS AT ALL TIMES THE UNIT IS OPERATING**

Permit condition 2.1.9-6 states that it is emission monitoring for CO<sub>2</sub>. However, it states that:

Pursuant to 40 CFR 60.49Da(a) for the affected boiler, the Permittee shall install, certify, operate and maintain a CEMS for CO<sub>2</sub> emissions.

Draft Permit condition 2.1.9-6. However, 40 C.F.R. § 60.49Da(a)(2013) is the regulation addressing continuous opacity monitoring systems (COMS) and other opacity measuring technics. Thus, it appears the draft permit did not mean to cite to 40 CFR 60.49Da(a). We cannot tell what IEPA meant to cite to. Therefore, we should be given an opportunity to comment on this issue after IEPA addresses it.

Nevertheless, the draft permit must make clear that 40 C.F.R. § 60.49Da(f)(2) is not applicable to monitoring to comply with the CO<sub>2</sub> and all other annual emission limits in Draft Permit condition 2.1.6(b). 40 C.F.R. § 60.49Da(f)(2) allows sources to ignore their emissions 10% of the time during boiler operating days and all of the time when a day is not a boiler operating day. This means that monitoring for a limit that is supposed to refer potential to emit and keep the source from triggering PSD would substantially underreport actual emissions. This would make the permit not enforceable as a practical matter. Therefore, the permit must

require monitoring for CO<sub>2</sub>, SO<sub>2</sub> and NO<sub>x</sub> at all times that the boiler is combusting any type of fuel. This may require redundant CEMs.

**C. THE MERCURY LIMIT NEEDS TO BE CLARIFIED.**

Condition 2.1.3-1(b)(i)(C) sets a mercury limit of 0.003 lb/GWh for “not low rank coal” and 0.04 lb/GWh for “low rank coal.” In order for this condition to be enforceable as a practical matter, it must define low rank coal. In addition, this condition must explain what the emission limit is when a facility burns a blend of low rank and not low rank coal. This is important because FutureGen intends to burn a blend of Wyoming coal and Illinois coal. *See* Ex. 1 at 64.

**D. THE HAUL ROADS NEED A DIFFERENT LIMIT**

Condition 2.6.4 does not have a PM<sub>2.5</sub> limit. However, the application claims maximum emissions of 0.11 tpy. Ex. 1 at 57. We dispute that this is what the emissions will be. However, to the extent IEPA maintains that this is that emissions will be, the permit must contain this limit and include testing, monitoring and reporting to ensure this limit is not violated.

Condition 2.6.4 needs testing, monitoring and reporting to ensure this limit is not violated. Condition 2.6.6(c) is not sufficient as it does not require testing or monitoring. IEPA should also define what it means by “design PM and PM<sub>10</sub> emission rates” in Draft Permit Condition 2.6.6.

Sincerely,



---

Robert Ukeiley  
Law Office of Robert Ukeiley  
507 Center Street  
Berea, KY 40403  
[rukeiley@igc.org](mailto:rukeiley@igc.org)  
859.986.5402



---

Eva Schueller  
Associate Attorney  
The Sierra Club  
85 Second Street  
San Francisco, CA 94105  
(415) 977-5637  
[eva.schueller@sierraclub.org](mailto:eva.schueller@sierraclub.org)

Counsel for Sierra Club

---

/s/Meleah Geertsma  
Meleah Geertsma  
Staff Attorney, Midwest Program  
Natural Resources Defense Council  
20 N. Wacker Drive, Suite 1600  
Chicago, IL 60606  
(312) 651-7904

Counsel for Natural Resources Defense  
Council

# Exhibit 3



ILLINOIS ENVIRONMENTAL PROTECTION AGENCY  
BUREAU OF AIR  
PERMIT SECTION

DECEMBER 2013

RESPONSIVENESS SUMMARY FOR  
PUBLIC QUESTIONS AND COMMENTS ON THE APPLICATIONS FOR  
AIR POLLUTION CONTROL CONSTRUCTION PERMITS FOR THE  
FUTUREGEN 2.0 PROJECT

Source Identification No.: 137805AAA  
Application Nos.: 12020013 and 12020051

Table of Contents

	Page
Decision.....	2
Background.....	2
Comment Period and Public Hearing.....	2
Availability of Documents .....	3
General Comments.....	3
Questions and Comments with Responses by the Illinois EPA .....	5
For Additional Information .....	68
Listing of Significant Changes between the Draft and Issued Permits.....	69

## **DECISION**

On December 13, 2013, the Illinois Environmental Protection Agency (Illinois EPA) issued an air pollution control construction permit to Ameren Energy Medina Valley Cogeneration, LLC (Ameren) and the FutureGen Industrial Alliance, Inc. (Alliance) for construction of an oxy-combustion power plant at the existing Meredosia Energy Center at 800 South Washington Street, in Meredosia, Illinois.

On December 13, 2013, the Illinois EPA also issued a second air pollution control construction permit to the Alliance for construction of a backup engine to be located at the site of the separate carbon dioxide sequestration facility in rural Morgan County.

Copies of the documents can be obtained from the contact listed at the end of this document. The permits and additional copies of this document can also be obtained from the Illinois EPA website [www.epa.state.il.us/public-notices/](http://www.epa.state.il.us/public-notices/).

## **BACKGROUND**

On February 9, 2012, the Illinois EPA, Bureau of Air received an application from Ameren and the Alliance requesting a permit to construct a coal-fired oxy-combustion power plant at Ameren's existing power plant in Meredosia. The proposed project would be developed to enable the use of carbon capture and sequestration technology, with a portion of the carbon dioxide (CO<sub>2</sub>) emissions from the plant being captured and sent by pipeline to a sequestration facility about 30 miles east of the plant.

The construction permit issued for the project identifies the applicable rules governing emissions from the plant, and establishes enforceable limits on its emissions. The permit also establishes appropriate compliance procedures, including requirements for emissions testing, continuous emission monitoring, recordkeeping, and reporting. The source will be required to carry out these procedures on an ongoing basis to demonstrate that the plant is operating within the limits established by the permit and that emissions are being properly controlled.

On February 9, 2012, the Illinois EPA, Bureau of Air also received an application from the Alliance for a construction permit for an oil-fired engine generator to provide electricity to buildings during power outages at the sequestration site. This construction permit, as well, identifies the applicable rules governing emissions from the plant, and establishes enforceable limitations on its emissions. The permit also establishes appropriate compliance procedures, including requirements for opacity observations, recordkeeping and reporting.

## **COMMENT PERIOD AND PUBLIC HEARING**

The Illinois EPA Bureau of Air evaluates applications and issues permits for sources of emissions. An air permit application must appropriately address compliance with applicable air

pollution control laws and regulations before a permit can be issued. Following its initial review of the applications, the Illinois EPA Bureau of Air made a preliminary determination that the applications met the standards for issuance of a construction permit and prepared draft permits for public review and comment.

The public comment period began with the publication of a notice in the Jacksonville Journal-Courier on August 24, 2013. The notice was published again in the Jacksonville Journal-Courier on August 31 and September 7, 2013. A public hearing was held on October 9, 2013, at the Meredosia High School to receive oral comments and answer questions regarding the applications and the draft air permits. The comment period closed on November 8, 2013.

## **AVAILABILITY OF DOCUMENTS**

The permit issued to Ameren/Alliance, the second permit issued to the Alliance and this responsiveness summary are available on the Illinois Permit Database at [www.epa.gov/region5/air/permits/ilonline.htm](http://www.epa.gov/region5/air/permits/ilonline.htm) (please look for the documents under All Permit Records (sorted by name), Construction Permit Records). Copies of these documents may also be obtained by contacting the Illinois EPA at the telephone numbers listed at the end of this document.

## **GENERAL COMMENTS**

The proposal to issue a permit for the construction of an oxy-combustion power plant at the existing Meredosia Energy Center and a permit for a backup engine to be located at the site of the separate carbon dioxide (CO<sub>2</sub>) sequestration facility in rural Morgan County has generated a variety of comments from the public and environmental organizations. The comments that were submitted were helpful to the Illinois EPA in the decision making process and these comments were fully considered by the Illinois EPA prior to issuance of these permits.

The Illinois EPA received numerous general comments and comments on the proposed FutureGen project. Representative examples of these general comments are listed below without response. Specific comments that address topics that are relevant to this permitting decision, with responses, follow in subsequent section.

### Comments in Support of the Project

The project will mean more jobs, more business, increased tax revenue, and increased economic spending. As a member of the business community, I also understand the need for clean fuel and clean utilities that will replace those that are causing more pollution. This project has been well-considered and well-received in the area, and I firmly believe it will be one of the cleanest energy projects in the world.

The working men and women of central Illinois desperately need good-paying jobs that provide benefits for their families. FutureGen will provide these jobs. The world-leading clean-coal project will create an average of 620 well-paying jobs for the next 20 years. In addition, a brisk construction period will see this project generate as many as 1610 total jobs (direct and indirect) for the State of Illinois as work reaches its peak on the power plant retrofit, the CO<sub>2</sub> pipeline that will stretch from Meredosia to the northeast corner of Morgan County, the CO<sub>2</sub> injection well system and the construction of the new visitor research and training facility. Jacksonville, Morgan County and central Illinois need this boost of this project and the jobs it will bring.

This project means more than just some new jobs. It represents an economic development engine for Morgan County and the state. This will be a boon to the Illinois economy and will put Morgan County on the global stage of energy technology innovation.

Future Gen 2.0 is a \$1.65 billion capital project jointly sponsored by the United States Department of Energy (USDOE) and a group of international energy-sector companies. It is the world's first large-scale, integrated demonstration project of oxy-combustion advanced clean coal technology with carbon capture and sequestration (CCS). Construction of a new visitor/research center and a training facility in the Jacksonville area is also part of the plan.

I support this project. The application itself, the Illinois EPA, and the monitoring that will go with it seem to protect the citizens in the area. I live very close to the plant. Also the economic development benefits of the program are needed here in the area.

FutureGen represents an excellent opportunity to give the community an economic shot in the arm during the construction phase as well as the ongoing operation. In the long term FutureGen will produce, in addition to jobs, increased tax revenues and more than replace the jobs that had been lost due to the closure of the Meredosia power plant in 2011.

Approximately 60 percent of power in rural America is based on coal-fired power plants. So coal is very important to rural America. However, with ever-tightening environmental regulations, new technology is needed to make coal cleaner. Even though this project may do very little as far as global warming, it is a start, a start in the right direction.

FutureGen has a great opportunity to demonstrate this clean-coal technology. So let's build this plant and protect the coal power of rural America. The Jacksonville Regional Development Corporation, including myself, fully supports issuing this permit.

#### Comments in Opposition to the Project

This project is designed to thwart climate change by reducing CO<sub>2</sub>. However, this project will have no effect on the amount of CO<sub>2</sub> removed from or in the atmosphere. It is less than 1/10th of 1 percent. The net changes in CO<sub>2</sub> emissions from FutureGen 2.0 are so

small, that my calculations show that it would take 2127.66 like-kind FutureGen 2.0 projects per year to reduce atmospheric CO<sub>2</sub> by just 1 ppm.

FutureGen does not consider who will be responsible for covering possible escalating costs of FutureGen 2.0. Carbon capture and sequestration have a history of exceeding costs. The first FutureGen project was abandoned in 2010 due to increased project costs. Mississippi Power Company's Kemper integrated gasification combined cycle power plant costs doubled throughout the course of the project. Most of Kemper's \$4 billion price tag will be paid by ratepayers in economically depressed communities of color. The state of Illinois has bound its utilities to purchase electricity from FutureGen 2.0 for 20 years, without any commitment regarding the rates that will be charged to customers. This is a huge blunder or a huge sell-out.

FutureGen 2.0 includes the construction of a large "show place" facility featuring the FutureGen 2.0 project, including a visitor and research center, training facility and an arts center. The building is to be built on a 5 acre site in Jacksonville's Community Park. Mature trees will be cut down and space will be subtracted from various established activities held at the park. FutureGen 2.0 already has an office on Jacksonville's downtown square. This is a huge waste of money, money that would be better used for the actual project, particularly when projects like this go over budget. The visitor center at the Park smacks of ingratiation. It looks to me that the arts center is an add-on to appease the public for the unnecessary industrial move-in in our green Community Park.

I have long been disturbed by the FutureGen 2.0 project; hoping it would go away. To spend resources on a coal fired electric plant is poor judgment. Coal is an inefficient and outdated source of energy and coal-fired power plants are the dirtiest source of energy that is in use today.

The latest Cooperative Agreement between USDOE and FutureGen (Amendment 17) is on the website of the Illinois Commerce Commission. This amendment, filed on September 24, 2013 under ICC e-docket 13-0252, contains a risk assessment that indicates that FutureGen 2.0 is a high risk investment. I think it would be wise for all concerned to read the FutureGen Ex 13 Parts 1 and 2 prior to making a decision.

## **QUESTIONS AND COMMENTS WITH RESPONSES BY THE ILLINOIS EPA**

(Each question or comment is followed by the response by the Illinois EPA in bold-face type.)

1. FutureGen 2.0 Alliance has publicly stated that this plant is supposed to be a near-zero emission coal-fired power plant because it is supposed to capture more than 90 percent of its climate-change-inducing CO<sub>2</sub> emissions and sequester it permanently. However, this draft permit falls far short of that goal. Rather than ensuring that FutureGen will actually capture 90 percent of its CO<sub>2</sub> emission, this draft permit would allow all of the CO<sub>2</sub> emissions it generates; none has to be captured, none has to be sequestered. This is not

FutureGen's intent. Therefore, I urge Illinois EPA to go back to the drawing board and come up with permit limits that match FutureGen's stated intent.

**The FutureGen facility will be a demonstration project for use of carbon capture and sequestration (CCS) technology for control of emissions of CO<sub>2</sub>. As such, it was not unreasonable for a permit application to have been submitted for this project that does not require this construction permit to set specific performance requirements for CCS. This avoids requirements related to the use of CCS by this facility that may not be able to be achieved, at least initially, as the facility would be a demonstration facility and would use technologies that have not been previously demonstrated at the scale of the proposed facility. At the same time, this facility will be subject to requirements related to control of CO<sub>2</sub> emissions and use of CCS that are imposed by the USDOE. The facility will likely be subject to requirements related to CCS that are established by USEPA in its new proposed New Source Performance Standards (NSPS) for Greenhouse Gas (GHG) Emissions of Electric Utility Generating Units (EGUs), 40 CFR 60 Subpart TTTT.**

2. The facility would be able to emit excessive amounts of sulfur dioxide (SO<sub>2</sub>), nitrogen oxides (NO<sub>x</sub>), fine particulate matter (PM<sub>2.5</sub>), lead, and other pollutants. FutureGen may intend to do better, but this permit gives no assurance that it will.

**As addressed by the construction permit that has been issued for the proposed facility, this facility is subject to various federal and state rules that limit its emissions of different pollutants. In particular, the emissions of the oxy-combustion boiler are limited by an existing NSPS, 40 CFR 60 Subpart Da, that addresses emissions of particulate matter, SO<sub>2</sub> and NO<sub>x</sub>, and by federal National Emission Standards for Hazardous Air Pollutants (NESHAP), 40 CFR 63 Subpart UUUUU, that address emissions of hazardous air pollutants (HAP).**

3. USEPA recently prepared an NSPS for GHG Emissions from EGUs, 40 CFR 60 Subpart TTTT. The Illinois EPA should examine how FutureGen's plans to emit over one million tons of GHG annually would comply with these new standards. I disagree that these standards are not applicable because FutureGen proposes to offset the increase in GHG emissions from this facility with emissions decreases from the long-shuttered Meredosia Energy Center. This is legally problematic for two reasons. First, USEPA only allows a source to net out of Clean Air Act requirements if there are actual contemporaneous decreases in emissions, i.e., the emissions must fall within a period defined as five years before the proposed construction date of the new facility. That would mean that the emission reductions would have to have occurred between July of 2009 and July 2014. However, FutureGen Alliance is trying to use a contemporaneous period that goes back to February 2007, over seven years from when construction is expected to begin, which is two years beyond the allowable window for contemporaneous period.

**As observed by this comment, the proposed facility will likely be subject to requirements under USEPA's proposed NSPS for GHG emissions from Electric**

**Utility Generating Units (EGUs). Once these rules are adopted by USEPA, these rules will address emissions of CO<sub>2</sub> from new EGUs. The proposed facility will likely be subject to these rules because construction on the facility will not commence prior to the publication of the rulemaking proposal in the Federal Register.<sup>1</sup> Based on the pre-publication version of this proposed rulemaking, these rules would set a standard for the CO<sub>2</sub> emissions of new coal-fired EGUs that would require the use of CO<sub>2</sub> sequestration. As the proposed facility would be developed to capture and sequester CO<sub>2</sub>, it should meet the standard for CO<sub>2</sub> emissions that USEPA ultimately adopts, when these rules become applicable. With capture and sequestration of CO<sub>2</sub>, the facility's actual emissions of CO<sub>2</sub> to the atmosphere would be much lower than its potential emissions of CO<sub>2</sub>, as are addressed by the construction permit.**

**In this regard, nothing in this construction permit allows FutureGen to disregard this NSPS in the future when it becomes applicable. As discussed elsewhere in this document, NSPS are "self-executing." Based on the planned rulemaking proposal and Section 111(b) of the Clean Air Act, FutureGen will be subject to the requirements of the adopted NSPS for GHG emissions if construction on this facility commences after the proposed rule is published in the Federal Register, irrespective of this construction permit. The laws and rules that govern the applicability of NSPS, which are adopted by USEPA under Section 111 of the Clean Air Act, are different than the laws and rules that govern the PSD program, which is addressed by Sections 160 through 169 of the Clean Air Act. As explained elsewhere in this document, consistent with applicable law, rule and guidance, this project is not a major project for purposes of PSD due to decreases in emissions from the permanent shutdown of the existing boilers at the Meredosia Energy Center that are contemporaneous with this project. However, this does not shield the facility from other requirements that apply under the Clean Air Act, including NSPS rules.**

4. USEPA has issued a series of guidance documents addressing whether a source that has been shut down is subject to PSD review upon reactivation. USEPA has evaluated such situations in terms of the permanence of the shutdowns based upon the intent of the owner or operator. The facts and circumstances of the particular case, including the duration of the shutdown and the handling of the shutdown by the State, are considered evidence of intent of the owner or operator. A shutdown lasting for two years or more or resulting in removal of the source from the emissions inventory of the state should be presumed permanent. Review of the record here shows that Ameren intended to shut down the Meredosia center permanently at the time of its closure.

---

<sup>1</sup> On September 20, 2013, USEPA Administrator Gina McCarthy signed the notice for this proposed rulemaking. As of December 12, 2013, based on the information on USEPA's website for this rulemaking (2013 Proposed Carbon Pollution Standard for New Power Plants), this notice had not yet been published in the Federal Register. Only a pre-publication version of this notice was available at this website. Refer to: <http://www2.epa.gov/carbon-pollution-standards/2013-proposed-carbon-pollution-standard-new-power-plants>.

**The USEPA's reactivation policy is not applicable to this project. This policy addresses the proposed reactivation by a source of an emission unit that has not operated for an extended period of time following the permanent shutdown of the unit. As acknowledged in this comment, the policy provides for case-by-case consideration of specific facts including statements of intent by the owner and operator, the continued existence of the subject emission unit in a state's emission inventory and other factors.**

**In this case, none of the existing boilers at the Meredosia Energy Center will be reactivated or restarted. All the existing boilers will be permanently shutdown. This is a requirement in the construction permit that has been issued for the new oxy-combustion power facility. Since the existing boilers will not be reactivated, USEPA's reactivation policy is not relevant for these boilers.**

**The other existing emissions that will become part of the proposed facility are not affected by USEPA's reactivation policy. In this regard, Ameren and the Alliance submitted a permit application for this project, with the continued use of the Meredosia Energy Center, on February 9, 2012. This was only 40 days after the shutdown of Boilers 5 and 6, which occurred on January 1, 2012. Accordingly, the continued use of the Meredosia Energy Center was clearly planned separate from the shutdown of the existing boilers. In addition, Ameren currently maintains the buildings and equipment at the facility in light of their planned future use for this proposed project. The Illinois EPA's emission inventory continues to include emission units at the Meredosia Energy Center including the existing six boilers.<sup>2</sup> Ameren and the Alliance have continued to provide documentation to Illinois EPA showing their intent to continue operation of the Meredosia Energy Center consistent with this permitting action. Finally, Ameren has maintained all existing permits and has continued to pay all annual site fees.<sup>3</sup>**

5. As noted in the draft Environmental Impact Statement for the proposed project prepared by the USDOE, the Meredosia Energy Center has not been operating for the last two years.<sup>4</sup> Ameren's 2011 annual report also refers to Meredosia's closure and its consequences for the company.<sup>5</sup> Ameren also disclosed to investors in its most recent annual report that the company has been required by the Illinois Pollution Control Board (IPCB) to refrain from operating the Meredosia Energy Center through December 31, 2020.<sup>6</sup> Nor does the facility have a valid operating permit, as the Title V permit for the

---

<sup>2</sup> As related to the federal Acid Rain Program, Ameren notified USEPA that the existing boilers were to be classified as long term cold storage units per 40 CFR 75.2 and 75.61. Ameren letter, March 7, 2012.

<sup>3</sup> Because Ameren appealed and received a stay of the Clean Air Act Permit program (CAAPP) permit for the Meredosia Energy Center issued in 2005, the state operating permits for the facility remain in effect.

<sup>4</sup> See Draft Environmental Impact Statement for the FutureGen 2.0 Project (DOE/EIS-0460D), whose release was announced in the Federal Register (78 FR 26004, May 3, 2013).

<sup>5</sup> Ameren Annual Report and 10-K, 2011, at 8, 33, 47, 54, 68, 70, 77, 103, 104, 159, 167.

<sup>6</sup> Ameren Corporation, Form 10-K Annual Report for the Fiscal Year Ended December 31, 2012, available at <http://www.sec.gov/Archives/edgar/data/18654/000144530513000414/aee-2012x1231x10k.html>.



Meredosia Energy Center was stayed in 2005 and never took effect.<sup>7</sup> Data from USEPA databases confirms that this plant generated zero emissions in 2012.<sup>8</sup> Despite the clear indication that the Meredosia Energy Center was closed permanently in 2011, the draft permit would take its emissions from 2007 to 2009 into account in concluding that the FutureGen project will have lower emissions. This runs counter to USEPA guidelines and common sense.

**Issues regarding shutdown and reactivation have already been addressed in the above discussion. While an IPCB order prohibits operation of the existing boilers at the Meredosia Energy Center, the FutureGen project is not subject to that prohibition. The statements in Ameren's 2011 annual report notwithstanding, Ameren's intention not to permanently cease operations at the Meredosia Energy Center is demonstrated by the various actions that have already been discussed, including the submittal of an application for this proposed project. The status of the Title V or CAAPP permit for the Meredosia Energy Center provides further evidence that continued operation is planned. This is because Ameren has not dropped its appeal of the issued CAAPP permit and this appeal is still pending before the IPCB.**

**In addition, as will be discussed in more detail in response to other comments, the shutdowns of the existing boilers at the Meredosia Energy Center are contemporaneous with the proposed FutureGen project. The amounts of those emission decreases were properly determined as the actual emissions of those boilers during a 24-month period preceding the shutdowns.**

6. The residents surrounding the Meredosia Energy Center have breathed air free from its pollution for the last two years. The proposed project should be considered from this baseline of zero emissions. The same fuzzy math that the Applicant uses to avoid carbon regulations is also being used to avoid modern emission limits for all criteria pollutants, including SO<sub>2</sub>, NO<sub>x</sub>, particulate matter and lead. The 7<sup>th</sup> Circuit has stated there is an expectation that as old plants wear out and are replaced by new ones, the new plants will be subject to "the more stringent pollution controls that the Clean Air Act imposes on the new plants." By allowing FutureGen to improperly credit Meredosia's old emissions to evade otherwise applicable standards, the draft permit contravenes the law.

**As discussed, the proposed facility would be a new power plant and the oxy-combustion boiler would appropriately be subject to emissions standards that apply to new utility boilers. Only the applicability of the PSD rules is affected by the decreases in emissions due to the shutdown of existing boilers. The applicability of the PSD rules to a proposed project, that is, whether a proposed project is a major project, is governed by the net increases in emissions of different pollutants from a proposed project. These rules do not provide that only the emissions increases from**

---

<sup>7</sup> See DOE/EIS-0460D, p 3.1-8-9.

<sup>8</sup> Coal-fired Characteristics and Controls: 2012, USEPA. Clean Air Markets Program, *available at* <http://www.epa.gov/airmarket/quarterlytracking.html>.

**a project must be considered. For this project, the PSD rules allow the decreases in emissions from the shutdown of the existing boilers to be considered in determining that that this project would not result in significant net increases in emissions and should not be considered a major project for purposes of the PSD rules.**

**In particular, as provided by 40 CFR 52.21(a)(2), the applicability of PSD requirements to proposed projects at an existing major source requires that the project results in both a significant increase in emissions, by itself, and a significant net emission increase as those terms are defined on a pollutant-by-pollutant basis. Therefore, to determine the applicability of PSD, first, the particular project's emissions are examined to determine whether the project, by itself, would result in a significant increase in emissions. In this case, the project, by itself, would be significant for a number of pollutants, including, NO<sub>x</sub>, SO<sub>2</sub>, CO, PM, PM<sub>10</sub>, PM<sub>2.5</sub>, and GHG. For each pollutant for which there is a significant increase in emissions from the project, the second step is to determine whether there is a net emissions increase. This is the sum of the emissions increase from the project and the emissions increases and decreases from other projects in a contemporaneous 5-year time period preceding the date on which construction of the proposed project will commence (40 CFR 52.21(b)(3)(i)). If the sum of the project's emissions and the contemporaneous increases and decreases for other projects is not significant, the project is not a major project for that pollutant. In this case, the net emissions increases from the project will not be significant for any pollutants regulated by the PSD rules. Thus, the FutureGen project is not a major project for purposes of applicability of PSD review.**

**The comment argues that if emission units have recently ceased operations, the resulting emissions decreases should not be considered in determining the applicability of PSD to a future project at a source. However, the PSD rules (40 CFR 52.21(b)(3)(i)(b)) provide that a source may determine applicability of PSD for a future project considering emission decreases from past shutdowns at the source when those shutdowns are still contemporaneous. For the proposed FutureGen project, the shutdown of the existing boilers at the Meredosia Energy Center will be within the 5-year contemporaneous period specified by the PSD rules.**

7. How will restarting the Meredosia Energy Center affect the multi-pollutant standard that Ameren agreed to in 2006?

**The continuing operation of the Meredosia Energy Center as an oxy-combustion power plant will not affect the multi-pollutant standards under 35 IAC 225.233. These standards, which coordinate the timing of control requirements for emissions of mercury with certain requirements for control of NO<sub>x</sub> and SO<sub>2</sub> emissions, are applicable to Ameren's existing coal-fired electrical generating units. As a new generating unit, the new oxy-combustion facility will not be subject to the multi-pollutant standards but must directly comply with the standard for mercury emissions in 35 IAC 225.230(a)(1). See, Condition 2.1.3-2(f).**

8. Concerning the multistep control train for removing pollutants from the flue gas, the first step is the circulating dry scrubber that uses hydrated lime to remove SO<sub>2</sub>, other acid gases, and mercury. What are the waste streams generated from the circulating dry scrubber? Is the waste stream solid or wet?

**The waste material from the Circulating Dry Scrubber (CDS), which will be composed of gypsum, ash and unreacted lime, will be removed from the flue gas as dry material by the downstream fabric filter. This waste stream will be analyzed to determine its regulatory classification and disposed of appropriately at an off-site commercial waste disposal facility.**

9. The primary purpose of the polishing system for the oxy-combustion boiler, which includes a scrubber and baghouse, is to reduce the moisture content of the flue gas and adjust its temperature. Would this be direct contact, i.e., contact cooler polishing system? Are the waste streams generated from this dry, wet or both?

**The waste generated by this polishing system (i.e., the Direct Contact Cooler - Polishing System or DCCPS) and its cooling tower, which involve direct contact with flue gas, is a wet stream. It will be addressed by the National Pollutant Discharge Elimination System (NPDES) permit for the Meredosia Energy Center. The waste from the baghouse that is downstream of the DCCPS is a dry stream.**

10. Does Section 40 of Illinois Public Act 97-618 mean that the Illinois EPA, as a representative of the State of Illinois, must grant all necessary and appropriate permits no matter what? Is there an option for the Illinois EPA not to issue any permits? Section 40 of this Act reads

Permitting. The State of Illinois shall issue to the Operator all necessary and appropriate permits consistent with State and federal law and corresponding regulations. The State of Illinois must allow the Operator to combine applications when appropriate, and the State of Illinois must otherwise streamline the application process for timely permit issuance.

**The cited act, the Clean Coal Futuregen for Illinois Act of 2011, does not require that the Illinois EPA issue a construction permit “no matter what.” The Illinois EPA has acted on the construction permit application for this project pursuant to Section 39(a) of Illinois’ Environmental Protection Act. Section 39(a) of this Act generally addresses the circumstances under which the Illinois EPA shall or shall not issue a construction permit for a proposed facility. It provides, in relevant part, that when a permit is required for the construction of a facility “...the applicant shall apply to the Agency for such permit and it shall be the duty of the Agency to issue such a permit upon proof by the applicant that the facility ...will not cause a violation of this Act or of regulations thereunder.”**

**In fact, the scope of Section 40 of the Clean Coal Futuregen for Illinois Act of 2011, as addressed by this comment, is narrow. Section 40 of this act merely requires the State of Illinois to issue all necessary and appropriate permits for this project consistent with state law. As applied to the Illinois EPA, this means that the Illinois EPA must proceed in accordance with Illinois' Environmental Protection Act. Section 40 does not require the Illinois EPA to issue a construction permit in circumstances where the permit would be inconsistent with provisions of the Environmental Protection Act or associated regulations. Section 40 does little more than require the Illinois EPA to allow the operator to combine various permit applications, to the extent appropriate, and to streamline the application process.**

11. I find it rather unsettling that under the wastewater permit all the cooling tower chemicals are listed. If you have ever been around a cooling tower, things can go wrong, and some of these chemicals can be discharged to the air. Some of these chemicals are very bad as an air pollutant. This was not addressed.

**The emissions to the atmosphere of the chemicals that are used in cooling water are indirectly addressed by the wastewater permit under the NPDES program. As that permit sets requirement for the nature and/or amount of contaminants in the water that is circulated in the cooling towers, as related to discharges of wastewater to surface waters, it also serves to address other losses of these chemicals to the atmosphere, including emissions.**

12. I raised some questions about the anti-fouling materials used in the cooling towers at a hearing on the FutureGen project held by USDOE. My husband, who is knowledgeable about cooling towers, says that the cooling towers are closed systems. That is, the water used in the boiler and the water in the cooling towers will be kept separate. Therefore, the chemicals in the boiler water are normally not emitted to the atmosphere. Given the nature of the chemicals used in the water used in the cooling towers, e.g., short lifespan of the chemicals, there should not be a problem from these chemicals.

**The Illinois EPA agrees with the observations made in this comment.**

13. What practices are going to be employed at the site to control fugitive dust and prevent fugitive dust from affecting area residents?

**The haul roads at the site used by trucks carrying coal and other bulk materials must be paved. These roads must also be swept, flushed or vacuumed on a regular basis as needed to prevent the accumulation of excessive levels of dust (silt) on the roads, which would result in significant emissions of fugitive dust.**

**Emissions from coal handling operations must also be controlled to prevent nuisance emissions of fugitive dust. For the existing coal handling operations, which will not be modified, good housekeeping practices would be used consistent with the historic practices at the Meredosia Energy Center. The control practices for the two**

**new and modified operations must be sufficient to ensure ongoing compliance with the NSPS that addresses coal handling operations, 40 CFR 60 Subpart Y.**

14. Given that there are multiple coal ash contamination sites throughout Illinois, I am glad water is not going to be used anymore to transport coal ash and to sort coal ash in wet impoundments. However, with dry ash handling comes fugitive dust.

**The permit requires that emissions of particulate matter from handling of ash be effectively controlled using a combination of enclosure, filtration and work practices, i.e., mixing of water with the dry ash prior to loading out into trucks.**

15. Other than CO<sub>2</sub>, the increases in emissions with the proposed plant will exceed the significant emission thresholds for a major project under PSD rules. My local newspaper mentioned that coal to be used would be high sulfur. It seems all the emphasis is on capturing CO<sub>2</sub> which undoubtedly contributes to global warming and climate change but does not cause asthma, allergies, lung problems, acid rain and polluted water which other emissions cause and are present from every coal-fired power plant. CO<sub>2</sub> capture is the star of FutureGen 2.0, but pity the nearby inhabitants who have enjoyed a clear atmosphere during the facility shutdown, but who will now be affected by dirty air again.

**As already discussed, emissions of pollutants besides CO<sub>2</sub> from the proposed facility must be appropriately controlled. There will not be either significant increases or significant net increases in emissions for each of the pollutants regulated under the PSD rules. This project will be accompanied by net decreases in emissions of most pollutants. In particular, the permitted emissions of SO<sub>2</sub> and NO<sub>x</sub> from the proposed facility, as allowed by the construction permit, are much less than the previous emissions of the Meredosia Energy Center. The permitted emissions of particulate matter are also less.**

16. Using coal for energy has devastating environmental impacts during every point in its lifecycle. Mining coal from the ground damages lands, water and air. The transportation of coal by diesel trucks and trains adds emissions and dust to the atmosphere. The new oxy-combustion boiler will need 25 percent more coal than a traditional air boiler, thereby adding the increased emissions of pollutants other than CO<sub>2</sub>.

**Coal mines are subject to specific regulatory and permitting programs that have been developed to prevent and mitigate detrimental impacts from mining activity. This includes planning for ground subsidence, as is a particular concern for long wall mining, to prevent damage to structures, agricultural productivity and the natural environment, as well as provisions for land reclamation following completion of mining. As the coal mines that would supply the proposed facility would be separate sources from the Meredosia Energy Center, it is beyond the scope of this permit for the proposed facility to address the impacts of coal mining.**

**Similarly, regulatory programs have been developed and continue to evolve to address the emissions from the diesel engines in trucks and railroad locomotives. As trucks and locomotives are mobile sources, it is also beyond the scope of this permit for the proposed facility to address them.**

**It is certainly correct, as observed by this comment, that sequestration of CO<sub>2</sub> has costs. The proposed facility will use more coal for the electricity that it provides to the power grid than would be used by a comparable power plant without sequestration. However, pollution controls commonly have costs. These costs are justified by the adverse impacts to human health and welfare and to the environment that are avoided by the use of those controls. In this regard, the costs of CO<sub>2</sub> sequestration are not inconsequential but neither are the impacts of global warming and climate change. Moreover, CO<sub>2</sub> sequestration is only one step that will be needed if global emissions of CO<sub>2</sub> emissions are to be reduced. Improvements in energy efficiency and the generation of electricity with technologies that do not involve combustion of fuel, such as wind power, will also be important. These other approaches to avoiding CO<sub>2</sub> emissions also have the accompanying benefit of reducing emissions of other pollutants that accompany the generation of electricity.**

17. I am concerned about the permanence of CO<sub>2</sub> storage schemes. The thrust of this demonstration project would be to reduce the amount of CO<sub>2</sub> to the atmosphere by putting over 350 million gallons of liquefied CO<sub>2</sub> per year under Illinois farm land to reduce the amount of CO<sub>2</sub> emissions to the atmosphere. Improper storage or lack of long term monitoring could lead to health risks to nearby populations, harm agriculture, create pressure changes causing ground heave, and even trigger seismic events. Safe and permanent storage cannot be guaranteed and even low leakage rates would undermine any climate mitigation effect. This is not a tried and tested process. In 1986, a large leakage of naturally sequestered CO<sub>2</sub> rose from Lake Nyos in Cameroon and asphyxiated 1,700 people. While the CO<sub>2</sub> had been sequestered naturally, the event could be evidence for the potentially catastrophic effects of sequestering carbon artificially. Local residents fear a potentially dangerous CO<sub>2</sub> leak and the lack of adequate evacuation procedures. Is future long term monitoring or a financial assurance plan to insure the long term stability of the CO<sub>2</sub> sequestration addressed?

**Geological sequestration of CO<sub>2</sub> is subject to USEPA regulations that are designed to address the risks posed by sequestration and to prevent adverse impacts. In this regard, in December, 2010, USEPA adopted its "Class VI Rule" for underground injection of CO<sub>2</sub> for geologic sequestration, 40 CFR Part 146. This rule sets minimum technical criteria for permitting, geologic site characterization, area of review and corrective action, financial responsibility, well construction, operation, mechanical integrity testing, monitoring, sealing of wells, post-injection site care, and site closure of such wells. In Illinois, USEPA administers the permit program that implements this rule.**

18. Adding a new coal-fired power plant in Illinois is extremely ill advised. The Applicant's own analysis shows that the area in which this new plant is proposed is already riddled with sulfur dioxide (SO<sub>2</sub>) air quality levels that exceed the health-based National Ambient Air Quality Standard (NAAQS) by more than ten times. Permitting the addition of over 646,000 pounds (323 tons) per year of SO<sub>2</sub> to this area, which is already violating the NAAQS, is wrong.

**The air quality in Illinois generally complies with the hourly NAAQS for SO<sub>2</sub>. There are currently only two discrete areas in Illinois that are designated nonattainment areas for SO<sub>2</sub> in Illinois. One is the Pekin area, south of Peoria, and the other is the Lemont area, southwest of Chicago. In both areas the elevated levels of SO<sub>2</sub> are caused by the contribution of certain sources in those areas. Actions are underway to reduce SO<sub>2</sub> emissions in these areas to bring them into attainment.**

**This project will not add 323 tons of SO<sub>2</sub> emissions annually in Illinois. Rather, as will be discussed later in more detail, due to the contemporaneous decreases in emissions from the permanent shutdown of the six existing boilers at the Meredosia Energy Center, this project represents a net decrease in annual SO<sub>2</sub> emissions of over 9,000 tons.**

**Moreover, this comment grossly misrepresents the analysis of SO<sub>2</sub> air quality that the Applicant conducted for the proposed facility. In fact, this analysis was not prepared to address the current levels of air quality but the potential impacts of the proposed facility on air quality. The Applicant's analysis, which was independently reviewed by the Illinois EPA, shows that the impacts of the proposed project on any exceedances of the hourly SO<sub>2</sub> NAAQS would not be significant. The Applicant performed a cumulative assessment for the SO<sub>2</sub> considering both the SO<sub>2</sub> emissions of the facility and SO<sub>2</sub> emissions from existing sources in Central Illinois. For those receptors and times where the assessment showed a modeled exceedance of the SO<sub>2</sub> NAAQS, the modeled impacts of the proposed facility were not significant. The facility's greatest contribution at a particular receptor and time with a modeled exceedance was less than 15 percent of the applicable significant impact level (SIL). Accordingly, the SO<sub>2</sub> air quality assessment for the proposed project shows that it would not cause or contribute to SO<sub>2</sub> exceedances.**

19. While there are no ozone monitors in Morgan County where the proposed project would be located, lack of air quality data does not make anyone safe. Ozone monitors are located in nearby Jersey and Sangamon Counties. Based on monitored ozone levels for 2010 through 2012, the ozone design value for Jersey County is 79 parts per billion (ppb), which exceeds the 2008, health-based ambient air quality standard for ozone, 75 ppb. The ozone monitor in Sangamon County was relocated in 2011, so there is not a design value for the period of 2010 through 2012. However, the 4<sup>th</sup> highest value recorded by the ozone monitor in Sangamon County in 2011 and 2012 were 79 ppb and 76 ppb, respectively. Thus, Sangamon County also appears to be headed for a nonattainment designation for ozone air quality. Permitting the addition of over

3,468,000 pounds per year of nitrogen dioxide (NO<sub>x</sub>), an ozone precursor, to this area that is already violating health based air quality standards is wrong.

**Current levels of ozone in Central Illinois do not provide a basis to deny a permit for the proposed project. As a technical matter, this comment does not consider the nature of ozone air quality in Central Illinois or the role that individual sources have on ozone air quality. Elevated levels of ozone in Central Illinois are generally the result of transport of ozone and ozone precursors from sources located in the greater St. Louis Area (both Illinois and Missouri), including emissions from both stationary sources, like power plants, and cars, trucks and other mobile sources. Local emissions of ozone precursors in Central Illinois have little or no role in elevated levels of ozone that occur locally. Moreover, programs are underway to reduce the emissions of ozone precursors both in major urban areas and nationally to improve air quality. These are achieving gradual but steady improvements in air quality. This is shown by the design values for ozone for Jersey and Sangamon Counties for the period of 2011 through the end of the 2013 ozone season. Air quality in Jersey County, which is directly adjacent to the St. Louis area, has improved, with the design value for Jersey County now being 77 ppb. Continued attainment of the ozone air quality standard is shown in Sangamon County, which is significantly farther from the St. Louis Area, with an ozone design value of 72 ppb.**

20. The Prevention of Significant Deterioration (PSD) program found in Part C of Title I of the federal Clean Air Act establishes the statutory framework for protecting public health and welfare from adverse effects of air pollution in areas designated attainment. Congress specified that the PSD program is intended to:

insure that economic growth will occur in a manner consistent with the reservation of existing clean air resources”; and (2) “assure that any decision to permit increased air pollution . . . is made only after careful evaluation of all the consequences of such a decision and after adequate procedural opportunities for informed public participation in the decisionmaking process.

42 U.S.C. § 7470.

To accomplish these purposes, the Clean Air Act relies primarily on a preconstruction permitting program as the mechanism for reviewing proposals to increase air pollution in areas meeting the NAAQS. The Clean Air Act generally requires PSD permits prior to construction and/or operation of new major stationary sources and major modifications to stationary sources in areas designated attainment or unclassified for the pollutants to be emitted by the sources. See 42 U.S.C. §§ 7475 (a) and 7479(2)(C).<sup>9</sup>

---

<sup>9</sup> “Modification” is defined to include, “any physical change in, or change in the method of operation of, a stationary source which increases the amount of any air pollutant emitted by such source or which results in the emission of any air pollutant not previously emitted.” 42 U.S.C. § 7411(a)(4).



The Illinois EPA and the Applicant agree that the new oxy-combustion boiler and most of the other changes occurring because of the FutureGen 2.0 project are new construction and/or changes of operation. (For example, *See* the application, June 2013 submittal, p. 6, Table 3-1.) The Illinois EPA and the Applicant agree that these activities will create significant emission increases for certain regulated NSR pollutants.<sup>10</sup> The Applicant also claims that the increases in emissions of lead and fluorides from this project are not significant. (See application, June 2013 submittal, p. 21.) However, as explained in later comments, the increase in emissions of fluorides is significant.

Therefore, except for fluorides, the only issue with regard to PSD applicability is whether the changes cause significant net emission increases. The Applicant and the Illinois EPA claim that they do not. See, e.g. Draft Permit at Finding 3 (“this project will not be accompanied by significant net increases in emissions of PSD pollutants”). However, as detailed below, the changes do cause significant net emission increases for particulate matter (PM), particulate matter<sub>10</sub> (PM<sub>10</sub>), particulate matter<sub>2.5</sub> (PM<sub>2.5</sub>), sulfur dioxide (SO<sub>2</sub>), nitrogen oxides (NO<sub>x</sub>), sulfuric acid mist, fluorides, and greenhouse gases. Thus, PSD is an applicable requirement for these pollutants, which requires the Applicant to obtain a PSD permit.

**As will be discussed in response to specific comments, the proposed facility is not a major project under the federal PSD rules. There are contemporaneous decreases in emissions from the permanent shutdown of the existing boilers at the Meredosia Energy Center such that the net increases in emissions of regulated NSR pollutants from this project will not be significant.**

21. In the application (June 2013 submittal, p. 16), the Applicant admits that for an emission decrease to be creditable under the PSD program, the following must be true. “All increases and decreases have occurred after the applicable minor source baseline date.” See also 40 CFR 52.21(b)(3)(iv). While the Applicant clearly acknowledges that a decrease must occur after the minor source baseline date, the Applicant and the Illinois EPA completely fail to discuss this requirement, much less demonstrate that it is met.

**As is necessary for certain pollutants, the requirement of 40 CFR 52.21(b)(3)(iv) is met by the emissions decreases from the shutdown of the existing boilers at the Meredosia Energy Center so these emissions decreases are creditable and may be considered in the netting analysis for the proposed project.**

---

<sup>10</sup> For example, in the application (June 2013 Submittal, page 14), the Applicant states “FutureGen 2.0 emissions increases are greater than the significant emissions rates so the Project will result in a significant emissions increase as that term is defined in the US EPA regulations.”

As related to emissions of SO<sub>2</sub>, this requirement is met as the shutdown of the existing boilers at the Meredosia Energy Center, in fact, occurred after the minor source baseline date for SO<sub>2</sub>, which is in 1985.<sup>11</sup>

As a more general matter, this comment misrepresents 40 CFR 52.21(b)(3)(iv), relying on an incomplete statement in the application that broadly suggests that decreases in emissions are not creditable for purposes of netting if they occur before the minor source baseline. In fact, this provision only addresses emissions of three pollutants, i.e., SO<sub>2</sub>, particulate matter and nitrogen oxides (NO<sub>x</sub>). For decreases in emissions of these pollutants that occur before the minor source baseline date, this provision merely addresses an additional requirement on such decreases for them to be creditable for netting. These decreases must be considered in determining the “maximum allowable increases remaining available,” more commonly referred to as the available PSD increment. As is necessary for certain pollutants, the decreases in emissions in the netting analysis for the proposed project meet this requirement and are creditable. In this regard, 40 CFR 52.21(b)(3)(iv), in its entirety, provides:

An increase or decrease in actual emissions of sulfur dioxide, particulate matter, or nitrogen oxides that occurs before the applicable minor source baseline date is creditable only if it is required to be considered in calculating the amount of maximum allowable increases remaining available.

This requirement is satisfied for the decreases in emissions of particulate matter and NO<sub>x</sub> in the netting analysis for the proposed project.<sup>12</sup> This is because these decreases involve changes in actual emissions of particulate matter and NO<sub>x</sub> at a major stationary source (i.e., the Meredosia Energy Center) that occurred after the major source baseline date for these pollutants, i.e., January 6, 1975<sup>13</sup> and February 8, 1988, respectively. Thus, these decreases must be considered when determining the available PSD increments for particulate matter and NO<sub>x</sub>. In this regard, after the major source baseline date for a pollutant, the baseline concentration, which is the starting point for consumption or expansion of PSD increment, is not affected by changes in emissions at major sources, which changes in emissions accordingly affect the amount of increment that is available. Decreases in emissions at major sources act to expand the amount of increment that is available. (Increase in emissions at major sources act to consume available increment.) In this regard, in

---

<sup>11</sup> For SO<sub>2</sub>, the minor source baseline date was set in Morgan County in 1985 when a source, Anderson Clayton, submitted an application for a PSD permit for the conversion of an existing boiler to coal (Construction Permit No. 84030035).

<sup>12</sup> As already discussed, this requirement is met for the decreases in SO<sub>2</sub> from the shutdowns of the existing boilers at the Meredosia Energy Center because they occurred after the minor source baseline date.

<sup>13</sup> The PSD rules no longer contain a major source baseline date specifically for particulate matter. As addressed by Section 166(f) of the Clean Air Act, USEPA has converted the major source baseline date originally established for particulate matter, January 6, 1975, into the major source baseline date for PM<sub>10</sub>. In this regard, Section 166(f) of the Clean Air Act authorized the USEPA to substitute provisions for PSD increment in terms of PM<sub>10</sub> for earlier provisions in terms of particulate matter.

the provisions of the PSD rules dealing with PSD increments, the definition of baseline concentration, 40 CFR 52.21(b)(13)(ii), provides:

The following will not be included in the baseline concentration and will affect the applicable maximum allowable increase(s):

(a) Actual emissions from any major stationary source on which construction commenced after January 6, 1975; ...

This subject was specifically addressed by USEPA in 1980 when it adopted the provisions of the PSD rules that provide for netting, including 40 CFR 52.21(b)(3)(iv). In the preamble to the adoption of these provisions, USEPA explains that emission decreases at major stationary sources that occur before the minor source baseline date are considered in determining the available increment. This action was taken to address the circumstances of projects, like the proposed project, that will occur at a major stationary source.<sup>14</sup>

EPA's policy under the June 1978 regulations is unclear as to whether emissions reductions prior to the baseline date increase the amount of available increments. The policy allows decreases after January 6, 1975, and prior to the baseline date, to be used by sources to offset subsequent increases from the requirement for an ambient air quality assessment, since the decreases permit later emissions increase at the same source to avoid the otherwise required air quality assessment. The policy did not state whether

---

<sup>14</sup> This approach to the available increment was subsequently confirmed in 2010 in the preamble to the adoption of the PSD increments for PM<sub>2.5</sub> and other revisions to the PSD rules to address PM<sub>2.5</sub>.

To make this distinction between the date when emissions resulting from the construction at a major stationary source consume the increment and the date when emissions changes in general (*i.e.*, from both major and minor sources) begin to consume the increment, we established the terms "major source baseline date" and "minor source baseline date," respectively. *See* 40 CFR 51.166(b)(14) and 52.21(b)(14). Accordingly, the "major source baseline date," which precedes the trigger date, is the date after which actual emissions increases associated with construction at any major stationary source consume the PSD increment. In accordance with the statutory definition of "baseline concentration," the PSD regulations define a fixed date to represent the major source baseline date for each pollutant for which an increment exists. ... In this final rule, as described later, we are establishing a separate major source baseline date for implementing the PM<sub>2.5</sub> increments. *See* section V.F of this preamble for further discussion of the major source baseline date for PM<sub>2.5</sub>.

The "minor source baseline date" is the earliest date after the trigger date on which a source or modification submits the first complete application for a PSD permit in a particular area. After the minor source baseline date, any increase in actual emissions (from both major and minor sources) consumes the PSD increment for that area.

Once the minor source baseline date is established, the new emissions increase from that major source consumes a portion of the increment in that area, as do any subsequent actual emissions increases that occur from any new or existing source in the area.

75 FR 64868 (Oct. 10, 2010).

isolated decreases not made in conjunction with intrasource increase were considered to expand available increment. In contrast the policy is clear that emission reductions after the baseline date increase available increments.

As a result of the revised definition of modification which permits offset credit for emission reductions occurring within a moving five-year period, EPA has decided to clarify its existing policy. All emission reductions prior to the baseline date at major stationary source will now be considered to expand available increment. Since contemporaneous emission reductions accomplished before the baseline date can be used by a source to offset a contemporaneous post-baseline emissions increase, and thereby avoid PSD review, it is also reasonable to allow these contemporaneous pre-baseline date reductions to expand the increment. Without this change, source owners that reduce emissions by retiring or controlling old equipment before the baseline date will be penalized by having increase after the baseline data count against increments even though the pre-baseline decrease might offset the later increase and eliminate the need for PSD review.

45 FR 52720 (Aug. 7, 1980).

It should be noted that this approach to increment consumption is facilitated by the definition of "construction" in the PSD rules. As construction is defined by 40 CFR 52.21(b)(8), it encompasses not only activities that increase emissions, such as modifications, but also activities that may increase or decrease emissions, e.g., changes in the method of operation of emission units, and activities that act to reduce emissions, i.e., the demolition of emission units. The definition of construction was intentionally developed in this way by USEPA to facilitate implementation of its approach to increment consumption and expansion.<sup>15</sup>

Construction means any physical change or change in the method of operation (including fabrication, erection, installation, demolition, or modification of an emissions unit) that would result in a change in emissions.

---

<sup>15</sup> The definition of "construction" was specifically addressed by USEPA in 1980 when it adopted the provisions of the PSD rules that provide for netting. As explained in the preamble to this rulemaking,

The changed policy [for increments] is reflected in a new definition of "construction" which is any physical change or change in the method of operation of a stationary source resulting in a change in the actual emissions of the source (including fabrication, erection, installation, demolition, or modification). Any construction commencing at a major source since January 6, 1975, may result in an increase or decrease in actual source emissions. If an actual decrease involving construction at a major stationary source occurs before the baseline date, the reduction will expand the available increment if it is included in a federally enforceable permit or SIP provision. An actual increase associated with construction activities at a major stationary source will consume increment.

75 FR 52720 (Aug. 7, 1980).

**40 CFR 52.21(b)(8).**

22. As already noted, in the application, the Applicant admits that for an emission decrease to be creditable under the PSD program, the following must be true. "All increases and decreases have occurred after the applicable minor source baseline date." See also 40 CFR 52.21(b)(3)(iv). The decreases in PM<sub>2.5</sub> emissions from the shutdown of the existing boilers at the Meredosia Energy Center did not occur after the minor source baseline date for PM<sub>2.5</sub>. The trigger date must occur before the minor source baseline date. After the trigger date, the minor source baseline date is established when the first complete PSD permit application covering the pollutant in question is filed for the area at issue. *See, e.g.* 75 FR 64,864, 64,868 (Oct. 20, 2010).

The trigger date for PM<sub>2.5</sub> is October 20, 2011, per 75 FR 64,887. Therefore, by definition, the minor source baseline date for PM<sub>2.5</sub> must be after October 20, 2011. According to the application (June 2013 submittal, p. 17), the decrease at Boilers 1 through 4 happened on November 9, 2009 when the boilers were removed from service. Thus, this decrease from Boilers 1 through 4 is not creditable because it happened before the PM<sub>2.5</sub> minor source baseline date.

According to the application (June 2013 submittal, p. 17), Boilers 5 and 6 were removed from service and created emission decreases, according to the Applicant, on January 1, 2012. However, the Applicant and the Illinois EPA did not claim (nor do I think they could) that a complete PSD application for a project in Morgan County subject to PSD for PM<sub>2.5</sub> was filed between October 21, 2011 and December 31, 2011. Thus, the decreases in PM<sub>2.5</sub> emissions from Boilers 5 and 6 are also not creditable. The fact that increase from the 2008 emergency engine generator is not creditable does not change the conclusion. The new equipment for FutureGen 2.0 will create an increase of 97 tpy of PM<sub>2.5</sub>. There are no creditable decreases so the net increase is also 97 tpy of PM<sub>2.5</sub>. This is above the significant emission rate of 10 tpy so FutureGen 2.0 triggers PSD for PM<sub>2.5</sub>.

**This comment also misrepresents 40 CFR 52.21(b)(3)(iv) by relying on an incomplete statement in the application to suggest that it applies to emissions of PM<sub>2.5</sub>. This provision only addresses three pollutants, i.e. SO<sub>2</sub>, particulate matter and NO<sub>x</sub>. It does not apply for emissions of PM<sub>2.5</sub>. USEPA has addressed PM<sub>2.5</sub> as a new pollutant, distinct from emissions of particulate matter and PM<sub>10</sub>. As discussed in the preamble to the adoption of the PSD increments for PM<sub>2.5</sub>, the USEPA acted under the authority of Section 166(a) of the Clean Air Act and not under Section 166(f) of the Clean Air Act.<sup>16</sup> Accordingly, this comment does not**

---

<sup>16</sup> Among other matters, Section 166(a) of the Clean Air Act addresses the establishment by USEPA of PSD increments for new pollutants for which NAAQS are adopted. Section 166(f) provides that increments for PM<sub>10</sub> may be substituted for the increments for particulate matter that are specified by Sections 163(b) and 165(d)(2)(C)(iv) of the Clean Air Act.

In the preamble to the adoption of the PSD increments for PM<sub>2.5</sub> and other revisions to the PSD rules to address PM<sub>2.5</sub>, USEPA explains that the increments for PM<sub>2.5</sub> are being adopted under Section 166(a) of the Clean Air Act.

show that decrease in emissions of PM<sub>2.5</sub> from the shutdown of the existing boilers at the Meredosia Energy Center is not creditable for purposes of netting.

At most, this comment observes that, as related to PM<sub>2.5</sub>, the decreases in emissions from the shutdown of Boilers 1 through 4 occurred prior to the major source baseline date set by USEPA for PM<sub>2.5</sub>, October 20, 2010. With respect to the decreases in emissions from the shutdown of Boilers 5 and 6, the comment acknowledges they that occurred after the major source baseline date for PM<sub>2.5</sub>. It is undisputed that the decreases in emissions from the shutdown of the existing boilers occurred prior to the minor source baseline date for PM<sub>2.5</sub>. As theorized by this commenter, a PSD application has not been received for a project in Morgan County that is subject to PSD for PM<sub>2.5</sub>.<sup>17</sup> However, as already discussed, emission decreases that occur at a major stationary source do not have to occur after the minor source baseline date to be creditable for purposes of netting.

In response to this comment, the Illinois EPA has further considered whether a revised netting analysis could be prepared for the proposed project for PM<sub>2.5</sub> that shows that the net increase in emissions of PM<sub>2.5</sub> is not significant only relying on the decreases in emissions from Boilers 5 and 6. That is, whether a netting analysis for the proposed project could show a less than significant net increase in emissions without relying on decreases from the shutdown of Boilers 1 through 4, which occurred before the major source baseline date for PM<sub>2.5</sub>.

In fact, such a netting analysis could be prepared. The decrease in PM<sub>2.5</sub> emissions from just the shutdown of Boilers 5 and 6 is 103.8 tons/year.<sup>18</sup> Accordingly, the net

---

For the reasons discussed previously in this preamble, EPA has decided to finalize the PM<sub>2.5</sub> increments under the authority of section 166(a) of the Act. With respect to the potential creation of PM<sub>2.5</sub> increments under section 166(f) (as discussed in the 2007 NPRM at 72 FR 54120-54121), we have not reached any final conclusion whether that approach is authorized by statute, but believe that such an approach raises significant legal issues. Because the Agency is not relying on section 166(f) in this rulemaking, we do not address these issues in this preamble, although some additional discussion is included in the response to Comments document for this rule.

75 FR 64890 (Oct. 20, 2010).

<sup>17</sup> The “trigger date” for PM<sub>2.5</sub>, October 20, 2011, does not have any effect on this conclusion. The trigger date merely governs the earliest that the minor source baseline date may be set for a pollutant for which PSD increments have been established. The term is used in the definition of minor source baseline date, 40 CFR 52.21(b)(14)(i), which includes the trigger date for PM<sub>2.5</sub>, October 20, 2011, as well the trigger dates for PM<sub>10</sub> and SO<sub>2</sub>, August 7, 1977 and the trigger date for NO<sub>x</sub>, February 8, 1988.

“Minor source baseline date” means the earliest date after the trigger date on which a major stationary source or major modification subject to 40 CFR 52.21 or to regulations approved pursuant to 40 CFR 51.166 submits a complete application under the relevant regulations. ...

40 CFR 52.21(b)(14)(ii).

<sup>18</sup> The emissions of PM<sub>2.5</sub> during the baseline period selected by the Applicant, March 2007 through February 2009, were determined using data for heat input to these boilers that is available from USEPA on its Clean

increase in emissions of PM<sub>2.5</sub> from the proposed project is still not significant even if one does not consider the decreases in emissions from Boilers 1 through 4. Based on the PM<sub>2.5</sub> emissions that would have been allowed for this proposed project by the draft permit, 97.0 tpy, a revised netting analysis for PM<sub>2.5</sub> that only relies on the decrease in emissions from Boilers 5 and 6 would still show a net decrease in emissions of 9.0 tpy.<sup>19</sup> After considering the effect of the limit in the issued permit on the operation of the oxy-combustion boiler in air firing mode, the net decrease would become 28.8 tpy.<sup>20</sup>

To provide further assurance that the proposed project would not be significant for PM<sub>2.5</sub> even if Boilers 1 through 4 were not considered, the permitted PM<sub>2.5</sub> emissions of the auxiliary boiler have been lowered in the issued permit to reduce the PM<sub>2.5</sub> emissions of the proposed project.<sup>21</sup> For the auxiliary boiler, the application indicated PM<sub>10</sub> and PM<sub>2.5</sub> emissions of 16.6 and 4.9 tpy, respectively. However, the draft permit would have limited both PM<sub>10</sub> and PM<sub>2.5</sub> emissions to 16.6 tpy. In the issued permit, the PM<sub>2.5</sub> emissions of the auxiliary boiler are limited to 4.9 tpy, as reflected in the application, which lowers the permitted PM<sub>2.5</sub> emissions of the auxiliary boiler by 11.7 tpy. See Condition 2.2.6. With this change, the net decrease in PM<sub>2.5</sub> emissions of this project only considering the decrease in emissions from Boilers 5 and 6 would be 40.5 tpy.

23. An analysis similar to my analysis concerning creditability of decreases in emissions of PM<sub>2.5</sub> should also apply for decreases in emissions of PM, PM<sub>10</sub>, SO<sub>2</sub> and NO<sub>x</sub>. Neither the Applicant nor Illinois EPA claims that the minor source baseline date was established

---

Air Markets internet site. (This information was also provided by the Applicant in Attachment No. 9 in its February 2012 application submittal.)

Based on this data, the PM<sub>2.5</sub> emissions of Boiler 5 during this two-year period were 205.72 tons, for an annual emission decrease of 102.86 tpy.

$(25,715,444 \text{ mmBtu} \times 0.016 \text{ lb/mmBtu} \div 2000 \text{ lbs/ton} = 205.72 \text{ tpy}, 205.72 \text{ tpy} \div 2 = 102.86 \text{ tpy})$

The PM<sub>2.5</sub> emission of Boiler 6, which operated as a peaking unit, during these two years were only 1.99 tons.  $(99,654 \text{ mmBtu} \times 0.040 \text{ lb/mmBtu} \div 2000 \text{ lbs/ton} = 1.99 \text{ tpy}, 1.99 \text{ tpy} \div 2 = 0.99 \text{ tpy})$

Combined, the overall decrease in PM<sub>2.5</sub> emissions from the shutdown of Boilers 5 and 6 is 103.85 tpy.

<sup>19</sup> The draft permit would have allowed PM<sub>2.5</sub> emissions of 97.0 tpy from the project. The baseline emissions of the main cooling tower (- 3.0 tpy) and a contemporaneous increase from the existing emergency engine generator at the Meredosia Energy Center (+ 0.8 tpy), produce a combined net change of -2.2 tpy. Accordingly, absent consideration of the emissions decreases from the existing boilers, the project would result in a net emission increase for PM<sub>2.5</sub> of 94.8 tpy  $(97.0 \text{ tpy} - 2.2 \text{ tpy} = 94.8 \text{ tpy})$ . With the decrease in PM<sub>2.5</sub> emissions from Boilers 5 and 6, the net decrease in PM<sub>2.5</sub> emissions from this project would become -9.0 tpy.  $(94.8 \text{ tpy} - 103.8 \text{ tpy} = -9.0 \text{ tpy})$ .

<sup>20</sup> Limiting operation of the oxy-combustion boiler to at most 4,800 years in air-firing mode reduces its permitted PM<sub>2.5</sub> emissions by 19.8 tpy, from 64.5 tpy to 45.3 tpy. With the decrease in PM<sub>2.5</sub> emissions from Boilers 5 and 6, the net decrease in PM<sub>2.5</sub> emissions from this project would become -9.0 tpy.  $((94.8 \text{ tpy} - 19.8 \text{ tpy}) - 103.8 \text{ tpy} = -28.8 \text{ tpy})$

<sup>21</sup> For purposes of consumption of PSD increment for PM<sub>2.5</sub> in Morgan County, it is desirable that the decreases in PM<sub>2.5</sub> be significantly greater than the permitted increases in emissions from this proposed project at the Meredosia Energy Center after the baseline date for PM<sub>2.5</sub>. This will act to ensure that the overall effect of this project is to expand the available increments for PM<sub>2.5</sub>.

for PM, PM<sub>10</sub>, SO<sub>2</sub> or NO<sub>x</sub> in Morgan County before November 9, 2009 or January 1, 2012. I have no reason to believe that minor source baseline dates have ever been established for these pollutants in Morgan County. Thus, the decreases from the shutdown of Boilers 1 through 6 are not creditable for PM, PM<sub>10</sub>, SO<sub>2</sub> or NO<sub>x</sub>. Therefore, FutureGen 2.0 causes a significant net emission increase for these pollutants, as well as a significant emission increase, triggering PSD.

**As already discussed, decreases in emissions of particulate matter, SO<sub>2</sub> and NO<sub>x</sub> that occur at a major stationary source do not have to occur after the applicable minor source baseline date to be creditable for netting. This is because 40 CFR 52.21(b)(13)(ii) requires that such decreases be considered when determining the amounts of available increment. In addition, for PM<sub>10</sub> and NO<sub>x</sub>, the emissions decreases occurred after the applicable major source baseline dates. For SO<sub>2</sub>, the decreases in emissions occurred after both the applicable major source baseline date and the minor source baseline date, since the minor source baseline date for SO<sub>2</sub> was set for Morgan County in 1985.**

24. In calculating the net emissions, the Applicant and the Illinois EPA under-calculated the emission increases from new equipment. They did not consider CO<sub>2</sub> from the scrubbers, that is, the hydrated lime used in the circulating dry scrubber and the trona used in the direct contact cooling/polishing system (DCCPS). Both of these systems produce CO<sub>2</sub> as a byproduct of the reaction with SO<sub>2</sub>. However, this CO<sub>2</sub> was not considered.

**The limits for emissions of greenhouse gases (GHG) in the permit, which address emissions of CO<sub>2</sub>, reflect information in the application and are appropriate for assessing the increase and net increase in GHG emissions from this project for purposes of applicability of PSD. The permit includes appropriate monitoring requirements to verify compliance with the limits for the GHG emissions of this new facility. Most significantly, Condition 2.1.9-6 of the permit requires continuous emissions monitoring for the CO<sub>2</sub> emissions of the oxy-combustion boiler, which are projected to comprise over 99 percent of the GHG generated by this boiler.**

**This comment does not identify additional emissions of CO<sub>2</sub> from this new facility that would result in the net increase in the GHG emissions of the project being significant. For the oxy-combustion boiler, the circulating dry scrubber system, which is the primary control device for SO<sub>2</sub>, will not generate CO<sub>2</sub>. This is because the scrubbing agent is hydrated lime, not limestone. Only small amounts of CO<sub>2</sub> will be generated as a result of the control of SO<sub>2</sub> with trona in the DCCPS, which is the secondary control system for SO<sub>2</sub> emissions.<sup>22</sup> These emissions will not change the conclusion of the netting analysis for GHG emissions.**

---

<sup>22</sup> A conservative evaluation of the amount of CO<sub>2</sub> generated by the trona used in the DCCPS, disregarding any sequestration of this CO<sub>2</sub>, can be made using the emission data in the application. As described in Table 3-2 of the application (June 2013 submittal, p.8), the amount of SO<sub>2</sub> controlled by the DCCPS is only about 155 pounds/hr. The amount of CO<sub>2</sub> from controlling this SO<sub>2</sub> would be about 112 pounds/hr or 500 tons/yr.  
Amount of SO<sub>2</sub> entering DCCPS = 163.6 pounds/hr



25. The Applicant and the Illinois EPA did not consider fugitive emissions from the coal in the coal trucks. I do not mean the emissions that the coal trucks generate off the road but rather coal that is blown out of the back of the coal truck while the coal trucks are on-site.

**To the extent that any coal is lost from the coal trucks, it is appropriate to assume that it is deposited on the surface of roadways and contributes to the silt loading on the roadways. As such, “fugitive coal” is reasonably accounted for in both the application and in the permit. This comment does not provide a means by which the contribution of fugitive coal to emissions, if any, could be determined. In this regard, USEPA’s methodology for determination of the emissions from roadways does not address direct emissions from the loss of trucks as they travel on roadways.<sup>23</sup>**

26. The Applicant and the Illinois EPA underestimated fugitive emissions from the haul roads, as explained in the detailed evaluation of these emissions accompanying my comments. See Victoria R. Stamper, Evaluation of Particulate Matter Emissions from Haul Roads at the Proposed FutureGen 2.0 Project at the Meredosia Energy Center, Nov. 7, 2013 (Stamper Evaluation).

**The fugitive emissions from roadways have not been underestimated, as explained in the following five responses to each of the specific points made in the summary section of the evaluation of emissions accompanying these comments. Indeed, the Applicant revised its initial data for emissions from roadways, increasing emissions, to ensure that the data did not underestimate emissions. See, August 21, 2013, email from Gregg Hagerty, URS Corporation, to Robert Smet, Illinois EPA.<sup>24</sup>**

27. Fugitive emissions from the haul roads were underestimated because the permit does not identify which roads must be paved. The permit must clearly state which haul roads are to be paved and it must require the roads to be paved by the time the FutureGen project commences operation.

---

(SO<sub>2</sub> rate for air-firing rate mode adjusted for the load for oxy-combustion,  $73.6 \times 100/45 = 163.6$  lbs/hr)

Amount of SO<sub>2</sub> leaving DCCPS = 9.99 pounds/hr

(SO<sub>2</sub> rate for oxy-combustion mode with bypass of CO<sub>2</sub> pipeline)

Amount of SO<sub>2</sub> controlled by the DCCPS = 154.6 pounds/hr

(difference between SO<sub>2</sub> entering and leaving the DCCPS,  $163.6 - 9.9 = 154.6$  lbs/hr)

Amount of CO<sub>2</sub> generated = 112 pounds/hr

(stoichiometry of the reaction, with one-to-one exchange of SO<sub>2</sub> and CO<sub>2</sub> and the respective molecular weights of SO<sub>2</sub> and CO<sub>2</sub>,  $154 \times 46/64 = 112$  lbs/hr)

<sup>23</sup> In its *Compilation of Air Pollutant Emission Factors*, AP-42, USEPA observes that “At industrial sites, surface loading is replenished by spillage of material and trackout from unpaved roads and staging areas.” AP-42, 1/11, p 13.2.1-.1.

<sup>24</sup> In its original application submittal in February, 2012, the Applicant used a value for silt loading of 0.6 g/m<sup>2</sup> in its projections for roadway emissions. It subsequently submitted revised emission projections based on a value for silt loading of 2.0 g/m<sup>2</sup>.

**In response to this comment, an additional condition has been included in the issued permit, Condition 2.6.3(a). This condition specifies the principal roadways at the facility that must be paved, i.e., the haul roads for coal, lime, trona and ash and the roads that serve the parking lots for employees and visitors. This condition generally requires that paving must be completed no later than the date that the oxy-combustion boiler begins operation. However, the portions of roads in specific areas where they might be damaged by the continuing presence of construction equipment, such as cranes and tracked vehicles, must promptly be paved after that equipment is removed and paving would no longer be at risk of being damaged. This addresses the likelihood that heavy construction equipment will still be in place when the oxy-combustion boiler initially begins operation so that paving in certain areas would be damaged by that equipment.**

28. Fugitive emissions from the haul roads were underestimated because of the approach to gravel roads. The particulate matter emissions for the portions of the haul roads that will be gravel must be properly accounted for in the projection of potential particulate matter increases from the haul roads.

**As already discussed, the principal haul roads must be paved when the project begin operation. Regular deliveries and material removal will be conducted on these principal roadways. These principal roadways will also serve as the main traffic routes to employee and visitor parking areas.**

29. Fugitive emissions from the haul roads were underestimated because the permit does not use an appropriate silt loading. The silt loading assumed in the projection of particulate matter emissions from haul roads must be reflective of the silt loadings expected from an industrial facility, not a public road.

**In response to this comment, a condition has been included in the issued permit, requiring the source to measure silt loading on roadways at the facility (Condition 2.6.5-2). This will ensure that compliance with the emission limits is accurately determined.**

**The comment does not show that a different value for silt loading should be used to determine emissions from roadways. The silt loading used by the Applicant for its revised emission data, 2 grams per square meter, reflects the Applicant's judgment for the future silt loading on haul roads at this facility. The information provided with this comment does not justify the use of a higher value for the silt loading, 8.2 g/m<sup>2</sup>, and increasing the permitted particulate matter emissions from haul roads fourfold. The fact that higher values for silt loadings have been used for projects in other states does not justify use of a value for the proposed facility that is higher than the one that the Applicant has used. As acknowledged in the evaluation**

**submitted with this comment, historically, a wide range of silt loadings has been measured on roadways at different industrial facilities.<sup>25</sup>**

30. Fugitive emissions from the haul roads have been underestimated because the permit does not limit the maximum amount of coal that may be handled. In projecting potential particulate matter emissions, the maximum annual amount of coal and all other materials hauled must be projected. My calculations of roadway emissions show that, when the paved road emissions are corrected to more properly account for silt loading and the maximum amount of coal that could be transported on the paved haul roads, emissions are significantly higher than projected by Ameren.

**In response to this comment, the issued permit includes an additional condition limiting the amount of coal that is received by the facility by truck (Condition 2.6.3(d)). This makes this element in the application in the emissions calculations for roadways enforceable as both a legal and practical matter.<sup>26</sup> As already discussed, it is not appropriate to use a higher value for silt loading in these calculations.**

31. When emissions from gravel roads are taken into account, particulate matter emissions from roadways at the facility will be even higher than the projections of emissions in the Stamper Evaluation (PM<sub>2.5</sub> at 1.709 tpy, PM<sub>10</sub> at 6.961 tpy and PM at 34.804 tpy, as summarized in Table 3 of the Stamper Evaluation).

**As previously discussed, in response to another comment, an additional condition has been included in the issued permit, Condition 2.6.3(a), that requires the principal roadways at the facility to be paved, with such paving to generally be completed by the time that the oxy-combustion boiler initially begins operation. The principal roadways at the facility are the haul roads for coal, lime, trona and ash and the roads that serve the parking lots for employees and visitors.**

32. The application (June 2013 submittal, Executive Summary, p. 1, Figure ES-1) indicates that nitrogen is the only output from the air separation unit (ASU). The draft permit does not require any testing or monitoring to see if any NO<sub>x</sub>, ozone, CO<sub>2</sub>, N<sub>2</sub>O or methane is emitted from the ASU. All of these pollutants could be formed and emitted in the ASU because they are constituents of ambient air.

**Testing or monitoring of the ASU, as requested by this comment, is not warranted. The ASU extracts or separates oxygen from air for utilization in the oxy-combustion boiler. The air, less extracted oxygen, is then returned to the atmosphere. The ASU does not convert constituents of the incoming air into pollutants or add pollutants into the incoming air and therefore is not an emission unit.**

---

<sup>25</sup> In its *Compilation of Air Pollutant Emission Factors*, AP-42, USEPA reports mean values for silt loading on paved road roads at different types of industrial facilities. The lowest value of silt loading is for corn wet mills, 1.1 g/m<sup>2</sup>. The highest value is for copper smelting facilities, 292 g/m<sup>2</sup>. See AP-42, Table 13.2.1-3.

<sup>26</sup> Incidentally, as the calculations in the Stamper Evaluation were based on all coal being received at the facility by truck, rather than by a combination of truck and barge, those calculations overestimate emissions.

33. The draft permit, Table 1B, indicates that the net emission increase for sulfuric acid mist is 6.92 tons per year (tpy), which is just 0.08 tpy below the significant emission rate for sulfuric acid mist, 7.0 tpy. However, the Applicant left out emissions of sulfuric acid mist from the emergency diesel engine generator permitted on November 21, 2008, Construction Permit No. 08100029, in its calculations. (See Project Summary, p. 5.) The diesel fuel burned in this engine contains sulfur. Therefore, the Applicant must quantify the potential emissions of sulfuric acid mist from this engine, as permitted in 2008, to see if, accepting all other premises, which I don't, these emissions would make the facility a major project for emissions of sulfuric acid mist.

**Emissions of sulfuric acid mist from the existing emergency diesel generator would not make the facility a major project subject to PSD for emissions of sulfuric acid mist. The permitted SO<sub>2</sub> emissions of this generator are only 0.4 tons per year.<sup>27</sup> It is reasonable to assume that less than 2.0 percent of this SO<sub>2</sub> would be converted to SO<sub>3</sub> and actually emitted as sulfuric acid mist, for potential emissions of sulfuric acid mist of only 0.008 tpy.<sup>28</sup> Using this conservative assumption and also applying it auxiliary boiler and the new emergency engine at the sequestration facility, the net increase in the emissions of sulfuric acid mist from this project is still only 6.949 tpy, which is still less than 7.0 tpy and is not significant.<sup>29</sup>**

**While the permitted net increase in emissions of sulfuric acid mist for the proposed project is only slightly less than the significant emission rate for sulfuric acid mist, the netting analysis is very conservative. It assumes that the new facility will operate continuously without any outages for routine maintenance. This is not the case for any power plant and will certainly not be the case for this demonstration**

---

<sup>27</sup> Condition 5(a) of Construction Permit No. 08100029 limits the SO<sub>2</sub> emissions from this emergency engine to 0.4 lbs/hour and 0.4 tpy, which accommodates operation for 2,000 hours per year. As an engine that is regulated as an emergency engine under the National Emission Standards for Hazardous Air Pollutants (NESHAP) for Reciprocating Internal Combustion Engines, 40 CFR 63 Subpart ZZZZ, actual operation will be far less. The routine operation of this engine for purposes other than actual emergencies, e.g., readiness testing is limited to 100 hours per year by the NESHAP.

<sup>28</sup> According to USEPA's *Compilation of Air Pollutant Emission Factors*, AP-42, Section 3.3.3.5, "during the combustion process, essentially all the sulfur in the fuel is oxidized to SO<sub>2</sub>." Given essentially all the sulfur is oxidized to SO<sub>2</sub>, this leaves very little sulfur for conversion to sulfuric acid mist.

Consistent with USEPA's conclusion, a paper on the subject of emissions of sulfuric acid mist from the sulfur contained in fuel, emissions of sulfuric acid mist from firing of oil could be as much as 1.5 percent of the theoretical emissions of SO<sub>2</sub>. See Larry S. Monroe, Southern Company Generation and Energy Marketing, *An Updated Method for Estimating Total Sulfuric Acid Mist Emissions from Stationary Power Plants*, Revised March 2003.

<sup>29</sup> Given the passage of time, it is also likely that a reevaluation of the net change in emissions for the proposed facility would now show that the increases in emissions from the construction of the emergency diesel engine are no longer contemporaneous with the proposed project. It is now over five years since the permit for this engine was issued. For the increases from this engine to still be contemporaneous, the installation and initial startup of this engine will have to have occurred within five years of commencement of construction of the oxy-combustion facility.

**facility. The netting analysis is also based on a maximum value for the amount of time that this facility will operate in air-firing mode (i.e., is not operated in oxy-combustion mode). However, the purpose of this facility is to demonstrate both oxy-combustion technology and CO<sub>2</sub> sequestration technology. This inherently necessitates routine operation of the boiler in oxy-combustion mode.**

34. I do not accept all the Applicant's other premises in calculating the net emission increases. In the application (June 2013 submittal, p. 8, Table 3-2), for air-firing, the Applicant assumed for the oxy-combustion boiler that the emission rate for sulfuric acid mist is 2.97 lb/hr. However, the Applicant also assumed that this boiler would only operate in air-firing for 4800 hours per year. (Application, June 2013 submittal, p. 7) This assumption would not be enforceable as a practical matter. The draft permit would not limit air firing of the oxy-combustion boiler to 4800 hours per year.

Indeed, Condition 2.1.1 of the draft permit explains that "In the event of an upset in the operation of the boiler or an outage or upset in the CO<sub>2</sub> pipeline or the sequestration facility, the boiler can transition back into air firing mode." While this is true, the draft permit, as written, would also allow operation of the oxy-combustion boiler in air-firing mode all the time. Air-firing mode is much more economical and efficient. The source could choose to operate in air firing mode for a variety of reasons such as outage or upset in the boiler, including the air separation unit, the CO<sub>2</sub> pipeline or the sequestration site. See Project Summary, p. 2. In addition, because the permit would not require carbon capture, it could be simply that the source chooses to operate the plant as a "traditional" pulverized coal plant. The ASU is very expensive to operate so the source will have a tremendous financial incentive to operate the boiler in air firing as much as possible. It is also critical to keep in mind that the conditions in this permit are permanent. The source's current intent can certainly change in the decades to come. Operating at full load air firing, this would be the only pulverized coal unit permitted in the last decade or longer without selective catalytic reduction.

**In response to this comment, the issued permit explicitly limits the operation of the oxy-combustion boiler in air-firing mode to no more than 4,800 hours/year. In addition, the issued permit requires recordkeeping to verify compliance with this limit. (Conditions 2.1.6(a)(ii) and 2.1.10(b)(i).) This makes this element in the determination of the potential emissions of sulfuric acid mist from the facility enforceable as both a legal and practical matter. It should be recognized that this operational limit merely memorializes the intended operation of the boiler. As already discussed, this limit is conservative, i.e., being much greater than it is expected that this facility would ever actually operate in air-firing mode. This is because the initial purpose of this project is to evaluate and demonstrate oxy-combustion, which inherently necessitates operation of the boiler in oxy-combustion mode rather than air-firing mode.**

**The possible incentives to increase operation of the oxy-combustion boiler in air-firing mode in the future, as speculated upon by this comment, are not relevant**

since operation in this mode is explicitly limited in the issued permit. Moreover, as discussed elsewhere, it is expected that the GHG emissions of the proposed facility will be subject to a New Source Performance Standards (NSPS) that will eventually be adopted by USEPA that will require that the bulk of the CO<sub>2</sub> generated by this facility be sequestered.<sup>30</sup> This will preclude routine operation of the facility in air-firing mode since the oxy-combustion boiler must be in oxy-combustion mode, not air-firing mode, to sequester CO<sub>2</sub> emissions.

The inclusion of a limit in the issued permit on the operation of the oxy-combustion boiler in air-firing mode (i.e., other than in oxy-combustion mode) also acts to reduce the increases and net increases in emissions for the proposed facility for pollutants other than sulfuric acid mist, including NO<sub>x</sub>, SO<sub>2</sub>, PM and GHG. This is because the limits in the draft permit for these other pollutants reflected continuous operation in the mode of operation with highest emissions of each pollutant, most commonly air-firing.

35. As already mentioned, in the application (June 2013 submittal, p. 8, Table 3-2), for air-firing, the Applicant assumed that the sulfuric acid mist emission rate of the oxy-combustion boiler is 2.97 lb/hr. However, the Applicant also assumed that this boiler would only operate in air-firing at up to 45 percent load. (Application, June 2013 submittal, p. 7) This assumption would not be enforceable as a practical matter. The draft permit would not limit the load of the oxy-combustion boiler when air firing to 45 percent load.

**This comment does not identify a flaw in the data for emissions of sulfuric mist from the oxy-combustion boiler for “air firing.” This comment incorrectly assumes that the capacity of the oxy-combustion boiler in “air-firing mode” and “oxy-combustion mode” are identical and that the Applicant is relying on an “assumption” about the maximum level of operation during air firing. This is understandable given various statements made in the application that suggest that the emission data provided for this boiler in air-firing mode is based on operation of this boiler at 45 percent of its capacity. In fact, the output capacity of this boiler in air-firing mode will be significantly less than its capacity in oxy-combustion.<sup>31</sup> Above all else, the representations in the application about load during air-firing served to communicate this difference in the capacity of this boiler in air-firing and oxy-combustion modes. These statements do not show that the emission data for this**

---

<sup>30</sup> Pre-publication notice of proposed rulemaking, Standards of Performance for Greenhouse Gas Emissions from New Stationary Sources: Electric Utility Generating Units, signed by USEPA Administrator Gina McCarthy on September 20, 2013 [EPA-HQ-OAR-2013-0495; FRL-9839-4]. (As of December 12, 2013, USEPA’s website for this rulemaking (2013 Proposed Carbon Pollution Standard for New Power Plants) indicated that this notice had not yet been published in the Federal Register.)

<sup>31</sup> As a technical matter, this is because the oxy-combustion boiler will be designed for oxy-combustion. The boiler will physically be smaller than a comparable boiler designed for air firing. Accordingly, various systems in the boiler that affect its capacity in air-firing mode, e.g., the combustion air system and the exhaust gas handling system, will be designed as if for a smaller boiler with less capacity since larger systems could not be productively utilized.

**boiler submitted by the Applicant for emissions of sulfuric acid mist, or other pollutants, during air-firing was based simply on an assumption about the level of operation of this boiler during air-firing. The data in the application for the emissions of the oxy-combustion boiler during air-firing is appropriately used as the basis for the emission limits set by the permit.**

**To address the concern of this comment, a condition has been added in the issued permit, Condition 2.1.5(c), that limits the operation of the boiler to the load at which emission testing shows compliance with emissions limits for sulfuric acid mist, as well as fluorides. (For sulfuric acid mist, continuous emission monitoring is neither feasible nor warranted.<sup>32</sup>) This requires that this boiler be appropriately operated, on an ongoing basis, in a manner that is consistent with the manner in which this boiler was operated during emission testing in which compliance with the relevant limit was demonstrated. This approach ensures the practical enforceability of the emission limits for sulfuric acid mist. In addition to its use in permitting, this type of approach is used in a variety of air pollution control regulations, including: NSPS 40 CFR Part 60; National Emission Standards for Hazardous Air Pollutants ((NESHAP) 40 CFR Part 61 and 63; and Compliance Assurance Monitoring (CAM) 40 CFR Part 64. This approach is particularly apt in the circumstances of the proposed boiler. As a demonstration unit, notwithstanding its design and expected capacity in air-firing, there is a degree of uncertainty about the actual capacity of this boiler in air-firing. Air-firing is a secondary mode of operation of this boiler. The actual capacity of this boiler in air-firing, will only be able to be authoritatively and conclusively determined from the actual operation and performance of this boiler after it is constructed.**

36. Minor status to avoid PSD must be calculated based on the potential to emit of emission units, that is, on maximum output, 100 percent load, and continuous operation, 8,760 hours per year, unless there is a physical or legal restriction. See 40 CFR 52.21(b)(4). Thus, the sulfuric acid mist emission factor for air-firing should be 6.6 lbs/hr ( $2.97 \times 1.0/.45 = 6.6$ ) as there is no physical or legal restriction on operating the oxy-combustion boiler in air-firing mode above 45 percent load. There is also no enforceable limit on hours of operation firing air. Therefore, the potential to emit must be based on continuous air-firing which results in potential emissions of 28.9 tpy ( $6.6 \text{ lbs/hr} \times 8,760 \text{ hrs /yr} = 28.9 \text{ tpy}$ ). In the application (June 2013 submittal, p. 21, Table 3-9), the Applicant claims a contemporaneous emission decrease of 3.58 tpy of sulfuric acid mist. As explained in other comments, I dispute this claim. However, even if this decrease is accepted, the net increase in emissions of sulfuric acid mist is 25.3 tpy based on the increase from the oxy-combustion boiler alone. This is above the significant emission rate for sulfuric acid mist, 7.0 tpy, so FutureGen 2.0 is a major project subject to PSD for sulfuric acid mist.

---

<sup>32</sup> Techniques to continuously monitor emissions of sulfuric acid mist from coal fired boilers have not been developed. As a general matter, the magnitude of the expected emissions also does not warrant continuous monitoring, certainly not until the actual levels of emissions are determined by testing.

**As already discussed, the operation of the oxy-combustion boiler in air-firing mode will be physically and legally restricted. The load at which this boiler will be capable of operating in air-firing mode will be less than its maximum load in oxy-combustion mode. For both air-firing and oxy-combustion, the issued permit now limits the load at which the oxy-combustion boiler is operated to the load at which the relevant emission testing has shown compliance with the emission limits for sulfuric acid mist, as well as fluorides. The operation of the oxy-combustion boiler in air-firing mode is also limited to no more than 4,800 hours per year. Recordkeeping is required to verify compliance with these limits.**

37. The limits on emissions of sulfuric acid mist in Draft Permit Condition 2.1.6(b) would not change my comments. The Draft Permit lacks testing, monitoring and reporting for sulfuric acid mist emissions. It does not even have a one-time stack test, much less continuous monitoring that applies at all times including startup, shutdown or malfunction. Thus, those limits do not change the potential to emit sulfuric acid mist, that I calculated, 28.9 tpy. (See 40 CFR 52.21(b)(4).) These limits also do not change the significant net increase that I calculated, 25.3 tpy.

**The limits in the permit for sulfuric acid mist are enforceable as a practical matter. As mentioned in response to earlier comments, the issued permit requires that the emission testing required for the oxy-combustion boiler include measurements for emissions of sulfuric acid mist in both air-firing and oxy-combustion modes. (See Conditions 2.1.7(c)(i), (ii) and (iii).) The issued permit also requires specific recordkeeping related to emissions of sulfuric acid mist. (See new Condition 2.1.10(c)(i) and revised Condition 2.1.10(c)(v).) As related to emissions of sulfuric acid mist, proper operation of the oxy-combustion boiler on an ongoing basis, including periods of startup, shutdown and malfunction, is very effectively addressed by the continuous emissions monitoring that is required on this boiler for SO<sub>2</sub>. In fuel combustion devices, SO<sub>2</sub> is a precursor to emissions of sulfuric acid mist. As such, continuous emissions monitoring for SO<sub>2</sub> also serves to address emissions of sulfuric acid mist.**

38. The FutureGen 2.0 project would be a major project for emissions of sulfuric acid mist if either one of the unenforceable assumptions about air-firing of the oxy-combustion boiler were removed. For example, if one accepted the Applicant's emission rate of 2.97 lb/hr but calculated potential emissions based on continuous operation, the potential emissions of sulfuric acid mist would be 13 tpy. Less the disputed 3.58 tpy contemporaneous decrease, the net increase would still be 9.4 tpy which is above the significant emission rate for sulfuric acid mist. Similarly, if one accepts the 4800 hour per year limit but corrects the load to the allowable 100 percent while air firing, the potential emissions of sulfuric acid mist would be 15.84 tpy. Subtracting the disputed decrease of 3.58 tpy leaves a net increase of 12.26 tpy, which is also above the significant emission rate.



**As already discussed, the issued permit includes limits and other provisions to make enforceable the various elements of the determination of sulfuric acid mist emissions for the proposed project. Accordingly, this comment is no longer relevant.**

39. The Applicant did not actually provide the estimates of sulfuric acid mist emissions that it received from the designer of the oxy-combustion boiler, Babcock and Wilcox. (See application, June 2013 submittal, p. 8, fn 3.) However, to the extent these estimates are based on the nominal heat input of 1,605 mmBtu/hr (application, June 2013 submittal, p. 7), they would under-predict potential to emit. In the draft permit, the only enforceable limit on the heat input to this boiler would be 14.5 million mmBtu/yr. (Draft Condition 2.1.6(a).) That limit works out to an hourly maximum heat input of 1,655 mmBtu/hr maximum. ( $14,500,000 \text{ mmBtu/yr} \div 8760 \text{ hrs/yr} = 1,655.25 \text{ mmBtu/hr}$ ).

**In response to the discrepancy identified by this comment, the issued permit limits the annual heat in put to the oxy-combustion boiler to 14.1 million mmBtu, rather than 14.5 million mmBtu. This maintains consistency between the limit on the heat input to this boiler set by the permit and the representation of the nominal heat input to this boiler made in the application.**

40. In the original permit application (February 2012 submittal, Attachment No. 1), the Applicant stated that emissions of sulfuric acid mist of the oxy-combustion boiler would be 26 tpy when air firing at 45 percent load. Even at 4800 hours/year, that is 14.2 tpy, which would make the project major for emissions of sulfuric acid mist ( $26 \text{ tpy} \times 4800 \text{ hr/yr} / 8760 \text{ hr/yr} = 14.247 \text{ tpy}$ ). The Applicant has not explained why the revised application assumed less sulfuric acid mist emissions.

**The issued permit sets limits on emissions of sulfuric acid mist that reflect the current application submittal. When submitting a revised application, an applicant is not required to explain why the emission data in the revised application is different than the previous application. It is commonly recognized that the most recent submittal reflects a more thorough and refined evaluation of the emissions of a proposed project by an applicant than previous submittals. The later submittals may also reflect changes to a proposed project, as is the case for this project. The current application addresses a smaller oxy-combustion boiler, with less capacity, than the boiler addressed in the original application submitted in February 2012.**

41. The same basic problems that exist for emissions of sulfuric acid mist also apply to emissions of NO<sub>x</sub>. In the application (June 2013 submittal, p. 8, Table 3-2), the Applicant claimed the oxy-combustion boiler's NO<sub>x</sub> emissions in air-firing are 319 lb/hr based on a 45 percent load. However, at the permitted 100 percent load air firing, this would be 708.9 lbs/hr and 3104.9 tpy. ( $319 \text{ lbs/hr} \times 1.0 / .45 = 708.88 \text{ lb/hr}$ ,  $708.9 \text{ lbs/hr} \times 8760 \text{ hrs/yr} \div 2000 \text{ lbs/ton} = 3104.93 \text{ tpy}$ ). Even accepting the Applicant's disputed contemporaneous decrease of 2,813 tpy, the net increase for just the oxy-combustion boiler would be 291.9 tpy which is above the 40 ton per year significant emission rate for NO<sub>x</sub>. The annual limit in Draft Permit Condition 2.1.6(b) would not be enforceable as a

practical matter because the Draft Permit does not say that the CEMS has to operate all the time and that compliance with the annual limit has to be determined based on NOx emissions during every hour of operation.

**As concerns by this commenter with respect to emissions of sulfuric acid mist from this project have been addressed and responded to in the issued permit, the concerns about NOx emissions posed in this comment have also been addressed. Indeed, as the issued permit limits operation of the oxy-combustion boiler in air-firing mode to no more than 4,800 hours per year, the permitted annual NOx emissions from this boiler are now 1,529.9 tpy. The net change in NOx emissions, considering both the increase in emissions from this project and contemporaneous emissions increases and decreases from other projects, is now a decrease of 1,208.4 tpy.<sup>33</sup> As such, the proposed facility is clearly not subject to PSD for NOx.**

42. Emissions of fluorides are also above the significance emission rate. The Applicant claims a 0.63 lb/hr emission rate at 45 percent load. (Application, June 2103 submittal, Table 3-2, p. 8). This translates to 1.4 lbs/hr at the permitted 100 percent load. ( $0.63 \times 1/.45 = 1.4$ ). For a full year, 1.4 lbs/hr is equivalent to 6.1 tpy. ( $1.4 \times 8760 \div 2000 = 6.132$ ). This is above the significant emission rate for fluorides, 3.0 tpy. The Applicant did not claim that there was a contemporaneous decrease so the new boiler also triggers PSD for fluorides.

**The proposed project is not subject to PSD for fluorides. The provisions that have been added to the issued permit in response to comments concerning the limits in the draft permit for emission of sulfuric acid mist also serve to respond to this comment. In particular, the issued permit appropriately restricts the load at which the oxy-combustion boiler may be operated. It also limits operation of this boiler in air-firing mode to no more than 4,800 hours per year. Indeed, with this operational limit, the issued permit now limits annual emissions of fluorides to 1.6 tpy.<sup>34</sup> This is well below the significant emissions rate for fluorides, 3.0 tpy.**

**Moreover, as observed by this comment, netting was not conducted for fluorides, i.e., the decreases in fluoride emissions from the shutdown of the existing boilers were not considered by the Applicant when determining applicability of PSD. If decreases in fluoride emissions were considered, the net increase in fluoride emissions would be less than 1.6 tpy.**

---

<sup>33</sup> Based on operation in a mode other than oxy-combustion for no more than 4800 hours per year, the permitted NOx emissions of the oxy-combustion boiler are 1529.9 tpy. The net change in NOx emissions from the project, also considering the NOx emissions of the auxiliary boiler and the engine at the sequestration site, the contemporaneous increase from the existing emergency engine, and the contemporaneous decreases in emissions from existing boilers, is a net decrease of 1208.4 tpy. ( $1529.9 \text{ tpy} + 41.6 \text{ tpy} + 1.1 \text{ tpy} + 32 \text{ tpy} - 2813 \text{ tpy} = -1208.4 \text{ tpy}$ ).

<sup>34</sup> Based on operation in a mode other than oxy-combustion for no more than 4800 hours per year, the permitted fluoride emissions of the oxy-combustion boiler are now 1.6 tpy. ( $\{(0.63 \text{ lbs/hr} \times 4800 \text{ hrs/yr}) + (0.05 \text{ lbs/hr} \times 3960 \text{ hr/yr})\} \div 2000 \text{ lbs/ton} = 1.6 \text{ tpy}$ ).

43. The emission limit for fluorides in Draft Condition 2.1.6(b) would not change the conclusion of my analysis. The Draft Permit would not require any monitoring, testing or reporting for fluorides. Thus, the fluorides emission limit is not federally or practically enforceable and therefore does not impact the potential to emit calculation. See 40 CFR 52.21(b)(4).

**In response to this and other comments, upon further consideration, the issued permit requires initial testing of the oxy-combustion boiler in both oxy-combustion and air-firing modes for emissions of fluorides (See Conditions 2.1.7(c)(i), (ii) and (iii)). It is not unreasonable for this testing to be required. With the restriction in the issued permit on operation of this boiler in other than oxy-combustion mode, the permitted emissions of fluorides from this boiler, 1.6 tons per year, are still more than 50 percent of the significant emission rate for fluorides.**

**The issued permit also specifically requires recordkeeping for emissions of fluorides (See revised Condition 2.1.10(c)(iv).) Finally, as related to emissions of fluorides, proper operation of the oxy-combustion boiler on an ongoing basis is addressed by the continuous emissions monitoring that is required on this boiler for SO<sub>2</sub> and PM.**

44. The proposed project, FutureGen 2.0, triggers PSD for all pollutants but SO<sub>2</sub> and PM<sub>10</sub>. This is because the Applicant's netting analysis incorrectly used a baseline for calculating the emission decreases from the shutdown of Boilers 1 through 6 that is more than five years prior to commencing construction on the project. The Applicant used baselines for calculating the decreases from the boilers that ranged from March 2007 to February 2009. However, the Applicant indicates it intends to commence construction in July 2014. (See Draft Permit, Table 1B, Note A.) Thus, the baseline period can begin no earlier than August 2009. 40 CFR 52.21(b)(3)(i)(B) states baseline "actual emissions for calculating increases and decreases under this paragraph (b)(3)(i)(b) shall be determined as provided in paragraph (b)(48) of this section, except that paragraphs (b)(48)(i)(c) and (b)(48)(ii)(d) of this section shall not apply."

40 CFR 52.21(b)(48)(i) provides the baseline is the:

... average rate, in tons per year, at which the unit actually emitted the pollutant during any consecutive 24-month period selected by the owner or operator within the 5-year period immediately preceding when the **owner or operator begins actual construction of the project.**

40 CFR 52.21(b)(48)(emphasis added).

In the application (June 2013 submittal, p. 17), the Applicant claims, without any citation, that "US EPA has determined that the baseline period for contemporaneous emissions changes is based on the date the change occurred." This claim contradicts the plain language of 40 CFR 52.21(b)(48) which says the baseline for contemporaneous increases and decreases is "*any consecutive 24-month period selected by the owner or operator*

*within the 5-year period immediately preceding when the owner or operator begins actual construction of the project.”* The plain language controls. Thus, the baseline period can thus start no earlier than August 2009, which is five years prior to when the Applicant will begin actual construction. (See application, June 2013 submittal, Form 240-CAAPP for the oxy-combustion boiler, p. 1 of 11.)

**The emissions decreases from the shutdowns of Boilers 1 through 6 were appropriately determined in accordance with the PSD rules and USEPA guidance, including USEPA’s *New Source Review Workshop Manual*, draft 1990 (NSR Manual). This comment incorrectly assumes that there is only one project for purposes of netting so that the “baseline period” and the “contemporaneous period” are identical. However, the netting analysis for the proposed facility actually involves several projects.<sup>35</sup> The first project is the construction of the proposed facility. The shutdowns of the existing boilers are separate projects, which occurred when the various boilers were shutdown.<sup>36</sup> Thus the “baseline periods” or the periods that may be used to determine the emissions decreases from the shutdowns of Boilers 1 through 6 are different than the five year contemporaneous time period for netting.<sup>37</sup>**

**The contemporaneous period is determined from the timing of the proposed project for which netting is being conducted, in this case, the proposed modification of the Meredosia Energy Center, including the construction of an oxy-combustion boiler.<sup>38</sup> As provided by 40 CFR 52.21(b)(3)(ii), the contemporaneous period begins “...five years before the date that construction on the particular change commences.” All increases and decreases in emissions that occur in this contemporaneous period must be included in the determination of a net emission increase under 40 CFR 52.21(b)(3)(i).**

**On the other hand, the baseline period for decreases in emissions from other projects during the contemporaneous period for a proposed project is governed by the definition of baseline actual emissions, 40 CFR 52.21(b)(48), and the specific timing of those other projects. For changes in emissions at electrical steam generating units, 40 CFR 52.21(b)(48)(i) provides that the baseline period is any consecutive 24 month period in the 5 year period that precedes a project.<sup>39</sup> The**

---

<sup>35</sup> As defined by 40 CFR 52.21(b)(52), “*Project* means a physical change in, or change in the method of operation of, an existing major stationary source.”

<sup>36</sup> The installation of the existing diesel fired emergency generator is also a separate project.

<sup>37</sup> The appropriate emissions baseline is also distinct from the baseline period for determining the increase resulting from the modification of an existing emission unit.

<sup>38</sup> Using the terminology of the PSD rules, 40 CFR 52.21(3)(i)(a), the project that determines the contemporaneous time period is the “...particular physical change or change in the method of operation at a stationary source.” That is, it is a project for which netting is conducted to show that, notwithstanding the fact that the increase in emissions of a pollutant from such project is significant, the net increases in emissions of the pollutant, considering contemporaneous increases and decreases, is not significant.

<sup>39</sup> The baseline period for emission units other than electrical steam generating units is governed by 40 CFR 52.21(b)(48)(ii). The baseline period for these other types of units generally extends back 10-years, i.e., “...

provisions for the baseline period for a shutdown are no different than the provisions that apply for other projects that can result in decreases in emissions, such as the additional of control equipment or a process change that acts to lower emissions. The baseline period is the period preceding the particular change.<sup>40</sup> Accordingly, the baseline periods for the shutdowns of the existing boilers at the Meredosia Energy Center are set by the timing of these shutdowns. The baseline periods for these emissions decreases are not set by the timing of the proposed project, which only governs whether these decreases are contemporaneous.

This approach to netting under the PSD rules is confirmed by USEPA in the NSR Manual. In particular, the NSR Manual, pp. A.46 through A.50, describes a procedure for netting in which the determination of the contemporaneous period (Step 2) is a separate step from the determination of creditable emissions increases and decreases (Step 5). In addition, the baseline period for decreases in emissions need not be within the contemporaneous period that determines whether a decrease in emissions is contemporaneous. The NSR Manual, p. A.49 and Figure A.2, provides a specific example of netting in which the baseline period extends back beyond the contemporaneous time period, as is the case for the proposed FutureGen 2.0 project.<sup>41, 42</sup>

---

any consecutive 24 month period selected by the owner of operator within the 10-year period immediately preceding either the date the owner of operator begins actual construction of the project, or the date a complete application is received ...”

This provision for other units would have no purpose if the baseline period for netting were always constrained to the contemporaneous period, as claimed in this comment. For this provision to have meaningful effect, baseline periods and contemporaneous periods must necessarily be different.

<sup>40</sup> It would not be logical for the baseline period for these changes to be determined using a different date that would be governed by the date of a future project for which netting would be relied upon.

<sup>41</sup> USEPA prepared the NSR Manual prior to the revisions to the PSD rules that occurred as part of “New Source Review Reform,” including the adoption of the definition of baseline actual emissions, 40 CFR 52.21(b)(48). As such, the NSR Manual addresses an earlier version of the PSD rules in which the baseline period for netting was governed by the definition of actual emissions, 40 CFR 52.21(b)(21) and was generally the 24-month period prior to a change. The subsequent changes to the provisions of the PSD rules that govern the baseline period, with the adoption of 40 CFR 52.21(b)(48), affected how the baseline period is determined. These changes did not alter the fact, as confirmed by the cited example of netting in the NSR Manual, that the contemporaneous period and baseline periods are different and that a baseline period can extend back beyond the contemporaneous period.

<sup>42</sup> The fact that the baseline period and the contemporaneous period are different and that the baseline for a shutdown is determined by the timing of the shutdown is also confirmed by the USEPA guidance cited elsewhere by this commenter, Memorandum, “Proposed Netting for Modifications at Cyprus Northshore Mining Corporation, Silver Bay, Minnesota,” from John Calcagni, Director, Air Quality Management Division, USEPA, to David Kee, Director, Air and Radiation Division, USEPA Region V, August 11, 1992. In this memorandum, USEPA addresses whether certain emission decreases from past shutdowns at a source can be included in a netting analysis for a proposed project at the source.

USEPA first concludes that the emission decreases are not contemporaneous because the shutdown of the existing operations occurred outside of the contemporaneous period for the proposed project. USEPA continues with a discussion of the amount of the emission decreases that accompanied the shutdown of the existing operations, hypothetically assuming that the shutdowns were contemporaneous. For this purpose, USEPA considered the actual decreases in emissions from the shutdowns using a baseline determined from the assumed date that the shutdowns occurred, not from the timing of the proposed project and the

45. If the proper baseline is used for the proposed project, there are only creditable emissions decreases from the shutdown of Boilers 5 and 6 at the Meredosia Energy Center. Using the proper baseline, my analysis shows that the project will have significant net emission increases for NO<sub>x</sub>, PM<sub>2.5</sub>, and GHG. My calculations, as follow, rely on the project's potential emissions from the Draft Permit, Attachment 1, Table 1B, and on data from 2009 and 2010 that I obtained from USEPA's Clean Air Markets database. I excluded the emergency engine-generator permitted in 2008 as this was before the baseline period. I accepted the Applicant's calculations of potential emissions for the sake of this analysis even though I dispute these calculations in my other comments. For example, using the proper baseline, for emissions of NO<sub>x</sub>, the creditable decrease in emissions from the shutdown of the boilers at the Meredosia Energy Center is 882 tpy (average annual NO<sub>x</sub> emissions of Boilers 5 and 6 from 2009 and 2010). The net increase in emissions is 852 tpy (1,734.4 tpy - 882 tpy = 852 tpy). This net increase is far above the significant emission rate for NO<sub>x</sub>, 40 tpy. For PM<sub>2.5</sub>, using the Draft Permit's emission factor, use of the proper baseline results in a creditable decrease of 72 tpy (average annual PM<sub>2.5</sub> emissions of Boilers 5 and 6 calculated from operation in 2009 and 2010). The net increase in emissions is 25 tpy (97 tpy - 72 tpy = 25 tpy). This is above the significant emission rate for PM<sub>2.5</sub>, 10 tpy.<sup>43</sup>

**This comment does not show that the proposed project is subject to PSD for emissions for NO<sub>x</sub>, PM<sub>2.5</sub>, and GHG. As already discussed, a proper baseline period, consistent with 40 CFR 52.21(b)(48)(i), was used to determine the emission decreases from the shutdown of the existing boilers at the Meredosia Energy Center. The Applicant used the same 24-month period, March 2007 through February 2009, to determine the emission decreases from the shutdowns of Boilers 1 through 4 and Boilers 5 and 6. These 24-months are within the five year period preceding November 9, 2009, the date on which Boilers 1 through 4 were removed from service. These 24-months are also within the five year period preceding January 1, 2012, the date on which Boilers 5 and 6 were removed from service. The fact that a later 24-month period, as used by this commenter, yields smaller decreases in emissions from the shutdown of the existing boilers does not show that the Applicant improperly determined these emissions decreases.<sup>44</sup>**

---

contemporaneous period. As such, this guidance also confirms that the emissions decreases from the shutdown of a unit are to be determined based on the timing of the shutdown. (In the particular case that was being addressed, USEPA concluded that there were no creditable emission decreases from the shutdowns. This was because the existing operations had not operated and had no emissions during the relevant baseline period.)

<sup>43</sup> Similarly, the use of the proper baseline for CO<sub>2</sub> results in a creditable decrease of 935,848 tpy (average annual CO<sub>2</sub> emissions of Boilers 5 and 6 from 2009 and 2010). The net emissions increase is 586,655 tpy (1,522,503 tpy - 935,848 tpy = 586,655 tpy). This exceeds the 75,000 tpy significant emission rate for GHG to an extent that easily covers any potential creditable decrease from N<sub>2</sub>O and methane that may not have been included in the Applicant's calculation.

<sup>44</sup> Incidentally, with the reduction in permitted PM<sub>2.5</sub> emissions that have been made in the issued permit, which reduce the proposed project's PM<sub>2.5</sub> emissions to 66.1 tpy, the project would still not be significant for PM<sub>2.5</sub> even using the baseline period for Boilers 5 and 6 that this commenter used.

46. FutureGen 2.0 modeling shows that the proposed facility would violate the 1-hour SO<sub>2</sub> and NO<sub>2</sub> NAAQS.<sup>45</sup> Therefore, FutureGen 2.0 cannot net out of PSD. As explained by USEPA when discussing a modification proposed by Cyprus Northshore Mining Corporation,

The PSD rules restrict the creditability of some decreases in emissions for the purpose of emissions netting. In particular, one provision allows credit for a decrease only to the extent that it has approximately the same qualitative significance for public health and welfare as the increase from the proposed change [see 40 CFR 52.21(b)(3)(vi)(c)]. Where there is reason to believe that the reduction in ambient concentrations from the decrease will not be sufficient to prevent the proposed emissions increase from causing or contributing to a violation of any NAAQS or PSD increment, this provision requires an applicant to demonstrate that the proposed netting transaction (despite the absence of a significant net increase in emissions) will not cause or contribute to such a violation (see 54 FR 27298). Even if EPA found the proffered reductions otherwise quantitatively acceptable in this case--where the existing emissions units have not contributed to ambient concentrations for the last 10 years -- Cyprus would have to perform sufficient air quality modeling to demonstrate that the emissions increase from the new units would not violate the applicable NAAQS and PSD increments before the reductions could be credited (see 54 FR 27298).

Memorandum, Aug. 11, 1992, from John Calcagni, USEPA, to David Kee, USEPA, re: Proposed Netting for Modifications at Cyprus Northshore Mining Corporation, Silver Bay Minnesota, p. 6

The Applicant tries to excuse its violations of the NAAQS by claiming that because its contribution to the modeled NAAQS violations was below what it claims is the significant impact level, there is no problem. However, the U.S. Court of Appeals for the District of Columbia has recently rejected the use of significant impact levels (SIL). See *Sierra Club v. EPA*, 705 F.3d 458 (D.C. Cir. 2013).

Moreover, even before that decision, USEPA had determined that if a source causes any NAAQS violations, regardless of the level of contribution, the violation cannot be forgiven. The Applicant failed to do any such analysis.

**The position taken in this comment is contrary to sound, well-established practice for air quality analysis for proposed projects. While air quality analyses was not required for this project under the PSD rules, the Applicant conducted air quality modeling to confirm that the project would be appropriately designed so as to not cause or contribute to a violation of the relatively new one-hour NAAQS for SO<sub>2</sub>**

---

<sup>45</sup> Refer to Memorandum, August 24, 2013, Steven King, Illinois EPA, Air Quality Planning Section, Modeling Unit, to Bob Smet, New Source Review Unit, BOA Permits, *FutureGen2.0 Repowering Project at the Meredosia Energy Center* (King Memorandum), pp 6 -7.

and NO<sub>2</sub>.<sup>46</sup> These analyses demonstrate that the proposed facility will not cause or contribute to such violations without considering the compensating impacts of the contemporaneous decreases in emissions on air quality. Accordingly, it is not reasonable to expect that the net change in emissions, considering both increases and decreases in emissions, will cause or contribute to such violations. This comment certainly does not make this showing.

Moreover, the NSR Manual, pp. A.38 and A.39 (emphasis added) states:

Reductions must be of the same pollutant as the emissions increase from the proposed modification and must be qualitatively equivalent in their effects on public health and welfare to the effects attributable to the proposed increase. Current EPA policy is to assume that an emission decrease will have approximately the same qualitative significance for public health and welfare as that attributed to an increase, unless the reviewing agency has reason to believe that the reduction in ambient concentrations from the emissions decrease will not be sufficient to prevent the proposed emission increase from causing or contributing to a violation of any NAAQS or PSD increment. In such cases, the applicant must demonstrate that the proposed netting transaction will not cause or contribute to an air quality violation before the emissions reduction may be credited.

FutureGen 2.0 emission decreases are of the same pollutants (i.e., SO<sub>2</sub> and NO<sub>x</sub>) and from the same source category (i.e., coal-fired utility boiler). The permitted NO<sub>x</sub> emissions of the facility are less than 65 percent of past actual emissions. The SO<sub>2</sub> emissions will be less than 5 percent of the past actual emissions.

Finally, the 2013 decision of the District of Columbia Circuit Court cited by the comment does not address the use of SILs for SO<sub>2</sub> and NO<sub>2</sub> and is not applicable to this action. Even if it were applicable, the use of SO<sub>2</sub> and NO<sub>2</sub> SILs in the air quality analyses for the proposed facility was appropriate under the principles for use of SILs for PM<sub>2.5</sub> discussed in that decision and in subsequent USEPA guidance regarding that decision. “Circuit Court Decision on PM<sub>2.5</sub> Significant Impact Levels and Significant Monitoring Concentration, Questions and Answers,” USEPA, March 4, 2013. *Sierra Club v. EPA*, 705 F.3d 458, 465 (D.C. Cir. 2013). “We agree that the parts of the EPA’s rule codifying SILs in §51.165(b)(2) should remain.”

---

<sup>46</sup> The comment’s reference to the King Memorandum, a memorandum prepared by Steven King of the Illinois EPA, to support of its assertion that FutureGen 2.0 modeling shows that the proposed facility would violate the 1-hour SO<sub>2</sub> and NO<sub>2</sub> NAAQS is disingenuous. In fact, this memorandum states that for each 1-hour NO<sub>x</sub> NAAQS exceedance, “the model predicted results that demonstrated that FutureGen impacts coincident with the time and location of NAAQS exceedances, were below the significance level.” For the 1-hour SO<sub>2</sub> NAAQS, this memorandum states “the model results showed that Future Gen’s worst case contribution to a NAAQS exceedance was 13% of the SIL.” (King Memorandum, pp. 6-7).



47. The modeling determined there would be NAAQS violations even though the modeling was not conservative, that is, it under-predicted violations or ignored violations. For example, the application (Application June 2013 submittal, p. 29) indicates that the Applicant only modeled the oxy-combustion boiler air firing as “low power operations,” which I assume is limited to 45 percent load based on the assumptions about air-firing that the Applicant made in calculating potential emissions. However, as explained in my other comments, the draft permit would allow the oxy-combustion boiler to operate in air-firing mode outside of startups and shutdowns. Thus, NO<sub>2</sub> and SO<sub>2</sub> modeling must be done for air-firing at 100 percent load. This is particularly important because a mere four or eight hours of emissions per year can cause NAAQS violations of the 1-hour NAAQS.

**As already discussed, the permit establishes enforceable limits for the maximum emissions from different modes of operation of the oxy-combustion boiler. These limits apply independently of the operating load of the boiler. As such, contrary to the claim in this comment, the modeling used appropriate emissions rates for the different modes of operation of the oxy-combustion boiler. In particular, the modeling for air-firing was based on the maximum hourly emission rates that have been set in the permit for air-firing.**

48. The Applicant did not model the haul roads or new emergency diesel generator at the sequestration site and the existing emergency engine generator at the Meredosia Energy Center and coal pile fugitives for PM<sub>10</sub> and PM<sub>2.5</sub>. There are new haul roads and also there is much more activity on the haul roads as trona and lime were not used on site and the ash used to be disposed of on-site rather than being hauled off-site. (Application, June 2013 submittal, p 5). In modeling the haul roads, the Applicant must use worst day emissions which I provided in the Stamper Evaluation.

**This comment does not show the modeling should be conducted for the proposed project for PM<sub>10</sub> and PM<sub>2.5</sub>, much less that modeling should be conducted in the manner suggested by this comment. The net emissions increases from this proposed project for PM<sub>10</sub> and PM<sub>2.5</sub> are below the respective significant emission rates and, consequently, this project is not a major project subject to PSD for these pollutants. As such, air quality impact analyses for PM<sub>10</sub> and PM<sub>2.5</sub> are not required for the permitting of this proposed project. The circumstances of this proposed project for PM<sub>10</sub> and PM<sub>2.5</sub> do not otherwise justify such modeling. In this regard, the project, is a new, modern coal-fired power plant in a rural, attainment area, and should not be expected to pose a direct threat to air quality for either PM<sub>10</sub> or PM<sub>2.5</sub>.<sup>47</sup>**

---

<sup>47</sup> The circumstances of the proposed project for PM<sub>10</sub> and PM<sub>2.5</sub> are different than those for SO<sub>2</sub> and NO<sub>2</sub>, for which new NAAQS that apply on a shorter, 1-hour averaging time were recently adopted by USEPA. It is difficult to evaluate the impacts of a proposed power plant on these new NAAQS absent modeling. Accordingly, the Illinois EPA used its discretionary authority to require the Applicant to prepare air quality analyses for the proposed project to address these new one-hour NAAQS. These analyses confirmed that the proposed project would not cause or contribute to any NAAQS violations even without taking into account contemporaneous decreases in emissions and their ensuing positive impact on air quality.

49. There are numerous provisions of the draft permit that would not be federally enforceable or enforceable as a practical matter. For example, the PTE for lead was based on emission factors from USEPA's *Compilation of Air Pollutant Emission Factors*, AP42. VOM was based on vendor estimates. (Application, June 2013 submittal, p. 8, fns 8 and 4). The draft permit would not require any testing to confirm these emission factor estimates are not actually exceeded. Thus, the claim that the source is minor for these pollutants is not enforceable. In order to make these enforceable, the permit needs to require continuous emission monitoring systems (CEMS) or annual stack testing at various loads and all operating scenarios including air firing coupled with parametric monitoring.

**This comment does not show that emission testing of the oxy-combustion boiler for lead is needed to make the permit limits enforceable. The total permitted lead emissions from the project are only 0.154 tpy. This is well below the significant emission rate for lead, 0.6 tpy, without consideration of any decreases in lead emissions from the shutdown of the existing boilers. The oxy-combustion boiler will be the only significant source of lead emissions at the facility. As lead is a HAP, emissions of lead from this boiler are addressed by the NESHAP for Coal- and Oil-Fired Electric Utility Steam Generating Units, 40 CFR 63 Subpart UUUUU. The relevant requirements of this NESHAP that apply to this boiler will reasonably ensure compliance with the emission limits that are set by the permit for lead. In this regard, during the development of this NESHAP, USEPA found that filterable PM is appropriately used as a surrogate for non-mercury metal HAPs, including lead.<sup>48, 49</sup> That is, a NESHAP standard set in terms of filterable PM also serves to appropriately limit emissions of non-mercury metal HAPs to levels that are comparable to the alternative standards in the NESHAP for individual non-metal HAPs. For emissions of lead, this alternative standard is 0.02 lb/GWhr.<sup>50</sup> Based on this standard, the lead emissions of the oxy-combustion boiler should be expected to**

---

<sup>48</sup> For new coal-fired steam generating units, the NESHAP, 40 CFR 63 Subpart UUUUU, contains three alternative standards to address metal HAPs other than mercury: 1) A standard that is expressed in terms of filterable PM; 2) A standard for the total emissions of ten metal HAPs, including lead; and 3) Individual standards for ten metal HAPs, including mercury.

It is expected that most sources, including this source, will elect to comply with the standard for filterable PM.

<sup>49</sup> In this NESHAP, USEPA found it appropriate to set a standard in terms of filterable PM, with filterable PM serving as a surrogate for non-mercury metal HAPs. Among other things, for sources that elected to comply with such a standard, continuous particulate emission monitoring could be required as the means to demonstrate ongoing compliance with the standard. Continuous emission monitoring would not be possible if only standards for total and individual non-mercury metal HAPs were adopted.

<sup>50</sup> As explained by USEPA in the preamble to the adoption of 40 CFR 63 Subpart UUUUU,

Except for Hg, the best PM controls provide the best control of metal emissions. Emissions measurements of either filterable particulate, total particulate, individual metals, or total metals provide comparable indications that the best level of control is achieved. We can find no significant difference in the emissions that would be achieved by using any of these emissions measurements.

77 FR 9402, Feb. 16, 2012.

be no more than 0.0145 tpy.<sup>51</sup> This is a fraction of the annual limit that has been conservatively set by the permit for the lead emissions of lead from this boiler. Moreover, the permit, Condition 2.1.7(c), requires the source to conduct emission testing for the oxy-combustion boiler upon request from the Illinois EPA, as specified in such a request. This provides for emission testing for lead in the event that information arises that indicates that such testing is warranted for this boiler notwithstanding the requirements for PM emissions.

This comment also does not show that emission testing of the oxy-combustion boiler for VOM is needed to make the limits on VOM emissions enforceable. The total permitted VOM emissions from the project are only 12.0 tpy. This is well below the applicable significant emission rate for VOM, 40 tpy. The results of emission testing of coal-fired utility boilers for organic emissions indicate that the oxy-combustion boiler should readily comply with the limits that have been set by the permit for VOM emissions.<sup>52</sup> However, test data is not available for a coal-fired utility boiler with oxy-combustion technology. Because of the absence of such data, it is not unreasonable for initial testing for VOM emissions to be required. Accordingly, the issued permit (Condition 2.1.7(a)) also requires that the initial emission testing for the oxy-combustion boiler include measurements for VOM emissions. It is not appropriate for further testing requirements for VOM emissions to be established before this testing is conducted. This is because this testing may show that the VOM emissions of this boiler with oxy-combustion technology are similar to those of boilers using conventional combustion technology.<sup>53</sup>

50. For the oxy-combustion boiler, CH<sub>4</sub> and N<sub>2</sub>O PTE were from default emission factors from the 40 CFR Part 98, the Mandatory Greenhouse Gas Reporting Rule. (Application, June 2013 submittal, p. 8, fn 6). The permit needs adequate testing for these to confirm. The Draft Permit would only require one time testing. That is not enough.

**This comment does not show that the permit should require additional testing of the oxy-combustion boiler for emissions of CH<sub>4</sub> and N<sub>2</sub>O.<sup>54</sup> As observed by this comment, the initial emission testing required for the oxy-combustion boiler must**

<sup>51</sup>  $0.02 \text{ lb/GWhr} \times 0.165 \text{ GWhr} \times 8760 \text{ hrs/yr} \div 2,000 \text{ lbs/ton} = 0.0145 \text{ tpy}$ .

<sup>52</sup> In its development of 40 CFR 63 Subpart UUUUU, the USEPA concluded that regulation of organic HAPs with numerical standards under Section 112(d) of Clean Air Act was not practical. This was because most of the test data for emissions of organic HAPs and volatile organic compounds assembled by USEPA pursuant to its Information Collection Request for the development of this rule showed emissions that were below the detection levels of applicable test methods even with long durations for test runs. As a result, USEPA decided not to set numerical limits for emissions of organic HAPs. Instead, USEPA set work practice standards (i.e., requirements for periodic combustion tune-ups) under Section 112(h) of the Clean Air Act. *See* 77 FR 9304, 9369 (February 16, 2012).

<sup>53</sup> In this regard, the permit, as already discussed, requires the source to conduct emission testing for the oxy-combustion boiler upon request from the Illinois EPA, as specified in such a request. This provides for emission testing for VOM in the event that the initial testing for VOM emissions indicates that further testing for VOM emissions is warranted for this boiler during the period before a CAAPP permit is issued that addresses this new facility.

<sup>54</sup> Methane (CH<sub>4</sub>) and nitrous oxide (N<sub>2</sub>O) are compounds that are regulated as greenhouse gases (GHG).

include measurements for emissions of CH<sub>4</sub> and N<sub>2</sub>O. This will provide information that is needed to determine whether further testing for these pollutants should be required for this boiler and the timing and other aspects of any such further testing.<sup>55</sup> In this regard, Condition 2.1.7(c)(ii)(b) requires that, upon request by the Illinois EPA, the source must conduct additional emission testing for the oxy-combustion boiler for pollutants as specified by the Illinois EPA.

As a more general matter, the approach to the GHG emissions of the oxy-combustion boiler in the permit is consistent with the approach that has generally been taken by USEPA in its current rules dealing with quantification of GHG emissions from coal-fired boilers. USEPA generally requires continuous monitoring for emissions of CO<sub>2</sub>. Emissions of CH<sub>4</sub> and N<sub>2</sub>O may be determined using either unit-specific emission factors developed from emission testing or generic emission factors. As reflected by the provisions of 40 CFR 98, USEPA has found that this approach reasonably addresses the contribution of CH<sub>4</sub> and N<sub>2</sub>O to GHG emissions of coal-fired boilers, as CO<sub>2</sub> makes up most of the GHG emissions.

51. The permit must require commencement of construction by not later than August 2014 in order for the Applicant's claim of contemporaneous emission decreases, which I dispute, to be valid under the Applicant's own theory. This is because the last time Boilers 1 through 4 had emissions was August 2009.<sup>56</sup>

As requested by the comment, a condition has been added to the issued permit to maintain consistency with the netting analysis that was prepared for this proposed facility. New Condition 1.2(a) provides that the permit will expire if construction of this facility is not commenced by August 2014. This will act to explicitly require construction of this facility to commence by August 2014, as specifically requested by this comment, so that the emission decreases from the shutdown of Boilers 1 through 4 will be contemporaneous with this project.

52. NO<sub>x</sub> and SO<sub>2</sub> monitoring must apply all the time for netting to be valid including during startups, shutdowns and malfunctions. Alternative monitoring or NSPS monitoring is not sufficient as it does not require emission data from every hour of operation.

The continuous emission monitoring systems required by the permit must be operated "continuously," consistent with the provisions of the NSPS, 40 CFR Part 60, the NESHAP, 40 CFR Part 63, and the Acid Rain Program, 40 CFR Part 75, as applicable. The relevant provisions in these rules do not provide that continuous emission monitoring do not need to be operated during startup, shutdown and

---

<sup>55</sup> As addressed in other comments, the limit for the annual emissions of the oxy-combustion boiler is extraordinarily conservative. This is because it reflects calculations of potential GHG emissions from this boiler without any consideration for sequestration of CO<sub>2</sub>. However, demonstration of CO<sub>2</sub> sequestration technology is an essential aspect of the operation of proposed facility. As such, the permitted GHG emissions of this boiler are much greater than the actual emissions would ever be. These circumstances will not be altered by any contribution of CH<sub>4</sub> and N<sub>2</sub>O to the GHG emissions of the oxy-combustion boiler.

<sup>56</sup> See data for the Meredosia Energy Center from USEPA, on its Clean Air Markets Division's internet site.

**malfunction of emission units. These rules reasonably and appropriately address proper operation of monitoring systems. For example, 40 CFR 75.10(d), which applies for continuous monitoring of SO<sub>2</sub>, NO<sub>x</sub> and CO<sub>2</sub> emissions of the oxy-combustion boiler only provides that monitoring systems do not have to be operated during periods of calibration, quality assurance, or preventative maintenance, periods of repair, periods of backup of data and during recertification of monitoring equipment.**

**Incidentally, “proper continuous monitoring” is not needed for the reason given by this comment. Given the magnitude of emission decreases and the basis upon which permitted emissions of the proposed facility were determined, less rigorous emissions monitoring would be sufficient to ensure that this project is not a major project for emissions of NO<sub>x</sub> and SO<sub>2</sub>. Proper monitoring is required as it is required by rule to verify compliance with applicable emissions standards and other regulatory requirements that apply for emissions of NO<sub>x</sub> and SO<sub>2</sub>.**

53. The application (June 2013 submittal, p. 4 and p. 27, fn 13)) states that the auxiliary boiler will use ultra low sulfur diesel oil containing 15 ppm sulfur. However, Condition 2.2.3-1(a)(iii)(A) of the draft permit would only limit the sulfur content of the oil fired in this boiler to 5000 ppm. The permit needs to limit the sulfur content of this oil to 15 ppm, as well as require monitoring, recordkeeping and reporting to make this limit enforceable as a practical matter. This includes provisions to ensure that the source does not use diesel currently on site that is above 15 ppm sulfur or transmix diesel.

**The issued permit includes additional requirements in response to the concerns identified in this comment. The issued permit explicitly requires that the fuel fired in the auxiliary boiler be ultra-low sulfur diesel (maximum sulfur content of 15 ppm). (See Condition 2.2.5(b)(ii)). As a consequence, this boiler is prohibited from firing any diesel oil that may currently be held at the Meredosia Energy Center that is not ultra-low sulfur diesel fuel. Use of “transmix” or off-specification mixes of ultra-low sulfur diesel and other petroleum products, which would not qualify as ultra-low sulfur diesel fuel, is also prohibited.**

**The related compliance provisions in the permit for the auxiliary boiler have been enhanced to address this new requirement. The relevant conditions in the issued permit now generally address all requirements for the sulfur content of the fuel for this boiler, including the requirement that it be ultra-low sulfur diesel fuel, as well as the requirements of the NSPS for the sulfur content of this fuel. (See Condition 2.2.8-1 and 2.2.9(a)(i).)**

54. The application (June 2013 submittal, Attachment No. 11) claims that the oxy-combustion boiler will have a total HAP emission of no greater than 1.09 lb/hr at all times including startup, shutdown and malfunction. Therefore, the permit needs a total HAP emission limit of 1.09 lb/hr that applies at all times including startup, shutdown and malfunction. The permit should also include a HAPs CEM which monitors hydrogen chloride (HCL) and other HAPs at all times including during startup, shutdown, and

malfunction. This is critical because the uncontrolled emission factor in AP-42 for HCl is 1.2 lb/ton. This means that burning a mere 16,666 tons of coal in the oxy-combustion boiler uncontrolled would put the source over the 10 tons per year major source threshold for an individual HAP.

**This comment does not demonstrate that additional limits should be placed on the HAP emissions of the oxy-combustion boiler. The emissions of HAPs from this boiler are regulated by the National Emission Standards for Hazardous Air Pollutants (NESHAP) from Coal and Oil-Fired Electric Utility Steam Generating Units, 40 CFR 63 Subpart UUUUU. The various requirements of this rule that are applicable to this boiler will act to ensure that its annual emissions do not exceed the limits for emissions of HAPs set in Condition 2.1.6(b), 4.5 tpy for any individual HAP and 19.86 tpy for total HAPs. Given that emissions of HAPs are regulated by 40 CFR 63 Subpart UUUUU, it is not appropriate for the permit to set additional short-term limits for emissions of HAPs or to include additional compliance procedures related to HAPs beyond those in this NESHAP.**

**Additional permit requirements certainly are not justified because of the magnitude of “uncontrolled” emissions of HCl, as suggested by this comment. The control systems on the oxy-combustion boiler for SO<sub>2</sub> emissions will also control HCl emissions. Emissions will specifically be restricted by the NESHAP, which limits HCl emissions to 0.010 lb/MWh, either directly or through compliance with a limit for SO<sub>2</sub> of 1.0 lb/MWh. This will necessitate HCL emissions being controlled so that actual emissions are a fraction of uncontrolled HCl emissions, as would be determined using the emission factor in AP-42 cited by this comment.**

55. The application (June 2013 submittal, Attachment No. 2) assumes 95 percent control for two transfer points for the coal handling equipment: (1) Conveyor C to Chain Conveyor and, (2) Chain Conveyor to Coal Silos. Therefore the permit must have emission limits, testing and monitoring to ensure that these emission limits, that is, 0.85 lb/hr PM, 0.38 lb/hr PM<sub>10</sub> and 0.0425 lb/hr PM<sub>2.5</sub> for each of these transfer points, is not exceeded. In addition, the permit must require there be zero fugitive emissions from these transfer points and monitoring, testing and reporting to ensure compliance with the absolute restriction on fugitives from the transfer points.

**In response to this comment, changes have been made in the issued permit to enhance the practical enforceability of the emission limits for the new and modified coal handling operations. In particular, the issued permit now individually limits the emissions of PM and PM<sub>10</sub>/PM<sub>2.5</sub> from each of the coal handling operations, rather than limiting the combined emissions of these operations. The permit also sets limits for emissions of each operation expressed in pounds per ton of coal handled. These changes reasonably enhance practical enforceability of the emission limits for these operations. It will be simpler to review compliance of individual operations than to review compliance of the operations in aggregate. It also will be**

easier to review compliance with both short-term and annual emission limits than only an annual limit.

However, it is not appropriate for the permit to limit emissions in pounds per hour, as requested by this comment. This is because these operations will not run continuously but periodically to fill the bin that supplies coal to the boiler.<sup>57</sup> It also is not appropriate to prohibit any fugitive emissions from the subject operations, as requested by this comment. This is because the emission limits for the subject operations reflect emissions calculations in the Application that are predicated upon compliance with applicable control requirements of the NSPS, 40 CFR 60 Subpart Y, by the subject operations. This NSPS establishes limits for both “stack” emissions and “fugitive” emissions from coal handling operations. The opacity of fugitive emissions is limited to 10 percent by 40 CFR 60.254(b)(2). As such, it is not necessary for the permit to include the compliance provisions that are specifically requested by this comment.

Moreover, the permit does include compliance provisions that reasonably address the emissions limits that have been set by the permit. The permit generally relies on the applicable requirements of the NSPS to address the initial performance testing for the subject operations and monitoring of their ongoing operation (Condition 2.3.7). The permit also includes appropriate recordkeeping requirements, building on the testing and monitoring requirements of NSPS, to address compliance with the emission limits that have been set for the subject operations. In particular, the issued permit requires records for the maximum emissions rates of the subject operations, in pounds per ton of coal handled, with supporting documentation, to provide an authoritative basis for these emission rates that are used in the determination of compliance with emission limits (Condition 2.3.8(d)(i)). The permit also requires records of actual emissions to directly verify compliance with the applicable emission limits (Condition 2.3.8(d)(ii)).

56. The permit needs to limit the usage of coal by the oxy-combustion boiler to 744,600 tons per year. Many of the emission calculations are based on this assumption for maximum coal usage. The 14.5 million mmBtu/yr limit is important for other calculations but it is not sufficient for all calculations such as the coal transfer equipment and the haul roads. The permit must also include monitoring and reporting to ensure that the 744,600 tons per year of coal limit is enforceable as a practical matter.

**In response to this comment, a condition has been added in the issued permit limiting the amount of coal conveyed to the oxy-combustion boiler to 744,600 tons per year. (Condition 2.1.6(a)(ii).) In addition, the recordkeeping requirements for**

---

<sup>57</sup> It is also not necessary to set separate limits for the PM<sub>2.5</sub> emissions of the subject operations. Limits for PM<sub>10</sub>/PM<sub>2.5</sub> will simplify review of the determinations of compliance that are made by the source. Separate, lower emission limits for PM<sub>2.5</sub> emissions are not needed to ensure that the net increase in emissions of PM<sub>2.5</sub> from the proposed project is less than significant. Separate limits for PM<sub>2.5</sub> emissions also would not meaningfully affect the net change in emissions of PM<sub>2.5</sub> from this project.

**this boiler in the issued permit have been enhanced to address compliance with this additional operational limit. (Condition 2.1.10(b)(i).)**

57. The application (submittal June 2013, Attachments No. 3, 4 and 5) assumes PM emissions of 0.02 grains per dry standard cubic feet from the ash silo bin vent, lime transfer and trona transfer. The permit needs to have an emission limit of 0.02 grains per dry standard cubic feet for these emission units and monitoring, testing and reporting to ensure this limit is enforceable as a practical matter.

**In fact, the limit for the subject operations requested by this comment was included in the draft permit (Draft Condition 2.4.5(a) and is carried over in the issued permit (Condition 2.4.5(a)). The compliance provisions of the permit that address the subject operations and their emissions will generally serve to address compliance with this specific requirement for filters. However, in response to this comment, the recordkeeping for the subject operations has been enhanced. These records must now include a copy of the design specifications for these filters, including the particulate exhaust loading, in gr/dscf. This will provide further confirmation that the source has installed appropriate filters for these operations.**

58. The permit needs to limit the trona transfer flow to no more than 700 scfm, the lime flow to 1,500 scfm, and the ash flow to 2,500 scfm, consistent with information used in the emission calculations in the application (submittal June 2013, Attachments No. 3, 4 and 5). The permit needs testing, monitoring and reporting to ensure that these flow limits are not violated. In the alternative, these emission points could have PM CEMs.

**This comment does not show that it is appropriate to set limits for air flow capacity of the filters for the subject operations. Limits on air flow capacity would potentially interfere with effective control of particulate emissions as necessary to comply with the emission limits that have been set for these units. The emissions of the subject operations are adequately addressed by the individual limits that have now been set in the issued permit for each of the subject operations.**

**In addition, PM CEMS are not feasible for the subject operations, much less reasonable or appropriate. The subject operations only involve handling of bulk materials. The amounts of emissions are small. Proper operation of the subject operations and associated control measures and control devices can be reasonably be assured by appropriate work practices and recordkeeping, accompanied by emissions testing as necessary.**

59. As to the pugmill to trucks drop point, the application (submittal June 2013, Attachment No. 3) assumes the ash is wetted to 15 percent moisture. The permit must have an enforceable requirement that the ash be wetted to 15 percent moisture content and testing, monitoring and reporting for this requirement.



**In response to this comment, the issued permit now limits the moisture content of dry ash from the oxy-combustion boiler as loaded out from the facility, including the dry solids from the circulating dry scrubber, to at least 15 percent by weight. (Condition 2.4.5(b).) To ensure that the 15 percent moisture requirement is met for dry ash, the issued permit requires operational monitoring for the amount of water mixed with the ash. (Condition 2.4.8-1.) This makes this element of the emissions calculations in the application for the ash handling operations enforceable as both a legal and practical matter.**

60. The permit must limit the drift flow for the Unit 4 main cooling tower to 0.94 gallons per minute (gpm), for the ASU/CPU cooling tower to 0.23 gpm and the DCCPS cooling tower to 0.16 gpm. (See application, June 2013 submittal, Attachment No. 7). The permit must also limit the total dissolved solids (TDS) to 518 ppm for the Unit 4 main cooling tower, 2090 ppm for the ASU/CPU cooling tower and 7043 ppm for the DCCPS cooling tower. The permit must have testing, monitoring and reporting requirements to ensure these flow rate and TDS limits are not exceeded.

**In response to this comment, changes have been made in the issued permit to enhance the practical enforceability of the emission limits for the cooling towers. In particular, the issued permit now individually limits the emissions of PM and PM<sub>10</sub>/PM<sub>2.5</sub> from each of the cooling towers, rather than limiting the combined emissions of the cooling towers. These changes reasonably enhance the practical enforceability of the emission limits. Similar to the circumstance of the coal-handling operations, it will be simpler to review compliance of individual cooling towers than to review compliance of the group of three cooling towers, in aggregate. Circumstances have not been identified that would argue against establishment of emission limits for the individual cooling towers.**

**However, this comment does not show that it is appropriate to set limits for the cooling towers for water flow rates and TDS levels in the water. These operating parameters of the cooling towers, which are relevant to particulate emissions, can be readily determined through the operational monitoring and recordkeeping that is required by the issued permit. This is different than the circumstances of emission units for which actual emissions can only be authoritatively determined by emissions testing. Moreover, limits on water flow rates and TDS levels could inadvertently act to interfere with the proper operation of the DCCPS control system for the oxy-combustion boiler, which relies on cooling from the associated DCCPS cooling tower.<sup>58</sup> Such limits could potentially make compliance with the applicable requirements established for the wastewater discharges from the facility, which are from the blowdown from these cooling towers, more challenging or problematic. Such limits could also unnecessarily interfere with other aspects of the operation of the cooling towers, such as minimization of water consumption and**

---

<sup>58</sup> The DCCPS cooling tower is necessary for the functioning of the DCCPS which controls the temperature and moisture content of the flue gas stream for the oxy-combustion boiler that is then further processed by the Compression Purification Unit.

**adjustment of operation in response to seasonal variation in the quality of the incoming water. In such circumstances, it is reasonable to rely on limits for the emissions of these cooling towers with operational monitoring and recordkeeping by the source as needed to verify compliance with those limits.**

61. The limits for annual emissions of NO<sub>x</sub>, CO, PM, PM<sub>10</sub>, PM<sub>2.5</sub> and GHG for the auxiliary boiler are not enforceable as a practical matter. One time testing tells nothing about annual emissions. While Draft Permit Condition 2.2.9(g)(iii) would require the source to keep records of the emissions of these pollutants in tons/month and tons/year, there is no data for the source to keep these records.

**This comment does not show that the emission limits for the auxiliary boiler are not enforceable as a practical matter. As observed by this comment, initial emission testing is required by the construction permit (see Condition 2.2.7-2).<sup>59</sup> It is not reasonable for the specific timing of subsequent emission tests to be addressed in this permit. This is appropriately addressed as part of Periodic Monitoring required for this boiler in the Clean Air Act Operating Permit Program (CAAPP) permit for the new facility.<sup>60</sup> In this regard, add-on control equipment is not present on the auxiliary boiler. As part of the processing of the application for the CAAPP permit, key factors that are relevant to the timing of periodic emission testing, which are not known prior to operation, can be properly considered. In particular, at this time, the magnitude and nature of actual operation of this boiler, on both a short-term and annual basis, are unknown.<sup>61</sup> The results of actual emission testing of this boiler also are not available.<sup>62</sup>**

The construction permit includes provisions to reasonably address the day-to-day operation of the auxiliary boiler as this will determine the annual emissions of this boiler. Among other things, the permit addresses the requirements of the NESHAP for periodic tune-ups of this boiler (Condition 2.2.3-1(b)(ii)). It also addresses the requirement of the NSPS for ongoing monitoring of the opacity of the boiler (Condition 2.2.8-2). The permit requires recordkeeping for various aspects of the operation of this boiler, including: fuel usage (Condition 2.2.9(a)(ii)); startups, shutdown and malfunctions (Condition 2.2.9(d)); inspections, maintenance and repair (Condition 2.2.9(e)); and deviations (Condition 2.2.9(f)). The required

---

<sup>59</sup> In the issued permit, the initial emission testing for the auxiliary boiler must also include measurements for filterable and condensable particulate matter.

<sup>60</sup> The CAAPP is Illinois' operating permit program for sources of emissions pursuant to Title V of the Clean Air Act.

<sup>61</sup> The annual emission limits that have been set for the auxiliary boiler are very conservative. This boiler will support the startup of the oxy-combustion boiler and will normally not be in service. However, the permitted annual emissions of this boiler reflect continuous operation (8760 hours per year).

<sup>62</sup> The construction permit also addresses the possibility that additional emission testing of the auxiliary boiler is warranted in the time before a CAAPP permit is issued that addresses this boiler (e.g., the results of the initial emission testing for this boiler shows a small margin of compliance for a particular pollutant). Condition 2.2.7-2(a)(ii) provides that the source must conduct additional emission testing upon written request from the Illinois EPA.

**recordkeeping for emissions includes not only records for annual emissions, but also supporting information, including documentation for the various emission rates and factors that are used to determine annual emissions (Condition 2.2.9(g)(i)) and records of any other operating data that the source uses in determining its annual emissions (Condition 2.2.9(g)(ii)). Additional requirements to address the ongoing operation of this boiler may be included in the CAAPP permit for this new facility considering actual operation of this boiler.**

62. For the auxiliary boiler, the initial test for NO<sub>x</sub> and CO would only be required to be conducted within one year of startup. See Draft Permit Condition 2.2.7-2(a)(i). There is no reason to allow a year of operations to go by before determining initial compliance.

**The required timing for the initial emission testing of the auxiliary boiler is appropriate. This boiler will support the startup of the oxy-combustion boiler. Because the auxiliary boiler will not operate routinely, the scheduling of the emission testing for this boiler will be more challenging than for a unit that operates routinely. Accordingly, the permit provides that the initial emission testing required of this boiler must be conducted within one year of initial startup. This is reasonable to address the challenges that will be faced in the scheduling of this testing. This will potentially also enable this testing to be conducted when this boiler would normally be operated, rather than necessitating that it be operated only for the purpose of conducting testing.**

63. The Illinois EPA should include terms in this construction permit that require carbon capture. The Illinois EPA's authority and discretion in establishing permit terms and conditions is addressed by 35 IAC 201.156 ("The Agency may impose such conditions in a construction permit as may be necessary to accomplish the purposes of the Act, and as are not inconsistent with the regulations promulgated by the Board thereunder.").

**As previously discussed, this project is being developed to demonstrate full-scale oxy-combustion and carbon capture and sequestration (CCS) technologies for a coal-fired electrical generating unit. The development of these technologies is being pursued to reduce the CO<sub>2</sub> emissions of electric power plants, thereby mitigating their contribution to global warming and climate change.**

**The initial phase of operation of the facility would be specifically designed to evaluate the performance and capabilities of these technologies as installed at this plant. During this time, data would be gathered to facilitate subsequent large-scale commercial projects that rely on these technologies. While the Environmental Protection Act (Act) gives the Illinois EPA authority to establish construction permit terms that are necessary to accomplish the purposes of the Act, this comment does not show how a condition imposing requirements related to CCS is necessary to accomplish the purposes of the Act. Indeed, the project is by its basic nature consistent with the Act. That is, successful implementation of the project will facilitate use of technologies that can reduce CO<sub>2</sub> emissions from power plants and,**

**potentially, other large sources, with accompanying benefits for the environment due to the resulting reductions in CO<sub>2</sub> emissions.**

64. During the public hearing on the draft permit, the Applicant suggested that the definition of a clean coal facility in the Illinois Power Agency Act (Public Act 95-0481) may somehow preclude inclusion of carbon capture requirements in this construction permit. However, the Illinois Power Agency Act does not include any such limitation. The purpose of the Illinois Power Agency Act is to create an independent state agency, the Illinois Power Agency (IPA), to develop and administer electricity procurement plans for investor-owned electric utilities supplying over 100,000 Illinois customers. These plans must include the procurement of cost-effective renewable energy resources. The law also states that “the goal of the State [is] that by January 1, 2025, 25 percent of the electricity used in the State shall be generated by cost-effective clean coal facilities.” The Illinois Commerce Commission (ICC) has stated that the law then “set[s] forth a framework for evaluation and approval of certain clean coal sourcing agreements,” and “provides that the IPA and the ICC may approve such sourcing agreements, as long as they do not exceed cost-based benchmarks.” Re FutureGen Industrial Alliance, Inc., 13-0034, June 26, 2013 (Ill.C.C.).

“Clean coal” facilities are defined in the Illinois Power Agency Act. In relevant part, this law defines a “clean coal facility” as “an electric generating facility that uses primarily coal as a feedstock and that captures and sequesters carbon dioxide emissions at ... at least 70 percent of the total carbon dioxide emissions that the facility would otherwise emit if, at the time construction commences, the facility is scheduled to commence operation during 2016 or 2017...” The definition also limits emissions from such facilities to the “allowable emission rates for sulfur dioxide, nitrogen oxides, carbon monoxide, particulates and mercury for a natural gas-fired combined-cycle facility the same size as and in the same location as the clean coal facility at the time the clean coal facility obtains an approved air permit.” 20 ILCS 3855/1-10.

The law does not discuss requirements for “clean coal” construction permits, nor does it limit Illinois EPA’s authority with respect to issuing a robust permit in accordance with the purposes of Illinois’ Environmental Protection Act. Indeed, there is nothing in the Illinois Power Agency Act suggesting that carbon capture should not also be included in the construction permit. Whether the restrictions included in the Illinois Power Agency Act’s definition of a “clean coal facility” are included in any financing, cooperation, or purchasing agreements that the Applicant has entered into should not insulate the air permit from including similar restrictions.

The hearing officer made clear that this permit is governed by Illinois’ Environmental Protection Act rather than the Illinois Power Agency Act. At the hearing, he explained: “And I can tell you that our authority to issue permits is not based on the act that you stated, it is based on the Environmental Protection Act.” Public Hearing Transcript at 32:9-18.

**The Illinois EPA agrees that nothing in the definition of “clean coal facility” as provided by the Illinois Power Agency Act, 20 ILCS 3855, precludes the Illinois EPA from including carbon capture requirements in this construction permit. However, by the same token, nothing in the Illinois Power Agency Act mandates the inclusion of such requirements in this permit. Rather, the Illinois EPA is acting under different authority as provided by the Illinois’ Environmental Protection Act, 415 ILCS 5. In particular, the Illinois EPA is guided by Section 39(a) of the Environmental Protection Act, which provides that a permit is to be issued by the Illinois EPA upon proof that a facility will be consistent with the Environmental Protection Act and regulations thereunder. Given the applicant has submitted such proof, the Illinois EPA has taken action to issue the current construction permit.**

65. Illinois law does not excuse the Illinois EPA from its responsibility to issue a construction permit for this proposed facility that is compliant with the Clean Air Act.

**This is correct. The permit that has been issued for the proposed facility is consistent with the requirements of both state law, i.e., the Environmental Protection Act, and federal law, i.e., the Clean Air Act.**

66. New electric utility generating units (EGU) will be subject to the USEPA’s proposed NSPS for emissions of carbon dioxide (CO<sub>2</sub>), Standards of Performance for Greenhouse Gas Emissions from New Stationary Sources: Electric Utility Generating Units, 40 CFR 60 Subpart TTTT. According to the pre-publication version of USEPA’s proposed rulemaking, this NSPS “will apply to both a new, greenfield EGU facility or an existing facility that adds EGU capacity by adding a new EGU that is an affected facility under this NSPS.” USEPA, Preliminary Version of Notice of Proposed Rule, Standards of Performance for Greenhouse Gas Emissions from New Stationary Sources: Electric Utility Generating Units, [EPA-HQ-OAR-2013-0495; RL-9839-4], at 310 (September 20, 2013).

This proposed NSPS will soon be formally proposed by USEPA, with publication of a notice of proposed rulemaking in the Federal Register well before construction of the proposed oxy-combustion boiler is commenced. Accordingly, the requirements of this NSPS will apply to the proposed facility.<sup>63</sup> This is because the emission limits in the proposed rule will apply from the date of the proposal once the rule is finalized. Clean Air Act, 42 U.S.C. §§ 7411(a)(2). As a major source of CO<sub>2</sub>, as shown above, FutureGen 2.0 will be required to comply with the best available control technology (BACT) for CO<sub>2</sub>. The proposed rule establishes limits which will form the “floor” with this requirement. As such, the Illinois EPA should use its discretionary authority to include the proposed rule’s CO<sub>2</sub> limits in the permit.

---

<sup>63</sup> The Illinois EPA indirectly acknowledges this fact in the Project Summary that accompanied the draft permit. The Project Summary states that the requirements of USEPA’s NSPS for Greenhouse gas Emissions of Electric Utility Generating Units are not included in the draft permit “because USEPA has not completed this rulemaking.” Project Summary, p. 6, fn. 12. The Illinois EPA goes on to state that “the plant would be designed to sequester CO<sub>2</sub>, as the USEPA proposed for new coal-fired generating units.”

**As generally observed by this comment, the proposed facility will in all likelihood be subject to requirements under USEPA's NSPS for emissions of GHG from EGUs, 40 CFR Part 60 Subpart TTTT, which will address emissions of CO<sub>2</sub> from new EGUs once this NSPS is adopted by USEPA. This is because construction on the proposed facility will not commence prior to the publication of the proposed NSPS standard in the Federal Register, which is expected to occur in the near future.<sup>64</sup>**

**What this comment overlooks, is that the proposed facility will be subject to the requirements of the final NSPS rule as actually adopted by USEPA, after consideration of public comments on the proposed rule and resolution of any legal challenges that may lead to a stay of the rule adopted by USEPA. The proposed facility will not be subject to the requirements of the proposed rule to the extent that the requirements of the final rule differ from the proposed requirements. At present, the actual requirements that the proposed facility will be subject to pursuant to this new NSPS are uncertain. It would be improper in the construction permit to assume that these requirements will be identical to those of the proposed NSPS.<sup>65</sup> Moreover, based on the text of the planned Federal Register Notice, this new NSPS would be based on sequestration of CO<sub>2</sub> from new coal-fired electric generating units. As the proposed facility would be developed to sequester CO<sub>2</sub>, it should meet the standard that USEPA ultimately adopts for CO<sub>2</sub> emissions, when this standard becomes applicable.**

67. The application incorrectly identifies the NO<sub>x</sub> limit that will apply to proposed oxy-combustion boiler under the NSPS for Electric Utility Steam Generating Units, 40 CFR 60 Subpart Da. The application (June 2013 Submittal, page 23) indicates that this boiler will have to comply with a NO<sub>x</sub> emission limit of 0.07 lb/MWh (gross) or 0.76 lb/MWh (net), 30 day rolling average, pursuant to 40 CFR 60.44Da(f)(1). However, 40 CFR 60.44Da(f) only applies to certain integrated gasification combined cycle (IGCC) units and the oxy-combustion boiler is not an IGCC unit.

**In fact, the numerical emission limits that are relevant for the new oxy-combustion boiler for NO<sub>x</sub> pursuant to the NSPS, 40 CFR 60 Subpart Da, are correctly identified in the application. However, as observed by this comment, the application incorrectly referred to 40 CFR 60.44Da(f)(1) as the regulatory basis for these limits. The application should have referred to 40 CFR 60.44Da(g)(1). This discrepancy**

---

<sup>64</sup> Pursuant to Section 111(b)(1)(B) of the Clean Air Act, when USEPA proposes NSPS regulations for a category of source, it must complete adoption of such rules within one year after the date that the proposed regulations are published in the Federal Register.

<sup>65</sup> The history of USEPA's proposed NSPS for GHG emissions of new EGUs illustrates another reason why the provisions of the NSPS that USEPA has now proposed should not be included in the construction permit. The issuance of a proposed rule by USEPA does not mean that a rule will even be adopted pursuant to that proposal. In this regard, the current proposal is USEPA's second proposed rule. The previous proposal was published in the Federal Register on April 13, 2012. Concurrent with issuing its new proposal, USEPA plans to formally withdraw the earlier proposed rule. That proposal did not proceed to timely completion, in part, due to the number of public comments that were submitted on the proposal.

was addressed in the draft permit, which correctly cites 40 CFR 60.44Da(g). (See Condition 2.1.3-1(a).)

**Moreover, as observed elsewhere by this commenter, the NSPS regulations are “self-executing.” As such, even if this error in the application had not been identified and there were an error in the construction permit with respect to the applicable provisions of the NSPS, the oxy-combustion boiler would still be subject to the actual standards and other requirements that are applicable under the NSPS.**

68. 40 CFR 60.44Da(g)(1) sets two standards that will apply to the oxy-combustion boiler for emissions of NO<sub>x</sub>. As provided below, one standard is expressed in terms of the gross energy output of the unit and the other expressed in terms of the net energy output of the unit.<sup>66</sup> Condition 2.1.3-1(a)(ii)(A) of the draft permit only includes the NSPS standard for NO<sub>x</sub> that is expressed in terms of gross energy output. The permit must require compliance with both standards. The permit must also include monitoring and reporting of net electricity production.

(1) For an affected facility which commenced construction or reconstruction, any gases that contain NO<sub>x</sub> in excess of either:

- (i) 88 ng/J (0.70 lb/MWh) gross energy output; or
- (ii) 95 ng/J (0.76 lb/MWh) net energy output.

40 CFR 60.44Da(g)(1)[2013] (emphasis added)

**This comment does not show that the proposed facility must meet both numerical limits under the NSPS for NO<sub>x</sub>. Indeed, this comment is not accompanied by any explanation or factual support for this position other than the text of the relevant provision, itself. Such support would be needed for the permit to reflect the position taken in this comment. This is because the actual wording of the relevant provision and other provisions of the NSPS indicate that these are alternative standards and a subject unit need only comply with one of them, not both. This is confirmed by a review of the adoption of this standard, including explicit statements by USEPA.**

**With respect to the wording of the provision, 40 CFR 60.44Da(g)(1) does not state that both limits must be met. It provides that either one limit or the other limit must be met. The use of the words “either” and “or” to link the two numerical**

---

<sup>66</sup> In its entirety, 40 CFR 60.44Da(g) [2013] provides that: “Except as provided in paragraphs (h) of this section and 40 CFR 60.45Da, on and after the date on which the initial performance test is completed or required to be completed under 60.8, whichever date comes first, no owner or operator of an affected facility that commenced construction, reconstruction, or modification after May 3, 2011, shall cause to be discharged into the atmosphere from that affected facility any gases that contain NO<sub>x</sub> (expressed as NO<sub>2</sub>) in excess of the applicable emissions limit specified in paragraphs (g)(1) through (3) of this section.

(1) For an affected facility which commenced construction or reconstruction, any gases that contain NO<sub>x</sub> in excess of either: (i) 88 ng/J (0.70 lb/MWh) gross energy output; or (ii) 95 ng/J (0.76 lb/MWh) net energy output.”

limits means that a subject unit need only comply with one of the limits, not both. This is confirmed by the relevant language of 40 CFR 60.48Da(d), the related provision that addresses the procedures by which compliance with the NO<sub>x</sub> emission standard is to be shown. For subject units like the proposed oxy-combustion boiler, for which construction has not yet commenced, it provides for compliance to be shown with the applicable NO<sub>x</sub> limit with which a source has elected to comply.

...For affected facilities for which construction, modification, or reconstruction commenced after May 3, 2011, compliance with applicable 30-boiler operating day rolling average SO<sub>2</sub> and NO<sub>x</sub> emissions limits is determined by dividing the sum of the SO<sub>2</sub> and NO<sub>x</sub> emissions for the 30 successive boiler operating days by the sum of the gross energy output or net energy output, as applicable, for the 30 successive boiler operating days.

40 CFR 60.48Da(d) [2013] (emphasis added)

The fact that these limits are alternatives is also demonstrated by a review of the history of provision. When 40 CFR 60.44Da(g)(1) was proposed by USEPA, it only included a single NO<sub>x</sub> limit, expressed in terms of gross energy output. USEPA solicited comments on whether a limit in terms of net energy output should be adopted. (76 FR 24976, May 3, 2011). In the final rule, USEPA also included a NO<sub>x</sub> limit in terms of net energy output. However, USEPA did not reopen the rulemaking for comment on this second limit. (77 FR 9304, Feb. 16, 2012). Accordingly, the NO<sub>x</sub> limit in 40 CFR 60.44Da(g)(1) that is in terms of net energy cannot be a mandatory limit. It must be an additional, “alternative limit” that would potentially be appropriate for certain subject units with an effect that is identical or less stringent than the NO<sub>x</sub> limit in terms of gross energy output that underwent public comment. In fact, this is what USEPA stated in its written response to public comments concerning the adoption of limits in terms of net energy for NO<sub>x</sub>, as well as SO<sub>2</sub> and PM, when adopting 40 CFR 60.44Da(g).

Due to the lack of net output-based emission rates for multiple types of EGUs with various control configurations over a range of operating conditions, the final rule allows, but does not require, the use of a net-output based standard as an alternative to the gross-output based standard.

USEPA, OAQPS, Response to Public Comments on Rule Amendment Proposed May 3, 2011, December 2011,<sup>67</sup> p 4.

---

<sup>67</sup> *Standards of Performance for Fossil Fuel-Fired Steam Generating Units for Which Construction Is Commenced after August 17, 1971 (40 CFR 60, Subpart D), Standards of Performance for Electric Utility Steam Generating Units for Which Construction Is Commenced after September 18, 1978 (40 CFR 60 Subpart Da), et al., Response to Public Comments on Rule Amendments Proposed May 3, 2011 (73 FR 33642), USEPA, December 2011.*



**Accordingly, the permit properly addresses only the limit for NO<sub>x</sub> in terms of gross energy output, which is the limit with which the source indicates it will comply. As such, it is not necessary for the permit to require monitoring and recordkeeping for net energy output.<sup>68</sup>**

69. Similarly, for the alternative standards of the NSPS for combined emissions of NO<sub>x</sub> and CO, Condition 2.1.3-1(a)(ii)(B) must include both the gross and net energy output standards in 40 CFR 60.45Da(b)(1)<sup>69</sup> and clearly provide that the oxy-combustion generating units has to comply with both standards.

**For the reasons already discussed above, this comment does not demonstrate that the NSPS limits for combined NO<sub>x</sub> and CO expressed in terms of gross energy output and net energy output must both be met.<sup>70</sup> As such, the permit properly addresses only the limit in terms of gross energy output, which is the limit with which the source indicates it will comply.**

70. Similarly, 40 CFR 60.44Da(g)(1)<sup>71</sup> sets three standards that will apply to the oxy-combustion boiler for its SO<sub>2</sub> emissions, one standard expressed in terms of its gross energy output, one expressed in terms of its net energy output, and one in terms of the reduction in SO<sub>2</sub> emissions provided by the SO<sub>2</sub> emission control system. Condition 2.1.3-1(a)(i) of the draft permit only includes the NSPS standard for SO<sub>2</sub> that is expressed

---

<sup>68</sup> **As the oxy-combustion boiler would be complying with the NSPS limit for NO<sub>x</sub> emissions in terms of gross energy output, the source will have to fulfill relevant monitoring and recordkeeping requirements of NSPS related to gross energy output.**

<sup>69</sup> 40 CFR 60.45Da(b) (1) [2013] provides that: “On and after the date on which the initial performance test is completed or required to be completed under 40 CFR 60.8 no owner or operator of an affected facility that commenced construction, reconstruction, or modification after May 3, 2011, shall cause to be discharged into the atmosphere from that affected facility any gases that contain NO<sub>x</sub> (expressed as NO<sub>2</sub>) plus CO in excess of the applicable emissions limit specified in paragraphs (b)(1) through (3) of this section as determined on a 30-boiler operating day rolling average basis.

(1) For an affected facility which commenced construction or reconstruction, any gases that contain NO<sub>x</sub> plus CO in excess of either: (i) 140 ng/J (1.1 lb/MWh) gross energy output; or (ii) 150 ng/J (1.2 lb/MWh) net energy output.”

<sup>70</sup> **As related to the compliance provisions of the NSPS for the standards for combined emissions of NO<sub>x</sub> and CO, 40 CFR 60.48Da(g) provides: “For affected facilities for which construction, modification, or reconstruction commenced after May 3, 2011, compliance with applicable 30-boiler operating day rolling average NO<sub>x</sub> plus CO emissions limit is determined by dividing the sum of the NO<sub>x</sub> plus CO emissions for the 30 successive boiler operating days by the sum of the gross energy output or net energy output, as applicable, for the 30 successive boiler operating days.” [emphasis added]**

<sup>71</sup> 40 CFR 60.43Da(g) provides that: “Except as provided in paragraphs (h) of this section and 40 CFR 60.45Da, on and after the date on which the initial performance test is completed or required to be completed under 60.8, whichever date comes first, no owner or operator of an affected facility that commenced construction, reconstruction, or modification after May 3, 2011, shall cause to be discharged into the atmosphere from that affected facility any gases that contain NO<sub>x</sub> (expressed as NO<sub>2</sub>) in excess of the applicable emissions limit specified in paragraphs (g)(1) through (3) of this section.

(1) For an affected facility which commenced construction or reconstruction, any gases that contain NO<sub>x</sub> in excess of either: (i) 88 ng/J (0.70 lb/MWh) gross energy output; or (ii) 95 ng/J (0.76 lb/MWh) net energy output.” 40 CFR 60.44Da(g)(1)[2013].

in terms of gross energy output. The permit must require the oxy-combustion generating unit to comply with all three standards for SO<sub>2</sub>.

**For the reasons already discussed, this comment does not demonstrate that all three NSPS limits for SO<sub>2</sub> must be met.<sup>72</sup> In this regard, since the limits in terms of gross energy output and net energy output are alternative limits, the third limit, which is expressed in terms of the reduction in SO<sub>2</sub> emissions, must also be an alternative limit. Accordingly, the permit properly addresses only the two limits with which the source indicates that it will comply, the limits in terms of gross energy output or, in the alternative, the limit for reduction in SO<sub>2</sub> emissions.**

71. Similarly, for the standard of the NSPS for PM, Condition 2.1.3-1(a)(iii) must include both the gross and net energy output standards in 40 CFR 60.45Da(b)(1)<sup>73</sup> and clearly provide that the oxy-combustion generating units has to comply with both standards.

**For the reasons already discussed, this comment does not demonstrate that both NSPS limits for PM must be met.<sup>74</sup> As such, the permit properly addresses only the PM limit in terms of gross energy output, which is the limit with which the source indicates it will comply.**

72. 40 CFR 60.48Da(a) provides that: “For affected facilities for which construction, modification, or reconstruction commenced after May 3, 2011, the applicable SO<sub>2</sub> emissions limit under 40 CFR 60.43Da, NO<sub>x</sub> emissions limit under 40 CFR 60.44Da, and NO<sub>x</sub> plus CO emissions limit under 40 CFR 60.45Da apply at all times.” For the oxy-combustion boiler, the construction permit should make clear that these limits apply

---

<sup>72</sup> As related to the compliance provisions of the NSPS for the standards for SO<sub>2</sub> emissions, 40 CFR 60.48Da(d) provides: “For affected facilities for which construction, modification, or reconstruction commenced after May 3, 2011, compliance with applicable 30-boiler operating day rolling average SO<sub>2</sub> and NO<sub>x</sub> emissions limits is determined by dividing the sum of the SO<sub>2</sub> and NO<sub>x</sub> emissions for the 30 successive boiler operating days by the sum of the gross energy output or net energy output, as applicable, for the 30 successive boiler operating days.” [emphasis added]

<sup>73</sup> 40 CFR 60.45Da(b)(1) (e) provides that: “Except as provided in paragraph (f) of this section, the owner or operator of an affected facility that commenced construction, reconstruction, or modification commenced after May 3, 2011, shall meet the requirements specified in paragraphs (e)(1) and (2) of this section.

(1) On and after the date on which the initial performance test is completed or required to be completed under 40 CFR 60.8, whichever date comes first, the owner or operator shall not cause to be discharged into the atmosphere from that affected facility any gases that contain PM in excess of the applicable emissions limit specified in paragraphs (e)(1)(i) or (ii) of this section.

(i) For an affected facility which commenced construction or reconstruction: (A) 11 ng/J (0.090 lb/MWh) gross energy output; or (B) 12 ng/J (0.097 lb/MWh) net energy output.”

<sup>74</sup> As related to the compliance provisions of the NSPS for the standards for SO<sub>2</sub> emissions, 40 CFR 60.48Da(n) provides:

“Compliance provisions for sources subject to §60.42Da(c)(1) or (e)(1)(i). The owner or operator shall calculate PM emissions by multiplying the average hourly PM output concentration (measured according to the provisions of §60.49Da(t)), by the average hourly flow rate (measured according to the provisions of §60.49Da(l) or §60.49Da(m)), and dividing by the average hourly gross energy output (measured according to the provisions of §60.49Da(k)) or the average hourly net energy output, as applicable.” [emphasis added]

during startup, shutdown and malfunction. The permit should also ensure that the permit has monitoring and reporting to ensure compliance at all times.

**In response to the request made in this comment, the issued permit incorporates the language of 40 CFR 60.48Da(a). (See revised Condition 2.1.3-1.) This is not unreasonable as 40 CFR 60.48Da(a) directly addresses the applicability of the emission limits in 40 CFR 60 Subpart Da that apply to the oxy-combustion boiler. It also may avoid future misunderstanding about the applicability of these limits.**

**Accordingly, for the oxy-combustion boiler, the issued permit indicates that the standards of the NSPS for SO<sub>2</sub>, NO<sub>x</sub> and NO<sub>x</sub> plus CO apply at all times, consistent with the language of 40 CFR 60.48Da specifically cited by this comment. In addition, although not cited by this comment, the issued permit also indicates that the NSPS limits for PM and opacity do not apply during startup and shutdown, as also provided by 40 CFR 60.48Da(a).**

73. The Illinois EPA must make a determination of whether this facility, with its large parasitic energy loads from the ASU, CPU and two scrubbers, can comply with emission standards under the NSPS that are expressed in terms of net energy output. If the facility cannot, the Illinois EPA must deny the permit.

**As already discussed, this commenter has not demonstrated that the proposed facility must comply with both the limits of the NSPS that are expressed in terms of the net energy output and the standards that are expressed in terms of gross energy output. As such, it is sufficient for the application to show compliance with the NSPS limits in terms of gross energy output, which it does.**

**Moreover, it is reasonable for the source to comply with the limits in terms of gross energy output. This is because USEPA did not consider oxy-combustion facilities with sequestration when it set limits in terms of net energy output under the NSPS.**

74. The NSPS regulations are self-executing. In this regard, this minor source permit cannot shield the source from the obligation to comply with applicable requirements of the NSPS. Even if Illinois EPA does not correct the errors in the draft permit with respect to the NSPS that I have identified in my comments, I can and will enforce the net energy emission limits of the NSPS if they are violated.

**The Illinois EPA agrees that the NSPS regulations are “self-executing.” That is, the effectiveness of the NSPS regulations is independent of the issuance of a construction permit that identifies or specifies the requirements of the NSPS that are applicable to particular new, modified or reconstructed emission units. As already discussed, this commenter has not demonstrated that there are errors in the approach that has been taken in the permit for the oxy-combustion boiler with respect to the NSPS.**

75. Draft Condition 2.1.9-6 requires emission monitoring for CO<sub>2</sub>. However, it refers to 40 CFR 60.49Da(a),<sup>75</sup> which addresses continuous opacity monitoring systems (COMS) and other opacity measuring techniques. Thus, it appears the draft permit did not mean to cite to 40 CFR 60.49Da(a). I cannot tell what Illinois EPA meant to cite to. Therefore, I should be given an opportunity to comment on this issue after Illinois EPA addresses it.

**The error identified in this comment has been corrected in the issued permit, i.e., Condition 2.1.9-6 no longer refers to 40 CFR 60.49Da(a). In fact, the reference to 40 CFR 60.49Da(a) in the draft permit was superfluous. The remainder of the condition, as present in the draft permit, clearly identified the nature of the continuous emissions monitoring that would be required for the oxy-combustion boiler for CO<sub>2</sub> emissions. In this regard, the condition provided that such monitoring would be required to be conducted in accordance with 40 CFR 75.10(a)(3), provisions of the federal Acid Rain Program that address monitoring of CO<sub>2</sub> emissions.**

**The fact that the Illinois EPA has responded to this comment by a change in the issued permit does not mean that the commenter is entitled to a further opportunity to comment. In this respect, this comment is similar to other comments in which changes have been made between the draft permit and the issued permit in response to comments.**

76. The construction permit must make clear that 40 CFR 60.49Da(f)(2) is not applicable to monitoring to comply with the CO<sub>2</sub> and all other annual emission limits in Condition 2.1.6(b) of the permit. 40 CFR 60.49Da(f)(2) allows sources to ignore their emissions 10 percent of the time during boiler operating days and all of the time when a day is not a boiler operating day. This means that monitoring for a limit that is supposed to refer potential to emit and keep the source from triggering PSD would substantially underreport actual emissions. This would make the permit not enforceable as a practical matter. Therefore, the permit must require monitoring for CO<sub>2</sub>, SO<sub>2</sub> and NO<sub>x</sub> at all times that the boiler is combusting any fuel. This may require redundant CEMS.

**This comment does not support the change to the permit that is requested. First, 40 CFR 60.49Da(f)(2) is not applicable to continuous monitoring for CO<sub>2</sub>. As a purely factual matter, this is because 40 CFR 60 Subpart Da does not set emission limits for CO<sub>2</sub> and, accordingly, does not address monitoring of CO<sub>2</sub> emissions.<sup>76</sup> In addition, 40 CFR 60.49Da(f)(2) does not allow sources “to ignore their emissions” at certain times. For NO<sub>x</sub> and SO<sub>2</sub>, for which 40 CFR 60 Subpart Da does require continuous monitoring, 40 CFR 60.49Da(f)(2) sets minimum, quantitative requirements for data collection by these monitoring systems. If these minimum requirements cannot be met by a monitoring system installed on a subject unit, 40 CFR 60.49Da(f)(2)**

<sup>75</sup> Draft Condition 2.1.9-6 states “Pursuant to 40 CFR 60.49Da(a) for the affected boiler, the Permittee shall install, certify, operate and maintain a CEMS for CO<sub>2</sub> emissions.”

<sup>76</sup> USEPA is engaged in rulemaking to adopt an NSPS, 40 CFR 60 Subpart TTTT, that would set standards for CO<sub>2</sub> for new electrical generating units.

requires that a source take necessary actions to meet these minimum requirements, which potentially could include installation and operation of a redundant monitoring system.<sup>77</sup> The establishment by 40 CFR 60.49Da(f)(2) of a minimum quantitative requirement for data collection does not condone or legitimize poor operation of a continuous monitoring system by a source simply because this minimum requirement is met. As already explained, other requirements apply to the operation of continuous emission monitoring systems that address aspects of proper operation of such systems other than the percentage of data that is collected.

As a more general matter, this comment implies that the source need not account for emissions of the oxy-combustion boiler during any periods when continuous emission monitoring systems are not operated. This is not the case. The source must account for all emissions when determining compliance with the emission limits that have been set by the permit. For the oxy-combustion boiler for pollutants for which continuous emissions monitoring is conducted, during any periods when emission data is not available from the monitoring system, the source must determine emissions using “credible data,” consistent with USEPA’s principle of credible evidence. In most cases, it is expected that this will simply require use of emission data collected by the monitoring system for another period of time in which the operation of the boiler was similar to that during the period in which the data was not available from the monitoring system.<sup>78</sup>

77. Condition 2.1.3-1(b)(i)(C) in the draft permit would set a mercury limit of 0.003 lb/GWh for “not low rank coal” and 0.04 lb/GWh for “low rank coal.” In order for this condition to be enforceable as a practical matter, it must define low rank coal. In addition, this condition must explain what the emission limit is when a facility burns a blend of low rank and not low rank coal. This is important because FutureGen intends to burn a blend of Wyoming coal and Illinois coal.

Upon further consideration in response to this comment, Condition 2.1.3-1(b)(i)(C) in the issued permit only includes the more stringent limit for mercury in the NESHAP, 40 CFR 63 Subpart UUUUU, for “coal that is not low rank coal” (i.e., the

---

<sup>77</sup> In fact, for units constructed after February 28, 2005, a “boiler operating day” is defined by 40 CFR 60.41Da to mean “a 24-hour period between 12 midnight and the following midnight during which any fuel is combusted at any time in the steam-generating unit. It is not necessary for fuel to be combusted the entire 24-hour period.” As such, the minimum data collection requirement set by 40 CFR 60.49Da(f)(2) for the monitoring systems on the oxy-combustion boiler that are required by the NSPS is collection of emission data for at least 90 percent of all operating hours for each 30 successive boiler operating days.

This requirement is different than the minimum data collection requirement for older units set by 40 CFR 60.49Da(f)(1), for which a different definition of “boiler operating day” applies. For older units subject to 40 CFR 60 Subpart Da, a boiler operating day means “a 24-hour period during which fossil fuel is combusted in a steam generating unit for the entire 24-hour period.”

<sup>78</sup> In circumstances in which representative monitoring data is not available, the source will need to conduct an engineering analysis to develop credible emission data for the boiler. It is expected that this would involve interpolation or extrapolation from the best, available data collected by the monitoring system, to account for the actual operation of the boiler during the period when data from the monitoring system was not available.

limit for a unit that is not a “unit designed for low rank virgin coal”). The condition does not include the alternative, less stringent limit for “low rank coal” (i.e., the limit for a “unit designed for low rank virgin coal”). Under the NESHAP, one criterion for a “unit designed for low rank virgin coal” is that it be “... at or near the mine that produces such coal.” This will never be the case for the oxy-combustion boiler. The heat content of Illinois coal, which is the only coal that could potentially ever be mined near the facility, is above the level necessary for it to be considered low rank coal. As such, the oxy-combustion boiler will never qualify as a “unit designed for low rank virgin coal.”<sup>79</sup>

78. Condition 2.6.4 does not have a PM<sub>2.5</sub> limit. However, the application (June 2013 submittal, Attachment No. 8) claims maximum emissions of 0.11 tpy. I dispute that this is what the emissions will be. However, to the extent Illinois EPA maintains that this is what emissions will be, the permit must contain this limit and include testing, monitoring and reporting to ensure this limit is not violated. Condition 2.6.4 needs testing, monitoring and reporting to ensure this limit is not violated.

This comment does not show that the permit should limit the PM<sub>2.5</sub> emissions of roadways to 0.11 tpy. First, 0.11 tpy is the potential PM<sub>2.5</sub> emissions from roadways that the Applicant initially provided. As already discussed, the Applicant initially used a value of 0.6 g/m<sup>2</sup> for silt loading in its emission calculations for roadways. The Applicant subsequently submitted revised emission data that was calculated using a value of 2.0 g/m<sup>2</sup>. The emission limits for roadways in the permit reflect this later data. Second, in preparing the permit, the Illinois EPA decided to set a single limit for emissions of PM<sub>10</sub> and PM<sub>2.5</sub> from roadways, 1.9 tpy, based on the revised emission data provided by the Applicant for PM<sub>10</sub>. A single limit for PM<sub>10</sub>/PM<sub>2.5</sub> will simplify review of the compliance determinations that are made by the source for roadways. A separate, lower emission limit for the PM<sub>2.5</sub> emissions from roadways is not needed for the net increase in emissions of PM<sub>2.5</sub> from the proposed project to be less than significant. A separate limit for PM<sub>2.5</sub> emissions also would not meaningfully affect the net change in emissions of PM<sub>2.5</sub> from this project.

---

<sup>79</sup> It was not necessary for the draft permit to supply a definition of the term “low-rank coal.” The classification of coal for purposes of the mercury standard in the NESHAP, 40 CFR 63 Subpart UUUUU, is governed by the definitions for “Unit designed for coal ≥ 8,300 Btu/lb subcategory” and “Unit designed for low rank virgin coal subcategory,” at 40 CFR 63.10042, as follow (emphasis added):

*Unit designed for coal ≥ 8,300 Btu/lb subcategory* means any coal-fired EGU that is not a coal-fired EGU in the “unit designed for low rank virgin coal” subcategory.

*Unit designed for low rank virgin coal subcategory* means any coal-fired EGU that is designed to burn and that is burning non-agglomerating virgin coal having a calorific value (moist, mineral matter-free basis) of less than 19,305 kJ/kg (8,300 Btu/lb) that is constructed and operates at or near the mine that produces such coal.

**As already discussed, the issued permit includes appropriate provisions for verification of compliance with the emission limits that have been set for roadways. In particular, in response to another comment, the issued permit requires measurements for the silt loading on roadways (new Condition 2.6.5-2). If an operating program for roadways that involves more than normal housekeeping practices for roadways must be implemented to ensure compliance with applicable limits, such an operating program is required to be implemented (Condition 2.6.3(b)). Recordkeeping for the implementation of this program is also required (Condition 2.6.6(b)).**

79. The Illinois EPA should define what is meant by “design PM and PM<sub>10</sub> emission rates” in Draft Permit Condition 2.6.6(a)(ii).

**Condition 2.6.6(a)(ii) serves to enhance the practical enforceability of the emission limits for roadways. This is because it requires the source to keep projections for the maximum emissions from roadways. This acts to require the source to appropriately plan and undertake measures to ensure that actual emissions comply with the applicable emission limits. In this regard, this condition also provides the mechanism by which it will be determined if an operating program must be implemented for roadways or whether normal housekeeping practices will be sufficient to determine compliance with the emission limits that have been set for roadways. In response to comments, in the issued permit, this condition has been enhanced to make its purposes clear.**

80. Condition 2.6.6(c) is not sufficient as it does not require testing or monitoring.

**As already discussed, the issued permit includes appropriate provisions for verification of compliance with the emission limits that have been set for roadways. These provisions are set forth elsewhere in the permit than in Condition 2.6.6(c). Condition 2.6.6(c) requires specific recordkeeping for the particulate emissions of roadways, based on the information and data collected pursuant to these other provisions of the permit, to directly confirm compliance with the emission limits that have been set for roadways in Condition 2.6.4.**

81. FutureGen would be an oxy-combustion power plant designed to enable the use of carbon capture and sequestration (CCS) to control up to 90 percent of the facility’s CO<sub>2</sub> emissions. It would be one of the very first utility-scale electric generating CCS projects in the country. I have supported the FutureGen project over the years, conditioned upon its promise of demonstration of CCS technology in which nearly all CO<sub>2</sub> is captured and sequestered.

However, that promise of CCS demonstration would not be required by the draft permit, which would not require the capture or sequestration of any CO<sub>2</sub>. Instead, Condition 2.1.6(b) of the draft permit would allow the facility to emit over 1.4 million tons of CO<sub>2</sub> annually. This level of emissions reflects “continuous operation of the oxy-combustion

boiler at the maximum emission rate under the mode of operation with the greatest emissions.” (Project Summary at 3-4). In other words, the Draft Permit would allow operation of FutureGen as a conventional coal-fired plant, without deploying CCS. The Draft Permit would authorize the construction and operation of a different facility than what FutureGen, as originally proposed, was intended to achieve, and a different plant than what I have supported. The Illinois EPA should repropose a permit that reflects the model CCS project that FutureGen is supposed to be.

**This comment does not provide a legal basis for the action that is requested, i.e., inclusion of specific performance requirements related to CCS in the construction permit for the facility. In particular, the comment does not show that such provisions are necessary to ensure that the proposed facility is not a major project for GHG emissions under the PSD program.**

**Moreover, as acknowledged by this comment, this facility will be a demonstration project. Not only will it be one of the very first utility-scale CCS projects in the country, it will also be a full-scale demonstration project for oxy-combustion technology. As such, it is not unreasonable for the Applicant to have submitted a permit application that does not require that the construction permit establish specific performance requirements for CCS. This avoids requirements for performance of CCS by the facility that may not be able to be achieved, at least initially, as the facility would be a demonstration facility and use technology that has not been demonstrated at the scale of the proposed facility. At the same time, the facility will be subject to requirements related to CCS that are imposed by the USDOE. These requirements will consider both the goals for this project and the circumstances that are present for this facility as it is a demonstration project. The facility will likely be subject to requirements related to CCS that are eventually established by USEPA in its new NSPS for GHG emissions of new electricity utility generating units. The facility may also become subject to requirements related to CCS as a consequence of actions and agreements that take place in the context of the Illinois Power Agency Act.**

82. This permit must include emission limits based on Best Available Control Technology (BACT) determinations for the pollutants, including CO<sub>2</sub> and other GHG, for which the new plant would cause net emissions increases.

**As already discussed elsewhere in this document, this project does not result in a significant net emissions increase for any PSD regulated pollutants and consequently is not subject to the BACT requirement of the PSD rules.**



83. One central PSD requirement is the inclusion of BACT limits for each regulated pollutant for which a major modification would create a significant net emissions increase at the source. 42 U.S.C. § 7475(a)(4)<sup>80</sup>. The Clean Air Act defines BACT as:

an emission limitation based on the maximum degree of reduction of each pollutant subject to regulation under this chapter emitted from or which results from any major emitting facility, which the permitting authority, on a case-by-case basis, taking into account energy, environmental, and economic impacts and other costs, determines is achievable for such facility through application of production processes and available methods, systems, and techniques, including fuel cleaning, clean fuels, or treatment or innovative fuel combustion techniques for control of each such pollutant.

42 U.S.C. § 7479(3).

**While the observation made in this comment is correct, it is not relevant to the permitting of the proposed project. As already discussed, the proposed project is not a major project under the PSD rules. The increase or net increase in emissions of all regulated PSD pollutants from this project will not be significant, in part due to the contemporaneous decreases in emissions from the permanent shutdown of the existing boilers at the Meredosia Energy Center. As such, the project is not subject to the BACT requirement of the PSD rules.**

84. The Illinois EPA has acknowledged that the new oxy-combustion boiler and most of the other changes occurring because of the FutureGen 2.0 project are new construction and/or physical changes or changes of operation. Furthermore, Illinois EPA has acknowledged that these activities will create significant emissions increases for regulated pollutants. Illinois EPA states:

For many . . . pollutants, . . . the increases in emissions with the proposed plant exceed the significant emission thresholds for a major project under the PSD rules.

Project Summary, pp 3-5 (identifying significant emissions increases of particulate matter, PM<sub>10</sub>, PM<sub>2.5</sub>, SO<sub>2</sub>, NO<sub>x</sub>, CO, sulfuric acid mist, and GHG).

The only issue with regard to PSD applicability is whether the changes cause significant net emissions increases. Illinois EPA claims that they do not. *See e.g.* Draft Permit at Finding 3 (“this project will not be accompanied by significant net increases in emissions of PSD pollutants”). Illinois EPA’s analysis of net emissions increases is flawed, though, and PSD is an applicable requirement for these pollutants which requires the Applicant to obtain a PSD permit, including BACT limits.

---

<sup>80</sup> “No major emitting facility . . . may be constructed in any area . . . unless . . . (4) the proposed facility is subject to the best available control technology for each pollutant subject to regulation under this chapter emitted from, or which results from, such facility.” 42 U.S.C. § 7475(a)(4).

Using an appropriate baseline would significantly reduce the emissions decreases that the Illinois EPA has credited to the shutdown of Boilers 1 through 6. For example, for the calendar years 2009 to 2011, the average annual CO<sub>2</sub> emissions at the Meredosia Energy Center were 865,650 tons—far less than both the CO<sub>2</sub>e baseline of 1,937,858 tpy for the Meredosia Energy Center and FutureGen's the CO<sub>2</sub>e emissions of 1,522,503 tpy.<sup>81</sup> Using an appropriate baseline would trigger PSD requirements, including BACT, at a minimum, for GHG, PM<sub>2.5</sub> and NO<sub>x</sub>.

In its Project Summary, Illinois EPA fails to explain why it accepted a baseline period of March 2007 through February 2009, other than to state that this is was a period during which “all these boilers operated.” (Project Summary, p. 5 n.8.) This explanation contradicts the plain language of 40 CFR 52.21(b)(48)(i), which limits the baseline period to one during the “5-year period immediately preceding when the owner or operator begins actual construction of the project.” In any case, the explanation's applicability to the Meredosia Energy Center is entirely unclear. Illinois EPA's implication might be that using the selected baseline period would more accurately reflect emissions from each of the boilers, because it would correct for any increased utilization of Boilers 5 and 6 following the retirement of Boilers 1 through 4. That would not be the case for the Meredosia Energy Center, though. For the period of 2007 to 2011, CO<sub>2</sub> emissions from Boilers 5 and 6 peaked in 2007.<sup>82</sup> CO<sub>2</sub> emissions from Boilers 5 and 6 declined even after the retirement of Boilers 1 through 4, likely because of reduced market demand. In accordance with the plain language of 40 CFR 52.21(b)(48)(i), Illinois EPA must use a later baseline period for Boilers 1 through 6, starting no later than August 2009, that reflects the reduced market demand for the now-shuttered Meredosia Energy Center. Using an appropriate period triggers PSD requirements for FutureGen, including BACT.

**As already discussed, a proper netting analysis was performed using an appropriate baseline period for the contemporaneous decreases in emissions from the shutdown of the existing boilers. The Illinois EPA did not select the baseline period because it would correct for any increased utilization of Boilers 5 and 6 following the retirement of Boilers 1 through 4, as suggested by this comment. The Applicant selected the baseline periods for the contemporaneous emissions decreases from the shutdowns of the existing boilers in accordance with the provisions for baseline periods under 40 CFR 52.21(b)(48)(i). As allowed for by this rule, the Applicant elected to use the same baseline period for the shutdown of Boilers 1 through 4 and the shutdown of Boilers 5 and 6, March 2007 through February 2009. In fact, pursuant to 40 FR 52.21(b)(48), the Applicant could have selected different baseline periods for the shutdown of each group of boilers as each of these shutdowns was a separate project. The Applicant also could have selected different baseline periods**

---

<sup>81</sup> Annual emission rates for Meredosia Boilers 1 through 6 are available from the USEPA's Air Markets Program Data, available at <http://ampd.epa.gov/ampd/QueryToolie.html>. The Meredosia plant's CO<sub>2</sub> emissions for 2009, 2010, and 2011 were 640,404 tons; 914,512 tons; and 1,042,004 tons, respectively.

<sup>82</sup> In 2007, Boilers 5 and 6 emitted 1,544,108 tons of CO<sub>2</sub>, significantly higher than its CO<sub>2</sub> emissions during 2009 through 2011.

**for different pollutants. Such changes to the selected baseline periods would potentially have resulted in greater emissions decreases.<sup>83</sup>**

85. The BACT analysis that is required for GHG emissions must take into account USEPA's proposed *Standards of Performance for Greenhouse Gas Emissions from New Stationary Sources: Electric Utility Generating Units* ("GHG NSPS Prepublication Version of Proposal") (Sept. 20, 2013).<sup>84</sup> See *In re St. Lawrence Cty. Solid Waste Disposal Auth.*, PSD 90-9 (EAB 1990) (remanding PSD permit for permitting authority to consider USEPA determinations in proposed NSPS). In its proposal, USEPA makes clear its determination that implementation of CCS is achievable for new coal-fired boilers. See, e.g., GHG NSPS at PDF pp. 25-26. The Illinois EPA's GHG BACT analysis for FutureGen therefore must reflect both USEPA's determination, as well as the reality that FutureGen's central purpose is to serve as a demonstration of CCS technology to control up to 90 percent of the facility's CO<sub>2</sub> emissions.

**As already discussed, the GHG emissions of the proposed project are not subject to the substantive requirements of PSD, including BACT. This is because the net increase in GHG emissions is below the significant emission rate for GHG. However, the proposed facility will likely be subject to future requirements for CO<sub>2</sub> emissions under USEPA's NSPS for EGUs, 40 CFR 60 Subpart TTTT. Given the facility's use of CCS, it is anticipated that the CO<sub>2</sub> emissions from the oxy-combustion boiler will meet the applicable requirements.**

**The circumstances of the proposed project are not the same as those addressed by the Environmental Appeals Board (EAB) in *In re St. Lawrence (In re St. Lawrence County Solid Waste Auth.*, PSD Appeal No. 90-9, slip op. at 1-3 (Adm'r July 27, 1990)). In *St. Lawrence*, the EAB heard an appeal of a PSD permit for a project that was subject to BACT.<sup>85</sup> As the FutureGen project does not require a PSD permit for GHG emissions, this comment's reliance on *In re St. Lawrence* is unavailing.**

---

<sup>83</sup> 40 CFR 52.21(b)(48) does not require that a single baseline period be used in a netting analysis for all emission units and all pollutants covered by the analysis. 40 CFR 52.21(b)(48)(i)(c) only provides that "For a regulated NSR pollutant, when a project involves multiple emission units, only one consecutive 24-month period must be used to determine the baseline actual emissions for the units being changed. A different consecutive 24-month period can be used For (sic) each regulated NSR pollutant."

<sup>84</sup> Available at <http://www2.epa.gov/sites/production/files/2013-09/documents/20130920proposal.pdf>.

<sup>85</sup> In *St. Lawrence*, the EAB heard an appeal of a PSD permit for a resource recovery facility in which the BACT limits set for NO<sub>x</sub>, SO<sub>2</sub> and CO were challenged. The basis of this appeal was that in the BACT analysis, the permitting authority had not considered USEPA's proposed NSPS rules for municipal waste incinerators, which addressed emissions of NO<sub>x</sub>, SO<sub>2</sub> and CO. The EAB found that the proposal of limits for these pollutants by USEPA in this rulemaking represented a determination by USEPA that the proposed limits were "presumptively achievable using currently available technologies." As such, the limits proposed by USEPA had to be considered in the BACT analysis, where they "should serve as the starting point" for BACT determinations.

**FOR ADDITIONAL INFORMATION**

Questions about the public comment period and the permit decisions should be directed to:

Bradley Frost, Community Relations Coordinator  
Illinois Environmental Protection Agency  
Office of Community Relations  
1021 North Grand Avenue, East  
P.O. Box 19506  
Springfield, Illinois 62794-9506

217-782-7027 Desk line  
217-782-9143 TDD  
217-524-5023 Facsimile

[brad.frost@illinois.gov](mailto:brad.frost@illinois.gov)

## LISTING OF SIGNIFICANT CHANGES BETWEEN THE DRAFT AND ISSUED PERMITS

### Changes to the Permit for the Oxy-Combustion Power Plant, Permit No. 12020013

#### Section 1: Source-Wide Conditions

Condition 1.2(a) – In response to a comment concerning the timing of the contemporaneous emission decreases for this proposed project, an additional provision has been included in the issued permit that provides that the permit will expire if construction is not commenced by August 31, 2014. This provision will explicitly address the timing of the contemporaneous emission decreases from existing Boilers 1 through 4, terminating the authorization to construct provided by the permit at the point when these decreases would cease to be contemporaneous.

Condition 1.2(c) – In response to a comment, the issued permit limits the emissions of sulfuric acid mist from the existing emergency diesel fired engine generator at the source. This change ensures that any increases in emissions of sulfuric acid mist from this contemporaneous construction project are no more than 0.008 tons per year. In addition, this condition includes compliance provisions to verify compliance with this limit for sulfuric acid mist emissions from this engine, including relevant records for the operation of this engine, the methodology by which emissions of sulfuric acid mist are determined, and the emissions of sulfuric acid mist.

#### Section 2.1: Unit-Specific Conditions for the Oxy-Combustion Boiler

Condition 2.1.3-1(a) – In response to a comment, the issued permit incorporates the language of 40 CFR 60.48Da(a) of the NSPS for Electric Utility Steam Generating Units. The additional language provides that the standards of this NSPS for SO<sub>2</sub> and NO<sub>x</sub> or NO<sub>x</sub> plus CO apply at all times. As a consequence of the further review of 40 CFR 60.48Da that was prompted by the comment, the issued permit also includes other relevant language of this provision, which provides that the limits of this NSPS for PM and opacity apply at all times except during periods of startup and shutdown.

Condition 2.1.3-1(b)(i)(C) – In response to a comment, the issued permit only includes the more stringent limit for mercury in the NESHAP, 40 CFR 60 Subpart UUUUU, for a unit firing “coal that is not low rank coal,” 0.003 lb/GWh. The less stringent mercury limit for a unit firing “low rank coal” is not included. This is because this other limit would never be applicable to this boiler.

Condition 2.1.5(c) – In response to a comment expressing concern over the absence of a limit on the load of the oxy-combustion boiler when air firing, the issued permit limits the operation of this boiler to no more than the maximum load established during emissions testing for air-firing or oxy-combustion, as applicable, that demonstrates compliance with the hourly emission limits set for sulfuric acid mist and fluorides in Condition 2.1.6(b). This operational requirement will enhance the practical enforceability of the hourly limits on the emissions of sulfuric acid mist and fluorides of this boiler.

Condition 2.1.6(a)(i) – In response to a comment, the issued permit now limits the annual heat input to the oxy-combustion boiler from fuel to not more than 14.1 million mmBtu/year rather 14.5 million mmBtu/year, as would have been provided by the draft permit. The comment indicated that the potential emissions of the oxy-combustion boiler were under predicted due to the erroneous use of a maximum annual heat input to the boiler that was equivalent to an hourly heat input of 1,655 mmBtu/hour, rather than the nominal heat input of capacity of the boiler, 1,605 mmBtu/hour, as indicated in the application. The limit for annual heat input in the issued permit, 14.1 million mmBtu/year, is equivalent to an hourly

heat input capacity of 1,605 mmBtu/hour. This change acts to maintain consistency between the limit on the heat input to this boiler set by the permit and the representation of the nominal heat input to this boiler made in the application.

Condition 2.1.6(a)(ii) – In response to a comment, the issued permit limits the amount of coal used by the oxy-combustion boiler to no more than 744,600 tons per year. The comment observed that the emission calculations in the application for the new and modified coal handling operations were based on the assumption that the amount of coal used by this boiler is no more than 744,600 tons per year. This change will make this element in the calculations for these coal handling operations enforceable and enhance the practical enforceability of the emission limits that have been set for these operations.

Condition 2.1.6(a)(iii) – In response to various comments, the issued permit limits the operation of the oxy-combustion boiler in air-firing mode (i.e., operation in other than oxy-combustion mode) to no more than 4,800 hours/year. This change will make an element in the emission calculations for the oxy-combustion boiler enforceable and enhance the practical enforceability of the emission limits that have been set for various pollutants, notably sulfuric acid mist and fluorides.

Condition 2.1.6(b) – In the issued permit, the annual limits for emissions of the oxy-combustion boiler (limits for SO<sub>2</sub>, PM, PM<sub>10</sub>/PM<sub>2.5</sub>, VOM, CO and fluorides) are lower than the limits in the draft permit. This reflects adjustments to these limits that result from limiting the operation of this boiler in air-firing mode to no more than 4,800 hours/year, in response to comments, as discussed above.

In addition, the limit for emissions of an individual HAP is 4.5 tons per year (tpy), rather than 2.8 tpy. This corrects an error in the draft permit. The correct limit for individual HAPs was reflected in Table 1A of the draft permit.

Condition 2.1.7(c)(i) – In response to a comment, emission testing is required for the oxy-combustion boiler for sulfuric acid mist and fluorides. This testing will serve to verify compliance with the hourly emission limits that are set for these pollutants. Testing for these pollutants has been found to be reasonable because permitted emissions of these pollutants are more than half of the applicable PSD significant emission rates.

In response to another comment, the issued permit also requires emissions testing for VOM. Given test data is not available for a coal-fired utility boiler with oxy-combustion technology, it is not unreasonable for initial testing for VOM emissions to be required by the permit.

The issued permit now requires emission testing for filterable PM in addition to filterable PM<sub>10</sub> and PM<sub>2.5</sub> and condensable particulate. This corrects an oversight in the draft permit.

Condition 2.1.7(c)(ii)(A) – The issued permit now explicitly requires that the initial emission testing for the oxy-combustion boiler include testing for both operation in air-firing mode and operation in oxy-combustion mode while operating at maximum rates. This clarification was made in response to a comment. It will avoid potential future misunderstandings about the scope of the emission testing that is required under Condition 2.1.7(c).

Condition 2.1.7(c)(ii) – A note has been added to make clear that the additional testing that must be performed for the oxy-combustion boiler pursuant to a request from the Illinois EPA may extend to pollutants for which testing was not initially required, notably for lead. This change was made in response to a comment that believed that the initial emission testing should include testing for lead. Such testing is not warranted initially because emissions of lead are regulated by a NESHAP, 40 CFR 63 Subpart UUUUU, and emissions should be well below applicable emission limits that are set by the

permit. However, this provision addresses the possibility that information may arise that indicates that emission testing of this boiler is warranted for lead. It also provides for further testing for other pollutants, including sulfuric acid mist, fluorides and VOM, in the event that the initial testing for these pollutants indicates that further testing is warranted during the period before a CAAPP permit is issued that addresses this new facility.

Condition 2.1.7(c)(iii) – Test methods and procedures are now specified for testing emissions of filterable PM, VOM, sulfuric acid mist, and fluoride, as testing for these pollutants is now required.

Condition 2.1.7(c)(v) – The issued permit requires additional information in the report for emission testing related to the operating conditions of the oxy-combustion boiler during testing including the boiler's firing rate and load during testing. Information is now required detailing the maximum loads for air-firing and oxy-combustion at which the Permittee considers compliance with applicable emission limits has been demonstrated. This information is needed to implement the operational limit for the load at which the boiler is operated (new Condition 2.1.5(c)), which will be based on information for the operation of the boiler during emissions testing for sulfuric acid mist and fluorides.

Condition 2.1.9-6 – In response to an error identified by a comment, this condition no longer refers to 40 CFR 60.49Da(a). The remainder of the condition is unchanged as it clearly identifies the nature of the continuous emissions monitoring that is being required for the oxy-combustion boiler for CO<sub>2</sub> emissions.

Condition 2.1.10(b)(i) – Recordkeeping requirements related to operation of the oxy-combustion boiler have been enhanced in the issued permit. The additional records are needed to verify compliance with the operational limits for the amount of coal combusted in the boiler and the amount of time that the boiler operates in air-firing mode in new Conditions 2.1.6 (a)(ii) and (iii).

Condition 2.1.10(b)(iii) – Hourly recordkeeping is required for the mode of operation of the boiler and the load of the boiler as this information is needed verify compliance with the operational requirements for the amount of time that the boiler operates in air-firing mode and the load at which the boiler is operated, in new Conditions 2.1.6(a)(iii) and 2.1.5(c), respectively.

Condition 2.1.10(c)(i) and (iii) – The issued permit requires daily records based on CEMS data for emissions of PM, in addition to daily records for emissions of NO<sub>x</sub>, SO<sub>2</sub> and CO<sub>2</sub>, as provided for by the draft permit. Daily records for CO emissions are only required if monitoring is conducted for CO. These changes correct oversights in the draft permit. Pursuant to Condition 2.1.9-3CEMS data for CO will only be required for the oxy-combustion boiler if the Permittee elects to comply with the alternative standard in the NSPS for combined NO<sub>x</sub> and CO, rather than the standard for CO (see). Pursuant to Condition 2.1.9-2, CEMS data will be required for PM, as well as for the other pollutants that were addressed in the draft condition.

Condition 2.1.10(c)(iii) – Records of monthly and annual emissions are also required for CO<sub>2</sub>, as well as NO<sub>x</sub>, SO<sub>2</sub> and CO as provided by the draft permit. In addition, the issued permit requires records for CO only if monitoring is conducted. These changes make these recordkeeping requirements for the oxy-combustion boiler consistent with the continuous emissions monitoring that is conducted for this boiler.

Condition 2.1.10(c)(iv) – The issued permit now requires a file containing calculations including supporting documentation for the maximum hourly emission rates of PM<sub>10</sub>/PM<sub>2.5</sub>, sulfuric acid mist, fluorides, lead, VOM, methane, N<sub>2</sub>O, individual HAP, total HAPs and, if monitoring is not conducted, CO. These records, which address pollutants for which continuous monitoring is not conducted, will

provide reference information for the emissions of these pollutants from the oxy-combustion boiler relative to the hourly emission limits in Condition 2.1.6(b). These records will enhance the practical enforceability of those emission limits.

Condition 2.1.10(c)(v) – The issued permit requires records, including supporting calculations for monthly and annual emissions of PM<sub>10</sub>/PM<sub>2.5</sub>, sulfuric acid mist, fluorides, lead, individual HAP, total HAPs and, if monitoring is not conducted, CO, in addition to records for VOM and GHG, as provided for by the draft permit. These changes expand the scope of the required records to all pollutants emitted from the oxy-combustion boiler for which limits are set for which continuous emissions monitoring will not be conducted. The change will enhance the practical enforceability of the annual limits that are set for emissions of these pollutants.

#### Section 2.2: Unit-Specific Conditions for the Auxiliary Boiler

Condition 2.2.5(b)(ii) – In response to a comment, the issued permit requires the oil fired in the auxiliary boiler be ultra-low sulfur diesel oil thereby limiting the sulfur content of this oil to no more than 15 ppm sulfur, by weight. For this purpose, the fuel used in this boiler must comply with 40 CFR 80.520(a), without relying on the exception to 40 CFR 80.520(a) that is provided in 40 CFR 80.520(c). As a consequence, the auxiliary boiler is prohibited from firing any diesel oil that may currently be held at the Meredosia Energy Center that does not meet the specifications for ultra-low sulfur diesel fuel.

Condition 2.2.6 – In response to concerns expressed in comments that the project will be a major project for emissions of PM<sub>2.5</sub>, with a significant net increase in emissions of PM<sub>2.5</sub>, the permitted annual PM<sub>2.5</sub> emissions of the auxiliary boiler have been lowered in the issued permit. In the issued permit, annual emissions of PM<sub>2.5</sub> are limited to 4.9 tpy, rather than 16.6 tpy, as would have been provided by the draft permit. The hourly limits of for PM<sub>2.5</sub> emissions are also similarly lowered. The lower emission limits reflect emission data for PM<sub>2.5</sub> provided in the application. The draft permit would have set limits for emissions of PM<sub>2.5</sub> that were identical to the limits for PM<sub>10</sub> as this would simplify the review of the determinations of compliance that are made by the source. In response to comments, separate, lower emission limits for PM<sub>2.5</sub> emissions were determined to be reasonable and appropriate to provide further assurance that the proposed project would not be significant for PM<sub>2.5</sub>.

In addition, the issued permit limits sulfuric acid mist emissions from the auxiliary boiler to no more than 0.0124 tons per year. This new limit explicitly limits emissions of sulfuric acid mist from this boiler as they contribute to the increase in emissions from this proposed project that must be addressed in the netting analysis for sulfuric acid mist. The change is a consequence of comments concerning the emissions of sulfuric acid mist of the existing emergency generator at the Meredosia Energy Center, which was addressed as a contemporaneous emissions increase in the netting analysis for emissions of sulfuric acid mist.

Condition 2.2.7-2 (a)(ii) – To further verify compliance with applicable emission limits, emission testing requirements have been enhanced to now require testing from the auxiliary boiler for filterable PM, PM<sub>10</sub> and PM<sub>2.5</sub> and condensable particulate matter, in addition to the testing for emissions of NO<sub>x</sub> and CO that would be provided for by the draft permit. However, if the Permittee considers all PM emissions to be emissions of filterable PM<sub>10</sub> and PM<sub>2.5</sub>, testing for emissions of filterable PM<sub>10</sub> and PM<sub>2.5</sub> is not required unless such testing specifically requested by the Illinois EPA.

Condition 2.2.7(b) – Specific test methods and procedures are now have been added for the testing of the auxiliary boiler for emissions of filterable PM, PM<sub>10</sub> and PM<sub>2.5</sub> and condensable particulate matter.



Conditions 2.2.8-1 and 2.2.9(a) – The compliance provisions for the fuel used in the auxiliary boiler, i.e., fuel sampling and recordkeeping, have been enhanced in the issued permit to address compliance with Condition 2.2.5(b), which requires use of ultra-low sulfur diesel with a sulfur content of no more than 15 ppm, by weight.

Condition 2.2.9(g) – In response to a comment, the issued permit further delineates the records that must be kept for the maximum hourly emission rates of the auxiliary boiler, specifying the pollutants for which such records are required (i.e., NO<sub>x</sub>, CO, PM, PM<sub>10</sub>, PM<sub>2.5</sub>, VOM, SO<sub>2</sub>, sulfuric acid mist, GHG and total HAPs) and also requiring records for maximum emissions in lbs/mmBtu. These records will provide reference information for the emissions of these pollutants relative to the hourly emission limits in Condition 2.2.6 and facilitate the practical enforceability of those emission limits.

### Section 2.3: Unit-Specific Conditions for New And Modified Coal-Handling

Condition 2.3.6 – In response to a comment concerning the need for additional limits for the emissions of particulate matter from the new and modified coal handling operation, additional emission limits have been set in the issued permit. In particular, emission limits for PM and PM<sub>10</sub>/PM<sub>2.5</sub> in pounds per ton of coal and tons per year have been individually set for each operation, rather than limits on combined annual emissions, as would have been set by the draft permit. These additional limits reasonably enhance the practical enforceability of the emission limits for these operations. It will be simpler to review compliance of individual operations than to review compliance of the operations in aggregate. It also will be easier to review compliance with both short-term and annual emission limits than only an annual limit. However, it is not necessary to set separate limits for the PM<sub>2.5</sub> emissions of these operations. Limits for PM<sub>10</sub>/PM<sub>2.5</sub> will simplify review of the determinations of compliance that are made by the source. Separate, lower emission limits for the PM<sub>2.5</sub> emissions are not needed to ensure that the net increase in emissions of PM<sub>2.5</sub> from the proposed project to be less than significant. Such limits also would not meaningfully affect the net change in emissions of PM<sub>2.5</sub> from this project.

Draft Condition 2.3.8(b) – This condition from the draft permit is not included in the issued permit. This condition, which would have required records for the relative share of the emissions of the different operations compared to the annual limit, is no longer needed. This is because Condition 2.4.6 in the issued permit sets emission limits for individual operations.

Condition 2.3.8(d) (i) – The recordkeeping provisions have been enhanced to appropriately address compliance with the new emission limits for PM and PM<sub>10</sub>/PM<sub>2.5</sub> in Condition 2.3.6. Given that the issued permit sets separate emissions limits for each operation in pounds per ton of coal in addition to annual limits, it is appropriate to now require records that include records that address these limits, i.e., calculations, with supporting documentation, for the maximum emission rates of each operation in pounds per tons of coal handled.

### Section 2.4: Unit-Specific Conditions for Bulk Handling Operations

Condition 2.4.5(b) – In response to a comment that the permit must include an enforceable requirement that dry ash be wetted to no less than 15 percent moisture, the issued permit now sets a requirement for the moisture content of dry ash from the oxy-combustion boiler, including dry solids from the circulating dry scrubber, as loaded out from the facility. Consistent with the relevant information provided in the application, the moisture content of this material must be brought to at least 15 percent by weight in the pug mill that prepares this material for loadout.

Condition 2.4.6 – In response to a comment concerning the need for additional limits for the emissions of particulate matter from the lime system, trona system and ash system, additional emission limits have set in the issued permit. In particular, emission limits for PM and PM<sub>10</sub>/PM<sub>2.5</sub> in pounds per ton of material handled and tons per year have been individually set for each operation, rather than limits on combined annual emissions, as would have been set by the draft permit. These additional limits reasonably enhance practical enforceability of the emission limits for these operations. However, it is not necessary to set separate limits for the PM<sub>2.5</sub> emissions of the subject operations. Limits for PM<sub>10</sub>/PM<sub>2.5</sub> will simplify review of the determinations of compliance that are made by the source and separate, lower emission limits for the PM<sub>2.5</sub> emissions are not needed to ensure that the net increase in emissions of PM<sub>2.5</sub> from the proposed project is less than significant.

Condition 2.4.8-1 – In response to a comment requesting procedures to verify compliance with a requirement that dry ash from the oxy-combustion boiler be wetted to no less than 15 percent moisture, the issued permit requires operational monitoring for the amount of water mixed with the ash.

Draft Condition 2.4.9(a)(ii) – This condition from the draft permit is not included in the issued permit. This condition, which would have required records for the relative share of the emissions of the different operations compared to the annual limit, is no longer needed. This is because Condition 2.3.6 in the issued permit sets emission limits for individual operations.

Condition 2.4.9 – The recordkeeping provisions have been modified to appropriately document compliance with the new emission limits for PM and PM<sub>10</sub>/PM<sub>2.5</sub> in Condition 2.4.6. Given that the issued permit sets separate emissions limits for each system in pounds per ton of material handled, in addition to annual limits, it is appropriate to now require records that address these limits, i.e., calculations, with supporting documentation, for the maximum emission rates of each system for PM and PM<sub>10</sub>/PM<sub>2.5</sub> in pounds per tons of material handled. In addition, the Permittee is now required to maintain documentation of the design specifications for each filter for these operations and the manufacturer's recommended operating and maintenance procedures for these filters to verify compliance with the operating requirement of Condition 2.4.5(a), which requires the control devices on each operation be designed to emit no more than 0.02 gr/dscf.

#### Section 2.5: Unit-Specific Conditions for the Cooling Towers

Condition 2.5.6 – In response to a comment concerning the need for additional limits for the emissions of particulate matter from operations other than the cooling towers, additional emission limits have set in the issued permit for the cooling towers, including annual limits for each individual cooling tower. These additional limits reasonably enhance practical enforceability of the emission limits for the cooling towers.

Condition 2.5.7(a) – In response to a comment concerning the limits that would be set for the cooling towers, the issued permit requires sampling and analysis of the water being circulated in each cooling tower for total dissolved solids content to be conducted on at least a monthly basis, rather than a quarterly basis. This change reasonably enhances the practical enforceability of the emission limits that have been set for the cooling towers.

#### Section 2.6: Unit-Specific Conditions for Roadways

Condition 2.6.3(a) – In response to a comment that the issued permit should clearly state which haul roads are to be paved and further, that the issued permit should require the roads to be paved by the time the FutureGen project commences operation, the issued permit now requires the principal roadways at the

facility to be paved. Paving is to be completed by the time of initial startup of the oxy-combustion boiler, provided, however, that the portions of principal roadways in areas where they might be damaged by the continuing presence of heavy construction equipment must be promptly paved after that equipment is removed and paving would no longer be at risk of being damaged; regardless, paving must be completed no later than 90 days after initial startup of the oxy-combustion boiler. In addition, the issued permit also requires that the paving be maintained in good condition.

Condition 2.6.3(d) – In response to a comment that fugitive emissions from the haul roads have been underestimated because the draft permit did not limit the maximum amount of coal that may be received by truck, the issued permit limits the amount of coal that is received by the facility by truck. For this purpose, the amount of coal received by truck is limited to 446,760 tons per year, consistent with information in the application for the maximum amount of coal that would be received by truck.

Condition 2.6.4 – In response to a comment concerning the need for a  $PM_{2.5}$  emission limit from haul roads, the limit for  $PM_{10}$  emissions of haul roads is also applied to  $PM_{2.5}$ . A single limit for  $PM_{10}/PM_{2.5}$  will simplify review of the determinations of compliance that are made by the source. Separate, lower emission limits for  $PM_{2.5}$  emissions are not needed to ensure that the net increase in emissions of  $PM_{2.5}$  from the proposed project is less than significant. A separate emission limit for  $PM_{2.5}$  also would not meaningfully affect the net change in emissions of  $PM_{2.5}$  from this project.

Condition 2.6.5-1(a)(ii) – The periodic inspections that are required to verify implementation of necessary control measures for roadways must now address whether the paving on the principal roadways is in good condition. This sets a compliance procedure for this requirement that applies to these roadways.

Condition 2.6.5-1(b)(vi) – The recordkeeping for required inspections must include the condition of the pavement on the principal roadways, to address whether paving is in good condition.

Condition 2.6.5-2 – In response to a comment that the silt loading assumed in the projection of particulate matter emissions from haul roads should be higher, consistent with the silt loading used in the permitting of certain projects in other states, a requirement for the Permittee to measure the average silt load at the facility has been included in the issued permit. Such testing and analysis shall be conducted employing “Procedures for Sampling Surface/Bulk Dust Loading,” Appendix C.1 in Compilation of Air Pollutant Emission Factors, USEPA, AP-42. The required measurements will ensure that the particulate matter emissions of the haul roads at the facility are accurately determined and compliance with applicable emission limits is properly verified.

Condition 2.6.6(a)(ii) – In response to a comment, this condition has been revised to clarify and expand upon the records that are required. In the issued permit, the function of these projections of maximum particulate matter emissions for roadways, which are required by this condition, is more fully developed. These records must now also include a description of the control measures that are needed to ensure compliance with applicable emission limits considering the emissions that have been projected. These records must also include a determination whether compliance with applicable emissions limits that have been set for roadways necessitates implementation of control measures in accordance with a written operating program.

Condition 2.6.6(c) – In response to a comment, this condition requires specific recordkeeping for the amounts of different materials transported on haul roads. This information consists of records of the amount of coal (truck only), lime and trona received by the plant and the amount of ash loaded out from the plant in tons per month and tons per year. These records will address the limits that has been set for

the amount of coal that is received by truck and generally provide operational data that is needed to determine the particulate matter emissions of roadways.

Attachment 1: Summary of Project Emissions

Table 1A: Summary of Project Emissions (Tons/Year) - Various changes have been made in this table consistent with the various changes discussed above, including: 1) Addition of data for emissions of sulfuric acid mist from certain units for which it was not previously provided; 2) Reductions in the emissions of certain pollutants from the oxy-combustion boiler as a consequence of limiting annual operation of this boiler in air-firing mode to 4,800 hours per year; and 3) A reduction in the PM<sub>2.5</sub> emissions of the auxiliary boiler as a consequence of setting separate limits for PM<sub>2.5</sub>. The overall result is lower project emissions for CO, VOM, SO<sub>2</sub>, PM, PM<sub>10</sub>, PM<sub>2.5</sub> and fluorides and slightly higher project emissions for sulfuric acid mist.

Table 1B: Analysis of Net Changes in Emissions (Tons/Year) - Various changes have been made to this table as a consequence of the changes to Table 1A. In particular, for CO, SO<sub>2</sub>, PM, PM<sub>10</sub> and PM<sub>2.5</sub> (i.e., pollutants for which the permitted emissions of the project emissions are now lower, netting is being conducted and there is a net decrease in emission), the net decrease in emission considering contemporaneous increases and decreases in emissions is now even greater. For sulfuric acid mist, for which the net increase in emissions is less than significant and the permitted emissions of the project are slightly higher, the net increase in emissions is also slightly higher. This is due not only to the slightly higher emissions of sulfuric acid mist for the project but also consideration of a contemporaneous increase in emissions of sulfuric acid mist from the existing emergency engine generator at the Meredosia Energy Center.

**Changes to the Permit for the Emergency Engine at the Sequestration Facility, Permit No. 12020051**

Condition 6(a)(ii) – The issued permit limits the emissions of sulfuric acid mist from the emergency engine generator to no more than 0.0088 tons per year. This new limit explicitly limits emissions of sulfuric acid mist from this engine as they contribute to the increase in emissions of sulfuric acid mist from this proposed project that must be addressed in the netting analysis for sulfuric acid mist. The change is a consequence of comments concerning the emissions of sulfuric acid mist of the existing emergency generator at the Meredosia Energy Center that was addressed as a contemporaneous emissions increase in the netting analysis for this project for emissions of sulfuric acid mist.

Condition 8(b) – This condition requires additional recordkeeping to verify compliance with the limit in Condition 6(a)(ii) for the emissions of sulfuric acid mist from the emergency engine generator. The additional records include records for the methodology by which the source determines the emissions of sulfuric acid mist from the engine, relevant records for the operation of this engine, and records for the actual emissions of sulfuric acid mist from the engine.