

ILLINOIS POLLUTION CONTROL BOARD
January 11, 1990

METRO UTILITY COMPANY,)
)
Petitioner,)
)
v.) PCB 89-210
) (Variance)
ILLINOIS ENVIRONMENTAL)
PROTECTION AGENCY,)
)
Respondent.)


ORDER OF THE BOARD (by B. Forcade):

On December 20, 1989, Metro Utility Company ("Metro") filed a Petition for Variance from restricted status for its public water supply, as it applies to the Board's limitation on iron of 1.0 mg/l. This matter is accepted and will be held for the Illinois Environmental Protection Agency ("Agency") recommendation.

At page 8, paragraph 22, of the petition, Metro asserts that testing by the Agency showed iron concentrations of 50.60 mg/l on July 6, 1989. The Agency is directed to inform the Board in its recommendation as to whether the Agency believes this value is correct. And if so, what are the anticipated health and environmental impacts from such levels. Also, the Agency is directed to inform the Board whether Metro's water supply was placed on restricted status because of high iron concentrations, or low water pressure or both. See Attachment 8 to the petition.

IT IS SO ORDERED

I, Dorothy M. Gunn, Clerk of the Illinois Pollution Control Board, hereby certify that the above Order was adopted on the 11th day of January, 1990, by a vote of 7-0.



Dorothy M. Gunn, Clerk
Illinois Pollution Control Board