

ILLINOIS POLLUTION CONTROL BOARD
December 15, 1983

CITY OF WOOD RIVER,)
)
Petitioner,)
)
v.) PCB 83-232
)
ILLINOIS ENVIRONMENTAL)
PROTECTION AGENCY,)
)
Respondent.)

CONCURRING OPINION (by J. D. Dumelle):

My reason for concurring is that the alternative of using a portable power source (i.e. skid-mounted, etc.) seems not to have been examined.

Since the wet well and interceptor sewer have a one hour holding capacity, the system could have been pumped down, disconnected for up to an hour from the portable power supply while the new hookup occurred and then restarted with no by-passing at all to the Mississippi River.


The environmental effect of the instant provisional variance grant is admittedly minimal. But an examination of the portable power supply alternative might have made that effect non-existent.

Respectfully submitted,



Jacob D. Dumelle
Chairman

I, Christan L. Moffett, Clerk of the Illinois Pollution Control Board, do hereby certify that the above Concurring Opinion was filed on the 30th day of December 1983.



Christan L. Moffett, Clerk
Illinois Pollution Control Board