

ILLINOIS POLLUTION CONTROL BOARD
October 8, 1981

IN THE MATTER OF:)
)
AMENDMENTS TO CHAPTER 2: AIR) R79-11
POLLUTION CONTROL RULES AND REGULATIONS,)
RULE 203(g).)

Adopted Rule.

FINAL ORDER OF THE BOARD (by I. Goodman):

The opinion entered herein on August 7, 1981 is adopted. It is the Order of the Illinois Pollution Control Board that Rule 203(g)(1) of Chapter 2: Air Pollution Control Rules and Regulations, be amended to add the following subsection.


(E) Existing Coal-fired Industrial Boilers Equipped with Flue Gas Desulfurization Systems.

Notwithstanding sub-paragraphs (A)-(D) of Rule 203(g)(1), no person shall cause or allow the emission of particulate matter into the atmosphere from existing coal-fired industrial boilers equipped with flue gas desulfurization systems to exceed 0.25 pounds of particulate matter per million Btu of actual heat input in any one-hour period. Nothing in this rule shall be construed to prevent compliance with applicable regulations in Part IX of this Chapter.

On September 21, 1981 the 45-day Second Notice period for this rulemaking expired. The Joint Committee on Administrative Rules has not filed an objection to this rulemaking and has indicated that it does not intend to do so. Therefore, pursuant to Section 5.01(c) and Section 6 of the Illinois Administrative Procedure Act, the Board directs that the Clerk file this rule with the Secretary of State.

IT IS SO ORDERED.

I, Christan L. Moffett, Clerk of the Illinois Pollution Control Board, hereby certify that the above Order was adopted on the 8th day of October, 1981 by a vote of 8-0.


Christan L. Moffett, Clerk
Illinois Pollution Control Board