

ILLINOIS POLLUTION CONTROL BOARD  
November 20, 1986

CENTRAL ILLINOIS UTILITY CO.,        )  
  )  
          Petitioner,                    )  
  )  
          v.                                )  
  )  
  )  
ILLINOIS ENVIRONMENTAL                )  
PROTECTION AGENCY,                    )  
  )  
          Respondent.                    )

PCB 86-53

ORDER OF THE BOARD (by J. Theodore Meyer):

This matter comes before the Board on an October 28, 1986 motion made by the Illinois Environmental Protection Agency (Agency) for leave to file motion for reconsideration instanter. That motion is hereby granted.

The Agency requests that the Board enter an order amending the variance granted to Petitioner on September 11, 1986 by adding an additional condition to require that the fluoride level in Petitioner's drinking water not exceed the federal standard of 4.0 mg/l. In support of this motion the Agency states that:


1. The variance should be granted consistent with federal law and the federal drinking water standard was recently increased to 4.0 mg/l;
2. USEPA has sought revocation of previous variances granted by the Board to public water supplies and the parties wish to avoid such possible event;
3. Imposition of a condition that the fluoride level not exceed 4.0 mg/l would cause no hardship since Petitioner's fluoride levels are in the 2.5 - 2.85 mg/l range and have never exceeded 4.0 mg/l.

On reconsideration, for the foregoing reasons, the Board believes it should amend its September 11, 1986 order in this matter to provide that the level of fluoride in the potable water provided by Petitioner shall not exceed 4.0 mg/l.

IT IS SO ORDERED.

Board Member J. Anderson concurred.

I, Dorothy M. Gunn, Clerk of the Illinois Pollution Control Board, hereby certify that the above Order was adopted on the 20th day of November, 1986, by a vote of 6-0.

  
\_\_\_\_\_  
Dorothy M. Gunn, Clerk  
Illinois Pollution Control Board