

ILLINOIS POLLUTION CONTROL BOARD
November 16, 1978

IN THE MATTER OF:)
)
PROPOSED DETERMINATION OF) PCB 78-98
NO SIGNIFICANT ECOLOGICAL)
DAMAGE FOR THE DRESDEN)
GENERATING STATION)

INTERIM ORDER OF THE BOARD (by Mr. Dumelle):


On April 4, 1978 Commonwealth Edison Company filed a Petition pursuant to Rule 203(i)(5) of Chapter 3: Water Pollution of the Board's Rules and Regulations. A report was attached in support of the Petition. A hearing was held on August 15, 1978 at the Board's Chicago office.

The record does not contain any theoretical plume studies either for all four seasons for typical and worst case conditions or which identify isotherms at 3° Fahrenheit intervals down to ambient temperature indicating three dimensional effects. There is also no assessment of the impact on other animal life (wildfowl, amphibians, etc.) in the area or on recreation. This information is required by Procedural Rules 602(c)(2) and (3), 602(d)(2), and 602(d)(3)(a).

Commonwealth Edison Company is hereby ordered to supply the information listed above within 180 days of the date of this Order.

IT IS SO ORDERED.

I, Christan L. Moffett, Clerk of the Illinois Pollution Control Board, hereby certify the above Order was adopted on the 16th day of November, 1978 by a vote of 3-0.



Christan L. Moffett, Clerk
Illinois Pollution Control Board