

ILLINOIS POLLUTION CONTROL BOARD  
May 28, 1981

ILLINOIS POWER COMPANY )  
(Clinton Power Station), ET AL., )  
 )  
Petitioners, )  
 )  
v. ) PCB 81-82  
 )  
ILLINOIS ENVIRONMENTAL PROTECTION )  
AGENCY, )  
 )  
Respondent. )

ORDER OF THE BOARD (by I. Goodman):

The Order of May 14, 1981 under R80-17 and PCB 81-82 is incorporated herein.

Discharges to Lake Clinton from Illinois Power Company, from Soyland Power Cooperative, Inc., and from Western Illinois Power Cooperative, Inc. shall not exceed an effluent temperature of 96°F, except that during such time as only one generating unit is in operation at the Clinton Power Station, the daily average discharge temperature shall not exceed 99°F during more than 12 per cent of the hours in twelve-month periods ending with any month and shall at no time exceed 108.3°F.

IT IS SO ORDERED.

I, Christan L. Moffett, Clerk of the Illinois Pollution Control Board, hereby certify that the above Order was adopted on the 28<sup>th</sup> day of May, 1981 by a vote of 4-0.

  
Christan L. Moffett, Clerk  
Illinois Pollution Control Board