

ILLINOIS POLLUTION CONTROL BOARD  
July 24, 1980

MITCHELL DUTTON AND WILMA DUTTON, )  
  ) )  
  Complainant, ) )  
  ) )  
  v. ) )     PCB 79-110  
  ) )  
CITY OF CREST HILL, ) )  
  ) )  
  Respondent. ) )

INTERIM ORDER OF THE BOARD (by J.D. Dumelle):

An Opinion and Order was issued in this case on October 4, 1979, ordering the Respondent to submit a plan to minimize overflows of its sewers to the Board and the Agency within 60 days. It was further ordered that the Respondent, as expeditiously as possible, pursue its efforts through federal grant procedures in obtaining federal funding for improvement of its sewage treatment facilities.


Respondent's proposed plan was received by the Board on January 10, 1980, and the Agency's response was received by the Board on April 28, 1980 (dated April 24, 1980) indicating disapproval of the plan and citing the need for a suitable alarm system at the Elrose Court pumping station. The recommendation also notes Respondent's failure to apply for construction grant monies.

The Board is in substantial agreement with the Agency's recommendations and finds that the submitted plan is unacceptable. The Board further finds that any plan which does not include a suitable alarm system will also be unacceptable.

It is therefore ordered that within 60 days of this Order, Respondent shall submit to the Board and the Agency acceptable changes in its proposed plan which shall include the installation and operation of an alarm system at the Elrose Court pumping station that meets the Illinois Recommended Standards for Sewage Works (Section 35). The Board further reiterates its previous Order that Respondent expeditiously pursue funding for improvement of its sewage treatment facilities.

IT IS SO ORDERED.

I, Christan L. Moffett, Clerk of the Illinois Pollution Control Board, hereby certify that the above Interim Order was adopted on the 24<sup>th</sup> day of July, 1980 by a vote of 5-0.

  
\_\_\_\_\_  
Christan L. Moffett, Clerk  
Illinois Pollution Control Board