

CITY OF MACOMB,)	
)	
Petitioner,)	
)	
)	
v.)	PCB 76-27
)	
ENVIRONMENTAL PROTECTION AGENCY,)	
)	
Respondent.)	

ORDER OF THE BOARD (by Mr. Dumelle):


Petition filed January 26, 1976 is inadequate in that no information is given as to the occurrence, if any, of algae blooms upon the city reservoir and whether bad taste and odors are being experienced in the Macomb public water supply. Also no data are given as to the area of the Reservoir that would be affected by ammonia concentrations in excess of the standard of 1.5 mg/l and what effect this would have upon fish life in the Reservoir. Information as to the cost of treating the phosphorus effluent from the proposed septic system to 1.0 mg/l should also be given.

Petitioner shall amend the Petition within 45 days from the date of this Order to provide the needed information. The 90-day period set by statute for a decision shall run from the filing of the amended Petition. Failure to timely file the amended Petition shall make it liable to dismissal for inadequacy.

IT IS SO ORDERED.

Dr. Satchell abstained.

I, Christan L. Moffett, Clerk of the Illinois Pollution Control Board, hereby certify the above Order was adopted on the 29th day of January, 1976 by a vote of 4-0.



 Christan L. Moffett, Clerk
 Illinois Pollution Control Board