

ILLINOIS POLLUTION CONTROL BOARD
March 4, 2004

IN THE MATTER OF:)
) R04-3
SDWA UPDATE, USEPA AMENDMENTS) (Identical-in-Substance
(January 1, 2003 though June 30, 2003)) Rulemaking - Public Water Supply)

Adopted Rule. Final Order.

ORDER OF THE BOARD (by T.E. Johnson):

The Board today adopts amendments to the Illinois regulations that are “identical in substance” to drinking water regulations adopted by the United States Environmental Protection Agency (USEPA). The USEPA rules implement Sections 1412(b), 1414(c), 1417(a), and 1445(a) of the federal Safe Drinking Water Act (SDWA) (42 U.S.C. §§ 300g-1(a), 300g-3(c), 300g-6(a), and 300j-4(a) (1994)). This docket includes federal SDWA amendments that USEPA adopted in the period January 1, 2003 though June 30, 2003. The substantive amendments involved in this proceeding update the analytical methods approved for determining contaminants in drinking water. They also make minor changes to the consumer confidence report rule.

Sections 7.2 and 17.5 of the Environmental Protection Act (Act) (415 ILCS 5/7.2 and 17.5 (2002)) provide for quick adoption by the Board of regulations that are identical in substance to federal regulations that USEPA adopts to implement Sections 1412(b), 1414(c), 1417(a), and 1445(a) of the federal SDWA. Section 17.5 also provides that Title VII of the Act and Section 5 of the Administrative Procedure Act (APA) (5 ILCS 100/5-35 and 5-40 (2002)) do not apply to the Board’s adoption of identical-in-substance regulations. The federal SDWA regulations are found at 40 C.F.R. 141 through 143.

This order is supported by an opinion that the Board also adopts today. The Board will cause the adopted amendments to be filed no later than October 23, 2003 and published in the *Illinois Register*.

TITLE 35: ENVIRONMENTAL PROTECTION
SUBTITLE F: PUBLIC WATER SUPPLIES
CHAPTER I: POLLUTION CONTROL BOARD

PART 611
PRIMARY DRINKING WATER STANDARDS

SUBPART A: GENERAL

Section
611.100 Purpose, Scope, and Applicability
611.101 Definitions
611.102 Incorporations by Reference

611.103	Severability
611.107	Agency Inspection of PWS Facilities
611.108	Delegation to Local Government
611.109	Enforcement
611.110	Special Exception Permits
611.111	Relief Equivalent to SDWA Section 1415(a) Variances
611.112	Relief Equivalent to SDWA Section 1416 Exemptions
611.113	Alternative Treatment Techniques
611.114	Siting Requirements
611.115	Source Water Quantity
611.120	Effective Dates
611.121	Maximum Contaminant Levels and Finished Water Quality
611.125	Fluoridation Requirement
611.126	Prohibition on Use of Lead
611.130	Special Requirements for Certain Variances and Adjusted Standards
611.131	Relief Equivalent to SDWA Section 1415(e) Small System Variance
611.160	Composite Correction Program

SUBPART B: FILTRATION AND DISINFECTION

Section	
611.201	Requiring a Demonstration
611.202	Procedures for Agency Determinations
611.211	Filtration Required
611.212	Groundwater under Direct Influence of Surface Water
611.213	No Method of HPC Analysis
611.220	General Requirements
611.230	Filtration Effective Dates
611.231	Source Water Quality Conditions
611.232	Site-Specific Conditions
611.233	Treatment Technique Violations
611.240	Disinfection
611.241	Unfiltered PWSs
611.242	Filtered PWSs
611.250	Filtration
611.261	Unfiltered PWSs: Reporting and Recordkeeping
611.262	Filtered PWSs: Reporting and Recordkeeping
611.271	Protection during Repair Work
611.272	Disinfection Following Repair
611.276	Recycle Provisions

SUBPART C: USE OF NON-CENTRALIZED TREATMENT DEVICES

Section	
611.280	Point-of-Entry Devices
611.290	Use of Point-of-Use Devices or Bottled Water

SUBPART D: TREATMENT TECHNIQUES

Section	
611.295	General Requirements
611.296	Acrylamide and Epichlorohydrin
611.297	Corrosion Control

SUBPART F: MAXIMUM CONTAMINANT LEVELS (MCLs) AND MAXIMUM RESIDUAL DISINFECTANT LEVELS (MRDLs)

Section	
611.300	Old MCLs for Inorganic Chemical Contaminants
611.301	Revised MCLs for Inorganic Chemical Contaminants
611.310	Old Maximum Contaminant Levels (MCLs) for Organic Chemical Contaminants
611.311	Revised MCLs for Organic Chemical Contaminants
611.312	Maximum Contaminant Levels (MCLs) for Disinfection Byproducts (DBPs)
611.313	Maximum Residual Disinfectant Levels (MRDLs)
611.320	Turbidity (Repealed)
611.325	Microbiological Contaminants
611.330	Maximum Contaminant Levels for Radionuclides
611.331	Beta Particle and Photon Radioactivity (<u>Repealed</u>)

SUBPART G: LEAD AND COPPER

Section	
611.350	General Requirements
611.351	Applicability of Corrosion Control
611.352	Corrosion Control Treatment
611.353	Source Water Treatment
611.354	Lead Service Line Replacement
611.355	Public Education and Supplemental Monitoring
611.356	Tap Water Monitoring for Lead and Copper
611.357	Monitoring for Water Quality Parameters
611.358	Monitoring for Lead and Copper in Source Water
611.359	Analytical Methods
611.360	Reporting
611.361	Recordkeeping

SUBPART I: DISINFECTANT RESIDUALS, DISINFECTION BYPRODUCTS, AND DISINFECTION BYPRODUCT PRECURSORS

Section	
611.380	General Requirements
611.381	Analytical Requirements
611.382	Monitoring Requirements
611.383	Compliance Requirements
611.384	Reporting and Recordkeeping Requirements
611.385	Treatment Technique for Control of Disinfection Byproduct (DBP) Precursors

SUBPART K: GENERAL MONITORING AND ANALYTICAL
REQUIREMENTS

Section	
611.480	Alternative Analytical Techniques
611.490	Certified Laboratories
611.491	Laboratory Testing Equipment
611.500	Consecutive PWSs
611.510	Special Monitoring for Unregulated Contaminants (Repealed)

SUBPART L: MICROBIOLOGICAL MONITORING AND ANALYTICAL
REQUIREMENTS

Section	
611.521	Routine Coliform Monitoring
611.522	Repeat Coliform Monitoring
611.523	Invalidation of Total Coliform Samples
611.524	Sanitary Surveys
611.525	Fecal Coliform and E. Coli Testing
611.526	Analytical Methodology
611.527	Response to Violation
611.531	Analytical Requirements
611.532	Unfiltered PWSs
611.533	Filtered PWSs

SUBPART M: TURBIDITY MONITORING AND ANALYTICAL
REQUIREMENTS

Section	
611.560	Turbidity

SUBPART N: INORGANIC MONITORING AND ANALYTICAL
REQUIREMENTS

Section	
611.591	Violation of a State MCL
611.592	Frequency of State Monitoring
611.600	Applicability
611.601	Monitoring Frequency
611.602	Asbestos Monitoring Frequency
611.603	Inorganic Monitoring Frequency
611.604	Nitrate Monitoring
611.605	Nitrite Monitoring
611.606	Confirmation Samples
611.607	More Frequent Monitoring and Confirmation Sampling
611.608	Additional Optional Monitoring
611.609	Determining Compliance
611.610	Inorganic Monitoring Times
611.611	Inorganic Analysis
611.612	Monitoring Requirements for Old Inorganic MCLs

- 611.630 Special Monitoring for Sodium
 611.631 Special Monitoring for Inorganic Chemicals (Repealed)

SUBPART O: ORGANIC MONITORING AND ANALYTICAL REQUIREMENTS

- Section
 611.640 Definitions
 611.641 Old MCLs
 611.645 Analytical Methods for Organic Chemical Contaminants
 611.646 Phase I, Phase II, and Phase V Volatile Organic Contaminants
 611.647 Sampling for Phase I Volatile Organic Contaminants (Repealed)
 611.648 Phase II, Phase IIB, and Phase V Synthetic Organic Contaminants
 611.650 Monitoring for 36 Contaminants (Repealed)
 611.657 Analytical Methods for 36 Contaminants (Repealed)
 611.658 Special Monitoring for Organic Chemicals (Repealed)

SUBPART P: THM MONITORING AND ANALYTICAL REQUIREMENTS

- Section
 611.680 Sampling, Analytical, and other Requirements
 611.683 Reduced Monitoring Frequency (Repealed)
 611.684 Averaging (Repealed)
 611.685 Analytical Methods
 611.686 Modification to System (Repealed)
 611.687 Sampling for THM Potential (Repealed)
 611.688 Applicability Dates (Repealed)

SUBPART Q: RADIOLOGICAL MONITORING AND ANALYTICAL REQUIREMENTS

- Section
 611.720 Analytical Methods
 611.731 Gross Alpha
 611.732 Beta Particle and Photon Radioactivity
 611.733 General Monitoring and Compliance Requirements

SUBPART R: ENHANCED FILTRATION AND DISINFECTION: SYSTEMS THAT SERVE 10,000 OR MORE PEOPLE

- Section
 611.740 General Requirements
 611.741 Standards for Avoiding Filtration
 611.742 Disinfection Profiling and Benchmarking
 611.743 Filtration
 611.744 Filtration Sampling Requirements
 611.745 Reporting and Recordkeeping Requirements

SUBPART T: REPORTING AND RECORDKEEPING

- Section
 611.830 Applicability

611.831	Monthly Operating Report
611.832	Notice by Agency (Repealed)
611.833	Cross Connection Reporting
611.840	Reporting
611.851	Reporting MCL, MRDL, and other Violations (Repealed)
611.852	Reporting other Violations (Repealed)
611.853	Notice to New Billing Units (Repealed)
611.854	General Content of Public Notice (Repealed)
611.855	Mandatory Health Effects Language (Repealed)
611.856	Fluoride Notice (Repealed)
611.858	Fluoride Secondary Standard (Repealed)
611.860	Record Maintenance
611.870	List of 36 Contaminants (Repealed)

SUBPART U: CONSUMER CONFIDENCE REPORTS

Section	
611.881	Purpose and Applicability
611.882	Compliance Dates
611.883	Content of the Reports
611.884	Required Additional Health Information
611.885	Report Delivery and Recordkeeping

SUBPART V: PUBLIC NOTIFICATION OF DRINKING WATER VIOLATIONS

Section	
611.901	General Public Notification Requirements
611.902	Tier 1 Public Notice: Form, Manner, and Frequency of Notice
611.903	Tier 2 Public Notice: Form, Manner, and Frequency of Notice
611.904	Tier 3 Public Notice: Form, Manner, and Frequency of Notice
611.905	Content of the Public Notice
611.906	Notice to New Billing Units or New Customers
611.907	Special Notice of the Availability of Unregulated Contaminant Monitoring Results
611.908	Special Notice for Exceedence of the Fluoride Secondary Standard
611.909	Special Notice for Nitrate Exceedences above the MCL by a Non-Community Water System
611.910	Notice by the Agency on Behalf of a PWS

SUBPART X: ENHANCED FILTRATION AND DISINFECTION--SYSTEMS SERVING FEWER THAN 10,000 PEOPLE

Section	
611.950	General Requirements
611.951	Finished Water Reservoirs
611.952	Additional Watershed Control Requirements for Unfiltered Systems
611.953	Disinfection Profile
611.954	Disinfection Benchmark

611.955	Combined Filter Effluent Turbidity Limits
611.956	Individual Filter Turbidity Requirements
611.957	Reporting and Recordkeeping Requirements
611.Appendix A	Regulated Contaminants
611.Appendix B	Percent Inactivation of G. Lamblia Cysts
611.Appendix C	Common Names of Organic Chemicals
611.Appendix D	Defined Substrate Method for the Simultaneous Detection of Total Coliforms and Eschericia Coli from Drinking Water
611.Appendix E	Mandatory Lead Public Education Information for Community Water Systems
611.Appendix F	Mandatory Lead Public Education Information for Non-Transient Non-Community Water Systems
611.Appendix G	NPDWR Violations and Situations Requiring Public Notice
611.Appendix H	Standard Health Effects Language for Public Notification
611.Appendix I	Acronyms Used in Public Notification Regulation
611.Table A	Total Coliform Monitoring Frequency
611.Table B	Fecal or Total Coliform Density Measurements
611.Table C	Frequency of RDC Measurement
611.Table D	Number of Lead and Copper Monitoring Sites
611.Table E	Lead and Copper Monitoring Start Dates
611.Table F	Number of Water Quality Parameter Sampling Sites
611.Table G	Summary of Section 611.357 Monitoring Requirements for Water Quality Parameters
611.Table Z	Federal Effective Dates

AUTHORITY: Implementing Sections 7.2, 17, and 17.5 and authorized by Section 27 of the Environmental Protection Act [415 ILCS 5/7.2, 17, 17.5, and 27].

SOURCE: Adopted in R88-26 at 14 Ill. Reg. 16517, effective September 20, 1990; amended in R90-21 at 14 Ill. Reg. 20448, effective December 11, 1990; amended in R90-13 at 15 Ill. Reg. 1562, effective January 22, 1991; amended in R91-3 at 16 Ill. Reg. 19010, effective December 1, 1992; amended in R92-3 at 17 Ill. Reg. 7796, effective May 18, 1993; amended in R93-1 at 17 Ill. Reg. 12650, effective July 23, 1993; amended in R94-4 at 18 Ill. Reg. 12291, effective July 28, 1994; amended in R94-23 at 19 Ill. Reg. 8613, effective June 20, 1995; amended in R95-17 at 20 Ill. Reg. 14493, effective October 22, 1996; amended in R98-2 at 22 Ill. Reg. 5020, effective March 5, 1998; amended in R99-6 at 23 Ill. Reg. 2756, effective February 17, 1999; amended in R99-12 at 23 Ill. Reg. 10348, effective August 11, 1999; amended in R00-8 at 23 Ill. Reg. 14715, effective December 8, 1999; amended in R00-10 at 24 Ill. Reg. 14226, effective September 11, 2000; amended in R01-7 at 25 Ill. Reg. 1329, effective January 11, 2001; amended in R01-20 at 25 Ill. Reg. 13611, effective October 9, 2001; amended in R02-5 at 26 Ill. Reg. 3522, effective February 22, 2002; amended in R03-4 at 27 Ill. Reg. 1183, effective January 10, 2003; amended in R03-15 at 27 Ill. Reg. 16447, effective October 10, 2003; amended in R04-3 at 28 Ill. Reg. _____, effective _____.

SUBPART A: GENERAL

Section 611.101 Definitions

As used in this Part, the following terms have the given meanings:

“Act” means the Environmental Protection Act [415 ILCS 5].

“Agency” means the Illinois Environmental Protection Agency.

BOARD NOTE: The Department of Public Health (Public Health or DPH) regulates non-community water supplies (“non-CWSs,” including non-transient, non-community water supplies (“NTNCWSs”) and transient non-community water supplies (“transient non-CWSs”). For the purposes of regulation of supplies by Public Health by reference to this Part, “Agency” will mean the Department of Public Health.

“Ai” means “inactivation ratio.”

“Approved source of bottled water,” for the purposes of Section 611.130(ed)(4), means a source of water and the water therefrom, whether it be from a spring, artesian well, drilled well, municipal water supply, or any other source, that has been inspected and the water sampled, analyzed, and found to be a safe and sanitary quality according to applicable laws and regulations of State and local government agencies having jurisdiction, as evidenced by the presence in the plant of current certificates or notations of approval from each government agency or agencies having jurisdiction over the source, the water it bottles, and the distribution of the water in commerce.

BOARD NOTE: Derived from 40 CFR 142.62(g)(2) and 21 CFR 129.3(a)-(2002) (2003). The Board cannot compile an exhaustive listing of all federal, State, and local laws to which bottled water and bottling water may be subjected. However, the statutes and regulations of which the Board is aware are the following: the Illinois Food, Drug and Cosmetic Act [410 ILCS 620], the Bottled Water Act [815 ILCS 310], the DPH Water Well Construction Code (77 Ill. Adm. Code 920), the DPH Water Well Pump Installation Code (77 Ill. Adm. Code 925), the federal bottled water quality standards (21 CFR 103.35), the federal drinking water processing and bottling standards (21 CFR 129), the federal Current Good Manufacturing Practice in Manufacturing, Packing, or Holding Human Food (21 CFR 110), the federal Fair Packaging and Labeling Act (15 USC 1451 et seq.), and the federal Fair Packaging and Labeling regulations (21 CFR 201).

“Best available technology” or “BAT” means the best technology, treatment techniques, or other means that USEPA has found are available for the contaminant in question. BAT is specified in Subpart F of this Part.

“Board” means the Illinois Pollution Control Board.

“CAS No.” means “Chemical Abstracts Services Number.”

“CT” or “CT_{calc}” is the product of “residual disinfectant concentration” (RDC or C) in mg/ℓ determined before or at the first customer, and the corresponding “disinfectant contact time” (T) in minutes. If a supplier applies disinfectants at more than one point prior to the first customer, it must determine the CT of each disinfectant sequence before or at the first customer to determine the total percent inactivation or “total inactivation ratio.” In determining the total inactivation ratio, the supplier must determine the RDC of each disinfection sequence and corresponding contact time before any subsequent disinfection application points. (See “CT_{99.9}.”)

“CT_{99.9}” is the CT value required for 99.9 percent (3-log) inactivation of *Giardia lamblia* cysts. CT_{99.9} for a variety of disinfectants and conditions appear in Tables 1.1-1.6, 2.1 and 3.1 of Appendix B of this Part. (See “Inactivation Ratio.”)
BOARD NOTE: Derived from the definition of “CT” in 40 CFR 141.2-(2002) (2003).

“Coagulation” means a process using coagulant chemicals and mixing by which colloidal and suspended materials are destabilized and agglomerated into flocs.

“Community water system” or “CWS” means a public water system (PWS) that serves at least 15 service connections used by year-round residents or regularly serves at least 25 year-round residents.

BOARD NOTE: This definition differs slightly from that of Section 3.05 of the Act.

“Compliance cycle” means the nine-year calendar year cycle during which public water systems (PWSs) must monitor. Each compliance cycle consists of three three-year compliance periods. The first calendar cycle began January 1, 1993, and ended December 31, 2001; the second began January 1, 2002, and ends December 31, 2010; the third begins January 1, 2011, and ends December 31, 2019.

“Compliance period” means a three-year calendar year period within a compliance cycle. Each compliance cycle has three three-year compliance periods. Within the first compliance cycle, the first compliance period ran from January 1, 1993 to December 31, 1995; the second from January 1, 1996 to December 31, 1998; the third from January 1, 1999 to December 31, 2001.

“Comprehensive performance evaluation” or “CPE” is a thorough review and analysis of a treatment plant’s performance-based capabilities and associated administrative, operation, and maintenance practices. It is conducted to identify factors that may be adversely impacting a plant’s capability to achieve compliance and emphasizes approaches that can be implemented without significant capital improvements.

BOARD NOTE: The final sentence of the definition of “comprehensive performance evaluation” in 40 CFR 141.2 is codified as Section 611.160(a)(2),

since it contains substantive elements that are more appropriately codified in a substantive provision.

“Confluent growth” means a continuous bacterial growth covering the entire filtration area of a membrane filter or a portion thereof, in which bacterial colonies are not discrete.

“Contaminant” means any physical, chemical, biological, or radiological substance or matter in water.

“Conventional filtration treatment” means a series of processes including coagulation, flocculation, sedimentation, and filtration resulting in substantial particulate removal.

“Diatomaceous earth filtration” means a process resulting in substantial particulate removal in which the following occur:

A precoat cake of diatomaceous earth filter media is deposited on a support membrane (septum); and

While the water is filtered by passing through the cake on the septum, additional filter media known as body feed is continuously added to the feed water to maintain the permeability of the filter cake.

“Direct filtration” means a series of processes including coagulation and filtration but excluding sedimentation resulting in substantial particulate removal.

“Disinfectant” means any oxidant, including but not limited to chlorine, chlorine dioxide, chloramines, and ozone added to water in any part of the treatment or distribution process, that is intended to kill or inactivate pathogenic microorganisms.

“Disinfectant contact time” or “T” means the time in minutes that it takes for water to move from the point of disinfectant application or the previous point of RDC measurement to a point before or at the point where RDC is measured.

Where only one RDC is measured, T is the time in minutes that it takes for water to move from the point of disinfectant application to a point before or at the point where RDC is measured.

Where more than one RDC is measured, T is as follows:

For the first measurement of RDC, the time in minutes that it takes for water to move from the first or only point of disinfectant application to a point before or at the point where the first RDC is measured; and

For subsequent measurements of RDC, the time in minutes that it takes for water to move from the previous RDC measurement point to the RDC measurement point for which the particular T is being calculated.

T in pipelines must be calculated based on “plug flow” by dividing the internal volume of the pipe by the maximum hourly flow rate through that pipe.

T within mixing basins and storage reservoirs must be determined by tracer studies or an equivalent demonstration.

“Disinfection” means a process that inactivates pathogenic organisms in water by chemical oxidants or equivalent agents.

“Disinfection byproduct” or “DBP” means a chemical byproduct that forms when disinfectants used for microbial control react with naturally occurring compounds already present in source water. DBPs include, but are not limited to, bromodichloromethane, bromoform, chloroform, dichloroacetic acid, bromate, chlorite, dibromochloromethane, and certain haloacetic acids.

“Disinfection profile” is a summary of daily *Giardia lamblia* inactivation through the treatment plant. The procedure for developing a disinfection profile is contained in Section 611.742.

“Distribution system” includes all points downstream of an “entry point” to the point of consumer ownership.

“Domestic or other non-distribution system plumbing problem” means a coliform contamination problem in a PWS with more than one service connection that is limited to the specific service connection from which the coliform-positive sample was taken.

“Dose equivalent” means the product of the absorbed dose from ionizing radiation and such factors as account for differences in biological effectiveness due to the type of radiation and its distribution in the body as specified by the International Commission on Radiological Units and Measurements (ICRU).

“Enhanced coagulation” means the addition of sufficient coagulant for improved removal of disinfection byproduct (DBP) precursors by conventional filtration treatment.

“Enhanced softening” means the improved removal of disinfection byproduct (DBP) precursors by precipitative softening.

“Entry point” means a point just downstream of the final treatment operation, but

upstream of the first user and upstream of any mixing with other water. If raw water is used without treatment, the “entry point” is the raw water source. If a PWS receives treated water from another PWS, the “entry point” is a point just downstream of the other PWS, but upstream of the first user on the receiving PWS, and upstream of any mixing with other water.

“Filter profile” is a graphical representation of individual filter performance, based on continuous turbidity measurements or total particle counts versus time for an entire filter run, from startup to backwash inclusively, that includes an assessment of filter performance while another filter is being backwashed.

“Filtration” means a process for removing particulate matter from water by passage through porous media.

“Flocculation” means a process to enhance agglomeration or collection of smaller floc particles into larger, more easily settleable particles through gentle stirring by hydraulic or mechanical means.

“GAC10” means granular activated carbon (GAC) filter beds with an empty-bed contact time of 10 minutes based on average daily flow and a carbon reactivation frequency of every 180 days.

“GC” means “gas chromatography” or “gas-liquid phase chromatography.”

“GC/MS” means gas chromatography (GC) followed by mass spectrometry (MS).

“Gross alpha particle activity” means the total radioactivity due to alpha particle emission as inferred from measurements on a dry sample.

“Gross beta particle activity” means the total radioactivity due to beta particle emission as inferred from measurements on a dry sample.

“Groundwater under the direct influence of surface water” means any water beneath the surface of the ground with significant occurrence of insects or other macroorganisms, algae, or large-diameter pathogens, such as *Giardia lamblia* or *Cryptosporidium*, or significant and relatively rapid shifts in water characteristics, such as turbidity, temperature, conductivity, or pH, that closely correlate to climatological or surface water conditions. “Groundwater under the direct influence of surface water” is as determined in Section 611.212.

“GWS” means “groundwater system,” a public water supply (PWS) that uses only groundwater sources.

BOARD NOTE: Drawn from 40 CFR 141.23(b)(2) & 141.24(f)(2) note ~~(2002)~~ (2003).

“Haloacetic acids (five)” or “HAA5” means the sum of the concentrations in

milligrams per liter (mg/ℓ) of five haloacetic acid compounds (monochloroacetic acid, dichloroacetic acid, trichloroacetic acid, monobromoacetic acid, and dibromoacetic acid), rounded to two significant figures after addition.

“Halogen” means one of the chemical elements chlorine, bromine, or iodine.

“HPC” means “heterotrophic plate count,” measured as specified in Section 611.531(c).

“Inactivation ratio” (Ai) means as follows:

$$A_i = CT_{\text{calc}}/CT_{99.9}$$

The sum of the inactivation ratios, or “total inactivation ratio” (B) is calculated by adding together the inactivation ratio for each disinfection sequence as follows:

$$B = \sum(A_i)$$

A total inactivation ratio equal to or greater than 1.0 is assumed to provide a 3-log inactivation of *Giardia lamblia* cysts.

BOARD NOTE: Derived from the definition of “CT” in 40 CFR 141.2-(2002) (2003).

“Initial compliance period” means the three-year compliance period that begins January 1, 1993, except for the MCLs for dichloromethane, 1,2,4-trichlorobenzene, 1,1,2-trichloroethane, benzo(a)pyrene, dalapon, di(2-ethylhexyl)adipate, di(2-ethylhexyl)phthalate, dinoseb, diquat, endothall, endrin, glyphosate, hexachlorobenzene, hexachlorocyclopentadiene, oxamyl, picloram, simazine, 2,3,7,8-TCDD, antimony, beryllium, cyanide, nickel, and thallium, as they apply to a supplier whose system has fewer than 150 service connections, for which it means the three-year compliance period that began on January 1, 1996.

“Inorganic contaminants” or “IOCs” refers to that group of contaminants designated as such in United States Environmental Protection Agency (USEPA) regulatory discussions and guidance documents. IOCs include antimony, arsenic, asbestos, barium, beryllium, cadmium, chromium, cyanide, mercury, nickel, nitrate, nitrite, selenium, and thallium.

BOARD NOTE: The IOCs are derived from 40 CFR 141.23(a)(4)-(2002) (2003).

“ℓ” means “liter.”

“Legionella” means a genus of bacteria, some species of which have caused a type of pneumonia called Legionnaires Disease.

“Man-made beta particle and photon emitters” means all radionuclides emitting beta

particles or photons listed in “Maximum Permissible Body Burdens and Maximum Permissible Concentrations of Radionuclides in Air and in Water for Occupational Exposure,” NCRP Report Number 22, incorporated by reference in Section 611.102, except the daughter products of thorium-232, uranium-235 and uranium-238.

“Maximum contaminant level” or “MCL” means the maximum permissible level of a contaminant in water that is delivered to any user of a public water system. (See Section 611.121.)

“Maximum contaminant level goal” or “MCLG” means the maximum level of a contaminant in drinking water at which no known or anticipated adverse effect on the health of persons would occur, and which allows an adequate margin of safety. MCLGs are nonenforceable health goals.

BOARD NOTE: The Board has not routinely adopted the regulations relating to the federal MCLGs because they are outside the scope of the Board’s identical-in-substance mandate under Section 17.5 of the Act [415 ILCS 5/17.5].

“Maximum residual disinfectant level” or “MRDL” means the maximum permissible level of a disinfectant added for water treatment that may not be exceeded at the consumer’s tap without an unacceptable possibility of adverse health effects. MRDLs are enforceable in the same manner as are MCLs. (See Section 611.313 and Section 611.383.)

“Maximum residual disinfectant level goal” or “MRDLG” means the maximum level of a disinfectant added for water treatment at which no known or anticipated adverse effect on the health of persons would occur, and which allows an adequate margin of safety. MRDLGs are nonenforceable health goals and do not reflect the benefit of the addition of the chemical for control of waterborne microbial contaminants.

“Maximum total trihalomethane potential” or “MTP” means the maximum concentration of total trihalomethanes (TTHMs) produced in a given water containing a disinfectant residual after seven days at a temperature of 25° C or above.

“MFL” means millions of fibers per liter larger than 10 micrometers.

BOARD NOTE: Derived from 40 CFR 141.23(a)(4)(i) ~~(2002)~~ (2003).

“mg” means milligrams (1/1000 of a gram).

“mg/ℓ” means milligrams per liter.

“Mixed system” means a PWS that uses both groundwater and surface water sources.

BOARD NOTE: Drawn from 40 CFR 141.23(b)(2) and 141.24(f)(2) note ~~(2002)~~ (2003).

“MUG” means 4-methyl-umbelliferyl-beta-d-glucuronide.

“Near the first service connection” means at one of the 20 percent of all service connections in the entire system that are nearest the public water system (PWS) treatment facility, as measured by water transport time within the distribution system.

“nm” means nanometer (1/1,000,000,000 of a meter).

“Non-community water system” or “NCWS” or “non-CWS” means a public water system (PWS) that is not a community water system (CWS). A non-community water system is either a “transient non-community water system (TWS)” or a “non-transient non-community water system (NTNCWS).”

“Non-transient non-community water system” or “NTNCWS” means a public water system (PWS) that is not a community water system (CWS) and that regularly serves at least 25 of the same persons over six months per year.

“NPDWR” means “national primary drinking water regulation.”

“NTU” means “nephelometric turbidity units.”

“Old MCL” means one of the inorganic maximum contaminant levels (MCLs), codified at Section 611.300, or organic MCLs, codified at Section 611.310, including any marked as “additional State requirements.”

BOARD NOTE: Old MCLs are those derived prior to the implementation of the USEPA “Phase II” regulations. The Section 611.640 definition of this term, which applies only to Subpart O of this Part, differs from this definition in that the definition does not include the Section 611.300 inorganic MCLs.

“P-A Coliform Test” means “Presence-Absence Coliform Test.”

“Paired sample” means two samples of water for Total Organic Carbon (TOC). One sample is of raw water taken prior to any treatment. The other sample is taken after the point of combined filter effluent and is representative of the treated water. These samples are taken at the same time. (See Section 611.382.)

“Performance evaluation sample” or “PE sample” means a reference sample provided to a laboratory for the purpose of demonstrating that the laboratory can successfully analyze the sample within limits of performance specified by the Agency; or, for bacteriological laboratories, Public Health; or, for radiological laboratories, the Illinois Department of Nuclear Safety. The true value of the concentration of the reference material is unknown to the laboratory at the time of the analysis.

“Person” means an individual, corporation, company, association, partnership, state, unit of local government, or federal agency.

“Phase I” refers to that group of chemical contaminants and the accompanying regulations promulgated by USEPA on July 8, 1987, at 52 Fed. Reg. 25712.

“Phase II” refers to that group of chemical contaminants and the accompanying regulations promulgated by USEPA on January 30, 1991, at 56 Fed. Reg. 3578.

“Phase IIB” refers to that group of chemical contaminants and the accompanying regulations promulgated by USEPA on July 1, 1991, at 56 Fed. Reg. 30266.

“Phase V” refers to that group of chemical contaminants promulgated by USEPA on July 17, 1992, at 57 Fed. Reg. 31776.

“Picrocurie” or “pCi” means the quantity of radioactive material producing 2.22 nuclear transformations per minute.

“Point of disinfectant application” is the point at which the disinfectant is applied and downstream of which water is not subject to recontamination by surface water runoff.

“Point-of-entry treatment device” or “POE” is a treatment device applied to the drinking water entering a house or building for the purpose of reducing contaminants in the drinking water distributed throughout the house or building.

“Point-of-use treatment device” or “POU” is a treatment device applied to a single tap used for the purpose of reducing contaminants in drinking water at that one tap.

“Public Health” or “DPH” means the Illinois Department of Public Health.
BOARD NOTE: The Department of Public Health (“Public Health”) regulates non-community water supplies (“non-CWSs,” including non-transient, non-community water supplies (“NTNCWSs”) and transient non-community water supplies (“transient non-CWSs”). For the purposes of regulation of supplies by Public Health by reference to this Part, “Agency” must mean Public Health.

“Public water system” or “PWS” means a system for the provision to the public of water for human consumption through pipes or other constructed conveyances, if such system has at least 15 service connections or regularly serves an average of at least 25 individuals daily at least 60 days out of the year. A PWS is either a community water system (CWS) or a non-community water system (non-CWS). Such term includes the following:

Any collection, treatment, storage, and distribution facilities under control of the operator of such system and used primarily in connection with such system; and

Any collection or pretreatment storage facilities not under such control that

are used primarily in connection with such system.

BOARD NOTE: Where used in Subpart F of this Part, “public water supply” means the same as “public water system.”

“Radioactive contaminants” refers to that group of contaminants designated “radioactive contaminants” in USEPA regulatory discussions and guidance documents. “Radioactive contaminants” include tritium, strontium-89, strontium-90, iodine-131, cesium-134, gross beta emitters, and other nuclides.

BOARD NOTE: Derived from 40 CFR 141.25(c) Table B ~~(2002)~~ (2003). These radioactive contaminants must be reported in Consumer Confidence Reports under Subpart U of this Part when they are detected above the levels indicated in Section 611.720(c)(3).

“Reliably and consistently” below a specified level for a contaminant means an Agency determination based on analytical results following the initial detection of a contaminant to determine the qualitative condition of water from an individual sampling point or source. The Agency must base this determination on the consistency of analytical results, the degree below the MCL, the susceptibility of source water to variation, and other vulnerability factors pertinent to the contaminant detected that may influence the quality of water.

BOARD NOTE: Derived from 40 CFR 141.23(b)(9), 141.24(f)(11)(ii), and 141.24(f)(11)(iii) ~~(2002)~~ (2003).

“Rem” means the unit of dose equivalent from ionizing radiation to the total body or any internal organ or organ system. A “millirem (mrem)” is 1/1000 of a rem.

“Repeat compliance period” means a compliance period that begins after the initial compliance period.

“Representative” means that a sample must reflect the quality of water that is delivered to consumers under conditions when all sources required to supply water under normal conditions are in use and all treatment is properly operating.

“Residual disinfectant concentration” (“RDC” or “C” in CT calculations) means the concentration of disinfectant measured in mg/ℓ in a representative sample of water. For purposes of the requirement of Section 611.241(d) of maintaining a detectable RDC in the distribution system, “RDC” means a residual of free or combined chlorine.

“Safe Drinking Water Act” or “SDWA” means the Public Health Service Act, as amended by the Safe Drinking Water Act, Pub. L. 93-523, 42 USC 300f et seq.

“Sanitary survey” means an onsite review of the water source, facilities, equipment, operation, and maintenance of a public water system (PWS) for the purpose of evaluating the adequacy of such source, facilities, equipment, operation, and maintenance for producing and distributing safe drinking water.

“Sedimentation” means a process for removal of solids before filtration by gravity or separation.

“SEP” means special exception permit (Section 611.110).

“Service connection,” as used in the definition of public water system, does not include a connection to a system that delivers water by a constructed conveyance other than a pipe if any of the following is true:

The water is used exclusively for purposes other than residential use (consisting of drinking, bathing, and cooking, or other similar uses);

The Agency determines by issuing a SEP that alternative water for residential use or similar uses for drinking and cooking is provided to achieve the equivalent level of public health protection provided by the applicable national primary drinking water regulations; or

The Agency determines by issuing a SEP that the water provided for residential use or similar uses for drinking, cooking, and bathing is centrally treated or treated at the point of entry by the provider, a pass-through entity, or the user to achieve the equivalent level of protection provided by the applicable national primary drinking water regulations.

BOARD NOTE: See sections 1401(4)(B)(i)(II) and (4)(B)(i)(III) of SDWA (42 USC 300f(4)(B)(i)(II) and (4)(B)(i)(III) (2000)).

“Slow sand filtration” means a process involving passage of raw water through a bed of sand at low velocity (generally less than 0.4 meters per hour (m/h)) resulting in substantial particulate removal by physical and biological mechanisms.

“SOC” or “Synthetic organic chemical contaminant” refers to that group of contaminants designated as “SOCs,” or “synthetic organic chemicals” or “synthetic organic contaminants,” in USEPA regulatory discussions and guidance documents. “SOCs” include alachlor, aldicarb, aldicarb sulfone, aldicarb sulfoxide, atrazine, benzo(a)pyrene, carbofuran, chlordane, dalapon, dibromoethylene (ethylene dibromide or EDB), dibromochloropropane (DBCP), di(2-ethylhexyl)adipate, di(2-ethylhexyl)phthalate, dinoseb, diquat, endothall, endrin, glyphosate, heptachlor, heptachlor epoxide, hexachlorobenzene, hexachlorocyclopentadiene, lindane, methoxychlor, oxamyl, pentachlorophenol, picloram, simazine, toxaphene, polychlorinated biphenyls (PCBs), 2,4-D, 2,3,7,8-TCDD, and 2,4,5-TP.

BOARD NOTE: See the Board note appended to Section 611.311 for information relating to implementation of requirements relating to aldicarb, aldicarb sulfone, and aldicarb sulfoxide.

“Source” means a well, reservoir, or other source of raw water.

“Special irrigation district” means an irrigation district in existence prior to May 18, 1994 that provides primarily agricultural service through a piped water system with only incidental residential use or similar use, where the system or the residential users or similar users of the system comply with either of the following exclusion conditions:

The Agency determines by issuing a SEP that alternative water is provided for residential use or similar uses for drinking or cooking to achieve the equivalent level of public health protection provided by the applicable national primary drinking water regulations; or

The Agency determines by issuing a SEP that the water provided for residential use or similar uses for drinking, cooking, and bathing is centrally treated or treated at the point of entry by the provider, a pass-through entity, or the user to achieve the equivalent level of protection provided by the applicable national primary drinking water regulations.

BOARD NOTE: Derived from 40 CFR 141.2-~~(2002)~~ (2003) and sections 1401(4)(B)(i)(II) and (4)(B)(i)(III) of SDWA (42 USC 300f(4)(B)(i)(II) and (4)(B)(i)(III) (2000)).

“Standard sample” means the aliquot of finished drinking water that is examined for the presence of coliform bacteria.

“Subpart B system” means a public water system that uses surface water or groundwater under the direct influence of surface water as a source and which is subject to the requirements of Subpart B of this Part and the analytical and monitoring requirements of Sections 611.531, 611.532, 611.533, Appendix B of this Part, and Appendix C of this Part.

“Supplier of water” or “supplier” means any person who owns or operates a public water system (PWS). This term includes the “official custodian.”

“Surface water” means all water that is open to the atmosphere and subject to surface runoff.

“SUVA” means specific ultraviolet absorption at 254 nanometers (nm), which is an indicator of the humic content of water. It is a calculated parameter obtained by dividing a sample’s ultraviolet absorption at a wavelength of 254 nm (UV_{254}) (in m^{-1}) by its concentration of dissolved organic carbon (in mg/l).

“SWS” means “surface water system,” a public water supply (PWS) that uses only surface water sources, including “groundwater under the direct influence of surface water.”

BOARD NOTE: Derived from 40 CFR 141.23(b)(2) and 141.24(f)(2) note-~~(2002)~~ (2003).

“System with a single service connection” means a system that supplies drinking water to consumers via a single service line.

“Too numerous to count” means that the total number of bacterial colonies exceeds 200 on a 47-mm diameter membrane filter used for coliform detection.

“Total organic carbon” or “TOC” means total organic carbon (in mg/ℓ) measured using heat, oxygen, ultraviolet irradiation, chemical oxidants, or combinations of these oxidants that convert organic carbon to carbon dioxide, rounded to two significant figures.

“Total trihalomethanes” or “TTHM” means the sum of the concentration of trihalomethanes (THMs), in milligrams per liter (mg/ℓ), rounded to two significant figures.

BOARD NOTE: See the definition of “trihalomethanes” for a listing of the four compounds that USEPA considers TTHMs to comprise.

“Transient, non-community water system” or “transient non-CWS” means a non-CWS that does not regularly serve at least 25 of the same persons over six months of the year.

BOARD NOTE: The federal regulations apply to all “public water systems,” which are defined as all systems having at least 15 service connections or regularly serving water to at least 25 persons. (See 42 USC 300f(4).) The Act mandates that the Board and the Agency regulate “public water supplies,” which it defines as having at least 15 service connections or regularly serving 25 persons daily at least 60 days per year. (See Section 3.28 of the Act [415 ILCS 5/3.28].) The Department of Public Health regulates transient, non-community water systems.

“Treatment” means any process that changes the physical, chemical, microbiological, or radiological properties of water, is under the control of the supplier, and is not a point-of-use treatment device or a point-of-entry treatment device as defined in this Section. Treatment includes, but is not limited to, aeration, coagulation, sedimentation, filtration, activated carbon treatment, disinfection, and fluoridation.

“Trihalomethane” or “THM” means one of the family of organic compounds, named as derivatives of methane, in which three of the four hydrogen atoms in methane are each substituted by a halogen atom in the molecular structure. The THMs are the following compounds:

Trichloromethane (chloroform),

Dibromochloromethane,

Bromodichloromethane, and

Tribromomethane (bromoform)

“µg” means micrograms (1/1,000,000 of a gram).

“USEPA” means the U.S. Environmental Protection Agency.

“Uncovered finished water storage facility” is a tank, reservoir, or other facility that is open to the atmosphere and which is used to store water that will undergo no further treatment except residual disinfection.

“Virus” means a virus of fecal origin that is infectious to humans by waterborne transmission.

“VOC” or “volatile organic chemical contaminant” refers to that group of contaminants designated as “VOCs,” “volatile organic chemicals,” or “volatile organic contaminants,” in USEPA regulatory discussions and guidance documents. “VOCs” include benzene, dichloromethane, tetrachloromethane (carbon tetrachloride), trichloroethylene, vinyl chloride, 1,1,1-trichloroethane (methyl chloroform), 1,1-dichloroethylene, 1,2-dichloroethane, cis-1,2-dichloroethylene, ethylbenzene, monochlorobenzene, o-dichlorobenzene, styrene, 1,2,4-trichlorobenzene, 1,1,2-trichloroethane, tetrachloroethylene, toluene, trans-1,2-dichloroethylene, xylene, and 1,2-dichloropropane.

“Waterborne disease outbreak” means the significant occurrence of acute infectious illness, epidemiologically associated with the ingestion of water from a public water system (PWS) that is deficient in treatment, as determined by the appropriate local or State agency.

“Wellhead protection program” means the wellhead protection program for the State of Illinois, approved by USEPA under Section 1428 of the SDWA, 42 USC 300h-7. BOARD NOTE: Derived from 40 CFR 141.71(b)-(2002) (2003). The wellhead protection program includes the “groundwater protection needs assessment” under Section 17.1 of the Act [415 ILCS 5/17.1] and 35 Ill. Adm. Code 615-617.

BOARD NOTE: Derived from 40 CFR 141.2-(2002) (2003).

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.102 Incorporations by Reference

- a) Abbreviations and short-name listing of references. The following names and abbreviated names, presented in alphabetical order, are used in this Part to refer to materials incorporated by reference:

“Amco-AEPA-1 Polymer” is available from Advanced Polymer Systems.

“ASTM Method” means a method published by and available from the American Society for Testing and Materials (ASTM).

“Colisure Test” means “Colisure Presence/Absence Test for Detection and Identification of Coliform Bacteria and Escherichia Coli in Drinking Water,” available from Millipore Corporation, Technical Services Department.

“Dioxin and Furan Method 1613” means “Tetra- through Octa-Chlorinated Dioxins and Furans by Isotope-Dilution HRGC/HRMS,” available from NTIS.

“GLI Method 2” means GLI Method 2, “Turbidity,” Nov. 2, 1992, available from Great Lakes Instruments, Inc.

“Hach FilterTrak Method 10133” means “Determination of Turbidity by Laser Nephelometry,” available from Hach Co.

“HASL Procedure Manual” means HASL Procedure Manual, HASL 300, available from ERDA Health and Safety Laboratory.

“Kelada 01” means “Kelada Automated Test Methods for Total Cyanide, Acid Dissociable Cyanide, And Thiocyanate,” Revision 1.2, August 2001, EPA # 821-B-01-009, available from the National Technical Information Service (NTIS).

“Membrane Filter Technique using Chromocult Coliform Agar” means “Chromocult Coliform Agar Presence/Absence Membrane Filter Test Method for Detection and Identification of Coliform Bacteria and *Escherichia coli*-Escherichia coli in Finished Waters,” available from EM Science.

“NCRP” means “National Council on Radiation Protection.”

“NTIS” means “National Technical Information Service.”

“New Jersey Radium Method” means “Determination of Radium 228 in Drinking Water,” available from the New Jersey Department of Environmental Protection.

“New York Radium Method” means “Determination of Ra-226 and Ra-228 (Ra-02),” available from the New York Department of Public Health.

“ONGP-MUG Test” (meaning “minimal medium ortho-nitrophenyl-beta-d-galactopyranoside-4-methyl-umbelliferyl-beta-d-glucuronide test”), also

called the “Autoanalysis Colilert System,” is Method 9223, available in “Standard Methods for the Examination of Water and Wastewater,” 18th ed., from American Public Health Association.

“Palintest Method 1001” means “Method Number 1001,” available from Palintest, Ltd. or the Hach Company.

“QuikChem Method 10–204–00–1–X” means “Digestion and distillation of total cyanide in drinking and wastewaters using MICRO DIST and determination of cyanide by flow injection analysis,” available from Lachat Instruments.

“Readycult Coliforms 100 Presence/Absence Test” means “Readycult Coliforms 100 Presence/Absence Test for Detection and Identification of Coliform Bacteria and ~~*Escherichia coli*~~ *Escherichia coli* in Finished Waters,” available from EM Science.

“SimPlate Method” means “IDEXX SimPlate TM HPC Test Method for Heterotrophs in Water,” available from IDEXX Laboratories, Inc.

“Radiochemical Methods” means “Interim Radiochemical Methodology for Drinking Water,” available from NTIS.

“Standard Methods” means “Standard Methods for the Examination of Water and Wastewater,” available from the American Public Health Association or the American Waterworks Association.

“Syngenta AG-625” means “Atrazine in Drinking Water by Immunoassay,” February 2001 is available from Syngenta Crop Protection, Inc.

“Technical Bulletin 601” means “Technical Bulletin 601, Standard Method of Testing for Nitrate in Drinking Water,” July 1994, available from Analytical Technology, Inc.

“Technicon Methods” means “Fluoride in Water and Wastewater,” available from Bran & Luebbe.

“USDOE Manual” means “EML Procedures Manual,” available from the United State Department of Energy.

“USEPA Asbestos Methods-100.1” means Method 100.1, “Analytical Method for Determination of Asbestos Fibers in Water,” September 1983, available from NTIS.

“USEPA Asbestos Methods-100.2” means Method 100.2, “Determination

of Asbestos Structures over 10-mm in Length in Drinking Water,” June 1994, available from NTIS.

“USEPA Environmental Inorganics Methods” means “Methods for the Determination of Inorganic Substances in Environmental Samples,” August 1993, available from NTIS.

“USEPA Environmental Metals Methods” means “Methods for the Determination of Metals in Environmental Samples,” available from NTIS.

“USEPA Inorganic Methods” means “Methods for Chemical Analysis of Water and Wastes,” March 1983, available from NTIS.

“USEPA Interim Radiochemical Methods” means “Interim Radiochemical Methodology for Drinking Water,” EPA 600/4-75-008 (revised), March 1976. Available from NTIS.

“USEPA Organic Methods” means “Methods for the Determination of Organic Compounds in Drinking Water,” July 1991, for Methods 502.2, 505, 507, 508, 508A, 515.1, and 531.1; “Methods for the Determination of Organic Compounds in Drinking Water--Supplement I,” July 1990, for Methods 506, 547, 550, 550.1, and 551; and “Methods for the Determination of Organic Compounds in Drinking Water--Supplement II,” August 1992, for Methods 515.2, 524.2, 548.1, 549.1, 552.1, and 555, available from NTIS. Methods 504.1, 508.1, and 525.2 are available from EPA EMSL; “Methods for the Determination of Organic Compounds” in Drinking Water--Supplement II, August 1992, for Method 552.1; “Methods for the Determination of Organic Compounds in Drinking Water--Supplement III,” August 1995, for Methods 502.2, 524.2, 551.1, and 552.2. Method 515.4, “Determination of Chlorinated Acids in Drinking Water by Liquid-Liquid Microextraction, Derivatization and Fast Gas Chromatography with Electron Capture Detection,” Revision 1.0, April 2000, EPA 815/B-00/001, and Method 531.2, “Measurement of N-methylcarbamoyloximes and N-methylcarbamates in Water by Direct Aqueous Injection HPLC with Postcolumn Derivatization,” Revision 1.0, September 2001, EPA 815/B/01/002, are both available on-line from USEPA, Office of Ground Water and Drinking Water.

“USEPA Radioactivity Methods” means “Prescribed Procedures for Measurement of Radioactivity in Drinking Water,” EPA 600/4-80-032, August 1980. Available from NTIS.

“USEPA Radiochemical Analyses” means “Radiochemical Analytical Procedures for Analysis of Environmental Samples,” March 1979. Available from NTIS.

“USEPA Radiochemistry Methods” means “Radiochemistry Procedures Manual,” EPA 520/5-84-006, December 1987. Available from NTIS.

“USEPA Technical Notes” means “Technical Notes on Drinking Water Methods,” available from NTIS.

“USGS Methods” means “Methods of Analysis by the U.S. Geological Survey National Water Quality Laboratory--Determination of Inorganic and Organic Constituents in Water and Fluvial Sediments,” available from NTIS and USGS.

“Waters Method B-1011” means “Waters Test Method for the Determination of Nitrite/Nitrate in Water Using Single Column Ion Chromatography,” available from Waters Corporation, Technical Services Division.

- b) The Board incorporates the following publications by reference:

Advanced Polymer Systems, 3696 Haven Avenue, Redwood City, CA 94063 415-366-2626.

Amco-AEPA-1 Polymer. See 40 CFR 141.22(a)-~~(2002)~~ (2003). Also, as referenced in ASTM D1889.

American Public Health Association, 1015 Fifteenth Street NW, Washington, DC 20005 800-645-5476.

“Standard Methods for the Examination of Water and Wastewater,” 17th Edition, 1989 (referred to as “Standard Methods, 17th ed.”).

“Standard Methods for the Examination of Water and Wastewater,” 18th Edition, 1992, including “Supplement to the 18th Edition of Standard Methods for the Examination of Water and Wastewater,” 1994 (collectively referred to as “Standard Methods, 18th ed.”). See the methods listed separately for the same references under American Waterworks Association.

“Standard Methods for the Examination of Water and Wastewater,” 19th Edition, 1995 (referred to as “Standard Methods, 19th ed.”).

“Standard Methods for the Examination of Water and Wastewater,” 20th Edition, 1998 (referred to as “Standard Methods, 20th ed.”).

American Waterworks Association et al., 6666 West Quincy Ave., Denver, CO 80235 303-794-7711.

“National Field Evaluation of a Defined Substrate Method for the Simultaneous Enumeration of Total Coliforms and *Escherichia coli* for Drinking Water: Comparison with the Standard Multiple Tube Fermentation Method,” S.C. Edberg, M.J. Allen & D.B. Smith, *Applied Environmental Microbiology*, vol. 54, iss. 6, pp 1595-1601 (1988).

“Standard Methods for the Examination of Water and Wastewater,” 13th Edition, 1971 (referred to as “Standard Methods, 13th ed.”).

Method 302, Gross Alpha and Gross Beta Radioactivity in Water (Total, Suspended, and Dissolved).

Method 303, Total Radioactive Strontium and Strontium 90 in Water.

Method 304, Radium in Water by Precipitation.

Method 305, Radium 226 by Radon in Water (Soluble, Suspended, and Total).

Method 306, Tritium in Water.

“Standard Methods for the Examination of Water and Wastewater,” 17th Edition, 1989 (referred to as “Standard Methods, 17th ed.”).

Method 7110 B, Gross Alpha and Gross Beta Radioactivity in Water (Total, Suspended, and Dissolved).

Method 7500-Cs B, Radioactive Cesium, Precipitation Method.

Method 7500-³H B, Tritium in Water.

Method 7500-I B, Radioactive Iodine, Precipitation Method.

Method 7500-I C, Radioactive Iodine, Ion-Exchange Method.

Method 7500-I D, Radioactive Iodine, Distillation Method.

Method 7500-Ra B, Radium in Water by Precipitation.

Method 7500-Ra C, Radium 226 by Radon in Water (Soluble, Suspended, and Total).

Method 7500-Ra D, Radium, Sequential Precipitation Method (Proposed).

Method 7500-Sr B, Total Radioactive Strontium and Strontium 90 in Water.

Method 7500-U B, Uranium, Radiochemical Method (Proposed).

Method 7500-U C, Uranium, Isotopic Method (Proposed).

“Standard Methods for the Examination of Water and Wastewater,” 18th Edition, 1992 (referred to as “Standard Methods, 18th ed.”).

Method 2130 B, Turbidity, Nephelometric Method.

Method 2320 B, Alkalinity, Titration Method.

Method 2510 B, Conductivity, Laboratory Method.

Method 2550, Temperature, Laboratory and Field Methods.

Method 3111 B, Metals by Flame Atomic Absorption Spectrometry, Direct Air-Acetylene Flame Method.

Method 3111 D, Metals by Flame Atomic Absorption Spectrometry, Direct Nitrous Oxide-Acetylene Flame Method.

Method 3112 B, Metals by Cold-Vapor Atomic Absorption Spectrometry, Cold-Vapor Atomic Absorption Spectrometric Method.

Method 3113 B, Metals by Electrothermal Atomic Absorption Spectrometry, Electrothermal Atomic Absorption Spectrometric Method.

Method 3114 B, Metals by Hydride Generation/Atomic

Absorption Spectrometry, Manual Hydride
Generation/Atomic Absorption Spectrometric Method.

Method 3120 B, Metals by Plasma Emission Spectroscopy,
Inductively Coupled Plasma (ICP) Method.

Method 3500-Ca D, Calcium, EDTA Titrimetric Method.

Method 3500-Mg E, Magnesium, Calculation Method.

Method 4110 B, Determination of Anions by Ion
Chromatography, Ion Chromatography with Chemical
Suppression of Eluent Conductivity.

Method 4500-CN⁻ C, Cyanide, Total Cyanide after
Distillation.

Method 4500-CN⁻ E, Cyanide, Colorimetric Method.

Method 4500-CN⁻ F, Cyanide, Cyanide-Selective Electrode
Method.

Method 4500-CN⁻ G, Cyanide, Cyanides Amenable to
Chlorination after Distillation.

Method 4500-Cl D, Chlorine, Amperometric Titration
Method.

Method 4500-Cl E, Chlorine, Low-Level Amperometric
Titration Method.

Method 4500-Cl F, Chlorine, DPD Ferrous Titrimetric
Method.

Method 4500-Cl G, Chlorine, DPD Colorimetric Method.

Method 4500-Cl H, Chlorine, Syringaldazine (FACTS)
Method.

Method 4500-Cl I, Chlorine, Iodometric Electrode Method.

Method 4500-ClO₂ C, Chlorine Dioxide, Amperometric
Method I.

Method 4500-ClO₂ D, Chlorine Dioxide, DPD Method.

Method 4500-ClO₂ E, Chlorine Dioxide, Amperometric Method II (Proposed).

Method 4500-F⁻ B, Fluoride, Preliminary Distillation Step.

Method 4500-F⁻ C, Fluoride, Ion-Selective Electrode Method.

Method 4500-F⁻ D, Fluoride, SPADNS Method.

Method 4500-F⁻ E, Fluoride, Complexone Method.

Method 4500-H⁺ B, pH Value, Electrometric Method.

Method 4500-NO₂⁻ B, Nitrogen (Nitrite), Colorimetric Method.

Method 4500-NO₃⁻ D, Nitrogen (Nitrate), Nitrate Electrode Method.

Method 4500-NO₃⁻ E, Nitrogen (Nitrate), Cadmium Reduction Method.

Method 4500-NO₃⁻ F, Nitrogen (Nitrate), Automated Cadmium Reduction Method.

Method 4500-O₃ B, Ozone (Residual) (Proposed), Indigo Colorimetric Method.

Method 4500-P E, Phosphorus, Ascorbic Acid Method.

Method 4500-P F, Phosphorus, Automated Ascorbic Acid Reduction Method.

Method 4500-Si D, Silica, Molybdosilicate Method.

Method 4500-Si E, Silica, Heteropoly Blue Method.

Method 4500-Si F, Silica, Automated Method for Molybdate-Reactive Silica.

Method 6651, Glyphosate Herbicide (Proposed).

Method 7110 B, Gross Alpha and Beta Radioactivity (Total, Suspended, and Dissolved), Evaporation Method for Gross Alpha-Beta.

Method 7110 C, Gross Alpha and Beta Radioactivity (Total, Suspended, and Dissolved), Coprecipitation Method for Gross Alpha Radioactivity in Drinking Water (Proposed).

Method 7500-Cs B, Radioactive Cesium, Precipitation Method.

Method 7500-³H B, Tritium, Liquid Scintillation Spectrometric Method.

Method 7500-I B, Radioactive Iodine, Precipitation Method.

Method 7500-I C, Radioactive Iodine, Ion-Exchange Method.

Method 7500-I D, Radioactive Iodine, Distillation Method.

Method 7500-Ra B, Radium, Precipitation Method.

Method 7500-Ra C, Radium, Emanation Method.

Method 7500-Ra D, Radium, Sequential Precipitation Method (Proposed).

Method 7500-Sr B, Total ~~Radioactive~~ Radioactive Strontium and Strontium 90, Precipitation Method.

Method 7500-U B, Uranium, Radiochemical Method (Proposed).

Method 7500-U C, Uranium, Isotopic Method (Proposed).

Method 9215 B, Heterotrophic Plate Count, Pour Plate Method.

Method 9221 A, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Introduction.

Method 9221 B, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Standard Total Coliform Fermentation Technique.

Method 9221 C, Multiple-Tube Fermentation Technique

for Members of the Coliform Group, Estimation of Bacterial Density.

Method 9221 D, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Presence-Absence (P-A) Coliform Test.

Method 9221 E, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Fecal Coliform Procedure.

Method 9222 A, Membrane Filter Technique for Members of the Coliform Group, Introduction.

Method 9222 B, Membrane Filter Technique for Members of the Coliform Group, Standard Total Coliform Membrane Filter Procedure.

Method 9222 C, Membrane Filter Technique for Members of the Coliform Group, Delayed-Incubation Total Coliform Procedure.

Method 9222 D, Membrane Filter Technique for Members of the Coliform Group, Fecal Coliform Membrane Filter Procedure.

Method 9223, Chromogenic Substrate Coliform Test (Proposed).

“Supplement to the 18th Edition of Standard Methods for the Examination of Water and Wastewater,” American Public Health Association, 1994.

Method 6610, Carbamate Pesticide Method.

“Standard Methods for the Examination of Water and Wastewater,” 19th Edition, 1995 (referred to as “Standard Methods, 19th ed.”).

Method 2130 B, Turbidity, Nephelometric Method.

Method 2320 B, Alkalinity, Titration Method.

Method 2510 B, Conductivity, Laboratory Method.

Method 2550, Temperature, Laboratory, and Field

Methods.

Method 3111 B, Metals by Flame Atomic Absorption Spectrometry, Direct Air-Acetylene Flame Method.

Method 3111 D, Metals by Flame Atomic Absorption Spectrometry, Direct Nitrous Oxide-Acetylene Flame Method.

Method 3112 B, Metals by Cold-Vapor Atomic Absorption Spectrometry, Cold-Vapor Atomic Absorption Spectrometric Method.

Method 3113 B, Metals by Electrothermal Atomic Absorption Spectrometry, Electrothermal Atomic Absorption Spectrometric Method.

Method 3114 B, Metals by Hydride Generation/Atomic Absorption Spectrometry, Manual Hydride Generation/Atomic Absorption Spectrometric Method.

Method 3120 B, Metals by Plasma Emission Spectroscopy, Inductively Coupled Plasma (ICP) Method.

Method 3500-Ca D, Calcium, EDTA Titrimetric Method.

Method 3500-Mg E, Magnesium, Calculation Method.

Method 4110 B, Determination of Anions by Ion Chromatography, Ion Chromatography with Chemical Suppression of Eluent Conductivity.

Method 4500-Cl D, Chlorine, Amperometric Titration Method.

Method 4500-Cl E, Chlorine, Low-Level Amperometric Titration Method.

Method 4500-Cl F, Chlorine, DPD Ferrous Titrimetric Method.

Method 4500-Cl G, Chlorine, DPD Colorimetric Method.

Method 4500-Cl H, Chlorine, Syringaldazine (FACTS) Method.

Method 4500-Cl I, Chlorine, Iodometric Electrode Method.

Method 4500-ClO₂ C, Chlorine Dioxide, Amperometric Method I.

Method 4500-ClO₂ D, Chlorine Dioxide, DPD Method.

Method 4500-ClO₂ E, Chlorine Dioxide, Amperometric Method II (Proposed).

Method 4500-CN⁻ C, Cyanide, Total Cyanide after Distillation.

Method 4500-CN⁻ E, Cyanide, Colorimetric Method.

Method 4500-CN⁻ F, Cyanide, Cyanide-Selective Electrode Method.

Method 4500-CN⁻ G, Cyanide, Cyanides Amenable to Chlorination after Distillation.

Method 4500-F⁻ B, Fluoride, Preliminary Distillation Step.

Method 4500-F⁻ C, Fluoride, Ion-Selective Electrode Method.

Method 4500-F⁻ D, Fluoride, SPADNS Method.

Method 4500-F⁻ E, Fluoride, Complexone Method.

Method 4500-H⁺ B, pH Value, Electrometric Method.

Method 4500-NO₂⁻ B, Nitrogen (Nitrite), Colorimetric Method.

Method 4500-NO₃⁻ D, Nitrogen (Nitrate), Nitrate Electrode Method.

Method 4500-NO₃⁻ E, Nitrogen (Nitrate), Cadmium Reduction Method.

Method 4500-NO₃⁻ F, Nitrogen (Nitrate), Automated Cadmium Reduction Method.

Method 4500-O₃ B, Ozone (Residual) (Proposed), Indigo Colorimetric Method.

Method 4500-P E, Phosphorus, Ascorbic Acid Method.

Method 4500-P F, Phosphorus, Automated Ascorbic Acid Reduction Method.

Method 4500-Si D, Silica, Molybdosilicate Method.

Method 4500-Si E, Silica, Heteropoly Blue Method.

Method 4500-Si F, Silica, Automated Method for Molybdate-Reactive Silica.

Method 5910 B, UV Absorbing Organic Constituents, Ultraviolet Absorption Method.

Method 6251 B, Disinfection Byproducts: Haloacetic Acids and Trichlorophenol, Micro Liquid-Liquid Extraction Gas Chromatographic Method.

Method 6651, Glyphosate Herbicide (Proposed).

Method 7110 B, Gross Alpha and Gross Beta Radioactivity, Evaporation Method for Gross Alpha-Beta.

Method 7110 C, Gross Alpha and Beta Radioactivity (Total, Suspended, and Dissolved), Coprecipitation Method for Gross Alpha Radioactivity in Drinking Water (Proposed).

Method 7120 B, Gamma-Emitting Radionuclides, Gamma Spectrometric Method.

Method 7500-Cs B, Radioactive Cesium, Precipitation Method.

Method 7500-3H B, Tritium, Liquid Scintillation Spectrometric Method.

Method 7500-I B, Radioactive Iodine, Precipitation Method.

Method 7500-I C, Radioactive Iodine, Ion-Exchange Method.

Method 7500-I D, Radioactive Iodine, Distillation Method.

Method 7500-Ra B, Radium, Precipitation Method.

Method 7500-Ra C, Radium, Emanation Method.

Method 7500-Ra D, Radium, Sequential Precipitation Method.

Method 7500-Sr B, Total Radiactive Strontium and Strontium 90, Precipitation Method.

Method 7500-U B, Uranium, Radiochemical Method.

Method 7500-U C, Uranium, Isotopic Method.

Method 9215 B, Heterotrophic Plate Count, Pour Plate Method.

Method 9221 A, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Introduction.

Method 9221 B, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Standard Total Coliform Fermentation Technique.

Method 9221 C, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Estimation of Bacterial Density.

Method 9221 D, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Presence-Absence (P-A) Coliform Test.

Method 9221 E, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Fecal Coliform Procedure.

Method 9222 A, Membrane Filter Technique for Members of the Coliform Group, Introduction.

Method 9222 B, Membrane Filter Technique for Members of the Coliform Group, Standard Total Coliform Membrane Filter Procedure.

Method 9222 C, Membrane Filter Technique for Members of the Coliform Group, Delayed-Incubation Total Coliform

Procedure.

Method 9222 D, Membrane Filter Technique for Members of the Coliform Group, Fecal Coliform Membrane Filter Procedure.

Method 9223, Chromogenic Substrate Coliform Test (Proposed).

“Supplement to the 19th Edition of Standard Methods for the Examination of Water and Wastewater,” American Public Health Association, 1996.

Method 5310 B, TOC, Combustion-Infrared Method.

Method 5310 C, TOC, Persulfate-Ultraviolet Oxidation Method.

Method 5310 D, TOC, Wet-Oxidation Method.

“Standard Methods for the Examination of Water and Wastewater,” 20th Edition, 1998 (referred to as “Standard Methods, 20th ed.”).

Method 2130 B, Turbidity, Nephelometric Method.

Method 2320 B, Alkalinity, Titration Method.

Method 2510 B, Conductivity, Laboratory Method.

Method 2550, Temperature, Laboratory, and Field Methods.

Method 3120 B, Metals by Plasma Emission Spectroscopy, Inductively Coupled Plasma (ICP) Method.

Method 3500-Ca B, Calcium, EDTA Titrimetric Method.

Method 3500-Mg B, Magnesium, EDTA Titrimetric Method.

Method 4110 B, Determination of Anions by Ion Chromatography, Ion Chromatography with Chemical Suppression of Eluent Conductivity.

Method 4500-CN⁻ C, Cyanide, Total Cyanide after

Distillation.

Method 4500-CN⁻ E, Cyanide, Colorimetric Method.

Method 4500-CN⁻ F, Cyanide, Cyanide-Selective Electrode Method.

Method 4500-CN⁻ G, Cyanide, Cyanides Amenable to Chlorination after Distillation.

Method 4500-Cl D, Chlorine, Amperometric Titration Method.

Method 4500-Cl E, Chlorine, Low-Level Amperometric Titration Method.

Method 4500-Cl F, Chlorine, DPD Ferrous Titrimetric Method.

Method 4500-Cl G, Chlorine, DPD Colorimetric Method.

Method 4500-Cl H, Chlorine, Syringaldazine (FACTS) Method.

Method 4500-Cl I, Chlorine, Iodometric Electrode Method.

Method 4500-ClO₂ C, Chlorine Dioxide, Amperometric Method I.

Method 4500-ClO₂ D, Chlorine Dioxide, DPD Method.

Method 4500-ClO₂ E, Chlorine Dioxide, Amperometric Method II (Proposed).

Method 4500-F⁻ B, Fluoride, Preliminary Distillation Step.

Method 4500-F⁻ C, Fluoride, Ion-Selective Electrode Method.

Method 4500-F⁻ D, Fluoride, SPADNS Method.

Method 4500-F⁻ E, Fluoride, Complexone Method.

Method 4500-H⁺ B, pH Value, Electrometric Method.

Method 4500-NO₂⁻ B, Nitrogen (Nitrite), Colorimetric

Method.

Method 4500-NO₃⁻ D, Nitrogen (Nitrate), Nitrate Electrode Method.

Method 4500-NO₃⁻ E, Nitrogen (Nitrate), Cadmium Reduction Method.

Method 4500-NO₃⁻ F, Nitrogen (Nitrate), Automated Cadmium Reduction Method.

Method 4500-O₃ B, Ozone (Residual) (Proposed), Indigo Colorimetric Method.

Method 4500-P E, Phosphorus, Ascorbic Acid Method.

Method 4500-P F, Phosphorus, Automated Ascorbic Acid Reduction Method.

Method 4500-Si C, Silica, Molybdosilicate Method.

Method 4500-Si D, Silica, Heteropoly Blue Method.

Method 4500-Si E, Silica, Automated Method for Molybdate-Reactive Silica.

Method 4500-Cl E, Chlorine (Residual), Low-Level Amperometric Titration Method.

Method 4500-Cl F, Chlorine (Residual), DPD Ferrous Titrimetric Method.

Method 4500-Cl G, Chlorine (Residual), DPD Colorimetric Method.

Method 4500-Cl H, Chlorine (Residual), Syringaldazine (FACTS) Method.

Method 4500-Cl I, Chlorine (Residual), Iodometric Electrode Technique.

Method 4500-ClO₂ D, Chlorine Dioxide, DPD Method.

Method 4500-ClO₂ E, Chlorine Dioxide, Amperometric Method II.

Method 6651, Glyphosate Herbicide (Proposed).

Method 7110-B, Gross Alpha and Gross Beta Radioactivity, Evaporation Method for Gross Alpha-Beta.

Method 7110 C, Gross Alpha and Beta Radioactivity (Total, Suspended, and Dissolved), Coprecipitation Method for Gross Alpha Radioactivity in Drinking Water (Proposed).

Method 7120-B, Gamma-Emitting Radionuclides, Gamma Spectrometric Method.

Method 7500-Cs B, Radioactive Cesium, Precipitation Method.

Method 7500-3H B, Tritium, Liquid Scintillation Spectrometric Method.

Method 7500-I B, Radioactive Iodine, Precipitation Method.

Method 7500-I C, Radioactive Iodine, Ion-Exchange Method.

Method 7500-I D, Radioactive Iodine, Distillation Method.

Method 7500-Ra B, Radium, Precipitation Method.

Method 7500-Ra C, Radium, Emanation Method.

Method 7500-Sr B, Total Radiactive Strontium and Strontium 90, Precipitation Method.

Method 7500-U B, Uranium, Radiochemical Method.

Method 7500-U C, Uranium, Isotopic Method.

Method 9215 B, Heterotrophic Plate Count, Pour Plate Method.

Method 9221 A, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Introduction.

Method 9221 B, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Standard Total

Coliform Fermentation Technique.

Method 9221 C, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Estimation of Bacterial Density.

Method 9221 D, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Presence-Absence (P-A) Coliform Test.

Method 9221 E, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Fecal Coliform Procedure.

Method 9222 A, Membrane Filter Technique for Members of the Coliform Group, Introduction.

Method 9222 B, Membrane Filter Technique for Members of the Coliform Group, Standard Total Coliform Membrane Filter Procedure.

Method 9222 C, Membrane Filter Technique for Members of the Coliform Group, Delayed-Incubation Total Coliform Procedure.

Method 9222 D, Membrane Filter Technique for Members of the Coliform Group, Fecal Coliform Membrane Filter Procedure.

Method 9223, Chromogenic Substrate Coliform Test (Proposed).

Analytical Technology, Inc. ATI Orion, 529 Main Street, Boston, MA 02129.

Technical Bulletin 601, "Standard Method of Testing for Nitrate in Drinking Water," July, 1994, PN 221890-001 (referred to as "Technical Bulletin 601").

ASTM. American Society for Testing and Materials, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959 610-832-9585.

ASTM Method D511-93 A and B, "Standard Test Methods for Calcium and Magnesium in Water," "Test Method A--Complexometric Titration" & "Test Method B--Atomic Absorption Spectrophotometric," approved 1993.

ASTM Method D515-88 A, "Standard Test Methods for Phosphorus in Water," "Test Method A--Colorimetric Ascorbic Acid Reduction," approved August 19, 1988.

ASTM Method D859-88, "Standard Test Method for Silica in Water," approved August 19, 1988.

ASTM Method D1067-92 B, "Standard Test Methods for Acidity or Alkalinity in Water," "Test Method B--Electrometric or Color-Change Titration," approved May 15, 1992.

ASTM Method D1125-91 A, "Standard Test Methods for Electrical Conductivity and Resistivity of Water," "Test Method A--Field and Routine Laboratory Measurement of Static (Non-Flowing) Samples," approved June 15, 1991.

ASTM Method D1179-93 B, "Standard Test Methods for Fluoride in Water," "Test Method B--Ion Selective Electrode," approved 1993.

ASTM Method D1293-84, "Standard Test Methods for pH of Water," "Test Method A--Precise Laboratory Measurement" & "Test Method B--Routine or Continuous Measurement," approved October 26, 1984.

ASTM Method D1688-90 A or C, "Standard Test Methods for Copper in Water," "Test Method A--Atomic Absorption, Direct" & "Test Method C--Atomic Absorption, Graphite Furnace," approved March 15, 1990.

ASTM Method D2036-91 A or B, "Standard Test Methods for Cyanide in Water," "Test Method A--Total Cyanides after Distillation" & "Test Method B--Cyanides Amenable to Chlorination by Difference," approved September 15, 1991.

ASTM Method D2459-72, "Standard Test Method for Gamma Spectrometry in Water," approved July 28, 1972, discontinued 1988.

ASTM Method D2460-90, "Standard Test Method for Radionuclides of Radium in Water," approved 1990.

ASTM Method D2907-91, "Standard Test Methods for Microquantities of Uranium in Water by Fluorometry," "Test Method A--Direct Fluorometric" & "Test Method B—Extraction,"

approved June 15, 1991.

ASTM Method D2972-93 B or C, "Standard Test Methods for Arsenic in Water," "Test Method B--Atomic Absorption, Hydride Generation" & "Test Method C--Atomic Absorption, Graphite Furnace," approved 1993.

ASTM Method D3223-91, "Standard Test Method for Total Mercury in Water," approved September 23, 1991.

ASTM Method D3454-91, "Standard Test Method for Radium-226 in Water," approved 1991.

ASTM Method D3559-90 D, "Standard Test Methods for Lead in Water," "Test Method D--Atomic Absorption, Graphite Furnace," approved August 6, 1990.

ASTM Method D3645-93 B, "Standard Test Methods for Beryllium in Water," "Method B--Atomic Absorption, Graphite Furnace," approved 1993.

ASTM Method D3649-91, "Standard Test Method for High-Resolution Gamma-Ray Spectrometry of Water," approved 1991.

ASTM Method D3697-92, "Standard Test Method for Antimony in Water," approved June 15, 1992.

ASTM Method D3859-93 A, "Standard Test Methods for Selenium in Water," "Method A--Atomic Absorption, Hydride Method," approved 1993.

ASTM Method D3867-90 A and B, "Standard Test Methods for Nitrite-Nitrate in Water," "Test Method A--Automated Cadmium Reduction" & "Test Method B--Manual Cadmium Reduction," approved January 10, 1990.

ASTM Method D3972-90, "Standard Test Method for Isotopic Uranium in Water by Radiochemistry," approved 1990.

ASTM Method D4107-91, "Standard Test Method for Tritium in Drinking Water," approved 1991.

ASTM Method D4327-91, "Standard Test Method for Anions in Water by Ion Chromatography," approved October 15, 1991.

ASTM Method D4785-88, "Standard Test Method for Low-Level

Iodine-131 in Water,” approved 1988.

ASTM Method D5174-91, “Standard Test Method for Trace Uranium in Water by Pulsed-Laser Phosphorimetry,” approved 1991.

ASTM Method D 1253-86, “Standard Test Method for Residual Chlorine in Water,” reapproved 1992.

Bran & Luebbe, 1025 Busch Parkway, Buffalo Grove, IL 60089.

“Fluoride in Water and Wastewater,” Industrial Method #129-71W, December 1972 (referred to as “Technicon Methods: Method #129-71W”). See 40 CFR 141.23(k)(1), footnote 11 (~~2002~~) (2003).

“Fluoride in Water and Wastewater,” #380-75WE, February 1976 (referred to as “Technicon Methods: Method #380-75WE”). See 40 CFR 141.23(k)(1), footnote 11 (~~2002~~) (2003).

EM Science (an affiliate of Merck KGaA, Darmstadt, Germany), 480 S. Democrat Road, Gibbstown, NJ 08027-1297. Telephone: 800-222-0342. E-mail: adellenbusch@emscience.com.

“Chromocult Coliform Agar Presence/Absence Membrane Filter Test Method for Detection and Identification of Coliform Bacteria and *Escherichia coli* Escherichia coli in Finished Waters,”; November 2000, Version 1.0.

“Readycult Coliforms 100 Presence/Absence Test for Detection and Identification of Coliform Bacteria and *Escherichia coli* Escherichia coli in Finished Waters,”; November 2000, Version 1.0.

ERDA Health and Safety Laboratory, New York, NY.

HASL Procedure Manual, HASL 300, 1973. See 40 CFR 141.25(b)(2) (~~2002~~) (2003).

Great Lakes Instruments, Inc., 8855 North 55th Street, Milwaukee, WI 53223.

GLI Method 2, “Turbidity,” Nov. 2, 1992.

The Hach Company, P.O. Box 389, Loveland, CO 80539-0389. Phone: 800-227-4224.

“Lead in Drinking Water by Differential Pulse Anodic Stripping Voltammetry,” Method 1001, August 1999.

“Determination of Turbidity by Laser Nephelometry,” January 2000, Revision 2.0 (referred to as “Hach FilterTrak Method 10133”).

IDEXX Laboratories, Inc., One IDEXX Drive, Westbrook, Maine 04092.
Telephone: 800-321-0207.

“IDEXX SimPlate™ HPC Test Method for Heterotrophs in Water,” November 2000.

Lachat Instruments, 6645 W. Mill Rd., Milwaukee, WI 53218. Phone:
414-358-4200.

“Digestion and distillation of total cyanide in drinking and wastewaters using MICRO DIST and determination of cyanide by flow injection analysis,” Revision 2.1, November 30, 2000 (referred to as “QuikChem Method 10-204-00-1-X”).

Millipore Corporation, Technical Services Department, 80 Ashby Road,
Milford, MA 01730 800-654-5476.

Colisure Presence/Absence Test for Detection and Identification of Coliform Bacteria and Escherichia Coli in Drinking Water, February 28, 1994 (referred to as “Colisure Test”).

NCRP. National Council on Radiation Protection, 7910 Woodmont Ave.,
Bethesda, MD 301-657-2652.

“Maximum Permissible Body Burdens and Maximum Permissible Concentrations of Radionuclides in Air and in Water for Occupational Exposure,” NCRP Report Number 22, June 5, 1959.

NSF. National Sanitation Foundation International, 3475 Plymouth Road,
PO Box 130140, Ann Arbor, Michigan 48113-0140, 734-769-8010.

NSF Standard 61, section 9, November 1998.

NTIS. National Technical Information Service, U.S. Department of Commerce, 5285 Port Royal Road, Springfield, VA 22161, 703-487-4600 or 800-553-6847.

“Interim Radiochemical Methodology for Drinking Water,” EPA

600/4-75-008 (revised), March 1976 (referred to as “USEPA Interim Radiochemical Methods”). (Pages 1, 4, 6, 9, 13, 16, 24, 29, 34)

“Kelada Automated Test Methods for Total Cyanide, Acid Dissociable Cyanide, And Thiocyanate₂”, Revision 1.2, August 2001, EPA # 821-B-01-009 (referred to as “~~Kaleda~~ Kelada 01”).

“Maximum Permissible Body Burdens and Maximum Permissible Concentrations of Radionuclides in Air and in Water for Occupational Exposure,” NBS (National Bureau of Standards) Handbook 69, as amended August 1963, U.S. Department of Commerce.

Method 100.1, “Analytical Method for Determination of Asbestos Fibers in Water,” EPA-600/4-83-043, September 1983, Doc. No. PB83-260471 (referred to as “USEPA Asbestos Methods-100.1”).

Method 100.2, “Determination of Asbestos Structures over 10-mm in Length in Drinking Water,” EPA-600/4-83-043, June 1994, Doc. No. PB94-201902 (referred to as “USEPA Asbestos Methods-100.2”).

“Methods for Chemical Analysis of Water and Wastes,” March 1983, Doc. No. PB84-128677 (referred to as “USEPA Inorganic Methods”). (Methods 150.1, 150.2, and 245.2, which formerly appeared in this reference, are available from USEPA EMSL.)

“Methods for the Determination of Inorganic Substances in Environmental Samples,” August 1993, PB94-120821 (referred to as “USEPA Environmental Inorganic Methods”).

“Methods for the Determination of Metals in Environmental Samples,” June 1991, Doc. No. PB91-231498 and “Methods for the Determination of Metals in Environmental Samples--Supplement I,” May 1994, PB95-125472 (referred to as “USEPA Environmental Metals Methods”).

“Methods for the Determination of Organic Compounds in Drinking Water,” December 1988, revised July 1991, EPA-600/4-88/039 (referred to as “USEPA Organic Methods”). (For methods 502.2, 505, 507, 508, 508A, 515.1, and 531.1.)

“Methods for the Determination of Organic Compounds in Drinking Water--Supplement I,” July 1990, EPA/600-4-90-020 (referred to as “USEPA Organic Methods”). (For methods 506,

547, 550, 550.1, and 551.)

“Methods for the Determination of Organic Compounds in Drinking Water--Supplement II,” August 1992, EPA-600/R-92-129 (referred to as “USEPA Organic Methods”). (For methods 515.2, 524.2, 548.1, 549.1, 552.1, and 555.)

“Prescribed Procedures for Measurement of Radioactivity in Drinking Water,” EPA 600/4-80-032, August 1980 (referred to as “USEPA Radioactivity Methods”). (Methods 900, 901, 901.1, 902, 903, 903.1, 904, 905, 906, 908, 908.1)

“Procedures for Radiochemical Analysis of Nuclear Reactor Aqueous Solutions,” H.L. Krieger and S. Gold, EPA-R4-73-014, May 1973, Doc. No. PB222-154/7BA.

“Radiochemical Analytical Procedures for Analysis of Environmental Samples,” March 1979, Doc. No. EMSL LV 053917 (referred to as “USEPA Radiochemical Analyses”). (Pages 1, 19, 33, 65, 87, 92)

“Radiochemistry Procedures Manual,” EPA-520/5-84-006, December 1987, Doc. No. PB-84-215581 (referred to as “USEPA Radiochemistry Methods”). (Methods 00-01, 00-02, 00-07, H-02, Ra-03, Ra-04, Ra-05, Sr-04)

“Technical Notes on Drinking Water Methods,” EPA-600/R-94-173, October 1994, Doc. No. PB-104766 (referred to as “USEPA Technical Notes”).

BOARD NOTE: USEPA made the following assertion with regard to this reference at 40 CFR 141.23(k)(1) and 141.24(e) and (n)(11)-~~(2002)~~ (2003): “This document contains other analytical test procedures and approved analytical methods that remain available for compliance monitoring until July 1, 1996.”

“Tetra- through Octa-Chlorinated Dioxins and Furans by Isotope Dilution HRGC/HRMS,” October 1994, EPA-821-B-94-005 (referred to as “Dioxin and Furan Method 1613”).

New Jersey Department of Environment, Division of Environmental Quality, Bureau of Radiation and Inorganic Analytical Services, 9 Ewing Street, Trenton, NJ 08625.

“Determination of Radium 228 in Drinking Water,” August 1990.

New York Department of Health, Radiological Sciences Institute, Center for Laboratories and Research, Empire State Plaza, Albany, NY 12201.

“Determination of Ra-226 and Ra-228 (Ra-02),” January 1980, Revised June 1982.

Palintest, Ltd., 21 Kenton Lands Road, P.O. Box 18395, Erlanger, KY 800-835-9629.

“Lead in Drinking Water by Differential Pulse Anodic Stripping Voltammetry,” Method 1001, August 1999.

Syngenta Crop Protection, Inc., 410 Swing Road, Post Office Box 18300, Greensboro, NC 27419. Telephone: 336-632-6000.

“Atrazine in Drinking Water by Immunoassay,” February 2001 (referred to as “Syngenta AG-625”).

United States Department of Energy, available at the Environmental Measurements Laboratory, U.S. Department of Energy, 376 Hudson Street, New York, NY 10014-3621.

“EML Procedures Manual,” 27th Edition, Volume 1, 1990.

United States Environmental Protection Agency, Office of Ground Water and Drinking Water, accessible on-line and available by download from <http://www.epa.gov/safewater/methods/>.

Method 515.4, “Determination of Chlorinated Acids in Drinking Water by Liquid-Liquid Microextraction, Derivatization and Fast Gas Chromatography with Electron Capture Detection,” Revision 1.0, April 2000, EPA 815/B-00/001 (document file name “met515_4.pdf”).

Method 531.2, “Measurement of N-methylcarbamoyloximes and N-methylcarbamates in Water by Direct Aqueous Injection HPLC with Postcolumn Derivatization,” Revision 1.0, September 2001, EPA 815/B/01/002 (document file name “met531_2.pdf”).

United States Environmental Protection Agency, EMSL, Cincinnati, OH 45268 513-569-7586.

“Interim Radiochemical Methodology for Drinking Water,” EPA-600/4-75-008 (referred to as “Radiochemical Methods”). (Revised) March 1976.

“Methods for the Determination of Organic Compounds in Finished Drinking Water and Raw Source Water” (referred to as “USEPA Organic Methods”). (For methods 504.1, 508.1, and 525.2 only.) See NTIS.

“Procedures for Radiochemical Analysis of Nuclear Reactor Aqueous Solutions.” See NTIS.

USEPA, Science and Technology Branch, Criteria and Standards Division, Office of Drinking Water, Washington, D.C. 20460.

“Guidance Manual for Compliance with the Filtration and Disinfection Requirements for Public Water Systems using Surface Water Sources,” October 1989.

USGS. Books and Open-File Reports Section, United States Geological Survey, Federal Center, Box 25286, Denver, CO 80225-0425.

Methods available upon request by method number from “Methods for Analysis by the U.S. Geological Survey National Water Quality Laboratory--Determination of Inorganic and Organic Constituents in Water and Fluvial Sediments,” Open File Report 93-125, 1993, or Book 5, Chapter A-1, “Methods for Determination of Inorganic Substances in Water and Fluvial Sediments,” 3rd ed., Open-File Report 85-495, 1989, as appropriate (referred to as “USGS Methods”).

I-1030-85

I-1062-85

I-1601-85

I-1700-85

I-2598-85

I-2601-90

I-2700-85

I-3300-85

Methods available upon request by method number from “Methods for Determination of Radioactive Substances in Water and Fluvial Sediments,” Chapter A5 in Book 5 of “Techniques of Water-

Resources Investigations of the United States Geological Survey,”
1997.

R-1110-76

R-1111-76

R-1120-76

R-1140-76

R-1141-76

R-1142-76

R-1160-76

R-1171-76

R-1180-76

R-1181-76

R-1182-76

Waters Corporation, Technical Services Division, 34 Maple St., Milford,
MA 01757 800-252-4752.

“Waters Test Method for Determination of Nitrite/Nitrate in Water
Using Single Column Ion Chromatography,” Method B-1011,
August 1987 (referred to as “Waters Method B-1011”).

- c) The Board incorporates the following federal regulations by reference:

40 CFR 136, Appendices B and C-~~(2002)~~ (2003).

- d) This Part incorporates no later amendments or editions.

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.110 Special Exception Permits

- a) Unless otherwise specified, each Agency determination in this Part is to be made by way of a written permit pursuant to Section 39(a) of the Act [415 ILCS 5/39(a)]. Such permit is titled a “special exception” permit (“SEP”).

- b) No person may cause or allow the violation of any condition of a SEP.
- c) The supplier may appeal the denial of or the conditions of a SEP to the Board pursuant to Section 40 of the Act [415 ILCS 5/40].
- d) A SEP may be initiated in either of the following ways:
 - 1) By an application filed by the supplier; or
 - 2) By the Agency, when authorized by Board regulations.

BOARD NOTE: The Board does not intend to mandate by any provision of this Part that the Agency exercise its discretion and initiate a SEP pursuant to this subsection (d)(2). Rather, the Board intends to clarify by this subsection (d)(2) that the Agency may opt to initiate a SEP without receiving a request from the supplier.

- e) The Agency must evaluate a request for a SEP from the monitoring requirements of Section 611.601, 611.602, or 611.603 (IOCs, excluding the Section 611.603 monitoring frequency requirements for cyanide); Section 611.646(e) and (f) (Phase I, Phase II, and Phase V VOCs); Section 611.646(d), only as to initial monitoring for 1,2,4-trichlorobenzene; Section 611.648(d) (for Phase II, Phase IIB, and Phase V SOCs); or Section 611.510 (for unregulated organic contaminants) on the basis of knowledge of previous use (including transport, storage, or disposal) of the contaminant in the watershed or zone of influence of the system, as determined pursuant to 35 Ill. Adm. Code 671.

BOARD NOTE: The Agency must grant a SEP from the Section 611.603 monitoring frequency requirements for cyanide only on the basis of subsection (g) of this Section, not on the basis of this subsection (e).

- 1) If the Agency determines that there was no prior use of the contaminant, it must grant the SEP; or
- 2) If the contaminant was previously used or the previous use was unknown, the Agency must consider the following factors:
 - A) Previous analytical results;
 - B) The proximity of the system to any possible point source of contamination (including spills or leaks at or near a water treatment facility; at manufacturing, distribution, or storage facilities; from hazardous and municipal waste land fills; or from waste handling or treatment facilities) or non-point source of contamination (including the use of pesticides and other land application uses of the contaminant);

- C) The environmental persistence and transport of the contaminant;
 - D) How well the water source is protected against contamination, including whether it is a SWS or a GWS.
 - i) A GWS must consider well depth, soil type, well casing integrity, and wellhead protection; and
 - ii) A SWS must consider watershed protection;
 - E) For Phase II, Phase IIB, and Phase V SOCs ~~and unregulated organic contaminants (pursuant to Section 611.631 or 611.648)~~, as follows:
 - i) Elevated nitrate levels at the water source; and
 - ii) The use of PCBs in equipment used in the production, storage, or distribution of water (including pumps, transformers, etc.); and
 - F) For Phase I, Phase II, and Phase V VOCs (pursuant to Section 611.646): the number of persons served by the PWS and the proximity of a smaller system to a larger one.
- f) If a supplier refuses to provide any necessary additional information requested by the Agency, or if a supplier delivers any necessary information late in the Agency's deliberations on a request, the Agency may deny the requested SEP or grant the SEP with conditions within the time allowed by law.
- g) The Agency must grant a supplier a SEP that allows it to discontinue monitoring for cyanide if it determines that the supplier's water is not vulnerable due to a lack of any industrial source of cyanide.

BOARD NOTE: Subsection (e) of this Section is derived from 40 CFR 141.24(f)(8) and (h)(6)~~(2002)~~ (2003). Subsection (f) of this Section is derived from 40 CFR 141.82(d)(2), and 141.83(b)(2)~~(2002)~~ (2003). Subsection (g) is derived from 40 CFR 141.23(c)(2)~~(2002)~~ (2003). USEPA has reserved the discretion, at 40 CFR 142.18~~(2002)~~ (2003), to review and nullify Agency determinations of the types made pursuant to Sections 611.510, 611.602, 611.603, 611.646, and 611.648 and the discretion, at 40 CFR 141.82(i), 141.83(b)(7), and 142.19~~(2002)~~ (2003), to establish federal standards for any supplier, superseding any Agency determination made pursuant to Sections 611.352(d), 611.352(f), 611.353(b)(2), and 611.353(b)(4).

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.125 Fluoridation Requirement

All CWSs that are required to add fluoride to the water must maintain a fluoride ion concentration, reported as F_2 of 0.9 to 1.2 ~~mg/l~~ mg/l in its distribution system, as required by Section 7a of the Public Water Supply Regulation Act [415 ILCS 40/7a].

BOARD NOTE: This is an additional State requirement.

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.130 Special Requirements for Certain Variances and Adjusted Standards

a) ~~Relief from the TTHM MCL.~~

1) ~~In granting any variance or adjusted standard to a supplier that is a CWS that adds a disinfectant at any part of treatment and which provides water to 10,000 or more persons on a regular basis from the maximum contaminant level for TTHM listed in Section 611.310(c), the Board will require application of the best available technology (BAT) identified at subsection (a)(4) of this Section for that constituent as a condition to the relief, unless the supplier has demonstrated through comprehensive engineering assessments that application of BAT is not technically appropriate and technically feasible for that system or that the application would only result in a marginal reduction in TTHM for that supplier.~~

2) ~~The Board will require the following as a condition for relief from the TTHM MCL where it does not require the application of BAT:~~

A) ~~That the supplier continue to investigate the following methods as an alternative means of significantly reducing the level of TTHM, according to a definite schedule:~~

i) ~~The introduction of off line water storage for THM precursor reduction;~~

ii) ~~Aeration for TTHM reduction, where geography and climate allow;~~

iii) ~~The introduction of clarification, where not presently practiced;~~

iv) ~~The use of alternative sources of raw water; and~~

v) ~~The use of ozone as an alternative or supplemental disinfectant or oxidant; and~~

- ~~B) That the supplier report results of that investigation to the Agency.~~
- 3) ~~The Agency must petition the Board to reconsider or modify a variance or adjusted standard, pursuant to Subpart I of 35 Ill. Adm. Code 101, if it determines that an alternative method identified by the supplier pursuant to subsection (a)(2) of this Section is technically feasible and would result in a significant reduction in TTHM.~~
- 4) ~~Best available technology for TTHM reduction is as follows:~~
 - A) ~~The use of chloramines as an alternative or supplemental disinfectant;~~
 - B) ~~The use of chlorine dioxide as an alternative or supplemental disinfectant; or~~
 - C) ~~Improved existing clarification for THM precursor reduction.~~

~~BOARD NOTE: Subsection (a) derived from 40 CFR 142.60 (2002).~~

- ~~ba)~~ Relief from the fluoride MCL.
 - 1) In granting any variance or adjusted standard to a supplier that is a CWS from the maximum contaminant level for fluoride listed in Section 611.301(b), the Board will require application of the best available technology (BAT) identified at subsection ~~(b)(4)~~(a)(4) of this Section for that constituent as a condition to the relief, unless the supplier has demonstrated through comprehensive engineering assessments that application of BAT is not technically appropriate and technically feasible for that supplier.
 - 2) The Board will require the following as a condition for relief from the fluoride MCL where it does not require the application of BAT:
 - A) That the supplier continue to investigate the following methods as an alternative means of significantly reducing the level of fluoride, according to a definite schedule:
 - i) A modification of lime softening;
 - ii) Alum coagulation;
 - iii) Electrodialysis;
 - iv) Anion exchange resins;

- v) Well field management;
 - vi) The use of alternative sources of raw water; and
 - vii) Regionalization; and
- B) That the supplier report results of that investigation to the Agency.
- 3) The Agency must petition the Board to reconsider or modify a variance or adjusted standard, pursuant to Subpart I of 35 Ill. Adm. Code 101, if it determines that an alternative method identified by the supplier pursuant to subsection ~~(b)(2)~~(a)(2) of this Section is technically feasible and would result in a significant reduction in fluoride.
- 4) Best available technology for fluoride reduction is as follows:
- A) Activated alumina absorption centrally applied; and
 - B) Reverse osmosis centrally applied.

BOARD NOTE: Subsection ~~(ba)~~ derived from 40 CFR 142.61~~(2002)~~(2003).

eb) Relief from an IOC, VOC, or SOC MCL.

- 1) In granting to a supplier that is a CWS or NTNCWS any variance or adjusted standard from the maximum contaminant levels for any VOC or SOC, listed in Section 611.311(a) or (c), or for any IOC, listed in Section 611.301, the supplier must have first applied the best available technology (BAT) identified at Section 611.311(b) (VOCs and SOCs) or Section 611.301(c) (IOCs) for that constituent, unless the supplier has demonstrated through comprehensive engineering assessments that application of BAT would achieve only a minimal and insignificant reduction in the level of contaminant.

BOARD NOTE: USEPA lists BAT for each SOC and VOC at 40 CFR 142.62(a), for the purposes of variances and exemptions (adjusted standards). That list is identical to the list at 40 CFR 141.61(b).

- 2) The Board may require any of the following as a condition for relief from an MCL listed in Section 611.301 or 611.311:
- A) That the supplier continue to investigate alternative means of compliance according to a definite schedule; and
 - B) That the supplier report results of that investigation to the Agency.

- 3) The Agency must petition the Board to reconsider or modify a variance or adjusted standard, pursuant to Subpart I of 35 Ill. Adm. Code 101, if it determines that an alternative method identified by the supplier pursuant to subsection ~~(e)(2)~~(b)(2) of this Section is technically feasible.

BOARD NOTE: Subsection ~~(e)~~(b) derived from 40 CFR 142.62(a) through ~~(e)~~(2002)(2003).

- ~~(c)~~(d) Conditions requiring use of bottled water, a point-of-use treatment device, or a point-of-entry treatment device. In granting any variance or adjusted standard from the maximum contaminant levels for organic and inorganic chemicals or an adjusted standard from the treatment technique for lead and copper, the Board may impose certain conditions requiring the use of bottled water, a point-of-entry treatment device, or a point-of-use treatment device to avoid an unreasonable risk to health, limited as provided in subsections ~~(e) and (f)~~(d) and ~~(e)~~(e) of this Section.
- 1) Relief from an MCL. The Board may, when granting any variance or adjusted standard from the MCL requirements of Sections 611.301 and 611.311, impose a condition that requires a supplier to use bottled water, a point-of-entry treatment device, a point-of-use treatment device, or other means to avoid an unreasonable risk to health.
 - 2) Relief from corrosion control treatment. The Board may, when granting an adjusted standard from the corrosion control treatment requirements for lead and copper of Sections 611.351 and 611.352, impose a condition that requires a supplier to use bottled water, a point-of-use treatment device, or other means, but not a point-of-entry treatment device, to avoid an unreasonable risk to health.
 - 3) Relief from source water treatment or service line replacement. The Board may, when granting an exemption from the source water treatment and lead service line replacement requirements for lead and copper under Sections 611.353 or 611.354, impose a condition that requires a supplier to use a point-of-entry treatment device to avoid an unreasonable risk to health.

BOARD NOTE: Subsection ~~(c)~~(d) derived from 40 CFR 142.62(f)~~(2002)~~(2003).

- ~~(d)~~(e) Use of bottled water. Suppliers that propose to use or use bottled water as a condition for receiving a variance or an adjusted standard from the requirements of Section 611.301 or Section 611.311 or an adjusted standard from the requirements of Sections 611.351 through 611.354 must meet the requirements of either subsections ~~(e)(1), (e)(2), (e)(3), and (e)(6)~~ or ~~(e)(4), (e)(5), and (e)(6)~~(d)(1), (d)(2), (d)(3), and (d)(6) or ~~(d)(4), (d)(5), and (d)(6)~~(d)(4), (d)(5), and (d)(6) of this Section.

- 1) The supplier must develop a monitoring program for Board approval that provides reasonable assurances that the bottled water meets all MCLs of Sections 611.301 and 611.311 and submit a description of this program as part of its petition. The proposed program must describe how the supplier will comply with each requirement of this subsection ~~(e)~~ (d).
- 2) The supplier must monitor representative samples of the bottled water for all contaminants regulated under Sections 611.301 and 611.311 during the first three-month period that it supplies the bottled water to the public, and annually thereafter.
- 3) The supplier must annually provide the results of the monitoring program to the Agency.
- 4) The supplier must receive a certification from the bottled water company as to each of the following:
 - A) that the bottled water supplied has been taken from an approved source of bottled water, as such is defined in Section 611.101;
 - B) that the approved source of bottled water has conducted monitoring in accordance with 21 CFR 129.80(g)(1) through (g)(3);
 - C) and that the bottled water does not exceed any MCLs or quality limits as set out in 21 CFR 103.35, 110, and 129.
- 5) The supplier must provide the certification required by subsection ~~(e)~~ (d)(4) of this Section to the Agency during the first quarter after it begins supplying bottled water and annually thereafter.
- 6) The supplier must assure the provision of sufficient quantities of bottled water to every affected person supplied by the supplier via door-to-door bottled water delivery.

BOARD NOTE: Subsection (ed) derived from 40 CFR 142.62(g) ~~(2002)~~ (2003).

- ~~¶e)~~ Use of a point-of-entry treatment device. Before the Board grants any PWS a variance or adjusted standard from any NPDWR that includes a condition requiring the use of a point-of-entry treatment device, the supplier must demonstrate to the Board each of the following:
- 1) That the supplier will operate and maintain the device;
 - 2) That the device provides health protection equivalent to that provided by central treatment;

- 3) That the supplier will maintain the microbiological safety of the water at all times;
- 4) That the supplier has established standards for performance, conducted a rigorous engineering design review, and field tested the device;
- 5) That the operation and maintenance of the device will account for any potential for increased concentrations of heterotrophic bacteria resulting through the use of activated carbon, by backwashing, post-contactor disinfection, and heterotrophic plate count monitoring;
- 6) That buildings connected to the supplier's distribution system have sufficient devices properly installed, maintained, and monitored to assure that all consumers are protected; and
- 7) That the use of the device will not cause increased corrosion of lead and copper bearing materials located between the device and the tap that could increase contaminant levels at the tap.

BOARD NOTE: Subsection (~~fe~~) derived from 40 CFR 142.62(h)-(2002) (2003).

~~gf~~) Relief from the maximum contaminant levels for radionuclides (effective December 8, 2003).

- 1) Relief from the maximum contaminant levels for combined radium-226 and radium-228, uranium, gross alpha particle activity (excluding radon and uranium), and beta particle and photon radioactivity.
 - A) Section 611.330(g) sets forth what USEPA has identified as the best available technology (BAT), treatment techniques, or other means available for achieving compliance with the maximum contaminant levels for the radionuclides listed in Section 611.330(b), (c), (d), and (e), for the purposes of issuing relief equivalent to a federal section 1415 variance or a section 1416 exemption.
 - B) In addition to the technologies listed in Section 611.330(g), Section 611.330(h) sets forth what USEPA has identified as the BAT, treatment techniques, or other means available for achieving compliance with the maximum contaminant levels for the radionuclides listed in Section 611.330(b), (c), (d), and (e), for the purposes of issuing relief equivalent to a federal section 1415 variance or a section 1416 exemption to small drinking water systems, defined here as those serving 10,000 persons or fewer, as shown in the second table set forth at Section 611.330(h).

- 2) The Board will require a CWS supplier to install and use any treatment technology identified in Section 611.330(g), or in the case of small water systems (those serving 10,000 persons or fewer), listed in Section 611.330(h), as a condition for granting relief equivalent to a federal section 1415 variance or a section 1416 exemption, except as provided in subsection ~~(a)(3)-(f)(3)~~ of this Section. If, after the system's installation of the treatment technology, the system cannot meet the MCL, that system will be eligible for relief.
- 3) If a CWS supplier can demonstrate through comprehensive engineering assessments, which may include pilot plant studies, that the treatment technologies identified in this Section would only achieve a de minimus reduction in the contaminant level, the Board may issue a schedule of compliance that requires the system being granted relief equivalent to a federal section 1415 variance or a section 1416 exemption to examine other treatment technologies as a condition of obtaining the relief.
- 4) If the Agency determines that a treatment technology identified under subsection ~~(a)(3)-(f)(3)~~ of this Section is technically feasible, it may request that the Board require the supplier to install and use that treatment technology in connection with a compliance schedule issued pursuant to Section 36 of the Act [415 ILCS 5/36]. The Agency's determination must be based upon studies by the system and other relevant information.
- 5) The Board may require a CWS to use bottled water, point-of-use devices, point-of-entry devices, or other means as a condition of granting relief equivalent to a federal section 1415 variance or a section 1416 exemption from the requirements of Section 611.330, to avoid an unreasonable risk to health.
- 6) A CWS supplier that uses bottled water as a condition for receiving relief equivalent to a federal section 1415 variance or a section 1416 exemption from the requirements of Section 611.330 must meet the requirements specified in either subsections ~~(e)(1) through (e)(3) or (e)(4) through (e)(6)~~ (d)(1) through (d)(3) or (d)(4) through (d)(6) of this Section.
- 7) A CWS supplier that uses point-of-use or point-of-entry devices as a condition for obtaining relief equivalent to a federal section 1415 variance or a section 1416 exemption from the radionuclides NPDWRs must meet the conditions in subsections ~~(g)(1) through (g)(6)~~ (e)(1) through (e)(6) of this Section.

BOARD NOTE: Subsection ~~(gf)~~ derived from 40 CFR 142.65 ~~(2002)~~ (2003).

(Source: Amended at 28 Ill. Reg. _____, effective _____)

SUBPART B: FILTRATION AND DISINFECTION

Section 611.211 Filtration Required

The Agency must determine that filtration is required unless the PWS meets the following criteria:

- a) Source water quality criteria:
 - 1) Coliforms, see Section 611.231(a)
 - 2) Turbidity, see Section 611.231(b)
- b) ~~Site-specific~~ Site-specific criteria:
 - 1) Disinfection, see Section 611.241(b)
 - 2) Watershed control, see Section 611.232(b)
 - 3) On-site inspection, see Section 611.232(c)
 - 4) Absence of waterborne disease outbreaks, see Section 611.232(d)
 - 5) Total coliform MCL, see Sections 611.232(e) and 611.325
 - 6) ~~TTHMs MCL, see Section 611.310~~

BOARD NOTE: Derived from 40 CFR 141.71 ~~2002~~ (2003) and from the preamble discussion at 54 Fed. Reg. 27505 (June 29, 1989).

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.230 Filtration Effective Dates

- a) A supplier that uses a surface water source must meet all of the conditions of Section 611.231 and 611.232, ~~and is subject to Section 611.233, beginning December 30, 1991,~~ unless the Agency has determined that filtration is required.
- b) A supplier that uses a groundwater source under the direct influence of surface water must meet all of the conditions of Section 611.231 and 611.232, and is subject to Section 611.233, beginning 18 months after the Agency determines that it is under the direct influence of surface water, ~~or December 30, 1991, whichever is later,~~ unless the Agency has determined that filtration is required.
- c) If the Agency ~~determines~~ determined, before December 30, 1991, that filtration is

required, the system must have installed filtration and must ~~meet~~ have met the criteria for filtered systems specified in Section 611.242 and Section 611.250 by June 29, 1993.

- d) Within 18 months of the failure of a system using surface water or a groundwater source under the direct influence of surface water to meet any one of the requirements of Sections 611.231 and 611.232, ~~or after June 29, 1993, whichever is later~~, the system must have installed filtration and meet the criteria for filtered systems specified in Sections 611.242 and 611.250.

BOARD NOTE: Derived from 40 CFR 141.71 preamble ~~(2002)~~ (2003).

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.232 Site-Specific Conditions

The Agency must consider the following site specific criteria in determining whether to require filtration pursuant to Section 611.211:

- a) Disinfection.
- 1) The supplier must meet the requirements of Section 611.241(a) at least 11 of the 12 previous months that the system served water to the public, on an ongoing basis, unless the system fails to meet the requirements during 2 of the 12 previous months that the system served water to the public, and the Agency determines that at least one of these failures was caused by circumstances that were unusual and unpredictable.
 - 2) The supplier must meet the following requirements at the times specified for each:
 - A) The requirements of Section 611.241(b)(1) at all times the system serves water to the public; and
 - B) The requirements of Section 611.241(b)(2) at all times the system serves water to the public, unless the Agency determines that any such failure was caused by circumstances that were unusual and unpredictable.
 - 3) The supplier must meet the requirements of Section 611.241(c) at all times the system serves water to the public, unless the Agency determines that any such failure was caused by circumstances that were unusual and unpredictable.
 - 4) The supplier must meet the requirements of Section 611.241(d) on an ongoing basis, unless the Agency determines that failure to meet these

requirements was not caused by a deficiency in treatment of the source water.

- b) Watershed control program. The supplier must maintain a watershed control program that minimizes the potential for contamination by *Giardia lamblia* cysts and viruses in the source water.
 - 1) The Agency must determine whether the watershed control program is adequate to meet this goal. The Agency must determine the adequacy of a watershed control program based on the following:
 - A) The comprehensiveness of the watershed review;
 - B) The effectiveness of the supplier's program to monitor and control detrimental activities occurring in the watershed; and
 - C) The extent to which the water supplier has maximized land ownership or controlled the land use within the watershed. At a minimum, the watershed control program must do the following:
 - i) Characterize the watershed hydrology and land ownership;
 - ii) Identify watershed characteristics and activities that may have an adverse effect on source water quality; and
 - iii) Monitor the occurrence of activities that may have an adverse effect on source water quality.
 - 2) The supplier must demonstrate through ownership or written agreements with landowners within the watershed that it can control all human activities that may have an adverse impact on the microbiological quality of the source water. The supplier must submit an annual report to the Agency that identifies any special concerns about the watershed and how they are being handled; describes activities in the watershed that affect water quality; and projects what adverse activities are expected to occur in the future and describes how the supplier expects to address them. For systems using a groundwater source under the direct influence of surface water, an approved wellhead protection program may be used, if appropriate, to meet these requirements.
- c) On-site inspection. The supplier must be subject to an annual on-site inspection to assess the watershed control program and disinfection treatment process. The Agency must conduct the inspection. A report of the on-site inspection summarizing all findings must be prepared every year. The on-site inspection must demonstrate that the watershed control program and disinfection treatment process are adequately designed and maintained. The on-site inspection must

include the following:

- 1) A review of the effectiveness of the watershed control program;
 - 2) A review of the physical condition of the source intake and how well it is protected;
 - 3) A review of the supplier's equipment maintenance program to ensure there is low probability for failure of the disinfection process;
 - 4) An inspection of the disinfection equipment for physical deterioration;
 - 5) A review of operating procedures;
 - 6) A review of data records to ensure that all required tests are being conducted and recorded and disinfection is effectively practiced; and
 - 7) Identification of any improvements that are needed in the equipment, system maintenance, and operation or data collection.
- d) Absence of waterborne disease outbreaks. The PWS must not have been identified as a source of a waterborne disease outbreak, or if it has been so identified, the system must have been modified sufficiently to prevent another such occurrence.
- e) Total coliform MCL. The supplier must comply with the MCL for total coliforms in Section 611.325 at least 11 months of the 12 previous months that the system served water to the public, on an ongoing basis, unless the Agency determines that failure to meet this requirement was not caused by a deficiency in treatment of the source water.
- f) ~~TTHM-MCL. The supplier must comply with the MCL for TTHM in Section 611.310. The PWS must comply with the requirements for trihalomethanes until December 31, 2001. After December 31, 2001, the supplier must comply with the requirements for total trihalomethanes, haloacetic acids (five), bromate, chlorite, chlorine, chloramines, and chlorine dioxide in Subpart I of this Part.~~

BOARD NOTE: Derived from 40 CFR 141.71(b)~~(2002)~~ (2003).

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.240 Disinfection

- a) A supplier that uses a surface water source and does not provide filtration treatment must provide the disinfection treatment specified in Section 611.241 beginning December 30, 1991.

- b) A supplier that uses a groundwater source under the influence of surface water and does not provide filtration treatment must provide disinfection treatment specified in Section 611.241 beginning December 30, 1991, or 18 months after the Agency determines that the groundwater source is under the influence of surface water, whichever is later, unless the Agency has determined that filtration is required.
- c) If the Agency determines that filtration is required, the Agency may, by a SEP issued pursuant to Section 611.110, require the supplier to comply with interim disinfection requirements before filtration is installed.
- d) A system that uses a surface water source that provides filtration treatment must provide the disinfection treatment specified in Section 611.242 beginning June 29, 1993, or beginning when filtration is installed, whichever is later.
- e) A system that uses a groundwater source under the direct influence of surface water and provides filtration treatment must ~~provide~~ have provided disinfection treatment as specified in Section 611.242 by June 29, 1993 or beginning when filtration is installed, whichever is later.
- f) Failure to meet any requirement of the following Sections after the applicable date specified in this Section is a treatment technique violation.

BOARD NOTE: Derived from 40 CFR 141.72 preamble ~~(2002)~~ (2003).

- g) CWS suppliers using groundwater that is not under the direct influence of surface water must chlorinate the water before it enters the distribution system, unless the Agency has granted the supplier an exemption pursuant to Section 17(b) of the Act [415 ILCS 5/17(b)].
 - 1) All GWS supplies that are required to chlorinate pursuant to this Section must maintain residuals of free or combined chlorine at levels sufficient to provide adequate protection of human health and the ability of the distribution system to continue to deliver potable water that complies with the requirements of this Part.
 - 2) The Agency may establish procedures and levels for chlorination applicable to a GWS using groundwater that is not under the direct influence of surface water by a SEP pursuant to Section 610.110.
 - 3) Those supplies having hand-pumped wells and no distribution system are exempted from the requirements of this Section.

BOARD NOTE: This is an additional State requirement originally codified at 35 Ill. Adm. Code 604.401.

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.241 Unfiltered PWSs

Each supplier that does not provide filtration treatment must provide disinfection treatment as follows:

- a) The disinfection treatment must be sufficient to ensure at least 99.9 percent (3-log) inactivation of *Giardia lamblia* cysts and 99.99 percent (4-log) inactivation of viruses, every day the system serves water to the public, except any one day each month. Each day a system serves water to the public, the supplier must calculate the $CT_{99.9}$ ~~values~~ value from the system's treatment parameters using the procedure specified in Section 611.532(c) and determine whether this ~~values~~ value is sufficient to achieve the specified inactivation rates for *Giardia lamblia* cysts and viruses.
 - 1) If a system uses a disinfectant other than chlorine, the system may demonstrate to the Agency, through the use of an Agency-approved protocol for on-site disinfection challenge studies or other information, that $CT_{99.9}$ values other than those specified in Appendix B of this Part, Tables 2.1 and 3.1 or other operational parameters are adequate to demonstrate that the system is achieving minimum inactivation rates required by this subsection.
 - 2) The demonstration must be made by way of a SEP application pursuant to Section 611.110.
- b) The disinfection system must have either of the following:
 - 1) Redundant components, including an auxiliary power supply with automatic start-up and alarm to ensure that disinfectant application is maintained continuously while water is being delivered to the distribution system; or
 - 2) Automatic shut-off of delivery of water to the distribution system whenever there is less than 0.2 mg/ℓ of RDC in the water. If the Agency determines, by a SEP issued pursuant to Section 611.110, that automatic shut-off would cause unreasonable risk to health or interfere with fire protection, the system must comply with subsection (b)(1).
- c) The RDC in the water entering the distribution system, measured as specified in Sections 611.531(e) and 611.532(e), cannot be less than 0.2 mg/ℓ for more than 4 hours.
- d) RDC in the distribution system.

- 1) The RDC in the distribution system, measured as total chlorine, combined chlorine or chlorine dioxide, as specified in Sections 611.531(e) and 611.532(f), cannot be undetectable in more than 5 percent of the samples each month for any two consecutive months that the system serves water to the public. Water in the distribution system with HPC less than or equal to 500/ml, measured as specified in Section 611.531(c), is deemed to have a detectable RDC for purposes of determining compliance with this requirement. Thus, the value “V” in the following formula cannot exceed 5 percent in one month, for any two consecutive months.

$$V = \frac{100(c + d + e)}{(a + b)}$$

where the terms mean the following:

- a = Number of instances where the RDC is measured;
- b = Number of instances where the RDC is not measured, but HPC is measured;
- c = Number of instances where the RDC is measured but not detected and no HPC is measured;
- d = Number of instances where the RDC is measured but not detected, and where the HPC is greater than 500/ml; and
- e = Number of instances where the RDC is not measured and HPC is greater than 500/ml.
- 2) Subsection (d)(1) does not apply if the Agency determines, pursuant to Section 611.213, that a supplier has no means for having a sample analyzed for HPC.

BOARD NOTE: Derived from 40 CFR 141.72(a)-~~(2002)~~ (2003).

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.242 Filtered PWSs

Each supplier that provides filtration treatment must provide disinfection treatment as follows:

- a) The disinfection treatment must be sufficient to ensure that the total treatment processes of that system achieve at least 99.9 percent (3-log) inactivation or removal of *Giardia lamblia* cysts and at least 99.99 percent (4-log) inactivation or

removal of viruses.

- b) The RDC in the water entering the distribution system, measured as specified in Section 611.531(e) and 611.533(b), cannot be less than 0.2 mg/l for more than 4 hours.
- c) RDC in the distribution system.
 - 1) The RDC in the distribution system, measured as total chlorine, combined chlorine, or chlorine dioxide, as specified in Section 611.531(e) and 611.533(c), cannot be undetectable in more than 5 percent of the samples each month, for any two consecutive months that the system serves water to the public. Water in the distribution system with HPC less than or equal to 500/ml, measured as specified in Section 611.531(c), is deemed to have a detectable RDC for purposes of determining compliance with this requirement. Thus, the value "V" in the following formula cannot exceed 5 percent in one month, for any two consecutive months.

$$V = 100(c + d + e) / (a + b)$$

where the terms mean the following:

- a = Number of instances where the RDC is measured;
 - b = Number of instances where the RDC is not measured, but HPC is measured;
 - c = Number of instances where the RDC is measured but not detected and no HPC is measured;
 - d = Number of instances where the RDC is measured but not detected, and where HPC is greater than 500/ml; and
 - e = Number of instances where the RDC is not measured and HPC is greater than 500/ml.
- 2) Subsection (c)(1) does not apply if the Agency determines, pursuant to Section 611.213, that a supplier has no means for having a sample analyzed for HPC.

BOARD NOTE: Derived from 40 CFR 141.72(b)-(2002) (2003).

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.250 Filtration

A supplier that uses a surface water source or a groundwater source under the direct influence of surface water, and does not meet all of the criteria in Sections 611.231 and 611.232 for avoiding filtration, must ~~provide~~ have provided treatment consisting of both disinfection, as specified in Section 611.242, and filtration treatment that complies with the requirements of subsection (a), (b), (c), (d), or (e) by June 29, 1993, or within 18 months after the failure to meet any one of the criteria for avoiding filtration in Sections 611.231 and 611.232, whichever is later. Failure to meet any requirement after the date specified in this introductory paragraph is a treatment technique violation.

- a) Conventional filtration treatment or direct filtration.
 - 1) For a system using conventional filtration or direct filtration, the turbidity level of representative samples of the system's filtered water must be less than or equal to 0.5 NTU in at least 95 percent of the measurements taken each month, except that if the Agency determines, by a SEP issued pursuant to Section 611.110, that the system is capable of achieving at least 99.9 percent removal or inactivation of *Giardia lamblia* cysts at some turbidity level higher than 0.5 NTU in at least 95 percent of the measurements taken each month, the Agency must substitute this higher turbidity limit for that system. However, in no case may the Agency approve a turbidity limit that allows more than 1 NTU in more than five percent of the samples taken each month.
 - 2) The turbidity level of representative samples of a system's filtered water must at no time exceed 5 NTU.
 - 3) Beginning January 1, 2001, a supplier serving at least 10,000 or more persons must meet the turbidity requirements of Section 611.743(a).
 - 4) Beginning January 1, 2005, a supplier that serves fewer than 10,000 people must meet the turbidity requirements in Section 611.955.
- b) Slow sand filtration.
 - 1) For a system using slow sand filtration, the turbidity level of representative samples of the system's filtered water must be less than or equal to 1 NTU in at least 95 percent of the measurements taken each month, except that if the Agency determines, by a SEP issued pursuant to Section 611.110, that there is no significant interference with disinfection at a higher level, the Agency must substitute the higher turbidity limit for that system.
 - 2) The turbidity level of representative samples of a system's filtered water must at no time exceed 5 NTU.

- c) Diatomaceous earth filtration.
- 1) For a system using diatomaceous earth filtration, the turbidity level of representative samples of the system's filtered water must be less than or equal to 1 NTU in at least 95 percent of the measurements taken each month.
 - 2) The turbidity level of representative samples of a system's filtered water must at no time exceed 5 NTU.
- d) Other filtration technologies. A supplier may use a filtration technology not listed in subsections (a) through (c) if it demonstrates, by a SEP application pursuant to Section 611.110, to the Agency, using pilot plant studies or other means, that the alternative filtration technology, in combination with disinfection treatment that meets the requirements of Section 611.242, consistently achieves 99.9 percent removal or inactivation of *Giardia lamblia* cysts and 99.99 percent removal or inactivation of viruses. For a supplier that makes this demonstration, the requirements of subsection (b) apply. Beginning January 1, 2002, a supplier serving 10,000 or more persons must meet the requirements for other filtration technologies in Section 611.743(b). Beginning January 1, 2005, a supplier that serves fewer than 10,000 people must meet the requirements for other filtration technologies in Section 611.955.

BOARD NOTE: Derived from 40 CFR 141.73-~~(2002)~~ (2003).

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.276 Recycle Provisions

- a) **Applicability.** A Subpart B system supplier that employs conventional filtration or direct filtration treatment and which recycles spent filter backwash water, thickener supernatant, or liquids from dewatering processes must meet the requirements in subsections (b) through (d) of this Section.
- b) **Reporting.** A supplier must ~~notify~~ have notified the Agency in writing by December 8, 2003, if the supplier recycles spent filter backwash water, thickener supernatant, or liquids from dewatering processes. This notification must include, at a minimum, the information specified in subsections (b)(1) and (b)(2) of this Section, as follows:
 - 1) A plant schematic showing the origin of all flows that are recycled (including, but not limited to, spent filter backwash water, thickener supernatant, and liquids from dewatering processes), the hydraulic conveyance used to transport them, and the location where they are re-introduced back into the treatment plant.

- 2) Typical recycle flow in gallons per minute (gpm), the highest observed plant flow experienced in the previous year (gpm), design flow for the treatment plant (gpm), and Agency-approved operating capacity for the plant where the Agency has made such a determination.
- c) Treatment technique requirement. Any supplier that recycles spent filter backwash water, thickener supernatant, or liquids from dewatering processes must return these flows through the processes of the supplier's existing conventional or direct filtration system, as defined in Section 611.101, or at an alternative location approved by a permit issued by the Agency by June 8, 2004. If capital improvements are required to modify the recycle location to meet this requirement, all capital improvements must be completed no later than June 8, 2006.
 - d) Recordkeeping. The supplier must collect and retain on file recycle flow information specified in subsections (d)(1) through (d)(6) of this Section for review and evaluation by the Agency beginning June 8, 2004, as follows:
 - 1) A copy of the recycle notification and information submitted to the State under subsection (b) of this Section.
 - 2) A list of all recycle flows and the frequency with which they are returned.
 - 3) The average and maximum backwash flow rate through the filters and the average and maximum duration of the filter backwash process in minutes.
 - 4) The typical filter run length and a written summary of how filter run length is determined.
 - 5) The type of treatment provided for the recycle flow.
 - 6) Data on the physical dimensions of the equalization or treatment units, typical and maximum hydraulic loading rates, type of treatment chemicals used and average dose and frequency of use, and frequency at which solids are removed, if applicable.

BOARD NOTE: Derived from 40 CFR 141.76-~~(2002)~~ (2003).

(Source: Amended at 28 Ill. Reg. _____, effective _____)

SUBPART C: USE OF NON-CENTRALIZED TREATMENT DEVICES

Section 611.290 Use of Point-of-Use Devices or Bottled Water

- a) Suppliers must not use bottled water to achieve compliance with an MCL.

- b) Bottled water or point-of-use devices may be used on a temporary basis to avoid an unreasonable risk to health pursuant to a SEP granted by the Agency under Section 611.110.
- c) Any use of bottled water must comply with the substantive requirements of Section 611.130(ed), except that the supplier must submit its quality control plan for Agency review as part of its SEP request, rather than for Board review.

BOARD NOTE: Derived from 40 CFR 141.101-(2002) (2003).

(Source: Amended at 28 Ill. Reg. _____, effective _____)

SUBPART F: MAXIMUM CONTAMINANT LEVELS (MCLs) AND
MAXIMUM RESIDUAL DISINFECTANT LEVELS (MRDLs)

Section 611.301 Revised MCLs for Inorganic Chemical Contaminants

- a) This subsection corresponds with 40 CFR 141.62(a), reserved by USEPA. This statement maintains structural consistency with USEPA rules.
- b) The MCLs in the following table apply to CWSs. Except for fluoride, the MCLs also apply to NTNCWSs. The MCLs for nitrate, nitrite, and total nitrate and nitrite also apply to transient non-CWSs.

Contaminant	MCL	Units
Antimony	0.006	mg/l
Arsenic (effective January 23, 2006)	0.01 <u>0.010</u>	mg/l
Asbestos	7	MFL
Barium	2	mg/l
Beryllium	0.004	mg/l
Cadmium	0.005	mg/l
Chromium	0.1	mg/l
Cyanide (as free CN)	0.2	mg/l
Fluoride	4.0	mg/l
Mercury	0.002	mg/l
Nitrate (as N)	10	mg/l
Nitrite (as N)	1	mg/l
Total Nitrate and Nitrite (as N)	10	mg/l
Selenium	0.05	mg/l
Thallium	0.002	mg/l

BOARD NOTE: See Section 611.300(d) for an elevated nitrate level for non-CWSs. USEPA removed and reserved the MCL for nickel on June

29, 1995, at 60 Fed. Reg. 33932, as a result of a judicial order in Nickel Development Institute v. EPA, No. 92-1407, and Specialty Steel Industry of the U.S. v. Browner, No. 92-1410 (D.C. Cir. Feb. 23 & Mar. 6, 1995), while retaining the contaminant, analytical methodology, and detection limit listings for this contaminant.

- c) USEPA has identified the following as BAT for achieving compliance with the MCL for the IOCs identified in subsection (b) of this Section, except for fluoride:

Contaminant	BATs
Antimony	C/F RO
Arsenic (BATs for As ^V . Pre- oxidation may be required to convert As ^{III} to As ^V .)	AAL C/F IX LIME RO ED O/F (To obtain high removals, the iron to arsenic ratio must be at least 20:1)
Asbestos	C/F DDF CC
Barium	IX LIME RO ED
Beryllium	AA C/F IX LIME RO
Cadmium	C/F IX LIME RO

Chromium	C/F IX LIME, BAT for Cr ^{III} only RO
Cyanide	IX RO Cl ₂
Mercury	C/F, BAT only if influent Hg concentrations less than or equal to (\leq) 10 $\mu\text{g}/\ell$ GAC LIME, BAT only if influent Hg concentrations \leq <u>less than or equal to 10 $\mu\text{g}/\ell$</u> RO, BAT only if influent Hg concentrations \leq <u>less than or equal to 10 $\mu\text{g}/\ell$</u>
Nickel	IX LIME RO
Nitrate	IX RO ED
Nitrite	IX RO
Selenium	AAL C/F, BAT for Se ^{IV} only LIME RO ED
Thallium	AAL IX

Abbreviations

AAL	Activated alumina
C/F	Coagulation/filtration (not BAT for a system that has fewer than 500 service connections)
DDF	Direct and diatomite filtration
GAC	Granular activated carbon
IX	Ion exchange
LIME	Lime softening

RO	Reverse osmosis
CC	Corrosion control
ED	Electrodialysis
Cl ₂	Oxidation (chlorine)
UV	Ultraviolet irradiation
O/F	Oxidation/filtration

- d) At 40 CFR 141.62(d)-(2002)(2003), USEPA identified the following as the affordable technology, treatment technique, or other means available to systems serving 10,000 persons or fewer for achieving compliance with the maximum contaminant level for arsenic:

Small System Compliance Technologies (SSCTs)¹ for Arsenic²

Small system compliance technology	Affordable for listed small system categories ³
Activated alumina (centralized)	All size categories
Activated alumina (point-of-use) ⁴	All size categories
Coagulation/filtration ⁵	501-3,300 persons, 3,301-10,000 persons
Coagulation-assisted microfiltration	501-3,300 persons, 3,301-10,000 persons
Electrodialysis reversal ⁶	501-3,300 persons, 3,301-10,000 persons
Enhanced coagulation/filtration	All size categories
Enhanced lime softening (pH > 10.5)	All size categories
Ion exchange	All size categories
Lime softening ⁵	501-3,300 persons, 3,301-10,000 persons
Oxidation/filtration ⁷	All size categories
Reverse osmosis (centralized) ⁶	501-3,300 persons, 3,301-10,000 persons
Reverse osmosis (point-of-use) ⁴	All size categories

¹ Section 1412(b)(4)(E)(ii) of the federal SDWA (42 USC 300g-1(b)(4)(E)(ii)) specifies that SSCTs must be affordable and technically feasible for a small system supplier.

² SSCTs for As^V. Pre-oxidation may be required to convert As^{III} to As^V.

³ The federal SDWA specifies three categories of small system suppliers: (1) those serving 25 or more, but fewer than 501 persons, (2) those serving more than 500 but fewer than 3,301 persons, and (3) those serving more than 3,300 but fewer than 10,001 persons.

~~³ The federal SDWA specifies three categories of small system suppliers: (1) those serving 25 or more, but fewer than 501, (2) those serving more than 500, but fewer than 3,301, and (3) those serving more than 3,300, but fewer than 10,001.~~

⁴ When POU or POE devices are used for compliance, programs to ensure proper long-term operation, maintenance, and monitoring must be provided by

the water supplier to ensure adequate performance.

- ⁵ Unlikely to be installed solely for arsenic removal. May require pH adjustment to optimal range if high removals are needed.
- ⁶ Technologies reject a large volume of water--may not be appropriate for areas where water quantity may be an issue.
- ⁷ To obtain high removals, iron to arsenic ratio must be at least 20:1.

BOARD NOTE: Derived from 40 CFR 141.62-(2002)(2003).

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.310 Old Maximum Contaminant Levels (MCLs) for Organic Chemical Contaminants

The following are ~~the~~ MCLs for organic chemical contaminants. The MCLs for organic chemical contaminants in this Section apply to all CWSs. They are additional State requirements. Compliance with the MCLs in subsections (a) and (b) is calculated pursuant to Subpart O of this Part. ~~Compliance with the MCL in subsection (c) is calculated pursuant to Subpart P of this Part.~~

Contaminant	Level mg/l	Additional State Requirement (*)
a) Chlorinated hydrocarbons		
Aldrin	0.001	*
DDT	0.05	*
Dieldrin	0.001	*
Heptachlor	0.0001	*
Heptachlor epoxide	0.0001	*

BOARD NOTE: ~~Originally derived from 40 CFR 141.12(a)(1994), USEPA removed the last entry in this subsection and marked it reserved at 57 Fed. Reg. 31838 (July 17, 1992). USEPA added another listing of organic MCLs at 40 CFR 141.61 (2002). Heptachlor, heptachlor epoxide, and 2,4 D appear in both this Section and in Section 611.311, with a different MCL in each Section. The heptachlor, heptachlor epoxide, and 2,4 D MCLs in this Section are Illinois limitations that are more stringent than the federal requirements. However, detection of these contaminants or violation of their federally-derived revised Section 611.311 MCLs imposes more stringent monitoring, reporting, and notice requirements.~~

b) ~~Chlorophenoxy~~s

2,4-D 0.01 *

BOARD NOTE: Originally derived from 40 CFR 141.12(b) (2002), USEPA removed the last entry in this subsection and marked it reserved at 56 Fed. Reg. 3578 (Jan. 30, 1991). See the preceding Board Note regarding the dual listing of MCLs for 2,4-D.

e) TTHM 0.10 *

1) ~~The MCL of 0.10 mg/l for TTHM applies to a Subpart B CWS supplier that serves 10,000 or more persons, until December 31, 2001.~~

2) ~~The MCL of 0.10 mg/l for TTHM applies to a CWS supplier that uses only groundwater not under the direct influence of surface water and serves 10,000 or more persons, until December 31, 2003.~~

3) ~~After December 31, 2003, the MCL for TTHM in this Section is no longer applicable.~~

BOARD NOTE: ~~Derived from 40 CFR 141.12 (2002). This is an additional State requirement to the extent that it applies to a supplier other than a CWS supplier that adds a disinfectant at any part of treatment and which provides water to 10,000 or more persons. The new MCL for TTHM is listed in Section 611.312.~~

<u>Contaminant</u>	<u>MCL (mg/l)</u>
<u>Aldrin</u>	<u>0.001</u>
<u>DDT</u>	<u>0.05</u>
<u>Dieldrin</u>	<u>0.001</u>
<u>Heptachlor</u>	<u>0.0001</u>
<u>Heptachlor epoxide</u>	<u>0.0001</u>
<u>2,4-D</u>	<u>0.01</u>

BOARD NOTE: Originally derived from 40 CFR 141.12 (1994), USEPA removed the last entry in subsections (a) and (b) and marked them reserved at 57 Fed. Reg. 31838 (July 17, 1992). USEPA added another listing of organic MCLs at 40 CFR 141.61 (2002). Heptachlor, heptachlor epoxide, and 2,4-D appear in both this Section and in Section 611.311, with a different MCL in each Section. The heptachlor, heptachlor epoxide, and 2,4-D MCLs in this Section are Illinois limitations that are more stringent than the federal requirements. However, detection of these contaminants or violation of their federally-derived revised Section 611.311 MCLs imposes more stringent monitoring, reporting, and notice requirements.

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.311 Revised MCLs for Organic Chemical Contaminants

- a) Volatile organic chemical contaminants. The following MCLs for volatile organic chemical contaminants (VOCs) apply to CWS suppliers and NTNCWS suppliers. ~~The MCLs for dichloromethane, 1,2,4-trichlorobenzene, and 1,1,2-trichloroethane were effective January 17, 1994.~~

CAS No.	Contaminant	MCL (mg/l)
71-43-2	Benzene	0.005
56-23-5	Carbon tetrachloride	0.005
95-50-1	o-Dichlorobenzene	0.6
106-46-7	p-Dichlorobenzene	0.075
107-06-2	1,2-Dichloroethane	0.005
75-35-4	1,1-Dichloroethylene	0.007
156-59-2	cis-1,2-Dichloroethylene	0.07
156-60-5	trans-1,2-Dichloroethylene	0.1
75-09-2	Dichloromethane (methylene chloride)	0.005
78-87-5	1,2-Dichloropropane	0.005
100-41-4	Ethylbenzene	0.7
108-90-7	Monochlorobenzene	0.1
100-42-5	Styrene	0.1
127-18-4	Tetrachloroethylene	0.005
108-88-3	Toluene	1
120-82-1	1,2,4-Trichlorobenzene	0.07
71-55-6	1,1,1-Trichloroethane	0.2
79-00-5	1,1,2-Trichloroethane	0.005
79-01-6	Trichloroethylene	0.005
75-01-4	Vinyl chloride	0.002
1330-20-7	Xylenes (total)	10

BOARD NOTE: See the definition of “initial compliance period” at Section 611.101.

- b) USEPA has identified, as indicated below, granular activated carbon (GAC), packed tower aeration (PTA), or oxidation (OX) as BAT for achieving compliance with the MCLs for volatile organic chemical contaminants (VOCs) and synthetic organic chemical contaminants (SOCs) in subsections (a) and (c) of this Section.

15972-60-8	Alachlor	GAC
116-06-3	Aldicarb*	GAC
1646-87-4	Aldicarb sulfone*	GAC
1646-87-3	Aldicarb sulfoxide*	GAC
1912-24-9	Atrazine	GAC
71-43-2	Benzene	GAC, PTA

50-32-8	Benzo(a)pyrene	GAC
1563-66-2	Carbofuran	GAC
56-23-5	Carbon tetrachloride	GAC, PTA
57-74-9	Chlordane	GAC
94-75-7	2,4-D	GAC
75-99-0	Dalapon	GAC
96-12-8	Dibromochloropropane	GAC, PTA
95-50-1	o-Dichlorobenzene	GAC, PTA
106-46-7	p-Dichlorobenzene	GAC, PTA
107-06-2	1,2-Dichloroethane	GAC, PTA
156-59-2	cis-1,2-Dichloroethylene	GAC, PTA
156-60-5	trans-1,2-Dichloroethylene	GAC, PTA
75-35-4	1,1-Dichloroethylene	GAC, PTA
75-09-2	Dichloromethane	PTA
78-87-5	1,2-Dichloropropane	GAC, PTA
103-23-1	Di(2-ethylhexyl)adipate	GAC, PTA
117-81-7	Di(2-ethylhexyl)phthalate	GAC
88-85-7	Dinoseb	GAC
85-00-7	Diquat	GAC
145-73-3	Endothall	GAC
72-20-8	Endrin	GAC
106-93-4	Ethylene dibromide (EDB)	GAC, PTA
100-41-4	Ethylbenzene	GAC, PTA
1071-53-6	Glyphosate	OX
76-44-8	Heptachlor	GAC
1024-57-3	Heptachlor epoxide	GAC
118-74-1	Hexachlorobenzene	GAC
77-47-3	Hexachlorocyclopentadiene	GAC, PTA
58-89-9	Lindane	GAC
72-43-5	Methoxychlor	GAC
108-90-7	Monochlorobenzene	GAC, PTA
23135-22-0	Oxamyl	GAC
87-86-5	Pentachlorophenol	GAC
1918-02-1	Picloram	GAC
1336-36-3	Polychlorinated biphenyls (PCB)	GAC
122-34-9	Simazine	GAC
100-42-5	Styrene	GAC, PTA
1746-01-6	2,3,7,8-TCDD	GAC
127-18-4	Tetrachloroethylene	GAC, PTA
108-88-3	Toluene	GAC
8001-35-2	Toxaphene	GAC
120-82-1	1,2,4-trichlorobenzene	GAC, PTA
71-55-6	1,1,1-Trichloroethane	GAC, PTA
79-00-5	1,1,2-trichloroethane	GAC, PTA
79-01-6	Trichloroethylene	GAC, PTA
93-72-1	2,4,5-TP	GAC

75-01-4 Vinyl chloride PTA
 1330-20-7 Xylene GAC, PTA

* See the Board note appended to the end of this Section.

- c) Synthetic organic chemical contaminants. The following MCLs for SOCs apply to CWS and NTNCWS suppliers. ~~The MCLs for benzo(a)pyrene, dalapon, di(2-ethylhexyl)adipate, di(2-ethylhexyl)phthalate, dinoseb, diquat, endothall, endrin, glyphosate, hexachlorobenzene, hexachlorocyclopentadiene, oxamyl (vydate), picloram, simazine, and 2,3,7,8-TCDD (dioxin) were effective January 17, 1994.~~

CAS Number	Contaminant	MCL (mg/l)
15972-60-8	Alachlor	0.002
116-06-3	Aldicarb*	0.002
1646-87-4	Aldicarb sulfone*	0.002
1646-87-3	Aldicarb sulfoxide*	0.004
1912-24-9	Atrazine	0.003
50-32-8	Benzo(a)pyrene	0.0002
1563-66-2	Carbofuran	0.04
57-74-9	Chlordane	0.002
94-75-7	2,4-D	0.07
75-99-0	Dalapon	0.2
96-12-8	Dibromochloropropane	0.0002
103-23-1	Di(2-ethylhexyl)adipate	0.4
117-81-7	Di(2-ethylhexyl)phthalate	0.006
88-85-7	Dinoseb	0.007
85-00-7	Diquat	0.02
145-73-3	Endothall	0.1
72-20-8	Endrin	0.002
106-93-4	Ethylene dibromide	0.00005
1071-53-6	Glyphosate	0.7
76-44-8	Heptachlor	0.0004
1024-57-3	Heptachlor epoxide	0.0002
118-74-1	Hexachlorobenzene	0.001
77-47-4	Hexachlorocyclopentadiene	0.05
58-89-9	Lindane	0.0002
72-43-5	Methoxychlor	0.04
23135-22-0	Oxamyl (Vydate)	0.2
87-86-5	Pentachlorophenol	0.001
1918-02-1	Picloram	0.5
1336-36-3	Polychlorinated biphenyls (PCBs)	0.0005
122-34-9	Simazine	0.004
1746-01-6	2,3,7,8-TCDD (Dioxin)	0.00000003
8001-35-2	Toxaphene	0.003
93-72-1	2,4,5-TP	0.05

* See the Board note appended to the end of this Section.

BOARD NOTE: Derived from 40 CFR 141.61-(2002) (2003). See the definition of “initial compliance period” at Section 611.101. More stringent state MCLs for 2,4-D, heptachlor, and heptachlor epoxide appear at Section 611.310. See the Board Note at that provision. In 40 ~~C.F.R.~~ CFR 141.6(g), USEPA postponed the effectiveness of the MCLs for aldicarb, aldicarb sulfone, and aldicarb sulfoxide until it took further action on those MCLs. See 40 CFR 141.6(g) and 57 Fed. Reg. 22178 (May 27, 1992). USEPA has stated that it anticipates taking no action until 2005 on a federal national primary drinking water regulation (NPDWR) applicable to the aldicarbs. 68 Fed. Reg. 31108 (May 27, 2003). No aldicarb requirements apply in Illinois until after USEPA adopts such requirements, and the Board removes this statement.

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.330 Maximum Contaminant Levels for Radionuclides

- a) This subsection corresponds with 40 CFR 141.66(a), marked reserved by USEPA. This statement maintains structural consistency with USEPA rules.
- b) MCL for combined radium-226 and -228. The maximum contaminant level for combined radium-226 and radium-228 is 5 pCi/ℓ. The combined radium-226 and radium-228 value is determined by the addition of the results of the analysis for radium-226 and the analysis for radium-228.
- c) MCL for gross alpha particle activity (excluding radon and uranium). The maximum contaminant level for gross alpha particle activity (including radium-226 but excluding radon and uranium) is 15 pCi/ℓ.
- d) Effective December 8, 2003, MCL for beta particle and photon radioactivity.
 - 1) The average annual concentration of beta particle and photon radioactivity from man-made radionuclides in drinking water must not produce an annual dose equivalent to the total body or any internal organ greater than 4 millirem/year (mrem/year).
 - 2) Except for the radionuclides listed in the following table, the concentration of man-made radionuclides causing 4 mrem total body or organ dose equivalents must be calculated on the basis of two liters per day drinking water intake, using the 168-hour data list set forth in “Maximum Permissible Body Burdens and Maximum Permissible Concentrations of Radionuclides in Air and in Water for Occupational Exposure,” incorporated by reference in Section 611.102, available from the NTIS. If two or more radionuclides are present, the sum of their annual dose equivalent to the total body or to any organ must not exceed 4 mrem/year.

Average Annual Concentrations Assumed to Produce a Total

Body or Organ Dose of 4 mrem/yr

Radionuclide	Critical organ	pCi per liter
1. Tritium	Total body	20,000
2. Strontium-90	Bone Marrow	8

- e) MCL for uranium. Effective December 8, 2003, the maximum contaminant level for uranium is 30 $\mu\text{g}/\ell$.
- f) Compliance dates for combined radium-226 and -228, gross alpha particle activity, gross beta particle and photon radioactivity, and uranium: Effective December 8, 2003, a CWS supplier must comply with the MCLs listed in subsections (b) through (e) of this Section ~~beginning December 8, 2003, and compliance must be determined in accordance with the requirements of Subpart Q of this Part. Compliance with reporting requirements for the radionuclides under Appendices A, G, and H of this Part is required before December 8, 2003.~~
- g) Best available technologies (BATs) for radionuclides. USEPA has identified the technologies indicated in the following table as the BAT for achieving compliance with the MCLs for combined radium-226 and -228, uranium, gross alpha particle activity, and beta particle and photon radioactivity.

BAT for Combined Radium-226 and Radium-228, Uranium, Gross Alpha Particle Activity, and Beta Particle and Photon Radioactivity

Contaminant	BAT
1. Combined radium-226 and radium-228	Ion exchange, reverse osmosis, lime softening.
2. Uranium	Ion exchange, reverse osmosis, lime softening, coagulation/filtration.
3. Gross alpha particle activity (excluding Radon and Uranium)	Reverse osmosis.
4. Beta particle and photon radioactivity	Ion exchange, reverse osmosis.

- h) Small systems compliance technologies list for radionuclides.

List of Small Systems Compliance Technologies for Radionuclides and Limitations to Use

Unit technologies	Limitations (see footnotes)	Operator skill level required ¹	Raw water quality range and considerations ¹
1. Ion exchange (IE)	(a)	Intermediate	All ground waters.
2. Point of use (POU ²) IE	(b)	Basic	All ground waters.

3. Reverse osmosis (RO)	(c)	Advanced	Surface waters usually require pre-filtration.
4. POU ² RO	(b)	Basic	Surface waters usually require pre-filtration.
5. Lime softening	(d)	Advanced	All waters.
6. Green sand filtration	(e)	Basic	
7. Co-precipitation with Barium sulfate	(f)	Intermediate to Advanced	Ground waters with suitable water quality.
8. Electrodialysis/ electrodialysis reversal		Basic to Intermediate	All ground waters.
9. Pre-formed hydrous Manganese oxide filtration	(g)	Intermediate	All ground waters.
10. Activated alumina	(a), (h)	Advanced	All ground waters; competing anion concentrations may affect regeneration frequency.
11. Enhanced coagulation/ filtration	(i)	Advanced	Can treat a wide range of water qualities.

¹ National Research Council (NRC). "Safe Water from Every Tap: Improving Water Service to Small Communities," National Academy Press, Washington, D.C. 1997.

² A POU, or "point-of-use" technology is a treatment device installed at a single tap used for the purpose of reducing contaminants in drinking water at that one tap. POU devices are typically installed at the kitchen tap.
BOARD NOTE: USEPA refers the reader to the notice of data availability (NODA) at 66 Fed. Reg. 21576 (April 21, 2000) for more details.

Limitations Footnotes: Technologies for Radionuclides:

- (a) The regeneration solution contains high concentrations of the contaminant ions. Disposal options should be carefully considered before choosing this technology.
- (b) When POU devices are used for compliance, programs for long-term operation, maintenance, and monitoring must be provided by water utility to

ensure proper performance.

- (c) Reject water disposal options should be carefully considered before choosing this technology.

BOARD NOTE: In corresponding 40 CFR 141.66, Table C, footnote c states in part as follows: “See other RO limitations described in the SWTR Compliance Technologies Table.” Table C was based in significant part on “Table 13.—Technologies for Radionuclides” that appears at 63 Fed. Reg. 42032 at 42043 (August 6, 1998), which refers to “Table 2.—SWTR Compliance Technology Table: Filtration.” That Table 2 lists the limitations on RO as follows:

- ^d Blending (combining treated water with untreated raw water) cannot be practiced at risk of increasing microbial concentrations in finished water.
 - ^e Post-disinfection recommended as a safety measure and for residual maintenance.
 - ^f Post-treatment corrosion control will be needed prior to distribution.
- 63 Fed. Reg. at 42036.

- (d) The combination of variable source water quality and the complexity of the water chemistry involved may make this technology too complex for small surface water systems.
- (e) Removal efficiencies can vary depending on water quality.
- (f) This technology may be very limited in application to small systems. Since the process requires static mixing, detention basins, and filtration, it is most applicable to systems with sufficiently high sulfate levels that already have a suitable filtration treatment train in place.
- (g) This technology is most applicable to small systems that already have filtration in place.
- (h) Handling of chemicals required during regeneration and pH adjustment may be too difficult for small systems without an adequately trained operator.
- (i) Assumes modification to a coagulation/filtration process already in place.

Compliance Technologies by System Size Category for Radionuclide NPDWRs

Contaminant	Compliance technologies ¹ for system size categories (population served)		
	25-500	501-3,300	3,300-10,000
1. Combined radium-226 and radium-228	1, 2, 3, 4, 5, 6, 7, 8, 9	1, 2, 3, 4, 5, 6, 7, 8, 9	1, 2, 3, 4, 5, 6, 7, 8, 9

2. Gross alpha particle activity	3, 4	3, 4	3, 4
3. Beta particle activity and photon activity	1, 2, 3, 4	1, 2, 3, 4	1, 2, 3, 4
4. Uranium	1, 2, 4, 10, 11	1, 2, 3, 4, 5, 10, 11	1, 2, 3, 4, 5, 10, 11

Note: ¹ Numbers correspond to those technologies found listed in the table, “List of Small Systems Compliance Technologies for Radionuclides and Limitations to Use,” set forth above.

BOARD NOTE: Derived from 40 CFR 141.66-(2002) (2003).

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.331 Beta Particle and Photon Radioactivity (Repealed)

The following provisions apply until December 8, 2003:

- a) ~~The average annual concentration of beta particle and photon radio-activity from man-made radionuclides in drinking water must not produce an annual dose equivalent to the total body or any internal organ greater than 4 mrem/year.~~
- b) ~~Except for the radionuclides listed below, the concentration of man-made radionuclides causing 4 mrem total body or organ dose equivalents must be calculated on the basis of a 2 liter per day drinking water intake using the 168 hour data listed in “Maximum Permissible Body Burdens and Maximum Permissible Concentrations of Radionuclides in Air and in Water for Occupational Exposure,” NCRP Report Number 22, incorporated by reference in Section 611.102. If two or more radionuclides are present, the sum of their annual dose equivalent to the total body or to any organ must not exceed 4 mrem/year.~~

~~AVERAGE ANNUAL CONCENTRATIONS ASSUMED TO PRODUCE A TOTAL BODY OR ORGAN DOSE OF 4 mrem/year~~

Radionuclide	Critical Organ	pCi/l
Tritium	Total body	20,000
Strontium-90	Bone marrow	8

BOARD NOTE: Derived from 40 CFR 141.16 (2002).

(Source: Repealed at 28 Ill. Reg. _____, effective _____)

SUBPART G: LEAD AND COPPER

Section 611.351 Applicability of Corrosion Control

- a) Corrosion control required. Suppliers must complete the applicable corrosion control treatment requirements described in Section 611.352 on or before the deadlines set forth in this Section.
 - 1) Large systems. Each large system supplier (one regularly serving more than 50,000 persons) must complete the corrosion control treatment steps specified in subsection (d) of this Section, unless it is deemed to have optimized corrosion control under subsection (b)(2) or (b)(3) of this Section.
 - 2) Medium-sized and small systems. Each small system supplier (one regularly serving 3,300 or fewer persons) and each medium-sized system (one regularly serving more than 3,300 up to 50,000 persons) must complete the corrosion control treatment steps specified in subsection (e) of this Section, unless it is deemed to have optimized corrosion control under one of subsections (b)(1), (b)(2), or (b)(3) of this Section.
- b) Suppliers deemed to have optimized corrosion control. A supplier is deemed to have optimized corrosion control, and is not required to complete the applicable corrosion control treatment steps identified in this Section, if the supplier satisfies one of the ~~criteria specified~~ criteria specified in subsections (b)(1) through (b)(3) of this Section. Any such system deemed to have optimized corrosion control under this subsection, and which has treatment in place, must continue to operate and maintain optimal corrosion control treatment and meet any requirements that the Agency determines are appropriate to ensure optimal corrosion control treatment is maintained.
 - 1) Small- or medium-sized system meeting action levels. A small system or medium-sized system supplier is deemed to have optimized corrosion control if the system meets the lead and copper action levels during each of two consecutive six-month monitoring periods with monitoring conducted in accordance with Section 611.356.
 - 2) SEP for equivalent activities to corrosion control. The Agency must, by a SEP granted pursuant to Section 611.110, deem any supplier to have optimized corrosion control treatment if it determines that the supplier has conducted activities equivalent to the corrosion control steps applicable under this Section. In making this determination, the Agency must specify the water quality control parameters representing optimal corrosion control in accordance with Section 611.352(f). A water supplier that is deemed to have optimized corrosion control under this subsection (b)(2) must operate in compliance with the Agency-designated optimal water

quality control parameters in accordance with Section 611.352(g) and must continue to conduct lead and copper tap and water quality parameter sampling in accordance with Sections 611.356(d)(3) and 611.357(d), respectively. A supplier must provide the Agency with the following information in order to support an Agency SEP determination under this subsection (b)(2):

- A) The results of all test samples collected for each of the water quality parameters in Section 611.352(c)(3);
 - B) A report explaining the test methods the supplier used to evaluate the corrosion control treatments listed in Section 611.352(c)(1), the results of all tests conducted, and the basis for the supplier's selection of optimal corrosion control treatment;
 - C) A report explaining how the supplier has installed corrosion control and how the supplier maintains it to insure minimal lead and copper concentrations at consumer's taps; and
 - D) The results of tap water samples collected in accordance with Section 611.356 at least once every six months for one year after corrosion control has been installed.
- 3) Results less than practical quantitation level (PQL) for lead. Any supplier is deemed to have optimized corrosion control if it submits results of tap water monitoring conducted in accordance with Section 611.356 and source water monitoring conducted in accordance with Section 611.358 that demonstrate that for two consecutive six-month monitoring periods the difference between the 90th percentile tap water lead level, computed pursuant to Section 611.350(c)(3), and the highest source water lead concentration is less than the practical quantitation level for lead specified in Section 611.359(a)(1)(B)(i).
- A) Those systems whose highest source water lead level is below the method detection limit (MDL) may also be deemed to have optimized corrosion control under this subsection (b) if the 90th percentile tap water lead level is less than or equal to the PQL for lead for two consecutive six-month monitoring periods.
 - B) Any water system deemed to have optimized corrosion control in accordance with this subsection (b) must continue monitoring for lead and copper at the tap no less frequently than once every three calendar years using the reduced number of sites specified in Section 611.356(c) and collecting the samples at times and locations specified in Section 611.356(d)(4)(D). Any such system that has not conducted a round of monitoring pursuant to Section

611.356(d) since September 30, 1997, must ~~complete~~ have completed a round of monitoring pursuant to this subsection (b) no later than September 30, 2000.

- C) Any water system deemed to have optimized corrosion control pursuant to this subsection (b) must notify the Agency in writing pursuant to Section 611.360(a)(3) of any change in treatment or the addition of a new source. The Agency must require any such system to conduct additional monitoring or to take other action if the Agency determines that the additional monitoring is necessary and appropriate to ensure that the supplier maintains minimal levels of corrosion in its distribution system.
 - D) As of July 12, 2001, a supplier is not deemed to have optimized corrosion control under this subsection (b), and must implement corrosion control treatment pursuant to subsection (b)(3)(E) of this Section, unless it meets the copper action level.
 - E) Any supplier triggered into corrosion control because it is no longer deemed to have optimized corrosion control under this subsection must implement corrosion control treatment in accordance with the deadlines in subsection (e) of this Section. Any such large system supplier must adhere to the schedule specified in that subsection (e) for a medium-sized system supplier, with the time periods for completing each step being triggered by the date the supplier is no longer deemed to have optimized corrosion control under this subsection (b).
- c) Suppliers not required to complete corrosion control steps for having met both action levels.
- 1) Any small system or medium-sized system supplier, otherwise required to complete the corrosion control steps due to its exceedence of the lead or copper action level, may cease completing the treatment steps after the supplier has fulfilled both of the following conditions:
 - A) It has met both the copper action level and the lead action level during each of two consecutive six-month monitoring periods conducted pursuant to Section 611.356; and
 - B) The supplier has submitted the results for those two consecutive six-month monitoring periods to the Agency.
 - 2) A supplier that has ceased completing the corrosion control steps pursuant to subsection (c)(1) of this Section (or the Agency, if appropriate) must resume completion of the applicable treatment steps, beginning with the

first treatment step that the supplier previously did not complete in its entirety, if the supplier thereafter exceeds the lead or copper action level during any monitoring period.

- 3) The Agency may, by SEP, require a supplier to repeat treatment steps previously completed by the supplier where it determines that this is necessary to properly implement the treatment requirements of this Section. Any such SEP must explain the basis for this decision.
 - 4) The requirement for any small- or medium-sized system supplier to implement corrosion control treatment steps in accordance with subsection (e) of this Section (including systems deemed to have optimized corrosion control under subsection (b)(1) of this Section) is triggered whenever any small- or medium-sized system supplier exceeds the lead or copper action level.
- d) Treatment steps and deadlines for large systems. Except as provided in subsections (b)(2) and (b)(3) of this Section, large system suppliers must complete the following corrosion control treatment steps (described in the referenced portions of Sections 611.352, 611.356, and 611.357) on or before the indicated dates.
- 1) Step 1: The supplier must ~~conduct~~ have conducted initial monitoring (Sections 611.356(d)(1) and 611.357(b)) during two consecutive six-month monitoring periods on or before January 1, 1993.
 - 2) Step 2: The supplier must ~~complete~~ have completed corrosion control studies (Section 611.352(c)) on or before July 1, 1994.
 - 3) Step 3: The Agency must ~~approve~~ have approved optimal corrosion control treatment (Section 611.352(d)) by a SEP issued pursuant to Section 611.110 on or before January 1, 1995.
 - 4) Step 4: The supplier must ~~install~~ have installed optimal corrosion control treatment (Section 611.352(e)) by January 1, 1997.
 - 5) Step 5: The supplier must ~~complete~~ have completed follow-up sampling (Sections 611.356(d)(2) and 611.357(c)) by January 1, 1998.
 - 6) Step 6: The Agency must ~~review~~ have reviewed installation of treatment and approve optimal water quality control parameters (Section 611.352(f)) by July 1, 1998.
 - 7) Step 7: The supplier must operate in compliance with the Agency-specified optimal water quality control parameters (Section 611.352(g)) and continue to conduct tap sampling (Sections 611.356(d)(3) and

611.357(d)).

- e) Treatment steps and deadlines for small- and medium-sized system suppliers. Except as provided in subsection (b) of this Section, small- and medium-sized system suppliers must complete the following corrosion control treatment steps (described in the referenced portions of Sections 611.352, 611.356, and 611.357) by the indicated time periods.
- 1) Step 1: The supplier must conduct initial tap sampling (Sections 611.356(d)(1) and 611.357(b)) until the supplier either exceeds the lead action level or the copper action level or it becomes eligible for reduced monitoring under Section 611.356(d)(4). A supplier exceeding the lead action level or the copper action level must recommend optimal corrosion control treatment (Section 611.352(a)) within six months after it exceeds one of the action levels.
 - 2) Step 2: Within 12 months after a supplier exceeds the lead action level or the copper action level, the Agency may require the supplier to perform corrosion control studies (Section 611.352(b)). If the Agency does not require the supplier to perform such studies, the Agency must, by a SEP issued pursuant to Section 611.110, specify optimal corrosion control treatment (Section 611.352(d)) within the following timeframes:
 - A) for medium-sized systems, within 18 months after such supplier exceeds the lead action level or the copper action level,
 - B) for small systems, within 24 months after such supplier exceeds the lead action level or the copper action level.
 - 3) Step 3: If the Agency requires a supplier to perform corrosion control studies under step 2 (subsection (e)(2) of this Section), the supplier must complete the studies (Section 611.352(c)) within 18 months after the Agency requires that such studies be conducted.
 - 4) Step 4: If the supplier has performed corrosion control studies under step 2 (subsection (e)(2) of this Section), the Agency must, by a SEP issued pursuant to Section 611.110, approve optimal corrosion control treatment (Section 611.352(d)) within six months after completion of step 3 (subsection (e)(3) of this Section).
 - 5) Step 5: The supplier must install optimal corrosion control treatment (Section 611.352(e)) within 24 months after the Agency approves such treatment.
 - 6) Step 6: The supplier must complete follow-up sampling (Sections 611.356(d)(2) and 611.357(c)) within 36 months after the Agency

approves optimal corrosion control treatment.

- 7) Step 7: The Agency must review the supplier's installation of treatment and, by a SEP issued pursuant to Section 611.110, approve optimal water quality control parameters (Section 611.352(f)) within six months after completion of step 6 (subsection (e)(6) of this Section).
- 8) Step 8: The supplier must operate in compliance with the Agency-approved optimal water quality control parameters (Section 611.352(g)) and continue to conduct tap sampling (Sections 611.356(d)(3) and 611.357(d)).

BOARD NOTE: Derived from 40 CFR 141.81-~~(2002)~~ (2003).

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.354 Lead Service Line Replacement

- a) Suppliers required to replace lead service lines.
 - 1) If the results from tap samples taken pursuant to Section 611.356(d)(2) exceed the lead action level after the supplier has installed corrosion control or source water treatment (whichever sampling occurs later), the supplier must recommence replacing lead service lines in accordance with the requirements of subsection (b) of this Section.
 - 2) If a supplier is in violation of Section 611.351 or Section 611.353 for failure to install source water or corrosion control treatment, the Agency may, by a SEP issued pursuant to Section 611.110, require the supplier to commence lead service line replacement under this Section after the date by which the supplier was required to conduct monitoring under Section 611.356(d)(2) has passed.
- b) Annual replacement of lead service lines.
 - 1) A supplier required to commence lead service line replacement pursuant to subsection (a) of this Section must annually replace at least seven percent of the initial number of lead service lines in its distribution system.
 - 2) The initial number of lead service lines is the number of lead lines in place at the time the replacement program begins.
 - 3) The supplier must identify the initial number of lead service lines in its distribution system, including an identification of the portions of the system owned by the supplier, based on a materials evaluation, including

the evaluation required under Section 611.356(a) and relevant legal authorities (e.g., contracts, local ordinances) ~~regardi ng~~ regarding the portion owned by the system.

- 4) The first year of lead service line replacement must begin on the date the supplier exceeded the action level in tap sampling referenced in subsection (a) of this Section.
- c) Service lines not needing replacement. A supplier is not required to replace any individual lead service line for which the lead concentrations in all service line samples taken from that line pursuant to Section 611.356(b)(3) are less than or equal to 0.015 mg/ℓ.
 - d) A water supplier must replace that portion of the lead service line that it owns. In cases where the supplier does not own the entire lead service line, the supplier must notify the owner of the line, or the owner's authorized agent, that the supplier will replace the portion of the service line that it owns and must offer to replace the owner's portion of the line. A supplier is not required to bear the cost of replacing the privately-owned portion of the line, nor is it required to replace the privately-owned portion where the owner chooses not to pay the cost of replacing the privately-owned portion of the line, or where replacing the privately-owned portion would be precluded by State, local, or common law. A water supplier that does not replace the entire length of the service line also must complete the following tasks:
 - 1) Notice Prior to Commencement of Work.
 - A) At least 45 days prior to commencing the partial replacement of a lead service line, the water supplier must provide notice to the residents of all buildings served by the line explaining that they may experience a temporary increase of lead levels in their drinking water, along with guidance on measures consumers can take to minimize their exposure to lead.
 - B) The Agency, by issuing an appropriate SEP, may allow the water supplier to provide notice under the previous sentence less than 45 days prior to commencing partial lead service line replacement where it determines that such replacement is in conjunction with emergency repairs.
 - C) In addition, the water supplier must inform the residents served by the line that the supplier will, at the supplier's expense, collect a sample from each partially-replaced lead service line that is representative of the water in the service line for analysis of lead content, as prescribed by Section 611.356(b)(3), within 72 hours after the completion of the partial replacement of the service line.

The supplier must collect the sample and report the results of the analysis to the owner and the residents served by the line within three business days of receiving the results.

- D) Mailed notices post-marked within three business days of receiving the results must be considered “on time.”
- 2) The water supplier must provide the information required by subsection (d)(1) of this Section to the residents of individual dwellings by mail or by other methods approved by the Agency by a SEP issued pursuant to Section 611.110. In instances where multi-family dwellings are served by the service line, the water supplier must have the option to post the information at a conspicuous location.
- e) Agency determination of shorter replacement schedule.
 - 1) The Agency must, by a SEP issued pursuant to Section 611.110, require a supplier to replace lead service lines on a shorter schedule than that otherwise required by this Section if it determines, taking into account the number of lead service lines in the system, that such a shorter replacement schedule is feasible.
 - 2) The Agency must notify the supplier of its finding pursuant to subsection (e)(1) of this Section within six months after the supplier is triggered into lead service line replacement based on monitoring, as referenced in subsection (a) of this Section.
- f) Cessation of service line replacement.
 - 1) Any supplier may cease replacing lead service lines whenever it fulfills both of the following conditions:
 - A) First draw tap samples collected pursuant to Section 611.356(b)(2) meet the lead action level during each of two consecutive six-month monitoring periods; and
 - B) The supplier has submitted those results to the Agency.
 - 2) If any of the supplier’s first draw tap samples thereafter exceed the lead action level, the supplier must recommence replacing lead service lines pursuant to subsection (b) of this Section.
- g) To demonstrate compliance with subsections (a) through (d) of this Section, a supplier must report to the Agency the information specified in Section 611.360(e).

BOARD NOTE: Derived from 40 CFR 141.84-~~(2002)~~ (2003).

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.356 Tap Water Monitoring for Lead and Copper

- a) Sample site location.
 - 1) Selecting a pool of targeted sampling sites.
 - A) By the applicable date for commencement of monitoring under subsection (d)(1) of this Section, each supplier must complete a materials evaluation of its distribution system in order to identify a pool of targeted sampling sites that meets the requirements of this Section.
 - B) The pool of targeted sampling sites must be sufficiently large to ensure that the supplier can collect the number of lead and copper tap samples required by subsection (c) of this Section.
 - C) The supplier must select the sites for collection of first draw samples from this pool of targeted sampling sites.
 - D) The supplier must not select as sampling sites any faucets that have point-of-use or point-of-entry treatment devices designed to remove or capable of removing inorganic contaminants.
 - 2) Materials evaluation.
 - A) A supplier must use the information on lead, copper, and galvanized steel collected pursuant to 40 CFR 141.42(d) (special monitoring for corrosivity characteristics) when conducting a materials evaluation.
 - B) When an evaluation of the information collected pursuant to 40 CFR 141.42(d) is insufficient to locate the requisite number of lead and copper sampling sites that meet the targeting criteria in subsection (a) of this Section, the supplier must review the following sources of information in order to identify a sufficient number of sampling sites:
 - i) All plumbing codes, permits, and records in the files of the building departments that indicate the plumbing materials that are installed within publicly- and privately-owned structures connected to the distribution system;

- ii) All inspections and records of the distribution system that indicate the material composition of the service connections which connect a structure to the distribution system;
 - iii) All existing water quality information, which includes the results of all prior analyses of the system or individual structures connected to the system, indicating locations that may be particularly susceptible to high lead or copper concentrations; and
 - iv) The supplier must seek to collect such information where possible in the course of its normal operations (e.g., checking service line materials when reading water meters or performing maintenance activities).
- 3) Tiers of sampling sites. Suppliers must categorize the sampling sites within their pool according to the following tiers:
- A) CWS Tier 1 sampling sites. “CWS Tier 1 sampling sites” must include the following single-family structures:
 - i) Those that contain copper pipes with lead solder installed after 1982 or which contain lead pipes; or
 - ii) Those that are served by a lead service line.

BOARD NOTE: Subsection (a)(3)(A) was derived from segments of 40 CFR 141.86(a)(3)-~~(2002)~~ (2003). This allows the pool of CWS tier 1 sampling sites to consist exclusively of structures served by lead service lines.

- B) CWS Tier 2 sampling sites. “CWS Tier 2 sampling sites” must include the following buildings, including multiple-family structures:
 - i) Those that contain copper pipes with lead solder installed after 1982 or contain lead pipes; or
 - ii) Those that are served by a lead service line.

BOARD NOTE: Subsection (a)(3)(B) was derived from segments of 40 CFR 141.86(a)(4)-~~(2002)~~ (2003). This allows the pool of CWS tier 2 sampling sites to consist exclusively of structures served by lead service lines.

- C) CWS Tier 3 sampling sites. “CWS Tier 3 sampling sites” must include the following single-family structures: those that contain copper pipes with lead solder installed before 1983.

BOARD NOTE: Subsection (a)(3)(C) was derived from segments of 40 CFR 141.86(a)(5)-~~(2002)~~ (2003).

- D) NTNCWS Tier 1 sampling sites. “NTNCWS Tier 1 sampling sites” must include the following buildings:

- i) Those that contain copper pipes with lead solder installed after 1982 or which contain lead pipes; or
- ii) Those that are served by a lead service line.

BOARD NOTE: Subsection (a)(3)(D) was derived from segments of 40 CFR 141.86(a)(6)-~~(2002)~~ (2003). This allows the pool of NTNCWS tier 1 sampling sites to consist exclusively of buildings served by lead service lines.

- E) Alternative NTNCWS sampling sites. “Alternative NTNCWS sampling sites” must include the following buildings: those that contain copper pipes with lead solder installed before 1983.

BOARD NOTE: Subsection (a)(3)(E) was derived from segments of 40 CFR 141.86(a)(7)-~~(2002)~~ (2003).

- 4) Selection of sampling sites. Suppliers must select sampling sites for their sampling pool as follows:

- A) CWS Suppliers. CWS suppliers must use CWS tier 1 sampling sites, except that the supplier may include CWS tier 2 or CWS tier 3 sampling sites in its sampling pool as follows:

- i) If multiple-family residences comprise at least 20 percent of the structures served by a supplier, the supplier may use CWS tier 2 sampling sites in its sampling pool; or

BOARD NOTE: Subsection (a)(4)(A)(i) was derived from a segment of 40 CFR 141.86(a)(3)(ii)-~~(2002)~~ (2003).

- ii) If the CWS supplier has an insufficient number of CWS tier 1 sampling sites on its distribution system, the supplier may use CWS tier 2 sampling sites in its sampling pool; or

BOARD NOTE: Subsection (a)(4)(A)(ii) was derived from

a segment of 40 CFR 141.86(a)(4)-~~(2002)~~ (2003).

- iii) If the CWS supplier has an insufficient number of CWS tier 1 and CWS tier 2 sampling sites on its distribution system, the supplier may complete its sampling pool with CWS tier 3 sampling sites.

BOARD NOTE: Subsection (a)(4)(A)(iii) was derived from a segment of 40 CFR 141.86(a)(5)-~~(2002)~~ (2003).

- iv) If the CWS supplier has an insufficient number of CWS tier 1 sampling sites, CWS tier 2 sampling sites, and CWS tier 3 sampling sites, the supplier must use those CWS tier 1 sampling sites, CWS tier 2 sampling sites, and CWS tier 3 sampling sites that it has and complete its sampling pool with representative sites throughout its distribution system for the balance of its sampling sites. For the purpose of this subsection (a)(4)(A)(iv), a representative site is a site in which the plumbing materials used at that site would be commonly found at other sites served by the water system.

BOARD NOTE: Subsection (a)(4)(A)(iv) was derived from segments of 40 CFR 141.86(a)(5)-~~(2002)~~ (2003).

B) NTNCWS suppliers.

- i) An NTNCWS supplier must select NTNCWS tier 1 sampling sites for its sampling pool.

BOARD NOTE: Subsection (a)(4)(B)(i) was derived from segments of 40 CFR 141.86(a)(6)-~~(2002)~~ (2003).

- ii) If the NTNCWS supplier has an insufficient number of NTNCWS tier 1 sampling sites, the supplier may complete its sampling pool with alternative NTNCWS sampling sites.

BOARD NOTE: Subsection (a)(4)(B)(ii) was derived from segments of 40 CFR 141.86(a)(7)-~~(2002)~~ (2003).

- iii) If the NTNCWS supplier has an insufficient number of NTNCWS tier 1 sampling sites and NTNCWS alternative sampling sites, the supplier must use representative sites throughout its distribution system. For the purpose of this subsection (a)(4)(B)(ii), a representative site is a site in which the plumbing materials used at that site would be

commonly found at other sites served by the water system.

BOARD NOTE: Subsection (a)(4)(B)(iii) was derived from segments of 40 CFR 141.86(a)(7)-~~(2002)~~ (2003).

- C) Suppliers with lead service lines. Any supplier whose distribution system contains lead service lines must draw samples during each six-month monitoring period from sampling sites as follows:
- i) 50 percent of the samples from sampling sites that contain lead pipes or from sampling sites that have copper pipes with lead solder; and
 - ii) 50 percent of those samples from sites served by a lead service line.
 - iii) A supplier that cannot identify a sufficient number of sampling sites served by a lead service line must collect first-draw samples from all of the sites identified as being served by such lines.

BOARD NOTE: Subsection (a)(4)(C) was derived from segments of 40 CFR 141.86(a)(8)-~~(2002)~~ (2003). This allows the pool of sampling sites to consist exclusively of structures or buildings served by lead service lines.

- b) Sample collection methods.
- 1) All tap samples for lead and copper collected in accordance with this Subpart G, with the exception of lead service line samples collected under Section 611.354(c) and samples collected under subsection (b)(5) of this Section, must be first-draw samples.
 - 2) First-draw tap samples.
 - A) Each first-draw tap sample for lead and copper must be one liter in volume and have stood motionless in the plumbing system of each sampling site for at least six hours.
 - B) First-draw samples from residential housing must be collected from the cold water kitchen tap or bathroom sink tap.
 - C) First-draw samples from a non-residential building must be one liter in volume and must be collected at an interior tap from which water is typically drawn for consumption.

- D) Non-first-draw samples collected in lieu of first-draw samples pursuant to subsection (b)(5) of this Section must be one liter in volume and must be collected at an interior tap from which water is typically drawn for consumption.
 - E) First-draw samples may be collected by the supplier or the supplier may allow residents to collect first-draw samples after instructing the residents of the sampling procedures specified in this subsection (b).
 - i) To avoid problems of residents handling nitric acid, acidification of first-draw samples may be done up to 14 days after the sample is collected.
 - ii) After acidification to resolubilize the metals, the sample must stand in the original container for the time specified in the approved USEPA method before the sample can be analyzed.
 - F) If a supplier allows residents to perform sampling under subsection (b)(2)(D) of this Section, the supplier may not challenge the accuracy of sampling results based on alleged errors in sample collection.
- 3) Service line samples.
- A) Each service line sample must be one liter in volume and have stood motionless in the lead service line for at least six hours.
 - B) Lead service line samples must be collected in one of the following three ways:
 - i) At the tap after flushing that volume of water calculated as being between the tap and the lead service line based on the interior diameter and length of the pipe between the tap and the lead service line;
 - ii) Tapping directly into the lead service line; or
 - iii) If the sampling site is a single-family structure, allowing the water to run until there is a significant change in temperature that would be indicative of water that has been standing in the lead service line.
- 4) Follow-up first-draw tap samples.

- A) A supplier must collect each follow-up first-draw tap sample from the same sampling site from which it collected the previous samples.
 - B) If, for any reason, the supplier cannot gain entry to a sampling site in order to collect a follow-up tap sample, the supplier may collect the follow-up tap sample from another sampling site in its sampling pool, as long as the new site meets the same targeting criteria and is within reasonable proximity of the original site.
- 5) Substitute non-first-draw samples.
- A) A NTNCWS supplier or a CWS supplier that meets the criteria of Sections 611.355(c)(7)(A) and (c)(7)(B), that does not have enough taps that can supply first-draw samples, as defined in Section 611.102, may apply to the Agency in writing to substitute non-first-draw samples by a SEP granted under Section 611.110.
 - B) A supplier approved to substitute non-first-draw samples must collect as many first-draw samples from appropriate taps as possible and identify sampling times and locations that would likely result in the longest standing time for the remaining sites.
 - C) The Agency may grant a SEP that waives the requirement for prior Agency approval of non-first-draw sample sites selected by the system.
- c) Number of samples.
- 1) Suppliers must collect at least one sample from the number of sites listed in the first column of Table D of this Part (labelled “standard monitoring”) during each six-month monitoring period specified in subsection (d) of this Section.
 - 2) A supplier conducting reduced monitoring pursuant to subsection (d)(4) of this Section must collect one sample from the number of sites specified in the second column of Table D of this Part (labelled “reduced monitoring”) during each reduced monitoring period specified in subsection (d)(4) of this Section. Such reduced monitoring sites must be representative of the sites required for standard monitoring. The Agency may, by a SEP issued pursuant to Section 611.110, specify sampling locations when a system is conducting reduced monitoring.
- d) Timing of monitoring.
- 1) Initial tap sampling. The first six-month monitoring period for small,

medium-sized and large system suppliers must begin on the dates specified in Table E of this Part.

- A) All large system suppliers must monitor during each of two consecutive six-month periods.
 - B) All small- and medium-sized system suppliers must monitor during each consecutive six-month monitoring period until the following is true:
 - i) The supplier exceeds the lead action level or the copper action level and is therefore required to implement the corrosion control treatment requirements under Section 611.351, in which case the supplier must continue monitoring in accordance with subsection (d)(2) of this Section; or
 - ii) The supplier meets the lead action level and the copper action level during each of two consecutive six-month monitoring periods, in which case the supplier may reduce monitoring in accordance with subsection (d)(4) of this Section.
- 2) Monitoring after installation of corrosion control and source water treatment.
- A) Any large system supplier that installs optimal corrosion control treatment pursuant to Section 611.351(d)(4) must ~~monitor~~ have monitored during each of two consecutive six-month monitoring periods ~~before the date specified in Section 611.351(d)(5) January 1, 1998.~~
 - B) Any small- or medium-sized system supplier that installs optimal corrosion control treatment pursuant to Section 611.351(e)(5) must monitor during each of two consecutive six-month monitoring periods ~~before the date~~ 36 months after the Agency approves optimal corrosion control treatment, as specified in Section 611.351(e)(6).
 - C) Any supplier that installs source water treatment pursuant to Section 611.353(a)(3) must monitor during each of two consecutive six-month monitoring periods ~~before the date~~ 36 months after completion of step 2, as specified in Section 611.353(a)(4).
- 3) Monitoring after the Agency specification of water quality parameter

values for optimal corrosion control. After the Agency specifies the values for water quality control parameters pursuant to Section 611.352(f), the supplier must monitor during each subsequent six-month monitoring period, with the first six-month monitoring period to begin on the date the Agency specifies the optimal values.

- 4) Reduced monitoring.
 - A) Reduction to annual for small- and medium-sized system suppliers meeting the lead and copper action levels. A small- or medium-sized system supplier that meets the lead and copper action levels during each of two consecutive six-month monitoring periods may reduce the number of samples in accordance with subsection (c) of this Section, and reduce the frequency of sampling to once per year.
 - B) SEP allowing reduction to annual for suppliers maintaining water quality control parameters.
 - i) Any supplier that maintains the range of values for the water quality control parameters reflecting optimal corrosion control treatment specified by the Agency under Section 611.352(f) during each of two consecutive six-month monitoring periods may reduce the frequency of monitoring to once per year and the number of lead and copper samples to that specified by subsection (c) of this Section if it receives written approval from the Agency in the form of a SEP granted pursuant to Section 611.110.
 - ii) The Agency must review monitoring, treatment, and other relevant information submitted by the water system in accordance with Section 611.360, and must notify the system in writing by a SEP granted pursuant to Sections 611.110 when it determines the system is eligible to reduce its monitoring frequency to once every three years pursuant to this subsection (d)(4).
 - iii) The Agency must review, and where appropriate, revise its determination under subsection (d)(4)(B)(i) of this Section when the supplier submits new monitoring or treatment data, or when other data relevant to the number and frequency of tap sampling becomes available to the Agency.
 - C) Reduction to triennial for small- and medium-sized system suppliers.

- i) Small- and medium-sized system suppliers meeting lead and copper action levels. A small- or medium-sized system supplier that meets the lead and copper action levels during three consecutive years of monitoring may reduce the frequency of monitoring for lead and copper from annually to once every three years.
 - ii) SEP for suppliers meeting optimal corrosion control treatment. Any supplier that maintains the range of values for the water quality control parameters reflecting optimal corrosion control treatment specified by the Agency under Section 611.352(f) during three consecutive years of monitoring may reduce its monitoring frequency from annual to once every three years if it receives written approval from the Agency in the form of a SEP granted pursuant to Section 611.110.
 - iii) The Agency must review, and where appropriate, revise its determination under subsection (d)(4)(C)(ii) of this Section when the supplier submits new monitoring or treatment data, or when other data relevant to the number and frequency of tap sampling becomes available to the Agency.
- D) Sampling at a reduced frequency. A supplier that reduces the number and frequency of sampling must collect these samples from representative sites included in the pool of targeted sampling sites identified in subsection (a) of this Section, preferentially selecting those sampling sites from the highest tier first. Suppliers sampling annually or less frequently must conduct the lead and copper tap sampling during the months of June, July, August, or September, unless the Agency has approved a different sampling period in accordance with subsection (d)(4)(D)(i) of this Section.
- i) The Agency may grant a SEP pursuant to Section 611.110 that approves a different period for conducting the lead and copper tap sampling for systems collecting a reduced number of samples. Such a period must be no longer than four consecutive months and must represent a time of normal operation where the highest levels of lead are most likely to occur. For a NTNCWS supplier that does not operate during the months of June through September and for which the period of normal operation where the highest levels of lead are most likely to occur is not known, the Agency must designate a period that represents a time of

normal operation for the system.

- ii) A supplier monitoring annually that has been collecting samples during the months of June through September and which receives Agency approval to alter its sample collection period under subsection (d)(4)(D)(i) of this Section must collect its next round of samples during a time period that ends no later than 21 months after the previous round of sampling. A supplier monitoring once every three years that has been collecting samples during the months of June through September and which receives Agency approval to alter the sampling collection period as provided in subsection (d)(4)(D)(i) of this Section must collect its next round of samples during a time period that ends no later than 45 months after the previous round of sampling. Subsequent rounds of sampling must be collected annually or once every three years, as required by this Section. A small system supplier with a waiver granted pursuant to subsection (g) of this Section that has been collecting samples during the months of June through September and which receives Agency approval to alter its sample collection period under subsection (d)(4)(D)(i) of this Section must collect its next round of samples before the end of the nine-year compliance cycle (as that term is defined in Section 611.101).
- E) Any water system that demonstrates for two consecutive six-month monitoring periods that the tap water lead level computed under Section 611.350(c)(3) is less than or equal to 0.005 mg/l and that the tap water copper level computed under Section 611.350(c)(3) is less than or equal to 0.65 mg/l may reduce the number of samples in accordance with subsection (c) of this Section and reduce the frequency of sampling to once every three calendar years.
- F) Resumption of standard monitoring.
- i) Small- or medium-sized suppliers exceeding lead or copper action level. A small- or medium-sized system supplier subject to reduced monitoring that exceeds the lead action level or the copper action level must resume sampling in accordance subsection (d)(3) of this Section and collect the number of samples specified for standard monitoring under subsection (c) of this Section. Such a supplier must also conduct water quality parameter monitoring in accordance with Section 611.357 (b), (c), or (d) (as appropriate) during

the six-month monitoring period in which it exceeded the action level. Any such supplier may resume annual monitoring for lead and copper at the tap at the reduced number of sites specified in subsection (c) of this Section after it has completed two subsequent consecutive six-month rounds of monitoring that meet the criteria of subsection (d)(4)(A) of this Section. Any such supplier may resume monitoring once every three years for lead and copper at the reduced number of sites after it demonstrates through subsequent rounds of monitoring that it meets the criteria of either subsection (d)(4)(C) or (d)(4)(E) of this Section.

- ii) Suppliers failing to operate within water quality control parameters. Any supplier subject to reduced monitoring frequency that fails to operate within the range of values for the water quality control parameters specified pursuant to Section 611.352(f) for more than nine days in any six-month period specified in Section 611.357(d) must conduct tap water sampling for lead and copper at the frequency specified in subsection (d)(3) of this Section, must collect the number of samples specified for standard monitoring under subsection (c) of this Section, and must resume monitoring for water quality parameters within the distribution system in accordance with Section 611.357(d).
- G) Any water supplier subject to a reduced monitoring frequency under subsection (d)(4) of this Section that either adds a new source of water or changes any water treatment must inform the Agency in writing in accordance with Section 611.360(a)(3). The Agency may, by a SEP granted pursuant to Section 611.110, require the system to resume sampling in accordance with subsection (d)(3) of this Section and collect the number of samples specified for standard monitoring under subsection (c) of this Section or take other appropriate steps such as increased water quality parameter monitoring or re-evaluation of its corrosion control treatment given the potentially different water quality considerations.
- H) A supplier required under subsection (d)(4)(F) of this Section to resume monitoring in accordance with Section 611.357(d) may resume reduced monitoring for lead and copper at the tap and for water quality parameters within the distribution system under the following conditions:
- i) The supplier may resume annual monitoring for lead and

copper at the tap at the reduced number of sites specified in subsection (c) of this Section after it has completed two subsequent six-month rounds of monitoring that meet the criteria of subsection (d)(4)(B) of this Section and the supplier has received written approval from the Agency by a SEP pursuant to Section 611.110 that it is appropriate to resume reduced monitoring on an annual frequency.

- ii) The supplier may resume monitoring for lead and copper once every three years at the tap at the reduced number of sites after it demonstrates through subsequent rounds of monitoring that it meets the criteria of either subsection (d)(4)(C) or (d)(4)(E) of this Section and the system has received a SEP under Section 611.110 from the Agency that it is appropriate to resume monitoring once every three years.
- iii) The supplier may reduce the number of water quality parameter tap water samples required in accordance with Section 611.357(e)(1) and the frequency with which it collects such samples in accordance with Section 611.357(e)(2). Such a system may not resume monitoring once every three years for water quality parameters at the tap until it demonstrates, in accordance with the requirements of Section 611.357(e)(2), that it has re-qualified for monitoring once every three years.

BOARD NOTE: Subsections (d)(4)(H)(i) through (d)(4)(H)(iii) are derived from 40 CFR 141.86(d)(4)(vi)(B)(I) through (d)(4)(vi)(B)(3)-(2002) (2003), since Illinois Administrative Code codification requirements allow only four indent levels of subsections.

- e) Additional monitoring. The results of any monitoring conducted in addition to the minimum requirements of this Section must be considered by the supplier and the Agency in making any determinations (i.e., calculating the 90th percentile lead action level or the copper level) under this Subpart G.
- f) Invalidation of lead or copper tap water samples. A sample invalidated under this subsection does not count toward determining lead or copper 90th percentile levels under Section 611.350(c)(3) or toward meeting the minimum monitoring requirements of subsection (c) of this Section.
 - 1) The Agency must invalidate a lead or copper tap water sample if it determines that one of the following conditions exists:

- A) The laboratory establishes that improper sample analysis caused erroneous results;
 - B) The sample was taken from a site that did not meet the site selection criteria of this Section;
 - C) The sample container was damaged in transit; or
 - D) There is substantial reason to believe that the sample was subject to tampering.
- 2) The supplier must report the results of all samples to the Agency and all supporting documentation for samples the supplier believes should be invalidated.
 - 3) To invalidate a sample under subsection (f)(1) of this Section, the decision and the rationale for the decision must be documented in writing. The Agency may not invalidate a sample solely on the grounds that a follow-up sample result is higher or lower than that of the original sample.
 - 4) The water supplier must collect replacement samples for any samples invalidated under this Section if, after the invalidation of one or more samples, the supplier has too few samples to meet the minimum requirements of subsection (c) of this Section. Any such replacement samples must be taken as soon as possible, but no later than 20 days after the date the Agency invalidates the sample or by the end of the applicable monitoring period, whichever occurs later. Replacement samples taken after the end of the applicable monitoring period must not also be used to meet the monitoring requirements of a subsequent monitoring period. The replacement samples must be taken at the same locations as the invalidated samples or, if that is not possible, at locations other than those already used for sampling during the monitoring period.
- g) Monitoring waivers for small system suppliers. Any small system supplier that meets the criteria of this subsection (g) may apply to the Agency to reduce the frequency of monitoring for lead and copper under this Section to once every nine years (i.e., a “full waiver”) if it meets all of the materials criteria specified in subsection (g)(1) of this Section and all of the monitoring criteria specified in subsection (g)(2) of this Section. Any small system supplier that meets the criteria in subsections (g)(1) and (g)(2) of this Section only for lead, or only for copper, may apply to the State for a waiver to reduce the frequency of tap water monitoring to once every nine years for that contaminant only (i.e., a “partial waiver”).
- 1) Materials criteria. The supplier must demonstrate that its distribution system and service lines and all drinking water supply plumbing,

including plumbing conveying drinking water within all residences and buildings connected to the system, are free of lead-containing materials or copper-containing materials, as those terms are defined in this subsection (g)(1), as follows:

- A) Lead. To qualify for a full waiver, or a waiver of the tap water monitoring requirements for lead (i.e., a “lead waiver”), the water supplier must provide certification and supporting documentation to the Agency that the system is free of all lead-containing materials, as follows:
- i) It contains no plastic pipes that contain lead plasticizers, or plastic service lines that contain lead plasticizers; and
 - ii) It is free of lead service lines, lead pipes, lead soldered pipe joints, and leaded brass or bronze alloy fittings and fixtures, unless such fittings and fixtures meet the specifications of NSF Standard 61, section 9, incorporated by reference in Section 611.102.

BOARD NOTE: Corresponding 40 CFR 141.86(g)(1)(i)(B) specifies “any standard established pursuant to 42 USC 300g-6(e) (SDWA section 1417(e)).” USEPA has stated that the NSF standard is that standard. See 62 Fed. Reg. 44684 (Aug. 22, 1997).

- B) Copper. To qualify for a full waiver, or a waiver of the tap water monitoring requirements for copper (i.e., a “copper waiver”), the water supplier must provide certification and supporting documentation to the Agency that the system contains no copper pipes or copper service lines.
- 2) Monitoring criteria for waiver issuance. The supplier must have completed at least one six-month round of standard tap water monitoring for lead and copper at sites approved by the Agency and from the number of sites required by subsection (c) of this Section and demonstrate that the 90th percentile levels for any and all rounds of monitoring conducted since the system became free of all lead-containing or copper-containing materials, as appropriate, meet the following criteria:
- A) Lead levels. To qualify for a full waiver, or a lead waiver, the supplier must demonstrate that the 90th percentile lead level does not exceed 0.005 mg/ℓ.
 - B) Copper levels. To qualify for a full waiver, or a copper waiver, the supplier must demonstrate that the 90th percentile copper level

does not exceed 0.65 mg/ℓ.

- 3) State approval of waiver application. The Agency must notify the supplier of its waiver determination by a SEP issued pursuant to Section 611.110, in writing, setting forth the basis of its decision and any condition of the waiver. As a condition of the waiver, the Agency may require the supplier to perform specific activities (e.g., limited monitoring, periodic outreach to customers to remind them to avoid installation of materials that might void the waiver) to avoid the risk of lead or copper concentration of concern in tap water. The small system supplier must continue monitoring for lead and copper at the tap as required by subsections (d)(1) through (d)(4) of this Section, as appropriate, until it receives written notification from the Agency that the waiver has been approved.
- 4) Monitoring frequency for suppliers with waivers.
 - A) A supplier with a full waiver must conduct tap water monitoring for lead and copper in accordance with subsection (d)(4)(D) of this Section at the reduced number of sampling sites identified in subsection (c) of this Section at least once every nine years and provide the materials certification specified in subsection (g)(1) of this Section for both lead and copper to the Agency along with the monitoring results.
 - B) A supplier with a partial waiver must conduct tap water monitoring for the waived contaminant in accordance with subsection (d)(4)(D) of this Section at the reduced number of sampling sites specified in subsection (c) of this Section at least once every nine years and provide the materials certification specified in subsection (g)(1) of this Section pertaining to the waived contaminant along with the monitoring results. Such a supplier also must continue to monitor for the non-waived contaminant in accordance with requirements of subsections (d)(1) through (d)(4) of this Section, as appropriate.
 - C) If a supplier with a full or partial waiver adds a new source of water or changes any water treatment, the supplier must notify the Agency in writing in accordance with Section 611.360(a)(3). The Agency has the authority to require the supplier to add or modify waiver conditions (e.g., require recertification that the supplier's system is free of lead-containing or copper-containing materials, require additional rounds of monitoring), if it deems such modifications are necessary to address treatment or source water changes at the system.
 - D) If a supplier with a full or partial waiver becomes aware that it is

no longer free of lead-containing or copper-containing materials, as appropriate (e.g., as a result of new construction or repairs), the supplier must notify the Agency in writing no later than 60 days after becoming aware of such a change.

- 5) Continued eligibility. If the supplier continues to satisfy the requirements of subsection (g)(4) of this Section, the waiver will be renewed automatically, unless any of the conditions listed in subsection (g)(5)(A) through (g)(5)(C) of this Section occur. A supplier whose waiver has been revoked may re-apply for a waiver at such time as it again meets the appropriate materials and monitoring criteria of subsections (g)(1) and (g)(2) of this Section.
 - A) A supplier with a full waiver or a lead waiver no longer satisfies the materials criteria of subsection (g)(1)(A) of this Section or has a 90th percentile lead level greater than 0.005 mg/ℓ.
 - B) A supplier with a full waiver or a copper waiver no longer satisfies the materials criteria of subsection (g)(1)(B) of this Section or has a 90th percentile copper level greater than 0.65 mg/ℓ.
 - C) The State notifies the supplier, in writing, that the waiver has been revoked, setting forth the basis of its decision.
- 6) Requirements following waiver revocation. A supplier whose full or partial waiver has been revoked by the Agency is subject to the corrosion control treatment and lead and copper tap water monitoring requirements, as follows:
 - A) If the supplier exceeds the lead or copper action level, the supplier must implement corrosion control treatment in accordance with the deadlines specified in Section 611.351(e), and any other applicable requirements of this Subpart G.
 - B) If the supplier meets both the lead and the copper action level, the supplier must monitor for lead and copper at the tap no less frequently than once every three years using the reduced number of sample sites specified in subsection (c) of this Section.
- 7) Pre-existing waivers. Small system supplier waivers approved by the Agency in writing prior to April 11, 2000 must remain in effect under the following conditions:
 - A) If the supplier has demonstrated that it is both free of lead-containing and copper-containing materials, as required by subsection (g)(1) of this Section and that its 90th percentile lead

levels and 90th percentile copper levels meet the criteria of subsection (g)(2) of this Section, the waiver remains in effect so long as the supplier continues to meet the waiver eligibility criteria of subsection (g)(5) of this Section. The first round of tap water monitoring conducted pursuant to subsection (g)(4) of this Section must be completed no later than nine years after the last time the supplier monitored for lead and copper at the tap.

- B) If the supplier has met the materials criteria of subsection (g)(1) of this Section but has not met the monitoring criteria of subsection (g)(2) of this Section, the supplier must conduct a round of monitoring for lead and copper at the tap demonstrating that it met the criteria of subsection (g)(2) of this Section no later than September 30, 2000. Thereafter, the waiver must remain in effect as long as the supplier meets the continued eligibility criteria of subsection (g)(5) of this Section. The first round of tap water monitoring conducted pursuant to subsection (g)(4) of this Section must be completed no later than nine years after the round of monitoring conducted pursuant to subsection (g)(2) of this Section.

BOARD NOTE: Derived from 40 CFR 141.86-~~(2002)~~ (2003).

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.358 Monitoring for Lead and Copper in Source Water

- a) Sample location, collection methods, and number of samples.
- 1) A supplier that fails to meet the lead action level or the copper action level on the basis of tap samples collected in accordance with Section 611.356 must collect lead and copper source water samples in accordance with the following requirements regarding sample location, number of samples, and collection methods:
- A) A groundwater supplier must take a minimum of one sample at every entry point to the distribution system that is representative of each well after treatment (hereafter called a sampling point). The supplier must take one sample at the same sampling point unless conditions make another sampling point more representative of each source or treatment plant.
- B) A surface water supplier must take a minimum of one sample at every entry point to the distribution system after any application of treatment or in the distribution system at a point that is representative of each source after treatment (hereafter called a sampling point). The system must take each sample at the same

sampling point unless conditions make another sampling point more representative of each source or treatment plant.

BOARD NOTE: For the purposes of this subsection (a)(1)(B), surface water systems include systems with a combination of surface and ground sources.

- C) If a supplier draws water from more than one source and the sources are combined before distribution, the supplier must sample at an entry point to the distribution system during periods of normal operating conditions (i.e., when water is representative of all sources being used).
 - D) The Agency may, by a SEP issued pursuant to Section 611.110, reduce the total number of samples that must be analyzed by allowing the use of compositing. Compositing of samples must be done by certified laboratory personnel. Composite samples from a maximum of five samples are allowed, provided that if the lead concentration in the composite sample is greater than or equal to 0.001 mg/ℓ or the copper concentration is greater than or equal to 0.160 mg/ℓ, then the supplier must do either of the following:
 - i) The supplier must take and analyze a follow-up sample within 14 days at each sampling point included in the composite; or
 - ii) If duplicates of or sufficient quantities from the original samples from each sampling point used in the composite are available, the supplier may use these instead of resampling.
- 2) SEP requiring an additional sample.
- A) When the Agency determines that the results of sampling indicate an exceedence of the lead or copper MPC established under Section 611.353(b)(4), it must, by a SEP issued pursuant to Section 611.110, require the supplier to collect one additional sample as soon as possible after the initial sample at the same sampling point, but no later than two weeks after the supplier took the initial sample.
 - B) If a supplier takes an Agency-required confirmation sample for lead or copper, the supplier must average the results obtained from the initial sample with the results obtained from the confirmation sample in determining compliance with the Agency-specified lead and copper MPCs.

- i) Any analytical result below the MDL must be considered as zero for the purposes of averaging.
 - ii) Any value above the MDL but below the PQL must either be considered as the measured value or be considered one-half the PQL.
- b) Monitoring frequency after system exceeds tap water action level. A supplier that exceeds the lead action level or the copper action level in tap sampling must collect one source water sample from each entry point to the distribution system within six months after the exceedence.
- c) Monitoring frequency after installation of source water treatment. A supplier that installs source water treatment pursuant to Section 611.353(a)(3) must collect an additional source water sample from each entry point to the distribution system during each of two consecutive six-month monitoring periods on or before ~~the~~ deadline 36 months after completion of step 2, as specified in Section 611.353(a)(4).
- d) Monitoring frequency after the Agency has specified the lead and copper MPCs or has determined that source water treatment is not needed.
 - 1) A supplier must monitor at the frequency specified by subsection (d)(1)(A) or (d)(1)(B) of this Section where the Agency has specified the MPCs pursuant to Section 611.353(b)(4) or has determined that the supplier is not required to install source water treatment pursuant to Section 611.353(b)(2).
 - A) GWS suppliers.
 - i) A GWS supplier required to sample by subsection (d)(1) of this Section must collect samples once during the three-year compliance period (as that term is defined in Section 611.101) during which the Agency makes its determination pursuant to Section 611.353(b)(4) or 611.353(b)(2).
 - ii) A GWS supplier required to sample by subsection (d)(1) of this Section must collect samples once during each subsequent compliance period.
 - B) A SWS or mixed system supplier must collect samples annually, the first annual monitoring period to begin on the date on which the Agency makes its determination pursuant to Section 611.353(b)(4) or 611.353(b)(2).

- 2) A supplier is not required to conduct source water sampling for lead or copper if the supplier meets the action level for the specific contaminant in all tap water samples collected during the entire source water sampling period applicable under subsection (d)(1)(A) or (d)(1)(B) of this Section.
- e) Reduced monitoring frequency.
- 1) A GWS supplier may reduce the monitoring frequency for lead and copper in source water to once during each nine-year compliance cycle (as that term is defined in Section 611.101) if the supplier meets one of the following criteria:
 - A) The supplier demonstrates that finished drinking water entering the distribution system has been maintained below the maximum permissible lead and copper concentrations specified by the State in Section 611.353(b)(4) during at least three consecutive compliance periods under subsection (d)(1) of this Section; or
 - B) The Agency has determined, by a SEP issued pursuant to Section 611.110, that source water treatment is not needed and the system demonstrates that, during at least three consecutive compliance periods in which sampling was conducted under subsection (d)(1) of this Section, the concentration of lead in source water was less than or equal to 0.005 mg/ℓ and the concentration of copper in source water was less than or equal to 0.65 mg/ℓ.
 - 2) A SWS or mixed system supplier may reduce the monitoring frequency in subsection (d)(1) of this Section to once during each nine-year compliance cycle (as that term is defined in Section 611.101) if the supplier meets one of the following criteria:
 - A) The supplier demonstrates that finished drinking water entering the distribution system has been maintained below the maximum permissible lead and copper concentrations specified by the Agency under Section 611.353(b)(4) for at least three consecutive years; or
 - B) The Agency has determined, by a SEP issued pursuant to Section 611.110, that source water treatment is not needed and the supplier demonstrates that, during at least three consecutive years, the concentration of lead in source water was less than or equal to 0.005 mg/ℓ and the concentration of copper in source water was less than or equal to 0.65 mg/ℓ.
 - 3) A supplier that uses a new source of water is not eligible for reduced monitoring for lead or copper until it demonstrates by samples collected

from the new source during three consecutive monitoring periods, of the appropriate duration provided by subsection (d)(1) of this Section, that lead or copper concentrations are below the MPC as specified by the Agency pursuant to Section 611.353(a)(4).

BOARD NOTE: Derived from 40 CFR 141.88-~~(2002)~~ (2003).

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.360 Reporting

A supplier must report all of the following information to the Agency in accordance with this Section.

- a) Reporting for tap, lead, and copper, and water quality parameter monitoring.
 - 1) Except as provided in subsection (a)(1)(viii) of this Section, a supplier must report the following information for all samples specified in Section 611.356 and for all water quality parameter samples specified in Section 611.357 within ten days of the end of each applicable sampling period specified in Sections 611.356 and 611.357 (i.e., every six months, annually, every three years, or every nine years).
 - A) The results of all tap samples for lead and copper, including the location of each site and the criteria under Section 611.356(a)(3) through (a)(7) under which the site was selected for the supplier's sampling pool;
 - B) Documentation for each tap water lead or copper sample for which the water supplier requests invalidation pursuant to Section 611.356(f)(2);
 - C) This subsection (a)(1)(C) corresponds with 40 CFR 141.90(a)(1)(iii), a provision that USEPA removed and marked "reserved." This statement preserves structural parity with the federal rules;
 - D) The 90th percentile lead and copper concentrations measured from among all lead and copper tap samples collected during each sampling period (calculated in accordance with Section 611.350(c)(3)), unless the Agency calculates the system's 90th percentile lead and copper levels under subsection (h) of this Section;
 - E) With the exception of initial tap sampling conducted pursuant to Section 611.356(d)(1), the supplier must designate any site that

was not sampled during previous sampling periods, and include an explanation of why sampling sites have changed;

- F) The results of all tap samples for pH, and where applicable, alkalinity, calcium, conductivity, temperature, and orthophosphate or silica collected pursuant to Section 611.357(b) through (e);
 - G) The results of all samples collected at entry points for applicable water quality parameters pursuant to Section 611.357(b) through (e).
 - H) A water supplier must report the results of all water quality parameter samples collected under Section 611.357(c) through (f) during each six-month monitoring period specified in Section 611.357(d) within the first 10 days following the end of the monitoring period, unless the Agency has specified, by a SEP granted pursuant to Section 611.110, a more frequent reporting requirement.
- 2) For a NTNCWS supplier, or a CWS supplier meeting the criteria of Sections 611.355(c)(7)(A) and (c)(7)(B), that does not have enough taps which can provide first-draw samples, the supplier must do either of the following:
- A) Provide written documentation to the Agency that identifies standing times and locations for enough non-first-draw samples to make up its sampling pool under Section 611.356(b)(5) by the start of the first applicable monitoring period under Section 611.356(d) that ~~commences~~commenced after April 11, 2000, unless the Agency has waived prior Agency approval of non-first-draw sample sites selected by the supplier pursuant to Section 611.356(b)(5); or
 - B) If the Agency has waived prior approval of non-first-draw sample sites selected by the supplier, identify, in writing, each site that did not meet the six-hour minimum standing time and the length of standing time for that particular substitute sample collected pursuant to Section 611.356(b)(5) and include this information with the lead and copper tap sample results required to be submitted pursuant to subsection (a)(1)(A) of this Section.
- 3) No later than 60 days after the addition of a new source or any change in water treatment, unless the Agency requires earlier notification, a water supplier deemed to have optimized corrosion control under Section 611.351(b)(3), a water supplier subject to reduced monitoring pursuant to Section 611.356(d)(4), or a water supplier subject to a monitoring waiver

pursuant to Section 611.356(g), must send written documentation to the Agency describing the change. In those instances where prior Agency approval of the treatment change or new source is not required, USEPA has stated that it encourages water systems to provide the notification to the Agency beforehand to minimize the risk the treatment change or new source will adversely affect optimal corrosion control.

- 4) Any small system supplier applying for a monitoring waiver under Section 611.356(g), or subject to a waiver granted pursuant to Section 611.356(g)(3), must provide the following information to the Agency in writing by the specified deadline:
 - A) By the start of the first applicable monitoring period in Section 611.356(d), any small water system supplier applying for a monitoring waiver must provide the documentation required to demonstrate that it meets the waiver criteria of Sections 611.356(g)(1) and (g)(2).
 - B) No later than nine years after the monitoring previously conducted pursuant to Section 611.356(g)(2) or Section 611.356(g)(4)(A), each small system supplier desiring to maintain its monitoring waiver must provide the information required by Sections 611.356(g)(4)(A) and (g)(4)(B).
 - C) No later than 60 days after it becomes aware that it is no longer free of lead-containing or copper-containing material, as appropriate, each small system supplier with a monitoring waiver must provide written notification to the Agency, setting forth the circumstances resulting in the lead-containing or copper-containing materials being introduced into the system and what corrective action, if any, the supplier plans to remove these materials.
 - D) By October 10, 2000, any small system supplier with a waiver granted prior to April 11, 2000 and that had not previously met the requirements of Section 611.356(g)(2) must have provided the information required by that subsection.
 - 5) Each GWS supplier that limits water quality parameter monitoring to a subset of entry points under Section 611.357(c)(3) must provide, by the commencement of such monitoring, written correspondence to the Agency that identifies the selected entry points and includes information sufficient to demonstrate that the sites are representative of water quality and treatment conditions throughout the system.
- b) Reporting for source water monitoring.

- 1) A supplier must report the sampling results for all source water samples collected in accordance with Section 611.358 within ten days of the end of each source water sampling period (i.e., annually, per compliance period, per compliance cycle) specified in Section 611.358.
 - 2) With the exception of the first round of source water sampling conducted pursuant to Section 611.358(b), a supplier must specify any site that was not sampled during previous sampling periods, and include an explanation of why the sampling point has changed.
- c) Reporting for corrosion control treatment. By the applicable dates under Section 611.351, a supplier must report the following information:
- 1) For a supplier demonstrating that it has already optimized corrosion control, the information required by Section 611.352(b)(2) or (b)(3).
 - 2) For a supplier required to optimize corrosion control, its recommendation regarding optimal corrosion control treatment pursuant to Section 611.352(a).
 - 3) For a supplier required to evaluate the effectiveness of corrosion control treatments pursuant to Section 611.352(c), the information required by Section 611.352(c).
 - 4) For a supplier required to install optimal corrosion control approved by the Agency pursuant to Section 611.352(d), a copy of the Agency permit letter, which acts as certification that the supplier has completed installing the permitted treatment.
- d) Reporting for source water treatment. On or before the applicable dates in Section 611.353, a supplier must provide the following information to the Agency:
- 1) If required by Section 611.353(b)(1), its recommendation regarding source water treatment; or
 - 2) For suppliers required to install source water treatment pursuant to Section 611.353(b)(2), a copy of the Agency permit letter, which acts as certification that the supplier has completed installing the treatment approved by the Agency within 24 months after the Agency approved the treatment.
- e) Reporting for lead service line replacement. A supplier must report the following information to the Agency to demonstrate compliance with the requirements of Section 611.354:

- 1) Within 12 months after a supplier exceeds the lead action level in sampling referred to in Section 611.354(a), the supplier must report each of the following to the Agency in writing:
 - A) A demonstration that it has conducted a materials evaluation, including the evaluation required by Section 611.356(a);
 - B) Identify the initial number of lead service lines in its distribution system; and
 - C) Provide the Agency with the supplier's schedule for annually replacing at least seven percent of the initial number of lead service lines in its distribution system.

- 2) Within 12 months after a supplier exceeds the lead action level in sampling referred to in Section 611.354(a), and every 12 months thereafter, the supplier must demonstrate to the Agency in writing that the supplier has done either of the following:
 - A) Replaced in the previous 12 months at least seven percent of the initial number of lead service lines in its distribution system (or any greater number of lines specified by the Agency pursuant to Section 611.354(e)); or
 - B) Conducted sampling that demonstrates that the lead concentration in all service line samples from individual lines, taken pursuant to Section 611.356(b)(3), is less than or equal to 0.015 mg/ℓ.
 - C) Where the supplier makes a demonstration under subsection (e)(2)(B) of this Section, the total number of lines that the supplier has replaced, combined with the total number that meet the criteria of Section 611.354(b), must equal at least seven percent of the initial number of lead lines identified pursuant to subsection (a) of this Section (or the percentage specified by the Agency pursuant to Section 611.354(e)).

- 3) The annual letter submitted to the Agency pursuant to subsection (e)(2) of this Section must contain the following information:
 - A) The number of lead service lines originally scheduled to be replaced during the previous year of the supplier's replacement schedule;
 - B) The number and location of each lead service line actually replaced during the previous year of the supplier's replacement

schedule; and

- C) If measured, the water lead concentration from each lead service line sampled pursuant to Section 611.356(b)(3) and the location of each lead service line sampled, the sampling method used, and the date of sampling.
- 4) Any supplier that collects lead service line samples following partial lead service line replacement required by Section 611.354 must report the results to the Agency within the first ten days of the month following the month in which the supplier receives the laboratory results, or as specified by the Agency. The Agency may, by a SEP granted pursuant to Section 611.110, eliminate this requirement to report these monitoring results. A supplier must also report any additional information as specified by the Agency, and in a time and manner prescribed by the Agency, to verify that all partial lead service line replacement activities have taken place.
- f) Reporting for public education program.
- 1) Any water supplier that is subject to the public education requirements in Section 611.355 must, within ten days after the end of each period in which the supplier is required to perform public education tasks in accordance with Section 611.355(c), send written documentation to the Agency that contains the following:
 - A) A demonstration that the supplier has delivered the public education materials that meet the content requirements in Sections 611.355(a) and (b) and the delivery requirements in Section 611.355(c); and
 - B) A list of all the newspapers, radio stations, television stations, and facilities and organizations to which the supplier delivered public education materials during the period in which the supplier was required to perform public education tasks.
 - 2) Unless required by the Agency, by a SEP issued pursuant to Section 611.110, a supplier that previously has submitted the information required by subsection (f)(1)(B) of this Section need not resubmit the information required by subsection (f)(1)(B) of this Section, as long as there have been no changes in the distribution list and the supplier certifies that the public education materials were distributed to the same list submitted previously.
- g) Reporting of additional monitoring data. Any supplier that collects sampling data in addition to that required by this Subpart G must report the results of that sampling to the Agency within the first ten days following the end of the applicable sampling periods specified by Sections 611.356 through 611.358

during which the samples are collected.

- h) Reporting of 90th percentile lead and copper concentrations where the Agency calculates a system's 90th percentile concentrations. A water supplier is not required to report the 90th percentile lead and copper concentrations measured from among all lead and copper tap water samples collected during each monitoring period, as required by subsection (a)(1)(D) of this Section if the following is true:
- 1) The Agency has previously notified the water supplier that it will calculate the water system's 90th percentile lead and copper concentrations, based on the lead and copper tap results submitted pursuant to subsection (h)(2)(A) of this Section, and has specified a date before the end of the applicable monitoring period by which the supplier must provide the results of lead and copper tap water samples;
 - 2) The supplier has provided the following information to the Agency by the date specified in subsection (h)(1) of this Section:
 - A) The results of all tap samples for lead and copper including the location of each site and the criteria under Section 611.356(a)(3), (a)(4), (a)(5), (a)(6), or (a)(7) under which the site was selected for the system's sampling pool, pursuant to subsection (a)(1)(A) of this Section; and
 - B) An identification of sampling sites utilized during the current monitoring period that were not sampled during previous monitoring periods, and an explanation why sampling sites have changed; and
 - 3) The Agency has provided the results of the 90th percentile lead and copper calculations, in writing, to the water supplier before the end of the monitoring period.

BOARD NOTE: Derived from 40 CFR 141.90-(2002)-(2003).

(Source: Amended at 28 Ill. Reg. _____, effective _____)

SUBPART N: INORGANIC MONITORING AND ANALYTICAL REQUIREMENTS

Section 611.600 Applicability

The following types of suppliers must conduct monitoring to determine compliance with the old MCLs in Section 611.300 and the revised MCLs in 611.301, as appropriate, in accordance with this Subpart N:

- a) CWS suppliers.
- b) NTNCWS suppliers.
- c) Transient non-CWS suppliers to determine compliance with the nitrate and nitrite MCLs.
- d) Detection limits. The following are detection limits for purposes of this Subpart N (MCLs from Section 611.301 are set forth for information purposes only):

Contaminant	MCL (mg/ℓ, except asbestos)	Method	Detection Limit (mg/ℓ)
Antimony	0.006	Atomic absorption-furnace technique	0.003
		Atomic absorption-furnace technique (stabilized temperature)	0.0008 ⁵
		Inductively-coupled plasma-mass spectrometry	0.0004
		Atomic absorption-gaseous hydride technique	0.001
Arsenic	0.01 0.010 ⁶	Atomic absorption-furnace technique	0.001
		Atomic absorption-furnace technique (stabilized temperature)	0.00005 ⁷
		Atomic absorption-gaseous hydride technique	0.001
		Inductively-coupled plasma-mass spectrometry	0.0014 ⁸
Asbestos	7 MFL ¹	Transmission electron microscopy	0.01 MFL
Barium	2	Atomic absorption-furnace technique	0.002
		Atomic absorption-direct aspiration technique	0.1
		Inductively-coupled plasma arc furnace	0.002
		Inductively-coupled plasma	0.001
Beryllium	0.004	Atomic absorption-furnace	0.0002

		technique	
		Atomic absorption-furnace technique (stabilized temperature)	0.00002 ⁵
		Inductively-coupled plasma ²	0.0003
		Inductively-coupled plasma-mass spectrometry	0.0003
Cadmium	0.005	Atomic absorption-furnace technique	0.0001
		Inductively-coupled plasma	0.001
Chromium	0.1	Atomic absorption-furnace technique	0.001
		Inductively-coupled plasma	0.007
		Inductively-coupled plasma	0.001
Cyanide	0.2	Distillation, spectrophotometric ³	0.02
		Automated distillation, spectrophotometric ³	0.005
		Distillation, selective electrode ³	0.05
		Distillation, amenable, spectrophotometric ⁴	0.02
		UV, distillation, spectrophotometric	0.0005
		Distillation, spectrophotometric	0.0006
Mercury	0.002	Manual cold vapor technique	0.0002
		Automated cold vapor technique	0.0002
Nickel	No MCL	Atomic absorption-furnace technique	0.001
		Atomic absorption-furnace technique (stabilized temperature)	0.0006 ⁵
		Inductively-coupled plasma ²	0.005
		Inductively-coupled plasma-mass spectrometry	0.0005

Nitrate (as N)	10	Manual cadmium reduction	0.01
		Automated hydrazine reduction	0.01
		Automated cadmium reduction	0.05
		Ion-selective electrode	1
		Ion chromatography	0.01
Nitrite (as N)	1	Spectrophotometric	0.01
		Automated cadmium reduction	0.05
		Manual cadmium reduction	0.01
		Ion chromatography	0.004
Selenium	0.05	Atomic absorption-furnace technique	0.002
		Atomic absorption-gaseous hydride technique	0.002
Thallium	0.002	Atomic absorption-furnace technique	0.001
		Atomic absorption-furnace technique (stabilized temperature)	0.0007 ⁵
		Inductively-coupled plasma-mass spectrometry	0.0003

Footnotes.

- 1 “MFL” means millions of fibers per liter less than 10 μm .
- 2 Using a 2 \times preconcentration step as noted in Method 200.7. Lower MDLs may be achieved when using a 4 \times preconcentration.
- 3 Screening method for total cyanides.
- 4 Measures “free” cyanides.
- 5 Lower MDLs are reported using stabilized temperature graphite furnace atomic absorbtion.
- 6 The value for arsenic is effective January 23, 2006. Until then, the MCL is 0.05 mg/ ℓ .
- 7 The MDL reported for USEPA Method 200.9 (atomic absorption-platform furnace (stabilized temperature)) was determined using a 2 \times concentration step during sample digestion. The MDL determined for samples analyzed using direct analyses (i.e., no sample digestion) will be higher. Using multiple depositions, USEPA Method 200.9 is capable of obtaining an MDL of 0.0001 mg/ ℓ .
- 8 Using selective ion monitoring, USEPA Method 200.8 (ICP-MS) is capable of obtaining an MDL of 0.0001 mg/ ℓ .

BOARD NOTE: Subsections (a) through (c) of this Section are derived from 40 CFR 141.23 preamble-~~(2002)~~ (2003), and subsection (d) of this Section is derived from 40 CFR 141.23(a)(4)(i)-~~(2002)~~ (2003). See the Board Note at Section 611.301(b) relating to the MCL for nickel.

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.601 Monitoring Frequency

Monitoring must be conducted as follows:

- a) Required sampling.
 - 1) Each supplier must take a minimum of one sample at each sampling point at the times required by Section 611.610 beginning in the initial compliance period.
 - 2) Each sampling point must produce samples that are representative of the water from each source after treatment or from each treatment plant, as required by subsection (b) of this Section. The total number of sampling points must be representative of the water delivered to users throughout the PWS.
 - 3) The supplier must take each sample at the same sampling point unless conditions make another sampling point more representative of each source or treatment plant and the Agency has granted a SEP pursuant to subsection (b)(5) of this Section.
- b) Sampling points.
 - 1) Sampling points for GWSs. Unless otherwise provided by SEP, a GWS supplier must take at least one sample from each of the following points: each entry point that is representative of each well after treatment.
 - 2) Sampling points for an SWS or a mixed system supplier. Unless otherwise provided by SEP, an SWS or mixed system supplier must take at least one sample from each of the following points:
 - A) Each entry point after the application of treatment; or
 - B) A point in the distribution system that is representative of each source after treatment.
 - 3) If a supplier draws water from more than one source, and the sources are combined before distribution, the supplier must sample at an entry point during periods of normal operating conditions when water is

representative of all sources being used.

- 4) Additional sampling points. The Agency must, by SEP, designate additional sampling points in the distribution system or at the consumer's tap if it determines that such samples are necessary to more accurately determine consumer exposure.
 - 5) Alternative sampling points. The Agency must, by SEP, approve alternate sampling points if the supplier demonstrates that the points are more representative than the generally required point.
- c) This subsection corresponds with 40 CFR 141.23(a)(4), an optional provision relating to compositing of samples that USEPA does not require for state programs. This statement maintains structural consistency with USEPA rules.
 - d) The frequency of monitoring for the following contaminants must be in accordance with the following Sections:
 - 1) Asbestos: Section 611.602;
 - 2) Antimony, arsenic (~~effective February 22, 2002~~), barium, beryllium, cadmium, chromium, cyanide, fluoride, mercury, nickel, selenium, and thallium: Section 611.603;
 - 3) Nitrate: Section 611.604; and
 - 4) Nitrite: Section 611.605.

BOARD NOTE: Derived from 40 CFR 141.23(a) and (c) ~~(2002)~~ (2003).

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.611 Inorganic Analysis

Analytical methods are from documents incorporated by reference in Section 611.102. These are mostly referenced by a short name defined by Section 611.102(a). Other abbreviations are defined in Section 611.101.

- a) Analysis for the following contaminants must be conducted using the following methods or an alternative approved pursuant to Section 611.480. Criteria for analyzing arsenic, chromium, copper, lead, nickel, selenium, sodium, and thallium with digestion or directly without digestion, and other analytical procedures, are contained in USEPA Technical Notes, incorporated by reference in Section 611.102. (This document also contains approved analytical test methods that remained available for compliance monitoring until July 1, 1996. These methods are not available for use after July 1, 1996.)

BOARD NOTE: Because MDLs reported in USEPA Environmental Metals Methods 200.7 and 200.9 were determined using a 2× preconcentration step during sample digestion, MDLs determined when samples are analyzed by direct analysis (i.e., no sample digestion) will be higher. For direct analysis of cadmium and arsenic by USEPA Environmental Metals Method 200.7, and arsenic by Standard Method 3120 B sample preconcentration using pneumatic nebulization may be required to achieve lower detection limits. Preconcentration may also be required for direct analysis of antimony, lead, and thallium by USEPA Environmental Metals Method 200.9; antimony and lead by Standard Method 3113 B; and lead by ASTM Method D3559-90D unless multiple in-furnace depositions are made.

- 1) Alkalinity.
 - A) Titrimetric.
 - i) ASTM Method D1067-92 B; or
 - ii) Standard Methods, 18th, 19th, or 20th ed.: Method 2320 B.
 - B) Electrometric titration: USGS Methods: Method I-1030-85.
- 2) Antimony.
 - A) Inductively-coupled plasma-mass spectrometry: USEPA Environmental Metals Methods: Method 200.8.
 - B) Atomic absorption, hydride technique: ASTM Method D3697-92.
 - C) Atomic absorption, platform furnace technique: USEPA Environmental Metals Methods: Method 200.9.
 - D) Atomic absorption, furnace technique: Standard Methods, 18th or 19th ed.: Method 3113 B.
- 3) Arsenic.

BOARD NOTE: If ultrasonic nebulization is used in the determination of arsenic by Methods 200.7, 200.8, or SM 3120 B, the arsenic must be in the pentavalent state to provide uniform signal response. For methods 200.7 and 3120 B, both samples and standards must be diluted in the same mixed acid matrix concentration of nitric and hydrochloric acid with the addition of 100 µℓ of 30% hydrogen peroxide per 100 ml of solution. For direct analysis of arsenic with method 200.8 using ultrasonic nebulization, samples and standards must contain one mg/ℓ of sodium hypochlorite.

A) Inductively-coupled plasma.

BOARD NOTE: Effective January 23, 2006, a supplier may no longer employ analytical methods using the ICP-AES technology because the detection limits for these methods are 0.008 mg/ℓ or higher. This restriction means that the two ICP-AES methods (USEPA Environmental Metals Method 200.7 and Standard Methods, Method 3120 B) approved for use for the MCL of 0.05 mg/ℓ may not be used for compliance determinations for the revised MCL of ~~0.01~~0.010 mg/ℓ. However, prior to the 2005 through 2007 compliance period, a supplier may have compliance samples analyzed with these less sensitive methods.

- i) USEPA Environmental Metals Methods: Method 200.7; or
- ii) Standard Methods, 18th, 19th, or 20th ed.: Method 3120 B.

B) Inductively-coupled plasma-mass spectrometry: USEPA Environmental Metals Methods: Method 200.8.

C) Atomic absorption, platform furnace technique: USEPA Environmental Metals Methods: Method 200.9.

D) Atomic absorption, furnace technique.

- i) ASTM Method D2972-97 C; or
- ii) Standard Methods, 18th or 19th ed.: Method 3113 B.

E) Atomic absorption, hydride technique.

- i) ASTM Method D2972-97 B; or
- ii) Standard Methods, 18th or 19th ed.: Method 3114 B.

4) Asbestos: Transmission electron microscopy: USEPA Asbestos Methods-100.1 and USEPA Asbestos Methods-100.2.

5) Barium.

A) Inductively-coupled plasma.

- i) USEPA Environmental Metals Methods: Method 200.7; or
- ii) Standard Methods, 18th, 19th, or 20th ed.: Method 3120 B.

- B) Inductively-coupled plasma-mass spectrometry: USEPA Environmental Metals Methods: Method 200.8.
 - C) Atomic absorption, direct aspiration technique: Standard Methods, 18th or 19th ed.: Method 3111 D.
 - D) Atomic absorption, furnace technique: Standard Methods, 18th, 19th ed.: Method 3113 B.
- 6) Beryllium.
- A) Inductively-coupled plasma.
 - i) USEPA Environmental Metals Methods: Method 200.7; or
 - ii) Standard Methods, 18th, 19th, or 20th ed.: Method 3120 B.
 - B) Inductively-coupled plasma-mass spectrometry: USEPA Environmental Metals Methods: Method 200.8.
 - C) Atomic absorption, platform furnace technique: USEPA Environmental Metals Methods: Method 200.9.
 - D) Atomic absorption, furnace technique.
 - i) ASTM Method D3645-97 B; or
 - ii) Standard Methods, 18th or 19th ed.: Method 3113 B.
- 7) Cadmium.
- A) Inductively-coupled plasma arc furnace: USEPA Environmental Metals Methods: Method 200.7.
 - B) Inductively-coupled plasma-mass spectrometry: USEPA Environmental Metals Methods: Method 200.8.
 - C) Atomic absorption, platform furnace technique: USEPA Environmental Metals Methods: Method 200.9.
 - D) Atomic absorption, furnace technique: Standard Methods, 18th or 19th ed.: Method 3113 B.
- 8) Calcium.

- A) EDTA titrimetric.
 - i) ASTM Method D511-93 A; or
 - ii) Standard Methods, 18th, 19th, or 20th ed.: Method 3500-Ca D.
 - B) Atomic absorption, direct aspiration.
 - i) ASTM Method D511-93 B; or
 - ii) Standard Methods, 18th or 19th ed.: Method 3111 B.
 - C) Inductively-coupled plasma.
 - i) USEPA Environmental Metals Methods: Method 200.7; or
 - ii) Standard Methods, 18th, 19th, or 20th ed.: Method 3120 B.
- 9) Chromium.
- A) Inductively-coupled plasma.
 - i) USEPA Environmental Metals Methods: Method 200.7; or
 - ii) Standard Methods, 18th, 19th, or 20th ed.: Method 3120 B.
 - B) Inductively-coupled plasma-mass spectrometry: USEPA Environmental Metals Methods: Method 200.8.
 - C) Atomic absorption, platform furnace technique: USEPA Environmental Metals Methods: Method 200.9.
 - D) Atomic absorption, furnace technique: Standard Methods, 18th or 19th ed.: Method 3113 B.
- 10) Copper.
- A) Atomic absorption, furnace technique.
 - i) ASTM Method D1688-95 C; or
 - ii) Standard Methods, 18th or 19th ed.: Method 3113 B.
 - B) Atomic absorption, direct aspiration.

- i) ASTM Method D1688-95 A; or
 - ii) Standard Methods, 18th or 19th ed.: Method 3111 B.
 - C) Inductively-coupled plasma.
 - i) USEPA Environmental Metals Methods: Method 200.7; or
 - ii) Standard Methods, 18th, 19th, or 20th ed.: Method 3120 B.
 - D) Inductively-coupled plasma-mass spectrometry: USEPA Environmental Metals Methods: Method 200.8.
 - E) Atomic absorption, platform furnace technique: USEPA Environmental Metals Methods: Method 200.9.
- 11) Conductivity; Conductance.
- A) ASTM Method D1125-95 A; or
 - B) Standard Methods, 18th, 19th, or 20th ed.: Method 2510 B.
- 12) Cyanide.
- A) Manual distillation (ASTM Method D2036-98 A or Standard Methods, 18th, 19th, or 20th ed.: Method 4500-CN C), followed by spectrophotometric, amenable.
 - i) ASTM Method D2036-98 B; or
 - ii) Standard Methods, 18th, 19th, or 20th ed.: Method 4500-CN G.
 - B) Manual distillation (ASTM Method D2036-98 A or Standard Methods, 18th, 19th, or 20th ed.: Method 4500-CN C), followed by spectrophotometric, manual.
 - i) ASTM Method D2036-98 A;
 - ii) Standard Methods, 18th, 19th, or 20th ed.: Method 4500-CN E; or
 - iii) USGS Methods: Method I-3300-85.
 - C) Manual distillation (ASTM Method D2036-98 A or Standard Methods, 18th, 19th, or 20th ed.: Method 4500-CN C), followed

by semiautomated spectrophotometric: USEPA Environmental Inorganic Methods: Method 335.4.

- D) Selective electrode: Standard Methods, 18th, 19th, or 20th ed.: Method 4500-CN F.
- E) UV/Distillation/Spectrophotometric: ~~Kaleda~~ Kelada 01.
- F) Distillation/Spectrophotometric: QuickChem 10-204-00-1-X.

13) Fluoride.

- A) Ion Chromatography.
 - i) USEPA Environmental Inorganic Methods: Method 300.0,
 - ii) ASTM Method D4327-97; or
 - iii) Standard Methods, 18th, 19th, or 20th ed.: Method 4110 B.
- B) Manual distillation, colorimetric SPADNS: Standard Methods, 18th, 19th, or 20th ed.: Method 4500-F⁻ B and D.
- C) Manual electrode.
 - i) ASTM Method D1179-93 B; or
 - ii) Standard Methods, 18th, 19th, or 20th ed.: Method 4500-F⁻ C.
- D) Automated electrode: Technicon Methods: Method 380-75WE.
- E) Automated alizarin.
 - i) Standard Methods, 18th, 19th, or 20th ed.: Method 4500-F⁻ E; or
 - ii) Technicon Methods: Method 129-71W.

14) Lead.

- A) Atomic absorption, furnace technique.
 - i) ASTM Method D3559-96 D; or
 - ii) Standard Methods, 18th or 19th ed.: Method 3113 B.

- B) Inductively-coupled plasma-mass spectrometry: USEPA Environmental Metals Methods: Method 200.8.
 - C) Atomic absorption, platform furnace technique: USEPA Environmental Metals Methods: Method 200.9.
 - D) Differential Pulse Anodic Stripping Voltammetry: Palintest Method 1001.
- 15) Magnesium.
- A) Atomic absorption.
 - i) ASTM Method D511-93 B; or
 - ii) Standard Methods, 18th or 19th ed.: Method 3111 B.
 - B) Inductively-coupled plasma.
 - i) USEPA Environmental Metals Methods: Method 200.7; or
 - ii) Standard Methods, 18th, 19th, or 20th ed.: Method 3120 B.
 - C) Complexation titrimetric.
 - i) ASTM Method D511-93 A; or
 - ii) Standard Methods, 18th or 19th ed.: Method 3500-Mg E.
 - iii) Standard Methods, 20th ed.: Method 3500-Mg B.
- 16) Mercury.
- A) Manual cold vapor technique.
 - i) USEPA Environmental Metals Methods: Method 245.1;
 - ii) ASTM Method D3223-97; or
 - iii) Standard Methods, 18th or 19th ed.: Method 3112 B.
 - B) Automated cold vapor technique: USEPA Inorganic Methods: Method 245.2.
 - C) Inductively-coupled plasma-mass spectrometry: USEPA

Environmental Metals Methods: Method 200.8.

- 17) Nickel.
- A) Inductively-coupled plasma.
 - i) USEPA Environmental Metals Methods: Method 200.7; or
 - ii) Standard Methods, 18th, 19th, or 20th ed.: Method 3120 B.
 - B) Inductively-coupled plasma-mass spectrometry: USEPA Environmental Metals Methods: Method 200.8.
 - C) Atomic absorption, platform furnace technique: USEPA Environmental Metals Methods: Method 200.9.
 - D) Atomic absorption, direct aspiration technique: Standard Methods, 18th or 19th ed.: Method 3111 B.
 - E) Atomic absorption, furnace technique: Standard Methods, 18th or 19th ed.: Method 3113 B.
- 18) Nitrate.
- A) Ion chromatography.
 - i) USEPA Environmental Inorganic Methods: Method 300.0;
 - ii) ASTM Method D4327-97;
 - iii) Standard Methods, 18th, 19th, or 20th ed.: Method 4110 B; or
 - iv) Waters Test Method B-1011, available from Millipore Corporation.
 - B) Automated cadmium reduction.
 - i) USEPA Environmental Inorganic Methods: Method 353.2;
 - ii) ASTM Method D3867-90 A; or
 - iii) Standard Methods, 18th, 19th, or 20th ed.: Method 4500-NO₃⁻ F.
 - C) Ion selective electrode.

- i) Standard Methods, 18th, 19th, or 20th ed.: Method 4500-NO₃⁻ D; or
 - ii) Technical Bulletin 601.
 - D) Manual cadmium reduction.
 - i) ASTM Method D3867-90 B; or
 - ii) Standard Methods, 18th, 19th, or 20th ed.: Method 4500-NO₃⁻ E.
- 19) Nitrite.
 - A) Ion chromatography.
 - i) USEPA Environmental Inorganic Methods: Method 300.0;
 - ii) ASTM Method D4327-97;
 - iii) Standard Methods, 18th, 19th, or 20th ed.: Method 4110 B; or
 - iv) Waters Test Method B-1011, available from Millipore Corporation.
 - B) Automated cadmium reduction.
 - i) USEPA Environmental Inorganic Methods: Method 353.2;
 - ii) ASTM Method D3867-90 A; or
 - iii) Standard Methods, 18th, 19th, or 20th ed.: Method 4500-NO₃⁻ F.
 - C) Manual cadmium reduction.
 - i) ASTM Method D3867-90 B; or
 - ii) Standard Methods, 18th, 19th, or 20th ed.: Method 4500-NO₃⁻ E.
 - D) Spectrophotometric: Standard Methods, 18th, 19th, or 20th ed.: Method 4500-NO₂⁻ B.

- 20) Orthophosphate (unfiltered, without digestion or hydrolysis).
- A) Automated colorimetric, ascorbic acid.
 - i) USEPA Environmental Inorganic Methods: Method 365.1; or
 - ii) Standard Methods, 18th, 19th, or 20th ed.: Method 4500-P F.
 - B) Single reagent colorimetric, ascorbic acid.
 - i) ASTM Method D515-88 A; or
 - ii) Standard Methods, 18th, 19th, or 20th ed.: Method 4500-P E.
 - C) Colorimetric, phosphomolybdate: USGS Methods: Method I-1601-85.
 - D) Colorimetric, phosphomolybdate, automated-segmented flow: USGS Methods: Method I-2601-90.
 - E) Colorimetric, phosphomolybdate, automated discrete: USGS Methods: Method I-2598-85.
 - F) Ion Chromatography.
 - i) USEPA Environmental Inorganic Methods: Method 300.0;
 - ii) ASTM Method D4327-97; or
 - iii) Standard Methods, 18th, 19th, or 20th ed.: Method 4110 B.
- 21) pH.
- A) Electrometric.
 - i) USEPA Inorganic Methods: Method 150.1;
 - ii) ASTM Method D1293-95; or
 - iii) Standard Methods, 18th, 19th, or 20th ed.: Method 4500-H+ B.
 - B) USEPA Inorganic Methods: Method 150.2.

- 22) Selenium.
- A) Atomic absorption, hydride.
 - i) ASTM Method D3859-98 A; or
 - ii) Standard Methods, 18th or 19th ed.: Method 3114 B.
 - B) Inductively-coupled plasma-mass spectrometry: USEPA Environmental Metals Methods: Method 200.8.
 - C) Atomic absorption, platform furnace technique: USEPA Environmental Metals Methods: Method 200.9.
 - D) Atomic absorption, furnace technique.
 - i) ASTM Method D3859-98 B; or
 - ii) Standard Methods, 18th or 19th ed.: Method 3113 B.
- 23) Silica.
- A) Colorimetric, molybdate blue: USGS Methods: Method I-1700-85.
 - B) Colorimetric, molybdate blue, automated-segmented flow: USGS Methods: Method I-2700-85.
 - C) Colorimetric: ASTM Method D859-95.
 - D) Molybdosilicate: Standard Methods, 18th or 19th ed.: Method 4500-Si D or Standard Methods, 20th ed.: Method 4500-Si C.
 - E) Heteropoly blue: Standard Methods, 18th or 19th ed.: Method 4500-Si E or Standard Methods, 20th ed.: Method 4500-Si D.
 - F) Automated method for molybdate-reactive silica: Standard Methods, 18th or 19th ed.: Method 4500-Si F or Standard Methods, 20th ed.: Method 4500-Si E.
 - G) Inductively-coupled plasma.
 - i) USEPA Environmental Metals Methods: Method 200.7; or
 - ii) Standard Methods, 18th, 19th, or 20th ed.: Method 3120 B.

- 24) Sodium.
 - A) Inductively-coupled plasma: USEPA Environmental Metals Methods: Method 200.7.
 - B) Atomic absorption, direct aspiration: Standard Methods, 18th or 19th ed.: Method 3111 B.
- 25) Temperature; thermometric: Standard Methods, 18th, 19th, or 20th ed.: Method 2550.
- 26) Thallium.
 - A) Inductively-coupled plasma-mass spectrometry: USEPA Environmental Metals Methods: Method 200.8.
 - B) Atomic absorption, platform furnace technique: USEPA Environmental Metals Methods: Method 200.9.

- b) Sample collection for antimony, arsenic (effective January 22, 2004), asbestos, barium, beryllium, cadmium, chromium, cyanide, fluoride, mercury, nickel, nitrate, nitrite, selenium, and thallium pursuant to Sections 611.600 through 611.604 must be conducted using the following sample preservation, container, and maximum holding time procedures:

BOARD NOTE: For cyanide determinations samples must be adjusted with sodium hydroxide to pH 12 at the time of collection. When chilling is indicated the sample must be shipped and stored at 4° C or less. Acidification of nitrate or metals samples may be with a concentrated acid or a dilute (50% by volume) solution of the applicable concentrated acid. Acidification of samples for metals analysis is encouraged and allowed at the laboratory rather than at the time of sampling provided the shipping time and other instructions in Section 8.3 of USEPA Environmental Metals Method 200.7, 200.8, or 200.9 ~~is~~are followed.

- 1) Antimony.
 - A) Preservative: Concentrated nitric acid to pH less than 2.
 - B) Plastic or glass (hard or soft).
 - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within ~~6~~six months.
- 2) Arsenic.

- A) Preservative: Concentrated nitric acid to pH less than 2.
 - B) Plastic or glass (hard or soft).
 - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within ~~6~~six months.
- 3) Asbestos.
- A) Preservative: Cool to 4° C.
 - B) Plastic or glass (hard or soft).
 - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within 48 hours.
- 4) Barium.
- A) Preservative: Concentrated nitric acid to pH less than 2.
 - B) Plastic or glass (hard or soft).
 - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within ~~6~~six months.
- 5) Beryllium.
- A) Preservative: Concentrated nitric acid to pH less than 2.
 - B) Plastic or glass (hard or soft).
 - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within six months.
- 6) Cadmium.
- A) Preservative: Concentrated nitric acid to pH less than 2.
 - B) Plastic or glass (hard or soft).
 - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within six months.
- 7) Chromium.
- A) Preservative: Concentrated nitric acid to pH less than 2.

- B) Plastic or glass (hard or soft).
 - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within six months.
- 8) Cyanide.
- A) Preservative: Cool to 4° C. Add sodium hydroxide to pH greater than 12. See the analytical methods for information on sample preservation.
 - B) Plastic or glass (hard or soft).
 - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within 14 days.
- 9) Fluoride.
- A) Preservative: None.
 - B) Plastic or glass (hard or soft).
 - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within one month.
- 10) Mercury.
- A) Preservative: Concentrated nitric acid to pH less than 2.
 - B) Plastic or glass (hard or soft).
 - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within 28 days.
- 11) Nickel.
- A) Preservative: Concentrated nitric acid to pH less than 2.
 - B) Plastic or glass (hard or soft).
 - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within six months.
- 12) Nitrate, chlorinated.

- A) Preservative: Cool to 4° C.
 - B) Plastic or glass (hard or soft).
 - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within 14 days.
- 13) Nitrate, non-chlorinated.
- A) Preservative: Concentrated sulfuric acid to pH less than 2.
 - B) Plastic or glass (hard or soft).
 - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within 14 days.
- 14) Nitrite.
- A) Preservative: Cool to 4° C.
 - B) Plastic or glass (hard or soft).
 - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within 48 hours.
- 15) Selenium.
- A) Preservative: Concentrated nitric acid to pH less than 2.
 - B) Plastic or glass (hard or soft).
 - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within six months.
- 16) Thallium.
- A) Preservative: Concentrated nitric acid to pH less than 2.
 - B) Plastic or glass (hard or soft).
 - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within six months.
- c) Analyses under this Subpart N must be conducted by laboratories that received approval from USEPA or the Agency. The Agency must certify laboratories to conduct analyses for antimony, arsenic (effective January 23, 2006), asbestos,

barium, beryllium, cadmium, chromium, cyanide, fluoride, mercury, nickel, nitrate, nitrite, selenium, and thallium if the laboratory does as follows:

- 1) It analyzes performance evaluation (PE) samples, provided by the Agency pursuant to 35 Ill. Adm. Code 186, that include those substances at levels not in excess of levels expected in drinking water; and
- 2) It achieves quantitative results on the analyses within the following acceptance limits:
 - A) Antimony: $\pm 30\%$ at greater than or equal to 0.006 mg/l.
 - B) Arsenic: $\pm 30\%$ at greater than or equal to 0.003 mg/l.
 - C) Asbestos: 2 standard deviations based on study statistics.
 - D) Barium: $\pm 15\%$ at greater than or equal to 0.15 mg/l.
 - E) Beryllium: $\pm 15\%$ at greater than or equal to 0.001 mg/l.
 - F) Cadmium: $\pm 20\%$ at greater than or equal to 0.002 mg/l.
 - G) Chromium: $\pm 15\%$ at greater than or equal to 0.01 mg/l.
 - H) Cyanide: $\pm 25\%$ at greater than or equal to 0.1 mg/l.
 - I) Fluoride: $\pm 10\%$ at 1 to 10 mg/l.
 - J) Mercury: $\pm 30\%$ at greater than or equal to 0.0005 mg/l.
 - K) Nickel: $\pm 15\%$ at greater than or equal to 0.01 mg/l.
 - L) Nitrate: $\pm 10\%$ at greater than or equal to 0.4 mg/l.
 - M) Nitrite: $\pm 15\%$ at greater than or equal to 0.4 mg/l.
 - N) Selenium: $\pm 20\%$ at greater than or equal to 0.01 mg/l.
 - O) Thallium: $\pm 30\%$ at greater than or equal to 0.002 mg/l.

BOARD NOTE: Derived from 40 CFR 141.23(k)-~~(2002)~~ (2003).

(Source: Amended at 27 Ill. Reg. 16447, effective October 10, 2003)

Section 611.631 Special Monitoring for Inorganic Chemicals (Repealed)

~~Section 611.510 sets forth requirements for the special monitoring of unregulated inorganic contaminants.~~

(Source: Repealed at 28 Ill. Reg. _____, effective _____)

SUBPART O: ORGANIC MONITORING AND ANALYTICAL
REQUIREMENTS

Section 611.640 Definitions

The following terms are defined for use in this Subpart O only. Additional definitions are located in Section 611.102.

“Old MCL” means an MCL in Section 611.310. These include the MCLs identified as “additional state requirements,” ~~and those derived from 40 CFR 141.12, but excluding TTHM.~~ “Old MCLs” include the Section 611.310 MCLs for the following contaminants:

Aldrin

2,4-D

DDT

Dieldrin

Heptachlor

Heptachlor epoxide

BOARD NOTE: 2,4-D, heptachlor, and heptachlor epoxide are also “Phase II SOCs.” The additional state requirements of Section 611.310 impose a more stringent “old MCL” for each of these compounds than that imposed on them as Phase II SOCs by Section 611.311. However, the requirements for sampling and monitoring for these compounds as Phase II SOCs and the consequences of their detection and violation of their revised MCLs is more stringent as Phase II SOCs.

“Phase II SOCs” means the following:

Alachlor

Atrazine

Carbofuran

Chlordane

Dibromochloropropane

Ethylene dibromide

Heptachlor

Heptachlor epoxide

Lindane

Methoxychlor

Polychlorinated biphenyls

Toxaphene

2,4-D

2,4,5-TP

BOARD NOTE: These are organic contaminants regulated at 40 CFR 141.61(c)(1) through (c)(18)-~~(2002)~~ (2003). The MCLs for these contaminants are located at Section 611.311. More stringent MCLs for heptachlor, heptachlor epoxide, and 2,4-D are found as “additional state requirements” in Section 611.310.

“Phase IIB SOCs” means the following:

Aldicarb

Aldicarb Sulfone

Aldicarb Sulfoxide

Pentachlorophenol

BOARD NOTE: These are organic contaminants regulated at 40 CFR 141.61(c)(1) through (c)(18)-~~(2002)~~ (2003). The MCLs for these contaminants are located at Section 611.311. See the Board note appended to Section 611.311(c) for information relating to implementation of requirements relating to aldicarb, aldicarb sulfone, and aldicarb sulfoxide.

“Phase V SOCs” means the following:

Benzo(a)pyrene

Dalapon

Di(2-ethylhexyl)adipate

Di(2-ethylhexyl)phthalate

Dinoseb

Diquat

Endothall

Endrin

Glyphosate

Hexachlorobenzene

Hexachlorocyclopentadiene

Oxamyl

Picloram

Simazine

2,3,7,8-TCDD

BOARD NOTE: These are organic contaminants regulated at 40 CFR 141.61(c)(19) through (c)(33)-~~(2002)~~ (2003). The MCLs for these contaminants are located at Section 611.311.

“Phase I VOCs” means the following:

Benzene

Carbon tetrachloride
 p-Dichlorobenzene,
 1,2-Dichloroethane
 1,1-Dichloroethylene
 1,1,1-Trichloroethane
 Trichloroethylene
 Vinyl chloride

BOARD NOTE: These are the organic contaminants regulated at 40 CFR 141.61(a)(1) through (a)(8)-~~(2002)~~ (2003). The MCLs for these contaminants are located at Section 611.311(a).

“Phase II VOCs” means the following:

o-Dichlorobenzene
 cis-1,2-Dichloroethylene
 trans-1,2-Dichloroethylene
 1,2-Dichloropropane
 Ethylbenzene
 Monochlorobenzene
 Styrene
 Tetrachloroethylene
 Toluene
 Xylenes (total)

BOARD NOTE: These are organic contaminants regulated at 40 CFR 141.61(a)(9) through (a)(18)-~~(2002)~~ (2003). The MCLs for these contaminants are in Section 611.311(a).

“Phase V VOCs” means the following:

Dichloromethane
 1,2,4-Trichlorobenzene
 1,1,2-Trichloroethane

BOARD NOTE: These are the organic contaminants regulated at 40 CFR 141.61(a)(19) through (a)(21)-~~(2002)~~ (2003). The MCLs for these contaminants are located at Section 611.311(a).

“Revised MCL” means an MCL in Section 611.311. This term includes MCLs for Phase I VOCs, Phase II VOCs, Phase V VOCs, Phase II SOCs, Phase IIB SOCs, and Phase V SOCs.

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.645 Analytical Methods for Organic Chemical Contaminants

Analysis for the Section 611.311(a) VOCs under Section 611.646; the Section 611.311(c) SOCs under Section 611.648; the Section 611.310 old ~~organic~~ MCLs under Section 611.641; and for

THMs, TTHMs, and TTHM potential must be conducted using the methods listed in this Section or by equivalent methods as approved by the Agency pursuant to Section 611.480. All methods are from USEPA Organic Methods, unless otherwise indicated. All methods are incorporated by reference in Section 611.102.

Volatile Organic Chemical Contaminants (VOCs).

Contaminant	Analytical Methods
Benzene	502.2, 524.2
Carbon tetrachloride	502.2, 524.2, 551.1
Chlorobenzene	502.2, 524.2
1,2-Dichlorobenzene	502.2, 524.2
1,4-Dichlorobenzene	502.2, 524.2
1,2-Dichloroethane	502.2, 524.2
cis-Dichloroethylene	502.2, 524.2
trans-Dichloroethylene	502.2, 524.2
Dichloromethane	502.2, 524.2
1,2-Dichloropropane	502.2, 524.2
Ethylbenzene	502.2, 524.2
Styrene	502.2, 524.2
Tetrachloroethylene	502.2, 524.2, 551.1
1,1,1-Trichloroethane	502.2, 524.2, 551.1
Trichloroethylene	502.2, 524.2, 551.1
Toluene	502.2, 524.2
1,2,4-Trichlorobenzene	502.2, 524.2
1,1-Dichloroethylene	502.2, 524.2
1,1,2-Trichloroethane	502.2, 524.2
Vinyl chloride	502.2, 524.2
Xylenes (total)	502.2, 524.2

Synthetic Organic Chemical Contaminants (SOCs).

Contaminant	Analytical Methods
2,3,7,8-Tetrachlorodibenzodioxin (2,3,7,8-TCDD or dioxin)	Dioxin and Furan Method 1613
2,4-D	515.2, 555, 515.1, 515.3, 515.4, ASTM Method D5317-93
2,4,5-TP (Silvex)	515.2, 555, 515.1, 515.3, 515.4, ASTM Method D5317-93
Alachlor	505*, 507, 508.1, 525.2, 551.1
Atrazine	505*, 507, 508.1, 525.2, 551.1
Benzo(a)pyrene	525.2, 550, 550.1

Carbofuran	531.1, 531.2, Standard Methods, 18th ed. Supplement, 19th ed., or 20th ed.: Method 6610
Chlordane	505, 508, 508.1, 525.2
Dalapon	515.1, 552.1, 552.2, 515.3, 515.4
Di(2-ethylhexyl)adipate	506, 525.2
Di(2-ethylhexyl)phthalate	506, 525.2
Dibromochloropropane (DBCP)	504.1, 551.1
Dinoseb	515.1, 515.2, 515.3, 515.4, 555
Diquat	549.1
Endothall	548.1
Endrin	505, 508, 508.1, 525.2, 551.1
Ethylene Dibromide (EDB)	504.1, 551.1
Glyphosate	547, Standard Methods, 18th ed., 19th ed., or 20th ed.: Method 6651
Heptachlor	505, 508, 508.1, 525.2, 551.1
Heptachlor Epoxide	505, 508, 508.1, 525.2, 551.1
Hexachlorobenzene	505, 508, 508.1, 525.2, 551.1
Hexachlorocyclopentadiene	505, 508, 508.1, 525.2, 551.1
Lindane	505, 508, 508.1, 525.2, 551.1
Methoxychlor	505, 508, 508.1, 525.2, 551.1
Oxamyl	531.1, 531.2, Standard Methods, 18th ed. Supplement, 19th ed., or 20th ed.: Method 6610 508A
PCBs (measured for compliance purposes as decchlorobiphenyl)	505, 508, 508.1, 525.2
PCBs (qualitatively identified as Aroclors)	515.1, 515.2, 525.2, 555, 515.3, 515.4, ASTM Method D5317-93
Pentachlorophenol	515.1, 515.2, 555, 515.3, 515.4, ASTM Method D5317-93
Picloram	515.1, 515.2, 555, 515.3, 515.4, ASTM Method D5317-93

Simazine	505*, 507, 508.1, 525.2, 551.2
Toxaphene	505, 508, 525.2, 508.1

Total Trihalomethanes (TTHMs).

Contaminant Total Trihalomethanes (TTHMs), Trihalomethanes (THMs), and Maximum Total Trihalomethane Potential	Analytical Methods 502.2, 524.2, 551.1
--	---

State-Only MCLs (for which a method is not listed above).

Contaminant Aldrin DDT Dieldrin	Analytical Methods 505, 508, 508.1, 525.2 505, 508 505, 508, 508.1, 525.2
--	--

* denotes that, for the particular contaminant, a nitrogen-phosphorus detector should be substituted for the electron capture detector in method 505 (or another approved method should be used) to determine alachlor, atrazine, and simazine if lower detection limits are required.

BOARD NOTE: Derived from 40 CFR 141.24(e)-(2002) (2003).

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.646 Phase I, Phase II, and Phase V Volatile Organic Contaminants

Monitoring of the Phase I, Phase II, and Phase V VOCs for the purpose of determining compliance with the MCL must be conducted as follows:

- a) Definitions. As used in this Section the following have the given meanings:

“Detect” and “detection” mean that the contaminant of interest is present at a level greater than or equal to the “detection limit.”

“Detection limit” means 0.0005 mg/ℓ.

BOARD NOTE: Derived from 40 CFR 141.24(f)(7), (f)(11), (f)(14)(i), and (f)(20)-(2002) (2003). This is a “trigger level” for Phase I, Phase II, and Phase V VOCs inasmuch as it prompts further action. The use of the term “detect” in this Section is not intended to include any analytical capability of quantifying lower levels of any contaminant, or the “method detection limit.” Note, however, that certain language at the end of federal paragraph (f)(20) is capable of meaning that the “method detection limit” is used to derive the “detection limit.” The Board has chosen to disregard that language at the end of paragraph (f)(20) in favor of the more direct language of paragraphs (f)(7) and (f)(11).

“Method detection limit,” as used in subsections (q) and (t) of this Section means the minimum concentration of a substance that can be measured and reported with 99 percent confidence that the analyte concentration is greater than zero and is determined from analysis of a sample in a given matrix containing the analyte.

BOARD NOTE: Derived from 40 CFR 136, Appendix B-~~(2002)~~ (2003). The method detection limit is determined by the procedure set forth in 40 CFR 136, Appendix B. See subsection (t) of this Section.

- b) Required sampling. Each supplier must take a minimum of one sample at each sampling point at the times required in subsection (u) of this Section.
- c) Sampling points.
 - 1) Sampling points for a GWS. Unless otherwise provided by a SEP granted by the Agency pursuant to Section 611.110, a GWS supplier must take at least one sample from each of the following points: each entry point that is representative of each well after treatment.
 - 2) Sampling points for an SWS or mixed system supplier. Unless otherwise provided by a SEP granted by the Agency pursuant to Section 611.110, an SWS or mixed system supplier must sample from each of the following points:
 - A) Each entry point after treatment; or
 - B) Points in the distribution system that are representative of each source.
 - 3) The supplier must take each sample at the same sampling point unless the Agency has granted a SEP pursuant to Section 611.110 that designates another location as more representative of each source, treatment plant, or within the distribution system.
 - 4) If a system draws water from more than one source, and the sources are combined before distribution, the supplier must sample at an entry point during periods of normal operating conditions when water is representative of all sources being used.

BOARD NOTE: Subsections (b) and (c) of this Section derived from 40 CFR 141.24(f)(1) through (f)(3)-~~(2002)~~ (2003).

- d) Each CWS and NTNCWS supplier must take four consecutive quarterly samples for each of the Phase I VOCs, excluding vinyl chloride, and Phase II VOCs during each compliance period, beginning in the compliance period starting in the

initial compliance period.

- e) Reduction to annual monitoring frequency. If the initial monitoring for the Phase I, Phase II, and Phase V VOCs, as allowed in subsection (r)(1) of this Section, was completed by December 31, 1992, and the supplier did not detect any of the Phase I VOCs, including vinyl chloride; Phase II VOCs; or Phase V VOCs, then the supplier must take one sample annually beginning in the initial compliance period.
- f) GWS reduction to triennial monitoring frequency. After a minimum of three years of annual sampling, GWS suppliers that have not previously detected any of the Phase I VOCs, including vinyl chloride; Phase II VOCs; or Phase V VOCs must take one sample during each three-year compliance period.
- g) A CWS or NTNCWS supplier that has completed the initial round of monitoring required by subsection (d) of this Section and which did not detect any of the Phase I VOCs, including vinyl chloride; Phase II VOCs; and Phase V VOCs may apply to the Agency for a SEP pursuant to Section 611.110 that releases it from the requirements of subsection (e) or (f) of this Section. A supplier that serves fewer than 3300 service connections may apply to the Agency for a SEP that releases it from the requirements of subsection (d) of this Section as to 1,2,4-trichlorobenzene.

BOARD NOTE: Derived from 40 CFR 141.24(f)(7) and (f)(10)-~~(2002)~~ (2003), and the discussion at 57 Fed. Reg. 31825 (July 17, 1992). Provisions concerning the term of the waiver appear in subsections (i) and (j) of this Section. The definition of “detect,” parenthetically added to the federal counterpart paragraph, is in subsection (a) of this Section.

- h) Vulnerability assessment. The Agency must consider the factors of Section 611.110(e) in granting a SEP from the requirements of subsection (d), (e), or (f) of this Section sought pursuant to subsection (g) of this Section.
- i) A SEP issued to a GWS pursuant to subsection (g) of this Section is for a maximum of six years, except that a SEP as to the subsection (d) of this Section monitoring for 1,2,4-trichlorobenzene must apply only to the initial round of monitoring. As a condition of a SEP, except as to a SEP from the initial round of subsection (d) of this Section monitoring for 1,2,4-trichlorobenzene, the supplier shall, within 30 months after the beginning of the period for which the waiver was issued, reconfirm its vulnerability assessment required by subsection (h) of this Section and submitted pursuant to subsection (g) of this Section, by taking one sample at each sampling point and reapplying for a SEP pursuant to subsection (g) of this Section. Based on this application, the Agency must do either of the following:
 - 1) If it determines that the PWS meets the standard of Section 611.610(e),

issue a SEP that reconfirms the prior SEP for the remaining three-year compliance period of the six-year maximum term; or

- 2) Issue a new SEP requiring the supplier to sample annually.

BOARD NOTE: Subsection (i) of this Section does not apply to an SWS or mixed system supplier.

- j) Special considerations for a SEP for an SWS or ~~mixed system~~ mixed-system supplier.

- 1) The Agency must determine that an SWS is not vulnerable before issuing a SEP pursuant to Section 611.110 to an SWS supplier. A SEP issued to an SWS or mixed system supplier pursuant to subsection (g) of this Section is for a maximum of one compliance period; and
- 2) The Agency may require, as a condition to a SEP issued to an SWS or mixed supplier, that the supplier take such samples for Phase I, Phase II, and Phase V VOCs at such a frequency as the Agency determines are necessary, based on the vulnerability assessment.

BOARD NOTE: There is a great degree of similarity between 40 CFR 141.24(f)(7)-(2002) (2003), the provision applicable to GWSs, and 40 CFR 141.24(f)(10)-(2002) (2003), the provision for SWSs. The Board has consolidated the common requirements of both paragraphs into subsection (g) of this Section. Subsection (j) of this Section represents the elements unique to an SWSs or mixed system, and subsection (i) of this Section relates to a GWS supplier. Although 40 CFR 141.24(f)(7) and (f)(10) are silent as to a mixed system supplier, the Board has included a mixed system supplier with an SWS supplier because this best follows the federal scheme for all other contaminants.

- k) If one of the Phase I VOCs, excluding vinyl chloride; a Phase II VOC; or a Phase V VOC is detected in any sample, then the following must occur:
 - 1) The supplier must monitor quarterly for that contaminant at each sampling point that resulted in a detection.
 - 2) Annual monitoring.
 - A) The Agency must grant a SEP pursuant to Section 611.110 that allows a supplier to reduce the monitoring frequency to annual at a sampling point if it determines that the sampling point is reliably and consistently below the MCL.
 - B) A request for a SEP must include the following minimal information:

- i) For a GWS, two quarterly samples.
 - ii) For an SWS or mixed system supplier, four quarterly samples.
 - C) In issuing a SEP, the Agency must specify the level of the contaminant upon which the “reliably and consistently” determination was based. Any SEP that allows less frequent monitoring based on an Agency “reliably and consistently” determination must include a condition requiring the supplier to resume quarterly monitoring pursuant to subsection (k)(1) of this Section if it violates the MCL specified by Section 611.311.
- 3) Suppliers that monitor annually must monitor during the quarters that previously yielded the highest analytical result.
 - 4) Suppliers that do not detect a contaminant at a sampling point in three consecutive annual samples may apply to the Agency for a SEP pursuant to Section 611.110 that allows it to discontinue monitoring for that contaminant at that point, as specified in subsection (g) of this Section.
 - 5) A GWS supplier that has detected one or more of the two-carbon contaminants listed in subsection (k)(5)(A) of this Section must monitor quarterly for vinyl chloride as described in subsection (k)(5)(B) of this Section, subject to the limitation of subsection (k)(5)(C) of this Section.
 - A) “Two-carbon contaminants” (Phase I or II VOC) are the following:
 - 1,2-Dichloroethane (Phase I)
 - 1,1-Dichloroethylene (Phase I)
 - cis-1,2-Dichloroethylene (Phase II)
 - trans-1,2-Dichloroethylene (Phase II)
 - Tetrachloroethylene (Phase II)
 - 1,1,1-Trichloroethylene (Phase I)
 - Trichloroethylene (Phase I)
 - B) The supplier must sample quarterly for vinyl chloride at each sampling point at which it detected one or more of the two-carbon contaminants listed in subsection (k)(5)(A) of this Section.
 - C) The Agency must grant a SEP pursuant to Section 611.110 that allows the supplier to reduce the monitoring frequency for vinyl chloride at any sampling point to once in each three-year compliance period if it determines that the supplier has not detected vinyl chloride in the first sample required by subsection

(k)(5)(B) of this Section.

- l) Quarterly monitoring following MCL violations.
 - 1) Suppliers that violate an MCL for one of the Phase I VOCs, including vinyl chloride; Phase II VOCs; or Phase V VOCs, as determined by subsection (o) of this Section, must monitor quarterly for that contaminant, at the sampling point where the violation occurred, beginning the next quarter after the violation.
 - 2) Annual monitoring.
 - A) The Agency must grant a SEP pursuant to Section 611.110 that allows a supplier to reduce the monitoring frequency to annually if it determines that the sampling point is reliably and consistently below the MCL.
 - B) A request for a SEP must include the following minimal information: four quarterly samples.
 - C) In issuing a SEP, the Agency must specify the level of the contaminant upon which the “reliably and consistently” determination was based. Any SEP that allows less frequent monitoring based on an Agency “reliably and consistently” determination must include a condition requiring the supplier to resume quarterly monitoring pursuant to subsection (l)(1) of this Section if it violates the MCL specified by Section 611.311.
 - D) The supplier must monitor during the quarters that previously yielded the highest analytical result.
- m) Confirmation samples. The Agency may issue a SEP pursuant to Section 610.110 to require a supplier to use a confirmation sample for results that it finds dubious for whatever reason. The Agency must state its reasons for issuing the SEP if the SEP is Agency-initiated.
 - 1) If a supplier detects any of the Phase I, Phase II, or Phase V VOCs in a sample, the supplier must take a confirmation sample as soon as possible, but no later than 14 days after the supplier receives notice of the detection.
 - 2) Averaging is as specified in subsection (o) of this Section.
 - 3) The Agency must delete the original or confirmation sample if it determines that a sampling error occurred, in which case the confirmation sample will replace the original or confirmation sample.

- n) This subsection (n) corresponds with 40 CFR 141.24(f)(14), an optional USEPA provision relating to compositing of samples that USEPA does not require for state programs. This statement maintains structural consistency with USEPA rules.
- o) Compliance with the MCLs for the Phase I, Phase II, and Phase V VOCs must be determined based on the analytical results obtained at each sampling point. Effective January 22, 2004, if one sampling point is in violation of an MCL, the system is in violation of the MCL.
 - 1) Effective January 22, 2004, for a supplier that monitors more than once per year, compliance with the MCL is determined by a running annual average at each sampling point.
 - 2) Effective January 22, 2004, a supplier that monitors annually or less frequently whose sample result exceeds the MCL must begin quarterly sampling. The system will not be considered in violation of the MCL until it has completed one year of quarterly sampling.
 - 3) Effective January 22, 2004, if any sample result will cause the running annual average to exceed the MCL at any sampling point, the supplier is out of compliance with the MCL immediately.
 - 4) Effective January 22, 2004, if a supplier fails to collect the required number of samples, compliance will be based on the total number of samples collected.
 - 5) Effective January 22, 2004, if a sample result is less than the detection limit, zero will be used to calculate the annual average.
 - 6) Until January 22, 2004, for a supplier that conducts monitoring at a frequency greater than annual, compliance is determined by a running annual average of all samples taken at each sampling point.
 - A) If the annual average of any sampling point is greater than the MCL, then the supplier is out of compliance.
 - B) If the initial sample or a subsequent sample would cause the annual average to exceed the MCL, then the supplier is out of compliance immediately.
 - C) Any samples below the detection limit must be deemed as zero for purposes of determining the annual average.
 - 7) Until January 22, 2004, if monitoring is conducted annually, or less frequently, the supplier is out of compliance if the level of a contaminant

at any sampling point is greater than the MCL. Until January 22, 2004, if a confirmation sample is taken, the determination of compliance is based on the average of two samples.

- p) This subsection (p) corresponds with 40 CFR 141.24(f)(16), which USEPA removed and reserved. This statement maintains structural consistency with the federal regulations.
- q) Analysis under this Section must only be conducted by laboratories that have received certification by USEPA or the Agency according to the following conditions:
 - 1) To receive certification to conduct analyses for the Phase I VOCs, excluding vinyl chloride; Phase II VOCs; and Phase V VOCs, the laboratory must do the following:
 - A) It must analyze performance evaluation (PE) samples that include these substances provided by the Agency pursuant to 35 Ill. Adm. Code 186.170;
 - B) It must achieve the quantitative acceptance limits under subsections (q)(1)(C) and (q)(1)(D) of this Section for at least 80 percent of the regulated organic contaminants in the PE sample;
 - C) It must achieve quantitative results on the analyses performed under subsection (q)(1)(A) of this Section that are within ± 20 percent of the actual amount of the substances in the PE sample when the actual amount is greater than or equal to 0.010 mg/l;
 - D) It must achieve quantitative results on the analyses performed under subsection (q)(1)(A) of this Section that are within ± 40 percent of the actual amount of the substances in the PE sample when the actual amount is less than 0.010 mg/l; and
 - E) It must achieve a method detection limit of 0.0005 mg/l, according to the procedures in 40 CFR 136, appendix B, incorporated by reference in Section 611.102.
 - 2) To receive certification to conduct analyses for vinyl chloride the laboratory must do the following:
 - A) It must analyze PE samples provided by the Agency pursuant to 35 Ill. Adm. Code 186.170;
 - B) It must achieve quantitative results on the analyses performed under subsection (q)(2)(A) of this Section that are within ± 40

percent of the actual amount of vinyl chloride in the PE sample;

- C) It must achieve a method detection limit of 0.0005 mg/ℓ, according to the procedures in 40 CFR 136, appendix B, incorporated by reference in Section 611.102; and
 - D) It must obtain certification pursuant to subsection (q)(1) of this Section for Phase I VOCs, excluding vinyl chloride; Phase II VOCs; and Phase V VOCs.
- r) Use of existing data. This subsection (r) corresponds with 40 CFR 141.24(f)(18), an obsolete provision that relates to the initial compliance period from 1993 through 1995. This statement maintains consistency with the federal regulations.
- ~~1) The Agency must allow the use of data collected after January 1, 1988 but prior to December 1, 1992, pursuant to Agency sample request letters, if it determines that the data are generally consistent with the requirements of this Section.~~
 - ~~2) The Agency must grant a SEP pursuant to Section 611.110 that allows a supplier to monitor annually beginning in the initial compliance period if it determines that the supplier did not detect any Phase I, Phase II, or Phase V VOC using existing data allowed pursuant to subsection (r)(1) of this Section.~~
- s) The Agency shall, by a SEP issued pursuant to Section 611.110, increase the number of sampling points or the frequency of monitoring if it determines that it is necessary to detect variations within the PWS.
- t) Each laboratory certified for the analysis of Phase I, Phase II, or Phase V VOCs pursuant to subsection (q)(1) or (q)(2) of this Section shall do the following:
- 1) Determine the method detection limit (MDL), as defined in 40 CFR 136, Appendix B, incorporated by reference in Section 611.102, at which it is capable of detecting the Phase I, Phase II, and Phase V VOCs; and,
 - 2) Achieve an MDL for each Phase I, Phase II, and Phase V VOC that is less than or equal to 0.0005 mg/ℓ.
- u) Each supplier must monitor, within each compliance period, at the time designated by the Agency by SEP pursuant to Section 611.110.
- v) A new system supplier or a supplier that uses a new source of water that begins operation after January 22, 2004 must demonstrate compliance with the MCL within a period of time specified by a permit issued by the Agency. The supplier must also comply with the initial sampling frequencies specified by the Agency to

ensure the supplier can demonstrate compliance with the MCL. Routine and increased monitoring frequencies must be conducted in accordance with the requirements in this Section.

BOARD NOTE: Derived from 40 CFR 141.24(f) ~~(2002)~~ (2003).

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.648 Phase II, Phase IIB, and Phase V Synthetic Organic Contaminants

Analysis of the Phase II, Phase IIB, and Phase V SOCs for the purposes of determining compliance with the MCL must be conducted as follows:

- a) Definitions. As used in this Section, the following terms will have the following meanings:

“Detect” or “detection” means that the contaminant of interest is present at a level greater than or equal to the “detection limit.”

“Detection limit” means the level of the contaminant of interest that is specified in subsection (r) of this Section.

BOARD NOTE: This is a “trigger level” for Phase II, Phase IIB, and Phase V SOCs inasmuch as it prompts further action. The use of the term “detect” or “detection” in this Section is not intended to include any analytical capability of quantifying lower levels of any contaminant, or the “method detection limit.”

- b) Required sampling. Each supplier must take a minimum of one sample at each sampling point at the times required in subsection (q) of this Section.

BOARD NOTE: See the Board note appended to Section 611.311(c) for information relating to implementation of requirements relating to aldicarb, aldicarb sulfone, and aldicarb sulfoxide.

- c) Sampling points.
- 1) Sampling points for GWSs. Unless otherwise provided by SEP, a GWS supplier must take at least one sample from each of the following points: each entry point that is representative of each well after treatment.
 - 2) Sampling points for an SWS or mixed system supplier. Unless otherwise provided by SEP, an SWS or mixed system supplier must sample from each of the following points:
 - A) Each entry point after treatment; or

- B) Points in the distribution system that are representative of each source.
- 3) The supplier must take each sample at the same sampling point unless the Agency has granted a SEP that designates another location as more representative of each source, treatment plant, or within the distribution system.
- 4) If a system draws water from more than one source, and the sources are combined before distribution, the supplier must sample at an entry point during periods of normal operating conditions when water is representative of all sources being used.

BOARD NOTE: Subsections (b) and (c) of this Section derived from 40 CFR 141.24(h)(1) through (h)(3)-~~(2002)~~ (2003).

- d) Monitoring frequency.
 - 1) Each CWS and NTNCWS supplier must take four consecutive quarterly samples for each of the Phase II, Phase IIB, and Phase V SOCs during each compliance period, beginning in the three-year compliance period starting in the initial compliance period.
 - 2) Suppliers serving more than 3,300 persons that do not detect a contaminant in the initial compliance period must take a minimum of two quarterly samples in one year of each subsequent three-year compliance period.
 - 3) Suppliers serving fewer than or equal to 3,300 persons that do not detect a contaminant in the initial compliance period must take a minimum of one sample during each subsequent three-year compliance period.
- e) Reduction to annual monitoring frequency. A CWS or NTNCWS supplier may apply to the Agency for a SEP that releases it from the requirements of subsection (d) of this Section. A SEP from the requirement of subsection (d) of this Section must last for only a single three-year compliance period.
- f) Vulnerability assessment. The Agency must grant a SEP from the requirements of subsection (d) of this Section based on consideration of the factors set forth at Section 611.110(e).
- g) If one of the Phase II, Phase IIB, or Phase V SOCs is detected in any sample, then the following must occur:
 - 1) The supplier must monitor quarterly for the contaminant at each sampling

point that resulted in a detection.

- 2) Annual monitoring.
 - A) A supplier may request that the Agency grant a SEP pursuant to Section 610.110 that reduces the monitoring frequency to annual.
 - B) A request for a SEP must include the following minimal information:
 - i) For a GWS, two quarterly samples.
 - ii) For an SWS or mixed system supplier, four quarterly samples.
 - C) The Agency must grant a SEP that allows annual monitoring at a sampling point if it determines that the sampling point is reliably and consistently below the MCL.
 - D) In issuing the SEP, the Agency must specify the level of the contaminant upon which the “reliably and consistently” determination was based. Any SEP that allows less frequent monitoring based on an Agency “reliably and consistently” determination must include a condition requiring the supplier to resume quarterly monitoring pursuant to subsection (g)(1) of this Section if it detects any Phase II SOC.
- 3) Suppliers that monitor annually must monitor during the quarters that previously yielded the highest analytical result.
- 4) Suppliers that have three consecutive annual samples with no detection of a contaminant at a sampling point may apply to the Agency for a SEP with respect to that point, as specified in subsections (e) and (f) of this Section.
- 5) Monitoring for related contaminants.
 - A) If monitoring results in detection of one or more of the related contaminants listed in subsection (g)(5)(B) of this Section, subsequent monitoring must analyze for all the related compounds in the respective group.
 - B) Related contaminants.
 - i) First group.
aldicarb

aldicarb sulfone
aldicarb sulfoxide

BOARD NOTE: See the Board note appended to Section 611.311(c) for information relating to implementation of requirements relating to aldicarb, aldicarb sulfone, and aldicarb sulfoxide.

ii) Second group.

heptachlor
heptachlor epoxide.

h) Quarterly monitoring following MCL violations.

1) Suppliers that violate an MCL for one of the Phase II, Phase IIB, or Phase V SOCs, as determined by subsection (k) of this Section, must monitor quarterly for that contaminant at the sampling point where the violation occurred, beginning the next quarter after the violation.

2) Annual monitoring.

A) A supplier may request that the Agency grant a SEP pursuant to Section 611.110 that reduces the monitoring frequency to annual.

B) A request for a SEP must include, at a minimum, the results from four quarterly samples.

C) The Agency must grant a SEP that allows annual monitoring at a sampling point if it determines that the sampling point is reliably and consistently below the MCL.

D) In issuing the SEP, the Agency must specify the level of the contaminant upon which the “reliably and consistently” determination was based. Any SEP that allows less frequent monitoring based on an Agency “reliably and consistently” determination must include a condition requiring the supplier to resume quarterly monitoring pursuant to subsection (h)(1) of this Section if it detects any Phase II SOC.

E) The supplier must monitor during the quarters that previously yielded the highest analytical result.

i) Confirmation samples.

1) If any of the Phase II, Phase IIB, or Phase V SOCs are detected in a

sample, the supplier must take a confirmation sample as soon as possible, but no later than 14 days after the supplier receives notice of the detection.

- 2) Averaging is as specified in subsection (k) of this Section.
 - 3) The Agency must delete the original or confirmation sample if it determines that a sampling error occurred, in which case the confirmation sample will replace the original or confirmation sample.
- j) This subsection (j) corresponds with 40 CFR 141.24(h)(10), an optional USEPA provision relating to compositing of samples that USEPA does not require for state programs. This statement maintains structural consistency with USEPA rules.
- k) Compliance with the MCLs for the Phase II, Phase IIB, and Phase V SOCs must be determined based on the analytical results obtained at each sampling point. Effective January 22, 2004, if one sampling point is in violation of an MCL, the supplier is in violation of the MCL.
- 1) Effective January 22, 2004, for a supplier that monitors more than once per year, compliance with the MCL is determined by a running annual average at each sampling point.
 - 2) Effective January 22, 2004, a supplier that monitors annually or less frequently whose sample result exceeds the regulatory detection level as defined by subsection (r) of this Section must begin quarterly sampling. The system will not be considered in violation of the MCL until it has completed one year of quarterly sampling.
 - 3) Effective January 22, 2004, if any sample result will cause the running annual average to exceed the MCL at any sampling point, the supplier is out of compliance with the MCL immediately.
 - 4) Effective January 22, 2004, if a supplier fails to collect the required number of samples, compliance will be based on the total number of samples collected.
 - 5) Effective January 22, 2004, if a sample result is less than the detection limit, zero will be used to calculate the annual average.
 - 6) Until January 22, 2004, for a supplier that conducts monitoring at a frequency greater than annual, compliance is determined by a running annual average of all samples taken at each sampling point.
 - A) If the annual average of any sampling point is greater than the MCL, then the supplier is out of compliance.

- B) If the initial sample or a subsequent sample would cause the annual average to exceed the MCL, then the supplier is out of compliance immediately.
 - C) Any samples below the detection limit must be deemed as zero for purposes of determining the annual average.
- 7) Until January 22, 2004, if the supplier conducts monitoring annually, or less frequently, the supplier is out of compliance if the level of a contaminant at any sampling point is greater than the MCL. Until January 22, 2004, if a confirmation sample is taken, the determination of compliance is based on the average of two samples.
- l) This subsection (l) corresponds with 40 CFR 141.24(h)(12), which USEPA removed and reserved. This statement maintains structural consistency with the federal regulations.
- m) Analysis for PCBs must be conducted as follows using the methods in Section 611.645:
- 1) Each supplier that monitors for PCBs must analyze each sample using either USEPA Organic Methods, Method 505 or Method 508.
 - 2) If PCBs are detected in any sample analyzed using USEPA Organic Methods, Method 505 or 508, the supplier must reanalyze the sample using Method 508A to quantitate the individual Aroclors (as decachlorobiphenyl).
 - 3) Compliance with the PCB MCL must be determined based upon the quantitative results of analyses using USEPA Organic Methods, Method 508A.
- n) Use of existing data. This subsection (n) corresponds with 40 CFR 141.24(h)(14), an obsolete provision that relates to the initial compliance period from 1993 through 1995. This statement maintains consistency with the federal regulations.
- ~~1) The Agency must allow the use of data collected after January 1, 1990 but prior to the effective date of this Section, pursuant to Agency sample request letters, if it determines that the data are generally consistent with the requirements of this Section.~~
 - ~~2) The Agency must grant a SEP pursuant to Section 611.110 that allows a supplier to monitor annually beginning in the initial compliance period if it determines that the supplier did not detect any Phase I VOC or Phase II~~

~~VOC using existing data allowed pursuant to subsection (n)(1) of this Section.~~

- o) The Agency must issue a SEP that increases the number of sampling points or the frequency of monitoring if it determines that this is necessary to detect variations within the PWS due to such factors as fluctuations in contaminant concentration due to seasonal use or changes in the water source.

BOARD NOTE: At 40 CFR 141.24(h)(15), USEPA uses the stated factors as non-limiting examples of circumstances that make additional monitoring necessary.

- p) This subsection (p) corresponds with 40 CFR 141.24(h)(16), a USEPA provision relating to reserving enforcement authority to the State that would serve no useful function as part of the State's rules. This statement maintains structural consistency with USEPA rules.
- q) Each supplier must monitor, within each compliance period, at the time designated by the Agency by SEP pursuant to Section 611.110.
- r) "Detection" means greater than or equal to the following concentrations for each contaminant:

- 1) for PCBs (Aroclors), the following:

Aroclor	Detection Limit (mg/ℓ)
1016	0.00008
1221	0.02
1232	0.0005
1242	0.0003
1248	0.0001
1254	0.0001
1260	0.0002

- 2) for other Phase II, Phase IIB, and Phase V SOCs, the following:

Contaminant	Detection Limit (mg/ℓ)
Alachlor	0.0002
Aldicarb	0.0005
Aldicarb sulfoxide	0.0005
Aldicarb sulfone	0.0008
Atrazine	0.0001
Benzo(a)pyrene	0.00002

Carbofuran	0.0009
Chlordane	0.0002
2,4-D	0.0001
Dalapon	0.001
1,2-Dibromo-3-chloropropane (DBCP)	0.00002
Di(2-ethylhexyl)adipate	0.0006
Di(2-ethylhexyl)phthalate	0.0006
Dinoseb	0.0002
Diquat	0.0004
Endothall	0.009
Endrin	0.00001
Ethylene dibromide (EDB)	0.00001
Glyphosate	0.006
Heptachlor	0.00004
Heptachlor epoxide	0.00002
Hexachlorobenzene	0.0001
Hexachlorocyclopentadiene	0.0001
Lindane	0.00002
Methoxychlor	0.0001
Oxamyl	0.002
Picloram	0.0001
Polychlorinated biphenyls (PCBs) (as decachlorobiphenyl)	0.0001
Pentachlorophenol	0.00004
Simazine	0.00007
Toxaphene	0.001
2,3,7,8-TCDD (dioxin)	0.000000005
2,4,5-TP (silvex)	0.0002

BOARD NOTE: See the Board note appended to Section 611.311(c) for information relating to implementation of requirements relating to aldicarb, aldicarb sulfone, and aldicarb sulfoxide.

- s) Laboratory certification.
- 1) Analyses under this Section must only be conducted by laboratories that have received approval by USEPA or the Agency according to the conditions of subsection (s)(2) of this Section.
 - 2) To receive certification to conduct analyses for the Phase II, Phase IIB, and Phase V SOCs, the laboratory must do the following:
 - A) Analyze PE samples provided by the Agency pursuant to 35 Ill. Adm. Code 183.125(c) that include these substances; and
 - B) Achieve quantitative results on the analyses performed under

subsection (s)(2)(A) of this Section that are within the following acceptance limits:

SOC	Acceptance Limits
Alachlor	± 45%
Aldicarb	2 standard deviations
Aldicarb sulfone	2 standard deviations
Aldicarb sulfoxide	2 standard deviations
Atrazine	± 45%
Benzo(a)pyrene	2 standard deviations
Carbofuran	± 45%
Chlordane	± 45%
Dalapon	2 standard deviations
Di(2-ethylhexyl)adipate	2 standard deviations
Di(2-ethylhexyl)phthalate	2 standard deviations
Dinoseb	2 standard deviations
Diquat	2 standard deviations
Endothall	2 standard deviations
Endrin	± 30%
Glyphosate	2 standard deviations
Dibromochloropropane (DBCP)	± 40%
Ethylene dibromide (EDB)	± 40%
Heptachlor	± 45%
Heptachlor epoxide	± 45%
Hexachlorobenzene	2 standard deviations
Hexachlorocyclopentadiene	2 standard deviations
Lindane	± 45%
Methoxychlor	± 45%
Oxamyl	2 standard deviations
PCBs (as decachlorobiphenyl)	0-200%
Pentachlorophenol	± 50%
Picloram	2 standard deviations
Simazine	2 standard deviations
Toxaphene	± 45%
2,4-D	± 50%
2,3,7,8-TCDD (dioxin)	2 standard deviations
2,4,5-TP (silvex)	± 50%

BOARD NOTE: See the Board note appended to Section 611.311(c) for information relating to implementation of requirements relating to aldicarb, aldicarb sulfone, and aldicarb sulfoxide.

- t) A new system supplier or a supplier that uses a new source of water that begins operation after January 22, 2004 must demonstrate compliance with the MCL

within a period of time specified by a permit issued by the Agency. The supplier must also comply with the initial sampling frequencies specified by the Agency to ensure the supplier can demonstrate compliance with the MCL. Routine and increased monitoring frequencies must be conducted in accordance with the requirements in this Section.

BOARD NOTE: Derived from 40 CFR 141.24(h)-(2002) (2003).

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.658 Special Monitoring for Organic Chemicals (Repealed)

~~Section 611.510 sets forth requirements for the special monitoring for unregulated organic contaminants.~~

(Source: Repealed at 28 Ill. Reg. _____, effective _____)

SUBPART P: THM MONITORING AND ANALYTICAL REQUIREMENTS

Section 611.683 Reduced Monitoring Frequency (Repealed)

- a) ~~A CWS supplier utilizing only groundwater sources may, by a SEP application pursuant to Section 611.110, seek to have the monitoring frequency required by Section 611.680(b)(1) reduced to a minimum of one sample for maximum TTHM potential per year for each treatment plant used by the supplier, taken at a point in the distribution system reflecting maximum residence time of the water in the system.~~
- 1) ~~The CWS supplier must submit to the Agency at least one sample for maximum TTHM potential using the procedure specified in Section 611.687. A sample must be analyzed from each treatment plant used by the supplier, taken at a point in the distribution system reflecting the maximum residence time of the water in the system.~~
 - 2) ~~The Agency must reduce the supplier's monitoring frequency if it determines that, based upon the data submitted by the supplier, the supplier has a maximum TTHM potential of less than 0.10 mg/l and that, based upon an assessment of the local conditions of the CWS, the CWS is not likely to approach or exceed the MCL for TTHMs.~~
 - 3) ~~The results of all analyses must be reported to the Agency within 30 days of the supplier's receipt of such results.~~
 - 4) ~~All samples collected must be used for determining whether the supplier complies with the monitoring requirements of Section 611.680(b), unless the analytical results are invalidated for technical reasons.~~

- 5) ~~Sampling and analyses must be conducted in accordance with the methods listed in Section 611.685.~~
- b) ~~Loss or modification of reduced monitoring frequency.~~
- 1) ~~If the results from any analysis taken by the supplier for maximum TTHM potential are equal to or greater than 0.10 mg/l, and such results are confirmed by at least one check sample taken promptly after such results are received, the CWS supplier must immediately begin monitoring in accordance with the requirements of Section 611.680(b), and such monitoring must continue for at least one year before the frequency may be reduced again.~~
 - 2) ~~In the event of any significant change to the CWS's raw water or treatment program, the supplier must immediately analyze an additional sample for maximum TTHM potential taken at a point in the distribution system reflecting maximum residence time of the water in the system.~~
 - 3) ~~The Agency must require increased monitoring frequencies above the minimum where necessary to detect variation of TTHM levels within the distribution system.~~

BOARD NOTE: ~~Derived from 40 CFR 141.30(e) (2002).~~

(Source: Repealed at 28 Ill. Reg. _____, effective _____)

Section 611.684 Averaging (Repealed)

~~Compliance with Section 611.310(e) or 611.312(a) is determined based on a running annual average of quarterly samples collected by the PWS, as prescribed in Section 611.680(b)(1) or (b)(2). If the average of samples covering any 12 month period exceeds the MCL, the PWS must report to the Agency and notify the public pursuant to Subpart V of this Part. Monitoring after public notification must be at a frequency designated by the Agency and must continue until a monitoring schedule as a condition to a variance, adjusted standard, or enforcement action becomes effective.~~

BOARD NOTE: ~~Derived from 40 CFR 141.30(d) (2002).~~

(Source: Repealed at 28 Ill. Reg. _____, effective _____)

Section 611.686 Modification to System (Repealed)

~~Before a CWS supplier makes any significant modifications to its existing treatment process for the purposes of achieving compliance with Section 611.310(e), the supplier must submit, by way of a SEP application pursuant to Section 611.110, a detailed plan setting forth its proposed~~

modification and those safeguards that it will implement to ensure that the bacteriological quality of the drinking water served by the CWS will not be adversely affected by such modification. Upon approval, the plan will become a SEP. At a minimum, the plan must require the supplier modifying its disinfection practice to the following:

- a) ~~Evaluate the water system for sanitary defects and evaluate the source water for biological quality;~~
- b) ~~Evaluate its existing treatment practices and consider improvements that will minimize disinfectant demand and optimize finished water quality throughout the distribution system;~~
- c) ~~Provide baseline water quality survey data of the distribution system. Such data should include the results from monitoring for coliform and fecal coliform bacteria, fecal streptococci, standard plate counts at 35 degrees C and 20 degrees C, phosphate, ammonia nitrogen, and total organic carbon. Virus studies are required where source waters are heavily contaminated with sewage effluent;~~
- d) ~~Conduct additional monitoring to assure continued maintenance of optimal biological quality in finished water, for example, when chloramines are introduced as disinfectants or when pre-chlorination is being discontinued. The Agency must also require additional monitoring for chlorate, chlorite and chlorine dioxide when chlorine dioxide is used. The Agency must also require HPC analysis (Section 611.531), as appropriate, before and after any modifications;~~
- e) ~~Consider inclusion in the plan of provisions to maintain an active RDC throughout the distribution system at all times during and after the modification.~~

BOARD NOTE: ~~Derived from 40 CFR 141.30(f) (2002).~~

(Source: Repealed at 28 Ill. Reg. _____, effective _____)

Section 611.687 Sampling for Maximum THM Potential (Repealed)

- a) ~~The water sample for determination of maximum total trihalomethane potential must be taken from a point in the distribution system that reflects maximum residence time. Procedures for sample collection and handling are given in the methods.~~
- b) ~~The supplier taking samples must not add reducing agent to “quench” the chemical reaction producing THMs at the time of sample collection. The intent is to permit the level of THM precursors to be depleted and the concentration of THMs to be maximized for the supply being tested.~~
- c) ~~Four experimental parameters affecting maximum THM production are pH, temperature, reaction time, and the presence of a disinfectant residual. The~~

~~supplier taking the sample must deal with these parameters as follows:~~

- ~~1) Measure the disinfectant residual at the selected sampling point. Proceed only if a measurable disinfectant residual is present.~~
- ~~2) Collect triplicate 40 ml water samples at the pH prevailing at the time of sampling, and prepare a method blank according to the methods.~~
- ~~3) Seal and store these samples together for seven days at 25° C or above.~~
- ~~4) After this time period, open one of the sample containers and check for disinfectant residual. Absence of a disinfectant residual invalidates the sample for further analysis.~~
- ~~5) Once a disinfectant residual has been demonstrated, open another of the sealed samples and determine total THM concentration using an approved analytical method.~~

~~BOARD NOTE: Derived from 40 CFR 141.30(g) (2002).~~

~~(Source: Repealed at 28 Ill. Reg. _____, effective _____)~~

~~Section 611.688 Applicability Dates (Repealed)~~

~~The requirements in Sections 611.680 through 611.686 applied to a Subpart B community water system that serves 10,000 or more persons until December 31, 2001. The requirements in Sections 611.680 through 611.686 apply to a community water system that uses only groundwater not under the direct influence of surface water which adds a disinfectant (oxidant) in any part of the treatment process and serves 10,000 or more persons until December 31, 2003. After December 31, 2003, Sections 611.680 through 611.688 are no longer applicable.~~

~~(Source: Repealed at 28 Ill. Reg. _____, effective _____)~~

SUBPART Q: RADIOLOGICAL MONITORING AND ANALYTICAL REQUIREMENTS

Section 611.731 Gross Alpha

Monitoring requirements for gross alpha particle activity, radium-226, radium-228, and uranium are as follows:

- a) Effective December 8, 2003, a community water system (CWS) supplier must conduct initial monitoring to determine compliance with Section 611.330(b), (c), and (e) by December 31, 2007. For the purposes of monitoring for gross alpha particle activity, radium-226, radium-228, uranium, and beta particle and photon radioactivity in drinking water, "detection limit" is defined as in Section

611.720(c).

- 1) Applicability and sampling location for an existing CWS supplier. An existing CWS supplier using groundwater, surface water, or both groundwater and surface water (for the purpose of this Section hereafter referred to as a supplier) must sample at every entry point to the distribution system that is representative of all sources being used (hereafter called a sampling point) under normal operating conditions. The supplier must take each sample at the same sampling point, unless conditions make another sampling point more representative of each source or the Agency has designated a distribution system location, in accordance with subsection (b)(2)(C) of this Section.
 - 2) Applicability and sampling location for a new CWS supplier. A new CWS supplier or a CWS supplier that uses a new source of water must begin to conduct initial monitoring for the new source within the first quarter after initiating use of the source. A CWS supplier must conduct more frequent monitoring when ordered by the Agency in the event of possible contamination or when changes in the distribution system or treatment processes occur that may increase the concentration of radioactivity in finished water.
- b) Initial monitoring: Effective December 8, 2003, a CWS supplier must conduct initial monitoring for gross alpha particle activity, radium-226, radium-228, and uranium as follows:
- 1) A CWS supplier without acceptable historical data, as defined in subsection (b)(2) of this Section, must collect four consecutive quarterly samples at all sampling points before December 31, 2007.
 - 2) Grandfathering of data: A CWS supplier may use historical monitoring data collected at a sampling point to satisfy the initial monitoring requirements for that sampling point, under the following situations.
 - A) To satisfy initial monitoring requirements, a CWS supplier having only one entry point to the distribution system may use the monitoring data from the last compliance monitoring period that began between June 2000 and December 8, 2003.
 - B) To satisfy initial monitoring requirements, a CWS supplier with multiple entry points and having appropriate historical monitoring data for each entry point to the distribution system may use the monitoring data from the last compliance monitoring period that began between June 2000 and December 8, 2003.
 - C) To satisfy initial monitoring requirements, a CWS supplier with

appropriate historical data for a representative point in the distribution system may use the monitoring data from the last compliance monitoring period that began between June 2000 and December 8, 2003, provided that the Agency finds that the historical data satisfactorily demonstrate that each entry point to the distribution system is expected to be in compliance based upon the historical data and reasonable assumptions about the variability of contaminant levels between entry points. The Agency must make its finding in writing, by a SEP issued pursuant to Section 611.110, indicating how the data conforms to the requirements of this subsection (b)(2).

- 3) For gross alpha particle activity, uranium, radium-226, and radium-228 monitoring, the Agency may, by a SEP issued pursuant to Section 611.110, waive the final two quarters of initial monitoring for a sampling point if the results of the samples from the previous two quarters are below the detection limit.
 - 4) If the average of the initial monitoring results for a sampling point is above the MCL, the supplier must collect and analyze quarterly samples at that sampling point until the system has results from four consecutive quarters that are at or below the MCL, unless the supplier enters into another schedule as part of a formal compliance agreement with the Agency.
- c) Reduced monitoring: Effective December 8, 2003, the Agency may allow a CWS supplier to reduce the future frequency of monitoring from once every three years to once every six or nine years at each sampling point, based on the following criteria:
- 1) If the average of the initial monitoring results for each contaminant (i.e., gross alpha particle activity, uranium, radium-226, or radium-228) is below the detection limit specified in the table at Section 611.720(c)(1), the supplier must collect and analyze for that contaminant using at least one sample at that sampling point every nine years.
 - 2) For gross alpha particle activity and uranium, if the average of the initial monitoring results for each contaminant is at or above the detection limit but at or below one-half the MCL, the supplier must collect and analyze for that contaminant using at least one sample at that sampling point every six years. For combined radium-226 and radium-228, the analytical results must be combined. If the average of the combined initial monitoring results for radium-226 and radium-228 is at or above the detection limit but at or below one-half the MCL, the supplier must collect and analyze for that contaminant using at least one sample at that sampling point every six years.

- 3) For gross alpha particle activity and uranium, if the average of the initial monitoring results for each contaminant is above one-half the MCL but at or below the MCL, the supplier must collect and analyze at least one sample at that sampling point every three years. For combined radium-226 and radium-228, the analytical results must be combined. If the average of the combined initial monitoring results for radium-226 and radium-228 is above one-half the MCL but at or below the MCL, the supplier must collect and analyze at least one sample at that sampling point every three years.
 - 4) A supplier must use the samples collected during the reduced monitoring period to determine the monitoring frequency for subsequent monitoring periods (e.g., if a supplier's sampling point is on a nine year monitoring period, and the sample result is above one-half the MCL, then the next monitoring period for that sampling point is three years).
 - 5) If a supplier has a monitoring result that exceeds the MCL while on reduced monitoring, the supplier must collect and analyze quarterly samples at that sampling point until the supplier has results from four consecutive quarters that are below the MCL, unless the supplier enters into another schedule as part of a formal compliance agreement with the Agency.
- d) Compositing: Effective December 8, 2003, to fulfill quarterly monitoring requirements for gross alpha particle activity, radium-226, radium-228, or uranium, a supplier may composite up to four consecutive quarterly samples from a single entry point if analysis is done within a year after the first sample. The analytical results from the composited sample must be treated as the average analytical result to determine compliance with the MCLs and the future monitoring frequency. If the analytical result from the composited sample is greater than one-half the MCL, the Agency may, by a SEP issued pursuant to Section 611.110, direct the supplier to take additional quarterly samples before allowing the supplier to sample under a reduced monitoring schedule.
- e) Effective December 8, 2003, a gross alpha particle activity measurement may be substituted for the required radium-226 measurement, provided that the measured gross alpha particle activity does not exceed 5 pCi/l. A gross alpha particle activity measurement may be substituted for the required uranium measurement provided that the measured gross alpha particle activity does not exceed 15 pCi/l.
- 1) The gross alpha measurement must have a confidence interval of 95% (1.65σ , where σ is the standard deviation of the net counting rate of the sample) for radium-226 and uranium.
 - 2) When a supplier uses a gross alpha particle activity measurement in lieu of

a radium-226 or uranium measurement, the gross alpha particle activity analytical result will be used to determine the future monitoring frequency for radium-226 or uranium.

- 3) If the gross alpha particle activity result is less than detection, one-half the detection limit will be used to determine compliance and the future monitoring frequency.
- f) Until December 8, 2003, compliance must be based on the analysis of an annual composite of four consecutive quarterly samples or the average of the analyses of four samples obtained at quarterly intervals.
- 1) A gross alpha particle activity measurement may be substituted for the required radium-226 and radium-228 analysis, provided that the measured gross alpha particle activity does not exceed 5 pCi/l at a confidence level of 95 percent (1.65σ where σ is the standard deviation of the net counting rate of the sample). In localities where radium-228 may be present in drinking water, the Agency may, by a SEP issued pursuant to Section 611.110, require radium-226 or radium-228 analyses if it determines that the gross alpha particle activity exceeds 2 pCi/l.
 - 2) When the gross alpha particle activity exceeds 5 pCi/l, the same or an equivalent sample must be analyzed for radium-226. If the concentration of radium-226 exceeds 3 pCi/l the same or an equivalent sample must be analyzed for radium-228.
- ~~g) See Section 611.100(e).~~
- hg) Until December 8, 2003, CWS suppliers must monitor at least once every four years following the procedure required by subsection (f) of this Section. When an annual record taken in conformance with subsection (f) of this Section has established that the average annual concentration is less than half the MCLs established by Section 611.330, the Agency shall, by a SEP issued pursuant to Section 611.110, substitute analysis of a single sample for the quarterly sampling procedure required by subsection (f) of this Section.
- 1) The Agency shall, by a SEP issued pursuant to Section 611.110, require more frequent monitoring in the vicinity of mining or other operations that may contribute alpha particle radioactivity to either surface or groundwater sources of drinking water.
 - 2) A CWS supplier must monitor in conformance with subsection (f) of this Section for one year after the introduction of a new water source. The Agency shall, by a SEP issued pursuant to Section 611.110, require more frequent monitoring in the event of possible contamination or when changes in the distribution system or treatment process occur that may

increase the concentration of radioactivity in finished water.

- 3) The Agency shall, by a SEP issued pursuant to Section 611.110, require a CWS supplier using two or more sources having different concentrations of radioactivity to monitor source water, in addition to water from a free-flowing tap.
 - 4) The Agency must not require monitoring for radium-228 to determine compliance with Section 611.330 after the initial period, provided that the average annual concentration of radium-228 has been assayed at least once using the quarterly sampling procedure required by subsection (f) of this Section.
 - 5) The Agency must require the CWS supplier to conduct annual monitoring if the radium-226 concentration exceeds 3 pCi/l.
- ih) Until December 8, 2003, if the average annual MCL for gross alpha particle activity or total radium as set forth in Section 611.330 is exceeded, the CWS supplier must give notice to the Agency and notify the public as required by Subpart V. Monitoring at quarterly intervals must be continued until the annual average concentration no longer exceeds the MCL or until a monitoring schedule as a condition to a variance, adjusted standard or enforcement action becomes effective.

BOARD NOTE: Subsections (a) through (e) derive from 40 CFR 141.26(a) ~~(2002)~~ (2003).
Subsections (f) through (i) derive from 40 CFR 141.26(a), as effective until December 8, 2003.

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.732 Beta Particle and Photon Radioactivity

Monitoring and compliance requirements for manmade radioactivity. To determine compliance with the maximum contaminant levels in Section 611.330(d) for beta particle and photon radioactivity, a supplier must monitor at a frequency as follows:

- a) Effective December 8, 2003, a CWS supplier (either a surface water or groundwater supplier) designated by the Agency, by a SEP issued pursuant to Section 611.110, as vulnerable must sample for beta particle and photon radioactivity. A supplier must collect quarterly samples for beta emitters and annual samples for tritium and strontium-90 at each entry point to the distribution system (hereafter called a sampling point), beginning within one quarter after being notified by the Agency. A supplier already designated by the Agency must continue to sample until the Agency reviews and either reaffirms or removes the designation, by a SEP issued pursuant to Section 611.110.
 - 1) If the gross beta particle activity minus the naturally occurring potassium-

40 beta particle activity at a sampling point has a running annual average (computed quarterly) less than or equal to 50 pCi/ℓ (screening level), the Agency may reduce the frequency of monitoring at that sampling point to once every three years. A supplier must collect all samples required in subsection (a) of this Section during the reduced monitoring period.

- 2) For a supplier in the vicinity of a nuclear facility, the Agency may allow the CWS supplier to utilize environmental surveillance data collected by the nuclear facility in lieu of monitoring at the supplier's entry points, where the Agency determines if such data is applicable to a particular water system, by a SEP issued pursuant to Section 611.110. In the event that there is a release from a nuclear facility, a supplier that is using surveillance data must begin monitoring at the community water supplier's entry points in accordance with subsection (b)(1) of this Section.

- b) Effective December 8, 2003, a CWS supplier (either a surface water or groundwater supplier) designated by the Agency, by a SEP issued pursuant to Section 611.110, as utilizing waters contaminated by effluents from nuclear facilities must sample for beta particle and photon radioactivity. A supplier must collect quarterly samples for beta emitters and iodine-131 and annual samples for tritium and strontium-90 at each entry point to the distribution system (hereafter called a sampling point), beginning within one quarter after being notified by the Agency. A supplier already designated by the Agency as a supplier using waters contaminated by effluents from nuclear facilities must continue to sample until the Agency reviews and either reaffirms or removes the designation, by a SEP issued pursuant to Section 611.110.

- 1) Quarterly monitoring for gross beta particle activity must be based on the analysis of monthly samples or the analysis of a composite of three monthly samples.

BOARD NOTE: In corresponding 40 CFR 141.26(b)(2)(i), USEPA recommends the use of a composite of three monthly samples.

- 2) For iodine-131, a composite of five consecutive daily samples must be analyzed once each quarter. The Agency may, by a SEP issued pursuant to Section 611.110, order more frequent monitoring for iodine-131 where it is identified in the finished water.
- 3) Annual monitoring for strontium-90 and tritium must be conducted by means of the analysis of a composite of four consecutive quarterly samples or analysis of four quarterly samples.

BOARD NOTE: In corresponding 40 CFR 141.26(b)(2)(iii), USEPA recommends the analysis of four consecutive quarterly samples.

- 4) If the gross beta particle activity minus the naturally occurring potassium-40 beta particle activity at a sampling point has a running annual average (computed quarterly) less than or equal to 15 pCi/ℓ, the Agency may, by a SEP issued pursuant to Section 611.110, reduce the frequency of monitoring at that sampling point to once every three years. The supplier must collect all samples required in subsection (b) of this Section during the reduced monitoring period.
 - 5) For a supplier in the vicinity of a nuclear facility, the Agency may allow the CWS to utilize environmental surveillance data collected by the nuclear facility in lieu of monitoring at the system's entry points, where the Agency determines, by a SEP issued pursuant to Section 611.110, that such data is applicable to the particular water system. In the event that there is a release from a nuclear facility, a supplier that uses such surveillance data must begin monitoring at the CWS's entry points in accordance with subsection (b) of this Section.
- c) Effective December 8, 2003, a CWS supplier designated by the Agency to monitor for beta particle and photon radioactivity can not apply to the Agency for a waiver from the monitoring frequencies specified in subsection (a) or (b) of this Section.
 - d) Effective December 8, 2003, a CWS supplier may analyze for naturally occurring potassium-40 beta particle activity from the same or equivalent sample used for the gross beta particle activity analysis. A supplier is allowed to subtract the potassium-40 beta particle activity value from the total gross beta particle activity value to determine if the screening level is exceeded. The potassium-40 beta particle activity must be calculated by multiplying elemental potassium concentrations (in mg/ℓ) by a factor of 0.82.
 - e) Effective December 8, 2003, if the gross beta particle activity minus the naturally occurring potassium-40 beta particle activity exceeds the screening level, an analysis of the sample must be performed to identify the major radioactive constituents present in the sample and the appropriate doses must be calculated and summed to determine compliance with Section 611.330(d)(1), using the formula in Section 611.330(d)(2). Doses must also be calculated and combined for measured levels of tritium and strontium to determine compliance.
 - f) Effective December 8, 2003, a supplier must monitor monthly at the sampling points that exceeds the maximum contaminant level in Section 611.330(d) beginning the month after the exceedence occurs. A supplier must continue monthly monitoring until the supplier has established, by a rolling average of three monthly samples, that the MCL is being met. A supplier that establishes that the MCL is being met must return to quarterly monitoring until it meets the requirements set forth in subsection (a)(2) or (b)(1) of this Section.

- g) Until December 8, 2003, CWSs using surface water sources and serving more than 100,000 persons and such other CWSs as the Agency, by a SEP issued pursuant to Section 611.110, requires must monitor for compliance with Section 611.331 by analysis of a composite of four consecutive quarterly samples or analysis of four quarterly samples. Compliance with Section 611.331 is assumed without further analysis if the average annual concentration of gross beta particle activity is less than 50 pCi/ℓ and if the average annual concentrations of tritium and strontium-90 are less than those listed in Section 611.331, provided that if both radionuclides are present the sum of their annual dose equivalents to bone marrow must not exceed 4 millirem/year.
- 1) If the gross beta particle activity exceeds 50 pCi/ℓ, an analysis of the sample must be performed to identify the major radioactive constituents present and the appropriate organ and total body doses must be calculated to determine compliance with Section 611.331.
 - 2) If the MCLs are exceeded, the Agency shall, by a SEP issued pursuant to Section 611.110, require the supplier to conduct additional monitoring to determine the concentration of man-made radioactivity in principal watersheds.
 - 3) The Agency shall, pursuant to subsection (j) of this Section, by a SEP issued pursuant to Section 611.110, require suppliers of water utilizing only groundwater to monitor for man-made radioactivity.
- ~~h) — See Section 611.100(e).~~
- ih) Until December 8, 2003, CWS suppliers must monitor at least every four years following the procedure in subsection (g) of this Section.
- ji) Until December 8, 2003, the Agency must, by a SEP issued pursuant to Section 611.110, require any CWS supplier utilizing waters contaminated by effluents from nuclear facilities to initiate quarterly monitoring for gross beta particle and iodine-131 radioactivity and annual monitoring for strontium-90 and tritium.
- 1) Quarterly monitoring for gross beta particle activity must be based on the analysis of monthly samples or the analysis of a composite of three monthly samples. If the gross beta particle activity in a sample exceeds 15 pCi/ℓ, the same or an equivalent sample must be analyzed for strontium-89 and cesium-134. If the gross beta particle activity exceeds 50 pCi/ℓ, an analysis of the sample must be performed to identify the major radioactive constituents present and the appropriate organ and total body doses must be calculated to determine compliance with Section 611.331.
 - 2) For iodine-131, a composite of five consecutive daily samples must be

analyzed once each quarter. The Agency shall, by a SEP issued pursuant to Section 611.110, require more frequent monitoring when iodine-131 is identified in the finished water.

- 3) The Agency shall, by a SEP issued pursuant to Section 611.110, require annual monitoring for strontium-90 and tritium by means of the analysis of a composite of four consecutive quarterly samples or analysis of four quarterly samples.
 - 4) The Agency shall, by a SEP issued pursuant to Section 611.110, allow the substitution of environmental surveillance data taken in conjunction with a nuclear facility for direct monitoring of manmade radioactivity by the supplier where the Agency determines such data is applicable to the CWS.
- Ⓚj) Until December 8, 2003, if the average annual MCL for man-made radioactivity set forth in Section 611.331 is exceeded, the CWS supplier must give notice to the Agency and to the public as required by Subpart T. Monitoring at monthly intervals must be continued until the concentration no longer exceeds the MCL or until a monitoring schedule as a condition to a variance, adjusted standard, or enforcement action becomes effective.

BOARD NOTE: Subsections (a) through (f) derive from 40 CFR 141.26(b)-(2002) (2003).
~~Subsections (g) through (k) derive from 40 CFR 141.26(b), as effective until December 8, 2003.~~

(Source: Amended at 28 Ill. Reg. _____, effective _____)

SUBPART R: ENHANCED FILTRATION AND DISINFECTION: SYSTEMS THAT SERVE 10,000 OR MORE PEOPLE

Section 611.742 Disinfection Profiling and Benchmarking

- a) Determination of a supplier required to profile. A PWS supplier subject to the requirements of this Subpart R must determine its TTHM annual average using the procedure in subsection (a)(1) of this Section and its HAA5 annual average using the procedure in subsection (a)(2) of this Section. The annual average is the arithmetic average of the quarterly averages of four consecutive quarters of monitoring.
 - 1) The TTHM annual average that is used must be the annual average during the same period as the HAA5 annual average.
 - A) A supplier that collected data under the provisions of 40 CFR 141 Subpart M (Information Collection Rule) must use the results of the samples collected during the last four quarters of required monitoring under former 40 CFR 141.42 (1995).

- B) A supplier that uses “grandfathered” HAA5 occurrence data that meet the provisions of subsection (a)(2)(B) of this Section must use TTHM data collected at the same time under the provisions of Section 611.680.
 - C) A supplier that uses HAA5 occurrence data that meet the provisions of subsection (a)(2)(C)(i) of this Section must use TTHM data collected at the same time under the provisions of Sections 611.310 and 611.680.
- 2) The HAA5 annual average that is used must be the annual average during the same period as the TTHM annual average.
- A) A supplier that collected data under the provisions of 40 CFR 141 Subpart M (Information Collection Rule) must use the results of the samples collected during the last four quarters of required monitoring under former 40 CFR 141.42 (1995).
 - B) A supplier that has collected four quarters of HAA5 occurrence data that meets the routine monitoring sample number and location requirements for TTHM in Section 611.680 and handling and analytical method requirements of Section 611.685 may use that data to determine whether the requirements of this Section apply.
 - C) A supplier that ~~has had~~ not collected four quarters of HAA5 occurrence data that meets the provisions of either subsection (a)(2)(A) or (a)(2)(B) of this Section by March 31, 1999 must do either of the following:
 - i) Conduct monitoring for HAA5 that meets the routine monitoring sample number and location requirements for TTHM in Section 611.680 and handling and analytical method requirements of Section 611.685 to determine the HAA5 annual average and whether the requirements of subsection (b) of this Section apply; or
 - ii) Comply with all other provisions of this Section as if the HAA5 monitoring had been conducted and the results required compliance with subsection (b) of this Section.
- 3) The supplier may request that the Agency approve a more representative annual data set than the data set determined under subsection (a)(1) or (a)(2) of this Section for the purpose of determining applicability of the requirements of this Section.
- 4) The Agency may require that a supplier use a more representative annual

data set than the data set determined under subsection (a)(1) or (a)(2) of this Section for the purpose of determining the applicability of the requirements of this Section.

- 5) The supplier must submit data to the Agency on the schedule in subsections (a)(5)(A) through (a)(5)(E) of this Section.
 - A) A supplier that collected TTHM and HAA5 data under the provisions of 40 CFR Subpart M (Information Collection Rule), as required by subsections (a)(1)(A) and (a)(2)(A) of this Section, must have submitted the results of the samples collected during the last 12 months of required monitoring under Section 611.685 not later than December 31, 1999.
 - B) A supplier that had collected four consecutive quarters of HAA5 occurrence data that meets the routine monitoring sample number and location for TTHM in former 40 CFR 141.42 (1994), and handling and analytical method requirements of Section 611.685, as allowed by subsections (a)(1)(B) and (a)(2)(B) of this Section, must have submitted that data to the Agency not later than April 30, 1999. Until the Agency has approved the data, the supplier must conduct monitoring for HAA5 using the monitoring requirements specified under subsection (a)(2)(C) of this Section.
 - C) A supplier that conducted monitoring for HAA5 using the monitoring requirements specified by subsections (a)(1)(C) and (a)(2)(C)(i) of this Section must have submitted TTHM and HAA5 data not later than March 31, 2000.
 - D) A supplier that elected to comply with all other provisions of this Section as if the HAA5 monitoring had been conducted and the results required compliance with this Section, as allowed under subsection (a)(2)(C)(ii) of this Section, must have notified the Agency in writing of its election not later than December 31, 1999.
 - E) If the supplier elected to request that the Agency approve a more representative data set than the data set determined under subsection (a)(2)(A) of this Section, the supplier must have submitted this request in writing not later than December 31, 1999.
- 6) Any supplier having either a TTHM annual average \geq (greater than or equal to) 0.064 mg/l or an HAA5 annual average \geq 0.048 mg/l during the period identified in subsections (a)(1) and (a)(2) of this Section must comply with subsection (b) of this Section.

- b) Disinfection profiling.

- 1) Any supplier that meets the standards in subsection (a)(6) of this Section must develop a disinfection profile of its disinfection practice for a period of up to three years. The Agency must determine the period of the disinfection profile, with a minimum period of one year.
- 2) The supplier must monitor daily for a period of 12 consecutive calendar months to determine the total logs of inactivation for each day of operation, based on the $CT_{99,9}$ values in Appendix B of this Part, as appropriate, through the entire treatment plant. The supplier must have begun this monitoring not later than April 1, 2000. As a minimum, the supplier with a single point of disinfectant application prior to entrance to the distribution system must conduct the monitoring in subsections (b)(2)(A) through (b)(2)(D) of this Section. A supplier with more than one point of disinfectant application must conduct the monitoring in subsections (b)(2)(A) through (b)(2)(D) of this Section for each disinfection segment. The supplier must monitor the parameters necessary to determine the total inactivation ratio, using analytical methods in Section 611.531, as follows:
 - A) The temperature of the disinfected water must be measured once per day at each residual disinfectant concentration sampling point during peak hourly flow.
 - B) If the supplier uses chlorine, the pH of the disinfected water must be measured once per day at each chlorine residual disinfectant concentration sampling point during peak hourly flow.
 - C) The disinfectant contact times (“T”) must be determined for each day during peak hourly flow.
 - D) The residual disinfectant concentrations (“C”) of the water before or at the first customer and prior to each additional point of disinfection must be measured each day during peak hourly flow.
- 3) In lieu of the monitoring conducted under the provisions of subsection (b)(2) of this Section to develop the disinfection profile, the supplier may elect to meet the requirements of subsection (b)(3)(A) of this Section. In addition to the monitoring conducted under the provisions of subsection (b)(2) of this Section to develop the disinfection profile, the supplier may elect to meet the requirements of subsection (b)(3)(B) of this Section.
 - A) A PWS supplier that had three years of existing operational data may have submitted that data, a profile generated using that data, and a request that the Agency approve use of that data in lieu of monitoring under the provisions of subsection (b)(2) of this

Section not later than March 31, 2000. The Agency must determine whether the operational data is substantially equivalent to data collected under the provisions of subsection (b)(2) of this Section. The data must also be representative of *Giardia lamblia* inactivation through the entire treatment plant and not just of certain treatment segments. If the Agency determines that the operational data is substantially equivalent, the Agency must approve the request. Until the Agency approves this request, the system is required to conduct monitoring under the provisions of subsection (b)(2) of this Section.

B) In addition to the disinfection profile generated under subsection (b)(2) of this Section, a PWS supplier that has existing operational data may use that data to develop a disinfection profile for additional years. The Agency must determine whether the operational data is substantially equivalent to data collected under the provisions of subsection (b)(2) of this Section. The data must also be representative of inactivation through the entire treatment plant and not just of certain treatment segments. If the Agency determines that the operational data is substantially equivalent, such systems may use these additional yearly disinfection profiles to develop a benchmark under the provisions of subsection (c) of this Section.

4) The supplier must calculate the total inactivation ratio as follows:

A) If the supplier uses only one point of disinfectant application, the system may determine the total inactivation ratio for the disinfection segment based on either of the methods in subsection (b)(4)(A)(i) or (b)(4)(A)(ii) of this Section.

i) Determine one inactivation ratio ($CT_{\text{calc}}/CT_{99.9}$) before or at the first customer during peak hourly flow.

ii) Determine successive $CT_{\text{calc}}/CT_{99.9}$ values, representing sequential inactivation ratios, between the point of disinfectant application and a point before or at the first customer during peak hourly flow. Under this alternative, the supplier must calculate the total inactivation ratio ($\Sigma(CT_{\text{calc}}/CT_{99.9})$) by determining $CT_{\text{calc}}/CT_{99.9}$ for each sequence and then adding the $CT_{\text{calc}}/CT_{99.9}$ values together to determine $\Sigma(CT_{\text{calc}}/CT_{99.9})$.

B) If the supplier uses more than one point of disinfectant application before the first customer, the system must determine the CT value of each disinfection segment immediately prior to the next point of

disinfectant application, or for the final segment, before or at the first customer, during peak hourly flow. The $(CT_{\text{calc}}/CT_{99.9})$ value of each segment and $(\Sigma(CT_{\text{calc}}/CT_{99.9}))$ must be calculated using the method in subsection (b)(4)(A) of this Section.

- C) The supplier must determine the total logs of inactivation by multiplying the value calculated in subsection (b)(4)(A) or (b)(4)(B) of this Section by 3.0.
- 5) A supplier that uses either chloramines or ozone for primary disinfection must also calculate the logs of inactivation for viruses using a method approved by the Agency.
 - 6) The supplier must retain disinfection profile data in graphic form, as a spreadsheet, or in some other format acceptable to the Agency for review as part of sanitary surveys conducted by the Agency.
- c) Disinfection benchmarking.
- 1) Any supplier required to develop a disinfection profile under the provisions of subsections (a) and (b) of this Section and that decides to make a significant change to its disinfection practice must consult with the Agency prior to making such change. Significant changes to disinfection practice are the following:
 - A) Changes to the point of disinfection;
 - B) Changes to the disinfectants used in the treatment plant;
 - C) Changes to the disinfection process; and
 - D) Any other modification identified by the Agency.
 - 2) Any supplier that is modifying its disinfection practice must calculate its disinfection benchmark using the procedure specified in subsections (c)(2)(A) and (c)(2)(B) of this Section.
 - A) For each year of profiling data collected and calculated under subsection (b) of this Section, the supplier must determine the lowest average monthly *Giardia lamblia* inactivation in each year of profiling data. The supplier must determine the average *Giardia lamblia* inactivation for each calendar month for each year of profiling data by dividing the sum of daily *Giardia lamblia* of inactivation by the number of values calculated for that month.
 - B) The disinfection benchmark is the lowest monthly average value

(for systems with one year of profiling data) or average of lowest monthly average values (for systems with more than one year of profiling data) of the monthly logs of Giardia lamblia inactivation in each year of profiling data.

- 3) A supplier that uses either chloramines or ozone for primary disinfection must also calculate the disinfection benchmark for viruses using a method approved by the Agency.
- 4) The supplier must submit information in subsections (c)(4)(A) through (c)(4)(C) of this Section to the Agency as part of its consultation process.
 - A) A description of the proposed change;
 - B) The disinfection profile for Giardia lamblia (and, if necessary, viruses) under subsection (b) of this Section and benchmark as required by subsection (c)(2) of this Section; and
 - C) An analysis of how the proposed change will affect the current levels of disinfection.

BOARD NOTE: Derived from 40 CFR 141.172-~~(2002)~~ (2003).

(Source: Amended at 28 Ill. Reg. _____, effective _____)

SUBPART U: CONSUMER CONFIDENCE REPORTS

Section 611.882 Compliance Dates

- a) Each existing CWS must have delivered its first report by October 19, 1999, its second report by July 1, 2000, and it must deliver subsequent reports by July 1 annually thereafter. The first report must have contained data collected during or prior to calendar year 1998, as prescribed in Section 611.883(d)(3). Each report thereafter must contain data collected during, or prior to, the previous calendar year.
- b) A new CWS must deliver its first report by July 1 of the year after its first full calendar year in operation and annually thereafter.
- c) A community water system that sells water to another community water system must deliver the applicable information required in Section 611.883 to the buyer system as follows:
 - 1) ~~No~~ By no later than ~~April 1, 2000, and by~~ April 1 annually ~~thereafter~~; or
 - 2) On a date mutually agreed upon by the seller and the purchaser, and specifically included in a contract between the parties.

BOARD NOTE: Derived from 40 CFR 141.152-~~(2002)~~ (2003).

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.883 Content of the Reports

- a) Each CWS must provide to its customers an annual report that contains the information specified in this Section and Section 611.884.
- b) Information on the source of the water delivered.
 - 1) Each report must identify the sources of the water delivered by the CWS by providing information on the following:
 - A) The type of the water (e.g., surface water, groundwater); and
 - B) The commonly used name (if any) and location of the body (or bodies) of water.
 - 2) If a source water assessment has been completed, the report must notify consumers of the availability of this information and the means to obtain it. In addition, systems are encouraged to highlight in the report significant sources of contamination in the source water area if they have readily available information. Where a system has received a source water assessment from the Agency, the report must include a brief summary of the system's susceptibility to potential sources of contamination, using language provided by the Agency or written by the supplier.
- c) Definitions.
 - 1) Each report must include the following definitions:
 - A) **Maximum Contaminant Level Goal or MCLG:** The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

BOARD NOTE: Although an MCLG is not an NPDWR that the Board must include in the Illinois SDWA regulations, the use of this definition is mandatory where the term "MCLG" is defined.
 - B) **Maximum Contaminant Level or MCL:** The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

- 2) A report for a CWS operating under relief from an NPDWR issued under Sections 611.111, 611.112, 611.130, or 611.131 must include the following definition: “Variances, Adjusted Standards, and Site-specific Rules: State permission not to meet an MCL or a treatment technique under certain conditions.”
- 3) A report that contains data on contaminants that USEPA regulates using any of the following terms must include the applicable definitions:
 - A) Treatment technique: A required process intended to reduce the level of a contaminant in drinking water.
 - B) Action level: The concentration of a contaminant that, if exceeded, triggers treatment or other requirements that a water system must follow.
 - C) Maximum residual disinfectant level goal or MRDLG: The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

BOARD NOTE: Although an MRDLG is not an NPDWR that the Board must include in the Illinois SDWA regulations, the use of this definition is mandatory where the term “MRDLG” is defined.

- D) Maximum residual disinfectant level or MRDL: The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- d) Information on detected contaminants.
- 1) This subsection (d) specifies the requirements for information to be included in each report for contaminants subject to mandatory monitoring (except *Cryptosporidium*). It applies to the following:
 - A) Contaminants subject to an MCL, action level, MRDL, or treatment technique (regulated contaminants);
 - B) Contaminants for which monitoring is required by Section 611.510 (unregulated contaminants); and
 - C) Disinfection byproducts or microbial contaminants for which monitoring is required by Section 611.382 and Subpart L of this Part, except as provided under subsection (e)(1) of this Section, and which are detected in the finished water.

- 2) The data relating to these contaminants must be displayed in one table or in several adjacent tables. Any additional monitoring results that a CWS chooses to include in its report must be displayed separately.
- 3) The data must have been derived from data collected to comply with monitoring and analytical requirements during calendar year 1998 for the first report and must be derived from the data collected in subsequent calendar years, except that the following requirements also apply:
 - A) Where a system is allowed to monitor for regulated contaminants less often than once a year, the tables must include the date and results of the most recent sampling, and the report must include a brief statement indicating that the data presented in the report is from the most recent testing done in accordance with the regulations. No data older than five years need be included.
 - B) Results of monitoring in compliance with Section 611.382 and Subpart L need only be included for five years from the date of last sample or until any of the detected contaminants becomes regulated and subject to routine monitoring requirements, whichever comes first.
- 4) For detected regulated contaminants (listed in Appendix A of this Part), the tables must contain the following:
 - A) The MCL for that contaminant expressed as a number equal to or greater than 1.0 (as provided in Appendix A of this Part);
 - B) The federal Maximum Contaminant Level Goal (MCLG) for that contaminant expressed in the same units as the MCL;
 - C) If there is no MCL for a detected contaminant, the table must indicate that there is a treatment technique, or specify the action level, applicable to that contaminant, and the report must include the definitions for treatment technique or action level, as appropriate, specified in subsection (c)(3) of this Section;
 - D) For contaminants subject to an MCL, except turbidity and total coliforms, the highest contaminant level used to determine compliance with an NPDWR, and the range of detected levels, as follows:
 - i) When compliance with the MCL is determined annually or less frequently: the highest detected level at any sampling point and the range of detected levels expressed in the same

units as the MCL.

- ii) When compliance with the MCL is determined by calculating a running annual average of all samples taken at a sampling point: the highest average of any of the sampling points and the range of all sampling points expressed in the same units as the MCL.
- iii) When compliance with the MCL is determined on a system-wide basis by calculating a running annual average of all samples at all sampling points: the average and range of detection expressed in the same units as the MCL;

BOARD NOTE to subsection (d)(4)(D): When rounding of results to determine compliance with the MCL is allowed by the regulations, rounding should be done prior to multiplying the results by the factor listed in Appendix A of this Part; derived from 40 CFR 153-(2002)-(2003).

- E) For turbidity the following:
 - i) When it is reported pursuant to Section 611.560: the highest average monthly value.
 - ii) When it is reported pursuant to the requirements of Section 611.211(b): the highest monthly value. The report must include an explanation of the reasons for measuring turbidity.
 - iii) When it is reported pursuant to Section 611.250, 611.743, or 611.955(b): the highest single measurement and the lowest monthly percentage of samples meeting the turbidity limits specified in Section 611.250, 611.743, or 611.955(b) for the filtration technology being used. The report must include an explanation of the reasons for measuring turbidity;
- F) For lead and copper the following: the 90th percentile value of the most recent round of sampling and the number of sampling sites exceeding the action level;
- G) For total coliform the following:
 - i) The highest monthly number of positive samples for systems collecting fewer than 40 samples per month; or
 - ii) The highest monthly percentage of positive samples for

systems collecting at least 40 samples per month;

- H) For fecal coliform the following: the total number of positive samples; and
 - I) The likely sources of detected contaminants to the best of the supplier's knowledge. Specific information regarding contaminants may be available in sanitary surveys and source water assessments, and must be used when available to the supplier. If the supplier lacks specific information on the likely source, the report must include one or more of the typical sources for that contaminant listed in Appendix G of this Part that are most applicable to the CWS.
- 5) If a CWS distributes water to its customers from multiple hydraulically independent distribution systems that are fed by different raw water sources, the table must contain a separate column for each service area and the report must identify each separate distribution system. Alternatively, a CWS may produce separate reports tailored to include data for each service area.
- 6) The tables must clearly identify any data indicating violations of MCLs, MRDLs, or treatment techniques, and the report must contain a clear and readily understandable explanation of the violation including the following: the length of the violation, the potential adverse health effects, and actions taken by the CWS to address the violation. To describe the potential health effects, the CWS must use the relevant language of Appendix A of this Part.
- 7) For detected unregulated contaminants for which monitoring is required (except *Cryptosporidium*), the tables must contain the average and range at which the contaminant was detected. The report may include a brief explanation of the reasons for monitoring for unregulated contaminants.
- e) Information on *Cryptosporidium*, radon, and other contaminants as follows:
- 1) If the CWS has performed any monitoring for *Cryptosporidium*, including monitoring performed to satisfy the requirements of Subpart L of this Part, that indicates that *Cryptosporidium* may be present in the source water or the finished water, the report must include the following:
 - A) A summary of the results of the monitoring; and
 - B) An explanation of the significance of the results.
 - 2) If the CWS has performed any monitoring for radon that indicates that radon may be present in the finished water, the report must include the following:
 - A) The results of the monitoring; and

- B) An explanation of the significance of the results.
- 3) If the CWS has performed additional monitoring that indicates the presence of other contaminants in the finished water, the report must include the following:
- A) The results of the monitoring; and
 - B) An explanation of the significance of the results noting the existence of any health advisory or proposed regulation.
- f) Compliance with an NPDWR. In addition to the requirements of subsection (d)(6) of this Section, the report must note any violation that occurred during the year covered by the report of a requirement listed below, and include a clear and readily understandable explanation of the violation, any potential adverse health effects, and the steps the CWS has taken to correct the violation.
- 1) Monitoring and reporting of compliance data.
 - 2) Filtration and disinfection prescribed by Subpart B of this Part. For CWSs that have failed to install adequate filtration or disinfection equipment or processes, or have had a failure of such equipment or processes that constitutes a violation, the report must include the following language as part of the explanation of potential adverse health effects: Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.
 - 3) Lead and copper control requirements prescribed by Subpart G of this Part. For systems that fail to take one or more actions prescribed by ~~Sections~~ Section 611.350(d), 611.351, 611.352, 611.353, or 611.354, the report must include the applicable language of Appendix A of this Part for lead, copper, or both.
 - 4) Treatment techniques for acrylamide and epichlorohydrin prescribed by Section 611.296. For systems that violate the requirements of Section 611.296, the report must include the relevant language from Appendix A of this Part.
 - 5) Recordkeeping of compliance data.
 - 6) Special monitoring requirements prescribed by Sections 611.510 and 611.630.
 - 7) Violation of the terms of a variance, adjusted standard, site-specific rule, or

administrative or judicial order.

- g) Variances, adjusted standards, and site-specific rules. If a system is operating under the terms of a variance, adjusted standard, or site-specific rule issued under Section 611.111, 611.112, or 611.131, the report must contain the following:
- 1) An explanation of the reasons for the variance, adjusted standard, or site-specific rule;
 - 2) The date on which the variance, adjusted standard, or site-specific rule was issued;
 - 3) A brief status report on the steps the CWS is taking to install treatment, find alternative sources of water, or otherwise comply with the terms and schedules of the variance, adjusted standard, or site-specific rule; and
 - 4) A notice of any opportunity for public input in the review, or renewal, of the variance, adjusted standard, or site-specific rule.
- h) Additional information.
- 1) The report must contain a brief explanation regarding contaminants that may reasonably be expected to be found in drinking water, including bottled water. This explanation may include the language of subsections (h)(1)(A) through (h)(1)(C) of this Section or CWSs may use their own comparable language. The report also must include the language of subsection (h)(1)(D) of this Section.
 - A) The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.
 - B) Contaminants that may be present in source water include the following:
 - i) Microbial contaminants, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife;
 - ii) Inorganic contaminants, such as salts and metals, which can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming;

- iii) Pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses;
 - iv) Organic chemical contaminants, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and
 - v) Radioactive contaminants, which can be naturally-occurring or be the result of oil and gas production and mining activities.
- C) In order to ensure that tap water is safe to drink, USEPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. United States Food and Drug Administration (USFDA) regulations establish limits for contaminants in bottled water that must provide the same protection for public health.
- D) Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA Safe Drinking Water Hotline (800-426-4791).
- 2) The report must include the telephone number of the owner, operator, or designee of the CWS as a source of additional information concerning the report.
 - 3) In communities with a large proportion of non-English speaking residents, as determined by the Agency, the report must contain information in the appropriate languages regarding the importance of the report or contain a telephone number or address where such residents may contact the system to obtain a translated copy of the report or assistance in the appropriate language.
 - 4) The report must include information about opportunities for public participation in decisions that may affect the quality of the water.
 - 5) The CWS may include such additional information as it deems necessary for public education consistent with, and not detracting from, the purpose of the report.

BOARD NOTE: Derived from 40 CFR 141.153-(2002) (2003).

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.884 Required Additional Health Information

- a) All reports must prominently display the following language: “Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA or Centers for Disease Control and Prevention guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the USEPA Safe Drinking Water Hotline (800-426-4791).”
- b) A supplier that detects arsenic above 0.005 mg/ℓ and up to and including ~~0.01~~ 0.010 mg/ℓ must do the following:
 - 1) The supplier must include in its report a short informational statement about arsenic, using the following language: “While your drinking water meets USEPA’s standard for arsenic, it does contain low levels of arsenic. USEPA’s standard balances the current understanding of arsenic’s possible health effects against the costs of removing arsenic from drinking water. USEPA continues to research the health effects of low levels of arsenic, which is a naturally-occurring mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.”; or
 - 2) The supplier may write its own educational statement, but only in consultation with the Agency.
- c) A supplier that detects nitrate at levels above 5 mg/ℓ, but below the MCL, must do the following:
 - 1) The supplier must include a short informational statement about the impacts of nitrate on children, using the following language: “Nitrate in drinking water at levels above 10 ppm is a health risk for infants of less than six months of age. High nitrate levels in drinking water can cause blue baby syndrome. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity. If you are caring for an infant you should ask advice from your health care provider”; or
 - 2) The CWS supplier may write its own educational statement, but only in

consultation with the Agency.

- d) A CWS supplier that detects lead above the action level in more than five percent, and up to and including ten percent, of homes sampled must do the following:
- 1) The CWS supplier must include a short informational statement about the special impact of lead on children, using the following language: “Infants and young children are typically more vulnerable to lead in drinking water than the general population. It is possible that lead levels at your home may be higher than at other homes in the community as a result of materials used in your home’s plumbing. If you are concerned about elevated lead levels in your home’s water, you may wish to have your water tested and flush your tap for 30 seconds to two minutes before using tap water. Additional information is available from the USEPA Safe Drinking Water Hotline (800-426-4791)”; or
 - 2) The CWS supplier may write its own educational statement, but only in consultation with the Agency.
- e) A CWS supplier that detects TTHM above 0.080 mg/ℓ, but below the MCL in Section 611.312, as an annual average, monitored and calculated under the provisions of former Section 611.680, must include the health effects language prescribed by Appendix A of this Part.
- f) Until January 22, 2006, a CWS supplier that detects arsenic above ~~0.01~~0.010 mg/ℓ and up to and including 0.05 mg/ℓ must include the arsenic health effects language prescribed by Appendix A to this Part.

BOARD NOTE: Derived from 40 CFR 141.154-(2002)(2003).

(Source: Amended at 28 Ill. Reg. _____, effective _____)

**SUBPART X: ENHANCED FILTRATION AND DISINFECTION--SYSTEMS
SERVING FEWER THAN 10,000 PEOPLE**

Section 611.954 Disinfection Benchmark

- a) **Applicability.** A Subpart B system supplier that is required to develop a disinfection profile under Section 611.953 must develop a disinfection benchmark if it decides to make a significant change to its disinfection practice. The supplier must consult with the Agency for approval before it can implement a significant disinfection practice change.
- b) **Significant changes to disinfection practice.** Significant changes to disinfection practice include the following:

- 1) Changes to the point of disinfection;
 - 2) Changes to the disinfectants used in the treatment plant;
 - 3) Changes to the disinfection process; or
 - 4) Any other modification identified by the Agency.
- c) Considering a significant change. A supplier that is considering a significant change to its disinfection practice must calculate disinfection benchmark, as described in subsections (d) and (e) of this Section, and provide the benchmarks to the Agency. A supplier may only make a significant disinfection practice change after consulting with the Agency for approval. A supplier must submit the following information to the Agency as part of the consultation and approval process:
- 1) A description of the proposed change;
 - 2) The disinfection profile for *Giardia lamblia* (and, if necessary, viruses) and disinfection benchmark;
 - 3) An analysis of how the proposed change will affect the current levels of disinfection; and
 - 4) Any additional information requested by the Agency.
- d) Calculation of a disinfection benchmark. A supplier that is making a significant change to its disinfection practice must calculate a disinfection benchmark using the following procedure:
- 1) Step 1: Using the data that the supplier collected to develop the disinfection profile, determine the average *Giardia lamblia* inactivation for each calendar month by dividing the sum of all *Giardia lamblia* inactivations for that month by the number of values calculated for that month; and
 - 2) Step 2: Determine the lowest monthly average value out of the 12 values. This value becomes the disinfection benchmark.
- e) If a supplier uses chloramines, ozone or chlorine dioxide for primary disinfection the supplier must calculate the disinfection benchmark from the data that the supplier collected for viruses to develop the disinfection profile in subsection (d) of this Section. This viral benchmark must be calculated in the same manner used to calculate the *Giardia lamblia* disinfection benchmark in subsection (d) of this Section.

BOARD NOTE: Derived from 40 CFR 141.540 through 141.544 ~~(2002)~~ (2003).

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.Appendix A Regulated Contaminants

Microbiological contaminants.

Contaminant (units): Total Coliform Bacteria

Traditional MCL in mg/ℓ: MCL: (a supplier that collects 40 or more samples/month) five percent or fewer of monthly samples are positive; (systems that collect fewer than 40 samples/month) one or fewer positive monthly samples.

To convert for CCR, multiply by: --

MCL in CCR units: MCL: (a supplier that collects 40 or more samples/month) five percent or fewer of monthly samples are positive; (a supplier that collects fewer than 40 samples/month) one or fewer positive monthly ~~sample~~ samples.

MCLG: 0

Major sources in drinking water: Naturally present in the environment.

Health effects language: Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.

Contaminant (units): Fecal coliform and E. coli

Traditional MCL in mg/ℓ: 0

To convert for CCR, multiply by: --

MCL in CCR units: 0

MCLG: 0

Major sources in drinking water: Human and animal fecal waste.

Health effects language: Fecal coliforms and E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes.

Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely-compromised immune systems.

Contaminant (units): Total organic carbon (ppm)

Traditional MCL in mg/ℓ: TT

To convert for CCR, multiply by: --

MCL in CCR units: TT

MCLG: N/A

Major sources in drinking water: Naturally present in the environment.

Health effects language: Total organic carbon (TOC) has no health effects. However, total organic carbon provides a medium for the formation of disinfection byproducts. These byproducts include trihalomethanes (THMs) and haloacetic acids (HAAs). Drinking water containing these byproducts in excess of the MCL

may lead to adverse health effects, liver or kidney problems, or nervous system effects, and may lead to an increased risk of getting cancer.

Contaminant (units): Turbidity (NTU)

Traditional MCL in mg/ℓ: TT

To convert for CCR, multiply by: --

MCL in CCR units: TT

MCLG: N/A

Major sources in drinking water: Soil runoff.

Health effects language: Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

Radioactive contaminants.

Contaminant (units): Beta/photon emitters (mrem/yr)

Traditional MCL in mg/ℓ: 4 mrem/yr

To convert for CCR, multiply by: --

MCL in CCR units: 4

MCLG: 0

Major sources in drinking water: Decay of natural and man-made deposits.

Health effects language: Certain minerals are radioactive and may emit forms of radiation known as photons and beta radiation. Some people who drink water containing beta particle and photon radioactivity in excess of the MCL over many years may have an increased risk of getting cancer.

Contaminant (units): Alpha emitters (pCi/ℓ)

Traditional MCL in mg/ℓ: 15 pCi/ℓ

To convert for CCR, multiply by: --

MCL in CCR units: 15

MCLG: 0

Major sources in drinking water: Erosion of natural deposits.

Health effects language: Certain minerals are radioactive and may emit a form of radiation known as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer.

Contaminant (units): Combined radium (pCi/ℓ)

Traditional MCL in mg/ℓ: 5 pCi/ℓ

To convert for CCR, multiply by: --

MCL in CCR units: 5

MCLG: 0

Major sources in drinking water: Erosion of natural deposits.

Health effects language: Some people who drink water containing radium-226 or -228 in

excess of the MCL over many years may have an increased risk of getting cancer.

Contaminant (units): Uranium ($\mu\text{g}/\ell$)

Traditional MCL in mg/ℓ : $30 \mu\text{g}/\ell$

To convert for CCR, multiply by: --

MCL in CCR units: 30

MCLG: 0

Major sources in drinking water: Erosion of natural deposits.

Health effects language: Some people who drink water containing uranium in excess of the MCL over many years may have an increased risk of getting cancer and kidney toxicity.

Inorganic contaminants.

Contaminant (units): Antimony (ppb)

Traditional MCL in mg/ℓ : 0.006

To convert for CCR, multiply by: 1000

MCL in CCR units: 6

MCLG: 6

Major sources in drinking water: Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder.

Health effects language: Some people who drink water containing antimony well in excess of the MCL over many years could experience increases in blood cholesterol and decreases in blood sugar.

Contaminant (units): Arsenic (ppb)

Traditional MCL in mg/ℓ : 0.05 until January 23, 2006 or ~~0.01~~0.010 effective January 23, 2006

To convert for CCR, multiply by: 1000

MCL in CCR units: 50

MCLG: 0 (effective January 26, 2006)

Major sources in drinking water: Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes.

Health effects language: Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

Contaminant (units): Asbestos (MFL)

Traditional MCL in mg/ℓ : 7 MFL

To convert for CCR, multiply by: --

MCL in CCR units: 7

MCLG: 7

Major sources in drinking water: Decay of asbestos cement water mains; erosion of natural deposits.

Health effects language: Some people who drink water containing asbestos in excess of the MCL over many years may have an increased risk of developing benign

intestinal polyps.

Contaminant (units): Barium (ppm)

Traditional MCL in mg/l: 2

To convert for CCR, multiply by: --

MCL in CCR units: 2

MCLG: 2

Major sources in drinking water: Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits.

Health effects language: Some people who drink water containing barium in excess of the MCL over many years could experience an increase in their blood pressure.

Contaminant (units): Beryllium (ppb)

Traditional MCL in mg/l: 0.004

To convert for CCR, multiply by: 1000

MCL in CCR units: 4

MCLG: 4

Major sources in drinking water: Discharge from metal refineries and coal-burning factories; discharge from electrical, aerospace, and defense industries.

Health effects language: Some people who drink water containing beryllium well in excess of the MCL over many years could develop intestinal lesions.

Contaminant (units): Bromate (ppb)

Traditional MCL in mg/l: 0.010

To convert for CCR, multiply by: 1000

MCL in CCR units: 10

MCLG: 0

Major sources in drinking water: By-product of drinking water disinfection.

Health effects language: Some people who drink water containing bromate in excess of the MCL over many years may have an increased risk of getting cancer.

Contaminant (units): Cadmium (ppb)

Traditional MCL in mg/l: 0.005

To convert for CCR, multiply by: 1000

MCL in CCR units: 5

MCLG: 5

Major sources in drinking water: Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints.

Health effects language: Some people who drink water containing cadmium in excess of the MCL over many years could experience kidney damage.

Contaminant (units): Chloramines (ppm)

Traditional MCL in mg/l: MRDL=4

To convert for CCR, multiply by: --

MCL in CCR units: MRDL=4

MCLG: MRDLG=4

Major sources in drinking water: Water additive used to control microbes.

Health effects language: Some people who drink water containing chloramines well in excess of the MRDL could experience irritating effects to their eyes and nose.

Some people who drink water containing chloramines well in excess of the MRDL could experience stomach discomfort or anemia.

Contaminant (units): Chlorine (ppm)

Traditional MCL in mg/l: MRDL=4

To convert for CCR, multiply by: --

MCL in CCR units: MRDL=4

MCLG: MRDLG=4

Major sources in drinking water: Water additive used to control microbes.

Health effects language: Some people who drink water containing chlorine well in excess of the MRDL could experience irritating effects to their eyes and nose.

Some people who drink water containing chlorine well in excess of the MRDL could experience stomach discomfort.

Contaminant (units): Chlorine dioxide (ppb)

Traditional MCL in mg/l: MRDL=800

To convert for CCR, multiply by: 1000

MCL in CCR units: MRDL=800

MCLG: MRDLG=800

Major sources in drinking water: Water additive used to control microbes.

Health effects language: Some infants and young children who drink water containing chlorine dioxide well in excess of the MRDL could experience nervous system effects. Similar effects may occur in fetuses of pregnant women who drink water containing chlorine dioxide in excess of the MRDL. Some people may experience anemia.

Contaminant (units): Chlorite (ppm)

Traditional MCL in mg/l: MRDL=1

To convert for CCR, multiply by: --

MCL in CCR units: MRDL=1

MCLG: MRDLG=0.8

Major sources in drinking water: By-product of drinking water disinfection.

Health effects language: Some infants and young children who drink water containing chlorite well in excess of the MCL could experience nervous system effects.

Similar effects may occur in fetuses of pregnant women who drink water containing chlorite in excess of the MCL. Some people may experience anemia.

Contaminant (units): Chromium (ppb)

Traditional MCL in mg/l: 0.1

To convert for CCR, multiply by: 1000

MCL in CCR units: 100

MCLG: 100

Major sources in drinking water: Discharge from steel and pulp mills; erosion of natural

deposits.

Health effects language: Some people who use water containing chromium well in excess of the MCL over many years could experience allergic dermatitis.

Contaminant (units): Copper (ppm)

Traditional MCL in mg/l: AL=1.3

To convert for CCR, multiply by: --

MCL in CCR units: AL=1.3

MCLG: 1.3

Major sources in drinking water: Corrosion of household plumbing systems; erosion of natural deposits.

Health effects language: Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.

Contaminant (units): Cyanide (ppb)

Traditional MCL in mg/l: 0.2

To convert for CCR, multiply by: 1000

MCL in CCR units: 200

MCLG: 200

Major sources in drinking water: Discharge from steel/metal factories; discharge from plastic and fertilizer factories.

Health effects language: Some people who drink water containing cyanide well in excess of the MCL over many years could experience nerve damage or problems with their thyroid.

Contaminant (units): Fluoride (ppm)

Traditional MCL in mg/l: 4

To convert for CCR, multiply by: --

MCL in CCR units: 4

MCLG: 4

Major sources in drinking water: Erosion of natural deposits; water additive that promotes strong teeth; discharge from fertilizer and aluminum factories.

Health effects language: Some people who drink water containing fluoride in excess of the MCL over many years could get bone disease, including pain and tenderness of the bones. Fluoride in drinking water at half the MCL or more may cause mottling of children's teeth, usually in children less than nine years old. Mottling, also known as dental fluorosis, may include brown staining or pitting of the teeth, and occurs only in developing teeth before they erupt from the gums.

Contaminant (units): Lead (ppb)

Traditional MCL in mg/l: AL=0.015

To convert for CCR, multiply by: 1000

MCL in CCR units: AL=15

MCLG: 0

Major sources in drinking water: Corrosion of household plumbing systems; erosion of natural deposits.

Health effects language: Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

Contaminant (units): Mercury (inorganic) (ppb)

Traditional MCL in mg/l: 0.002

To convert for CCR, multiply by: 1000

MCL in CCR units: 2

MCLG: 2

Major sources in drinking water: Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland.

Health effects language: Some people who drink water containing inorganic mercury well in excess of the MCL over many years could experience kidney damage.

Contaminant (units): Nitrate (ppm)

Traditional MCL in mg/l: 10

To convert for CCR, multiply by: --

MCL in CCR units: 10

MCLG: 10

Major sources in drinking water: Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.

Health effects language: Infants below the age of six months who drink water containing nitrate in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue baby syndrome.

Contaminant (units): Nitrite (ppm)

Traditional MCL in mg/l: 1

To convert for CCR, multiply by: --

MCL in CCR units: 1

MCLG: 1

Major sources in drinking water: Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits.

Health effects language: Infants below the age of six months who drink water containing nitrite in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue baby syndrome.

Contaminant (units): Selenium (ppb)

Traditional MCL in mg/l: 0.05

To convert for CCR, multiply by: 1000

MCL in CCR units: 50

MCLG: 50

Major sources in drinking water: Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines.

Health effects language: Selenium is an essential nutrient. However, some people who drink water containing selenium in excess of the MCL over many years could experience hair or fingernail losses, numbness in fingers or toes, or problems with their circulation.

Contaminant (units): Thallium (ppb)

Traditional MCL in mg/ℓ: 0.002

To convert for CCR, multiply by: 1000

MCL in CCR units: 2

MCLG: 0.5

Major sources in drinking water: Leaching from ore-processing sites; discharge from electronics, glass, and drug factories.

Health effects language: Some people who drink water containing thallium in excess of the MCL over many years could experience hair loss, changes in their blood, or problems with their kidneys, intestines, or liver.

Synthetic organic contaminants including pesticides and herbicides.

Contaminant (units): 2,4-D (ppb)

Traditional MCL in mg/ℓ: 0.07

To convert for CCR, multiply by: 1000

MCL in CCR units: 70

MCLG: 70

Major sources in drinking water: Runoff from herbicide used on row crops.

Health effects language: Some people who drink water containing the weed killer 2,4-D well in excess of the MCL over many years could experience problems with their kidneys, liver, or adrenal glands.

Contaminant (units): 2,4,5-TP (silvex) (ppb)

Traditional MCL in mg/ℓ: 0.05

To convert for CCR, multiply by: 1000

MCL in CCR units: 50

MCLG: 50

Major sources in drinking water: Residue of banned herbicide.

Health effects language: Some people who drink water containing silvex in excess of the MCL over many years could experience liver problems.

Contaminant (units): Acrylamide

Traditional MCL in mg/ℓ: TT

To convert for CCR, multiply by: --

MCL in CCR units: TT

MCLG: 0

Major sources in drinking water: Added to water during sewage/wastewater treatment.

Health effects language: Some people who drink water containing high levels of acrylamide over a long period of time could have problems with their nervous system or blood, and may have an increased risk of getting cancer.

Contaminant (units): Alachlor (ppb)

Traditional MCL in mg/ℓ: 0.002

To convert for CCR, multiply by: 1000

MCL in CCR units: 2

MCLG: 0

Major sources in drinking water: Runoff from herbicide used on row crops.

Health effects language: Some people who drink water containing alachlor in excess of the MCL over many years could have problems with their eyes, liver, kidneys, or spleen, or experience anemia, and may have an increased risk of getting cancer.

Contaminant (units): Atrazine (ppb)

Traditional MCL in mg/ℓ: 0.003

To convert for CCR, multiply by: 1000

MCL in CCR units: 3

MCLG: 3

Major sources in drinking water: Runoff from herbicide used on row crops.

Health effects language: Some people who drink water containing atrazine well in excess of the MCL over many years could experience problems with their cardiovascular system or reproductive difficulties.

Contaminant (units): Benzo(a)pyrene (PAH) (nanograms/ℓ)

Traditional MCL in mg/ℓ: 0.0002

To convert for CCR, multiply by: 1,000,000

MCL in CCR units: 200

MCLG: 0

Major sources in drinking water: Leaching from linings of water storage tanks and distribution lines.

Health effects language: Some people who drink water containing benzo(a)pyrene in excess of the MCL over many years may experience reproductive difficulties and may have an increased risk of getting cancer.

Contaminant (units): Carbofuran (ppb)

Traditional MCL in mg/ℓ: 0.04

To convert for CCR, multiply by: 1000

MCL in CCR units: 40

MCLG: 40

Major sources in drinking water: Leaching of soil fumigant used on rice and alfalfa.

Health effects language: Some people who drink water containing carbofuran in excess of the MCL over many years could experience problems with their blood, or nervous or reproductive systems.

Contaminant (units): Chlordane (ppb)

Traditional MCL in mg/ℓ: 0.002

To convert for CCR, multiply by: 1000

MCL in CCR units: 2

MCLG: 0

Major sources in drinking water: Residue of banned termiticide.

Health effects language: Some people who drink water containing chlordane in excess of the MCL over many years could experience problems with their liver or nervous system, and may have an increased risk of getting cancer.

Contaminant (units): Dalapon (ppb)

Traditional MCL in mg/ℓ: 0.2

To convert for CCR, multiply by: 1000

MCL in CCR units: 200

MCLG: 200

Major sources in drinking water: Runoff from herbicide used on rights of way.

Health effects language: Some people who drink water containing dalapon well in excess of the MCL over many years could experience minor kidney changes.

Contaminant (units): Di(2-ethylhexyl)adipate (ppb)

Traditional MCL in mg/ℓ: 0.4

To convert for CCR, multiply by: 1000

MCL in CCR units: 400

MCLG: 400

Major sources in drinking water: Discharge from chemical factories.

Health effects language: Some people who drink water containing di(2-ethylhexyl)adipate well in excess of the MCL over many years could experience toxic effects, such as weight loss, liver enlargement, or possible reproductive difficulties.

Contaminant (units): Di(2-ethylhexyl)phthalate (ppb)

Traditional MCL in mg/ℓ: 0.006

To convert for CCR, multiply by: 1000

MCL in CCR units: 6

MCLG: 0

Major sources in drinking water: Discharge from rubber and chemical factories.

Health effects language: Some people who drink water containing di(2-ethylhexyl)phthalate well in excess of the MCL over many years may have problems with their liver or experience reproductive difficulties, and they may have an increased risk of getting cancer.

Contaminant (units): Dibromochloropropane (DBCP) (ppt)

Traditional MCL in mg/ℓ: 0.0002

To convert for CCR, multiply by: 1,000,000

MCL in CCR units: 200

MCLG: 0

Major sources in drinking water: Runoff/leaching from soil fumigant used on soybeans,

cotton, pineapples, and orchards.

Health effects language: Some people who drink water containing DBCP in excess of the MCL over many years could experience reproductive problems and may have an increased risk of getting cancer.

Contaminant (units): Dinoseb (ppb)

Traditional MCL in mg/l: 0.007

To convert for CCR, multiply by: 1000

MCL in CCR units: 7

MCLG: 7

Major sources in drinking water: Runoff from herbicide used on soybeans and vegetables.

Health effects language: Some people who drink water containing dinoseb well in excess of the MCL over many years could experience reproductive difficulties.

Contaminant (units): Diquat (ppb)

Traditional MCL in mg/l: 0.02

To convert for CCR, multiply by: 1000

MCL in CCR units: 20

MCLG: 20

Major sources in drinking water: Runoff from herbicide use.

Health effects language: Some people who drink water containing diquat in excess of the MCL over many years could get cataracts.

Contaminant (units): Dioxin (2,3,7,8-TCDD) (ppq)

Traditional MCL in mg/l: 0.00000003

To convert for CCR, multiply by: 1,000,000,000

MCL in CCR units: 30

MCLG: 0

Major sources in drinking water: Emissions from waste incineration and other combustion; discharge from chemical factories.

Health effects language: Some people who drink water containing dioxin in excess of the MCL over many years could experience reproductive difficulties and may have an increased risk of getting cancer.

Contaminant (units): Endothall (ppb)

Traditional MCL in mg/l: 0.1

To convert for CCR, multiply by: 1000

MCL in CCR units: 100

MCLG: 100

Major sources in drinking water: Runoff from herbicide use.

Health effects language: Some people who drink water containing endothall in excess of the MCL over many years could experience problems with their stomach or intestines.

Contaminant (units): Endrin (ppb)

Traditional MCL in mg/ℓ: 0.002

To convert for CCR, multiply by: 1000

MCL in CCR units: 2

MCLG: 2

Major sources in drinking water: Residue of banned insecticide.

Health effects language: Some people who drink water containing endrin in excess of the MCL over many years could experience liver problems.

Contaminant (units): Epichlorohydrin

Traditional MCL in mg/ℓ: TT

To convert for CCR, multiply by: --

MCL in CCR units: TT

MCLG: 0

Major sources in drinking water: Discharge from industrial chemical factories; an impurity of some water treatment chemicals.

Health effects language: Some people who drink water containing high levels of epichlorohydrin over a long period of time could experience stomach problems, and may have an increased risk of getting cancer.

Contaminant (units): Ethylene dibromide (ppt)

Traditional MCL in mg/ℓ: 0.00005

To convert for CCR, multiply by: 1,000,000

MCL in CCR units: 50

MCLG: 0

Major sources in drinking water: Discharge from petroleum refineries.

Health effects language: Some people who drink water containing ethylene dibromide in excess of the MCL over many years could experience problems with their liver, stomach, reproductive system, or kidneys, and may have an increased risk of getting cancer.

Contaminant (units): Glyphosate (ppb)

Traditional MCL in mg/ℓ: 0.7

To convert for CCR, multiply by: 1000

MCL in CCR units: 700

MCLG: 700

Major sources in drinking water: Runoff from herbicide use.

Health effects language: Some people who drink water containing glyphosate in excess of the MCL over many years could experience problems with their kidneys or reproductive difficulties.

Contaminant (units): Heptachlor (ppt)

Traditional MCL in mg/ℓ: 0.0004

To convert for CCR, multiply by: 1,000,000

MCL in CCR units: 400

MCLG: 0

Major sources in drinking water: Residue of banned pesticide.

Health effects language: Some people who drink water containing heptachlor in excess of the MCL over many years could experience liver damage and may have an increased risk of getting cancer.

Contaminant (units): Heptachlor epoxide (ppt)

Traditional MCL in mg/ℓ: 0.0002

To convert for CCR, multiply by: 1,000,000

MCL in CCR units: 200

MCLG: 0

Major sources in drinking water: Breakdown of heptachlor.

Health effects language: Some people who drink water containing heptachlor epoxide in excess of the MCL over many years could experience liver damage, and may have an increased risk of getting cancer.

Contaminant (units): Hexachlorobenzene (ppb)

Traditional MCL in mg/ℓ: 0.001

To convert for CCR, multiply by: 1000

MCL in CCR units: 1

MCLG: 0

Major sources in drinking water: Discharge from metal refineries and agricultural chemical factories.

Health effects language: Some people who drink water containing hexachlorobenzene in excess of the MCL over many years could experience problems with their liver or kidneys, or adverse reproductive effects, and may have an increased risk of getting cancer.

Contaminant (units): Hexachlorocyclopentadiene (ppb)

Traditional MCL in mg/ℓ: 0.05

To convert for CCR, multiply by: 1000

MCL in CCR units: 50

MCLG: 50

Major sources in drinking water: Discharge from chemical factories.

Health effects language: Some people who drink water containing hexachlorocyclopentadiene well in excess of the MCL over many years could experience problems with their kidneys or stomach.

Contaminant (units): Lindane (ppt)

Traditional MCL in mg/ℓ: 0.0002

To convert for CCR, multiply by: 1,000,000

MCL in CCR units: 200

MCLG: 200

Major sources in drinking water: Runoff/leaching from insecticide used on cattle, lumber, gardens.

Health effects language: Some people who drink water containing lindane in excess of the MCL over many years could experience problems with their kidneys or liver.

Contaminant (units): Methoxychlor (ppb)

Traditional MCL in mg/l: 0.04

To convert for CCR, multiply by: 1000

MCL in CCR units: 40

MCLG: 40

Major sources in drinking water: Runoff/leaching from insecticide used on fruits, vegetables, alfalfa, livestock.

Health effects language: Some people who drink water containing methoxychlor in excess of the MCL over many years could experience reproductive difficulties.

Contaminant (units): Oxamyl (vydate) (ppb)

Traditional MCL in mg/l: 0.2

To convert for CCR, multiply by: 1000

MCL in CCR units: 200

MCLG: 200

Major sources in drinking water: Runoff/leaching from insecticide used on apples, potatoes and tomatoes.

Health effects language: Some people who drink water containing oxamyl in excess of the MCL over many years could experience slight nervous system effects.

Contaminant (units): PCBs (polychlorinated biphenyls) (ppt)

Traditional MCL in mg/l: 0.0005

To convert for CCR, multiply by: 1,000,000

MCL in CCR units: 500

MCLG: 0

Major sources in drinking water: Runoff from landfills; discharge of waste chemicals.

Health effects language: Some people who drink water containing PCBs in excess of the MCL over many years could experience changes in their skin, problems with their thymus gland, immune deficiencies, or reproductive or nervous system difficulties, and may have an increased risk of getting cancer.

Contaminant (units): Pentachlorophenol (ppb)

Traditional MCL in mg/l: 0.001

To convert for CCR, multiply by: 1000

MCL in CCR units: 1

MCLG: 0

Major sources in drinking water: Discharge from wood preserving factories.

Health effects language: Some people who drink water containing pentachlorophenol in excess of the MCL over many years could experience problems with their liver or kidneys, and may have an increased risk of getting cancer.

Contaminant (units): Picloram (ppb)

Traditional MCL in mg/l: 0.5

To convert for CCR, multiply by: 1000

MCL in CCR units: 500

MCLG: 500

Major sources in drinking water: Herbicide runoff.

Health effects language: Some people who drink water containing picloram in excess of the MCL over many years could experience problems with their liver.

Contaminant (units): Simazine (ppb)

Traditional MCL in mg/ℓ: 0.004

To convert for CCR, multiply by: 1000

MCL in CCR units: 4

MCLG: 4

Major sources in drinking water: Herbicide runoff.

Health effects language: Some people who drink water containing simazine in excess of the MCL over many years could experience problems with their blood.

Contaminant (units): Toxaphene (ppb)

Traditional MCL in mg/ℓ: 0.003

To convert for CCR, multiply by: 1000

MCL in CCR units: 3

MCLG: 0

Major sources in drinking water: Runoff/leaching from insecticide used on cotton and cattle.

Health effects language: Some people who drink water containing toxaphene in excess of the MCL over many years could have problems with their kidneys, liver, or thyroid, and may have an increased risk of getting cancer.

Volatile organic contaminants.

Contaminant (units): Benzene (ppb)

Traditional MCL in mg/ℓ: 0.005

To convert for CCR, multiply by: 1000

MCL in CCR units: 5

MCLG: 0

Major sources in drinking water: Discharge from factories; leaching from gas storage tanks and landfills.

Health effects language: Some people who drink water containing benzene in excess of the MCL over many years could experience anemia or a decrease in blood platelets, and may have an increased risk of getting cancer.

Contaminant (units): Carbon tetrachloride (ppb)

Traditional MCL in mg/ℓ: 0.005

To convert for CCR, multiply by: 1000

MCL in CCR units: 5

MCLG: 0

Major sources in drinking water: Discharge from chemical plants and other industrial activities.

Health effects language: Some people who drink water containing carbon tetrachloride in excess of the MCL over many years could experience problems with their liver

and may have an increased risk of getting cancer.

Contaminant (units): Chlorobenzene (ppb)

Traditional MCL in mg/l: 0.1

To convert for CCR, multiply by: 1000

MCL in CCR units: 100

MCLG: 100

Major sources in drinking water: Discharge from chemical and agricultural chemical factories.

Health effects language: Some people who drink water containing chlorobenzene in excess of the MCL over many years could experience problems with their liver or kidneys.

Contaminant (units): o-Dichlorobenzene (ppb)

Traditional MCL in mg/l: 0.6

To convert for CCR, multiply by: 1000

MCL in CCR units: 600

MCLG: 600

Major sources in drinking water: Discharge from industrial chemical factories.

Health effects language: Some people who drink water containing o-dichlorobenzene well in excess of the MCL over many years could experience problems with their liver, kidneys, or circulatory systems.

Contaminant (units): p-Dichlorobenzene (ppb)

Traditional MCL in mg/l: 0.075

To convert for CCR, multiply by: 1000

MCL in CCR units: 75

MCLG: 75

Major sources in drinking water: Discharge from industrial chemical factories.

Health effects language: Some people who drink water containing p-dichlorobenzene in excess of the MCL over many years could experience anemia; damage to their liver, kidneys, or spleen; or changes in their blood.

Contaminant (units): 1,2-Dichloroethane (ppb)

Traditional MCL in mg/l: 0.005

To convert for CCR, multiply by: 1000

MCL in CCR units: 5

MCLG: 0

Major sources in drinking water: Discharge from industrial chemical factories.

Health effects language: Some people who drink water containing 1,2-dichloroethane in excess of the MCL over many years may have an increased risk of getting cancer.

Contaminant (units): 1,1-Dichloroethylene (ppb)

Traditional MCL in mg/l: 0.007

To convert for CCR, multiply by: 1000

MCL in CCR units: 7

MCLG: 7

Major sources in drinking water: Discharge from industrial chemical factories.

Health effects language: Some people who drink water containing 1,1-dichloroethylene in excess of the MCL over many years could experience problems with their liver.

Contaminant (units): cis-1,2-Dichloroethylene (ppb)

Traditional MCL in mg/ℓ: 0.07

To convert for CCR, multiply by: 1000

MCL in CCR units: 70

MCLG: 70

Major sources in drinking water: Discharge from industrial chemical factories.

Health effects language: Some people who drink water containing cis-1,2-dichloroethylene in excess of the MCL over many years could experience problems with their liver.

Contaminant (units): trans-1,2-Dichloroethylene (ppb)

Traditional MCL in mg/ℓ: 0.1

To convert for CCR, multiply by: 1000

MCL in CCR units: 100

MCLG: 100

Major sources in drinking water: Discharge from industrial chemical factories.

Health effects language: Some people who drink water containing trans-1,2-dichloroethylene well in excess of the MCL over many years could experience problems with their liver.

Contaminant (units): Dichloromethane (ppb)

Traditional MCL in mg/ℓ: 0.005

To convert for CCR, multiply by: 1000

MCL in CCR units: 5

MCLG: 0

Major sources in drinking water: Discharge from pharmaceutical and chemical factories.

Health effects language: Some people who drink water containing dichloromethane in excess of the MCL over many years could have liver problems and may have an increased risk of getting cancer.

Contaminant (units): 1,2-Dichloropropane (ppb)

Traditional MCL in mg/ℓ: 0.005

To convert for CCR, multiply by: 1000

MCL in CCR units: 5

MCLG: 0

Major sources in drinking water: Discharge from industrial chemical factories.

Health effects language: Some people who drink water containing 1,2-dichloropropane in excess of the MCL over many years may have an increased risk of getting cancer.

Contaminant (units): Ethylbenzene (ppb)

Traditional MCL in mg/ℓ: 0.7

To convert for CCR, multiply by: 1000

MCL in CCR units: 700

MCLG: 700

Major sources in drinking water: Discharge from petroleum refineries.

Health effects language: Some people who drink water containing ethylbenzene well in excess of the MCL over many years could experience problems with their liver or kidneys.

Contaminant (units): Haloacetic acids (HAA5) (ppb)

Traditional MCL in mg/ℓ: 0.060

To convert for CCR, multiply by: 1000

MCL in CCR units: 60

MCLG: N/A

Major sources in drinking water: Byproduct of drinking water disinfection.

Health effects language: Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.

Contaminant (units): Styrene (ppb)

Traditional MCL in mg/ℓ: 0.1

To convert for CCR, multiply by: 1000

MCL in CCR units: 100

MCLG: 100

Major sources in drinking water: Discharge from rubber and plastic factories; leaching from landfills.

Health effects language: Some people who drink water containing styrene well in excess of the MCL over many years could have problems with their liver, kidneys, or circulatory system.

Contaminant (units): Tetrachloroethylene (ppb)

Traditional MCL in mg/ℓ: 0.005

To convert for CCR, multiply by: 1000

MCL in CCR units: 5

MCLG: 0

Major sources in drinking water: Discharge from factories and dry cleaners.

Health effects language: Some people who drink water containing tetrachloroethylene in excess of the MCL over many years could have problems with their liver, and may have an increased risk of getting cancer.

Contaminant (units): 1,2,4-Trichlorobenzene (ppb)

Traditional MCL in mg/ℓ: 0.07

To convert for CCR, multiply by: 1000

MCL in CCR units: 70

MCLG: 70

Major sources in drinking water: Discharge from textile-finishing factories.

Health effects language: Some people who drink water containing 1,2,4-

trichlorobenzene well in excess of the MCL over many years could experience changes in their adrenal glands.

Contaminant (units): 1,1,1-Trichloroethane (ppb)

Traditional MCL in mg/l: 0.2

To convert for CCR, multiply by: 1000

MCL in CCR units: 200

MCLG: 200

Major sources in drinking water: Discharge from metal degreasing sites and other factories.

Health effects language: Some people who drink water containing 1,1,1-trichloroethane in excess of the MCL over many years could experience problems with their liver, nervous system, or circulatory system.

Contaminant (units): 1,1,2-Trichloroethane (ppb)

Traditional MCL in mg/l: 0.005

To convert for CCR, multiply by: 1000

MCL in CCR units: 5

MCLG: 3

Major sources in drinking water: Discharge from industrial chemical factories.

Health effects language: Some people who drink water containing 1,1,2-trichloroethane well in excess of the MCL over many years could have problems with their liver, kidneys, or immune systems.

Contaminant (units): Trichloroethylene (ppb)

Traditional MCL in mg/l: 0.005

To convert for CCR, multiply by: 1000

MCL in CCR units: 5

MCLG: 0

Major sources in drinking water: Discharge from metal degreasing sites and other factories.

Health effects language: Some people who drink water containing trichloroethylene in excess of the MCL over many years could experience problems with their liver and may have an increased risk of getting cancer.

Contaminant (units): TTHMs (total trihalomethanes) (ppb)

Traditional MCL in mg/l: 0.10/0.080

To convert for CCR, multiply by: 1000

MCL in CCR units: 100/80

MCLG: N/A

Major sources in drinking water: Byproduct of drinking water disinfection.

Health effects language: Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer.

Contaminant (units): Toluene (ppm)

Traditional MCL in mg/ℓ: 1

To convert for CCR, multiply by: --

MCL in CCR units: 1

MCLG: 1

Major sources in drinking water: Discharge from petroleum factories.

Health effects language: Some people who drink water containing toluene well in excess of the MCL over many years could have problems with their nervous system, kidneys, or liver.

Contaminant (units): Vinyl Chloride (ppb)

Traditional MCL in mg/ℓ: 0.002

To convert for CCR, multiply by: 1000

MCL in CCR units: 2

MCLG: 0

Major sources in drinking water: Leaching from PVC piping; discharge from plastics factories.

Health effects language: Some people who drink water containing vinyl chloride in excess of the MCL over many years may have an increased risk of getting cancer.

Contaminant (units): Xylenes (ppm)

Traditional MCL in mg/ℓ: 10

To convert for CCR, multiply by: --

MCL in CCR units: 10

MCLG: 10

Major sources in drinking water: Discharge from petroleum factories; discharge from chemical factories.

Health effects language: Some people who drink water containing xylenes in excess of the MCL over many years could experience damage to their nervous system.

Key.

Abbreviation	Meaning
AL	action level
MCL	maximum contaminant level
MCLG	maximum contaminant level goal
MFL	million fibers per liter
MRDL	maximum residual disinfectant level
MRDLG	maximum residual disinfectant level goal
mrem/year	millirems per year (a measure of radiation absorbed by the body)
N/A	not applicable
NTU	nephelometric turbidity units(a measure of water clarity)
pCi/ℓ	picocuries per liter (a measure of radioactivity)
ppm	parts per million, or milligrams per liter (mg/ℓ)
ppb	parts per billion, or micrograms per liter (μg/ℓ)
ppt	parts per trillion, or nanograms per liter

ppq parts per quadrillion, or picograms per liter
 TT treatment technique

BOARD NOTE: Derived from Appendix A to Subpart O to 40 CFR 141-(2002) (2003).

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.Appendix G NPDWR Violations and Situations Requiring Public Notice

See note 1 at the end of this Appendix G for an explanation of the Agency's authority to alter the magnitude of a violation from that set forth in the following table.

Contaminant	MCL/MRDL/TT violations ²		Monitoring & testing procedure violations	
	Tier of public notice required	Citation	Tier of public notice required	Citation

I. Violations of National Primary Drinking Water Regulations (NPDWR):³

A. Microbiological Contaminants

1. Total coliform	2	611.325(a)	3	611.521-611.525
2. Fecal coliform/E. coli	1	611.325(b)	⁴ 1, 3	611.525
3. Turbidity MCL	2	611.320(a)	3	611.560
4. Turbidity MCL (average of two days' samples greater than 5 NTU)	⁵ 2, 1	611.320(b)	3	611.560
5. Turbidity (for TT violations resulting from a single exceedence of maximum allowable turbidity level)	⁶ 2, 1	611.231(b), 611.233(b)(1), 611.250(a)(2), 611.250(b)(2), 611.250(c)(2), 611.250(d), 611.743(a)(2), 611.743(b), 611.955(b)(2)	3	611.531(a), 611.532(b), 611.533(a), 611.744, 611.956(a)(1)- (a)(3), 611.956(b)

6. Surface Water Treatment Rule violations, other than violations resulting from single exceedence of max. allowable turbidity level (TT)	2	611.211, 611.213, 611.220, 611.230- 611.233, 611.240- 611.242, 611.250	3	611.531- 611.533
7. Interim Enhanced Surface Water Treatment Rule violations, other than violations resulting from single exceedence of max. turbidity level (TT)	2	⁷ 611.740- 611.743, 611.950- 611.955	3	611.742, 611.744, 611.953, 611.954, 611.956
8. Filter Backwash Recycling Rule violations	2	611.276	3	611.276
9. Long Term 1 Enhanced Surface Water Treatment Rule violations	2	611.950- 611.955	3	611.953, 611.954, 611.956

B. Inorganic Chemicals (IOCs)

1. Antimony	2	611.301(b)	3	611.600, 611.601, 611.603
2. Arsenic	2	¹⁰ 611.301(b)	3	⁹ 611.601, 611.612(a), 611.612(b)
3. Asbestos (fibers greater than 10 µm)	2	611.301(b)	3	611.600, 611.601, 611.602
4. Barium	2	611.301(b)	3	611.600, 611.601, 611.603
5. Beryllium	2	611.301(b)	3	611.600, 611.601, 611.603
6. Cadmium	2	611.301(b)	3	611.600, 611.601, 611.603
7. Chromium (total)	2	611.301(b)	3	611.600, 611.601, 611.603
8. Cyanide	2	611.301(b)	3	611.600, 611.601, 611.603

9. Fluoride	2	611.301(b)	3	611.600, 611.601, 611.603
10. Mercury (inorganic)	2	611.301(b)	3	611.600, 611.601, 611.603
11. Nitrate	1	611.301(b)	¹⁰ 1, 3	611.600, 611.601, 611.604, 611.606
12. Nitrite	1	611.301(b)	¹⁰ 1, 3	611.600, 611.601, 611.605, 611.606
13. Total Nitrate and Nitrite	1	611.301(b)	3	611.600, 611.601
14. Selenium	2	611.301(b)	3	611.600, 611.601, 611.603
15. Thallium	2	611.301(b)	3	611.600, 611.601, 611.603

C. Lead and Copper Rule (Action Level for lead is 0.015 mg/l, for copper is 1.3 mg/l)

1. Lead and Copper Rule (TT)	2	611.350- 611.355	3	611.356- 611.359
------------------------------	---	---------------------	---	---------------------

D. Synthetic Organic Chemicals (SOCs)

1. 2,4-D	2	611.310(c)	3	611.648
2. 2,4,5-TP (silvex)	2	611.310(c)	3	611.648
3. Alachlor	2	611.310(c)	3	611.648
4. Atrazine	2	611.310(c)	3	611.648
5. Benzo(a)pyrene (PAHs)	2	611.310(c)	3	611.648
6. Carbofuran	2	611.310(c)	3	611.648
7. Chlordane	2	611.310(c)	3	611.648
8. Dalapon	2	611.310(c)	3	611.648
9. Di(2-ethylhexyl)adipate	2	611.310(c)	3	611.648
10. Di(2-ethylhexyl)phthalate	2	611.310(c)	3	611.648
11. Dibromochloropropane (DBCP)	2	611.310(c)	3	611.648
12. Dinoseb	2	611.310(c)	3	611.648
13. Dioxin (2,3,7,8-TCDD)	2	611.310(c)	3	611.648
14. Diquat	2	611.310(c)	3	611.648
15. Endothall	2	611.310(c)	3	611.648

16. Endrin	2	611.310(c)	3	611.648
17. Ethylene dibromide	2	611.310(c)	3	611.648
18. Glyphosate	2	611.310(c)	3	611.648
19. Heptachlor	2	611.310(c)	3	611.648
20. Heptachlor epoxide	2	611.310(c)	3	611.648
21. Hexachlorobenzene	2	611.310(c)	3	611.648
22. Hexachlorocyclopentadiene	2	611.310(c)	3	611.648
23. Lindane	2	611.310(c)	3	611.648
24. Methoxychlor	2	611.310(c)	3	611.648
25. Oxamyl (Vydate)	2	611.310(c)	3	611.648
26. Pentachlorophenol	2	611.310(c)	3	611.648
27. Picloram	2	611.310(c)	3	611.648
28. Polychlorinated biphenyls (PCBs)	2	611.310(c)	3	611.648
29. Simazine	2	611.310(c)	3	611.648
30. Toxaphene	2	611.310(c)	3	611.648

E. Volatile Organic Chemicals (VOCs)

1. Benzene	2	611.310(a)	3	611.646
2. Carbon tetrachloride	2	611.310(a)	3	611.646
3. Chlorobenzene (monochlorobenzene)	2	611.310(a)	3	611.646
4. o-Dichlorobenzene	2	611.310(a)	3	611.646
5. p-Dichlorobenzene	2	611.310(a)	3	611.646
6. 1,2-Dichloroethane	2	611.310(a)	3	611.646
7. 1,1-Dichloroethylene	2	611.310(a)	3	611.646
8. cis-1,2-Dichloroethylene	2	611.310(a)	3	611.646
9. trans-1,2-Dichloroethylene	2	611.310(a)	3	611.646
10. Dichloromethane	2	611.310(a)	3	611.646
11. 1,2-Dichloropropane	2	611.310(a)	3	611.646
12. Ethylbenzene	2	611.310(a)	3	611.646
13. Styrene	2	611.310(a)	3	611.646
14. Tetrachloroethylene	2	611.310(a)	3	611.646
15. Toluene	2	611.310(a)	3	611.646
16. 1,2,4-Trichlorobenzene	2	611.310(a)	3	611.646
17. 1,1,1-Trichloroethane	2	611.310(a)	3	611.646
18. 1,1,2-Trichloroethane	2	611.310(a)	3	611.646
19. Trichloroethylene	2	611.310(a)	3	611.646
20. Vinyl chloride	2	611.310(a)	3	611.646
21. Xylenes (total)	2	611.310(a)	3	611.646

F. Radioactive Contaminants

1. Beta/photon emitters	2	611.330(d)	3	611.720(a), 611.732
-------------------------	---	------------	---	------------------------

2. Alpha emitters	2	611.330(c)	3	611.720(a), 611.731
3. Combined radium (226 & 228)	2	611.330(b)	3	611.720(a), 611.731
4. Uranium	⁴⁺ 2	611.330(e)	⁴⁺ 3	611.720(a), 611.731

G. Disinfection Byproducts (DBPs), Byproduct Precursors, Disinfectant Residuals. Where disinfection is used in the treatment of drinking water, disinfectants combine with organic and inorganic matter present in water to form chemicals called disinfection byproducts (DBPs). USEPA sets standards for controlling the levels of disinfectants and DBPs in drinking water, including trihalomethanes (THMs) and haloacetic acids (HAAs).¹³

1. Total trihalomethanes (TTHMs)	2	611.310, 611.312(a)	3	611.680- 611.688, 611.382(a)-(b)
2. Haloacetic Acids (HAA5)	2	611.312(a)	3	611.382(a)-(b)
3. Bromate	2	611.312(a)	3	611.382(a)-(b)
4. Chlorite	2	611.312(a)	3	611.382(a)-(b)
5. Chlorine (MRDL)	2	611.313(a)	3	611.382(a), (c)
6. Chloramine (MRDL)	2	611.313(a)	3	611.382(a), (c)
7. Chlorine dioxide (MRDL), where any two consecutive daily samples at entrance to distribution system only are above MRDL	2	611.313(a), 611.383(c)(3)	2 ¹⁵ , 3	611.382(a), (c), 611.383(c)(2)
8. Chlorine dioxide (MRDL), where samples in distribution system the next day are also above MRDL	¹⁶ 1	611.313(a), 611.383(c)(3)	1	611.382(a), (c), 611.383(c)(2)
9. Control of DBP precursors-- TOC (TT)	2	611.385(a)-(b)	3	611.382(a), (d)
10. Benchmarking and disinfection profiling	N/A	N/A	3	611.742, 611.953, 611.954
11. Development of monitoring plan	N/A	N/A	3	611.382(f)

H. Other Treatment Techniques

1. Acrylamide (TT)	2	611.296	N/A	N/A
2. Epichlorohydrin (TT)	2	611.296	N/A	N/A

II. Unregulated Contaminant Monitoring:¹⁷

A. Unregulated contaminants	N/A	N/A	3	611.510
B. Nickel	N/A	N/A	3	611.603, 611.611

III. Public Notification for Relief Equivalent to a SDWA section 1415 Variance or a section 1416 Exemption.

A. Operation under relief equivalent to a SDWA section 1415 variance or a section 1416 exemption	3	¹⁸ 1415, 1416	N/A	N/A
B. Violation of conditions of relief equivalent to a SDWA section 1415 variance or a section 1416 exemption	2	1415, 1416, ¹⁹ 611.111, 611.112	N/A	N/A

IV. Other Situations Requiring Public Notification.

A. Fluoride secondary maximum contaminant level (SMCL) exceedence	3	611.858	N/A	N/A
B. Exceedence of nitrate MCL for a non-CWS supplier, as allowed by the Agency	1	611.300(d)	N/A	N/A
C. Availability of unregulated contaminant monitoring data	3	611.510	N/A	N/A
D. Waterborne disease outbreak	1	611.101, 611.233(b)(2)	N/A	N/A
E. Other waterborne emergency ²⁰	1	N/A	N/A	N/A
F. Other situations as determined by the Agency by a SEP issued pursuant to Section 611.110	1, 2, 3	N/A	N/A	N/A

Appendix G--Endnotes

1. Violations and other situations not listed in this table (e.g., reporting violations and failure to prepare Consumer Confidence Reports) do not require notice, unless otherwise determined by the Agency by a SEP issued pursuant to Section 611.110. The Agency may, by a SEP issued pursuant to Section 611.110, further require a more stringent public notice tier (e.g., Tier 1 instead of Tier 2 or Tier 2 instead of Tier 3) for specific violations and situations listed in this Appendix, as authorized under Sections 611.902(a) and 611.903(a).

2. Definition of the abbreviations used: “MCL” means maximum contaminant level, “MRDL” means maximum residual disinfectant level, and “TT” means treatment technique.

3. The term “violations of National Primary Drinking Water Regulations (NPDWR)” is used here to include violations of MCL, MRDL, treatment technique, monitoring, and testing procedure requirements.

4. Failure to test for fecal coliform or E. coli is a Tier 1 violation if testing is not done after any repeat sample tests positive for coliform. All other total coliform monitoring and testing procedure violations are Tier 3 violations.
5. A supplier that violates the turbidity MCL of 5 NTU based on an average of measurements over two consecutive days must consult with the Agency within 24 hours after learning of the violation. Based on this consultation, the Agency may subsequently decide to issue a SEP pursuant to Section 611.110 that elevates the violation to a Tier 1 violation. If a supplier is unable to make contact with the Agency in the 24-hour period, the violation is automatically elevated to a Tier 1 violation.
6. A supplier with a treatment technique violation involving a single exceedence of a maximum turbidity limit under the Surface Water Treatment Rule (SWTR), the Interim Enhanced Surface Water Treatment Rule (IESWTR), or the Long Term 1 Enhanced Surface Water Treatment Rule are required to consult with the Agency within 24 hours after learning of the violation. Based on this consultation, the Agency may subsequently decide to issue a SEP pursuant to Section 611.110 that elevates the violation to a Tier 1 violation. If a supplier is unable to make contact with the Agency in the 24-hour period, the violation is automatically elevated to a Tier 1 violation.
7. ~~Most of the requirements of the Interim Enhanced Surface Water Treatment Rule (63 Fed. Reg. 69477 (December 16, 1998)) (Sections 611.740-611.741, 611.743-611.744) were effective January 1, 2002 for a Subpart B supplier (surface water systems and groundwater systems under the direct influence of surface water) that serves at least 10,000 persons. However, Section 611.742 is currently effective. The Surface Water Treatment Rule (SWTR) remains in effect for a supplier serving at least 10,000 persons even after 2002; the Interim Enhanced Surface Water Treatment Rule adds additional requirements and does not in many cases supercede the SWTR.~~
8. The arsenic MCL citations are effective January 23, 2006. Until then, the citations are Sections 611.330(b) and 611.612(c).
9. The arsenic Tier 3 violation MCL citations are effective January 23, 2006. Until then, the citations are Sections 611.100, 611.101, and 611.612.
10. Failure to take a confirmation sample within 24 hours for nitrate or nitrite after an initial sample exceeds the MCL is a Tier 1 violation. Other monitoring violations for nitrate are Tier 3.
11. ~~The uranium MCL Tier 2 violation citations are effective December 8, 2003 for a CWS supplier.~~This endnote 11 corresponds with the endnote to the table in Appendix A to Subpart Q of 40 CFR 141 (2003), which stated a past effective date. This statement maintains structural consistency with the federal regulations.
12. ~~The uranium Tier 3 violation citations were effective December 8, 2000 for a CWS supplier.~~This endnote 12 corresponds with the endnote to the table in Appendix A to Subpart Q of 40 CFR 141 (2003), which stated a past effective date. This statement maintains structural

consistency with the federal regulations.

13. A Subpart B community or non-transient non-community system supplier ~~that serves 10,000 persons or more~~ must comply with new DBP MCLs, disinfectant MRDLs, and related monitoring requirements. ~~All other community and non-transient non-community systems must meet the MCLs and MRDLs beginning January 1, 2004.~~ A Subpart B transient non-community system supplier serving 10,000 or more persons that uses chlorine dioxide as a disinfectant or oxidant ~~must comply with the chlorine dioxide MRDL.~~ A or a Subpart B transient non-community system supplier that serves fewer than 10,000 persons, which uses only groundwater not under the direct influence of surface water, and which uses chlorine dioxide as a disinfectant or oxidant must comply with the chlorine dioxide MRDL beginning January 1, 2004.

14. ~~Section 611.310 will no longer apply after January 1, 2004.~~ This endnote 14 corresponds with the endnote to the table in Appendix A to Subpart Q of 40 CFR 141 (2003), which stated a past effective date. This statement maintains structural consistency with the federal regulations.

15. Failure to monitor for chlorine dioxide at the entrance to the distribution system the day after exceeding the MRDL at the entrance to the distribution system is a Tier 2 violation.

16. If any daily sample taken at the entrance to the distribution system exceeds the MRDL for chlorine dioxide and one or more samples taken in the distribution system the next day exceed the MRDL, Tier 1 notification is required. A failure to take the required samples in the distribution system after the MRDL is exceeded at the entry point also triggers Tier 1 notification.

17. Some water suppliers must monitor for certain unregulated contaminants listed in Section 611.510.

18. This citation refers to sections 1415 and 1416 of the federal Safe Drinking Water Act. sections 1415 and 1416 require that “a schedule prescribed . . . for a public water system granted relief equivalent to a SDWA section 1415 variance or a section 1416 exemption must require compliance by the system . . .”

19. In addition to sections 1415 and 1416 of the federal Safe Drinking Water Act, 40 CFR 142.307 specifies the items and schedule milestones that must be included in relief equivalent to a SDWA section 1415 small system variance. In granting any form of relief from an NPDWR, the Board will consider all applicable federal requirements for and limitations on the State’s ability to grant relief consistent with federal law.

20. Other waterborne emergencies require a Tier 1 public notice under Section 611.902(a) for situations that do not meet the definition of a waterborne disease outbreak given in Section 611.101, but which still have the potential to have serious adverse effects on health as a result of short-term exposure. These could include outbreaks not related to treatment deficiencies, as well as situations that have the potential to cause outbreaks, such as failures or significant interruption in water treatment processes, natural disasters that disrupt the water supply or distribution system, chemical spills, or unexpected loading of possible pathogens into the source water.

BOARD NOTE: Derived from Appendix A to Subpart Q to 40 CFR 141-(2002) (2003).

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.Appendix H Standard Health Effects Language for Public Notification

Contaminant	MCLG ¹ mg/ℓ	MCL ² mg/ℓ	Standard health effects language for public notification
National Primary Drinking Water Regulations (NPDWR):			
A. Microbiological Contaminants			
1a. Total coliform	Zero	See footnote 3	Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially-harmful, bacteria may be present. Coliforms were found in more samples than allowed and this was a warning of potential problems.
1b. Fecal coliform/E. coli	Zero	Zero	Fecal coliforms and E. coli are bacteria whose presence indicates that the water may be contaminated with human or animal wastes. Microbes in these wastes can cause short-term effects, such as diarrhea, cramps, nausea, headaches, or other symptoms. They may pose a special health risk for infants, young children, some of the elderly, and people with severely compromised immune systems.
2a. Turbidity (MCL) ⁴	None	1 NTU ⁵ / 5 NTU	Turbidity has no health effects. However, turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

2b. Turbidity (SWTR TT)	None	TT ⁷	Turbidity has no health effects. However, ⁶ turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.
2c. Turbidity (IESWTR TT and LT1ESWTR TT)	None	TT	Turbidity has no health effects. However, ⁸ turbidity can interfere with disinfection and provide a medium for microbial growth. Turbidity may indicate the presence of disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.
B. Surface Water Treatment Rule (SWTR), Interim Enhanced Surface Water Treatment Rule (IESWTR), Long Term 1 Enhanced Surface Water Treatment Rule (LT1ESWTR), and Filter Backwash Recycling Rule (FBRR) violations:			
3. Giardia lamblia (SWTR/IESWTR/LT1ESWTR)	Zero	TT ¹⁰	Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.
4. Viruses (SWTR/IESWTR/LT1ESWTR)			Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.

5. Heterotrophic plate count (HPC) bacteria ⁹ (SWTR/IESWTR/ LT1ESWTR)			Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.
6. Legionella (SWTR/IESWTR/ LT1ESWTR)			Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.
7. Cryptosporidium (IESWTR/FBRR/ LT1ESWTR)			Inadequately treated water may contain disease-causing organisms. These organisms include bacteria, viruses, and parasites that can cause symptoms such as nausea, cramps, diarrhea, and associated headaches.
C. Inorganic Chemicals (IOCs)			
8. Antimony	0.006	0.006	Some people who drink water containing antimony well in excess of the MCL over many years could experience increases in blood cholesterol and decreases in blood sugar.
9. Arsenic ¹¹	0	0.01 <u>0.010</u>	Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.
10. Asbestos (10 µm)	7 MFL ¹²	7 MFL	Some people who drink water containing asbestos in excess of the MCL over many years may have an increased risk of developing benign intestinal polyps.
11. Barium	2	2	Some people who drink water containing barium in excess of the MCL over many years could experience an increase in their blood pressure.

12. Beryllium	0.004	0.004	Some people who drink water containing beryllium well in excess of the MCL over many years could develop intestinal lesions.
13. Cadmium	0.005	0.005	Some people who drink water containing cadmium in excess of the MCL over many years could experience kidney damage.
14. Chromium (total)	0.1	0.1	Some people who use water containing chromium well in excess of the MCL over many years could experience allergic dermatitis.
15. Cyanide	0.2	0.2	Some people who drink water containing cyanide well in excess of the MCL over many years could experience nerve damage or problems with their thyroid.
16. Fluoride	4.0	4.0	Some people who drink water containing fluoride in excess of the MCL over many years could get bone disease, including pain and tenderness of the bones. Fluoride in drinking water at half the MCL or more may cause mottling of children's teeth, usually in children less than nine years old. Mottling, also known as dental fluorosis, may include brown staining or pitting of the teeth, and occurs only in developing teeth before they erupt from the gums.
17. Mercury (inorganic)	0.002	0.002	Some people who drink water containing inorganic mercury well in excess of the MCL over many years could experience kidney damage.
18. Nitrate	10	10	Infants below the age of six months who drink water containing nitrate in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue baby syndrome.

19. Nitrite	1	1	Infants below the age of six months who drink water containing nitrite in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue baby syndrome.
20. Total Nitrate and Nitrite	10	10	Infants below the age of six months who drink water containing nitrate and nitrite in excess of the MCL could become seriously ill and, if untreated, may die. Symptoms include shortness of breath and blue baby syndrome.
21. Selenium	0.05	0.05	Selenium is an essential nutrient. However, some people who drink water containing selenium in excess of the MCL over many years could experience hair or fingernail losses, numbness in fingers or toes, or problems with their circulation.
22. Thallium	0.0005	0.002	Some people who drink water containing thallium in excess of the MCL over many years could experience hair loss, changes in their blood, or problems with their kidneys, intestines, or liver.
D. Lead and Copper Rule			
23. Lead	Zero	TT ¹³	Infants and children who drink water containing lead in excess of the action level could experience delays in their physical or mental development. Children could show slight deficits in attention span and learning abilities. Adults who drink this water over many years could develop kidney problems or high blood pressure.

24. Copper	1.3	TT ¹⁴	Copper is an essential nutrient, but some people who drink water containing copper in excess of the action level over a relatively short amount of time could experience gastrointestinal distress. Some people who drink water containing copper in excess of the action level over many years could suffer liver or kidney damage. People with Wilson's Disease should consult their personal doctor.
E. Synthetic Organic Chemicals (SOCs)			
25. 2,4-D	0.07	0.07	Some people who drink water containing the weed killer 2,4-D well in excess of the MCL over many years could experience problems with their kidneys, liver, or adrenal glands.
26. 2,4,5-TP (silvex)	0.05	0.05	Some people who drink water containing silvex in excess of the MCL over many years could experience liver problems.
27. Alachlor	Zero	0.002	Some people who drink water containing alachlor in excess of the MCL over many years could have problems with their eyes, liver, kidneys, or spleen, or experience anemia, and may have an increased risk of getting cancer.
28. Atrazine	0.003	0.003	Some people who drink water containing atrazine well in excess of the MCL over many years could experience problems with their cardiovascular system or reproductive difficulties.
29. Benzo(a)pyrene (PAHs).	Zero	0.0002	Some people who drink water containing benzo(a)pyrene in excess of the MCL over many years may experience reproductive difficulties and may have an increased risk of getting cancer.

30. Carbofuran	0.04	0.04	Some people who drink water containing carbofuran in excess of the MCL over many years could experience problems with their blood, or nervous or reproductive systems.
31. Chlordane	Zero	0.002	Some people who drink water containing chlordane in excess of the MCL over many years could experience problems with their liver or nervous system, and may have an increased risk of getting cancer.
32. Dalapon	0.2	0.2	Some people who drink water containing dalapon well in excess of the MCL over many years could experience minor kidney changes.
33. Di(2-ethylhexyl)adipate	0.4	0.4	Some people who drink water containing di(2-ethylhexyl)adipate well in excess of the MCL over many years could experience toxic effects, such as weight loss, liver enlargement, or possible reproductive difficulties.
34. Di(2-ethylhexyl)-phthalate	Zero	0.006	Some people who drink water containing di(2-ethylhexyl)phthalate well in excess of the MCL over many years may have problems with their liver or experience reproductive difficulties, and they may have an increased risk of getting cancer.
35. Dibromochloropropane (DBCP)	Zero	0.0002	Some people who drink water containing DBCP in excess of the MCL over many years could experience reproductive difficulties and may have an increased risk of getting cancer.
36. Dinoseb	0.007	0.007	Some people who drink water containing dinoseb well in excess of the MCL over many years could experience reproductive difficulties.

37. Dioxin (2,3,7,8-TCDD)	Zero	3×10^{-8}	Some people who drink water containing dioxin in excess of the MCL over many years could experience reproductive difficulties and may have an increased risk of getting cancer.
38. Diquat	0.02	0.02	Some people who drink water containing diquat in excess of the MCL over many years could get cataracts.
39. Endothall	0.1	0.1	Some people who drink water containing endothall in excess of the MCL over many years could experience problems with their stomach or intestines.
40. Endrin	0.002	0.002	Some people who drink water containing endrin in excess of the MCL over many years could experience liver problems.
41. Ethylene dibromide	Zero	0.00005	Some people who drink water containing ethylene dibromide in excess of the MCL over many years could experience problems with their liver, stomach, reproductive system, or kidneys, and may have an increased risk of getting cancer.
42. Glyphosate	0.7	0.7	Some people who drink water containing glyphosate in excess of the MCL over many years could experience problems with their kidneys or reproductive difficulties.
43. Heptachlor	Zero	0.0004	Some people who drink water containing heptachlor in excess of the MCL over many years could experience liver damage and may have an increased risk of getting cancer.
44. Heptachlor epoxide	Zero	0.0002	Some people who drink water containing heptachlor epoxide in excess of the MCL over many years could experience liver damage, and may have an increased risk of getting cancer.

45. Hexachlorobenzene	Zero	0.001	Some people who drink water containing hexachlorobenzene in excess of the MCL over many years could experience problems with their liver or kidneys, or adverse reproductive effects, and may have an increased risk of getting cancer.
46. Hexachlorocyclopentadiene	0.05	0.05	Some people who drink water containing hexachlorocyclopentadiene well in excess of the MCL over many years could experience problems with their kidneys or stomach.
47. Lindane	0.0002	0.0002	Some people who drink water containing lindane in excess of the MCL over many years could experience problems with their kidneys or liver.
48. Methoxychlor	0.04	0.04	Some people who drink water containing methoxychlor in excess of the MCL over many years could experience reproductive difficulties.
49. Oxamyl (Vydate)	0.2	0.2	Some people who drink water containing oxamyl in excess of the MCL over many years could experience slight nervous system effects.
50. Pentachlorophenol	Zero	0.001	Some people who drink water containing pentachlorophenol in excess of the MCL over many years could experience problems with their liver or kidneys, and may have an increased risk of getting cancer.
51. Picloram	0.5	0.5	Some people who drink water containing picloram in excess of the MCL over many years could experience problems with their liver.

52. Polychlorinated biphenyls (PCBs)	Zero	0.0005	Some people who drink water containing PCBs in excess of the MCL over many years could experience changes in their skin, problems with their thymus gland, immune deficiencies, or reproductive or nervous system difficulties, and may have an increased risk of getting cancer.
53. Simazine	0.004	0.004	Some people who drink water containing simazine in excess of the MCL over many years could experience problems with their blood.
54. Toxaphene	Zero	0.003	Some people who drink water containing toxaphene in excess of the MCL over many years could have problems with their kidneys, liver, or thyroid, and may have an increased risk of getting cancer.
F. Volatile Organic Chemicals (VOCs)			
55. Benzene	Zero	0.005	Some people who drink water containing benzene in excess of the MCL over many years could experience anemia or a decrease in blood platelets, and may have an increased risk of getting cancer.
56. Carbon tetrachloride	Zero	0.005	Some people who drink water containing carbon tetrachloride in excess of the MCL over many years could experience problems with their liver and may have an increased risk of getting cancer.
57. Chlorobenzene (monochlorobenzene)	0.1	0.1	Some people who drink water containing chlorobenzene in excess of the MCL over many years could experience problems with their liver or kidneys.
58. o-Dichlorobenzene	0.6	0.6	Some people who drink water containing o-dichlorobenzene well in excess of the MCL over many years could experience problems with their liver, kidneys, or circulatory systems.

59. p-Dichlorobenzene	0.075	0.075	Some people who drink water containing p-dichlorobenzene in excess of the MCL over many years could experience anemia, damage to their liver, kidneys, or spleen, or changes in their blood.
60. 1,2-Dichloroethane	Zero	0.005	Some people who drink water containing 1,2-dichloroethane in excess of the MCL over many years may have an increased risk of getting cancer.
61. 1,1-Dichloroethylene	0.007	0.007	Some people who drink water containing 1,1-dichloroethylene in excess of the MCL over many years could experience problems with their liver.
62. cis-1,2-Dichloroethylene	0.07	0.07	Some people who drink water containing cis-1,2-dichloroethylene in excess of the MCL over many years could experience problems with their liver.
63. trans-1,2-Dichloroethylene	0.1	0.1	Some people who drink water containing trans-1,2-dichloroethylene well in excess of the MCL over many years could experience problems with their liver.
64. Dichloromethane	Zero	0.005	Some people who drink water containing dichloromethane in excess of the MCL over many years could have liver problems and may have an increased risk of getting cancer.
65. 1,2-Dichloropropane	Zero	0.005	Some people who drink water containing 1,2-dichloropropane in excess of the MCL over many years may have an increased risk of getting cancer.
66. Ethylbenzene	0.7	0.7	Some people who drink water containing ethylbenzene well in excess of the MCL over many years could experience problems with their liver or kidneys.

67. Styrene	0.1	0.1	Some people who drink water containing styrene well in excess of the MCL over many years could have problems with their liver, kidneys, or circulatory system.
68. Tetrachloroethylene	Zero	0.005	Some people who drink water containing tetrachloroethylene in excess of the MCL over many years could have problems with their liver, and may have an increased risk of getting cancer.
69. Toluene	1	1	Some people who drink water containing toluene well in excess of the MCL over many years could have problems with their nervous system, kidneys, or liver.
70. 1,2,4-Trichlorobenzene	0.07	0.07	Some people who drink water containing 1,2,4-trichlorobenzene well in excess of the MCL over many years could experience changes in their adrenal glands.
71. 1,1,1-Trichloroethane	0.2	0.2	Some people who drink water containing 1,1,1-trichloroethane in excess of the MCL over many years could experience problems with their liver, nervous system, or circulatory system.
72. 1,1,2-Trichloroethane	0.003	0.005	Some people who drink water containing 1,1,2-trichloroethane well in excess of the MCL over many years could have problems with their liver, kidneys, or immune systems.
73. Trichloroethylene	Zero	0.005	Some people who drink water containing trichloroethylene in excess of the MCL over many years could experience problems with their liver and may have an increased risk of getting cancer.
74. Vinyl chloride	Zero	0.002	Some people who drink water containing vinyl chloride in excess of the MCL over many years may have an increased risk of getting cancer.

75. Xylenes (total)	10	10	Some people who drink water containing xylenes in excess of the MCL over many years could experience damage to their nervous system.
G. Radioactive Contaminants			
76. Beta/photon emitters	Zero	4 mrem/yr ¹⁵	Certain minerals are radioactive and may emit forms of radiation known as photons and beta radiation. Some people who drink water containing beta and photon emitters in excess of the MCL over many years may have an increased risk of getting cancer.
77. Alpha emitters	Zero	15 pCi/ℓ ¹⁶	Certain minerals are radioactive and may emit a form of radiation known as alpha radiation. Some people who drink water containing alpha emitters in excess of the MCL over many years may have an increased risk of getting cancer.
78. Combined radium (226 & 228)	Zero	5 pCi/ℓ	Some people who drink water containing radium 226 or 228 in excess of the MCL over many years may have an increased risk of getting cancer.
79. Uranium ¹⁷	Zero	30 µg/ℓ	Some people who drink water containing uranium in excess of the MCL over many years may have an increased risk of getting cancer and kidney toxicity.
<p>H. Disinfection Byproducts (DBPs), Byproduct Precursors, and Disinfectant Residuals: Where disinfection is used in the treatment of drinking water, disinfectants combine with organic and inorganic matter present in water to form chemicals called disinfection byproducts (DBPs). USEPA sets standards for controlling the levels of disinfectants and DBPs in drinking water, including trihalomethanes (THMs) and haloacetic acids (HAA5)¹⁸</p>			
80. Total trihalomethanes (TTHMs)	N/A	0.10 0.080 ¹⁹⁻²⁰	Some people who drink water containing trihalomethanes in excess of the MCL over many years may experience problems with their liver, kidneys, or central nervous system, and may have an increased risk of getting cancer.

81. Haloacetic Acids (HAA5)	N/A	0.060 ²¹	Some people who drink water containing haloacetic acids in excess of the MCL over many years may have an increased risk of getting cancer.
82. Bromate	Zero	0.010	Some people who drink water containing bromate in excess of the MCL over many years may have an increased risk of getting cancer.
83. Chlorite	0.08	1.0	Some infants and young children who drink water containing chlorite in excess of the MCL could experience nervous system effects. Similar effects may occur in fetuses of pregnant women who drink water containing chlorite in excess of the MCL. Some people may experience anemia.
84. Chlorine	4 (MRDLG) ²²	4.0 (MRDL) ²³	Some people who use water containing chlorine well in excess of the MRDL could experience irritating effects to their eyes and nose. Some people who drink water containing chlorine well in excess of the MRDL could experience stomach discomfort.
85. Chloramines	4 (MRDLG)	4.0 (MRDL)	Some people who use water containing chloramines well in excess of the MRDL could experience irritating effects to their eyes and nose. Some people who drink water containing chloramines well in excess of the MRDL could experience stomach discomfort or anemia.
85a. Chlorine dioxide, where any two consecutive daily samples taken at the entrance to the distribution system are above the MRDL	0.8 (MRDLG)	0.8 (MRDL)	Some infants and young children who drink water containing chlorine dioxide in excess of the MRDL could experience nervous system effects. Similar effects may occur in fetuses of pregnant women who drink water containing chlorine dioxide in excess of the MRDL. Some people may experience anemia.

			<p>Add for public notification only: The chlorine dioxide violations reported today are the result of exceedences at the treatment facility only, not within the distribution system that delivers water to consumers. Continued compliance with chlorine dioxide levels within the distribution system minimizes the potential risk of these violations to consumers.</p>
86a. Chlorine dioxide, where one or more distribution system samples are above the MRDL	0.8 (MRDLG)	0.8 (MRDL)	<p>Some infants and young children who drink water containing chlorine dioxide in excess of the MRDL could experience nervous system effects. Similar effects may occur in fetuses of pregnant women who drink water containing chlorine dioxide in excess of the MRDL. Some people may experience anemia.</p> <p>Add for public notification only: The chlorine dioxide violations reported today include exceedences of the USEPA standard within the distribution system that delivers water to consumers. Violations of the chlorine dioxide standard within the distribution system may harm human health based on short-term exposures. Certain groups, including fetuses, infants, and young children, may be especially susceptible to nervous system effects from excessive chlorine dioxide exposure.</p>

87. Control of DBP precursors (TOC)	None	TT	Total organic carbon (TOC) has no health effects. However, total organic carbon provides a medium for the formation of disinfection byproducts. These byproducts include trihalomethanes (THMs) and haloacetic acids (HAAs). Drinking water containing these byproducts in excess of the MCL may lead to adverse health effects, liver or kidney problems, or nervous system effects, and may lead to an increased risk of getting cancer.
I. Other Treatment Techniques:			
88. Acrylamide	Zero	TT	Some people who drink water containing high levels of acrylamide over a long period of time could have problems with their nervous system or blood, and may have an increased risk of getting cancer.
89. Epichlorohydrin	Zero	TT	Some people who drink water containing high levels of epichlorohydrin over a long period of time could experience stomach problems, and may have an increased risk of getting cancer.

Appendix H--Endnotes

1. "MCLG" means maximum contaminant level goal.
2. "MCL" means maximum contaminant level.
3. For a water supplier analyzing at least 40 samples per month, no more than 5.0 percent of the monthly samples may be positive for total coliforms. For a supplier analyzing fewer than 40 samples per month, no more than one sample per month may be positive for total coliforms.
4. There are various regulations that set turbidity standards for different types of systems, including Section 611.320, the 1989 Surface Water Treatment Rule, the 1998 Interim Enhanced Surface Water Treatment Rule, and the 2002 Long Term 1 Enhanced Surface Water Treatment Rule. The MCL for the monthly turbidity average is 1 NTU; the MCL for the 2-day average is 5 NTU for a supplier that is required to filter but has not yet installed filtration (Section 611.320).
5. "NTU" means nephelometric turbidity unit.

6. There are various regulations that set turbidity standards for different types of systems, including Section 611.320, the 1989 Surface Water Treatment Rule (SWTR), the 1998 Interim Enhanced Surface Water Treatment Rule (IESWTR), and the 2002 Long Term 1 Enhanced Surface Water Treatment Rule. A supplier subject to the Surface Water Treatment Rule (both filtered and unfiltered) may not exceed 5 NTU. In addition, in filtered systems, 95 percent of samples each month must not exceed 0.5 NTU in systems using conventional or direct filtration and must not exceed 1 NTU in systems using slow sand or diatomaceous earth filtration or other filtration technologies approved by the Agency.

7. "TT" means treatment technique.

8. There are various regulations that set turbidity standards for different types of systems, including Section 611.320, the 1989 Surface Water Treatment Rule (SWTR), the 1998 Interim Enhanced Surface Water Treatment Rule (IESWTR), and the 2002 Long Term 1 Enhanced Surface Water Treatment Rule. For a supplier subject to the IESWTR (systems serving at least 10,000 people, using surface water or groundwater under the direct influence of surface water), that use conventional filtration or direct filtration, the turbidity level of a system's combined filter effluent may not exceed 0.3 NTU in at least 95 percent of monthly measurements, and the turbidity level of a system's combined filter effluent must not exceed 1 NTU at any time. A supplier subject to the IESWTR using technologies other than conventional, direct, slow sand, or diatomaceous earth filtration must meet turbidity limits set by the Agency. For a supplier subject to the LT1ESWTR (a supplier that serves fewer than 10,000 people, using surface water or groundwater under the direct influence of surface water) that uses conventional filtration or direct filtration, after January 1, 2005, the turbidity level of the supplier's combined filter effluent may not exceed 0.3 NTU in at least 95 percent of monthly measurements, and the turbidity level of the supplier's combined filter effluent must not exceed 1 NTU at any time. A supplier subject to the LT1ESWTR using technologies other than conventional, direct, slow sand, or diatomaceous earth filtration must meet turbidity limits set by the Agency.

9. The bacteria detected by heterotrophic plate count (HPC) are not necessarily harmful. HPC is simply an alternative method of determining disinfectant residual levels. The number of such bacteria is an indicator of whether there is enough disinfectant in the distribution system.

10. SWTR, IESWTR, and LT1ESWTR treatment technique violations that involve turbidity exceedences may use the health effects language for turbidity instead.

11. These arsenic values are effective January 23, 2006. Until then, the MCL is 0.05 mg/l and there is no MCLG.

12. Millions of fibers per liter.

13. Action Level = 0.015 mg/l.

14. Action Level = 1.3 mg/l.

15. Millirems per year.

16. Picocuries per liter.

17. ~~The uranium MCL is effective December 8, 2003 for all community water systems. This endnote 17 corresponds with the endnote to the table in Appendix B to Subpart Q of 40 CFR 141 (2003), which stated a past effective date. This statement maintains structural consistency with the federal regulations.~~

18. A surface water system supplier or a groundwater system supplier under the direct influence of surface water is regulated under Subpart B of this Part. A Subpart B community water system supplier or a non-transient non-community system supplier that serves 10,000 or more persons must comply with DBP MCLs and disinfectant maximum residual disinfectant levels (MRDLs). All other community and non-transient non-community system suppliers must meet the MCLs and MRDLs beginning January 1, 2004. Subpart B transient non-community system suppliers serving 10,000 or more persons and using chlorine dioxide as a disinfectant or oxidant must comply with the chlorine dioxide MRDL. Subpart B transient non-community system suppliers serving fewer than 10,000 persons and systems using only groundwater not under the direct influence of surface water and using chlorine dioxide as a disinfectant or oxidant must comply with the chlorine dioxide MRDL beginning January 1, 2004.

19. ~~The MCL of 0.10 mg/l for TTHMs was in effect until January 1, 2002 for a Subpart B community water system supplier serving 10,000 or more persons. This MCL is in effect until January 1, 2004 for community water systems with a population of 10,000 or more using only groundwater not under the direct influence of surface water. After these deadlines, the MCL will be 0.080 mg/l. On January 1, 2004, a supplier serving fewer than 10,000 will have to comply with the new MCL as well. This endnote 19 corresponds with the endnote to the table in Appendix B to Subpart Q of 40 CFR 141 (2003), which expired by its own terms on January 1, 2004. This statement maintains structural consistency with the federal regulations.~~

20. The MCL for total trihalomethanes is the sum of the concentrations of the individual trihalomethanes.

21. The MCL for haloacetic acids is the sum of the concentrations of the individual haloacetic acids.

22. "MRDLG" means maximum residual disinfectant level goal.

23. "MRDL" means maximum residual disinfectant level.

BOARD NOTE: Derived from Appendix B to Subpart Q to 40 CFR 141 ~~(2002)~~ (2003).

(Source: Amended at 28 Ill. Reg. _____, effective _____)

Section 611.Table Z Federal Effective Dates

The following are the effective dates of the various federal ~~MCLs~~ NPDWRs:

Fluoride (40 CFR 141.60(b)(1)) (corresponding with Section 611.301(b))	October 2, 1987
Phase I VOCs (40 CFR 141.60(a)(1)) (corresponding with Section 611.311(a)) (benzene, carbon tetrachloride, p-dichlorobenzene, 1,2-dichloroethane, 1,1-dichloroethylene, 1,1,1-trichloroethane, trichloroethylene, and vinyl chloride)	July 9, 1989
Lead and Copper (40 CFR, Subpart I) (corresponding with Subpart G of this Part) (lead and copper monitoring, reporting, and recordkeeping requirements of 40 CFR 141.86 through 141.91)	July 7, 1991
Phase II IOCs (40 CFR 141.60(b)(2)) (corresponding with Section 611.301(b)) (asbestos, cadmium, chromium, mercury, nitrate, nitrite, and selenium)	July 30, 1992
Phase II VOCs (40 CFR 141.60(a)(2)) (corresponding with Section 611.311(a)) (o-dichlorobenzene, cis-1,2-dichloroethylene, trans-1,2-dichloroethylene, 1,2-dichloropropane, ethylbenzene, monochlorobenzene, styrene, tetrachloroethylene, toluene, and xylenes (total))	July 30, 1992
Phase II SOCs (40 CFR 141.60(a)(2)) (corresponding with Section 611.311(c)) (alachlor, atrazine, carbofuran, chlordane, dibromochloropropane, ethylene dibromide, heptachlor, heptachlor epoxide, lindane, methoxychlor, polychlorinated biphenyls, toxaphene, 2,4-D, and 2,4,5-TP (silvex))	July 30, 1992
Lead and Copper (40 CFR, Subpart I) (corresponding with Subpart G of this Part) (lead and copper corrosion control, water treatment, public education, and lead service line replacement requirements of 40 CFR 141.81 through 141.85)	December 7, 1992
Phase IIB IOC (40 CFR 141.60(b)(2)) (corresponding with Section 611.301(b)) (barium)	January 1, 1993
Phase IIB SOCs (40 CFR 141.60(a)(2)) (corresponding with Section 611.311(c)) (aldicarb, aldicarb sulfone, aldicarb sulfoxide, and pentachlorophenol. See the Board note appended to Section 611.311(c) for information relating to	January 1, 1993

implementation of requirements relating to aldicarb, aldicarb sulfone, and aldicarb sulfoxide.)

Phase V IOCs (40 CFR 141.60(b)(3)) (corresponding with Section 611.301(b)) (antimony, beryllium, cyanide, nickel, and thallium)	January 17, 1994
Phase V VOCs (40 CFR 141.60(a)(3)) (corresponding with Section 611.311(a)) (dichloromethane, 1,2,4-trichlorobenzene, and 1,1,2-trichloroethane)	January 17, 1994
Phase V SOCs (40 CFR 141.60(a)(3)) (corresponding with Section 611.311(c)) (benzo(a)pyrene, dalapon, di(2-ethylhexyl)adipate, di(2-ethylhexyl)phthalate dinoseb, diquat, endothall, endrin, glyphosate, hexachlorobenzene, hexachlorocyclo- pentadiene, oxamyl, picloram, simazine, and 2,3,7,8-TCDD)	January 17, 1994
<u>Consumer Confidence Report Rule (40 CFR 141, Subpart Q)</u> (corresponding with Subpart O) (notification to public of drinking water quality)	September 18, 1998
<u>Interim Enhanced Surface Water Treatment Rule (40 CFR 141, Subpart P)</u> (corresponding with Subpart R) (applicable to suppliers providing water to fewer than 10,000 persons) (Giardia lamblia, viruses, heterotrophic plate count bacteria, Legionella, Cryptosporidium, and turbidity)	February 16, 1999
<u>Public Notification Rule (40 CFR 141, Subpart Q)</u> (corresponding with Subpart V) (notification to public of NPDWR violations, variances or exemptions, or other situations that could bear on public health)	June 5, 2000
<u>Filter Backwash Rule (40 CFR 141.76)</u> (corresponding with Section 611.276) (reuse of spent filter backwash water, thickener supernatant, or liquids from dewatering processes)	August 7, 2001
Disinfection/disinfectant byproducts (40 CFR 141.64 & 141.65) <u>Disinfection/Disinfectant Byproducts Rule (40 CFR 141.64, 141.65 & 141, Subpart L)</u> Smaller Systems (serving 10,000 or fewer persons) Larger Systems (serving more than 10,000 persons) (corresponding with Section 611.312 & 611.313) (total trihalomethanes, haloacetic acids (five), bromate, chlorite, chlorine, chloramines, and chlorine dioxide)	December 16, 2001 December 16, 2003

Long Term 1 Enhanced Surface Water Treatment Rule (40 CFR 141, Subpart T)

February 13, 2002

(corresponding with Subpart X)
(applicable to suppliers providing water to 10,000 or more persons)
(Giardia lamblia, viruses, heterotrophic plate count bacteria, Legionella,
Cryptosporidium, and turbidity)


Radionuclides (40 CFR 141.66) December 8, 2003
(corresponding with Section 611.330)
(combined radium (Ra-226 + Ra-228), gross alpha particle activity, beta particle and
photon activity, and uranium)

Arsenic (40 CFR 141.62(b)(16)) January 23, 2006
(corresponding with Section 611.301(b))
(arsenic)

(Source: Amended at 28 Ill. Reg. _____, effective _____)

IT IS SO ORDERED.

I, Dorothy M. Gunn, Clerk of the Illinois Pollution Control Board, certify that the Board adopted the above order on March 4, 2004, by a vote of 5-0.



Dorothy M. Gunn, Clerk
Illinois Pollution Control Board