

ILLINOIS POLLUTION CONTROL BOARD
January 21, 1988

B.F. GOODRICH CHEMICAL COMPANY,)
)
 Petitioner,)
)
 v.) PCB 88-20
)
 ILLINOIS ENVIRONMENTAL)
 PROTECTION AGENCY,)
)
 Respondent.)

ORDER OF THE BOARD (by J.D. Dumelle):

Petitioner seeks a 45-day Provisional Variance from the BOD and TSS limitations set forth at 35 Ill. Adm. Code 304.120 and 304.141(a). The Illinois Environmental Protection Agency (Agency) has found that compliance with Sections 304.120 and 304.141(a) would impose an arbitrary or unreasonable hardship and recommends that Petitioner be granted the requested variance. The Board hereby grants Petitioner a 45-day Provisional Variance until March 7, 1988, subject to the following conditions:


- a) This variance shall expire on March 8, 1988 or until debugging of the new biotreaters has been completed, whichever occurs first;
- b) Effluent discharge shall be limited to 60 mg/l BOD and 35 mg/l suspended solids as monthly averages. Daily maximums shall be 120 mg/l BOD and 70 mg/l suspended solids;
- c) During this Provisional Variance, Petitioner shall operate its wastewater treatment facility so as to produce the best effluent practicable. Petitioner shall use temporary carbon filters as much as possible to improve effluent quality;
- d) Within 10 days of the date of this Order, Petitioner shall execute and submit a Certificate of Acceptance and Agreement to the following address:

Illinois Environmental Protection Agency
Division of Water Pollution Control
Compliance Assurance Section
2200 Churchill Road
P.O. Box 19276
Springfield, IL 62794-9276

Attn: Jim Frost

IT IS SO ORDERED.

I, Dorothy M. Gunn, Clerk of the Illinois Pollution Control Board, hereby certify that the above Order was adopted on the 21st day of January, 1988 by a vote of 7-0.



Dorothy M. Gunn, Clerk
Illinois Pollution Control Board