

ILLINOIS POLLUTION CONTROL BOARD
September 25, 1986

VILLAGE OF HANOVER PARK,)
)
 Petitioner,)
)
 v.) PCB 86-142
)
 ILLINOIS ENVIRONMENTAL)
 PROTECTION AGENCY,)
)
 Respondent.)

ORDER OF THE BOARD (by B. Forcade):

On September 12, 1986, the Village of Hanover Park filed a Petition for Variance, seeking relief from regulations on restricted status and standards for permit issuance as those regulations pertain to limitations on combined Radium 226 and 228. This petition is deficient in that it:

Fails to provide sufficient information to allow the Board to determine if the users, most directly served by Wells Nos. 1 and 2, are currently receiving water with radium levels below 5 pCi/l. To evaluate this issue the Board would need two types of information. First, a map of the water supply and distribution system that would allow determinations of where the samples were taken in relation to the water supplies and mixing locations. Second the Board would need any additional sampling and analysis data on Radium concentrations in the wells and distribution system or a statement that no additional monitoring data exists.

Unless an amended petition is filed within 45 days curing the above-noted defect, this matter will be subject to dismissal.

IT IS SO ORDERED.

I, Dorothy M. Gunn, Clerk of the Illinois Pollution Control Board, hereby certify that the above Order was adopted on the 25th day of September, 1986, by a vote of 6-0.

Dorothy M. Gunn
Dorothy M. Gunn, Clerk
Illinois Pollution Control Board