



## OFFICE OF THE SECRETARY OF STATE

JESSE WHITE • Secretary of State

December 16, 2010

POLLUTION CONTROL BOARD  
JOHN THERRIAULT ASSISTANT CLERK  
100 W RANDOLPH ST, STE 11-500  
CHICAGO, IL 60601

**RECEIVED**  
CLERK'S OFFICE  
DEC. 21 2010  
STATE OF ILLINOIS  
Pollution Control Board

Dear JOHN THERRIAULT ASSISTANT CLERK

Your rules Listed below met our codification standards and have been published in Volume 34, Issue 52 of the Illinois Register, dated 12/27/2010.

**ADOPTED RULES**

Primary Drinking Water Standards  
35 Ill. Adm. Code 611 19848  
Point of Contact: Michael McCambridge

**PROPOSED RULES**

Nitrogen Oxides Emissions  
35 Ill. Adm. Code 217 19830  
Point of Contact: Nancy Miller

If you have any questions, you may contact the Administrative Code Division at (217) 782 - 7017.

ILLINOIS REGISTER

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

RECEIVED  
CLERK'S OFFICE  
DEC 21 2010  
STATE OF ILLINOIS  
Pollution Control Board

- 1) Heading of the Part: Primary Drinking Water Standards
- 2) Code citation: 35 Ill. Adm. Code 611
- 3) 

<u>Section numbers:</u>	<u>Adopted action:</u>
611.101	Amended
611.102	Amended
611.105	Amended
611.111	Amended
611.112	Amended
611.381	Amended
611.382	Amended
611.526	Amended
611.531	Amended
611.611	Amended
611.612	Amended
611.645	Amended
611.680	Amended
611.720	Amended
611.802	Amended
611.925	Amended
611.971	Amended
611.1004	Amended
- 4) Statutory authority: 415 ILCS 5/7.2, 17.5, and 27.
- 5) Effective date of amendments: DEC -7 2010
- 6) Does this rulemaking contain an automatic repeal date?: No.
- 7) Do these amendments contain incorporations by reference?

Yes. Section 611.102 is a centralized listing of all documents incorporated by reference for the purposes of 35 Ill. Adm. Code 611. Many of the amendments involve updated analytical methods that USEPA has approved for use in determining compliance with the National Primary Drinking Water Standards. All of the methods updates involve adding or revising incorporations by reference. In addition, the Board has found a limited number of corrections necessary to the existing incorporations by reference.

RECEIVED  
DEC 7 2010  
SOS-CODE DIV.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

8) Statement of availability:

The adopted amendments, a copy of the Board's opinion and order adopted December 2, 2010 in docket R10-1/R10-17/R11-6 (consolidated), and all materials incorporated by reference are on file at the Board's principal office and are available for public inspection and copying.

9) Notice of proposal published in the Illinois Register:

October 8, 2010, 34 Ill. Reg. 14841.

10) Has JCAR issued a statement of objections to these rules? No.

Section 17.5 of the Environmental Protection Act [415 ILCS 5/17.5] provides that Section 5-35 of the Administrative Procedure Act [5 ILCS 100/5-35] does not apply to this rulemaking. Because this rulemaking is not subject to Section 5-35 of the APA, it is not subject to First Notice or to Second Notice review by the Joint Committee on Administrative Rules (JCAR).

11) Differences between the proposal and the final version:

A table that appears in the Board's opinion and order of December 2, 2010 in docket R10-1/R10-17/R11-6 (consolidated) summarizes the differences between the amendments adopted in that order and those proposed by the Board in an opinion and order dated August 5, 2010, in docket R10-1/R10-17/R11-6 (consolidated). Many of the differences are explained in greater detail in the Board's December 2, 2010 opinion and order adopting the amendments.

The differences are limited to (1) the removal of provisions of proposed new 35 Ill. Adm. Code 611 Subpart AA, pertaining to the federal Aircraft Drinking Water Rule (ADWR), from the text; (2) minor clarifications and corrections throughout the text; and (3) the inadvertent omission of the proposed correction to Appendix F from the Board's December 2, 2010 order adopting these amendments.

USEPA and the Illinois EPA both commented on the proposed amendments to the effect that USEPA will itself implement the ADWR without involvement of the states. For this

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

reason, the Board has chosen to not adopt the new Subpart AA ADWR provisions included in the August 5, 2010 proposal.

The minor clarifications and corrections are intended to have no substantive effect. The intent is to add clarity to the rules without deviation from the substance of the federal amendments on which this proceeding is based.

The omission of the minor correction that the Board proposed for Appendix F was an error. The Appendix was inadvertently removed from the text of the Board's December 2, 2010 order adopting the amendments together with the text of proposed new Subpart AA. The Board will defer the minor correction to Appendix F until a future rulemaking proposal.

- 12) Have all the changes agreed upon by the Board and JCAR been made as indicated in the agreements issued by JCAR?

Section 17.5 of the Environmental Protection Act [415 ILCS 5/17.5] provides that Section 5-35 of the Administrative Procedure Act [5 ILCS 100/5-35] does not apply to this rulemaking. Because this rulemaking is not subject to Section 5-35 of the APA, it is not subject to First Notice or to Second Notice review by JCAR.

Since the Notices of Proposed Amendments appeared in the October 8, 2010 issue of the *Illinois Register*, the Board received a number of suggestions for revisions from JCAR. The Board evaluated each suggestion and incorporated a number of changes into the text as a result, as detailed in the opinion and order of December 2, 2010 in docket R10-1/R10-17/R11-6 (consolidated), as indicated in item 11 above. See the December 2, 2010 opinion and order in docket R10-1/R10-17/R11-6 (consolidated) for additional details on the JCAR suggestions and the Board actions with regard to each.

- 13) Will these amendments replace emergency amendments currently in effect? No.
- 14) Are there any other amendments pending on this Part? No.
- 15) Summary and purpose of amendments:

The following briefly describes the subjects and issues involved in the docket R10-1/R10-17/R11-6 (consolidated) rulemaking of which the amendments to Part 611 are a single segment. Also affected is 35 Ill. Adm. Code 611, which is covered by a separate notice in

ILLINOIS REGISTER

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

this issue of the Illinois Register. A comprehensive description is contained in the Board's opinion and order of December 2, 2010, adopting amendments in docket R10-1/R10-17/R11-6 (consolidated), which opinion and order is available from the address below.

This proceeding updates the Illinois Safe Drinking Water Act (SDWA) rules to correspond with amendments adopted by the United States Environmental Protection Agency (USEPA) that appeared in the Federal Register during a single update period. The docket and time period that is involved in this proceeding is the following:

R10-1	Federal SDWA amendments that occurred during the period January 1, 2009 through June 30, 2009.
R10-17	Federal SDWA amendments that occurred during the period July 1, 2009 through December 31, 2009.
R11-6	Federal SDWA amendments that occurred during the period January 1, 2010 through June 30, 2010.

The R10-1/R10-17/R11-6 docket amends rules in Part 611. The amendments to the various Parts are inter-related. The following table briefly summarizes the federal actions in the update period:

June 29, 2009 (74 Fed. Reg. 30953)	USEPA adopted a minor correction to the Stage 2 Disinfection and Disinfectant By-Products Rule (Stage 2 DDBPR) and made a minor editorial change in the drinking water analytical methods.
August 3, 2009 (74 Fed. Reg. 38348)	USEPA used its authority to use a summary procedure to approve alternative testing methods for use in demonstrating compliance with the drinking water standards.
October 19, 2009 (74 Fed. Reg. 53590)	USEPA adopted National Primary Drinking Water Regulations applicable to aircraft public water systems. (The Board did not adopt amendments based on the federal Aircraft Drinking Water Rule in response to comments from the Illinois EPA and USEPA, as is explained in the Board's December 2, 2010 opinion.)
November 10, 2009 (74 Fed. Reg. 57908)	USEPA used its authority to employ a summary procedure to approve alternative testing methods for use in demonstrating compliance with the drinking water

ILLINOIS REGISTER

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

	standards.
December 2, 2009 (74 Fed. Reg. 63069)	USEPA made a minor correction in its November 10, 2009 summary approval of drinking water analytical methods.
June 8, 2010 (75 Fed. Reg. 32295)	USEPA used its authority to employ a summary procedure to approve alternative testing methods for use in demonstrating compliance with the drinking water standards.

Tables appear in the Board's opinion and order of December 2, 2010 in docket R10-1/R10-17/R11-6 (consolidated) that list numerous corrections and amendments that are not based on current federal amendments. The tables contain deviations from the literal text of the federal amendments underlying these amendments, as well as corrections and clarifications that the Board made in the base text involved. Persons interested in the details of those corrections and amendments should refer to the December 2, 2010 opinion and order in docket R10-1/R10-17/R11-6 (consolidated).

Section 17.5 of the Environmental Protection Act [415 ILCS 5/17.5] provides that Section 5-35 of the Administrative Procedure Act [5 ILCS 100/5-35] does not apply to this rulemaking. Because this rulemaking is not subject to Section 5-35 of the APA, it is not subject to First Notice or to Second Notice review by the Joint Committee on Administrative Rules (JCAR).

- 16) Information and questions regarding these adopted amendments shall be adopted to:

Please reference consolidated docket R10-1/R10-17/R11-6 (consolidated) and direct inquiries to the following person:

Michael J. McCambridge  
Staff Attorney  
Illinois Pollution Control Board  
100 W. Randolph 11-500  
Chicago, IL 60601  
312-814-6924

Request copies of the Board's opinion and order of December 2, 2010 at 312-814-3620. Alternatively, you may obtain a copy of the Board's opinion and order from the Internet at <http://www.ipcb.state.il.us>.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

The full text of the adopted amendments begins on the next page:

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

TITLE 35: ENVIRONMENTAL PROTECTION  
SUBTITLE F: PUBLIC WATER SUPPLIES  
CHAPTER I: POLLUTION CONTROL BOARD

PART 611  
PRIMARY DRINKING WATER STANDARDS

SUBPART A: GENERAL

Section	
611.100	Purpose, Scope, and Applicability
611.101	Definitions
611.102	Incorporations by Reference
611.103	Severability
611.105	Electronic Reporting
611.107	Agency Inspection of PWS Facilities
611.108	Delegation to Local Government
611.109	Enforcement
611.110	Special Exception Permits
611.111	Relief Equivalent to SDWA Section 1415(a) Variances
611.112	Relief Equivalent to SDWA Section 1416 Exemptions
611.113	Alternative Treatment Techniques
611.114	Siting Requirements
611.115	Source Water Quantity
611.120	Effective Dates
611.121	Maximum Contaminant Levels and Finished Water Quality
611.125	Fluoridation Requirement
611.126	Prohibition on Use of Lead
611.130	Special Requirements for Certain Variances and Adjusted Standards
611.131	Relief Equivalent to SDWA Section 1415(e) Small System Variance
611.160	Composite Correction Program
611.161	Case-by-Case Reduced Subpart Y Monitoring for Wholesale and Consecutive Systems

SUBPART B: FILTRATION AND DISINFECTION

Section	
611.201	Requiring a Demonstration
611.202	Procedures for Agency Determinations
611.211	Filtration Required



ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- 611.212 Groundwater under Direct Influence of Surface Water
- 611.213 No Method of HPC Analysis
- 611.220 General Requirements
- 611.230 Filtration Effective Dates
- 611.231 Source Water Quality Conditions
- 611.232 Site-Specific Conditions
- 611.233 Treatment Technique Violations
- 611.240 Disinfection
- 611.241 Unfiltered PWSs
- 611.242 Filtered PWSs
- 611.250 Filtration
- 611.261 Unfiltered PWSs: Reporting and Recordkeeping
- 611.262 Filtered PWSs: Reporting and Recordkeeping
- 611.271 Protection during Repair Work
- 611.272 Disinfection Following Repair
- 611.276 Recycle Provisions

SUBPART C: USE OF NON-CENTRALIZED TREATMENT DEVICES

- Section
- 611.280 Point-of-Entry Devices
- 611.290 Use of Point-of-Use Devices or Bottled Water

SUBPART D: TREATMENT TECHNIQUES

- Section
- 611.295 General Requirements
- 611.296 Acrylamide and Epichlorohydrin
- 611.297 Corrosion Control

SUBPART F: MAXIMUM CONTAMINANT LEVELS (MCLs) AND  
MAXIMUM RESIDUAL DISINFECTANT LEVELS (MRDLs)

- Section
- 611.300 Old MCLs for Inorganic Chemical Contaminants
- 611.301 Revised MCLs for Inorganic Chemical Contaminants
- 611.310 State-Only Maximum Contaminant Levels (MCLs) for Organic Chemical Contaminants
- 611.311 Revised MCLs for Organic Chemical Contaminants
- 611.312 Maximum Contaminant Levels (MCLs) for Disinfection Byproducts (DBPs)
- 611.313 Maximum Residual Disinfectant Levels (MRDLs)

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- 611.320 Turbidity (Repealed)
- 611.325 Microbiological Contaminants
- 611.330 Maximum Contaminant Levels for Radionuclides
- 611.331 Beta Particle and Photon Radioactivity (Repealed)

SUBPART G: LEAD AND COPPER

- Section
- 611.350 General Requirements
- 611.351 Applicability of Corrosion Control
- 611.352 Corrosion Control Treatment
- 611.353 Source Water Treatment
- 611.354 Lead Service Line Replacement
- 611.355 Public Education and Supplemental Monitoring
- 611.356 Tap Water Monitoring for Lead and Copper
- 611.357 Monitoring for Water Quality Parameters
- 611.358 Monitoring for Lead and Copper in Source Water
- 611.359 Analytical Methods
- 611.360 Reporting
- 611.361 Recordkeeping

SUBPART I: DISINFECTANT RESIDUALS, DISINFECTION BYPRODUCTS,  
AND DISINFECTION BYPRODUCT PRECURSORS

- Section
- 611.380 General Requirements
- 611.381 Analytical Requirements
- 611.382 Monitoring Requirements
- 611.383 Compliance Requirements
- 611.384 Reporting and Recordkeeping Requirements
- 611.385 Treatment Technique for Control of Disinfection Byproduct (DBP) Precursors

SUBPART K: GENERAL MONITORING AND ANALYTICAL  
REQUIREMENTS

- Section
- 611.480 Alternative Analytical Techniques
- 611.490 Certified Laboratories
- 611.491 Laboratory Testing Equipment
- 611.500 Consecutive PWSs
- 611.510 Special Monitoring for Unregulated Contaminants (Repealed)

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

SUBPART L: MICROBIOLOGICAL MONITORING AND ANALYTICAL  
REQUIREMENTS

Section	
611.521	Routine Coliform Monitoring
611.522	Repeat Coliform Monitoring
611.523	Invalidation of Total Coliform Samples
611.524	Sanitary Surveys
611.525	Fecal Coliform and E. Coli Testing
611.526	Analytical Methodology
611.527	Response to Violation
611.531	Analytical Requirements
611.532	Unfiltered PWSs
611.533	Filtered PWSs

SUBPART M: TURBIDITY MONITORING AND ANALYTICAL  
REQUIREMENTS

Section	
611.560	Turbidity

SUBPART N: INORGANIC MONITORING AND ANALYTICAL  
REQUIREMENTS

Section	
611.591	Violation of a State MCL
611.592	Frequency of State Monitoring
611.600	Applicability
611.601	Monitoring Frequency
611.602	Asbestos Monitoring Frequency
611.603	Inorganic Monitoring Frequency
611.604	Nitrate Monitoring
611.605	Nitrite Monitoring
611.606	Confirmation Samples
611.607	More Frequent Monitoring and Confirmation Sampling
611.608	Additional Optional Monitoring
611.609	Determining Compliance
611.610	Inorganic Monitoring Times
611.611	Inorganic Analysis
611.612	Monitoring Requirements for Old Inorganic MCLs

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- 611.630 Special Monitoring for Sodium
- 611.631 Special Monitoring for Inorganic Chemicals (Repealed)

SUBPART O: ORGANIC MONITORING AND ANALYTICAL REQUIREMENTS

Section

- 611.640 Definitions
- 611.641 Old MCLs
- 611.645 Analytical Methods for Organic Chemical Contaminants
- 611.646 Phase I, Phase II, and Phase V Volatile Organic Contaminants
- 611.647 Sampling for Phase I Volatile Organic Contaminants (Repealed)
- 611.648 Phase II, Phase IIB, and Phase V Synthetic Organic Contaminants
- 611.650 Monitoring for 36 Contaminants (Repealed)
- 611.657 Analytical Methods for 36 Contaminants (Repealed)
- 611.658 Special Monitoring for Organic Chemicals (Repealed)

SUBPART P: THM MONITORING AND ANALYTICAL REQUIREMENTS

Section

- 611.680 Sampling, Analytical, and other Requirements
- 611.683 Reduced Monitoring Frequency (Repealed)
- 611.684 Averaging (Repealed)
- 611.685 Analytical Methods
- 611.686 Modification to System (Repealed)
- 611.687 Sampling for THM Potential (Repealed)
- 611.688 Applicability Dates (Repealed)

SUBPART Q: RADIOLOGICAL MONITORING AND ANALYTICAL  
REQUIREMENTS

Section

- 611.720 Analytical Methods
- 611.731 Gross Alpha
- 611.732 Beta Particle and Photon Radioactivity
- 611.733 General Monitoring and Compliance Requirements

SUBPART R: ENHANCED FILTRATION AND DISINFECTION: SYSTEMS  
THAT SERVE 10,000 OR MORE PEOPLE

Section

- 611.740 General Requirements
- 611.741 Standards for Avoiding Filtration

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- 611.742 Disinfection Profiling and Benchmarking
- 611.743 Filtration
- 611.744 Filtration Sampling Requirements
- 611.745 Reporting and Recordkeeping Requirements

SUBPART S: GROUNDWATER RULE

- Section
- 611.800 General Requirements and Applicability
- 611.801 Sanitary Surveys for GWS Suppliers
- 611.802 Groundwater Source Microbial Monitoring and Analytical Methods
- 611.803 Treatment Technique Requirements for GWS Suppliers
- 611.804 Treatment Technique Violations for GWS Suppliers
- 611.805 Reporting and Recordkeeping for GWS Suppliers

SUBPART T: REPORTING AND RECORDKEEPING

- Section
- 611.830 Applicability
- 611.831 Monthly Operating Report
- 611.832 Notice by Agency (Repealed)
- 611.833 Cross Connection Reporting
- 611.840 Reporting
- 611.851 Reporting MCL, MRDL, and other Violations (Repealed)
- 611.852 Reporting other Violations (Repealed)
- 611.853 Notice to New Billing Units (Repealed)
- 611.854 General Content of Public Notice (Repealed)
- 611.855 Mandatory Health Effects Language (Repealed)
- 611.856 Fluoride Notice (Repealed)
- 611.858 Fluoride Secondary Standard (Repealed)
- 611.860 Record Maintenance
- 611.870 List of 36 Contaminants (Repealed)

SUBPART U: CONSUMER CONFIDENCE REPORTS

- Section
- 611.881 Purpose and Applicability
- 611.882 Compliance Dates
- 611.883 Content of the Reports
- 611.884 Required Additional Health Information
- 611.885 Report Delivery and Recordkeeping

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

SUBPART V: PUBLIC NOTIFICATION OF DRINKING WATER  
VIOLATIONS

Section	
611.901	General Public Notification Requirements
611.902	Tier 1 Public Notice: Form, Manner, and Frequency of Notice
611.903	Tier 2 Public Notice: Form, Manner, and Frequency of Notice
611.904	Tier 3 Public Notice: Form, Manner, and Frequency of Notice
611.905	Content of the Public Notice
611.906	Notice to New Billing Units or New Customers
611.907	Special Notice of the Availability of Unregulated Contaminant Monitoring Results
611.908	Special Notice for Exceedence of the Fluoride Secondary Standard
611.909	Special Notice for Nitrate Exceedences above the MCL by a Non-Community Water System
611.910	Notice by the Agency on Behalf of a PWS
611.911	Special Notice for Cryptosporidium

SUBPART W: INITIAL DISTRIBUTION SYSTEM EVALUATIONS

Section	
611.920	General Requirements
611.921	Standard Monitoring
611.922	System-Specific Studies
611.923	40/30 Certification
611.924	Very Small System Waivers
611.925	Subpart Y Compliance Monitoring Location Recommendations

SUBPART X: ENHANCED FILTRATION AND DISINFECTION—SYSTEMS  
SERVING FEWER THAN 10,000 PEOPLE

Section	
611.950	General Requirements
611.951	Finished Water Reservoirs
611.952	Additional Watershed Control Requirements for Unfiltered Systems
611.953	Disinfection Profile
611.954	Disinfection Benchmark
611.955	Combined Filter Effluent Turbidity Limits
611.956	Individual Filter Turbidity Requirements
611.957	Reporting and Recordkeeping Requirements

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

SUBPART Y: STAGE 2 DISINFECTION BYPRODUCTS REQUIREMENTS

Section	
611.970	General Requirements
611.971	Routine Monitoring
611.972	Subpart Y Monitoring Plan
611.973	Reduced Monitoring
611.974	Additional Requirements for Consecutive Systems
611.975	Conditions Requiring Increased Monitoring
611.976	Operational Evaluation Levels
611.977	Requirements for Remaining on Reduced TTHM and HAA5 Monitoring Based on Subpart I Results
611.978	Requirements for Remaining on Increased TTHM and HAA5 Monitoring Based on Subpart I Results
611.979	Reporting and Recordkeeping Requirements

SUBPART Z: ENHANCED TREATMENT FOR CRYPTOSPORIDIUM

Section	
611.1000	General Requirements
611.1001	Source Water Monitoring Requirements: Source Water Monitoring
611.1002	Source Water Monitoring Requirements: Sampling Schedules
611.1003	Source Water Monitoring Requirements: Sampling Locations
611.1004	Source Water Monitoring Requirements: Analytical Methods
611.1005	Source Water Monitoring Requirements: Approved Laboratories
611.1006	Source Water Monitoring Requirements: Reporting Source Water Monitoring Results
611.1007	Source Water Monitoring Requirements: Grandfathering Previously Collected Data
611.1008	Disinfection Profiling and Benchmarking Requirements: Requirements When Making a Significant Change in Disinfection Practice
611.1009	Disinfection Profiling and Benchmarking Requirements: Developing the Disinfection Profile and Benchmark
611.1010	Treatment Technique Requirements: Bin Classification for Filtered Systems
611.1011	Treatment Technique Requirements: Filtered System Additional Cryptosporidium Treatment Requirements
611.1012	Treatment Technique Requirements: Unfiltered System Cryptosporidium Treatment Requirements

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- 611.1013 Treatment Technique Requirements: Schedule for Compliance with Cryptosporidium Treatment Requirements
- 611.1014 Treatment Technique Requirements: Requirements for Uncovered Finished Water Storage Facilities
- 611.1015 Requirements for Microbial Toolbox Components: Microbial Toolbox Options for Meeting Cryptosporidium Treatment Requirements
- 611.1016 Requirements for Microbial Toolbox Components: Source Toolbox Components
- 611.1017 Requirements for Microbial Toolbox Components: Pre-Filtration Treatment Toolbox Components
- 611.1018 Requirements for Microbial Toolbox Components: Treatment Performance Toolbox Components
- 611.1019 Requirements for Microbial Toolbox Components: Additional Filtration Toolbox Components
- 611.1020 Requirements for Microbial Toolbox Components: Inactivation Toolbox Components
- 611.1021 Reporting and Recordkeeping Requirements: Reporting Requirements
- 611.1022 Reporting and Recordkeeping Requirements: Recordkeeping Requirements
- 611.1023 Requirements to Respond to Significant Deficiencies Identified in Sanitary Surveys Performed by USEPA or the Agency
  
- 611.APPENDIX A Regulated Contaminants
- 611.APPENDIX B Percent Inactivation of G. Lamblia Cysts
- 611.APPENDIX C Common Names of Organic Chemicals
- 611.APPENDIX D Defined Substrate Method for the Simultaneous Detection of Total Coliforms and Eschericia Coli from Drinking Water
- 611.APPENDIX E Mandatory Lead Public Education Information for Community Water Systems
- 611.APPENDIX F Mandatory Lead Public Education Information for Non-Transient Non-Community Water Systems
- 611.APPENDIX G NPDWR Violations and Situations Requiring Public Notice
- 611.APPENDIX H Standard Health Effects Language for Public Notification
- 611.APPENDIX I Acronyms Used in Public Notification Regulation
- 611.TABLE A Total Coliform Monitoring Frequency
- 611.TABLE B Fecal or Total Coliform Density Measurements
- 611.TABLE C Frequency of RDC Measurement
- 611.TABLE D Number of Lead and Copper Monitoring Sites
- 611.TABLE E Lead and Copper Monitoring Start Dates
- 611.TABLE F Number of Water Quality Parameter Sampling Sites



ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

611.TABLE G	Summary of Section 611.357 Monitoring Requirements for Water Quality Parameters
611.TABLE H	CT Values (mg·min/ℓ) for Cryptosporidium Inactivation by Chlorine Dioxide
611.TABLE I	CT Values (mg·min/ℓ) for Cryptosporidium Inactivation by Ozone
611.TABLE J	UV Dose Table for Cryptosporidium, Giardia lamblia, and Virus Inactivation Credit
611.TABLE Z	Federal Effective Dates

AUTHORITY: Implementing Sections 7.2, 17, and 17.5 and authorized by Section 27 of the Environmental Protection Act [415 ILCS 5/7.2, 17, 17.5, and 27].

SOURCE: Adopted in R88-26 at 14 Ill. Reg. 16517, effective September 20, 1990; amended in R90-21 at 14 Ill. Reg. 20448, effective December 11, 1990; amended in R90-13 at 15 Ill. Reg. 1562, effective January 22, 1991; amended in R91-3 at 16 Ill. Reg. 19010, effective December 1, 1992; amended in R92-3 at 17 Ill. Reg. 7796, effective May 18, 1993; amended in R93-1 at 17 Ill. Reg. 12650, effective July 23, 1993; amended in R94-4 at 18 Ill. Reg. 12291, effective July 28, 1994; amended in R94-23 at 19 Ill. Reg. 8613, effective June 20, 1995; amended in R95-17 at 20 Ill. Reg. 14493, effective October 22, 1996; amended in R98-2 at 22 Ill. Reg. 5020, effective March 5, 1998; amended in R99-6 at 23 Ill. Reg. 2756, effective February 17, 1999; amended in R99-12 at 23 Ill. Reg. 10348, effective August 11, 1999; amended in R00-8 at 23 Ill. Reg. 14715, effective December 8, 1999; amended in R00-10 at 24 Ill. Reg. 14226, effective September 11, 2000; amended in R01-7 at 25 Ill. Reg. 1329, effective January 11, 2001; amended in R01-20 at 25 Ill. Reg. 13611, effective October 9, 2001; amended in R02-5 at 26 Ill. Reg. 3522, effective February 22, 2002; amended in R03-4 at 27 Ill. Reg. 1183, effective January 10, 2003; amended in R03-15 at 27 Ill. Reg. 16447, effective October 10, 2003; amended in R04-3 at 28 Ill. Reg. 5269, effective March 10, 2004; amended in R04-13 at 28 Ill. Reg. 12666, effective August 26, 2004; amended in R05-6 at 29 Ill. Reg. 2287, effective January 28, 2005; amended in R06-15 at 30 Ill. Reg. 17004, effective October 13, 2006; amended in R07-2/R07-11 at 31 Ill. Reg. 11757, effective July 27, 2007; amended in R08-7/R08-13 at 33 Ill. Reg. 633, effective December 30, 2008; amended in R10-1/R10-17/R11-6 at 34 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_.

SUBPART A: GENERAL

**Section 611.101 Definitions**

As used in this Part, the following terms have the given meanings:

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

“Act” means the Environmental Protection Act [415 ILCS 5].

“Agency” means the Illinois Environmental Protection Agency.

BOARD NOTE: The Department of Public Health (Public Health or DPH) regulates non-community water supplies (“non-CWSs,” including non-transient, non-community water supplies (“NTNCWSs”) and transient non-community water supplies (“transient non-CWSs”). ~~For the purposes of regulation of supplies by Public Health by reference to this Part,~~ “Agency” will mean ~~the Department of Public Health where implementation by Public Health occurs~~ with regard to non-CWS suppliers.

“Approved source of bottled water,” for the purposes of Section 611.130(d)(4), means a source of water and the water therefrom, whether it be from a spring, artesian well, drilled well, municipal water supply, or any other source, that has been inspected and the water sampled, analyzed, and found to be a safe and sanitary quality according to applicable laws and regulations of State and local government agencies having jurisdiction, as evidenced by the presence in the plant of current certificates or notations of approval from each government agency or agencies having jurisdiction over the source, the water it bottles, and the distribution of the water in commerce.

BOARD NOTE: Derived from 40 CFR 142.62(g)(2) and 21 CFR 129.3(a) ~~(2007)~~ (2010). The Board cannot compile an exhaustive listing of all federal, State, and local laws to which bottled water and bottling water may be subjected. However, the statutes and regulations of which the Board is aware are the following: the Illinois Food, Drug and Cosmetic Act [410 ILCS 620], the Bottled Water Act [815 ILCS 310], the DPH Water Well Construction Code (77 Ill. Adm. Code 920), the DPH Water Well Pump Installation Code (77 Ill. Adm. Code 925), the federal bottled water quality standards (21 CFR 103.35), the federal drinking water processing and bottling standards (21 CFR 129), the federal Current Good Manufacturing Practice in Manufacturing, Packing, or Holding Human Food (21 CFR 110), the federal Fair Packaging and Labeling Act (15 USC 1451 et seq.), and the federal Fair Packaging and Labeling regulations (21 CFR 201).

“Bag filters” means pressure-driven separation devices that remove particulate matter larger than one micrometer using an engineered porous filtration media. They are typically constructed of a non-rigid, fabric filtration media housed in a

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

pressure vessel in which the direction of flow is from the inside of the bag to outside.

“Bank filtration” means a water treatment process that uses a well to recover surface water that has naturally infiltrated into groundwater through a river bed or banks. Infiltration is typically enhanced by the hydraulic gradient imposed by a nearby pumping water supply or other wells.

“Best available technology” or “BAT” means the best technology, treatment techniques, or other means that USEPA has found are available for the contaminant in question. BAT is specified in Subpart F of this Part.

“Bin classification” or “bin” means, for the purposes of Subpart Z of this Part, the appropriate of the four treatment categories (Bin 1, Bin 2, Bin 3, or Bin 4) that is assigned to a filtered system supplier pursuant to Section 611.1010 based on the results of the source water Cryptosporidium monitoring described in the previous section. This bin classification determines the degree of additional Cryptosporidium treatment, if any, the filtered PWS must provide.

BOARD NOTE: Derived from 40 CFR 141.710 and the preamble discussion at 71 Fed. Reg. 654, 657 (Jan. 5, 2006).

“Board” means the Illinois Pollution Control Board.

“Cartridge filters” means pressure-driven separation devices that remove particulate matter larger than 1 micrometer using an engineered porous filtration media. They are typically constructed as rigid or semi-rigid, self-supporting filter elements housed in pressure vessels in which flow is from the outside of the cartridge to the inside.

“CAS No.” means “Chemical Abstracts Services Number.”

“CT” or “CT<sub>calc</sub>” is the product of “residual disinfectant concentration” (RDC or C) in mg/l determined before or at the first customer, and the corresponding “disinfectant contact time” (T) in minutes. If a supplier applies disinfectants at more than one point prior to the first customer, it must determine the CT of each disinfectant sequence before or at the first customer to determine the total percent inactivation or “total inactivation ratio.” In determining the total inactivation ratio, the supplier must determine the RDC of each disinfection sequence and

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

corresponding contact time before any subsequent disinfection application points.  
(See “CT<sub>99.9</sub>.”)

“CT<sub>99.9</sub>” is the CT value required for 99.9 percent (3-log) inactivation of *Giardia lamblia* cysts. CT<sub>99.9</sub> for a variety of disinfectants and conditions appear in Tables 1.1-1.6, 2.1 and 3.1 of Appendix B of this Part. (See “Inactivation Ratio.”)

BOARD NOTE: Derived from the definition of “CT” in 40 CFR 141.2-(2007) (2010).

“Coagulation” means a process using coagulant chemicals and mixing by which colloidal and suspended materials are destabilized and agglomerated into flocs.

“Combined distribution system” means the interconnected distribution system consisting of the distribution systems of wholesale systems and of the consecutive systems that receive finished water.

“Community water system” or “CWS” means a public water system (PWS) that serves at least 15 service connections used by year-round residents or regularly serves at least 25 year-round residents.

BOARD NOTE: This definition differs slightly from that of Section 3.05 of the Act.

“Compliance cycle” means the nine-year calendar year cycle during which public water systems (PWSs) must monitor. Each compliance cycle consists of three three-year compliance periods. The first calendar cycle began January 1, 1993, and ended December 31, 2001; the second began January 1, 2002, and ends December 31, 2010; the third begins January 1, 2011, and ends December 31, 2019.

“Compliance period” means a three-year calendar year period within a compliance cycle. Each compliance cycle has three three-year compliance periods. Within the first compliance cycle, the first compliance period ran from January 1, 1993 to December 31, 1995; the second from January 1, 1996 to December 31, 1998; the third from January 1, 1999 to December 31, 2001.

“Comprehensive performance evaluation” or “CPE” is a thorough review and analysis of a treatment plant’s performance-based capabilities and associated administrative, operation, and maintenance practices. It is conducted to identify factors that may be adversely impacting a plant’s capability to achieve compliance

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

and emphasizes approaches that can be implemented without significant capital improvements.

BOARD NOTE: The final sentence of the definition of “comprehensive performance evaluation” in 40 CFR 141.2 is codified as Section 611.160(a)(2), since it contains substantive elements that are more appropriately codified in a substantive provision.

“Confluent growth” means a continuous bacterial growth covering the entire filtration area of a membrane filter or a portion thereof, in which bacterial colonies are not discrete.

“Consecutive system” means a public water system that receives some or all of its finished water from one or more wholesale systems. Delivery may be through a direct connection or through the distribution system of one or more consecutive systems.

“Contaminant” means any physical, chemical, biological, or radiological substance or matter in water.

“Conventional filtration treatment” means a series of processes including coagulation, flocculation, sedimentation, and filtration resulting in substantial particulate removal.

“Diatomaceous earth filtration” means a process resulting in substantial particulate removal in which the following occur:

A precoat cake of diatomaceous earth filter media is deposited on a support membrane (septum); and

While the water is filtered by passing through the cake on the septum, additional filter media known as body feed is continuously added to the feed water to maintain the permeability of the filter cake.

“Direct filtration” means a series of processes including coagulation and filtration but excluding sedimentation resulting in substantial particulate removal.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

“Disinfectant” means any oxidant, including but not limited to chlorine, chlorine dioxide, chloramines, and ozone added to water in any part of the treatment or distribution process, that is intended to kill or inactivate pathogenic microorganisms.

“Disinfectant contact time” or “T” means the time in minutes that it takes for water to move from the point of disinfectant application or the previous point of RDC measurement to a point before or at the point where RDC is measured.

Where only one RDC is measured, T is the time in minutes that it takes for water to move from the point of disinfectant application to a point before or at the point where RDC is measured.

Where more than one RDC is measured, T is as follows:

For the first measurement of RDC, the time in minutes that it takes for water to move from the first or only point of disinfectant application to a point before or at the point where the first RDC is measured; and

For subsequent measurements of RDC, the time in minutes that it takes for water to move from the previous RDC measurement point to the RDC measurement point for which the particular T is being calculated.

T in pipelines must be calculated based on “plug flow” by dividing the internal volume of the pipe by the maximum hourly flow rate through that pipe.

T within mixing basins and storage reservoirs must be determined by tracer studies or an equivalent demonstration.

“Disinfection” means a process that inactivates pathogenic organisms in water by chemical oxidants or equivalent agents.

“Disinfection byproduct” or “DBP” means a chemical byproduct that forms when disinfectants used for microbial control react with naturally occurring compounds already present in source water. DBPs include, but are not limited to,

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

bromodichloromethane, bromoform, chloroform, dichloroacetic acid, bromate, chlorite, dibromochloromethane, and certain haloacetic acids.

“Disinfection profile” is a summary of daily *Giardia lamblia* inactivation through the treatment plant. The procedure for developing a disinfection profile is contained in Section 611.742.

“Distribution system” includes all points downstream of an “entry point” to the point of consumer ownership.

“Domestic or other non-distribution system plumbing problem” means a coliform contamination problem in a PWS with more than one service connection that is limited to the specific service connection from which the coliform-positive sample was taken.

“Dose equivalent” means the product of the absorbed dose from ionizing radiation and such factors as account for differences in biological effectiveness due to the type of radiation and its distribution in the body as specified by the International Commission on Radiological Units and Measurements (ICRU).

“Dual sample set” means a set of two samples collected at the same time and same location, with one sample analyzed for TTHM and the other sample analyzed for HAA5. Dual sample sets are collected for the purposes of conducting an IDSE under Subpart W of this Part and determining compliance with the TTHM and HAA5 MCLs under Subpart Y of this Part.

“Enhanced coagulation” means the addition of sufficient coagulant for improved removal of disinfection byproduct (DBP) precursors by conventional filtration treatment.

“Enhanced softening” means the improved removal of disinfection byproduct (DBP) precursors by precipitative softening.

“Entry point” means a point just downstream of the final treatment operation, but upstream of the first user and upstream of any mixing with other water. If raw water is used without treatment, the “entry point” is the raw water source. If a PWS receives treated water from another PWS, the “entry point” is a point just

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

downstream of the other PWS, but upstream of the first user on the receiving PWS, and upstream of any mixing with other water.

“Filter profile” is a graphical representation of individual filter performance, based on continuous turbidity measurements or total particle counts versus time for an entire filter run, from startup to backwash inclusively, that includes an assessment of filter performance while another filter is being backwashed.

“Filtration” means a process for removing particulate matter from water by passage through porous media.

“Finished water” means water that is introduced into the distribution system of a public water system which is intended for distribution and consumption without further treatment, except that treatment which is necessary to maintain water quality in the distribution system (e.g., booster disinfection, addition of corrosion control chemicals, etc.).

“Flocculation” means a process to enhance agglomeration or collection of smaller floc particles into larger, more easily settleable particles through gentle stirring by hydraulic or mechanical means.

“Flowing stream” means a course of running water flowing in a definite channel.

“40/30 certification” means the certification, submitted by the supplier to the Agency pursuant to Section 611.923, that the supplier had no TTHM or HAA5 monitoring violations, and that no individual sample from its system exceeded 0.040 mg/l TTHM or 0.030 mg/l HAA5 during eight consecutive calendar quarters.

BOARD NOTE: Derived from 40 CFR 141.603(a) ~~(2007)~~ (2010).

“GAC10” means granular activated carbon (GAC) filter beds with an empty-bed contact time of 10 minutes based on average daily flow and a carbon reactivation frequency of every 180 days, except that the reactivation frequency for GAC10 that is used as a best available technology for compliance with the MCLs set forth in Subpart Y of this Part pursuant to Section 611.312(b)(2) is 120 days.



---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

“GAC20” means granular activated carbon filter beds with an empty-bed contact time of 20 minutes based on average daily flow and a carbon reactivation frequency of every 240 days.

“GC” means “gas chromatography” or “gas-liquid phase chromatography.”

“GC/MS” means gas chromatography (GC) followed by mass spectrometry (MS).

“Gross alpha particle activity” means the total radioactivity due to alpha particle emission as inferred from measurements on a dry sample.

“Gross beta particle activity” means the total radioactivity due to beta particle emission as inferred from measurements on a dry sample.

“Groundwater system” or “GWS” means a public water supply (PWS) that uses only groundwater sources, including a consecutive system that receives finished groundwater.

BOARD NOTE: Derived from 40 CFR 141.23(b)(2) and 141.24(f)(2) note and 40 CFR 141.400(b)-(2007) (2010).

“Groundwater under the direct influence of surface water” means any water beneath the surface of the ground with significant occurrence of insects or other macroorganisms, algae, or large-diameter pathogens, such as *Giardia lamblia* or *Cryptosporidium*, or significant and relatively rapid shifts in water characteristics, such as turbidity, temperature, conductivity, or pH, that closely correlate to climatological or surface water conditions. “Groundwater under the direct influence of surface water” is as determined in Section 611.212.

“Haloacetic acids (five)” or “HAA5” means the sum of the concentrations in milligrams per liter (mg/ℓ) of five haloacetic acid compounds (monochloroacetic acid, dichloroacetic acid, trichloroacetic acid, monobromoacetic acid, and dibromoacetic acid), rounded to two significant figures after addition.

“Halogen” means one of the chemical elements chlorine, bromine, or iodine.

“HPC” means “heterotrophic plate count,” measured as specified in Section 611.531(c).

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

“Hydrogeologic sensitivity assessment,” for the purposes of Subpart S of this Part, means a determination of whether a GWS supplier obtains water from a hydrogeologically sensitive setting.

BOARD NOTE: Derived from 40 CFR 141.400(c)(5)-(2007) (2010).

“Inactivation ratio” or “Ai” means as follows:

$$A_i = CT_{\text{calc}}/CT_{99.9}$$

The sum of the inactivation ratios, or “total inactivation ratio” (B), is calculated by adding together the inactivation ratio for each disinfection sequence as follows:

$$B = \sum(A_i)$$

A total inactivation ratio equal to or greater than 1.0 is assumed to provide a 3-log inactivation of *Giardia lamblia* cysts.

BOARD NOTE: Derived from the definition of “CT” in 40 CFR 141.2-(2007) (2010).

“Initial compliance period” means the three-year compliance period that begins January 1, 1993, except for the MCLs for dichloromethane, 1,2,4-trichlorobenzene, 1,1,2-trichloroethane, benzo(a)pyrene, dalapon, di(2-ethylhexyl)adipate, di(2-ethylhexyl)phthalate, dinoseb, diquat, endothall, endrin, glyphosate, hexachlorobenzene, hexachlorocyclopentadiene, oxamyl, picloram, simazine, 2,3,7,8-TCDD, antimony, beryllium, cyanide, nickel, and thallium, as they apply to a supplier whose system has fewer than 150 service connections, for which it means the three-year compliance period that began on January 1, 1996.

“Initial distribution system evaluation” or “IDSE” means the evaluation, performed by the supplier pursuant to Section 611.921(c), to determine the locations in a distribution system that are representative of high TTHM and HAA5 concentrations throughout the distribution system. An IDSE is used in conjunction with, but is distinct from, the compliance monitoring undertaken to identify and select monitoring locations used to determine compliance with Subpart I of this Part.

BOARD NOTE: Derived from 40 CFR 141.601(c)-(2007) (2010).

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

“Inorganic contaminants” or “IOCs” refers to that group of contaminants designated as such in United States Environmental Protection Agency (USEPA) regulatory discussions and guidance documents. IOCs include antimony, arsenic, asbestos, barium, beryllium, cadmium, chromium, cyanide, mercury, nickel, nitrate, nitrite, selenium, and thallium.

BOARD NOTE: The IOCs are derived from 40 CFR 141.23(a)(4)-~~(2007)~~ (2010).

“ℓ” means “liter.”

“Lake or reservoir” means a natural or man made basin or hollow on the Earth’s surface in which water collects or is stored that may or may not have a current or single direction of flow.

“Legionella” means a genus of bacteria, some species of which have caused a type of pneumonia called Legionnaires Disease.

“Locational running annual average” or “LRAA” means the average of sample analytical results for samples taken at a particular monitoring location during the previous four calendar quarters.

“Man-made beta particle and photon emitters” means all radionuclides emitting beta particles or photons listed in “Maximum Permissible Body Burdens and Maximum Permissible Concentrations of Radionuclides in Air and in Water for Occupational Exposure,” NCRP Report Number 22, incorporated by reference in Section 611.102, except the daughter products of thorium-232, uranium-235 and uranium-238.

“Maximum contaminant level” or “MCL” means the maximum permissible level of a contaminant in water that is delivered to any user of a public water system. (See Section 611.121.)

“Maximum contaminant level goal” or “MCLG” means the maximum level of a contaminant in drinking water at which no known or anticipated adverse effect on the health of persons would occur, and which allows an adequate margin of safety. MCLGs are nonenforceable health goals.

BOARD NOTE: The Board has not routinely adopted the regulations relating to the federal MCLGs because they are outside the scope of the Board’s identical-in-substance mandate under Section 17.5 of the Act [415 ILCS 5/17.5].

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

“Maximum residual disinfectant level” or “MRDL” means the maximum permissible level of a disinfectant added for water treatment that may not be exceeded at the consumer’s tap without an unacceptable possibility of adverse health effects. MRDLs are enforceable in the same manner as are MCLs. (See Section 611.313 and Section 611.383.)

“Maximum residual disinfectant level goal” or “MRDLG” means the maximum level of a disinfectant added for water treatment at which no known or anticipated adverse effect on the health of persons would occur, and which allows an adequate margin of safety. MRDLGs are nonenforceable health goals and do not reflect the benefit of the addition of the chemical for control of waterborne microbial contaminants.

“Maximum total trihalomethane potential” or “MTP” means the maximum concentration of total trihalomethanes (TTHMs) produced in a given water containing a disinfectant residual after seven days at a temperature of 25° C or above.

“Membrane filtration” means a pressure or vacuum driven separation process in which particulate matter larger than one micrometer is rejected by an engineered barrier, primarily through a size exclusion mechanism, and which has a measurable removal efficiency of a target organism that can be verified through the application of a direct integrity test. This definition includes the common membrane technologies of microfiltration, ultrafiltration, nanofiltration, and reverse osmosis.

“MFL” means millions of fibers per liter larger than 10 micrometers.  
BOARD NOTE: Derived from 40 CFR 141.23(a)(4)(i) ~~(2007)~~ (2010).

“mg” means milligrams (1/1000 of a gram).

“mg/l” means milligrams per liter.

“Mixed system” means a PWS that uses both groundwater and surface water sources.

BOARD NOTE: Drawn from 40 CFR 141.23(b)(2) and 141.24(f)(2) note ~~(2007)~~ (2010).

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

“MUG” means 4-methyl-umbelliferyl-beta-d-glucuronide.

“Near the first service connection” means at one of the 20 percent of all service connections in the entire system that are nearest the public water system (PWS) treatment facility, as measured by water transport time within the distribution system.

“nm” means nanometer (1/1,000,000,000 of a meter).

“Non-community water system” or “NCWS” or “non-CWS” means a public water system (PWS) that is not a community water system (CWS). A non-community water system is either a “transient non-community water system (TWS)” or a “non-transient non-community water system (NTNCWS).”

“Non-transient, non-community water system” or “non-transient, non-CWS” or “NTNCWS” means a public water system (PWS) that is not a community water system (CWS) and that regularly serves at least 25 of the same persons over six months per year.

“NPDWR” means “national primary drinking water regulation.”

“NTU” means “nephelometric turbidity units.”

“Old MCL” means one of the inorganic maximum contaminant levels (MCLs), codified at Section 611.300, or organic MCLs, codified at Section 611.310, including any marked as “additional State requirements.”

BOARD NOTE: Old MCLs are those derived prior to the implementation of the USEPA “Phase II” regulations. The Section 611.640 definition of this term, which applies only to Subpart O of this Part, differs from this definition in that the definition does not include the Section 611.300 inorganic MCLs.

“P-A Coliform Test” means “Presence-Absence Coliform Test.”

“Paired sample” means two samples of water for Total Organic Carbon (TOC). One sample is of raw water taken prior to any treatment. The other sample is taken after the point of combined filter effluent and is representative of the treated water. These samples are taken at the same time. (See Section 611.382.)

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

“Performance evaluation sample” or “PE sample” means a reference sample provided to a laboratory for the purpose of demonstrating that the laboratory can successfully analyze the sample within limits of performance specified by the Agency; or, for bacteriological laboratories, Public Health; or, for radiological laboratories, the Illinois Department of Nuclear Safety. The true value of the concentration of the reference material is unknown to the laboratory at the time of the analysis.

“Person” means an individual, corporation, company, association, partnership, state, unit of local government, or federal agency.

“Phase I” refers to that group of chemical contaminants and the accompanying regulations promulgated by USEPA on July 8, 1987, at 52 Fed. Reg. 25712.

“Phase II” refers to that group of chemical contaminants and the accompanying regulations promulgated by USEPA on January 30, 1991, at 56 Fed. Reg. 3578.

“Phase IIB” refers to that group of chemical contaminants and the accompanying regulations promulgated by USEPA on July 1, 1991, at 56 Fed. Reg. 30266.

“Phase V” refers to that group of chemical contaminants promulgated by USEPA on July 17, 1992, at 57 Fed. Reg. 31776.

“Picocurie” or “pCi” means the quantity of radioactive material producing 2.22 nuclear transformations per minute.

“Plant intake” means the works or structures at the head of a conduit through which water is diverted from a source (e.g., a river or lake) into the treatment plant.

“Point of disinfectant application” is the point at which the disinfectant is applied and downstream of which water is not subject to recontamination by surface water runoff.

“Point-of-entry treatment device” or “POE” is a treatment device applied to the drinking water entering a house or building for the purpose of reducing contaminants in the drinking water distributed throughout the house or building.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

“Point-of-use treatment device” or “POU” is a treatment device applied to a single tap used for the purpose of reducing contaminants in drinking water at that one tap.

“Presedimentation” means a preliminary treatment process used to remove gravel, sand, and other particulate material from the source water through settling before the water enters the primary clarification and filtration processes in a treatment plant.

“Public Health” or “DPH” means the Illinois Department of Public Health.  
BOARD NOTE: ~~The Department of Public Health (“Public Health”) regulates non-community water supplies (“non-CWSs,” including non-transient, non-community water supplies (“NTNCWSs”) and transient non-community water supplies (“transient non-CWSs”). For the purposes of regulation of supplies by Public Health by reference to this Part, See the definition of “Agency” must mean Public Health in this Section.~~

“Public water system” or “PWS” means a system for the provision to the public of water for human consumption through pipes or other constructed conveyances, if such system has at least 15 service connections or regularly serves an average of at least 25 individuals daily at least 60 days out of the year. A PWS is either a community water system (CWS) or a non-community water system (non-CWS). A PWS does not include any facility defined as “special irrigation district.” Such term includes the following:

Any collection, treatment, storage, and distribution facilities under control of the operator of such system and used primarily in connection with such system; and

Any collection or pretreatment storage facilities not under such control that are used primarily in connection with such system.

BOARD NOTE: Where used in Subpart F of this Part, “public water supply” means the same as “public water system.”

“Radioactive contaminants” refers to that group of contaminants designated “radioactive contaminants” in USEPA regulatory discussions and guidance documents. “Radioactive contaminants” include tritium, strontium-89, strontium-90, iodine-131, cesium-134, gross beta emitters, and other nuclides.

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

BOARD NOTE: Derived from 40 CFR 141.25(c) Table B-~~(2007)~~ (2010). These radioactive contaminants must be reported in Consumer Confidence Reports under Subpart U of this Part when they are detected above the levels indicated in Section 611.720(c)(3).

“Reliably and consistently” below a specified level for a contaminant means an Agency determination based on analytical results following the initial detection of a contaminant to determine the qualitative condition of water from an individual sampling point or source. The Agency must base this determination on the consistency of analytical results, the degree below the MCL, the susceptibility of source water to variation, and other vulnerability factors pertinent to the contaminant detected that may influence the quality of water.

BOARD NOTE: Derived from 40 CFR 141.23(b)(9), 141.24(f)(11)(ii), and 141.24(f)(11)(iii)-~~(2007)~~ (2010).

“Rem” means the unit of dose equivalent from ionizing radiation to the total body or any internal organ or organ system. A “millirem (mrem)” is 1/1000 of a rem.

“Repeat compliance period” means a compliance period that begins after the initial compliance period.

“Representative” means that a sample must reflect the quality of water that is delivered to consumers under conditions when all sources required to supply water under normal conditions are in use and all treatment is properly operating.

“Residual disinfectant concentration” (“RDC” or “C” in CT calculations) means the concentration of disinfectant measured in mg/l in a representative sample of water. For purposes of the requirement of Section 611.241(d) of maintaining a detectable RDC in the distribution system, “RDC” means a residual of free or combined chlorine.

“Safe Drinking Water Act” or “SDWA” means the Public Health Service Act, as amended by the Safe Drinking Water Act, Pub. L. 93-523, 42 USC 300f et seq.

“Sanitary survey” means an onsite review of the delineated WHPAs (identifying sources of contamination within the WHPAs and evaluations or the hydrogeologic sensitivity of the delineated WHPAs conducted under source water assessments or utilizing other relevant information where available), facilities, equipment,



---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

operation, maintenance, and monitoring compliance of a public water system (PWS) to evaluate the adequacy of the system, its sources, and operations for the production and distribution of safe drinking water.

BOARD NOTE: Derived from 40 CFR 141.2 and 40 CFR 142.16(o)(2)-(2007) (2010).

“Sedimentation” means a process for removal of solids before filtration by gravity or separation.

“SEP” means special exception permit (Section 611.110).

“Service connection,” as used in the definition of public water system, does not include a connection to a system that delivers water by a constructed conveyance other than a pipe if any of the following is true:

The water is used exclusively for purposes other than residential use (consisting of drinking, bathing, and cooking, or other similar uses);

The Agency determines by issuing a SEP that alternative water for residential use or similar uses for drinking and cooking is provided to achieve the equivalent level of public health protection provided by the applicable national primary drinking water regulations; or

The Agency determines by issuing a SEP that the water provided for residential use or similar uses for drinking, cooking, and bathing is centrally treated or treated at the point of entry by the provider, a pass-through entity, or the user to achieve the equivalent level of protection provided by the applicable national primary drinking water regulations.

BOARD NOTE: See sections 1401(4)(B)(i)(II) and (4)(B)(i)(III) of SDWA (42 USC 300f(4)(B)(i)(II) and (4)(B)(i)(III) (2000)).

“Significant deficiency” means a deficiency identified by the Agency in a groundwater system pursuant to Section 611.803. A significant deficiency might include, but is not limited to, a defect in system design, operation, or maintenance or a failure or malfunction of the sources, treatment, storage, or distribution system that the Agency determines to be causing or have potential for causing the introduction of contamination into the water delivered to consumers.

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

BOARD NOTE: Derived from 40 CFR 142.16(o)(2)(iv) ~~(2007)~~ (2010). The Agency must submit to USEPA a definition and description of at least one significant deficiency in each of the eight sanitary survey elements listed in Section 611.801(c) as part of the federal primacy requirements. The Board added the general description of what a significant deficiency might include in non-limiting terms, in order to provide this important definition within the body of the Illinois rules. No Agency submission to USEPA can provide definition within the context of Board regulations.

“Slow sand filtration” means a process involving passage of raw water through a bed of sand at low velocity (generally less than 0.4 meters per hour (m/h)) resulting in substantial particulate removal by physical and biological mechanisms.

“SOC” or “Synthetic organic chemical contaminant” refers to that group of contaminants designated as “SOCs,” or “synthetic organic chemicals” or “synthetic organic contaminants,” in USEPA regulatory discussions and guidance documents. “SOCs” include alachlor, aldicarb, aldicarb sulfone, aldicarb sulfoxide, atrazine, benzo(a)pyrene, carbofuran, chlordane, dalapon, dibromoethylene (ethylene dibromide or EDB), dibromochloropropane (DBCP), di(2-ethylhexyl)adipate, di(2-ethylhexyl)phthalate, dinoseb, diquat, endothall, endrin, glyphosate, heptachlor, heptachlor epoxide, hexachlorobenzene, hexachlorocyclopentadiene, lindane, methoxychlor, oxamyl, pentachlorophenol, picloram, simazine, toxaphene, polychlorinated biphenyls (PCBs), 2,4-D, 2,3,7,8-TCDD, and 2,4,5-TP.

BOARD NOTE: See the Board note appended to Section 611.311 for information relating to implementation of requirements relating to aldicarb, aldicarb sulfone, and aldicarb sulfoxide.

“Source” means a well, reservoir, or other source of raw water.

“Special irrigation district” means an irrigation district in existence prior to May 18, 1994 that provides primarily agricultural service through a piped water system with only incidental residential use or similar use, where the system or the residential users or similar users of the system comply with either of the following exclusion conditions:

The Agency determines by issuing a SEP that alternative water is provided for residential use or similar uses for drinking or cooking to achieve the

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

equivalent level of public health protection provided by the applicable national primary drinking water regulations; or

The Agency determines by issuing a SEP that the water provided for residential use or similar uses for drinking, cooking, and bathing is centrally treated or treated at the point of entry by the provider, a pass-through entity, or the user to achieve the equivalent level of protection provided by the applicable national primary drinking water regulations.

BOARD NOTE: Derived from 40 CFR 141.2-~~(2007)~~ (2010) and sections 1401(4)(B)(i)(II) and (4)(B)(i)(III) of SDWA (42 USC 300f(4)(B)(i)(II) and (4)(B)(i)(III)-~~(2007)~~ (2006)).

“Standard monitoring” means the monitoring, performed by the supplier pursuant to Section 611.921(a) and (b), at various specified locations in a distribution system including near entry points, at points that represent the average residence time in the distribution system, and at points in the distribution system that are representative of high TTHM and HAA5 concentrations throughout the distribution system.

BOARD NOTE: Derived from 40 CFR 141.601(a) and (b)-~~(2007)~~ (2010).

“Standard sample” means the aliquot of finished drinking water that is examined for the presence of coliform bacteria.

“Subpart B system” means a public water system that uses surface water or groundwater under the direct influence of surface water as a source and which is subject to the requirements of Subpart B of this Part and the analytical and monitoring requirements of Sections 611.531, 611.532, 611.533, Appendix B of this Part, and Appendix C of this Part.

“Subpart I compliance monitoring” means monitoring required to demonstrate compliance with disinfectant residuals, disinfection byproducts, and disinfection byproduct precursors requirements of Subpart I of this Part.

“Subpart I system” means a public water system that uses surface water or groundwater as a source and which is subject to the disinfectant residuals, disinfection byproducts, and disinfection byproduct precursors requirements of Subpart I of this Part.

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

“Subpart Y compliance monitoring” means monitoring required to demonstrate compliance with Stage 2 disinfection byproducts requirements of Subpart Y of this Part.

“Supplier of water” or “supplier” means any person who owns or operates a public water system (PWS). This term includes the “official custodian.”

“Surface water” means all water that is open to the atmosphere and subject to surface runoff.

“SUVA” means specific ultraviolet absorption at 254 nanometers (nm), which is an indicator of the humic content of water. It is a calculated parameter obtained by dividing a sample’s ultraviolet absorption at a wavelength of 254 nm ( $UV_{254}$ ) (in  $m^{-1}$ ) by its concentration of dissolved organic carbon (in mg/ℓ).

“SWS” means “surface water system,” a public water supply (PWS) that uses only surface water sources, including “groundwater under the direct influence of surface water.”

BOARD NOTE: Derived from 40 CFR 141.23(b)(2) and 141.24(f)(2) note ~~(2007)~~ (2010).

“System-specific study plan” means the plan, submitted by the supplier to the Agency pursuant to Section 611.922, for studying the occurrence of TTHM and HAA5 in a supplier’s distribution system based on either monitoring results or modelling of the system.

BOARD NOTE: Derived from 40 CFR 141.602-~~(2007)~~ (2010).

“System with a single service connection” means a system that supplies drinking water to consumers via a single service line.

“Too numerous to count” means that the total number of bacterial colonies exceeds 200 on a 47-mm diameter membrane filter used for coliform detection.

“Total organic carbon” or “TOC” means total organic carbon (in mg/ℓ) measured using heat, oxygen, ultraviolet irradiation, chemical oxidants, or combinations of these oxidants that convert organic carbon to carbon dioxide, rounded to two significant figures.

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

“Total trihalomethanes” or “TTHM” means the sum of the concentration of trihalomethanes (THMs), in milligrams per liter (mg/ℓ), rounded to two significant figures.

BOARD NOTE: See the definition of “trihalomethanes” for a listing of the four compounds that USEPA considers TTHMs to comprise.

“Transient, non-community water system” or “transient non-CWS” means a non-CWS that does not regularly serve at least 25 of the same persons over six months of the year.

BOARD NOTE: The federal regulations apply to all “public water systems,” which are defined as all systems that have at least 15 service connections or which regularly serve water to at least 25 persons. (See 42 USC 300f(4).) The Act mandates that the Board and the Agency regulate “public water supplies,” which it defines as having at least 15 service connections or regularly serving 25 persons daily at least 60 days per year. (See Section 3.28 of the Act [415 ILCS 5/3.28].) The Department of Public Health regulates transient, non-community water systems.

“Treatment” means any process that changes the physical, chemical, microbiological, or radiological properties of water, is under the control of the supplier, and is not a point-of-use treatment device or a point-of-entry treatment device as defined in this Section. Treatment includes, but is not limited to, aeration, coagulation, sedimentation, filtration, activated carbon treatment, disinfection, and fluoridation.

“Trihalomethane” or “THM” means one of the family of organic compounds, named as derivatives of methane, in which three of the four hydrogen atoms in methane are each substituted by a halogen atom in the molecular structure. The THMs are the following compounds:

Trichloromethane (chloroform),

Dibromochloromethane,

Bromodichloromethane, and

Tribromomethane (bromoform)

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

“Two-stage lime softening” means a process in which chemical addition and hardness precipitation occur in each of two distinct unit clarification processes in series prior to filtration.

“µg” means micrograms (1/1,000,000 of a gram).

“USEPA” means the U.S. Environmental Protection Agency.

“Uncovered finished water storage facility” is a tank, reservoir, or other facility that is used to store water which will undergo no further treatment to reduce microbial pathogens except residual disinfection and which is directly open to the atmosphere.

“Very small system waiver” means the conditional waiver from the requirements of Subpart W of this Part applicable to a supplier that serves fewer than 500 persons and which has taken TTHM and HAA5 samples pursuant to Subpart I of this Part.

BOARD NOTE: Derived from 40 CFR 141.604 ~~(2007)~~ (2010).

“Virus” means a virus of fecal origin that is infectious to humans by waterborne transmission.

“VOC” or “volatile organic chemical contaminant” refers to that group of contaminants designated as “VOCs,” “volatile organic chemicals,” or “volatile organic contaminants,” in USEPA regulatory discussions and guidance documents. “VOCs” include benzene, dichloromethane, tetrachloromethane (carbon tetrachloride), trichloroethylene, vinyl chloride, 1,1,1-trichloroethane (methyl chloroform), 1,1-dichloroethylene, 1,2-dichloroethane, cis-1,2-dichloroethylene, ethylbenzene, monochlorobenzene, o-dichlorobenzene, styrene, 1,2,4-trichlorobenzene, 1,1,2-trichloroethane, tetrachloroethylene, toluene, trans-1,2-dichloroethylene, xylene, and 1,2-dichloropropane.

“Waterborne disease outbreak” means the significant occurrence of acute infectious illness, epidemiologically associated with the ingestion of water from a public water system (PWS) that is deficient in treatment, as determined by the appropriate local or State agency.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

“Wellhead protection area” or “WHPA” means the surface and subsurface recharge area surrounding a community water supply well or well field, delineated outside of any applicable setback zones (pursuant to Section 17.1 of the Act [415 ILCS 5/17.1]) pursuant to Illinois’ Wellhead Protection Program, through which contaminants are reasonably likely to move toward such well or well field.

BOARD NOTE: The Agency uses two guidance documents for identification of WHPAs:

“Guidance Document for Groundwater Protection Needs Assessments,” Illinois Environmental Protection Agency, Illinois State Water Survey, and Illinois State Geologic Survey joint report, January 1995; and

“The Illinois Wellhead Protection Program Pursuant to Section 1428 of the Federal Safe Drinking Water Act,” Illinois Environmental Protection Agency, No. 22480, October 1992.

“Wellhead protection program” means the wellhead protection program for the State of Illinois, approved by USEPA under Section 1428 of the SDWA, 42 USC 300h-7. BOARD NOTE: Derived from 40 CFR 141.71(b) ~~(2007)~~ (2010). The wellhead protection program includes the “groundwater protection needs assessment” under Section 17.1 of the Act [415 ILCS 5/17.1] and 35 Ill. Adm. Code 615-617.

“Wholesale system” means a public water system that treats source water as necessary to produce finished water, which then delivers some or all of that finished water to another public water system. Delivery by a wholesale system may be through a direct connection or through the distribution system of one or more consecutive systems.

BOARD NOTE: Derived from 40 CFR 141.2 ~~(2007)~~ (2010).

(Source: Amended at 34 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

**Section 611.102 Incorporations by Reference**

- a) Abbreviations and short-name listing of references. The following names and abbreviated names, presented in alphabetical order, are used in this Part to refer to materials incorporated by reference:

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

“AMI Turbiwell Method” means “Continuous Measurement of Turbidity Using a SWAN AMI Turbiwell Turbidimeter,” available from NEMI or from SWAN Analytische Instrumente AG.

“ASTM Method” means a method published by and available from the American Society for Testing and Materials (ASTM).

“Colisure Test” means “Colisure Presence/Absence Test for Detection and Identification of Coliform Bacteria and Escherichia Coli in Drinking Water,” available from Millipore Corporation, Technical Services Department.

“Colitag® Test” means “Colitag® Product as a Test for Detection and Identification of Coliforms and E. coli Bacteria in Drinking Water and Source Water as Required in National Primary Drinking Water Regulations,” available from CPI International.

“Chromocult® Method” means “Chromocult® Coliform Agar Presence/Absence Membrane Filter Test Method for Detection and Identification of Coliform Bacteria and Escherichia coli in Finished Waters,” available from EMD Chemicals Inc.

“Determination of Inorganic Oxyhalide” means “Determination of Inorganic Oxyhalide Disinfection By-Products in Drinking Water Using Ion Chromatography with the Addition of a Postcolumn Reagent for Trace Bromate Analysis,” available from NTIS.

“Dioxin and Furan Method 1613” means “Tetra- through Octa-Chlorinated Dioxins and Furans by Isotope-Dilution HRGC/HRMS,” available from NTIS.

“E\*Colite Test” means “Charm E\*Colite Presence/Absence Test for Detection and Identification of Coliform Bacteria and Escherichia coli in Drinking Water,” available from Charm Sciences, Inc. and USEPA, Water Resource Center.



---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

“EC-MUG” means “Method 9221 F: Multiple-Tube Fermentation Technique for Members of the Coliform Group, Escherichia coli Procedure (Proposed),” available from American Public Health Association and American Waterworks Association.

“EML Procedures Manual” means “EML Procedures Manual, HASL 300,” available from USDOE, EML.

“Enterolert” means “Evaluation of Enterolert for Enumeration of Enterococci in Recreational Waters,” available from American Society for Microbiology.

“Georgia Radium Method” means “The Determination of Radium-226 and Radium-228 in Drinking Water by Gamma-ray Spectrometry Using HPGE or Ge(Li) Detectors,” Revision 1.2, December 2004, available from the Georgia Tech Research Institute.

“GLI Method 2” means GLI Method 2, “Turbidity,” Nov. 2, 1992, available from Great Lakes Instruments, Inc.

“Guidance Manual for Filtration and Disinfection” means “Guidance Manual for Compliance with the Filtration and Disinfection Requirements for Public Water Systems using Surface Water Sources,” March 1991, available from USEPA, NSCEP.

“Hach FilterTrak Method 10133” means “Determination of Turbidity by Laser Nephelometry,” available from Hach Co.

~~“HASL Procedure Manual” means HASL Procedure Manual, HASL 300, available from ERDA Health and Safety Laboratory.~~

“ITS Method D99-003” means Method D99-003, Revision 3.0, “Free Chlorine Species (HOCl<sup>-</sup> and OCl<sup>-</sup>) by Test Strip,” available from Industrial Test Systems, Inc.

“Kelada 01” means “Kelada Automated Test Methods for Total Cyanide, Acid Dissociable Cyanide, And Thiocyanate,” Revision 1.2, ~~August 2001,~~

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~EPA 821/B-01/009, available from the National Technical Information Service (NTIS).~~

~~“m-ColiBlue24 Test” means “Total Coliforms and E. coli Membrane Filtration Method with m-ColiBlue24® Broth,” available from USEPA, Water Resource Center and Hach Company and USEPA, Water Resource Center.~~

~~“Membrane Filter Technique using Chromocult Coliform Agar” means “Chromocult Coliform Agar Presence/Absence Membrane Filter Test Method for Detection and Identification of Coliform Bacteria and Escherichia coli in Finished Waters,” available from EMD Chemicals Inc.~~

~~“Method ME355.01” means “Determination of Cyanide in Drinking Water by GC/MS Headspace Analysis,” available from NEMI or from H&E Testing Laboratory.~~

~~“Mitchell Method M5271” means “Determination of Turbidity by Laser Nephelometry,” available from NEMI and Leck Mitchell, PhD.~~

~~“Mitchell Method M5331” means “Determination of Turbidity by LED Nephelometry,” available from NEMI and Leck Mitchell, PhD.~~

~~“Modified Colitag™ Method” means “Modified Colitag™ Test Method for Simultaneous Detection of E. coli and other Total Coliforms in Water,” available from NEMI and CPI International.~~

~~“NA-MUG” means “Method 9222 G: Membrane Filter Technique for Members of the Coliform Group, MF Partition Procedures,” available from American Public Health Association and American Waterworks Association.~~

~~“NCRP Report Number 22” means “National Council on Radiation Protection.” “Maximum Permissible Body Burdens and Maximum Permissible Concentrations of Radionuclides in Air and in Water for Occupational Exposure,” available from NCRP.~~

~~“NTIS” means “National Technical Information Service.”~~

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

“New Jersey Radium Method” means “Determination of Radium 228 in Drinking Water,” available from the New Jersey Department of Environmental Protection.

“New York Radium Method” means “Determination of Ra-226 and Ra-228 (Ra-02),” available from the New York Department of Public Health.

“OI Analytical Method OIA-1677” means “Method OIA-1677, DW Available Cyanide by Flow Injection, Ligand Exchange, and Amperometry,” available from ALPKEM, Division of OI Analytical.

“ONPG-MUG Test” (meaning “minimal medium ortho-nitrophenyl-beta-d-galactopyranoside-4-methyl-umbelliferyl-beta-d-glucuronide test”), also called the “Autoanalysis Colilert System,” is Method 9223, available in “Standard Methods for the Examination of Water and Wastewater,” 18th, 19th, 20th, or 21st ed., from American Public Health Association and the American Water Works Association.

“Orion Method AQ4500” means “Determination of Turbidity by LED Nephelometry,” available from Thermo Scientific.

“Palintest ChloroSense” means “Measurement of Free and Total Chlorine in Drinking Water by Palintest ChloroSense,” available from NEMI or Palintest Ltd.

“Palintest Method 1001” means “Method Number 1001,” available from Palintest, Ltd. or the Hach Company.

“QuikChem Method 10-204-00-1-X” means “Digestion and distillation of total cyanide in drinking and wastewaters using MICRO DIST and determination of cyanide by flow injection analysis,” available from Lachat Instruments.

~~“Readycult@ Coliforms 100 Presence/Absence Test 2000”~~ means “Readycult Coliforms 100 Presence/Absence Test for Detection and Identification of Coliform Bacteria and Escherichia coli in Finished Waters,” v. 1.0, available from EMD Chemicals Inc.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

“Readycult® 2007” means “Readycult® Coliforms 100 Presence/Absence Test for Detection and Identification of Coliform Bacteria and Escherichia coli in Finished Waters,” v. 1.1, available from EMD Chemicals Inc.

“SimPlate Method” means “IDEXX SimPlate™ HPC Test Method for Heterotrophs in Water,” available from IDEXX Laboratories, Inc.

~~“Radiochemical Methods” means “Interim Radiochemical Methodology for Drinking Water,” available from NTIS.~~

“Systea Easy (1-Reagent)” means “Systea Easy (1-Reagent) Nitrate Method,” available from NEMI or Systea Scientific LLC.

“Standard Methods” means “Standard Methods for the Examination of Water and Wastewater,” available from the American Public Health Association or the American Waterworks Association.

“Standard Methods Online” means the website maintained by the Standard Methods Organization (at [www.standardmethods.org](http://www.standardmethods.org)) for purchase of the latest versions of methods in an electronic format.

“Syngenta AG-625” means “Atrazine in Drinking Water by Immunoassay,” February 2001 is available from Syngenta Crop Protection, Inc.

“Systea Easy (1-Reagent)” means “Systea Easy (1-Reagent) Nitrate Method,” available from NEMI or Systea Scientific LLC.

“Technical Bulletin 601” means “Technical Bulletin 601, Standard Method of Testing for Nitrate in Drinking Water,” July 1994, available from Analytical Technology, Inc.

~~“Technical Notes on Drinking Water Methods” means the USEPA document by that title, October 1994, USEPA document number EPA 600/R-94/173, available from NTIS.~~

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

“Technicon Methods” means “Fluoride in Water and Wastewater,” available from Bran & Luebbe.

~~“USDOE Manual” means “EML Procedures Manual,” available from the United State Department of Energy.~~

“USEPA Asbestos ~~Methods~~ Method 100.1” means Method 100.1, “Analytical Method for Determination of Asbestos Fibers in Water,” September 1983, available from NTIS.

“USEPA Asbestos ~~Methods~~ Method 100.2” means Method 100.2, “Determination of Asbestos Structures over 10-mm in Length in Drinking Water,” June 1994, available from NTIS.

“USEPA Environmental ~~Inorganics~~ Inorganic Methods” means “Methods for the Determination of Inorganic Substances in Environmental Samples,” August 1993, available from NTIS.

“USEPA Environmental Metals Methods” means “Methods for the Determination of Metals in Environmental Samples,” available from NTIS.

“USEPA Inorganic Methods” means “Methods for Chemical Analysis of Water and Wastes,” March 1983, available from NTIS.

“USEPA Interim Radiochemical Methods” means “Interim Radiochemical Methodology for Drinking Water,” EPA 600/4-75/008 (revised), March 1976. Available from NTIS.

“USEPA Method 1600” means “Method 1600: Enterococci in Water by Membrane Filtration Using Membrane-Enterococcus Indoxyl-b-D-Glucoside Agar (mEI),” available from USEPA, Water Resource Center.

“USEPA Method 1601” means “Method 1601: Male-specific (F<sup>+</sup>) and Somatic Coliphage in Water by Two-step Enrichment Procedure,” available from USEPA, Water Resource Center.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

“USEPA Method 1602” means “Method 1602: Male-specific (F<sup>+</sup>) and Somatic Coliphage in Water by Single Agar Layer (SAL) Procedure,” available from USEPA, Water Resource Center.

“USEPA Method 1604” means “Method 1604: Total Coliforms and Escherichia coli in Water by Membrane Filtration Using a Simultaneous Detection Technique (MI Medium),” available from USEPA, Water Resource Center.

“USEPA NERL Method 200.5 (rev. 4.2)” means Method 200.5, Revision 4.2, “Determination of Trace Elements in Drinking Water by Axially Viewed Inductively Coupled Plasma—Atomic Emission Spectrometry,” October 2003, EPA 600/R-06/115. Available from ~~the~~ USEPA, Office of Research and Development.

“USEPA NERL Method 415.3 (rev. 1.1)” means Method 415.3, Revision 1.1, “Determination of Total Organic Carbon and Specific UV Absorbance at 254 nm in Source Water and Drinking Water,” USEPA, February 2005, EPA 600/R-05/055. Available from ~~the~~ USEPA, Office of Research and Development.

“USEPA NERL Method 415.3 (rev. 1.2)” means Method 415.3, Revision 1.2, “Determination of Total Organic Carbon and Specific UV Absorbance at 254 nm in Source Water and Drinking Water,” USEPA, August 2009, EPA 600/R-09/122. Available from USEPA, Office of Research and Development.

“USEPA NERL Method 549.2” means Method 549.2, Revision 1.0, “Determination of Diquat and Paraquat in Drinking Water by Liquid-Solid Extraction and High Performance Liquid Chromatography with Ultraviolet Detection,” June 1997. Available from USEPA, Office of Research and Development.

“USEPA OGWDW Methods” means ~~one of~~ the methods listed as available from the USEPA, Office of Ground Water and Drinking Water (Methods 302.0, 317.0 (rev. 2.0), 326.0 (rev. 1.0), 327.0 (rev. 1.1), 334.0, 515.4 (rev. 1.0), 524.3 (rev. 1.0), 531.2 (rev. 1.0), 552.3 (rev. 1.0), 557,

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

1622 (99), 1622 (01), 1622 (05), 1623 (99), 1623 (01), and 1623 (05)).  
Available from NTIS; USEPA, NSCEP; or USEPA, OGWDW.

“USEPA Organic Methods” means “Methods for the Determination of Organic Compounds in Drinking Water,” December 1988 (revised July 1991), ~~for (Methods 502.2, 505, 507, 508, 508A, (rev. 1.0) and 515.1, and 531.1 (rev. 4.0));~~ “Methods for the Determination of Organic Compounds in Drinking Water—Supplement I,” July 1990, ~~for (Methods 506, 547, 550, and 550.1, and 551);~~ “Methods for the Determination of Organic Compounds in Drinking Water—Supplement II,” August 1992, ~~for (Methods 504.1, 508.1, 515.2, 524.2, 525.2, 548.1 (rev. 1.0), 549.1, 552.1 (rev. 1.0), 552.2, and 555 (rev. 1.0)); and~~ “Methods for the Determination of Organic Compounds in Drinking Water—Supplement III,” August 1995, ~~for (Methods 502.2 (rev. 2.1), 504.1 (rev. 1.1), 505 (rev. 2.1), 506 (rev. 1.1), 507 (rev. 2.1), 508 (rev. 3.1), 508.1 (rev. 2.0), 515.2 (rev. 1.1), 524.2 (rev. 4.1), 525.2 (rev. 2.0), 531.1 (rev. 3.1), 551.1 (rev. 1.0), and 552.2 (rev. 1.0)).~~ Available from NTIS; USEPA, NSCEP; or USEPA, EMSL.

“USEPA Organic and Inorganic Methods” means “Methods for the Determination of Organic and Inorganic Compounds in Drinking Water, Volume 1,” EPA 815/R-00/014, PB2000-106981, August 2000. Available from NTIS.

“USEPA Radioactivity Methods” means “Prescribed Procedures for Measurement of Radioactivity in Drinking Water,” EPA 600/4-80/032, August 1980. Available from NTIS.

“USEPA Radiochemical Analyses” means “Radiochemical Analytical Procedures for Analysis of Environmental Samples,” March 1979. Available from NTIS.

“USEPA Radiochemistry ~~Methods Procedures~~” means “Radiochemistry Procedures Manual,” EPA 520/5-84/006, December 1987. Available from NTIS.

“USEPA Technical Notes” means “Technical Notes on Drinking Water Methods,” available from NTIS and USEPA, NSCEP.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

“USGS Methods” means “Methods of Analysis by the U.S. Geological Survey National Water Quality Laboratory—Determination of Inorganic and Organic Constituents in Water and Fluvial Sediments,” available from NTIS and USGS.

“Waters Method B-1011” means “Waters Test Method for the Determination of Nitrite/Nitrate in Water Using Single Column Ion Chromatography,” available from Waters Corporation, Technical Services Division.

- b) The Board incorporates the following publications by reference:

ALPKEM, Division of OI Analytical, P.O. Box 9010, College Station, TX 77842-9010, telephone: 979-690-1711, Internet: [www.oico.com](http://www.oico.com).

“Method OIA-1677 DW, Available Cyanide by Flow Injection, Ligand Exchange, and Amperometry,” EPA 821/R-04/001, January 2004 (referred to as “OI Analytical Method OIA-1677”), referenced in Section 611.611.

BOARD NOTE: Also available online for download from [www.epa.gov/waterscience/methods/method/cyanide/1677-2004.pdf](http://www.epa.gov/waterscience/methods/method/cyanide/1677-2004.pdf).

APHA. American Public Health Association, 1015 Fifteenth Street NW, Washington, DC 20005 202-777-2742.

“Standard Methods for the Examination of Water and Wastewater,” 17th Edition, 1989 (referred to as “Standard Methods, 17th ed.”). See the methods listed separately for the same references under American Waterworks Association.

“Standard Methods for the Examination of Water and Wastewater,” 18th Edition, 1992, including “Supplement to the 18th Edition of Standard Methods for the Examination of Water and Wastewater,” 1994 (collectively referred to as “Standard Methods, 18th ed.”). See the methods listed separately for the same references under American Waterworks Association.



## ILLINOIS REGISTER

---

### POLLUTION CONTROL BOARD

#### NOTICE OF ADOPTED AMENDMENTS

“Standard Methods for the Examination of Water and Wastewater,” 19th Edition, 1995 (referred to as “Standard Methods, 19th ed.”). See the methods listed separately for the same references under American Waterworks Association.

“Standard Methods for the Examination of Water and Wastewater,” 20th Edition, 1998 (referred to as “Standard Methods, 20th ed.”). See the methods listed separately for the same references under American Waterworks Association.

“Standard Methods for the Examination of Water and Wastewater,” 21st Edition, 2005 (referred to as “Standard Methods, 21st ed.”). See the methods listed separately for the same references under American Waterworks Association.

American Society for Microbiology, 1752 N Street N.W., Washington, DC 20036, 202-737-3600:

“Evaluation of Enterolert for Enumeration of Enterococci in Recreational Waters,” Applied and Environmental Microbiology, Oct. 1996, vol. 62, no. 10, p. 3881 (referred to as “Enterolert”), referenced in Section 611.802.

BOARD NOTE: At the table to 40 CFR 141.402(c)(2), USEPA approved the method as described in the above literature review. The method itself is embodied in the printed instructions to the proprietary kit available from IDEXX Laboratories, Inc. (accessible on-line and available by download from [www.asm.org](http://www.asm.org), as “Enterolert™ Procedure”). ASTM approved the method as “Standard Test Method for Enterococci in Water Using Enterolert™,” which is available in two versions from ASTM: ~~ASTM-D 6503-99~~ Method D6503-99 (superceded) and ~~ASTM-D 6503-99~~ Method D6503-99. While it is more conventional to incorporate the method as presented in the kit instructions or as approved by ASTM by reference, the Board is constrained to incorporate the version that appears in the technical literature by reference, which is the version that USEPA has explicitly approved.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

AWWA. American Water Works Association et al., 6666 West Quincy Ave., Denver, CO 80235 (303-794-7711).

“National Field Evaluation of a Defined Substrate Method for the Simultaneous Enumeration of Total Coliforms and Escherichia coli for Drinking Water: Comparison with the Standard Multiple Tube Fermentation Method,” S.C. Edberg, M.J. Allen & D.B. Smith, Applied Environmental Microbiology, vol. 54, iss. 6, pp 1595-1601 (1988), referenced in Appendix D to this Part.

“Standard Methods for the Examination of Water and Wastewater,” 13th Edition, 1971 (referred to as “Standard Methods, 13th ed.”).

Method 302, Gross Alpha and Gross Beta Radioactivity in Water (Total, Suspended, and Dissolved), referenced in Section 611.720.

Method 303, Total Radioactive Strontium and Strontium 90 in Water, referenced in Section 611.720.

Method 304, Radium in Water by Precipitation, referenced in Section 611.720.

Method 305, Radium 226 by Radon in Water (Soluble, Suspended, and Total), referenced in Section 611.720.

Method 306, Tritium in Water, referenced in Section 611.720.

“Standard Methods for the Examination of Water and Wastewater,” 17th Edition, 1989 (referred to as “Standard Methods, 17th ed.”).

Method 7110 B, Gross Alpha and Gross Beta Radioactivity in Water (Total, Suspended, and Dissolved), referenced in Section 611.720.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Method 7500-Cs B, Radioactive Cesium, Precipitation Method, referenced in Section 611.720.

Method 7500-<sup>3</sup>H B, Tritium in Water, referenced in Section 611.720.

Method 7500-I B, Radioactive Iodine, Precipitation Method, referenced in Section 611.720.

Method 7500-I C, Radioactive Iodine, Ion-Exchange Method, referenced in Section 611.720.

Method 7500-I D, Radioactive Iodine, Distillation Method, referenced in Section 611.720.

Method 7500-Ra B, Radium in Water by Precipitation, referenced in Section 611.720.

Method 7500-Ra C, Radium 226 by Radon in Water (Soluble, Suspended, and Total), referenced in Section 611.720.

Method 7500-Ra D, Radium, Sequential Precipitation Method (Proposed), referenced in Section 611.720.

Method 7500-Sr B, Total Radioactive Strontium and Strontium 90 in Water, referenced in Section 611.720.

Method 7500-U B, Uranium, Radiochemical Method (Proposed), referenced in Section 611.720.

Method 7500-U C, Uranium, Isotopic Method (Proposed), referenced in Section 611.720.

“Standard Methods for the Examination of Water and Wastewater,” 18th Edition, 1992 (referred to as “Standard Methods, 18th ed.”).

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Method 2130 B, Turbidity, Nephelometric Method, referenced in Section 611.531.

Method 2320 B, Alkalinity, Titration Method, referenced in Section 611.611.

Method 2510 B, Conductivity, Laboratory Method, referenced in Section 611.611.

Method 2550, Temperature, Laboratory and Field Methods, referenced in Section 611.611.

Method 3111 B, Metals by Flame Atomic Absorption Spectrometry, Direct Air-Acetylene Flame Method, referenced in Sections 611.611 and 611.612.

Method 3111 D, Metals by Flame Atomic Absorption Spectrometry, Direct Nitrous Oxide-Acetylene Flame Method, referenced in Section 611.611.

Method 3112 B, Metals by Cold-Vapor Atomic Absorption Spectrometry, Cold-Vapor Atomic Absorption Spectrometric Method, referenced in Section 611.611.

Method 3113 B, Metals by Electrothermal Atomic Absorption Spectrometry, Electrothermal Atomic Absorption Spectrometric Method, referenced in Sections 611.611 and 611.612.

Method 3114 B, Metals by Hydride Generation/Atomic Absorption Spectrometry, Manual Hydride Generation/Atomic Absorption Spectrometric Method, referenced in Section 611.611.

Method 3120 B, Metals by Plasma Emission Spectroscopy, Inductively Coupled Plasma (ICP) Method, referenced in Sections 611.611 and 611.612.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Method 3500-Ca D, Calcium, EDTA Titrimetric Method, referenced in Section 611.611.

Method 3500-Mg E, Magnesium, Calculation Method, referenced in Section 611.611.

Method 4110 B, Determination of Anions by Ion Chromatography, Ion Chromatography with Chemical Suppression of Eluent Conductivity, referenced in Section 611.611.

Method 4500-CN<sup>-</sup> C, Cyanide, Total Cyanide after Distillation, referenced in Section 611.611.

Method 4500-CN<sup>-</sup> E, Cyanide, Colorimetric Method, referenced in Section 611.611.

Method 4500-CN<sup>-</sup> F, Cyanide, Cyanide-Selective Electrode Method, referenced in Section 611.611.

Method 4500-CN<sup>-</sup> G, Cyanide, Cyanides Amenable to Chlorination after Distillation, referenced in Section 611.611.

Method 4500-Cl D, Chlorine, Amperometric Titration Method, referenced in Section 611.531.

Method 4500-Cl E, Chlorine, Low-Level Amperometric Titration Method, referenced in Section 611.531.

Method 4500-Cl F, Chlorine, DPD Ferrous Titrimetric Method, referenced in Section 611.531.

Method 4500-Cl G, Chlorine, DPD Colorimetric Method, referenced in Section 611.531.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Method 4500-Cl H, Chlorine, Syringaldazine (FACTS)  
Method, referenced in Section 611.531.

Method 4500-Cl I, Chlorine, Iodometric Electrode Method,  
referenced in Section 611.531.

Method 4500-ClO<sub>2</sub> C, Chlorine Dioxide, Amperometric  
Method I, referenced in Section 611.531.

Method 4500-ClO<sub>2</sub> D, Chlorine Dioxide, DPD Method,  
referenced in Section 611.531.

Method 4500-ClO<sub>2</sub> E, Chlorine Dioxide, Amperometric  
Method II (Proposed), referenced in Section 611.531.

Method 4500-F<sup>-</sup> B, Fluoride, Preliminary Distillation Step,  
referenced in Section 611.611.

Method 4500-F<sup>-</sup> C, Fluoride, Ion-Selective Electrode  
Method, referenced in Section 611.611.

Method 4500-F<sup>-</sup> D, Fluoride, SPADNS Method, referenced  
in Section 611.611.

Method 4500-F<sup>-</sup> E, Fluoride, Complexone Method,  
referenced in Section 611.611.

Method 4500-H<sup>+</sup> B, pH Value, Electrometric Method,  
referenced in Section 611.611.

Method 4500-NO<sub>2</sub><sup>-</sup> B, Nitrogen (Nitrite), Colorimetric  
Method, referenced in Section 611.611.

Method 4500-NO<sub>3</sub><sup>-</sup> D, Nitrogen (Nitrate), Nitrate Electrode  
Method, referenced in Section 611.611.

Method 4500-NO<sub>3</sub><sup>-</sup> E, Nitrogen (Nitrate), Cadmium  
Reduction Method, referenced in Section 611.611.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Method 4500-NO<sub>3</sub><sup>-</sup> F, Nitrogen (Nitrate), Automated Cadmium Reduction Method, referenced in Section 611.611.

Method 4500-O<sub>3</sub> B, Ozone (Residual) (Proposed), Indigo Colorimetric Method, referenced in Section 611.531.

Method 4500-P E, Phosphorus, Ascorbic Acid Method, referenced in Section 611.611.

Method 4500-P F, Phosphorus, Automated Ascorbic Acid Reduction Method, referenced in Section 611.611.

Method 4500-Si D, Silica, Molybdosilicate Method, referenced in Section 611.611.

Method 4500-Si E, Silica, Heteropoly Blue Method, referenced in Section 611.611.

Method 4500-Si F, Silica, Automated Method for Molybdate-Reactive Silica, referenced in Section 611.611.

Method 6651, Glyphosate Herbicide (Proposed), referenced in Section 611.645.

Method 7110 B, Gross Alpha and Beta Radioactivity (Total, Suspended, and Dissolved), Evaporation Method for Gross Alpha-Beta, referenced in Section 611.720.

Method 7110 C, Gross Alpha and Beta Radioactivity (Total, Suspended, and Dissolved), Coprecipitation Method for Gross Alpha Radioactivity in Drinking Water (Proposed), referenced in Section 611.720.

Method 7500-Cs B, Radioactive Cesium, Precipitation Method, referenced in Section 611.720.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Method 7500-<sup>3</sup>H B, Tritium, Liquid Scintillation Spectrometric Method, referenced in Section 611.720.

Method 7500-I B, Radioactive Iodine, Precipitation Method, referenced in Section 611.720.

Method 7500-I C, Radioactive Iodine, Ion-Exchange Method, referenced in Section 611.720.

Method 7500-I D, Radioactive Iodine, Distillation Method, referenced in Section 611.720.

Method 7500-Ra B, Radium, Precipitation Method, referenced in Section 611.720.

Method 7500-Ra C, Radium, Emanation Method, referenced in Section 611.720.

Method 7500-Ra D, Radium, Sequential Precipitation Method (Proposed), referenced in Section 611.720.

Method 7500-Sr B, Total Radioactive Strontium and Strontium 90, Precipitation Method, referenced in Section 611.720.

Method 7500-U B, Uranium, Radiochemical Method (Proposed), referenced in Section 611.720.

Method 7500-U C, Uranium, Isotopic Method (Proposed), referenced in Section 611.720.

Method 9215 B, Heterotrophic Plate Count, Pour Plate Method, referenced in Section 611.531.

Method 9221 A, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Introduction, referenced in Sections 611.526 and 611.531.



ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Method 9221 B, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Standard Total Coliform Fermentation Technique, referenced in Sections 611.526 and 611.531.

Method 9221 C, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Estimation of Bacterial Density, referenced in Sections 611.526 and 611.531.

Method 9221 D, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Presence-Absence (P-A) Coliform Test, referenced in Section 611.526.

Method 9221 E, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Fecal Coliform Procedure, referenced in Sections 611.526 and 611.531.

Method 9222 A, Membrane Filter Technique for Members of the Coliform Group, Introduction, referenced in Sections 611.526 and 611.531.

Method 9222 B, Membrane Filter Technique for Members of the Coliform Group, Standard Total Coliform Membrane Filter Procedure, referenced in Sections 611.526 and 611.531.

Method 9222 C, Membrane Filter Technique for Members of the Coliform Group, Delayed-Incubation Total Coliform Procedure, referenced in Sections 611.526 and 611.531.

Method 9222 D, Membrane Filter Technique for Members of the Coliform Group, Fecal Coliform Membrane Filter Procedure, referenced in Section 611.531.

Method 9223, Chromogenic Substrate Coliform Test (Proposed) (also referred to as the variations "Autoanalysis

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Colilert System” and “Colisure Test”), referenced in Sections 611.526, and 611.531.

Method 9223 B, Chromogenic Substrate Coliform Test (Proposed), referenced in Section 611.1004.

“Supplement to the 18th Edition of Standard Methods for the Examination of Water and Wastewater,” American Public Health Association, 1994.

Method 6610, Carbamate Pesticide Method, referenced in Section 611.645.

“Standard Methods for the Examination of Water and Wastewater,” 19th Edition, 1995 (referred to as “Standard Methods, 19th ed.”).

Method 2130 B, Turbidity, Nephelometric Method, referenced in Section 611.531.

Method 2320 B, Alkalinity, Titration Method, referenced in Section 611.611.

Method 2510 B, Conductivity, Laboratory Method, referenced in Section 611.611.

Method 2550, Temperature, Laboratory, and Field Methods, referenced in Section 611.611.

Method 3111 B, Metals by Flame Atomic Absorption Spectrometry, Direct Air-Acetylene Flame Method, referenced in Sections 611.611 and 611.612.

Method 3111 D, Metals by Flame Atomic Absorption Spectrometry, Direct Nitrous Oxide-Acetylene Flame Method, referenced in Section 611.611.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Method 3112 B, Metals by Cold-Vapor Atomic Absorption Spectrometry, Cold-Vapor Atomic Absorption Spectrometric Method, referenced in Section 611.611.

Method 3113 B, Metals by Electrothermal Atomic Absorption Spectrometry, Electrothermal Atomic Absorption Spectrometric Method, referenced in Sections 611.611 and 611.612.

Method 3114 B, Metals by Hydride Generation/Atomic Absorption Spectrometry, Manual Hydride Generation/Atomic Absorption Spectrometric Method, referenced in Section 611.611.

Method 3120 B, Metals by Plasma Emission Spectroscopy, Inductively Coupled Plasma (ICP) Method, referenced in Sections 611.611 and 611.612.

Method 3500-Ca D, Calcium, EDTA Titrimetric Method, referenced in Section 611.611.

Method 3500-Mg E, Magnesium, Calculation Method, referenced in Section 611.611.

Method 4110 B, Determination of Anions by Ion Chromatography, Ion Chromatography with Chemical Suppression of Eluent Conductivity, referenced in Section 611.611.

Method 4500-Cl D, Chlorine, Amperometric Titration Method, referenced in Sections 611.381 and 611.531.

Method 4500-Cl E, Chlorine, Low-Level Amperometric Titration Method, referenced in Sections 611.381 and 611.531.

Method 4500-Cl F, Chlorine, DPD Ferrous Titrimetric Method, referenced in Sections 611.381 and 611.531.

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Method 4500-Cl G, Chlorine, DPD Colorimetric Method, referenced in Sections 611.381 and 611.531.

Method 4500-Cl H, Chlorine, Syringaldazine (FACTS) Method, referenced in Sections 611.381 and 611.531.

Method 4500-Cl I, Chlorine, Iodometric Electrode Method, referenced in Sections 611.381 and 611.531.

Method 4500-ClO<sub>2</sub> C, Chlorine Dioxide, Amperometric Method I, referenced in Section 611.531.

Method 4500-ClO<sub>2</sub> D, Chlorine Dioxide, DPD Method, referenced in Sections 611.381 and 611.531.

Method 4500-ClO<sub>2</sub> E, Chlorine Dioxide, Amperometric Method II, referenced in Sections 611.381 and 611.531.

Method 4500-CN<sup>-</sup> C, Cyanide, Total Cyanide after Distillation, referenced in Section 611.611.

Method 4500-CN<sup>-</sup> E, Cyanide, Colorimetric Method, referenced in Section 611.611.

Method 4500-CN<sup>-</sup> F, Cyanide, Cyanide-Selective Electrode Method, referenced in Section 611.611.

Method 4500-CN<sup>-</sup> G, Cyanide, Cyanides Amenable to Chlorination after Distillation, referenced in Section 611.611.

Method 4500-F<sup>-</sup> B, Fluoride, Preliminary Distillation Step, referenced in Section 611.611.

Method 4500-F<sup>-</sup> C, Fluoride, Ion-Selective Electrode Method, referenced in Section 611.611.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Method 4500-F<sup>-</sup> D, Fluoride, SPADNS Method, referenced in Section 611.611.

Method 4500-F<sup>-</sup> E, Fluoride, Complexone Method, referenced in Section 611.611.

Method 4500-H<sup>+</sup> B, pH Value, Electrometric Method, referenced in Section 611.611.

Method 4500-NO<sub>2</sub><sup>-</sup> B, Nitrogen (Nitrite), Colorimetric Method, referenced in Section 611.611.

Method 4500-NO<sub>3</sub><sup>-</sup> D, Nitrogen (Nitrate), Nitrate Electrode Method, referenced in Section 611.611.

Method 4500-NO<sub>3</sub><sup>-</sup> E, Nitrogen (Nitrate), Cadmium Reduction Method, referenced in Section 611.611.

Method 4500-NO<sub>3</sub><sup>-</sup> F, Nitrogen (Nitrate), Automated Cadmium Reduction Method, referenced in Section 611.611.

Method 4500-O<sub>3</sub> B, Ozone (Residual) (Proposed), Indigo Colorimetric Method, referenced in Section 611.531.

Method 4500-P E, Phosphorus, Ascorbic Acid Method, referenced in Section 611.611.

Method 4500-P F, Phosphorus, Automated Ascorbic Acid Reduction Method, referenced in Section 611.611.

Method 4500-Si D, Silica, Molybdosilicate Method, referenced in Section 611.611.

Method 4500-Si E, Silica, Heteropoly Blue Method, referenced in Section 611.611.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Method 4500-Si F, Silica, Automated Method for Molybdate-Reactive Silica, referenced in Section 611.611.

Method 5310 B, TOC, Combustion-Infrared Method, referenced in Section 611.381.

Method 5310 C, TOC, Persulfate-Ultraviolet Oxidation Method, referenced in Section 611.381.

Method 5310 D, TOC, Wet-Oxidation Method, referenced in Section 611.381.

Method 5910 B, UV Absorbing Organic Constituents, Ultraviolet Absorption Method, referenced in Section 611.381.

Method 6251 B, Disinfection Byproducts: Haloacetic Acids and Trichlorophenol, Micro Liquid-Liquid Extraction Gas Chromatographic Method, referenced in Section 611.381.

Method 6610, Carbamate Pesticide Method, referenced in Section 611.645.

Method 6651, Glyphosate Herbicide (Proposed), referenced in Section 611.645.

Method 7110 B, Gross Alpha and Gross Beta Radioactivity, Evaporation Method for Gross Alpha-Beta, referenced in Section 611.720.

Method 7110 C, Gross Alpha and Beta Radioactivity (Total, Suspended, and Dissolved), Coprecipitation Method for Gross Alpha Radioactivity in Drinking Water (Proposed), referenced in Section 611.720.

Method 7120 B, Gamma-Emitting Radionuclides, Gamma Spectrometric Method, referenced in Section 611.720.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Method 7500-Cs B, Radioactive Cesium, Precipitation Method, referenced in Section 611.720.

Method 7500-<sup>3</sup>H B, Tritium, Liquid Scintillation Spectrometric Method, referenced in Section 611.720.

Method 7500-I B, Radioactive Iodine, Precipitation Method, referenced in Section 611.720.

Method 7500-I C, Radioactive Iodine, Ion-Exchange Method, referenced in Section 611.720.

Method 7500-I D, Radioactive Iodine, Distillation Method, referenced in Section 611.720.

Method 7500-Ra B, Radium, Precipitation Method, referenced in Section 611.720.

Method 7500-Ra C, Radium, Emanation Method, referenced in Section 611.720.

Method 7500-Ra D, Radium, Sequential Precipitation Method, referenced in Section 611.720.

Method 7500-Sr B, Total Radiactive Strontium and Strontium 90, Precipitation Method, referenced in Section 611.720.

Method 7500-U B, Uranium, Radiochemical Method, referenced in Section 611.720.

Method 7500-U C, Uranium, Isotopic Method, referenced in Section 611.720.

Method 9215 B, Heterotrophic Plate Count, Pour Plate Method, referenced in Section 611.531.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Method 9221 A, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Introduction, referenced in Sections 611.526 and 611.531.

Method 9221 B, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Standard Total Coliform Fermentation Technique, referenced in Sections 611.526 and 611.531.

Method 9221 C, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Estimation of Bacterial Density, referenced in Sections 611.526 and 611.531.

Method 9221 D, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Presence-Absence (P-A) Coliform Test, referenced in Section 611.526.

Method 9221 E, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Fecal Coliform Procedure, referenced in Sections 611.526 and 611.531.

Method 9222 A, Membrane Filter Technique for Members of the Coliform Group, Introduction, referenced in Sections 611.526 and 611.531.

Method 9222 B, Membrane Filter Technique for Members of the Coliform Group, Standard Total Coliform Membrane Filter Procedure, referenced in Sections 611.526 and 611.531.

Method 9222 C, Membrane Filter Technique for Members of the Coliform Group, Delayed-Incubation Total Coliform Procedure, referenced in Sections 611.526 and 611.531.

Method 9222 D, Membrane Filter Technique for Members of the Coliform Group, Fecal Coliform Membrane Filter Procedure, referenced in Section 611.531.



ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Method 9222 G, Membrane Filter Technique for Members of the Coliform Group, MF Partition Procedures, referenced in Section 611.526.

Method 9223, Chromogenic Substrate Coliform Test (also referred to as the variations "Autoanalysis Colilert System" and "Colisure Test"), referenced in Sections 611.526, and 611.531.

Method 9223 B, Chromogenic Substrate Coliform Test (Proposed), referenced in Section 611.1004.

"Supplement to the 19th Edition of Standard Methods for the Examination of Water and Wastewater," American Public Health Association, 1996.

Method 5310 B, TOC, Combustion-Infrared Method, referenced in Section 611.381.

Method 5310 C, TOC, Persulfate-Ultraviolet Oxidation Method, referenced in Section 611.381.

Method 5310 D, TOC, Wet-Oxidation Method, referenced in Section 611.381.

"Standard Methods for the Examination of Water and Wastewater," 20th Edition, 1998 (referred to as "Standard Methods, 20th ed.").

Method 2130 B, Turbidity, Nephelometric Method, referenced in Section 611.531.

Method 2320 B, Alkalinity, Titration Method, referenced in Section 611.611.

Method 2510 B, Conductivity, Laboratory Method, referenced in Section 611.611.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Method 2550, Temperature, Laboratory, and Field Methods, referenced in Section 611.611.

Method 3120 B, Metals by Plasma Emission Spectroscopy, Inductively Coupled Plasma (ICP) Method, referenced in Sections 611.611 and 611.612.

Method 3500-Ca B, Calcium, EDTA Titrimetric Method, referenced in Section 611.611.

Method 3500-Mg B, Magnesium, EDTA Titrimetric Method, referenced in Section 611.611.

Method 4110 B, Determination of Anions by Ion Chromatography, Ion Chromatography with Chemical Suppression of Eluent Conductivity, referenced in Section 611.611.

Method 4500-CN<sup>-</sup> C, Cyanide, Total Cyanide after Distillation, referenced in Section 611.611.

Method 4500-CN<sup>-</sup> E, Cyanide, Colorimetric Method, referenced in Section 611.611.

Method 4500-CN<sup>-</sup> F, Cyanide, Cyanide-Selective Electrode Method, referenced in Section 611.611.

Method 4500-CN<sup>-</sup> G, Cyanide, Cyanides Amenable to Chlorination after Distillation, referenced in Section 611.611.

Method 4500-Cl D, Chlorine, Amperometric Titration Method, referenced in Section 611.531.

Method 4500-Cl E, Chlorine, Low-Level Amperometric Titration Method, referenced in Section 611.531.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Method 4500-Cl F, Chlorine, DPD Ferrous Titrimetric Method, referenced in Section 611.531.

Method 4500-Cl G, Chlorine, DPD Colorimetric Method, referenced in Section 611.531.

Method 4500-Cl H, Chlorine, Syringaldazine (FACTS) Method, referenced in Section 611.531.

Method 4500-Cl I, Chlorine, Iodometric Electrode Method, referenced in Section 611.531.

Method 4500-ClO<sub>2</sub> C, Chlorine Dioxide, Amperometric Method I, referenced in Section 611.531.

Method 4500-ClO<sub>2</sub> D, Chlorine Dioxide, DPD Method, referenced in Section 611.531.

Method 4500-ClO<sub>2</sub> E, Chlorine Dioxide, Amperometric Method II (Proposed), referenced in Section 611.531.

Method 4500-F<sup>-</sup> B, Fluoride, Preliminary Distillation Step, referenced in Section 611.611.

Method 4500-F<sup>-</sup> C, Fluoride, Ion-Selective Electrode Method, referenced in Section 611.611.

Method 4500-F<sup>-</sup> D, Fluoride, SPADNS Method, referenced in Section 611.611.

Method 4500-F<sup>-</sup> E, Fluoride, Complexone Method, referenced in Section 611.611.

Method 4500-H<sup>+</sup> B, pH Value, Electrometric Method, referenced in Section 611.611.

Method 4500-NO<sub>2</sub><sup>-</sup> B, Nitrogen (Nitrite), Colorimetric Method, referenced in Section 611.611.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Method 4500-NO<sub>3</sub><sup>-</sup> D, Nitrogen (Nitrate), Nitrate Electrode Method, referenced in Section 611.611.

Method 4500-NO<sub>3</sub><sup>-</sup> E, Nitrogen (Nitrate), Cadmium Reduction Method, referenced in Section 611.611.

Method 4500-NO<sub>3</sub><sup>-</sup> F, Nitrogen (Nitrate), Automated Cadmium Reduction Method, referenced in Section 611.611.

Method 4500-O<sub>3</sub> B, Ozone (Residual) (Proposed), Indigo Colorimetric Method, referenced in Section 611.531.

Method 4500-P E, Phosphorus, Ascorbic Acid Method, referenced in Section 611.611.

Method 4500-P F, Phosphorus, Automated Ascorbic Acid Reduction Method, referenced in Section 611.611.

Method 4500-Si C, Silica, Molybdosilicate Method, referenced in Section 611.611.

Method 4500-Si D, Silica, Heteropoly Blue Method, referenced in Section 611.611.

Method 4500-Si E, Silica, Automated Method for Molybdate-Reactive Silica, referenced in Section 611.611.

Method 5310 B, TOC, Combustion-Infrared Method, referenced in Section 611.381.

Method 5310 C, TOC, Persulfate-Ultraviolet Oxidation Method, referenced in Section 611.381.

Method 5310 D, TOC, Wet-Oxidation Method, referenced in Section 611.381.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Method 5910 B, UV-Absorbing Organic Constituents, Ultraviolet Absorption Method, referenced in Sections 611.381 and 611.382.

Method 6251, Disinfection By-Products: Haloacetic Acids and Trichlorophenol, referenced in Section 611.381.

Method 6610, Carbamate Pesticide Method, referenced in Section 611.645.

Method 6651, Glyphosate Herbicide (Proposed), referenced in Section 611.645.

Method 7110 B, Gross Alpha and Gross Beta Radioactivity, Evaporation Method for Gross Alpha-Beta, referenced in Section 611.720.

Method 7110 C, Gross Alpha and Beta Radioactivity (Total, Suspended, and Dissolved), Coprecipitation Method for Gross Alpha Radioactivity in Drinking Water (Proposed), referenced in Section 611.720.

Method 7120, Gamma-Emitting Radionuclides, referenced in Section 611.720.

Method 7500-Cs B, Radioactive Cesium, Precipitation Method, referenced in Section 611.720.

Method 7500-<sup>3</sup>H B, Tritium, Liquid Scintillation Spectrometric Method, referenced in Section 611.720.

Method 7500-I B, Radioactive Iodine, Precipitation Method, referenced in Section 611.720.

Method 7500-I C, Radioactive Iodine, Ion-Exchange Method, referenced in Section 611.720.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Method 7500-I D, Radioactive Iodine, Distillation Method, referenced in Section 611.720.

Method 7500-Ra B, Radium, Precipitation Method, referenced in Section 611.720.

Method 7500-Ra C, Radium, Emanation Method, referenced in Section 611.720.

Method 7500-Ra D, Radium, Sequential Precipitation Method, referenced in Section 611.720.

Method 7500-Sr B, Total Radioactive Strontium and Strontium 90, Precipitation Method, referenced in Section 611.720.

Method 7500-U B, Uranium, Radiochemical Method, referenced in Section 611.720.

Method 7500-U C, Uranium, Isotopic Method, referenced in Section 611.720.

Method 9215 B, Heterotrophic Plate Count, Pour Plate Method, referenced in Section 611.531.

Method 9221 A, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Introduction, referenced in Sections 611.526 and 611.531.

Method 9221 B, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Standard Total Coliform Fermentation Technique, referenced in Sections 611.526 and 611.531.

Method 9221 C, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Estimation of Bacterial Density, referenced in Sections 611.526 and 611.531.

---

ILLINOIS REGISTER

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Method 9221 D, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Presence-Absence (P-A) Coliform Test, referenced in Sections 611.526.

Method 9221 E, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Fecal Coliform Procedure, referenced in Sections 611.526 and 611.531.

Method 9221 F, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Escherichia Coli Procedure (Proposed), referenced in Section 611.802.

Method 9222 A, Membrane Filter Technique for Members of the Coliform Group, Introduction, referenced in Sections 611.526 and 611.531.

Method 9222 B, Membrane Filter Technique for Members of the Coliform Group, Standard Total Coliform Membrane Filter Procedure, referenced in Sections 611.526 and 611.531.

Method 9222 C, Membrane Filter Technique for Members of the Coliform Group, Delayed-Incubation Total Coliform Procedure, referenced in Sections 611.526 and 611.531.

Method 9222 D, Membrane Filter Technique for Members of the Coliform Group, Fecal Coliform Membrane Filter Procedure, referenced in Section 611.531.

Method 9222 G, Membrane Filter Technique for Members of the Coliform Group, MF Partition Procedures, referenced in Section 611.526.

Method 9223, Chromogenic Substrate Coliform Test (also referred to as the variations "Autoanalysis Colilert System" and "Colisure Test"), referenced in Sections 611.526, and 611.531.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Method 9223 B, Chromogenic Substrate Coliform Test (also referred to as the variations “Autoanalysis Colilert System” and “Colisure Test”), referenced in Sections 611.526, 611.802, and 611.1004.

Method 9230 B, Fecal Streptococcus and Enterococcus Groups, Multiple Tube Techniques, referenced in Section 611.802.

Method 9230 C, Fecal Streptococcus and Enterococcus Groups, Membrane Filter Techniques, referenced in Section 611.802.

“Standard Methods for the Examination of Water and Wastewater,” 21st Edition, 2005 (referred to as “Standard Methods, 21st ed.”).

Method 2130 B, Turbidity, Nephelometric Method, referenced in Section 611.531.

Method 2320 B, Alkalinity, Titration Method, referenced in Section 611.611.

Method 2510 B, Conductivity, Laboratory Method, referenced in Section 611.611.

Method 2550, Temperature, Laboratory, and Field Methods, referenced in Section 611.611.

Method 3111 B, Metals by Flame Atomic Absorption Spectrometry, Direct Air-Acetylene Flame Method, referenced in Sections 611.611 and 611.612.

Method 3111 D, Metals by Flame Atomic Absorption Spectrometry, Direct Nitrous Oxide-Acetylene Flame Method, referenced in Section 611.611.



ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Method 3112 B, Metals by Cold-Vapor Atomic Absorption Spectrometry, Cold-Vapor Atomic Absorption Spectrometric Method, referenced in Section 611.611.

Method 3113 B, Metals by Electrothermal Atomic Absorption Spectrometry, Electrothermal Atomic Absorption Spectrometric Method, referenced in Sections 611.611 and 611.612.

Method 3114 B, Metals by Hydride Generation/Atomic Absorption Spectrometry, Manual Hydride Generation/Atomic Absorption Spectrometric Method, referenced in Section 611.611.

Method 3120 B, Metals by Plasma Emission Spectroscopy, Inductively Coupled Plasma (ICP) Method, referenced in Sections 611.611 and 611.612.

Method 3500-Ca B, Calcium, EDTA Titrimetric Method, referenced in Section 611.611.

Method 3500-Ca D, Calcium, EDTA Titrimetric Method, referenced in Section 611.611.

Method 3500-Mg B, Magnesium, Calculation Method, referenced in Section 611.611.

Method 4110 B, Determination of Anions by Ion Chromatography, Ion Chromatography with Chemical Suppression of Eluent Conductivity, referenced in Section 611.611.

Method 4500-Cl D, Chlorine, Amperometric Titration Method, referenced in Section 611.381.

Method 4500-Cl E, Chlorine, Low-Level Amperometric Titration Method, referenced in Section 611.381.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Method 4500-Cl F, Chlorine, DPD Ferrous Titrimetric Method, referenced in Section 611.381.

Method 4500-Cl G, Chlorine, DPD Colorimetric Method, referenced in Section 611.381.

Method 4500-Cl H, Chlorine, Syringaldazine (FACTS) Method, referenced in Section 611.381.

Method 4500-Cl I, Chlorine, Iodometric Electrode Method, referenced in Section 611.381.

Method 4500-ClO<sub>2</sub> C, Chlorine Dioxide, Amperometric Method I, referenced in Section 611.531.

Method 4500-ClO<sub>2</sub> E, Chlorine Dioxide, Amperometric Method II (Proposed), referenced in Section 611.381.

Method 4500-CN<sup>-</sup> E, Cyanide, Colorimetric Method, referenced in Section 611.611.

Method 4500-CN<sup>-</sup> F, Cyanide, Cyanide-Selective Electrode Method, referenced in Section 611.611.

Method 4500-CN<sup>-</sup> G, Cyanide, Cyanides Amenable to Chlorination after Distillation, referenced in Section 611.611.

Method 4500-F<sup>-</sup> B, Fluoride, Preliminary Distillation Step, referenced in Section 611.611.

Method 4500-F<sup>-</sup> C, Fluoride, Ion-Selective Electrode Method, referenced in Section 611.611.

Method 4500-F<sup>-</sup> D, Fluoride, SPADNS Method, referenced in Section 611.611.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Method 4500-F<sup>-</sup> E, Fluoride, Complexone Method, referenced in Section 611.611.

Method 4500-H<sup>+</sup> B, pH Value, Electrometric Method, referenced in Section 611.611.

Method 4500-NO<sub>2</sub><sup>-</sup> B, Nitrogen (Nitrite), Colorimetric Method, referenced in Section 611.611.

Method 4500-NO<sub>3</sub><sup>-</sup> D, Nitrogen (Nitrate), Nitrate Electrode Method, referenced in Section 611.611.

Method 4500-NO<sub>3</sub><sup>-</sup> E, Nitrogen (Nitrate), Cadmium Reduction Method, referenced in Section 611.611.

Method 4500-NO<sub>3</sub><sup>-</sup> F, Nitrogen (Nitrate), Automated Cadmium Reduction Method, referenced in Section 611.611.

Method 4500-O<sub>3</sub> B, Ozone (Residual) (Proposed), Indigo Colorimetric Method, referenced in Section 611.531.

Method 4500-P E, Phosphorus, Ascorbic Acid Method, referenced in Section 611.611.

Method 4500-P F, Phosphorus, Automated Ascorbic Acid Reduction Method, referenced in Section 611.611.

Method 4500-SiO<sub>2</sub> C, Silica, Molybdosilicate Method, referenced in Section 611.611.

Method 4500-SiO<sub>2</sub> D, Silica, Heteropoly Blue Method, referenced in Section 611.611.

Method 4500-SiO<sub>2</sub> E, Silica, Automated Method for Molybdate-Reactive Silica, referenced in Section 611.611.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Method 5310 B, TOC, Combustion-Infrared Method, referenced in Section 611.381.

Method 5310 C, TOC, Persulfate-Ultraviolet Oxidation Method, referenced in Section 611.381.

Method 5310 D, TOC, Wet-Oxidation Method, referenced in Section 611.381.

Method 5910 B, UV-Absorbing Organic Constituents, Ultraviolet Absorption Method, referenced in Sections 611.381 and 611.382.

Method 6251, Disinfection By-Products: Haloacetic Acids and Trichlorophenol, referenced in Section 611.381.

Method 6610, Carbamate Pesticide Method, referenced in Section 611.645.

Method 6640 B, Acidic Herbicide Compounds, Micro Liquid-Liquid Extraction Gas Chromatographic Method, referenced in Section 611.645.

Method 7110 B, Gross Alpha and Gross Beta Radioactivity, Evaporation Method for Gross Alpha-Beta, referenced in Section 611.720.

Method 7110 C, Gross Alpha and Beta Radioactivity (Total, Suspended, and Dissolved), Coprecipitation Method for Gross Alpha Radioactivity in Drinking Water (Proposed), referenced in Section 611.720.

Method 7120, Gamma-Emitting Radionuclides, referenced in Section 611.720.

Method 7500-Cs B, Radioactive Cesium, Precipitation Method, referenced in Section 611.720.

---

ILLINOIS REGISTER

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Method 7500-<sup>3</sup>H B, Tritium, Liquid Scintillation Spectrometric Method, referenced in Section 611.720.

Method 7500-I B, Radioactive Iodine, Precipitation Method, referenced in Section 611.720.

Method 7500-I C, Radioactive Iodine, Ion-Exchange Method, referenced in Section 611.720.

Method 7500-I D, Radioactive Iodine, Distillation Method, referenced in Section 611.720.

Method 7500-Ra B, Radium, Precipitation Method, referenced in Section 611.720.

Method 7500-Ra C, Radium, Emanation Method, referenced in Section 611.720.

Method 7500-Ra D, Radium, Sequential Precipitation Method, referenced in Section 611.720.

Method 7500-Sr B, Total Radioactive Strontium and Strontium 90, Precipitation Method, referenced in Section 611.720.

Method 7500-U B, Uranium, Radiochemical Method, referenced in Section 611.720.

Method 7500-U C, Uranium, Isotopic Method, referenced in Section 611.720.

Method 9221 A, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Introduction, referenced in Sections 611.526 and 611.531.

Method 9221 B, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Standard Total

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Coliform Fermentation Technique, referenced in Sections 611.526 and 611.531.

Method 9221 C, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Estimation of Bacterial Density, referenced in Sections 611.526 and 611.531.

Method 9221 D, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Presence-Absence (P-A) Coliform Test, referenced in Section 611.526.

Method 9221 E, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Fecal Coliform Procedure, referenced in Sections 611.526 and 611.531.

Method 9221 F, Multiple-Tube Fermentation Technique for Members of the Coliform Group, Escherichia Coli Procedure (Proposed), referenced in Section 611.802.

Method 9222 A, Membrane Filter Technique for Members of the Coliform Group, Introduction, referenced in Sections 611.526 and 611.531.

Method 9222 B, Membrane Filter Technique for Members of the Coliform Group, Standard Total Coliform Membrane Filter Procedure, referenced in Sections 611.526 and 611.531.

Method 9222 C, Membrane Filter Technique for Members of the Coliform Group, Delayed-Incubation Total Coliform Procedure, referenced in Sections 611.526 and 611.531.

Method 9222 D, Membrane Filter Technique for Members of the Coliform Group, Fecal Coliform Membrane Filter Procedure, referenced in Section 611.531.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Method 9222 G, Membrane Filter Technique for Members of the Coliform Group, MF Partition Procedures, referenced in Section 611.526.

Method 9223, Chromogenic Substrate Coliform Test (also referred to as the variations “Autoanalysis Colilert System” and “Colisure Test”), referenced in Sections 611.526 and 611.531.

Method 9223 B, Chromogenic Substrate Coliform Test (also referred to as the variations “Autoanalysis Colilert System” and “Colisure Test”), referenced in Sections 611.526, 611.802, and 611.1004.

BOARD NOTE: See the Board note appended to Standard Methods Online in this Section about methods that appear in Standard Methods, 21st ed. which USEPA has cited as available from Standard Methods Online.

BOARD NOTE: Individual Methods from Standard Methods are available online at [www.standardmethods.org](http://www.standardmethods.org) from Standard Methods Online.

Analytical Technology, Inc. ATI Orion, 529 Main Street, Boston, MA 02129.

Technical Bulletin 601, “Standard Method of Testing for Nitrate in Drinking Water,” July, 1994, PN 221890-001 (referred to as “Technical Bulletin 601”), referenced in Section 611.611.

ASTM. American Society for Testing and Materials, 100 Barr Harbor Drive, West Conshohocken, PA 19428-2959 (610-832-9585).

ASTM Method D511-93 A and B, “Standard Test Methods for Calcium and Magnesium in Water,” “Test Method A—Complexometric Titration” & “Test Method B—Atomic Absorption Spectrophotometric,” approved 1993, referenced in Section 611.611.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

ASTM Method D511-03 A and B, "Standard Test Methods for Calcium and Magnesium in Water," "Test Method A—Complexometric Titration" & "Test Method B—Atomic Absorption Spectrophotometric," approved 2003, referenced in Section 611.611.

ASTM Method D511-09 A and B, "Standard Test Methods for Calcium and Magnesium in Water," "Test Method A—Complexometric Titration" & "Test Method B—Atomic Absorption Spectrophotometric," approved 2009, referenced in Section 611.611.

ASTM Method D515-88 A, "Standard Test Methods for Phosphorus in Water," "Test Method A—Colorimetric Ascorbic Acid Reduction," approved August 19, 1988, referenced in Section 611.611.

ASTM Method D859-94, "Standard Test Method for Silica in Water," approved 1994, referenced in Section 611.611.

ASTM Method D859-00, "Standard Test Method for Silica in Water," approved 2000, referenced in Section 611.611.

ASTM Method D859-05, "Standard Test Method for Silica in Water," approved 2005, referenced in Section 611.611.

ASTM Method D1067-92 B, "Standard Test Methods for Acidity or Alkalinity in Water," "Test Method B—Electrometric or Color-Change Titration," approved May 15, 1992, referenced in Section 611.611.

ASTM Method D1067-02 B, "Standard Test Methods for Acidity or Alkalinity in Water," "Test Method B—Electrometric or Color-Change Titration," approved in 2002, referenced in Section 611.611.



ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

ASTM Method D1125-95(1999) A, "Standard Test Methods for Electrical Conductivity and Resistivity of Water," "Test Method A—Field and Routine Laboratory Measurement of Static (Non-Flowing) Samples," approved 1995, reapproved 1999, referenced in Section 611.611.

ASTM Method D1179-93 B, "Standard Test Methods for Fluoride in Water," "Test Method B—Ion Selective Electrode," approved 1993, referenced in Section 611.611.

ASTM Method D1179-99 B, "Standard Test Methods for Fluoride in Water," "Test Method B—Ion Selective Electrode," approved 1999, referenced in Section 611.611.

ASTM Method D1179-04 B, "Standard Test Methods for Fluoride in Water," "Test Method B—Ion Selective Electrode," approved 2004, referenced in Section 611.611.

ASTM Method D1253-86, "Standard Test Method for Residual Chlorine in Water," reapproved 1992, referenced in Section 611.381.

ASTM Method D1253-96, "Standard Test Method for Residual Chlorine in Water," ~~reapproved~~ approved 1996, referenced in Section 611.381.

ASTM Method D1253-03, "Standard Test Method for Residual Chlorine in Water," ~~reapproved~~ approved 2003, referenced in Sections 611.381 and 611.531.

ASTM Method D1253-08, "Standard Test Method for Residual Chlorine in Water," approved 2008, referenced in Sections 611.381 and 611.531.

ASTM Method D1293-95 A or B, "Standard Test Methods for pH of Water," "Test Method A—Precise Laboratory Measurement" & "Test Method B—Routine or Continuous Measurement," approved 1995, referenced in Section 611.611.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

ASTM Method D1293-99 A or B, "Standard Test Methods for pH of Water," "Test Method A—Precise Laboratory Measurement" & "Test Method B—Routine or Continuous Measurement," approved 1999, referenced in Section 611.611.

ASTM Method D1688-95 A or C, "Standard Test Methods for Copper in Water," "Test Method A—Atomic Absorption, Direct" & "Test Method C—Atomic Absorption, Graphite Furnace," approved 1995, referenced in Section 611.611.

ASTM Method D1688-02 A or C, "Standard Test Methods for Copper in Water," "Test Method A—Atomic Absorption, Direct" & "Test Method C—Atomic Absorption, Graphite Furnace," approved 2002, referenced in Section 611.611.

ASTM Method D1688-07 A or C, "Standard Test Methods for Copper in Water," "Test Method A—Atomic Absorption, Direct" & "Test Method C—Atomic Absorption, Graphite Furnace," approved 2007, referenced in Section 611.611.

ASTM Method D2036-98 A or B, "Standard Test Methods for Cyanide in Water," "Test Method A—Total Cyanides after Distillation" & "Test Method B—Cyanides Amenable to Chlorination by Difference," approved 1998, referenced in Section 611.611.

ASTM Method D2036-06 A or B, "Standard Test Methods for Cyanide in Water," "Test Method A—Total Cyanides after Distillation" & "Test Method B—Cyanides Amenable to Chlorination by Difference," approved 2006, referenced in Section 611.611.

ASTM Method D2459-72, "Standard Test Method for Gamma Spectrometry in Water," approved July 28, 1972, discontinued 1988, referenced in Section 611.720.

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

ASTM Method D2460-90, "Standard Test Method for Radionuclides of Radium in Water," approved 1990, referenced in Section 611.720.

ASTM Method D2460-07, "Standard Test Method for Radionuclides of Radium in Water," approved 2007, referenced in Section 611.720.

ASTM Method D2907-91, "Standard Test Methods for Microquantities of Uranium in Water by Fluorometry," "Test Method A—Direct Fluorometric" & "Test Method B—Extraction," approved June 15, 1991, referenced in Section 611.720.

ASTM Method D2972-97 B or C, "Standard Test Methods for Arsenic in Water," "Test Method B—Atomic Absorption, Hydride Generation" & "Test Method C—Atomic Absorption, Graphite Furnace," approved 1997, referenced in Section 611.611.

ASTM Method D2972-03 B or C, "Standard Test Methods for Arsenic in Water," "Test Method B—Atomic Absorption, Hydride Generation" & "Test Method C—Atomic Absorption, Graphite Furnace," approved 2003, referenced in Section 611.611.

ASTM Method D2972-08 B or C, "Standard Test Methods for Arsenic in Water," "Test Method B—Atomic Absorption, Hydride Generation" & "Test Method C—Atomic Absorption, Graphite Furnace," approved 2008, referenced in Section 611.611.

ASTM Method D3223-97, "Standard Test Method for Total Mercury in Water," approved 1997, referenced in Section 611.611.

ASTM Method D3223-02, "Standard Test Method for Total Mercury in Water," approved 2002, referenced in Section 611.611.

ASTM Method ~~D3454-91~~ D3454-97, "Standard Test Method for Radium-226 in Water," approved ~~1991~~ 1997, referenced in Section 611.720.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

ASTM Method D3454-05, "Standard Test Method for Radium-226 in Water," approved 2005, referenced in Section 611.720.

ASTM Method D3559-96 D, "Standard Test Methods for Lead in Water," "Test Method D—Atomic Absorption, Graphite Furnace," approved August 6, 1990, referenced in Section 611.611.

ASTM Method D3559-03 D, "Standard Test Methods for Lead in Water," "Test Method D—Atomic Absorption, Graphite Furnace," approved 2003, referenced in Section 611.611.

ASTM Method D3559-08 D, "Standard Test Methods for Lead in Water," "Test Method D—Atomic Absorption, Graphite Furnace," approved 2008, referenced in Section 611.611.

ASTM Method D3645-97 B, "Standard Test Methods for Beryllium in Water," "Method B—Atomic Absorption, Graphite Furnace," approved 1997, referenced in Section 611.611.

ASTM Method D3645-03 B, "Standard Test Methods for Beryllium in Water," "Method B—Atomic Absorption, Graphite Furnace," approved 2003, referenced in Section 611.611.

ASTM Method D3645-08 B, "Standard Test Methods for Beryllium in Water," "Method B—Atomic Absorption, Graphite Furnace," approved 2008, referenced in Section 611.611.

ASTM Method D3649-91, "Standard Test Method for High-Resolution Gamma-Ray Spectrometry of Water," approved 1991, referenced in Section 611.720.

ASTM Method D3649-98a, "Standard Test Method for High-Resolution Gamma-Ray Spectrometry of Water," approved 1998, referenced in Section 611.720.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

ASTM Method D3649-06, "Standard Test Method for High-Resolution Gamma-Ray Spectrometry of Water," approved 2006, referenced in Section 611.720.

ASTM Method D3697-92, "Standard Test Method for Antimony in Water," approved June 15, 1992, referenced in Section 611.611.

ASTM Method D3697-02, "Standard Test Method for Antimony in Water," approved 2002, referenced in Section 611.611.

ASTM Method D3697-07, "Standard Test Method for Antimony in Water," approved 2007, referenced in Section 611.611.

ASTM Method D3859-98 A, "Standard Test Methods for Selenium in Water," "Method A—Atomic Absorption, Hydride Method," approved 1998, referenced in Section 611.611.

ASTM Method D3859-03 A, "Standard Test Methods for Selenium in Water," "Method A—Atomic Absorption, Hydride Method," approved 2003, referenced in Section 611.611.

ASTM Method D3859-08 A, "Standard Test Methods for Selenium in Water," "Method A—Atomic Absorption, Hydride Method" & "Method B—Atomic Absorption, Graphite Furnace," approved 2008, referenced in Section 611.611.

ASTM Method D3867-90 A and B, "Standard Test Methods for Nitrite-Nitrate in Water," "Test Method A—Automated Cadmium Reduction" & "Test Method B—Manual Cadmium Reduction," approved January 10, 1990, referenced in Section 611.611.

ASTM Method D3972-90, "Standard Test Method for Isotopic Uranium in Water by Radiochemistry," approved 1990, referenced in Section 611.720.

ASTM Method D3972-02, "Standard Test Method for Isotopic Uranium in Water by Radiochemistry," approved 2002, referenced in Section 611.720.

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

ASTM Method D4107-91, "Standard Test Method for Tritium in Drinking Water," approved 1991, referenced in Section 611.720.

ASTM Method D4107-98, "Standard Test Method for Tritium in Drinking Water," approved 1998 (reapproved 2002), referenced in Section 611.720.

ASTM Method D4107-08, "Standard Test Method for Tritium in Drinking Water," approved 2008 (reapproved 2002), referenced in Section 611.720.

ASTM Method D4327-97, "Standard Test Method for Anions in Water by Ion Chromatography," approved 1997, referenced in Section 611.611.

ASTM Method D4327-03, "Standard Test Method for Anions in Water by Ion Chromatography," approved 2003, referenced in Section 611.611.

ASTM Method ~~D4785-88~~ D4785-93, "Standard Test Method for Low-Level Iodine-131 in Water," approved ~~1988~~ 1993, referenced in Section 611.720.

ASTM Method ~~D4785-00a~~ D4785-98, "Standard Test Method for Low-Level Iodine-131 in Water," approved ~~2000~~ 1998, referenced in Section 611.720.

ASTM Method D4785-08, "Standard Test Method for Low-Level Iodine-131 in Water," approved 2008, referenced in Section 611.720.

ASTM Method ~~D5174-94~~ D5174-97, "Standard Test Method for Trace Uranium in Water by Pulsed-Laser Phosphorimetry," approved ~~1994~~ 1997, referenced in Section 611.720.

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

ASTM Method D5174-02, "Standard Test Method for Trace Uranium in Water by Pulsed-Laser Phosphorimetry," approved 2002, referenced in Section 611.720.

ASTM Method D5174-07, "Standard Test Method for Trace Uranium in Water by Pulsed-Laser Phosphorimetry," approved 2007, referenced in Section 611.720.

ASTM Method D5317-93, "Standard Test Method for Determination of Chlorinated Organic Acid Compounds in Water by Gas Chromatography with an Electron Capture Detector," approved 1993, referenced in Section 611.645.

ASTM Method D5317-98, "Standard Test Method for Determination of Chlorinated Organic Acid Compounds in Water by Gas Chromatography with an Electron Capture Detector," approved 1998 (reapproved 2003), referenced in Section 611.645.

ASTM Method D5673-03, "Standard Test Method for Elements in Water by Inductively Coupled Plasma—Mass Spectrometry," approved 2003, referenced in Section 611.720.

ASTM Method D5673-05, "Standard Test Method for Elements in Water by Inductively Coupled Plasma—Mass Spectrometry," approved 2005, referenced in Section 611.720.

ASTM Method D6508-00(2005), "Standard Test Method for Determination of Dissolved Inorganic Anions in Aqueous Matrices Using Capillary Ion Electrophoresis and Chromate Electrolyte," approved 2000 (revised 2005), referenced in Section 611.611.

ASTM Method D6581-00, "Standard Test Method for Bromate, Bromide, Chlorate, and Chlorite in Drinking Water by Chemically Suppressed Ion Chromatography," approved 2000, referenced in Section 611.381.

ASTM Method D6581-08 A and B, "Standard Test Method for Bromate, Bromide, Chlorate, and Chlorite in Drinking Water by

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Suppressed Ion Chromatography,” “Test Method A—Chemically Suppressed Ion Chromatography” & “Test Method B—Electrolytically Suppressed Ion Chromatography,” approved 2008, referenced in Section 611.381.

ASTM Method D6919-03, “Standard Test Method for Determination of Dissolved Alkali and Alkaline Earth Cations and Ammonium in Water and Wastewater by Ion Chromatography,” approved 2003, referenced in Section 611.611.

ASTM Method D6888-04, “Standard Test Method for Available Cyanide with Ligand Displacement and Flow Injection Analysis (FIA) Utilizing Gas Diffusion Separation and Amperometric Detection,” approved 2004, referenced in Section 611.611.

Bran & Luebbe, 1025 Busch Parkway, Buffalo Grove, IL 60089.

“Fluoride in Water and Wastewater,” Industrial Method #129-71W, December 1972 (referred to as “Technicon Methods—, Method #129-71W”). See 40 CFR 141.23(k)(1), footnote 11 (~~2007~~) (2010), referenced in Section 611.611.

“Fluoride in Water and Wastewater,” #380-75WE, February 1976 (referred to as “Technicon Methods—, Method #380-75WE”). See 40 CFR 141.23(k)(1), footnote 11 (~~2007~~) (2010), referenced in Section 611.611.

Charm Sciences, Inc., 659 Andover St., Lawrence, MA 01843–1032:

“Charm E\*Colite Presence/Absence Test for Detection and Identification of Coliform Bacteria and Escherichia coli in Drinking Water,” January 9, 1998 (referred to as “E\*Colite Test”), referenced in Section 611.802 (also available from USEPA, Water Resource Center).

CPI International, Inc., 5580 Skylane Blvd., Santa Rosa, CA 95403 (800-878-7654/fax: 707-545-7901/Internet address: [www.cpiinternational.com](http://www.cpiinternational.com)).



ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

“Colitag® Product as a Test for Detection and Identification of Coliforms and E. coli Bacteria in Drinking Water and Source Water as Required in National Primary Drinking Water Regulations,” August 2001, referenced in Section 611.526.

“Modified Colitag™ Test Method for Simultaneous Detection of E. coli and other Total Coliforms in Water (ATP D05-0035),” August 2009 (referred to as “Modified Colitag™ Method”), referenced in Sections 611.526 and 611.802. See also NEMI.

EMD Chemicals Inc. (an affiliate of Merck KGaA, Darmstadt, Germany), 480 S. Democrat Road, Gibbstown, NJ 08027-1297. (800-222-0342/e-mail: adellenbusch@emscience.com).

“Chromocult® Coliform Agar Presence/Absence Membrane Filter Test Method for Detection and Identification of Coliform Bacteria and Escherichia coli in Finished Waters,” November 2000 referred to as “Chromocult® Method, Version 1.0, referenced in Section Sections 611.526 and 611.802.

“Readycult Coliforms 100 Presence/Absence Test for Detection and Identification of Coliform Bacteria and Escherichia coli in Finished Waters,” November 2000 (referred to as Readycult® 2000), Version 1.0, referenced in Section 611.526.

“Readycult Coliforms 100 Presence/Absence Test for Detection and Identification of Coliform Bacteria and Escherichia coli in Finished Waters,” Version 1.1, January 2007 (referred to as Readycult® 2007), referenced in Section 611.802.

~~ERDA Health and Safety Laboratory, New York, NY.~~

~~HASL Procedure Manual, HASL 300, 1973. See 40 CFR 141.25(b)(2) (2007), referenced in Section 611.720.~~

Georgia Tech Research Institute, Robert Rosson, 925 Dalney Road, Atlanta, GA 30332 (404-407-6339).

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

“The Determination of Radium-226 and Radium-228 in Drinking Water by Gamma-ray Spectrometry Using HPGE or Ge(Li) Detectors,” Revision 1.2, December 2004 (called “Georgia Radium Method”), referenced in Section 611.720.

Great Lakes Instruments, Inc., 8855 North 55th Street, Milwaukee, WI 53223.

GLI Method 2, “Turbidity,” Nov. 2, 1992, referenced in Section 611.531.

H&E Testing Laboratory, 221 State Street, Augusta, ME 04333 (207-287-2727).

Method ME355.01, Revision 1, “Determination of Cyanide in Drinking Water by GC/MS Headspace Analysis,” May 2009, referenced in Section 611.611. See also NEMI.

The Hach Company, P.O. Box 389, Loveland, CO 80539-0389 (800-227-4224).

“Lead in Drinking Water by Differential Pulse Anodic Stripping Voltammetry,” Method 1001, August 1999, referenced in Section 611.611.

“Determination of Turbidity by Laser Nephelometry,” January 2000, Revision 2.0 (referred to as “Hach FilterTrak Method 10133”), referenced in Section 611.531.

“Total Coliforms and E. coli Membrane Filtration Method with m-ColiBlue24® Broth,” Method No. 10029, Revision 2, August 17, 1999 (referred to as “m-ColiBlue24 Test”), referenced in Section 611.802 (also available from USEPA, Water Resource Center).

IDEXX Laboratories, Inc., One IDEXX Drive, Westbrook, Maine 04092 (800-321-0207).

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

“IDEXX SimPlate™ HPC Test Method for Heterotrophs in Water,” November 2000 (referred to as “SimPlate method”), referenced in Section 611.531.

Industrial Test Systems, Inc., 1875 Langston St., Rock Hill, SC 29730.

Method D99-003, Revision 3.0, “Free Chlorine Species (HOCl and OCl<sup>-</sup>) by Test Strip,” November 21, 2003 (referred to as “ITS Method D99-003”), referenced in Section 611.381.

Lachat Instruments, 6645 W. Mill Rd., Milwaukee, WI 53218 (414-358-4200).

“Digestion and distillation of total cyanide in drinking and wastewaters using MICRO DIST and determination of cyanide by flow injection analysis,” Revision 2.1, November 30, 2000 (referred to as “QuikChem Method 10-204-00-1-X”), referenced in Section 611.611.

Leck Mitchell, PhD, PE, 656 Independence Valley Dr., Grand Junction, CO 81507. See also NEMI.

Mitchell Method M5271, “Determination of Turbidity by Laser Nephelometry,” March 2009, referenced in Section 611.531.

Mitchell Method M5331, “Determination of Turbidity by LED Nephelometry,” March 2009, referenced in Section 611.531.

Millipore Corporation, Technical Services Department, 80 Ashby Road, Milford, MA 01730 (800-654-5476).

Colisure Presence/Absence Test for Detection and Identification of Coliform Bacteria and Escherichia Coli in Drinking Water, February 28, 1994 (referred to as “Colisure Test”), referenced in Section 611.526.

NCRP. National Council on Radiation Protection, 7910 Woodmont Ave., Bethesda, MD (301-657-2652).

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

NCRP Report Number 22, "Maximum Permissible Body Burdens and Maximum Permissible Concentrations of Radionuclides in Air and in Water for Occupational Exposure," NCRP Report Number 22, June 5, 1959, referenced in Section 611.101.

NEMI. National Environmental Method Index (on-line at [www.nemi.gov](http://www.nemi.gov)).

AMI Turbiwell Method, "Continuous Measurement of Turbidity Using a SWAN AMI Turbiwell Turbidimeter," August 2009. See also SWAN Analytische Instrumente AG.

Method ME355.01, Revision 1, "Determination of Cyanide in Drinking Water by GC/MS Headspace Analysis," May 2009, referenced in Section 611.611. See also H&E Testing Laboratory.

Mitchell Method M5271, "Determination of Turbidity by Laser Nephelometry," March 2009, referenced in Section 611.531. See also Leck Mitchell, PhD, PE.

Mitchell Method M5331, "Determination of Turbidity by LED Nephelometry," March 2009, referenced in Section 611.531. See also Leck Mitchell, PhD, PE

Modified Colitag™ Method, "Modified Colitag™ Test Method for Simultaneous Detection of E. coli and other Total Coliforms in Water (ATP D05-0035)," August 2009, referenced in Sections 611.526 and 611.802. See also CPI International, Inc.

Orion Method AQ4500, "Determination of Turbidity by LED Nephelometry," May 2009, referenced in Section 611.531. See also Thermo Scientific.

Palintest ChloroSense, "Measurement of Free and Total Chlorine in Drinking Water by Palintest ChloroSense," September 2009 (referred to as "Palintest ChloroSense"), referenced in Sections 611.381 and 611.531. See also Palintest.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

“Systea Easy (1-Reagent) Nitrate Method,” referenced in Section 611.611. See also Systea Scientific, LLC.

NSF. National Sanitation Foundation International, 3475 Plymouth Road, PO Box 130140, Ann Arbor, Michigan 48113-0140 (734-769-8010).

NSF Standard 61, section 9, November 1998, referenced in Sections 611.126 and 611.356.

NTIS. National Technical Information Service, U.S. Department of Commerce, 5285 Port Royal Road, Springfield, VA 22161 (703-487-4600 or 800-553-6847).

Dioxin and Furan Method 1613, Revision B, “Tetra- through Octa-Chlorinated Dioxins and Furans by Isotope Dilution HRGC/HRMS,” October 1994, Revision B, EPA 821/B-94/005, Doc. No. 94-104774, referenced in Section 611.645. See also USEPA, NSCEP.

“Interim Radiochemical Methodology for Drinking Water,” EPA 600/4-75-008 (revised), March 1976 (referred to as “USEPA Interim Radiochemical Methods”), referenced in Section 611.720. (Pages 1, 4, 6, 9, 13, 16, 24, 29, 34)

Kelada 01, “Kelada Automated Test Methods for Total Cyanide, Acid Dissociable Cyanide, and Thiocyanate,” Revision 1.2, August 2001, EPA 821/B-01-009 (referred to as “Kelada 01”), referenced in Section 611.611.

“Maximum Permissible Body Burdens and Maximum Permissible Concentrations of Radionuclides in Air and in Water for Occupational Exposure,” NBS (National Bureau of Standards) Handbook 69, as amended August 1963, U.S. Department of Commerce, referenced in Section 611.330.

Method 100.1, “Analytical Method for Determination of Asbestos Fibers in Water,” EPA 600/4-83-043, September 1983, Doc. No.

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~PB83-260471 (referred to as "USEPA Asbestos Methods 100.1"), referenced in Section 611.611.~~

~~Method 100.2, "Determination of Asbestos Structures over 10 mm in Length in Drinking Water," EPA 600/R-94-134, June 1994, Doc. No. PB94-201902 (referred to as "USEPA Asbestos Methods 100.2"), referenced in Section 611.611.~~

~~"Methods for Chemical Analysis of Water and Wastes," March 1983, EPA 600/4-79-020, Doc. No. PB84-128677 (referred to as "USEPA Inorganic Methods"). (Method 300.0. Methods 150.1, 150.2, and 245.2, which formerly appeared in this reference, are available from USEPA EMSL.), referenced in Section 611.611.~~

~~"Methods for the Determination of Inorganic Substances in Environmental Samples," August 1993, EPA 600/R-93-100, Doc. No. PB94-120821 (referred to as "USEPA Environmental Inorganic Methods"), referenced in Sections 611.381, 611.531, and 611.611. (For methods 180.1, 300.0, 335.4, 353.2, and 365.1.)~~

~~"Methods for the Determination of Metals in Environmental Samples," June 1991, EPA 600/4-91-010, Doc. No. PB91-231498 and "Methods for the Determination of Metals in Environmental Samples—Supplement I," May 1994, EPA 600/R-94-111, Doc. No. PB95-125472 (referred to as "USEPA Environmental Metals Methods"), referenced in Sections 611.611, 611.612, and 611.720. (For methods 200.7, 200.8, 200.9, and 245.1.) See also USEPA, NSCEP.~~

~~"Methods for the Determination of Organic and Inorganic Compounds in Drinking Water, Volume 1" August 2000, EPA 815/R-00/014, Doc. No. PB2000-106981 (referred to as "USEPA Organic and Inorganic Methods"), referenced in Section 611.381. (For methods 300.1 and 321.8.)~~

~~"Methods for the Determination of Organic Compounds in Drinking Water," December 1988, revised July 1991, EPA 600/4-88/039, Doc. No. PB91-231480 (referred to as "USEPA Organic~~

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Methods”), referenced in Sections 611.645 and 611.648. (For methods 502.2, 505, 507, 508, 508A, 515.1, and 531.1.)

“Methods for the Determination of Organic Compounds in Drinking Water—Supplement I,” July 1990, EPA 600/4-90/020, Doc. No. PB91-146027 (referred to as “USEPA Organic Methods”), referenced in Section 611.645. (For methods 506, 547, 550, 550.1, and 551.)

“Methods for the Determination of Organic Compounds in Drinking Water—Supplement II,” August 1992, EPA 600/R-92/129, Doc. No. PB92-207703 (referred to as “USEPA Organic Methods”), referenced in Sections 611.381 and 611.645. (For methods 515.2, 524.2, 548.1, 549.1, 552.1, and 555.)

“Methods for the Determination of Organic Compounds in Drinking Water—Supplement III,” August 1995, EPA 600/R-95/131, Doc. No. PB95-261616, (referred to as “USEPA Organic Methods”), referenced in Sections 611.381 and 611.645. (For methods 502.2, 524.2, 551.1, and 552.2.)

“Prescribed Procedures for Measurement of Radioactivity in Drinking Water,” EPA 600/4-80/032, August 1980 (Doc. No. PB 80-224744) (referred to as “USEPA Radioactivity Methods”), referenced in Section 611.720. (For methods 900, 901, 901.1, 902, 903, 903.1, 904, 905, 906, 908, 908.1)

“Procedures for Radiochemical Analysis of Nuclear Reactor Aqueous Solutions,” H.L. Krieger and S. Gold, EPA-R4-73-014, May 1973, Doc. No. PB222-154/7BA, referenced in Section 611.720.

“Radiochemical Analytical Procedures for Analysis of Environmental Samples,” March 1979, Doc. No. EMSL LV 053917 (referred to as “USEPA Radiochemical Analyses”), referenced in Section 611.720. (Pages 1, 19, 33, 65, 87, 92)

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

“Radiochemistry Procedures Manual,” EPA 520/5-84-006, August 1984, Doc. No. PB84-215581 (referred to as “USEPA Radiochemistry Methods”), referenced in Section 611.720. (Methods 00-01, 00-02, 00-07, H-02, Ra-03, Ra-04, Ra-05, Sr-04)

“Technical Notes on Drinking Water Methods,” EPA 600/R-94/173, October 1994, Doc. No. PB95-104766 (referred to as “USEPA Technical Notes”), referenced in Sections 611.531, 611.611, and 611.685.

BOARD NOTE: USEPA made the following assertion with regard to this reference at 40 CFR 141.23(k)(1) and 141.24(e) and (n)(11) (2007): “This document contains other analytical test procedures and approved analytical methods that remain available for compliance monitoring until July 1, 1996.” Also available online at <http://nepis.epa.gov/EPA/html/Pubs/pubtitleORD.htm> under the document designation “600R94173.”

“Method 1613: Tetra through Octa-Chlorinated Dioxins and Furans by Isotope Dilution HRGC/HRMS,” October 1994, EPA 821/B-94/005, Doc. No. 94-104774 (referred to as “Dioxin and Furan Method 1613”), referenced in Section 611.645.

USEPA Method 326.0, Revision 1.0, “Determination of Inorganic Oxyhalide Disinfection By Products in Drinking Water Using Ion Chromatography Incorporating the Addition of a Suppressor Acidified Postcolumn Reagent for Trace Bromate Analysis,” USEPA, June 2002, EPA 815/R-03/007, Doc. No. PB2003-107402 (referred to as “OGWDW Methods, Method 326.0, rev. 1.0”), referenced in Sections 611.381 and 611.382.

BOARD NOTE: Also available from United States Environmental Protection Agency, Office of Ground Water and Drinking Water.

USEPA Asbestos Method 100.1, “Analytical Method for Determination of Asbestos Fibers in Water,” EPA 600/4-83-043, September 1983, Doc. No. PB83-260471, referenced in Section 611.611. See also USEPA, NSCEP.



ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

USEPA Asbestos Method 100.2, "Determination of Asbestos Structures over 10-mm in Length in Drinking Water," EPA 600/R-94-134, June 1994, Doc. No. PB94-201902, referenced in Section 611.611. See also USEPA, NSCEP.

USEPA Environmental Inorganic Methods, "Methods for the Determination of Inorganic Substances in Environmental Samples," August 1993, EPA 600/R-93-100, Doc. No. PB94-121811, referenced in Sections 611.381, 611.531, and 611.611. (Methods 180.1 (rev. 2.0), 300.0 (rev. 2.1), 335.4 (rev. 1.0), 353.2 (rev. 2.0), and 365.1 (rev. 2.0) only.) See also USEPA, NSCEP.

USEPA Environmental Metals Methods, "Methods for the Determination of Metals in Environmental Samples—Supplement I," May 1994, EPA 600/R-94-111, Doc. No. PB95-125472, referenced in Sections 611.611, 611.612, and 611.720. (Methods 200.7 (rev. 4.4), 200.8 (rev. 5.3), 200.9 (rev. 2.2), and 245.1 (rev. 3.0) only.) See also USEPA, NSCEP.

USEPA Inorganic Methods, "Methods for Chemical Analysis of Water and Wastes," March 1983, EPA 600/4-79-020, Doc. No. PB84-128677. (Methods 150.1, 150.2, and 245.2 only.), referenced in Section 611.611. See also USEPA, NSCEP.

USEPA Interim Radiochemical Methods, "Interim Radiochemical Methodology for Drinking Water," EPA 600/4-75-008 (revised), Doc. No. PB253258, March 1976, referenced in Section 611.720.

USEPA OGWDW Methods, Method 326.0, Revision 1.0, "Determination of Inorganic Oxyhalide Disinfection By-Products in Drinking Water Using Ion Chromatography Incorporating the Addition of a Suppressor Acidified Postcolumn Reagent for Trace Bromate Analysis," June 2002, EPA 815/R-03/007, Doc. No. PB2003-107402, referenced in Sections 611.381 and 611.382. See also USEPA, NSCEP and USEPA, OGWDW.

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

USEPA Organic and Inorganic Methods, "Methods for the Determination of Organic and Inorganic Compounds in Drinking Water, Volume 1," August 2000, EPA 815/R-00/014, Doc. No. PB2000-106981, referenced in Section 611.381. (For methods 300.1 (rev. 1.0) and 321.8 (rev. 1.0).) See also USEPA, NSCEP.

USEPA Organic Methods, "Methods for the Determination of Organic Compounds in Drinking Water," December 1988 (revised July 1991), EPA 600/4-88/039, Doc. No. PB91-231480, referenced in Sections 611.645 and 611.648 (Methods 508A (rev. 1.0) and 515.1 (rev. 4.0) only); "Methods for the Determination of Organic Compounds in Drinking Water—Supplement I," July 1990, EPA 600/4-90/020, Doc. No. PB91-146027, referenced in Section 611.645 (Methods 547, 550, and 550.1 only); "Methods for the Determination of Organic Compounds in Drinking Water—Supplement II," August 1992, EPA 600/R-92/129, Doc. No. PB92-207703, referenced in Sections 611.381 and 611.645. (Methods 548.1 (rev. 1.0), 552.1 (rev. 1.0), and 555 (rev. 1.0) only); and "Methods for the Determination of Organic Compounds in Drinking Water—Supplement III," August 1995, EPA 600/R-95/131, Doc. No. PB95-261616, referenced in Sections 611.381, 611.645, and 611.648 (Methods 502.2 (rev. 2.1), 504.1 (rev. 1.1), 505 (rev. 2.1), 506 (rev. 1.1), 507 (rev. 2.1), 508 (rev. 3.1), 508.1 (rev. 2.0), 515.2 (rev. 1.1), 524.2 (rev. 4.1), 525.2 (rev. 2.0), 531.1 (rev. 3.1), 551.1 (rev. 1.0), and 552.2 (rev. 1.0) only.) See also USEPA, EMSL and USEPA, NSCEP.

USEPA Radioactivity Methods, "Prescribed Procedures for Measurement of Radioactivity in Drinking Water," EPA 600/4-80/032, August 1980, Doc. No. PB80-224744, referenced in Section 611.720 (Methods 900.0, 901.0, 901.1, 902.0, 903.0, 903.1, 904.0, 905.0, 906.0, 908.0, 908.1). See also USEPA, NSCEP.

USEPA Radiochemical Analyses, "Radiochemical Analytical Procedures for Analysis of Environmental Samples," March 1979, Doc. No. EMSL LV 053917, referenced in Section 611.720. (Pages 1-5, 19-32, 33-48, 65-73, 87-91, and 92-95 only.)

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

USEPA Radiochemistry Procedures, "Radiochemistry Procedures Manual," EPA 520/5-84-006, August 1984, Doc. No. PB84-215581 (referred to as ""), referenced in Section 611.720. (Methods 00-01, 00-02, 00-07, H-02, Ra-03, Ra-04, Ra-05, Sr-04 only.)

USEPA Technical Notes, "Technical Notes on Drinking Water Methods," EPA 600/R-94/173, October 1994, Doc. No. PB95-104766, referenced in Sections 611.531, 611.611, and 611.645. See also USEPA, NSCEP.

BOARD NOTE: USEPA made the following assertion with regard to this reference at 40 CFR 141.23(k)(1) and 141.24(e) and (n)(11) (2010): "This document contains other analytical test procedures and approved analytical methods that remain available for compliance monitoring until July 1, 1996." Also available online at <http://nepis.epa.gov/EPA/html/Pubs/pubtitleORD.htm> under the document designation "600R94173."

New Jersey Department of Environment, Division of Environmental Quality, Bureau of Radiation and Inorganic Analytical Services, 9 Ewing Street, Trenton, NJ 08625.

"Determination of Radium 228 in Drinking Water," August 1990 (referred to as "New Jersey Radium Method"), referenced in Section 611.720.

New York Department of Health, Radiological Sciences Institute, Center for Laboratories and Research, Empire State Plaza, Albany, NY 12201.

"Determination of Ra-226 and Ra-228 (Ra-02)," January 1980, Revised June 1982 (referred to as "New York Radium Method"), referenced in Section 611.720.

Palintest, Ltd., 21 Kenton Lands Road, P.O. Box 18395, Erlanger, KY (800-835-9629).

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Palintest Method 1001, "Lead in Drinking Water by Differential Pulse Anodic Stripping Voltammetry," Method 1001, August 1999 (referred to as "Palintest Method 1001"), referenced in Section 611.611.

Palintest ChloroSense, "Measurement of Free and Total Chlorine in Drinking Water by Palintest ChloroSense," September 2009, referenced in Sections 611.381 and 611.531. See also NEMI.

Standard Methods Online, available online from the Standard Methods Organization at [www.standardmethods.org](http://www.standardmethods.org).

Method 6610 B-04, Carbamate Pesticides, High-Performance Liquid Chromatographic Method, referenced in Section 611.645.

Method 9230 B-04, Fecal Streptococcus and Enterococcus Groups, Multiple Tube Techniques, referenced in Section 611.802.

BOARD NOTE: Where, in appendix A to subpart C of 40 CFR 141, USEPA has authorized use of an approved alternative method from Standard Methods Online, and that version of the method appears also in Standard Methods, 21st ed., the Board cites only to Standard Methods, 21st ed. for that method. The methods that USEPA listed as available from Standard Methods Online, and which are listed above as in Standard Methods, 21st edition, are the following: 4500-P E-99, 4500-P F-99, 6640 B-01, and 9223 B-97. Since each method is the same version from both sources, the Board views a copy from Standard Methods Online as equivalent to a copy from Standard Methods Online, even though the Board does not also cite to Standard Methods Online. The Board intends that use of the method from either source is acceptable.

SWAN Analytische Instrumente AG, Studbachstrasse 13, CH-8340, Hinwil, Switzerland.

AMI Turbiwell Method, "Continuous Measurement of Turbidity Using a SWAN AMI Turbiwell Turbidimeter," August 2009, referenced in Section 611.531. See also NEMI.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Syngenta Crop Protection, Inc., 410 Swing Road, Post Office Box 18300, Greensboro, NC 27419 (336-632-6000).

“Atrazine in Drinking Water by Immunoassay,” February 2001 (referred to as “Syngenta AG-625”), referenced in Section 611.645.

Systea Scientific LLC, 900 Jorie Blvd., Suite 35, Oak Brook, IL 60523.

Systea Easy (1-Reagent), “Systea Easy (1-Reagent) Nitrate Method.” February 2009, referenced in Section 611.611. See also NEMI.

Thermo Scientific, 166 Cummings Center, Beverly, MA 01915. (www.thermo.com)

Orion Method AQ4500, “Determination of Turbidity by LED Nephelometry,” May 2009, referenced in Section 611.531. See also NEMI.

USDOE, EML. United States Department of Energy, available at the Environmental Measurements Laboratory, U.S. Department of Energy, 376 Hudson Street, New York, NY 10014-3621.

“EML Procedures Manual,” HASL 300, 27th Edition, Volume 1, 1990 (referred to as “USDOE EML Procedures Manual (27th ed.)”), referenced in Section 611.720.

“EML Procedures Manual,” HASL 300, 28th ed., 1997 (referred to as “EML Procedures Manual (28th ed.)”), referenced in Section 611.720.

USEPA, EMSL. United States Environmental Protection Agency, Environmental Monitoring and Support Laboratory, Cincinnati, OH 45268 (513-569-7586).

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

USEPA Interim Radiochemical Methods, "Interim Radiochemical Methodology for Drinking Water," EPA 600/4-75/008 (revised), March 1976, referenced in Section 611.720. See also NTIS.

USEPA Organic Methods, "Methods for the Determination of Organic Compounds in Drinking Water," December 1988 (revised July 1991), EPA 600/4-88/039, referenced in Sections 611.645 and 611.648 (Methods 508A (rev. 1.0) and 515.1 (rev. 4.0) only); "Methods for the Determination of Organic Compounds in Drinking Water—Supplement I," July 1990, EPA 600/4-90/020, referenced in Sections 611.645 and 611.648 (Methods 547, 550, and 550.1 only); "Methods for the Determination of Organic Compounds in Drinking Water—Supplement II," August 1992, EPA 600/R-92/129, referenced in Sections 611.381 and 611.645 (Methods 548.1 (rev. 1.0), 552.1 (rev. 1.0), and 555 (rev. 1.0) only); "Methods for the Determination of Organic Compounds in Drinking Water—Supplement III," August 1995, EPA 600/R-95/131, referenced in Sections 611.381, 611.645, and 611.648 (Methods 502.2 (rev. 2.1), 504.1 (rev. 1.1), 505 (rev. 2.1), 506 (rev. 1.1), 507 (rev. 2.1), 508 (rev. 3.1), 508.1 (rev. 2.0), 515.2 (rev. 4.1), 524.2 (rev. 4.1), 525.2 (rev. 2.0), 551.1 (rev. 1.0), and 552.2 (rev. 1.0) only). See also NTIS and USEPA, NSCEP.

"Procedures for Radiochemical Analysis of Nuclear Reactor Aqueous Solutions," referenced in Section 611.720. See also NTIS.

USEPA, NSCEP. United States Environmental Protection Agency, National Service Center for Environmental Publications, P.O. Box 42419, Cincinnati, OH 45242-0419 (accessible on-line and available by download from <http://www.epa.gov/nscep/>).

Dioxin and Furan Method 1613, Revision B, "Tetra- through Octa-Chlorinated Dioxins and Furans by Isotope Dilution HRGC/HRMS," October 1994, EPA 821/B-94/005, referenced in Section 611.645. See also NTIS.

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Guidance Manual for Filtration and Disinfection, "Guidance Manual for Compliance with the Filtration and Disinfection Requirements for Public Water Systems Using Surface Water Sources," March 1991, EPA 570/3-91-001, referenced in Section 611.111.

USEPA Asbestos Method 100.1, "Analytical Method for Determination of Asbestos Fibers in Water," September 1983, EPA 600/4-83-043, referenced in Section 611.611. See also NTIS.

USEPA Asbestos Method 100.2, "Determination of Asbestos Structures over 10-mm in Length in Drinking Water," June 1994, EPA 600/R-94-134, referenced in Section 611.611. See also NTIS.

USEPA Environmental Inorganic Methods, "Methods for the Determination of Inorganic Substances in Environmental Samples," August 1993, EPA 600/R-93-100, referenced in Sections 611.381, 611.531, and 611.611. (Methods 180.1 (rev. 2.0), 300.0 (rev. 2.1), 335.4 (rev. 1.0), 353.2 (rev. 2.0), and 365.1 (rev. 2.0) only.) See also NTIS.

USEPA Environmental Metals Methods, "Methods for the Determination of Metals in Environmental Samples—Supplement I," May 1994, EPA 600/R-94-111, referenced in Sections 611.611, 611.612, and 611.720. (Methods 200.7 (rev. 4.4), 200.8 (rev. 5.3), 200.9 (rev. 2.2), and 245.1 (rev. 3.0) only.) See also NTIS.

USEPA Inorganic Methods, "Methods for Chemical Analysis of Water and Wastes," March 1983, EPA 600/4-79-020, referenced in Section 611.611. (Methods 150.1, 150.2, and 245.2 only.) See also NTIS.

USEPA OGWDW Methods, Method 302.0, "Determination of Bromate in Drinking Water Using Two-Dimensional Ion Chromatography with Suppressed Conductivity Detection," September 2009, EPA 815/B-09/014, referenced in Sections 611.381 and 611.382. See also USEPA, OGWDW.

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

USEPA OGWDW Methods, Method 317.0, rev. 2.0, "Determination of Inorganic Oxhalide Disinfection By-Products in Drinking Water Using Ion Chromatography with the Addition of a Postcolumn Reagent for Trace Bromate Analysis," July 2001, EPA 815/B-01/001, referenced in Sections 611.381 and 611.382. See also USEPA, OGWDW.

USEPA OGWDW Methods, Method 326.0, rev. 1.0, "Determination of Inorganic Oxhalide Disinfection By-Products in Drinking Water Using Ion Chromatography Incorporating the Addition of a Suppressor Acidified Postcolumn Reagent for Trace Bromate Analysis," June 2002, EPA 815/R-03/007, referenced in Sections 611.381 and 611.382. See also NTIS and USEPA, OGWDW.

USEPA OGWDW Methods, Method 327.0, rev. 1.1, "Determination of Chlorine Dioxide and Chlorite Ion in Drinking Water Using Lissamine Green B and Horseradish Peroxidase with Detection by Visible Spectrophotometry," May 2005, EPA 815/R-05/008, referenced in Sections 611.381 and 611.531. See also USEPA, OGWDW.

USEPA OGWDW Methods, Method 334.0, "Determination of Residual in Drinking Water Using an On-line Chlorine Analyzer," August 2009, EPA 815/B-09/013, referenced in Section 611.531. See also USEPA, OGWDW.

USEPA OGWDW Methods, Method 531.2, rev. 1.0, "Measurement of N-methylcarbamoyloximes and N-methylcarbamates in Water by Direct Aqueous Injection HPLC with Postcolumn Derivatization," September 2001, EPA 815/B-01/002 (document file name "met531\_2.pdf"), referenced in Section 611.645. See also USEPA, OGWDW.

USEPA OGWDW Methods, Method 552.3, rev. 1.0, "Determination of Haloacetic Acids and Dalapon in Drinking Water by Liquid-Liquid Microextraction, Derivatization, and Gas



ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Chromatography with Electron Capture Detection,” July 2003, EPA 815/B-03/002, referenced in Sections 611.381 and 611.645.

USEPA OGWDW Methods, Method 557, “Determination of Haloacetic Acids, Bromate, and Dalapon in Drinking Water by Ion Chromatography Electrospray Ionization Tandem Mass Spectrometry,” July 2003, EPA 815/B-03/002, referenced in Sections 611.381, 611.382, and 611.645. See also USEPA, OGWDW.

USEPA OGWDW Methods, Method 1622 (01), “Cryptosporidium in Water by Filtration/IMS/FA,” April 2001, EPA 821/R-01/026, referenced in Section 611.1007. See also USEPA, OGWDW.

USEPA Organic and Inorganic Methods, “Methods for the Determination of Organic and Inorganic Compounds in Drinking Water, Volume 1,” August 2000, EPA 815/R-00/014, referenced in Section 611.381. (Methods 300.1 (rev. 1.0) and 321.8 (rev. 1.0) only.) See also NTIS.

USEPA Organic Methods, “Methods for the Determination of Organic Compounds in Drinking Water,” December 1988, revised July 1991, EPA 600/4-88/039, referenced in Sections 611.645 and 611.648 (Methods 508A (rev. 1.0) and 515.1 (rev. 4.0) only); “Methods for the Determination of Organic Compounds in Drinking Water—Supplement I,” July 1990, EPA 600/4-90/020, referenced in Section 611.645 and 611.648 (Methods 547, 550, and 550.1 only); “Methods for the Determination of Organic Compounds in Drinking Water—Supplement II,” August 1992, EPA 600/R-92/129, referenced in Sections 611.381 and 611.645 (Methods 548.1 (rev. 1.0), 552.1 (rev. 1.0), and 555 (rev. 1.0) only); “Methods for the Determination of Organic Compounds in Drinking Water—Supplement III,” August 1995, EPA 600/R-95/131, referenced in Sections 611.381, 611.645, and 611.648 (Methods 502.2 (rev. 2.1), 504.1 (rev. 1.1), 505 (rev. 2.1), 506 (rev. 1.1), 507 (rev. 2.1), 508 (rev. 3.1), 508.1 (rev. 2.0), 515.2 (rev. 4.1), 524.2 (rev. 4.1), 525.2 (rev. 2.0), 531.1 (rev. 3.1), 551.1 (rev.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

1.0), and 552.2 (rev. 1.0) only). See also NTIS and USEPA, EMSL.

USEPA Radioactivity Methods, "Prescribed Procedures for Measurement of Radioactivity in Drinking Water," August 1980, EPA 600/4-80/032, referenced in Section 611.720. (For methods 900.0, 901, 901.1, 902, 903, 903.1, 904, 905, 906, 908, 908.1 only.) See also NTIS.

USEPA Technical Notes, "Technical Notes on Drinking Water Methods," October 1994, EPA 600/R-94/173, referenced in Sections 611.531, 611.611, and 611.645. See also NTIS.

BOARD NOTE: USEPA made the following assertion with regard to this reference at 40 CFR 141.23(k)(1) and 141.24(e) and (n)(11) (2007): "This document contains other analytical test procedures and approved analytical methods that remain available for compliance monitoring until July 1, 1996." Also available online at <http://nepis.epa.gov/EPA/html/Pubs/pubtitleORD.htm> under the document designation "600R94173."

USEPA, OGWDW. United States Environmental Protection Agency, USEPA, Office of Ground Water and Drinking Water (accessible on-line and available by download from <http://www.epa.gov/safewater/methods/>).

USEPA OGWDW Methods, Method 302.0, "Determination of Bromate in Drinking Water Using Two-Dimensional Ion Chromatography with Suppressed Conductivity Detection," September 2009, EPA 815/B-09/014, referenced in Section 611.381. See also USEPA, NSCEP.

USEPA OGWDW Methods, Method 317.0, ~~Revision~~ rev. 2.0, "Determination of Inorganic Oxyhalide Disinfection By-Products in Drinking Water Using Ion Chromatography with the Addition of a Postcolumn Reagent for Trace Bromate Analysis," USEPA, July 2001, EPA 815/B-01/001 (referred to as "OGWDW Methods, Method 317.0, rev. 2.0"), referenced in Sections ~~Section~~ Section 611.381 and 611.382. See also USEPA, NSCEP.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

USEPA OGWDW Methods, Method 326.0, ~~Revision rev. 1.0~~,  
“Determination of Inorganic Oxyhalide Disinfection By-Products  
in Drinking Water Using Ion Chromatography Incorporating the  
Addition of a Suppressor Acidified Postcolumn Reagent for Trace  
Bromate Analysis,” USEPA, June 2002, EPA 815/R-03/007  
(referred to as “OGWDW Methods, Method 326.0, rev. 1.0”),  
referenced in ~~Sections~~ Section 611.381 and 611.382. See also  
NTIS and USEPA, NSCEP.

~~BOARD NOTE: Also available from NTIS.~~

USEPA OGWDW Methods, Method 327.0, ~~Revision rev. 1.1~~,  
“Determination of Chlorine Dioxide and Chlorite Ion in Drinking  
Water Using Lissamine Green B and Horseradish Peroxidase with  
Detection by Visible Spectrophotometry,” USEPA, May 2005,  
EPA 815/R-05/008 (referred to as “OGWDW Methods, Method  
327.0, rev. 1.1”), referenced in Sections 611.381 and 611.531. See  
also USEPA, NSCEP.

USEPA OGWDW Methods, Method 334.0, “Determination of  
Residual in Drinking Water Using an On-line Chlorine Analyzer,”  
USEPA, August 2009, EPA 815/B-09/013, referenced in Section  
611.531. See also USEPA, NSCEP.

USEPA OGWDW Methods, Method 515.4, ~~Revision rev. 1.0~~,  
“Determination of Chlorinated Acids in Drinking Water by Liquid-  
Liquid Microextraction, Derivatization and Fast Gas  
Chromatography with Electron Capture Detection,” April 2000,  
EPA 815/B-00/001 (document file name “met515\_4.pdf”) (referred  
to as “OGWDW Methods, Method 515.4, rev. 1.0”), referenced in  
Section 611.645.

USEPA OGWDW Methods, Method 524.3, rev. 1.0,  
“Measurement of Purgeable Organic Compounds in Water by  
Capillary Column Gas Chromatography/Mass Spectrometry,” June  
2009, EPA 815/B-09/009 (referred to as “Method 524.3 (rev.  
1.0)”), referenced in Sections 611.381 and 611.645.

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

USEPA OGWDW Methods, Method 531.2, ~~Revision~~ rev. 1.0, "Measurement of N-methylcarbamoyloximes and N-methylcarbamates in Water by Direct Aqueous Injection HPLC with Postcolumn Derivatization," September 2001, EPA 815/B-01/002 (document file name "met531\_2.pdf") (~~referred to as "OGWDW Methods, Method 531.2, rev. 1.0"~~), referenced in Section 611.645. See also USEPA, NSCEP.

USEPA OGWDW Methods, Method 552.3, ~~Revision~~ rev. 1.0, "Determination of Haloacetic Acids and Dalapon in Drinking Water by Liquid-liquid Microextraction, Derivatization, and Gas Chromatography with Electron Capture Detection," USEPA, July 2003, EPA 815/B-03/002 (~~referred to as "OGWDW Methods, Method 552.3, rev. 1.0"~~), referenced in Sections 611.381 and 611.645.

USEPA OGWDW Methods, Method 557, "Determination of Haloacetic Acids, Bromate, and Dalapon in Drinking Water by Ion Chromatography Electrospray Ionization Tandem Mass Spectrometry," July 2003, EPA 815/B-03/002, referenced in Sections 611.381 and 611.645. See also USEPA, NSCEP.

USEPA OGWDW Methods, Method 1622 (05), "Method 1622: Cryptosporidium in Water by Filtration/IMS/FA," December 2005, EPA 815/R-05/001 (~~referred to as "USEPA Method 1622 (05)"~~), referenced in Sections 611.1004 and 611.1007.

USEPA OGWDW Methods, Method 1622 (01), "Method 1622: Cryptosporidium in Water by Filtration/IMS/FA," April 2001, EPA 821/R-01/026, (~~referred to as "USEPA Method 1622 (01)"~~), referenced in Section 611.1007. See also USEPA, NSCEP.

USEPA OGWDW Methods, Method 1622 (99), "Method 1622: Cryptosporidium in Water by Filtration/IMS/FA," April 1999, EPA 821/R-99/001, (~~referred to as "USEPA Method 1622 (99)"~~), referenced in Section 611.1007.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

USEPA OGWDW Methods, Method 1623 (05), "Method 1623: Cryptosporidium and Giardia in Water by Filtration/IMS/FA," December 2005, EPA 815/R-05/002 (referred to as "USEPA Method 1623 (05)"), referenced in Sections 611.1004 and 611.1007.

USEPA OGWDW Methods, Method 1623 (01), "Method 1623: Cryptosporidium and Giardia in Water by Filtration/IMS/FA," April 2001, EPA 821/R-01/025 (referred to as "USEPA Method 1623 (01)"), referenced in Section 611.1007.

USEPA OGWDW Methods, Method 1623 (99), "Method 1623: Cryptosporidium and Giardia in Water by Filtration/IMS/FA," January 1999, EPA 821/R-99/006 (referred to as "USEPA Method 1623 (99)"), referenced in Sections 611.1007.

BOARD NOTE: Many of the above-listed documents available from the USEPA, Office of Ground Water and Drinking Water are also listed as available from NTIS.

~~United States Environmental Protection Agency, EMSL, Cincinnati, OH 45268 (513-569-7586).~~

~~"Interim Radiochemical Methodology for Drinking Water," EPA 600/4-75/008 (revised), March 1976 (referred to as "USEPA Interim Radiochemical Methods"), referenced in Section 611.720. See NTIS.~~

~~"Methods for the Determination of Organic Compounds in Drinking Water," December 1988, revised July 1991, EPA 600/4-88/039 (referred to as "USEPA Organic Methods"), referenced in Sections 611.645 and 611.648. (For methods 504.1, 508.1, and 525.2 only.) See NTIS.~~

~~"Procedures for Radiochemical Analysis of Nuclear Reactor Aqueous Solutions," referenced in Section 611.720. See NTIS.~~

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

USEPA, ORD. USEPA, Office of Research and Development, National Exposure Research Laboratory, Microbiological & Chemical Exposure Assessment Research Division (accessible on-line and available by download from <http://www.epa.gov/nerlcwww/ordmeth.htm>).

USEPA NERL Method 200.5, Revision-rev. 4.2, "Determination of Trace Elements in Drinking Water by Axially Viewed Inductively Coupled Plasma—Atomic Emission Spectrometry," October 2003, EPA 600/R-06/115 (referred to as "USEPA NERL Method 200.5"), referenced in Sections 611.611 and 611.612.

USEPA NERL Method 415.3, Revision-rev. 1.1, "Determination of Total Organic Carbon and Specific UV Absorbance at 254 nm in Source Water and Drinking Water," February 2005, EPA 600/R-05/055 (referred to as "USEPA NERL Method 415.3 (rev. 1.1)"), referenced in Section 611.381.

USEPA NERL Method 415.3, rev. 1.2, "Determination of Total Organic Carbon and Specific UV Absorbance at 254 nm in Source Water and Drinking Water," February 2005, EPA 600/R-09/122, referenced in Section 611.381.

USEPA NERL Method 549.2, rev. 1.0, "Determination of Diquat and Paraquat in Drinking Water by Liquid-Solid Extraction and High Performance Liquid Chromatography with Ultraviolet Detection," June 1997.

USEPA, Science and Technology Branch, Criteria and Standards Division, Office of Drinking Water, Washington, D.C. 20460.

~~"Guidance Manual for Compliance with the Filtration and Disinfection Requirements for Public Water Systems using Surface Water Sources," October 1989, referenced in Sections 611.111 and 611.212.~~

USEPA Water Resource Center (RC-4100T), 1200 Pennsylvania Avenue, NW, Washington, DC 20460:

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

E\*Colite Test, “Charm E\*Colite Presence/Absence Test for Detection and Identification of Coliform Bacteria and *Escherichia coli* in Drinking Water,” January 9, 1998 (~~referred to as “E\*Colite Test”~~), referenced in Section 611.802. (~~See also available from Charm Sciences, Inc.~~)

m-ColiBlue24 Test, “Total Coliforms and *E. coli* Membrane Filtration Method with m-ColiBlue24® Broth,” Method No. 10029, Revision rev. 2, August 17, 1999 (~~referred to as “m-ColiBlue24 Test”~~), referenced in Section 611.802. (~~See also available from The Hach Company~~).

USEPA Method 1600, “EPA Method 1600: Enterococci in Water by Membrane Filtration Using Membrane-Enterococcus Indoxyl-b-D-Glucoside Agar (mEI),” September 2002, EPA 821/R-02/022 (~~referred to as “USEPA Method 1600”~~) is an approved variation of Standard Methods, Method 9230 C, “Fecal Streptococcus and Enterococcus Groups, Membrane Filter Techniques” (which has not itself been approved for use by USEPA) (accessible on-line and available by download from <http://www.epa.gov/nerlcwww/1600sp02.pdf>), referenced in Section 611.802.

USEPA Method 1601, “Method 1601: Male-specific (F<sup>+</sup>) and Somatic Coliphage in Water by Two-step Enrichment Procedure,” April 2001, EPA 821/R-01/030 (~~referred to as “USEPA Method 1601”~~) (accessible on-line and available by download from <http://www.epa.gov/nerlcwww/1601ap01.pdf>), referenced in Section 611.802.

USEPA Method 1602, “Method 1602: Male-specific (F<sup>+</sup>) and Somatic Coliphage in Water by Single Agar Layer (SAL) Procedure,” April 2001, EPA 821/R-01/029 (~~referred to as “USEPA Method 1602”~~) (accessible on-line and available by download from <http://www.epa.gov/nerlcwww/1602ap01.pdf>), referenced in Section 611.802.

USEPA Method 1604, “Method 1604: Total Coliforms and *Escherichia coli* in Water by Membrane Filtration Using a

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Simultaneous Detection Technique (MI Medium),” September 2002, EPA 821/R-02/024 (~~referred to as “USEPA Method 1604”~~) (accessible on-line and available by download from <http://www.epa.gov/nerlcwww/1604sp02.pdf>), referenced in Section 611.802.

USGS. Books and Open-File Reports Section, United States Geological Survey, Federal Center, Box 25286, Denver, CO 80225-0425.

Methods available upon request by method number from “Methods for Analysis by the U.S. Geological Survey National Water Quality Laboratory—Determination of Inorganic and Organic Constituents in Water and Fluvial Sediments,” Open File Report 93-125, 1993, or Book 5, Chapter A-1, “Methods for Determination of Inorganic Substances in Water and Fluvial Sediments,” 3rd ed., Open-File Report 85-495, 1989, as appropriate (referred to as “USGS Methods”).

I-1030-85, referenced in Section 611.611.

I-1601-85, referenced in Section 611.611.

I-1700-85, referenced in Section 611.611.

I-2598-85, referenced in Section 611.611.

I-2601-90, referenced in Section 611.611.

I-2700-85, referenced in Section 611.611.

I-3300-85, referenced in Section 611.611.

Methods available upon request by method number from “Methods for Determination of Radioactive Substances in Water and Fluvial Sediments,” Chapter A5 in Book 5 of “Techniques of Water-Resources Investigations of the United States Geological Survey,” 1997.



ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

R-1110-76, referenced in Section 611.720.

R-1111-76, referenced in Section 611.720.

R-1120-76, referenced in Section 611.720.

R-1140-76, referenced in Section 611.720.

R-1141-76, referenced in Section 611.720.

R-1142-76, referenced in Section 611.720.

R-1160-76, referenced in Section 611.720.

R-1171-76, referenced in Section 611.720.

R-1180-76, referenced in Section 611.720.

R-1181-76, referenced in Section 611.720.

R-1182-76, referenced in Section 611.720.

Waters Corporation, Technical Services Division, 34 Maple St., Milford, MA 01757 (800-252-4752 or 508-482-2131, fax: 508-482-3625).

“Waters Test Method for Determination of Nitrite/Nitrate in Water Using Single Column Ion Chromatography,” Method B-1011, August 1987 (referred to as “Waters Method B-1011”), referenced in Section 611.611.

- c) The Board incorporates the following federal regulations by reference:

40 CFR 3.2-~~(2007)~~ (2010) (How Does This Part Provide for Electronic Reporting?), referenced in Section 611.105.

40 CFR 3.3-~~(2007)~~ (2010) (What Definitions Are Applicable to This Part?), referenced in Section 611.105.

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

40 CFR 3.10-~~(2007)~~ (2010) (What Are the Requirements for Electronic Reporting to EPA?), referenced in Section 611.105.

40 CFR 3.2000-~~(2007)~~ (2010) (What Are the Requirements Authorized State, Tribe, and Local Programs' Reporting Systems Must Meet?), referenced in Section 611.105.

40 CFR 136.3(a)-~~(2007)~~ (2010), referenced in Section 611.1004.

Appendix B to 40 CFR 136-~~(2007)~~ (2010), referenced in Sections 611.359, 611.609, and 611.646.

40 CFR 142.20(b)(1) (2010), referenced in Section 611.112.

d) This Part incorporates no later amendments or editions.

(Source: Amended at 34 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

**Section 611.105 Electronic Reporting**

The submission of any document pursuant to any provision of this Part as an electronic document in lieu of a paper document is subject to this Section.

a) Scope and Applicability.

1) The USEPA, the Board, or the Agency may allow for the submission of electronic documents in lieu of paper documents. This Section does not require submission of electronic documents in lieu of paper documents. This Section sets forth the requirements for the optional electronic submission of any document that must be submitted to the appropriate of the following:

A) To USEPA directly under Title 40 of the Code of Federal Regulations; or

B) To the Board or the Agency pursuant to any provision of 35 Ill. Adm. Code 702 through 705, 720 through 728, 730, 733, 738, or 739.

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- 2) Electronic document submission under this Section can occur only as follows:
  - A) For submissions of documents to USEPA, submissions may occur only after USEPA has published a notice in the Federal Register announcing that USEPA is prepared to receive, in an electronic format, documents required or permitted by the identified part or subpart of Title 40 of the Code of Federal Regulations; or
  - B) For submissions of documents to the State, submissions may occur only under the following circumstances:
    - i) As to any existing electronic document receiving system (i.e., one in use or substantially developed on or before October 13, 2005) for which an electronic reporting application has not been submitted on behalf of the Board or the Agency to USEPA pursuant to 40 CFR 3.1000, the Board or the Agency may use that system until October 13, 2007, or until such later date as USEPA has approved in writing as the extended deadline for submitting the application;
    - ii) As to any existing electronic document receiving system (i.e., one in use or substantially developed on or before October 13, 2005) for which an electronic reporting application has been submitted on behalf of the Board or the Agency to USEPA pursuant to 40 CFR 3.1000 on or before October 13, 2007, or on or before such later date as USEPA has approved in writing as the extended deadline for submitting the application, the Board or the Agency may use that system until USEPA disapproves its use in writing; or
    - iii) The Board or the Agency may use any electronic document receiving system for which USEPA has granted approval pursuant to 40 C-F-R- 3.1000, so long as the system complies with 40 C-F-R- 3.2000, incorporated by reference

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

in Section 611.102(c), and USEPA has not withdrawn its approval of the system in writing.

- 3) This Section does not apply to any of the following documents, whether or not the document is a document submitted to satisfy the requirements cited in subsection (a)(1) of this Section:
  - A) Any document submitted via facsimile;
  - B) Any document submitted via magnetic or optical media, such as diskette, compact disc, digital video disc, or tape; or
  - C) Any data transfer between USEPA, any state, or any local government and either the Board or the Agency as part of administrative arrangements between the parties to the transfer to share data.
  
- 4) Upon USEPA conferring written approval for the submission of any types of documents as electronic documents in lieu of paper documents, as described in subsection (a)(2)(B)(iii) of this Section, the Agency or the Board, as appropriate, must publish a Notice of Public Information in the Illinois Register that describes the documents approved for submission as electronic documents, the electronic document receiving system approved to receive them, the acceptable formats and procedures for their submission, and, as applicable, the date on which the Board or the Agency will begin to receive those submissions. In the event of written cessation of USEPA approval for receiving any type of document as an electronic document in lieu of a paper document, the Board or the Agency must similarly cause publication of a Notice of Public Information in the Illinois Register.

BOARD NOTE: Subsection (a) of this Section is derived from 40 CFR 3.1, 3.2, 3.10, 3.20, and 3.1000, ~~as added at 70 Fed. Reg. 59848 (Oct. 13, 2005) (2010).~~

- b) Definitions. For the purposes of this Section, terms will have the meaning attributed them in 40 CFR 3.3, incorporated by reference in 35 Ill. Adm. Code 611.102(c).

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- c) Procedures for submission of electronic documents in lieu of paper documents to USEPA. Except as provided in subsection (a)(3) of this Section, any person who is required under Title 40 of the Code of Federal Regulations to create and submit or otherwise provide a document to USEPA may satisfy this requirement with an electronic document, in lieu of a paper document, provided the following conditions are met:
- 1) The person satisfies the requirements of 40 CFR 3.10, incorporated by reference in Section 611.102(c); and
  - 2) USEPA has first published a notice in the Federal Register as described in subsection (a)(2)(A) of this Section.

BOARD NOTE: Subsection (c) of this Section is derived from 40 CFR 3.2(a) and subpart B of 40 CFR 3, ~~as added at 70 Fed. Reg. 59848 (Oct. 13, 2005)~~ (2010).

- d) Procedures for submission of electronic documents in lieu of paper documents to the Board or the Agency.
- 1) The Board or the Agency may, but is not required to, establish procedural rules for the electronic submission of documents. The Board or the Agency must establish any such procedural rules under the Administrative Procedure Act [5 ILCS 100/Art. 5].
  - 2) The Board or the Agency may accept electronic documents under this Section only as provided in subsection (a)(2)(B) of this Section.

BOARD NOTE: Subsection (d) of this Section is derived from 40 CFR 3.2(b) and subpart D of 40 CFR 3, ~~as added at 70 Fed. Reg. 59848 (Oct. 13, 2005)~~ (2010).

- e) Effects of submission of an electronic document in lieu of paper documents.
- 1) If a person who submits a document as an electronic document fails to comply with the requirements of this Section, that person is subject to the penalties prescribed for failure to comply with the requirement that the electronic document was intended to satisfy.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- 2) Where a document submitted as an electronic document to satisfy a reporting requirement bears an electronic signature, the electronic signature legally binds, obligates, and makes the signer responsible to the same extent as the signer's handwritten signature would on a paper document submitted to satisfy the same reporting requirement.
- 3) Proof that a particular signature device was used to create an electronic signature will suffice to establish that the individual uniquely entitled to use the device did so with the intent to sign the electronic document and give it effect.
- 4) Nothing in this Section limits the use of electronic documents or information derived from electronic documents as evidence in enforcement or other proceedings.

BOARD NOTE: Subsection (e) of this Section is derived from 40 CFR 3.4 and 3.2000(c), as added at 70 Fed. Reg. 59848 (Oct. 13, 2005) (2010).

- f) Public document subject to State laws. Any electronic document filed with the Board is a public document. The document, its submission, its retention by the Board, and its availability for public inspection and copying are subject to various State laws, including, but not limited to, the following:
  - 1) The Administrative Procedure Act [5 ILCS 100];
  - 2) The Freedom of Information Act [5 ILCS 140];
  - 3) The State Records Act [5 ILCS 160];
  - 4) The Electronic Commerce Security Act [5 ILCS 175];
  - 5) The Environmental Protection Act [415 ILCS 5];
  - 6) Regulations relating to public access to Board records (2 Ill. Adm. Code 2175); and
  - 7) Board procedural rules relating to protection of trade secrets and confidential information (35 Ill. Adm. Code 130).

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- g) Nothing in this Section or in any provisions adopted pursuant to subsection (d)(1) of this Section will create any right or privilege to submit any document as an electronic document.

BOARD NOTE: Subsection (g) of this Section is derived from 40 CFR 3.2(c), as added at 70 Fed. Reg. 59848 (Oct. 13, 2005) (2010).

BOARD NOTE: Derived from 40 CFR 3, as added, and 40 CFR 142.10(g) ~~(2005)~~, as amended at 70 Fed. Reg. 59848 (Oct. 13, 2005) (2010).

(Source: Amended at 34 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

**Section 611.111 Relief Equivalent to SDWA Section 1415(a) Variances**

This Section is intended to describe how the Board grants State relief equivalent to that available from USEPA under section 1415(a)(1)(A) and (a)(1)(B) of the SDWA (42 USC 300g-4(a)(1)(A) and (a)(1)(B)). SDWA section 1415 variances do not require ultimate compliance within five years in every situation. Variances under Sections ~~35-37~~ through 37 of the Act [415 ILCS 5/35-37] do require compliance within five years in every case. Consequently, a PWS may have the option of seeking State regulatory relief equivalent to a SDWA section 1415 variance through one of three procedural mechanisms: a variance under Sections ~~35-37~~ through 37 of the Act [415 ILCS 5/35-37] and Subpart B of 35 Ill. Adm. Code 104; a site-specific rule under Sections ~~27-28~~ and 28 of the Act [415 ILCS 5/27-28] and 35 Ill. Adm. Code 102; or an adjusted standard under Section 28.1 of the Act [415 ILCS 5/28.1] and Subpart D of 35 Ill. Adm. Code 104.

- a) The Board will grant a PWS a variance, a site-specific rule, or an adjusted standard from an MCL or a treatment technique pursuant to this Section.
- 1) The PWS must file a petition pursuant to 35 Ill. Adm. Code 102 or 104, as applicable.
  - 2) If a State requirement does not have a federal counterpart, the Board may grant relief from the State requirements without following this Section.
- b) Relief from an MCL.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- 1) As part of the justification for relief from an MCL under this Section, the PWS must demonstrate the following:
  - A) Because of characteristics of the raw water sources and alternative sources that are reasonably available to the system, the PWS cannot meet the MCL; and
  - B) The PWS will install or has installed the best available technology (BAT) (as identified in Subpart F of this Part), treatment technique, or other means that the Agency finds available. BAT may vary depending on the following:
    - i) The number of persons served by the system;
    - ii) Physical conditions related to engineering feasibility; and
    - iii) Costs of compliance; and
  - C) The variance will not result in an unreasonable risk to health.
- 2) In any order granting relief under this subsection, the Board will prescribe a schedule for the following:
  - A) Compliance, including increments of progress, by the PWS, with each MCL with respect to which the relief was granted; and
  - B) Implementation by the PWS of each additional control measure for each MCL with respect to which the relief is granted, during the period ending on the date compliance with such requirement is required.
- 3) Schedule of compliance for relief from an MCL.
  - A) A schedule of compliance will require compliance with each MCL with respect to which the relief was granted as expeditiously as practicable.



ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- B) If the Board prescribes a schedule requiring compliance with an MCL for which the relief is granted later than five years from the date of issuance of the relief, the Board will do the following:
  - i) Document its rationale for the extended compliance schedule;
  - ii) Discuss the rationale for the extended compliance schedule in the required public notice and opportunity for public hearing; and
  - iii) Provide the shortest practicable time schedule feasible under the circumstances.
- c) Relief from a treatment technique requirement.
  - 1) As part of the justification for relief from a treatment technique requirement under this Section, the PWS must demonstrate that the treatment technique is not necessary to protect the health of persons served because of the nature of the raw water source.
  - 2) The Board may prescribe monitoring and other requirements as a condition for relief from a treatment technique requirement.
- d) The Board will hold at least one public hearing. In addition the Board will accept comments as appropriate pursuant to 35 Ill. Adm. Code 102 or 104.
- e) The Board will not grant relief from any of the following:
  - 1) From the MCL for total coliforms. However, the Board may grant a variance from the total coliform MCL of Section 611.325 for PWSs that prove that the violation of the total coliform MCL is due to persistent growth of total coliform in the distribution system, rather than from fecal or pathogenic contamination, from a treatment lapse or deficiency, or from a problem in the operation or maintenance of the distribution system.
  - 2) From any of the treatment technique requirements of Subpart B of this Part.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- 3) From the residual disinfectant concentration (RDC) requirements of Sections 611.241(c) and 611.242(b).
- f) The Agency must promptly send USEPA the opinion and order of the Board granting relief pursuant to this Section. The Board may reconsider and modify a grant of relief, or relief conditions, if USEPA notifies the Board of a finding pursuant to section 1415 of the SDWA (42 USC 300g-4).
- g) In addition to the requirements of this Section, the provisions of Section 611.130 or 611.131 may apply to relief granted pursuant to this Section.

BOARD NOTE: Derived from 40 CFR 141.4 ~~(2005)~~ (2010), from section 1415(a)(1)(A) and (a)(1)(B) of the SDWA ~~(42 USC 300g-4(a)(1)(A) and (a)(1)(B))~~ and from the “Guidance Manual for Compliance with the Filtration and Disinfection Requirements for Public Water Systems using Surface Water Sources,” incorporated by reference in Section 611.102 and available from USEPA, NSCEP. USEPA has ~~reserved the discretion~~ established a procedure at 40 CFR 142.23 (2010) to review and potentially modify or nullify ~~Board state determinations made pursuant to this Section at 40 CFR 142.23 (2005) granting relief from NPDWRs where USEPA finds that the state has abused its discretion or failed to prescribe required schedules for compliance in a substantial number of instances.~~

(Source: Amended at 34 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

**Section 611.112 Relief Equivalent to SDWA Section 1416 Exemptions**

This Section is intended to describe how the Board grants State relief equivalent to that available from USEPA under section 1416 of the SDWA (42 USC 300g-5). SDWA section 1416 exemptions do not require ultimate compliance within five years in every situation. Variances under Sections ~~35-37~~ through 37 of the Act [415 ILCS 5/35-37] do require compliance within five years in every case. Consequently, a PWS may have the option of seeking State regulatory relief equivalent to a SDWA section 1416 exemption through one of three procedural mechanisms: a variance under Sections ~~35-37~~ through 37 of the Act [415 ILCS 5/35-37] and Subpart B of 35 Ill. Adm. Code 104; a site-specific rule under Sections ~~27-28~~ and 28 of the Act [415 ILCS 5/27-28] and 35 Ill. Adm. Code 102; or an adjusted standard under Section 28.1 of the Act [415 ILCS 5/28.1] and Subpart D of 35 Ill. Adm. Code 104.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- a) The Board will grant a PWS a variance, a site-specific rule, or an adjusted standard from an MCL or treatment technique requirement, or from both, pursuant to this Section.
  - 1) The PWS must file a petition pursuant to 35 Ill. Adm. Code 102 or 104, as applicable.
  - 2) If a State requirement does not have a federal counterpart, the Board may grant relief from the State requirements without following this Section.
  
- b) As part of the justification for relief under this Section, the PWS must demonstrate the following:
  - 1) Due to compelling factors (which may include economic factors), the PWS is unable to comply with the MCL or treatment technique requirement, or to implement measures to develop an alternative source of water supply;
  - 2) The PWS was either of the following:
    - A) In operation on the effective date of the MCL or treatment technique requirement; or
    - B) Not in operation on the effective date of the MCL or treatment technique requirement and no reasonable alternative source of drinking water is available to the PWS;
  - 3) The relief will not result in an unreasonable risk to health; and
  - 4) Management or restructuring changes cannot reasonably be made that will result in compliance with the NPDWR or, if compliance cannot be achieved, improve the quality of the drinking water.

BOARD NOTE: In determining that management or restructuring changes cannot reasonably be made that will result in compliance with the NPDWR, the Board will consider the factors required by USEPA under 40 CFR 142.20(b)(1), incorporated by reference in Section 611.102(c).

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- c) In any order granting relief under this Section, the Board will prescribe a schedule for the following:
- 1) Compliance, including increments of progress, by the PWS, with each MCL and treatment technique requirement with respect to which the relief was granted; and
  - 2) Implementation by the PWS, of each additional control measure for each contaminant subject to the MCL or treatment technique requirement, with respect to which relief is granted.
- d) Schedule of compliance. A schedule of compliance will require compliance with each MCL or treatment technique requirement with respect to which relief was granted as expeditiously as practicable, but not later than three years after the otherwise applicable compliance date established in section 1412(b)(10) of the SDWA (42 USC 300g-1(b)(10)), except as follows:
- 1) No relief may be granted unless the PWS establishes that it is taking all practicable steps to meet the NPDWR; and
    - A) The PWS cannot meet the NPDWR without capital improvements that cannot be completed within 12 months;
    - B) In the case of a PWS that needs financial assistance for the necessary improvements, the PWS has entered into an agreement to obtain such financial assistance; or
    - C) The PWS has entered into an enforceable agreement to become a part of a regional PWS.
  - 2) In the case of a PWS that serves 3,300 or fewer persons that needs financial assistance for the necessary improvements, relief may be renewed for one or more additional two year periods, not to exceed a total of six years, if the PWS establishes that it is taking all practicable steps to meet the final date for compliance.
  - 3) A PWS may not receive relief under this Section if the PWS was granted relief under Section 611.111 or 611.131.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- e) The Board will hold at least one public hearing. In addition the Board will accept comments as appropriate pursuant to 35 Ill. Adm. Code 102 or 104.
- f) The Agency must promptly send USEPA the Opinion and Order of the Board granting relief pursuant to this Section. The Board may reconsider and modify a grant of relief, or relief conditions, if USEPA notifies the Board of a finding pursuant to section 1416 of the SDWA (42 USC 300g-5).

BOARD NOTE: Derived from section 1416 of the SDWA (42 USC 300g-5).

- g) The Board will not grant relief from any of the following:
  - 1) From the MCL for total coliforms. However, the Board may grant relief from the total coliform MCL of Section 611.325 for PWSs that prove that the violation of the total coliform MCL is due to persistent growth of total coliforms in the distribution system, rather than from fecal or pathogenic contamination, from a treatment lapse or deficiency, or from a problem in the operation or maintenance of the distribution system.
  - 2) From any of the treatment technique requirements of Subpart B of this Part.
  - 3) From the residual disinfectant concentration (RDC) requirements of Sections 611.241(c) and 611.242(b).
- h) In addition to the requirements of this Section, the provisions of Section 611.130 or 611.131 may apply to relief granted pursuant to this Section.

BOARD NOTE: Derived from 40 CFR 141.4 ~~(2002)~~ (2010). USEPA has ~~reserved the discretion~~ established a procedure at 40 CFR 142.23 (2010) to review and potentially modify or nullify ~~Board-state~~ determinations made pursuant to this Section at 40 CFR 142.23 (2005) granting relief from NPDWRs where USEPA finds that the state has abused its discretion or failed to prescribe required schedules for compliance in a substantial number of instances.

(Source: Amended at 34 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

SUBPART I: DISINFECTANT RESIDUALS, DISINFECTION BYPRODUCTS, AND  
DISINFECTION BYPRODUCT PRECURSORS

**Section 611.381 Analytical Requirements**

- a) A supplier must use only the analytical methods specified in this Section or alternative methods approved by the Agency pursuant to Section 611.480 to demonstrate compliance with the requirements of this Subpart I and with the requirements of Subparts W and Y of this Part.
- b) Disinfection byproducts (DBPs).
  - 1) A supplier must measure disinfection byproducts (DBPs) by the appropriate of the following methods:
    - A) TTHM:
      - i) By purge and trap, gas chromatography, electrolytic conductivity detector, and photoionization detector: USEPA Organic Methods, Method 502.2 (rev. 2.1). If TTHMs are the only analytes being measured in the sample, then a photoionization detector is not required.
      - ii) By purge and trap, gas chromatography, mass spectrometer: USEPA Organic Methods, Method 524.2 (rev. 4.1).
      - iii) By liquid-liquid extraction, gas chromatography, electron capture detector: USEPA Organic Methods, Method 551.1 (rev. 1.0).
      - iv) By purge and trap, gas chromatography, mass spectrometry: USEPA OGWDW Methods, Method 524.3 (rev. 1.0).

BOARD NOTE: USEPA added USEPA OGWDW Methods, Method 524.3 (rev. 1.0) as an approved alternative method for TTHM in appendix A to subpart C of 40 CFR 141 on August 3, 2009 (at 74 Fed. Reg. 38348).

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

B) HAA5:

- i) By liquid-liquid extraction (diazomethane), gas chromatography, electron capture detector: Standard Methods, 19th or 21st ed., Method 6251 B.

~~BOARD NOTE: On January 4, 2006 (at 71 Fed. Reg. 388), USEPA amended the entry for HAA5 by liquid-liquid extraction (diazomethane), gas chromatography, electron capture detector, in the table at corresponding 40 CFR 141.131(b)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 6251 B (as approved in 1994). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 6251 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 6251 B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- ii) By solid phase extractor (acidic methanol), gas chromatography, electron capture detector: USEPA Organic Methods, Method 552.1 (rev. 1.0).
- iii) By liquid-liquid extraction (acidic methanol), gas chromatography, electron capture detector: USEPA Organic Methods, Method 552.2 (rev. 1.0) or USEPA OGWDW Methods, Method 552.3 (rev. 1.0).
- iv) By ion chromatography, electrospray ionization, tandem mass spectrometry: USEPA OGWDW Methods, Method 557.

BOARD NOTE: USEPA added Standard Methods, 21st ed., Method 6251 B as an approved alternative method for HAA5 in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Fed. Reg. 31616). USEPA added USEPA OGWDW Methods, Method 557 as approved alternative methods for HAA5 in appendix A to subpart C of 40 CFR 141 on November 10, 2009 (at 74 Fed. Reg. 57908).

- C) Bromate:
- i) By ion chromatography: USEPA Organic and Inorganic Methods, Method 300.1 (rev. 1.0).
  - ii) By ion chromatography and post-column reaction: USEPA OGWDW Methods, Method 317.0; (rev 2.0), or 326.0; (rev. 1.0).
  - iii) By inductively coupled plasma-mass spectrometer: USEPA Organic and Inorganic Methods, Method 321.8 (rev. 1.0).
  - iv) By two-dimensional ion chromatography: USEPA OGWDW Methods, Method 302.0.
  - v) By ion chromatography, electrospray ionization, tandem mass spectrometry: USEPA OGWDW Methods, Method 557.
  - vi) By chemically suppressed chromatography: ASTM Method D6581-08 A.
  - vii) By electrolytically suppressed chromatography: ASTM Method D6581-08 B.

BOARD NOTE: Ion chromatography and post column reaction or inductively coupled plasma-mass spectrometry must be used for monitoring of bromate for purposes of demonstrating eligibility of reduced monitoring, as prescribed in Section 611.382(b)(3)(B). For inductively coupled plasma-mass spectrometry, samples must be preserved at the time of sampling with 50 mg ethylenediamine



ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

(EDA) per liter of sample, and the samples must be analyzed within 28 days.

BOARD NOTE: USEPA added USEPA OGWDW Methods, Methods 302.0 and 557 and ASTM Methods D6581-08 A and B as approved alternative methods for bromate in appendix A to subpart C of 40 CFR 141 on November 10, 2009 (at 74 Fed. Reg. 57908).

D) Chlorite:

- i) By amperometric titration: Standard Methods, 19th or 21st ed., Method 4500-ClO<sub>2</sub> E.

~~BOARD NOTE: On January 4, 2006 (at 71 Fed. Reg. 388), USEPA amended the entry for chlorite by amperometric titration, in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 4500-ClO<sub>2</sub>-E (as approved in 2000). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 4500-ClO<sub>2</sub> that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 4500-ClO<sub>2</sub>-E from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- ii) By spectrophotometry: USEPA OGWDW Methods, Method 327.0, (rev. 1.1).
- iii) By ion chromatography: USEPA Environmental Inorganic Methods, Method 300.0 (rev. 2.1); USEPA Organic and Inorganic Methods, Method 300.1 (rev. 1.0); USEPA OGWDW Methods, Method 317.0, (rev. 2.0), or 326.0, (rev. 1.0); or ASTM Method D6581-00.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

iv) By chemically suppressed chromatography: ASTM Method D6581-08 A.

v) By electrolytically suppressed chromatography: ASTM Method D6581-08 B.

BOARD NOTE: USEPA added Standard Methods, 21st ed., Method 4500-ClO<sub>2</sub> E as an approved alternative method for daily chlorite in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Methods D6581-08 A and B as approved alternative methods for chlorite in appendix A to subpart C of 40 CFR 141 on November 10, 2009 (at 74 Fed. Reg. 57908).

BOARD NOTE: Amperometric titration or spectrophotometry may be used for routine daily monitoring of chlorite at the entrance to the distribution system, as prescribed in Section 611.382(b)(2)(A)(i). Ion chromatography must be used for routine monthly monitoring of chlorite and additional monitoring of chlorite in the distribution system, as prescribed in Section 611.382(b)(2)(A)(ii) and (b)(2)(B).

- 2) Analyses under this Section for DBPs must be conducted by laboratories that have received certification by USEPA or the Agency except as specified under subsection (b)(3) of this Section. To receive certification to conduct analyses for the DBP contaminants listed in Sections 611.312 and 611.381 and Subparts W and Y of this Part, the laboratory must fulfill the requirements of subsections (b)(2)(A), (b)(2)(C), and (b)(2)(D) of this Section.
- A) The laboratory must analyze performance evaluation (PE) samples that are acceptable to USEPA or the Agency at least once during each consecutive 12-month period by each method for which the laboratory desires certification.
- B) This subsection corresponds with 40 CFR 141.131(b)(2)(ii), which has expired by its own terms. This statement maintains structural consistency with the corresponding federal rule.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- C) The laboratory must achieve quantitative results on the PE sample analyses that are within the acceptance limits set forth in subsections (b)(2)(C)(i) through (b)(2)(B)(xi) of this Section, subject to the conditions of subsections (b)(2)(C)(xii) and (b)(2)(C)(xiii) of this Section:
- i) Chloroform (a THM):  $\pm 20\%$  of true value;
  - ii) Bromodichloromethane (a THM):  $\pm 20\%$  of true value;
  - iii) Dibromochloromethane (a THM):  $\pm 20\%$  of true value;
  - iv) Bromoform (a THM):  $\pm 20\%$  of true value;
  - v) Monochloroacetic Acid (an HAA5):  $\pm 40\%$  of true value;
  - vi) Dichloroacetic Acid (an HAA5):  $\pm 40\%$  of true value;
  - vii) Trichloroacetic Acid (an HAA5):  $\pm 40\%$  of true value;
  - viii) Monobromoacetic Acid (an HAA5):  $\pm 40\%$  of true value;
  - ix) Dibromoacetic Acid (an HAA5):  $\pm 40\%$  of true value;
  - x) Chlorite:  $\pm 30\%$  of true value; and
  - xi) Bromate:  $\pm 30\%$  of true value.
  - xii) The laboratory must meet all four of the individual THM acceptance limits set forth in subsections (b)(2)(B)(i) through (b)(2)(B)(iv) of this Section in order to successfully pass a PE sample for TTHM.
  - xiii) The laboratory must meet the acceptance limits for four out of the five HAA5 compounds set forth in subsections (b)(2)(B)(v) through (b)(2)(B)(ix) of this Section in order to successfully pass a PE sample for HAA5.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- D) The laboratory must report quantitative data for concentrations at least as low as the minimum reporting levels (MRLs) listed in subsections (b)(2)(D)(i) through (b)(2)(D)(xi) of this Section, subject to the limitations of subsections (b)(2)(D)(xii) and (b)(2)(D)(xiii) of this Section, for all DBP samples analyzed for compliance with Sections 611.312 and 611.385 and Subparts W and Y of this Part:
- i) Chloroform (a THM): 0.0010 mg/l;
  - ii) Bromodichloromethane (a THM): 0.0010 mg/l;
  - iii) Dibromochloromethane (a THM): 0.0010 mg/l;
  - iv) Bromoform (a THM): 0.0010 mg/l;
  - v) Monochloroacetic Acid (an HAA5): 0.0020 mg/l;
  - vi) Dichloroacetic Acid (an HAA5): 0.0010 mg/l;
  - vii) Trichloroacetic Acid (an HAA5): 0.0010 mg/l;
  - viii) Monobromoacetic Acid (an HAA5): 0.0010 mg/l;
  - ix) Dibromoacetic Acid (an HAA5): 0.0010 mg/l;
  - x) Chlorite: 0.020 mg/l, applicable to monitoring as required by Section 611.382(b)(2)(A)(ii) and (b)(2)(B); and
  - xi) Bromate: 0.0050, or 0.0010 mg/l if the laboratory uses USEPA OGWDW Methods, Method 317.0, ~~rev. 2.0~~, or 326.0 or USEPA Organic and Inorganic Methods, Method 321.8.
  - xii) The calibration curve must encompass the regulatory MRL concentration. Data may be reported for concentrations lower than the regulatory MRL as long as the precision and

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

accuracy criteria are met by analyzing an MRL check standard at the lowest reporting limit chosen by the laboratory. The laboratory must verify the accuracy of the calibration curve at the MRL concentration by analyzing an MRL check standard with a concentration less than or equal to 110% of the MRL with each batch of samples. The measured concentration for the MRL check standard must be  $\pm 50\%$  of the expected value, if any field sample in the batch has a concentration less than five times the regulatory MRL. Method requirements to analyze higher concentration check standards and meet tighter acceptance criteria for them must be met in addition to the MRL check standard requirement.

- xiii) When adding the individual trihalomethane or haloacetic acid concentrations, for the compounds listed in subsections (b)(2)(D)(v) through (b)(2)(D)(ix) of this Section, to calculate the TTHM or HAA5 concentrations, respectively, a zero is used for any analytical result that is less than the MRL concentration for that DBP, unless otherwise specified by the Agency.
- 3) A party approved by USEPA or the Agency must measure daily chlorite samples at the entrance to the distribution system.
- c) Disinfectant residuals.
  - 1) A supplier must measure residual disinfectant concentrations for free chlorine, combined chlorine (chloramines), and chlorine dioxide by the appropriate of the methods listed in subsections (c)(1)(A) through (c)(1)(D) of this Section, subject to the provisions of subsection (c)(1)(E) of this Section:
    - A) Free Chlorine:
      - i) Amperometric titration: ~~using~~ Standard Methods, 19th, 20th, or 21st ed., Method 4500-Cl D, or ASTM Method

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~1253-86 D1253-86, 1253-96 D1253-96, or 1253-03 D1253-03, or D1253-08;~~

- ii) DPD ferrous titration: ~~using~~ Standard Methods, 19th, 20th, or 21st ed., Method 4500-CI F;
- iii) DPD colorimetric: ~~using~~ Standard Methods, 19th, 20th, or 21st ed., Method 4500-CI G; or
- iv) Syringaldazine (FACTS): ~~using~~ Standard Methods, 19th, 20th, or 21st ed., Method 4500-CI H.
- v) Test strips: ITS Method D99-003 if approved by the Agency pursuant to subsection (c)(2) of this Section.
- v) Amperometric sensor: Palintest ChloroSense.
- vi) On-line chlorine analyzer: USEPA OGWDW Methods, Method 334.0.

BOARD NOTE: USEPA added Standard Methods, 21st ed., Methods 4500-CI D, F, G, and H as approved alternative methods for free chlorine in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Method D1253-08, USEPA OGWDW Methods, Method 334.0, and Palintest ChloroSense as approved alternative methods for free chlorine in appendix A to subpart C of 40 CFR 141 on November 10, 2009 (at 74 Fed. Reg. 57908).

B) Combined Chlorine:

- i) Amperometric titration: ~~using~~ Standard Methods, 19th, 20th, or 21st ed., Method 4500-CI D, or ASTM Method ~~1253-86 D1253-86, 1253-96 D1253-96, or 1253-03 D1253-03, or D1253-08;~~
- ii) DPD ferrous titration: ~~using~~ Standard Methods, 19th, 20th, or 21st ed., Method 4500-CI F; or

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- iii) DPD colorimetric: ~~using~~ Standard Methods, 19th, 20th, or 21st ed., Method 4500-CI G.

BOARD NOTE: USEPA added Standard Methods, Methods 4500-CI D, F, and G as approved alternative methods for free chlorine in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Method D1253-08 as an approved alternative method for combined chlorine in appendix A to subpart C of 40 CFR 141 on November 10, 2009 (at 74 Fed. Reg. 57908).

C) Total Chlorine:

- i) Amperometric titration: ~~using~~ Standard Methods, 19th, 20th, or 21st ed., Method 4500-CI D, or ASTM Method ~~4253-86~~ D1253-86, ~~4253-96~~ D1253-96 ~~or 4253-03~~ D1253-03, or D1253-08;
- ii) Low-level amperometric titration: ~~using~~ Standard Methods, 19th, 20th, or 21st ed., Method 4500-CI E;
- iii) DPD ferrous titration: ~~using~~ Standard Methods, 19th, 20th, or 21st ed., Method 4500-CI F;
- iv) DPD colorimetric: ~~using~~ Standard Methods, 19th, 20th, or 21st ed., Method 4500-CI G; or
- v) Iodometric electrode: ~~using~~ Standard Methods, 19th, 20th, or 21st ed., Method 4500-CI I.
- vi) Amperometric sensor: Palintest ChloroSense.
- vii) On-line chlorine analyzer: USEPA OGWDW Methods, Method 334.0.

BOARD NOTE: USEPA added Standard Methods, Methods 4500-CI D, E, F, G, and I as approved alternative methods for free

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

chlorine in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Method D1253-08, USEPA OGWDW Methods, Method 334.0, and Palintest ChloroSense as approved alternative methods for total chlorine in appendix A to subpart C of 40 CFR 141 on November 10, 2009 (at 74 Fed. Reg. 57908).

- D) Chlorine Dioxide:
- i) DPD: ~~using~~ Standard Methods, 19th, 20th, or 21st ed., Method 4500-ClO<sub>2</sub> D;
  - ii) Amperometric Method II: ~~using~~ Standard Methods, 19th, 20th, or 21st ed., Method 4500-ClO<sub>2</sub> E; or
  - iii) Lissamine Green spectrophotometric: ~~using~~ USEPA OGWDW Method 327.0 (rev. 1.1).

BOARD NOTE: USEPA added Standard Methods, 21st ed., Methods 4500-ClO<sub>2</sub> D and E as approved alternative methods for chlorine dioxide in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

- E) The methods listed are approved for measuring the specified disinfectant residual. The supplier may measure free chlorine or total chlorine for demonstrating compliance with the chlorine MRDL and combined chlorine, or total chlorine may be measured for demonstrating compliance with the chloramine MRDL.

~~BOARD NOTE: On January 4, 2006 (at 71 Fed. Reg. 388), USEPA amended the entries for free chlorine, combined chlorine, and chlorine dioxide in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 4500-Cl D, E, F, G, H, or I or Method 4500-ClO<sub>2</sub> E (as approved in 2000). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the versions of Method 4500-Cl and Method 4500-ClO<sub>2</sub> that appear in that printed volume is that cited by USEPA as acceptable for~~



ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~use. USEPA later added Method 4500-Cl D, E, F, G, H, or I or Method 4500-ClO<sub>2</sub>-E from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- 2) Test strips Alternative methods available only upon specific approval by the Agency.

A) Test strips: ITS Method D99-003.

BOARD NOTE: USEPA added ITS Method D99-003 as an approved alternative method for free chlorine in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616), contingent upon specific state approval. The Board has opted to provide that the Agency can grant such approvals on a case-by-case basis using the SEP mechanism.

B) If approved by the Agency, by an SEP issued pursuant to Section 611.110, a supplier may also measure residual disinfectant concentrations for chlorine, chloramines, and chlorine dioxide by using DPD colorimetric test kits.

- 3) A party approved by USEPA or the Agency must measure residual disinfectant concentration.

d) A supplier required to analyze parameters not included in subsections (b) and (c) of this Section must use the methods listed below. A party approved by USEPA or the Agency must measure the following parameters:

1) Alkalinity. All methods allowed in Section 611.611(a)(21) for measuring alkalinity.

2) Bromide:

A) USEPA Inorganic Methods, Method 300.0 (rev. 2.1);

B) USEPA Organic and Inorganic Methods, Method 300.1 (rev. 1.0);

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- C) USEPA OGWDW Methods, Method 317.0 (rev. 2.0) or Method 326.0 (rev. 1.0); or
  - D) ASTM Method D6581-00.
- 3) Total Organic Carbon (TOC), by any of the methods listed in subsection (d)(3)(A)(i), (d)(3)(A)(ii), (d)(3)(A)(iii), or (d)(3)(B) of this Section, subject to the limitations of subsection (d)(3)(C) of this Section:
- A) ~~High-temperature combustion~~Standard Methods, 19th, 20th, or 21st ed., using one of the following methods:
    - i) ~~Standard Methods, 19th, 20th, or 21st ed., Method 5310 B (High Temperature Combustion Method); or~~
    - ii) ~~USEPA NERL Method 415.3 (rev. 1.2)Method 5310 C (Persulfate Ultraviolet or Heated Persulfate Oxidation Method); or~~
    - iii) ~~Method 5310 D (Wet Oxidation Method).~~

~~BOARD NOTE: On January 4, 2006 (at 71 Fed. Reg. 388), USEPA amended the entries for total organic carbon, high-temperature combustion, persulfate ultraviolet or heated persulfate, and wet oxidation at corresponding 40 CFR 141.131(d)(3) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 5310 B, C, or D (as approved in 2000). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 5310 B, C, or D that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 5310 B, C, or D from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- B) Persulfate-ultraviolet or heated-persulfate oxidation:

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

i) Standard Methods, 19th, 20th, or 21st ed., Method 5310 C;  
or

ii) USEPA NERL Method 415.3 (rev. 1.2).

C) Wet oxidation method:

i) Standard Methods, 19th, 20th, or 21st ed., Method 5310 D;  
or

ii) USEPA NERL Method 415.3 (rev. 1.2).

BD) Specific UV<sub>254</sub> absorbance: USEPA NERL Method 415.3 (rev. 1.1) or 415.3 (rev. 1.2).

CE) Inorganic carbon must be removed from the samples prior to analysis. TOC samples may not be filtered prior to analysis. TOC samples must be acidified at the time of sample collection to achieve pH less than or equal to 2 with minimal addition of the acid specified in the method or by the instrument manufacturer. Acidified TOC samples must be analyzed within 28 days.

BOARD NOTE: USEPA added Standard Methods, 21st ed., Methods 5310 B, C, and D as approved alternative methods for total organic carbon in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added USEPA NERL Method 415.3 (rev. 1.2) as an approved alternative method for total organic carbon in appendix A to subpart C of 40 CFR 141 on November 10, 2009 (at 74 Fed. Reg. 57908).

- 4) Specific Ultraviolet Absorbance (SUVA). SUVA is equal to the UV absorption at 254 nm (UV<sub>254</sub>) (measured in m<sup>-1</sup>) divided by the dissolved organic carbon (DOC) concentration (measured as mg/ℓ). In order to determine SUVA, it is necessary to separately measure UV<sub>254</sub> and DOC. When determining SUVA, a supplier must use the methods stipulated in subsection (d)(4)(A) of this Section to measure DOC and the method stipulated in subsection (d)(4)(B) of this Section to measure UV<sub>254</sub>. SUVA must be determined on water prior to the addition of disinfectants/oxidants

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

by the supplier. DOC and UV<sub>254</sub> samples used to determine a SUVA value must be taken at the same time and at the same location.

A) ~~Dissolved Organic Carbon (DOC).—Standard Methods, 19th ed., 20th ed., or 21st ed., Method 5310 B (High Temperature Combustion Method), Method 5310 C (Persulfate Ultraviolet or Heated Persulfate Oxidation Method), or Method 5310 D (Wet Oxidation Method) or USEPA NERL Method 415.3 (rev. 1.1).~~ Prior to analysis, DOC samples must be filtered through the 0.45 µm pore-diameter filter as soon as practical after sampling, not to exceed 48 hours. After filtration, DOC samples must be acidified to achieve pH less than or equal to 2 with minimal addition of the acid specified in the method or by the instrument manufacturer. Acidified DOC samples must be analyzed within 28 days after sample collection. Inorganic carbon must be removed from the samples prior to analysis. Water passed through the filter prior to filtration of the sample must serve as the filtered blank. This filtered blank must be analyzed using procedures identical to those used for analysis of the samples and must meet the following standards: DOC less than 0.5 mg/l.; ~~and~~

i) High-Temperature Combustion Method: Standard Methods, 19th ed., 20th ed., or 21st ed., Method 5310 B or USEPA NERL Methods 415.3 (rev. 1.1) or 415.3 (rev. 1.2).

ii) Persulfate-Ultraviolet or Heated-Persulfate Oxidation Method, Method 5310 C or USEPA NERL Methods 415.3 (rev. 1.1) or 415.3 (rev. 1.2).

iii) Wet-Oxidation Method: Standard Methods, 19th ed., 20th ed., or 21st ed., Method 5310 D or USEPA NERL Methods 415.3 (rev. 1.1) or 415.3 (rev. 1.2).

BOARD NOTE: ~~On January 4, 2006 (at 71 Fed. Reg. 388), USEPA amended the entries for specific ultraviolet absorbance-dissolved organic carbon at corresponding 40 CFR 141.131(d)(4)(i) to allow the use of Standard Methods Online (at www.standardmethods.org), Method 5310 B, C, or D (as approved~~

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~in 2000). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 5310 B, C, or D that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 5310 B, C, or D from the 21st edition of Standard Methods~~  
USEPA added Standard Methods, Methods 5310 B, C, and D as an approved alternative method-methods for dissolved organic carbon in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added USEPA NERL Method 415.3 (rev. 1.2) as an approved alternative method for dissolved organic carbon in appendix A to subpart C of 40 CFR 141 on November 10, 2009 (at 74 Fed. Reg. 57908).

- B) ~~Ultraviolet Absorption at 254 nm (UV<sub>254</sub>); by spectrometry; Standard Methods, 19th, 20th, or 21st ed., Method 5910 B (Ultraviolet Absorption Method) or USEPA NERL Method 415.3 (rev. 1.1) or 415.3 (rev. 1.2). UV absorption must be measured at 253.7 nm (may be rounded off to 254 nm). Prior to analysis, UV<sub>254</sub> samples must be filtered through a 0.45 µm pore-diameter filter. The pH of UV<sub>254</sub> samples may not be adjusted. Samples must be analyzed as soon as practical after sampling, not to exceed 48 hours; and~~

~~BOARD NOTE: On January 4, 2006 (at 71 Fed. Reg. 388), USEPA amended the entries for specific ultraviolet absorbance-ultraviolet absorption at 254 nm at corresponding 40 CFR 141.131(d)(4)(ii) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 5910 B (as approved in 2000). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 5910 B that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 5910 B from the 21st edition of Standard Methods~~  
USEPA added Standard Methods, 21st ed., Method 5910 B as an approved alternative method for ultraviolet absorption in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

added USEPA NERL Method 415.3 (rev. 1.2) as an approved alternative method for ultraviolet absorbance in appendix A to subpart C of 40 CFR 141 on November (at 74 Fed. Reg. 57908).

- 5) pH. All methods allowed in Section 611.611(a)(17) for measuring pH.
- 6) Magnesium. All methods allowed in Section 611.611(a) for measuring magnesium.

BOARD NOTE: Derived from 40 CFR 141.131-~~(2007)~~ and appendix A to 40 CFR 141, as added at ~~73 Fed. Reg. 31616 (June 3, 2008)~~ (2010).

(Source: Amended at 34 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

**Section 611.382 Monitoring Requirements**

- a) General requirements.
  - 1) A supplier must take all samples during normal operating conditions.
  - 2) A supplier may consider multiple wells drawing water from a single aquifer as one treatment plant for determining the minimum number of TTHM and HAA5 samples required with Agency approval.
  - 3) Failure to monitor in accordance with the monitoring plan required under subsection (f) of this Section is a monitoring violation.
  - 4) Where compliance is based on a running annual average of monthly or quarterly samples or averages and the supplier's failure to monitor makes it impossible to determine compliance with MCLs or MRDLs, this failure to monitor will be treated as a violation for the entire period covered by the annual average.
  - 5) A supplier must use only data collected under the provisions of this Subpart I to qualify for reduced monitoring.
- b) Monitoring requirements for disinfection byproducts (DBPs).

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- 1) TTHMs and HAA5.
  - A) Routine monitoring. A supplier must monitor at the following frequency:
    - i) A Subpart B system supplier that serves 10,000 or more persons must collect four water samples per quarter per treatment plant. At least 25 percent of all samples collected each quarter must be collected at locations representing maximum residence time. The remaining samples may be taken at locations representative of at least average residence time in the distribution system and representing the entire distribution system, taking into account the number of persons served, the different sources of water, and the different treatment methods.
    - ii) A Subpart B system supplier that serves from 500 to 9,999 persons must collect one water sample per quarter per treatment plant. The samples must be collected from locations representing maximum residence time.
    - iii) A Subpart B system supplier that serves fewer than 500 persons must collect one sample per year per treatment plant during month of warmest water temperature. The samples must be collected from locations representing maximum residence time. If the sample (or average of annual samples, if more than one sample is taken) exceeds the MCL, the supplier must increase the monitoring frequency to one sample per treatment plant per quarter, taken at a point reflecting the maximum residence time in the distribution system, until the supplier meets the standards in subsection (b)(1)(D) of this Section.
    - iv) A supplier that uses only groundwater not under direct influence of surface water, which uses chemical disinfectant, and which serves 10,000 or more persons must collect one water sample per quarter per treatment plant.

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

The samples must be collected from locations representing maximum residence time.

- v) A supplier that uses only groundwater not under direct influence of surface water, which uses chemical disinfectant, and which serves fewer than 10,000 persons must collect one sample per year per treatment plant during month of warmest water temperature. The samples must be collected from locations representing maximum residence time. If the sample (or average of annual samples, if more than one sample is taken) exceeds MCL, the supplier must increase monitoring to one sample per treatment plant per quarter, taken at a point reflecting the maximum residence time in the distribution system, until the supplier meets standards in subsection (b)(1)(D) of this Section.

BOARD NOTE: If a supplier elects to sample more frequently than the minimum required, at least 25 percent of all samples collected each quarter (including those taken in excess of the required frequency) must be taken at locations that represent the maximum residence time of the water in the distribution system. The remaining samples must be taken at locations representative of at least average residence time in the distribution system. For a supplier using groundwater not under the direct influence of surface water, multiple wells drawing water from a single aquifer may be considered one treatment plant for determining the minimum number of samples required, with Agency approval.

- B) A supplier may reduce monitoring, except as otherwise provided, in accordance with the following:
  - i) A Subpart B system supplier that serves 10,000 or more persons and which has a source water annual average TOC level, before any treatment, of less than or equal to 4.0 mg/l may reduce monitoring if it has monitored for at least one year and its TTHM annual average is less than or equal to 0.040 mg/l and HAA5 annual average is less than or equal to 0.030 mg/l. The reduced monitoring allowed is a



POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

minimum of one sample per treatment plant per quarter at a distribution system location reflecting maximum residence time.

- ii) A Subpart B system supplier that serves from 500 to 9,999 persons and which has a source water annual average TOC level, before any treatment, of less than or equal to 4.0 mg/ℓ may reduce monitoring if it has monitored at least one year and its TTHM annual average is less than or equal to 0.040 mg/ℓ and HAA5 annual average is less than or equal to 0.030 mg/ℓ. The reduced monitoring allowed is a minimum of one sample per treatment plant per year at a distribution system location reflecting maximum residence time during month of warmest water temperature.

BOARD NOTE: Any Subpart B system supplier that serves fewer than 500 persons may not reduce its monitoring to less than one sample per treatment plant per year.

- iii) A supplier using only groundwater not under direct influence of surface water using chemical disinfectant and that serves 10,000 or more persons may reduce monitoring if it has monitored at least one year and its TTHM annual average is less than or equal to 0.040 mg/ℓ and HAA5 annual average is less than or equal to 0.030 mg/ℓ. The reduced monitoring allowed is a minimum of one sample per treatment plant per year at a distribution system location reflecting maximum residence time during month of warmest water temperature.
- iv) A supplier using only groundwater not under direct influence of surface water that uses chemical disinfectant and which serves fewer than 10,000 persons may reduce monitoring if it has monitored at least one year and its TTHM annual average is less than or equal to 0.040 mg/ℓ and HAA5 annual average is less than or equal to 0.030 mg/ℓ for two consecutive years or TTHM annual average is

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

less than or equal to 0.020 mg/l and HAA5 annual average is less than or equal to 0.015 mg/l for one year. The reduced monitoring allowed is a minimum of one sample per treatment plant per three year monitoring cycle at a distribution system location reflecting maximum residence time during month of warmest water temperature, with the three-year cycle beginning on January 1 following the quarter in which the supplier qualifies for reduced monitoring.

- C) Monitoring requirements for source water TOC. In order to qualify for reduced monitoring for TTHM and HAA5 under subsection (b)(1)(B) of this Section, a Subpart B system supplier not monitoring under the provisions of subsection (d) of this Section must take monthly TOC samples every 30 days at a location prior to any treatment, beginning no later than April 1, 2008. In addition to meeting other criteria for reduced monitoring in subsection (b)(1)(B) of this Section, the source water TOC running annual average must be  $\leq 4.0$  mg/l (based on the most recent four quarters of monitoring) on a continuing basis at each treatment plant to reduce or remain on reduced monitoring for TTHM and HAA5. Once qualified for reduced monitoring for TTHM and HAA5 under subsection (b)(1)(B) of this Section, a system may reduce source water TOC monitoring to quarterly TOC samples taken every 90 days at a location prior to any treatment.
- D) A Subpart B system supplier on a reduced monitoring schedule may remain on that reduced schedule as long as the average of all samples taken in the year (for a supplier that must monitor quarterly) or the result of the sample (for a supplier that must monitor no more frequently than annually) is no more than 0.060 mg/l and 0.045 mg/l for TTHMs and HAA5, respectively. A supplier that does not meet these levels must resume monitoring at the frequency identified in subsection (b)(1)(A) of this Section in the quarter immediately following the monitoring period in which the supplier exceeds 0.060 mg/l for TTHMs or 0.045 mg/l for HAA5. For a supplier that uses only groundwater not under the direct influence of surface water and which serves fewer than 10,000 persons, if either the TTHM

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

annual average is greater than 0.080 mg/ℓ or the HAA5 annual average is greater than 0.060 mg/ℓ, the supplier must go to increased monitoring identified in subsection (b)(1)(A) of this Section in the quarter immediately following the monitoring period in which the supplier exceeds 0.080 mg/ℓ for TTHMs or 0.060 mg/ℓ for HAA5.

E) The Agency may return a supplier to routine monitoring.

2) Chlorite. A CWS or NTNCWS supplier using chlorine dioxide, for disinfection or oxidation, must conduct monitoring for chlorite.

A) Routine monitoring.

i) Daily monitoring. A supplier must take daily samples at the entrance to the distribution system. For any daily sample that exceeds the chlorite MCL, the supplier must take additional samples in the distribution system the following day at the locations required by subsection (b)(2)(B) of this Section, in addition to the sample required at the entrance to the distribution system.

ii) Monthly monitoring. A supplier must take a three-sample set each month in the distribution system. The supplier must take one sample at each of the following locations: near the first customer, at a location representative of average residence time, and at a location reflecting maximum residence time in the distribution system. Any additional routine sampling must be conducted in the same manner (as three-sample sets, at the specified locations). The supplier may use the results of additional monitoring conducted under subsection (b)(2)(B) of this Section to meet the requirement for monitoring in this subsection (b)(2)(A)(ii).

B) Additional monitoring. On each day following a routine sample monitoring result that exceeds the chlorite MCL at the entrance to the distribution system, the supplier must take three chlorite distribution system samples at the following locations: as close to

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

the first customer as possible, in a location representative of average residence time, and as close to the end of the distribution system as possible (reflecting maximum residence time in the distribution system).

- C) Reduced monitoring.
  - i) Chlorite monitoring at the entrance to the distribution system required by subsection (b)(2)(A)(i) of this Section may not be reduced.
  - ii) Chlorite monitoring in the distribution system required by subsection (b)(2)(A)(ii) of this Section may be reduced to one three-sample set per quarter after one year of monitoring where no individual chlorite sample taken in the distribution system under subsection (b)(2)(A)(ii) of this Section has exceeded the chlorite MCL and the supplier has not been required to conduct monitoring under subsection (b)(2)(B) of this Section. The supplier may remain on the reduced monitoring schedule until either any of the three individual chlorite samples taken quarterly in the distribution system under subsection (b)(2)(A)(ii) of this Section exceeds the chlorite MCL or the supplier is required to conduct monitoring under subsection (b)(2)(B) of this Section, at which time the supplier must revert to routine monitoring.
- 3) Bromate.
  - A) Routine monitoring. A CWS or NTNCWS supplier using ozone, for disinfection or oxidation, must take one sample per month for each treatment plant in the system using ozone. A supplier must take samples monthly at the entrance to the distribution system while the ozonation system is operating under normal conditions.
  - B) Reduced monitoring.
    - i) Until March 31, 2009, a supplier required to analyze for bromate may reduce monitoring from monthly to quarterly, if

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

the supplier demonstrates that the average source water bromide concentration is less than 0.05 mg/l based on representative monthly bromide measurements for one year. The supplier may remain on reduced bromate monitoring until the running annual average source water bromide concentration, computed quarterly, is equal to or greater than 0.05 mg/l based on representative monthly measurements. If the running annual average source water bromide concentration is equal to or greater than 0.05 mg/l, the supplier must resume routine monitoring required by subsection (b)(3)(A) of this Section in the following month.

- ii) Beginning April 1, 2009, a Subpart B system supplier may no longer use the provisions of subsection (b)(3)(B)(i) of this Section to qualify for reduced monitoring. A supplier required to analyze for bromate may reduce monitoring from monthly to quarterly, if the supplier's running annual average bromate concentration is not greater than 0.0025 mg/l based on monthly bromate measurements under subsection (b)(3)(A) of this Section for the most recent four quarters, with samples analyzed using USEPA OGWDW Methods, Method 302.0, Method 317.0 (rev. 2.0), ~~or~~ Method 326.0 (rev. 1.0), or Method 557 or USEPA Organic and Inorganic Methods, Method 321.8. If a supplier has qualified for reduced bromate monitoring under subsection (b)(3)(B)(i) of this Section, that supplier may remain on reduced monitoring as long as the running annual average of quarterly bromate samples not greater than 0.0025 mg/l based on samples analyzed using USEPA OGWDW Methods, Method 302.0, Method 317.0 ~~(rev. 2.0)~~, ~~or~~ Method 326.0 ~~(rev. 1.0)~~, or Method 557 or USEPA Organic and Inorganic Methods, Method 321.8. If the running annual average bromate concentration is greater than 0.0025 mg/l, the supplier must resume routine monitoring required by subsection (b)(3)(A) of this Section.
  
- c) Monitoring requirements for disinfectant residuals.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- 1) Chlorine and chloramines.
  - A) Routine monitoring. A CWS or NTNCWS supplier that uses chlorine or chloramines must measure the residual disinfectant level in the distribution system at the same point in the distribution system and at the same time as total coliforms are sampled, as specified in Section 611.521. A Subpart B system supplier may use the results of residual disinfectant concentration sampling conducted under Section 611.532 for unfiltered systems or Section 611.533 for systems that filter, in lieu of taking separate samples.
  - B) Reduced monitoring. Monitoring may not be reduced.
- 2) Chlorine dioxide.
  - A) Routine monitoring. A CWS, an NTNCWS, or a transient non-CWS supplier that uses chlorine dioxide for disinfection or oxidation must take daily samples at the entrance to the distribution system. For any daily sample that exceeds the MRDL, the supplier must take samples in the distribution system the following day at the locations required by subsection (c)(2)(B) of this Section, in addition to the sample required at the entrance to the distribution system.
  - B) Additional monitoring. On each day following a routine sample monitoring result that exceeds the MRDL, the supplier must take three chlorine dioxide distribution system samples. If chlorine dioxide or chloramines are used to maintain a disinfectant residual in the distribution system, or if chlorine is used to maintain a disinfectant residual in the distribution system and there are no disinfection addition points after the entrance to the distribution system (i.e., no booster chlorination), the supplier must take three samples as close to the first customer as possible, at intervals of at least six hours. If chlorine is used to maintain a disinfectant residual in the distribution system and there are one or more disinfection addition points after the entrance to the distribution system (i.e., booster chlorination), the supplier must take one sample at each of the following locations: as close to the first customer as possible, in a location representative of average residence time, and as close to

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

the end of the distribution system as possible (reflecting maximum residence time in the distribution system).

- C) Reduced monitoring. Monitoring may not be reduced.
- d) Monitoring requirements for disinfection byproduct (DBP) precursors.
- 1) Routine monitoring. A Subpart B system supplier that uses conventional filtration treatment (as defined in Section 611.101) must monitor each treatment plant for TOC not past the point of combined filter effluent turbidity monitoring and representative of the treated water. A supplier required to monitor under this subsection (d)(1) must also monitor for TOC in the source water prior to any treatment at the same time as monitoring for TOC in the treated water. These samples (source water and treated water) are referred to as paired samples. At the same time as the source water sample is taken, a system must monitor for alkalinity in the source water prior to any treatment. A supplier must take one paired sample and one source water alkalinity sample per month per plant at a time representative of normal operating conditions and influent water quality.
  - 2) Reduced monitoring. A Subpart B system supplier with an average treated water TOC of less than 2.0 mg/l for two consecutive years, or less than 1.0 mg/l for one year, may reduce monitoring for both TOC and alkalinity to one paired sample and one source water alkalinity sample per plant per quarter. The supplier must revert to routine monitoring in the month following the quarter when the annual average treated water TOC greater than or equal to 2.0 mg/l.
- e) Bromide. A supplier required to analyze for bromate may reduce bromate monitoring from monthly to once per quarter, if the supplier demonstrates that the average source water bromide concentration is less than 0.05 mg/l based upon representative monthly measurements for one year. The supplier must continue bromide monitoring to remain on reduced bromate monitoring.
- f) Monitoring plans. Each supplier required to monitor under this Subpart I must develop and implement a monitoring plan. The supplier must maintain the plan and make it available for inspection by the Agency and the general public no later than 30 days following the applicable compliance dates in Section 611.380(b). A

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Subpart B system supplier that serves more than 3,300 persons must submit a copy of the monitoring plan to the Agency no later than the date of the first report required under Section 611.384. After review, the Agency may require changes in any plan elements. The plan must include at least the following elements:

- 1) Specific locations and schedules for collecting samples for any parameters included in this Subpart I;
- 2) How the supplier will calculate compliance with MCLs, MRDLs, and treatment techniques; and
- 3) If approved for monitoring as a consecutive system, or if providing water to a consecutive system, under the provisions of Section 611.500, the sampling plan must reflect the entire distribution system.

BOARD NOTE: Derived from 40 CFR 141.132-~~(2006)~~ (2010).

(Source: Amended at 34 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

SUBPART L: MICROBIOLOGICAL MONITORING AND ANALYTICAL  
REQUIREMENTS

**Section 611.526 Analytical Methodology**

- a) The standard sample volume required for total coliform analysis, regardless of analytical method used, is 100 mL.
- b) Suppliers need only determine the presence or absence of total coliforms; a determination of total coliform density is not required.
- c) Suppliers must conduct total coliform analyses in accordance with one of the following analytical methods, incorporated by reference in Section 611.102, or in accordance with an alternative method approved by the Agency pursuant to Section 611.480 (the time from sample collection to initiation of analysis may not exceed 30 hours, and the supplier is encouraged but not required to hold samples below 10° C during transit):



ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- 1) Total Coliform Fermentation Technique, as set forth in Standard Methods, 18th, 19th, 20th, or 21st ed.; Methods 9221 A and B, as follows:
  - A) Lactose broth, as commercially available, may be used in lieu of lauryl tryptose broth if the supplier conducts at least 25 parallel tests between this medium and lauryl tryptose broth using the water normally tested and this comparison demonstrates that the false-positive rate and false-negative rate for total coliforms, using lactose broth, is less than 10 percent;
  - B) If inverted tubes are used to detect gas production, the media should cover these tubes at least one-half to two-thirds after the sample is added; and
  - C) No requirement exists to run the completed phase on 10 percent of all total coliform-positive confirmed tubes.
- 2) Total Coliform Membrane Filter Technique, as set forth in Standard Methods, 18th, 19th, 20th, or 21st ed.; Methods 9222 A, B, and C.
- 3) Presence-Absence (P-A) Coliform Test, as set forth in: Standard Methods, 18th, 19th, 20th, or 21st ed.; Method 9221 D, as follows:
  - A) No requirement exists to run the completed phase on 10 percent of all total coliform-positive confirmed tubes; and
  - B) Six-times formulation strength may be used if the medium is filter-sterilized rather than autoclaved.
- 4) ONPG-MUG test: Standard Methods, 18th, 19th, 20th, or 21st ed.; Method 9223. (The ONPG-MUG test is also known as the Autoanalysis Colilert System.)
- 5) Colisure Test (Autoanalysis Colilert System). (The Colisure Test may be read after an incubation time of 24 hours.)

BOARD NOTE: USEPA included the P-A Coliform and Colisure Tests for testing finished water under the coliform rule, but did not include them

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

for the purposes of the surface water treatment rule, under Section 611.531, for which quantitation of total coliforms is necessary. For these reasons, USEPA included Standard Methods<sup>2</sup>, Method 9221 C for the surface water treatment rule, but did not include it for the purposes of the total coliform rule, under this Section.

- 6) E\*Colite® Test (Charm Sciences, Inc.).
- 7) m-ColiBlue24® Test (Hatch Company).
- 8) ~~Readycult Coliforms 100 Presence/Absence Test~~ Readycult® 2000.
- 9) ~~Membrane Filter Technique using Chromocult® Method Coliform Agar.~~
- 10) Colitag® Test.
- 11) Modified Colitag™ Method.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended note 1 to the table at corresponding 40 CFR 141.21(f)(3) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 9221 A, B, and D (as approved in 1999) or Method 9222 A, B, and C (as approved in 1997); and 9223 B (as approved in 1997). The Board has cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods) for Methods 9221 and 9223, since the cited versions of the methods appears in that reference. USEPA later added Method 9221 A, B, and D; Method 9222 A, B, and C; Method 9223 from the 21st edition of Standard Methods. USEPA added Standard Methods, 21st ed., Methods 9221 A, B, and D; 9222 A, B, and C; and 9223 as approved alternative method-methods in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added Modified Colitag™ Method as an approved alternative method in appendix A to subpart C of 40 CFR 141 on November 10, 2009 (at 74 Fed. Reg. 57908).~~

- d) This subsection corresponds with 40 CFR 141.21(f)(4), which USEPA has marked “reserved.” This statement maintains structural consistency with the federal regulations.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- e) Suppliers must conduct fecal coliform analysis in accordance with the following procedure:
- 1) When the MTF Technique or P-A Coliform Test is used to test for total coliforms, shake the lactose-positive presumptive tube or P-A vigorously and transfer the growth with a sterile 3-mm loop or sterile applicator stick into brilliant green lactose bile broth and EC medium, defined below, to determine the presence of total and fecal coliforms, respectively.
  - 2) For approved methods that use a membrane filter, transfer the total coliform-positive culture by one of the following methods: remove the membrane containing the total coliform colonies from the substrate with sterile forceps and carefully curl and insert the membrane into a tube of EC medium; (the laboratory may first remove a small portion of selected colonies for verification); swab the entire membrane filter surface with a sterile cotton swab and transfer the inoculum to EC medium (do not leave the cotton swab in the EC medium); or inoculate individual total coliform-positive colonies into EC medium. Gently shake the inoculated tubes of EC medium to insure adequate mixing and incubate in a waterbath at  $44.5 \pm 0.2^\circ \text{C}$  for  $24 \pm 2$  hours. Gas production of any amount in the inner fermentation tube of the EC medium indicates a positive fecal coliform test.
  - 3) EC medium is described in Standard Methods, 18th ed., 19th ed., and 20th ed., Method 9221 E.
  - 4) Suppliers need only determine the presence or absence of fecal coliforms; a determination of fecal coliform density is not required.
- f) Suppliers must conduct analysis of *E. coli* in accordance with one of the following analytical methods, incorporated by reference in Section 611.102:
- 1) EC medium supplemented with  $50 \mu\text{g}/\ell$  of MUG (final concentration). EC medium is as described in subsection (e) of this Section. MUG may be added to EC medium before autoclaving. EC medium supplemented with  $50 \mu\text{g}/\ell$  MUG is commercially available. At least  $10 \text{ ml}$  of EC medium supplemented with MUG must be used. The inner inverted fermentation tube may be omitted. The procedure for transferring a total coliform-

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

positive culture to EC medium supplemented with MUG is as in subsection (e) of this Section for transferring a total coliform-positive culture to EC medium. Observe fluorescence with an ultraviolet light (366 nm) in the dark after incubating tube at  $44.5\pm 2^\circ$  C for  $24\pm 2$  hours; or

- 2) Nutrient agar supplemented with  $100\ \mu\text{g}/\ell$  MUG (final concentration), as described in Standard Methods, 19th ed. and 20th ed., Method 9222 G. This test is used to determine if a total coliform-positive sample, as determined by the MF technique, contains E. coli. Alternatively, Standard Methods, 18th ed., Method 9221 B may be used if the membrane filter containing a total coliform-positive colony or colonies is transferred to nutrient agar, as described in Method 9221 B (paragraph 3), supplemented with  $100\ \mu\text{g}/\ell$  MUG. If Method 9221 B is used, incubate the agar plate at  $35^\circ$  Celsius for four hours, then observe the colony or colonies under ultraviolet light (366-nm) in the dark for fluorescence. If fluorescence is visible, E. coli are present.
- 3) Minimal Medium ONPG-MUG (MMO-MUG) Test, as set forth in Appendix D of this Part. (The Autoanalysis Colilert System is a MMO-MUG test.) If the MMO-MUG test is total coliform positive after a 24-hour incubation, test the medium for fluorescence with a 366-nm ultraviolet light (preferably with a six-watt lamp) in the dark. If fluorescence is observed, the sample is E. coli-positive. If fluorescence is questionable (cannot be definitively read) after 24 hours incubation, incubate the culture for an additional four hours (but not to exceed 28 hours total), and again test the medium for fluorescence. The MMO-MUG test with hepes buffer is the only approved formulation for the detection of E. coli.
- 4) The Colisure Test (Autoanalysis Colilert System).
- 5) The membrane filter method with MI agar.
- 6) The E\*Colite® Test.
- 7) The m-ColiBlue24® Test.
- 8) ~~Readycult Coliforms 100 Presence/Absence Test~~ Readycult® 2000.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- 9) ~~Membrane Filter Technique using Chromocult® Method Coliform Agar.~~
- 10) Colitag® Test.
- 11) ONPG-MUG Test: Standard Methods, 20th or 21st ed., Method 9223 B.
- 12) Modified Colitag™ Method.

BOARD NOTE: USEPA added Standard Methods, 20th or 21st ed., Method 9223 B and Standard Methods Online, Method 9223 B-97 as approved alternative methods for E. coli in appendix A to subpart C of 40 CFR 141 on November 10, 2009 (at 74 Fed. Reg. 57908).

- g) As an option to the method set forth in subsection (f)(3) of this Section, a supplier with a total coliform-positive, MUG-negative, MMO-MUG test may further analyze the culture for the presence of E. coli by transferring a 0.1 ml, 28-hour MMO-MUG culture to EC medium + MUG with a pipet. The formulation and incubation conditions of the EC medium + MUG, and observation of the results, are described in subsection (f)(1) of this Section.
- h) This subsection corresponds with 40 CFR 141.21(f)(8), a central listing of all documents incorporated by reference into the federal microbiological analytical methods. The corresponding Illinois incorporations by reference are located at Section 611.102. This statement maintains structural parity with USEPA regulations.

BOARD NOTE: Derived from 40 CFR 141.21(f)-(2007) and appendix A to 40 CFR 141; ~~as added at 73 Fed. Reg. 31616 (June 3, 2008) (2010).~~

(Source: Amended at 34 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

**Section 611.531 Analytical Requirements**

The analytical methods specified in this Section, or alternative methods approved by the Agency pursuant to Section 611.480, must be used to demonstrate compliance with the requirements of only 611.Subpart B; they do not apply to analyses performed for the purposes of Sections 611.521 through 611.527 of this Subpart L. Measurements for pH, temperature, turbidity, and

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

RDCs must be conducted under the supervision of a certified operator. Measurements for total coliforms, fecal coliforms and HPC must be conducted by a laboratory certified by the Agency to do such analysis. The following procedures must be performed by the following methods, incorporated by reference in Section 611.102:

- a) A supplier ~~shall do~~ must conduct analyses as follows:
  - 1) ~~Conduct~~ The supplier must conduct analyses ~~of~~ for pH in accordance with one of the methods listed at Section 611.611; and
  - 2) ~~Conduct~~ The supplier must conduct analyses ~~of~~ for total coliforms, fecal coliforms, heterotrophic bacteria, and turbidity in accordance with one of the following methods, and by using analytical test procedures contained in USEPA Technical Notes, incorporated by reference in Section 611.102, as follows:
    - A) Total Coliforms.

BOARD NOTE: The time from sample collection to initiation of analysis for source (raw) water samples required by Sections 611.521 and 611.532 and Subpart B of this Part only must not exceed eight hours. The supplier is encouraged but not required to hold samples below 10° C during transit.

- i) Total coliform fermentation technique: Standard Methods, 18th, 19th, 20th, or 21st ed.; Method 9221 A, B, and C.

BOARD NOTE: Lactose broth, as commercially available, may be used in lieu of lauryl tryptose broth if the supplier conducts at least 25 parallel tests between this medium and lauryl tryptose broth using the water normally tested and this comparison demonstrates that the false-positive rate and false-negative rate for total coliforms, using lactose broth, is less than 10 percent. If inverted tubes are used to detect gas production, the media should cover these tubes at least one-half to two-thirds after the sample is added. No requirement exists to run the completed phase on 10 percent of all total coliform-positive confirmed tubes.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- ii) Total coliform membrane filter technique: Standard Methods, 18th, 19th, 20th, or 21st ed.; Method 9222 A, B, and C.
- iii) ONPG-MUG test (also known as the Autoanalysis Colilert System): Standard Methods, 18th, 19th, 20th, or 21st ed.; Method 9223.

BOARD NOTE: USEPA included the P-A Coliform and Colisure Tests for testing finished water under the coliform rule, under Section 611.526, but did not include them for the purposes of the surface water treatment rule, under this Section, for which quantitation of total coliforms is necessary. For these reasons, USEPA included Standard Methods; Method 9221 C for the surface water treatment rule, but did not include it for the purposes of the total coliform rule, under Section 611.526.

BOARD NOTE: USEPA added Standard Methods, 21st ed., Methods 9221 A, B, and C; 9222 A, B, and C; and 9223 as approved alternative methods for total coliform in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

B) Fecal Coliforms.

BOARD NOTE: The time from sample collection to initiation of analysis for source (raw) water samples required by Sections 611.521 and 611.532 and Subpart B of this Part only must not exceed eight hours. The supplier is encouraged but not required to hold samples below 10° C during transit.

- i) Fecal coliform procedure: Standard Methods, 18th, 19th, 20th, or 21st ed.; Method 9221 E.

BOARD NOTE: A-1 broth may be held up to seven days in a tightly closed screwcap tube at 4° C (39° F).

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- ii) Fecal Coliform Membrane Filter Procedure: Standard Methods, 18th, 19th, 20th, or 21st ed.; Method 9222 D.

BOARD NOTE: USEPA added Standard Methods, 21st ed., Methods 9221 E and 9222 D as approved alternative methods for fecal coliforms in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

- C) Heterotrophic bacteria.

- i) Pour plate method: Standard Methods, 18th, 19th, 20th, or 21st ed.; Method 9215 B.

BOARD NOTE: The time from sample collection to initiation of analysis must not exceed eight hours. The supplier is encouraged but not required to hold samples below 10° C during transit.

- ii) SimPlate method.

BOARD NOTE: USEPA added Standard Methods, 21st ed., Method 9215 B as an approved alternative method for heterotrophic bacteria in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

- D) Turbidity.

BOARD NOTE: Styrene divinyl benzene beads (*e.g.*, AMCO-AEPA-1 or equivalent) and stabilized formazin (*e.g.*, Hach StablCal™ or equivalent) are acceptable substitutes for formazin.

- i) Nephelometric method: Standard Methods, 18th, 19th, 20th, or 21st ed.; Method 2130 B.
- ii) Nephelometric method: USEPA Environmental Inorganic Methods; Method 180.1 (rev. 2.0).
- iii) GLI Method 2.



ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- iv) Hach FilterTrak Method 10133.
- v) Laser nephelometry (on-line): Mitchell Method M5271.
- vi) LED nephelometry (on-line): Mitchell Method M5331 or AMI Turbiwell Method.
- vii) LED nephelometry (portable): Orion Method AQ4500.

BOARD NOTE: USEPA added Standard Methods, 21st ed., Method 9130 B as an approved alternative method for turbidity in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added Mitchell Method M5271 and Orion Method AQ4500 as approved alternative methods for turbidity in appendix A to subpart C of 40 CFR 141 on August 3, 2009 (at 74 Fed. Reg. 38348). USEPA added AMI Turbiwell Method as an approved alternative method for turbidity in appendix A to subpart C of 40 CFR 141 on November 10, 2009 (at 74 Fed. Reg. 57908).

- E) Temperature: Standard Methods, 18th, 19th, 20th, or 21st ed.; Method 2550.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entries for total coliforms, fecal coliforms, heterotrophic bacteria, turbidity, and temperature at corresponding 40 CFR 141.74(a)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 2130 B (as approved in 2001); Method 9215 B (as approved in 2000); Method 9221 A, B, and C (as approved in 1999); Method 9222 A, B, C, and D (as approved in 1997); and Method 9223 B (as approved in 1997). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the versions of Method 2130, Method 9215, Method 9221, Method 9222, and Method 9223 that appear in that printed volume are those cited by USEPA as acceptable for use. USEPA later added Method 2130 B; Method 9215 B; Method 9221 A, B, C, and E; Method 9222 A, B, C, and D; and Method 9223 from the 21st edition of Standard~~

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~Methods as an approved alternative method for in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- b) A supplier must measure residual disinfectant concentrations with one of the following analytical methods:
- 1) Free chlorine.
    - A) Amperometric Titration.
      - i) Standard Methods, 18th, 19th, 20th, or 21st ed., Method 4500-Cl D.
      - ii) ASTM Method ~~D 1253-03~~ D1253-03 or D1253-08.
    - B) DPD Ferrous Titrimetric: Standard Methods, 18th, 19th, 20th, or 21st ed., Method 4500-Cl F.
    - C) DPD Colimetric: Standard Methods, 18th, 19th, 20th, or 21st ed., Method 4500-Cl G.
    - D) Syringaldazine (FACTS): Standard Methods, 18th, 19th, 20th, or 21st ed., Method 4500-Cl H.
    - E) On-line chlorine analyzer: USEPA OGWDW Methods, Method 334.0.
    - F) Amperometric sensor: Palintest ChloroSense.

BOARD NOTE: USEPA added Standard Methods, 21st ed., Methods 4500-Cl D, F, G, and H; Method 4500-ClO<sub>2</sub> C and E as approved alternative methods for free chlorine in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Method D1253-08, USEPA OGWDW Methods, Method 334.0, and Palintest ChloroSense as approved alternative methods for free chlorine in appendix A to subpart C of 40 CFR 141 on November 10, 2009 (at 74 Fed. Reg. 57908).

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- 2) Total chlorine.
  - A) Amperometric Titration:
    - i) Standard Methods, 18th, 19th, 20th, or 21st ed., Method 4500-Cl D.
    - ii) ASTM Method ~~D 1253-03~~ D1253-03 or D1253-08.
  - B) Amperometric Titration (low level measurement): Standard Methods, 18th, 19th, 20th, or 21st ed., Method 4500-Cl E.
  - C) DPD Ferrous Titrimetric: Standard Methods, 18th, 19th, 20th, or 21st ed., Method 4500-Cl F.
  - D) DPD Colimetric: Standard Methods, 18th, 19th, 20th, or 21st ed., Method 4500-Cl G.
  - E) Iodometric Electrode: Standard Methods, 18th, 19th, 20th, or 21st ed., Method 4500-Cl I.
  - F) On-line chlorine analyzer: USEPA OGWDW Methods, Method 334.0.
  - G) Amperometric sensor: Palintest ChloroSense.

BOARD NOTE: USEPA added Standard Methods, 21st ed., Methods 4500-Cl D, E, F, G, and I as approved alternative methods for total chlorine in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Method D1253-08, USEPA OGWDW Methods, Method 334.0, and Palintest ChloroSense as approved alternative methods for total chlorine in appendix A to subpart C of 40 CFR 141 on November 10, 2009 (at 74 Fed. Reg. 57908).

- 3) Chlorine dioxide.
  - A) Amperometric Titration: Standard Methods, 18th, 19th, 20th, or 21st ed., Method 4500-ClO<sub>2</sub> C or E.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- B) DPD Method: Standard Methods, 18th, 19th, or 20th ed., Method 4500-ClO<sub>2</sub> D.
  - C) Spectrophotometric: USEPA OGWDW Methods, Method 327.0 (rev. 1.1).
- 4) Ozone: Indigo Method: Standard Methods, 18th, 19th, 20th, or 21st ed., Method 4500-O<sub>3</sub> B.
- 5) Alternative test methods: The Agency may grant a SEP pursuant to Section 611.110 that allows a supplier to use alternative chlorine test methods as follows:
- A) DPD colorimetric test kits: Residual disinfectant concentrations for free chlorine and combined chlorine may also be measured by using DPD colorimetric test kits.
  - B) Continuous monitoring for free and total chlorine: Free and total chlorine residuals may be measured continuously by adapting a specified chlorine residual method for use with a continuous monitoring instrument, provided the chemistry, accuracy, and precision remain the same. Instruments used for continuous monitoring must be calibrated with a grab sample measurement at least every five days or as otherwise provided by the Agency.

BOARD NOTE: Suppliers may use a five-tube test or a 10-tube test.

BOARD NOTE: USEPA added Standard Methods, 21st ed., Method 4500-ClO<sub>2</sub> C, D, and E and Method 4500-O<sub>3</sub> B as approved alternative methods for chlorine dioxide in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entries for free chlorine, total chlorine, chlorine dioxide, and ozone at corresponding 40 CFR 141.74(a)(2) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 4500-Cl D, E, F, G, and H (as approved~~

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

in 2000); Method 4500-ClO<sub>2</sub>-C and E (as approved in 2000); and Method 4500-O<sub>3</sub>-B (as approved in 1997). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the versions of Method 4500-Cl, Method 4500-ClO<sub>2</sub>, and Method 4500-O<sub>3</sub> that appear in that printed volume are those cited by USEPA as acceptable for use. USEPA later added Method 4500-Cl D, E, F, G, and H; Method 4500-ClO<sub>2</sub>-C and E; and Method 4500-O<sub>3</sub>-B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).

BOARD NOTE: Derived from 40 CFR 141.74(a)-(2007) and appendix A to 40 CFR 141, as added at 73 Fed. Reg. 31616 (June 3, 2008) (2010).

(Source: Amended at 34 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

SUBPART N: INORGANIC MONITORING AND ANALYTICAL  
REQUIREMENTS

**Section 611.611 Inorganic Analysis**

Analytical methods are from documents incorporated by reference in Section 611.102. These are mostly referenced by a short name defined by Section 611.102(a). Other abbreviations are defined in Section 611.101.

- a) Analysis for the following contaminants must be conducted using the following methods or an alternative method approved pursuant to Section 611.480. Criteria for analyzing arsenic, chromium, copper, lead, nickel, selenium, sodium, and thallium with digestion or directly without digestion, and other analytical procedures, are contained in USEPA Technical Notes, incorporated by reference in Section 611.102.

BOARD NOTE: Because MDLs reported in USEPA Environmental Metals Methods 200.7 and 200.9 were determined using a 2× preconcentration step during sample digestion, MDLs determined when samples are analyzed by direct analysis (i.e., no sample digestion) will be higher. For direct analysis of cadmium and arsenic by USEPA Environmental Metals Method 200.7, and arsenic by Standard Methods, 18th, 19th, 20th, or 21st ed., Method 3120 B sample preconcentration using pneumatic nebulization may be required to achieve lower

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

detection limits. Preconcentration may also be required for direct analysis of antimony, lead, and thallium by USEPA Environmental Metals Method 200.9; antimony and lead by Standard Methods, 18th, 19th, or 21st ed., Method 3113 B; and lead by ASTM Method D3559-96 D or D3559-03 D unless multiple in-furnace depositions are made.

1) Alkalinity.

A) Titrimetric.

- i) ASTM Method D1067-92 B or D1067-02 B; or
- ii) Standard Methods, 18th, 19th 20th, or 21st ed., Method 2320 B.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for alkalinity by titrimetric alkalinity in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 2320 B (as approved in 1997). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 2320 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 2320 B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

B) Electrometric titration: USGS Methods-, Method I-1030-85.

BOARD NOTE: USEPA added Standard Methods, 21st ed., Method 2320 B as an approved alternative method for alkalinity in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

2) Antimony.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- A) Inductively coupled plasma-mass spectrometry: USEPA Environmental Metals Methods; Method 200.8 (rev. 5.3).
- B) Atomic absorption, hydride technique: ASTM Method D3697-92, ~~or D3697-02, or D3697-07~~.
- C) Atomic absorption, platform furnace technique: USEPA Environmental Metals Methods; Method 200.9 (rev. 2.2).
- D) Atomic absorption, furnace technique: Standard Methods, 18th, 19th, or 21st ed.; Method 3113 B.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for antimony by atomic absorption, furnace technique, in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3113 B (as approved in 1999). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 3113 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 3113 B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- E) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): USEPA ~~Methods;~~ NERL Method 200.5.

~~BOARD NOTE: USEPA added this method as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

BOARD NOTE: USEPA added Standard Methods, 21st ed., Method 3113B and USEPA NERL Method 200.5 as approved alternative methods for antimony in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Method D3697-07 as an

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

approved alternative method for antimony in appendix A to subpart C of 40 CFR 141 on November 10, 2009 (at 74 Fed. Reg. 57908).

3) Arsenic.

BOARD NOTE: If ultrasonic nebulization is used in the determination of arsenic by ~~Methods 200.7, Method 200.8, or Standard Methods, 18th, 19th, 20th, or 21st ed., 3120 B,~~ the arsenic must be in the pentavalent state to provide uniform signal response. ~~For methods 200.7 and 3120 B, both samples and standards must be diluted in the same mixed acid matrix concentration of nitric and hydrochloric acid with the addition of 100 µl of 30% hydrogen peroxide per 100 ml of solution. For direct analysis of arsenic with method Method 200.8 using ultrasonic nebulization, samples and standards must contain one mg/l of sodium hypochlorite.~~

~~A) Inductively coupled plasma.~~

~~BOARD NOTE: Effective January 23, 2006, a supplier may no longer employ analytical methods using the ICP-AES technology because the detection limits for these methods are 0.008 mg/l or higher. This restriction means that the two ICP-AES methods (USEPA Environmental Metals Method 200.7 and Standard Methods, Method 3120 B) approved for use for the MCL of 0.05 mg/l may not be used for compliance determinations for the revised MCL of 0.010 mg/l. However, prior to the 2005 through 2007 compliance period, a supplier may have compliance samples analyzed with these less sensitive methods.~~

~~i) USEPA Environmental Metals Methods: Method 200.7; or~~

~~ii) Standard Methods, 18th, 19th, 20th, or 21st ed.: Method 3120 B.~~

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for arsenic by inductively coupled plasma in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3120 B (as~~



POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

approved in 1999). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 3120 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 3120 B from the 21st edition of Standard Methods as an approved alternative method for several other metals in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA, however, did not specifically add Method 2130 B as to arsenic in the June 3, 2008 action.

~~BA)~~ Inductively coupled plasma-mass spectrometry: USEPA Environmental Metals Methods; Method 200.8 (rev. 5.3).

~~CB)~~ Atomic absorption, platform furnace technique: USEPA Environmental Metals Methods; Method 200.9 (rev. 2.2).

~~DC)~~ Atomic absorption, furnace technique.

i) ASTM Method D2972-97 C, ~~or 2972-03 C~~ D2972-03 C, or D2972-08 C; or

ii) Standard Methods, 18th, 19th, or 21st ed.; Method 3113 B.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for arsenic by atomic absorption, furnace technique, in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3113 B (as approved in 1999). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 3113 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 3113 B from the 21st edition of Standard Methods as an approved alternative~~

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

ED) Atomic absorption, hydride technique.

- i) ~~ASTM Method D2972-97 B, or 2972-03 C~~ D2972-03 C, or D2972-08 B; or
- ii) Standard Methods, 18th, 19th, or 21st ed., Method 3114 B.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for antimony by atomic absorption, hydride technique, in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3114 B (as approved in 1997). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 3114 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 3114 B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

FE) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): ~~USEPA Methods:~~ NERL Method 200.5.

~~BOARD NOTE: USEPA added this method as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

BOARD NOTE: USEPA added Standard Methods, 21st ed., Methods 3113 B and 3114 B and USEPA NERL Method 200.5 as approved alternative methods for arsenic in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Methods

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

D2972-08 B and C as approved alternative methods for arsenic in appendix A to subpart C of 40 CFR 141 on November 10, 2009 (at 74 Fed. Reg. 57908).

4) Asbestos: Transmission electron microscopy: USEPA Asbestos ~~Methods-Method 100.1 and or~~ USEPA Asbestos ~~Methods-Method 100.2.~~

5) Barium.

A) Inductively coupled plasma.

i) USEPA Environmental Metals Methods~~;~~, Method 200.7 (rev. 4.4); or

ii) Standard Methods, 18th, 19th, 20th, or 21st ed.~~;~~, Method 3120 B.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for barium by inductively coupled plasma in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3120 B (as approved in 1999). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 3120 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 3120 B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

B) Inductively coupled plasma-mass spectrometry: USEPA Environmental Metals Methods~~;~~, Method 200.8 (rev. 5.3).

C) Atomic absorption, direct aspiration technique: Standard Methods, 18th, 19th, or 21st ed.~~;~~, Method 3111 D.

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for barium by atomic absorption, direct aspiration technique, in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3111 D (as approved in 1999). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 3111 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 3111 D from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- D) Atomic absorption, furnace technique: Standard Methods, 18th, 19th, or 21st ed.; Method 3113 B.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for barium by atomic absorption, furnace technique, in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3113 B (as approved in 1999). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 3113 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 3113 B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- E) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): USEPA Methods; NERL Method 200.5.

~~BOARD NOTE: USEPA added this method as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

BOARD NOTE: USEPA added Standard Methods, 21st ed., Methods 3111D, 3113B, and 3120 B and NERL Method 200.5 as approved alternative methods for barium in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

6) Beryllium.

A) Inductively coupled plasma.

- i) USEPA Environmental Metals Methods~~;~~, Method 200.7 (rev. 4.4); or
- ii) Standard Methods, 18th, 19th, 20th, or 21st ed.~~;~~, Method 3120 B.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for beryllium by inductively coupled plasma in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3120 B (as approved in 1999). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 3120 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 3120 B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- B) Inductively coupled plasma-mass spectrometry: USEPA Environmental Metals Methods~~;~~, Method 200.8 (rev. 5.3).
- C) Atomic absorption, platform furnace technique: USEPA Environmental Metals Methods~~;~~, Method 200.9 (rev. 2.2).
- D) Atomic absorption, furnace technique.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- i) ASTM Method D3645-97 B, ~~or~~ D3645-03 B, or D3645-08 B; or
- ii) Standard Methods, 18th, 19th, or 21st ed., Method 3113 B.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for beryllium by atomic absorption, furnace technique, in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3113 B (as approved in 1999). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 3113 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 3113 B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- E) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): ~~USEPA Methods: NERL Method 200.5.~~

~~BOARD NOTE: USEPA added this method as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

BOARD NOTE: USEPA added Standard Methods, 21st ed., Methods 3113 B and 3120 B and USEPA NERL Method 200.5 as approved alternative methods for beryllium in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Method D3645-08 B as an approved alternative method for beryllium in appendix A to subpart C of 40 CFR 141 on November 10, 2009 (at 74 Fed. Reg. 57908).

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- 7) Cadmium.
- A) Inductively coupled plasma arc furnace: USEPA Environmental Metals Methods~~;~~ Method 200.7 (rev. 4.4).
  - B) Inductively coupled plasma-mass spectrometry: USEPA Environmental Metals Methods~~;~~ Method 200.8 (rev. 5.3).
  - C) Atomic absorption, platform furnace technique: USEPA Environmental Metals Methods~~;~~ Method 200.9 (rev. 2.2).
  - D) Atomic absorption, furnace technique: Standard Methods, 18th, 19th, or 21st ed.~~;~~ Method 3113 B.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for cadmium by atomic absorption, furnace technique, in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3113 B (as approved in 1999). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 3113 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 3113 B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- E) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): USEPA ~~Methods;~~ NERL Method 200.5.

~~BOARD NOTE: USEPA added this method as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

BOARD NOTE: USEPA added Standard Methods, 21st ed., Method 3113 B and USEPA NERL Method 200.5 as approved alternative methods for

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

cadmium in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

- 8) Calcium.
- A) EDTA titrimetric.
- i) ~~ASTM Method D511-93 A<sub>2</sub> or D511-03 A<sub>2</sub> or D511-09 A<sub>2</sub>;~~  
or
- ii) Standard Methods, 18th or 19th ed.; ~~Method 3500-Ca D~~  
or Standard Methods, 20th or 21st ed.; ~~Method 3500-Ca B.~~

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for calcium by EDTA titrimetric in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3500-Ca D (as approved in 1997). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 3500-Ca that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 3500-Ca B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- B) Atomic absorption, direct aspiration.
- i) ~~ASTM Method D511-93 B<sub>2</sub> or D511-03 B<sub>2</sub> or D511-09 B<sub>2</sub>;~~  
or
- ii) Standard Methods, 18th, 19th, or 21st ed.; ~~Method 3111 B.~~



---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for calcium by atomic absorption, direct aspiration in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3111 B (as approved in 1999). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 3111 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 3111 B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- C) Inductively coupled plasma.
- i) USEPA Environmental Metals Methods, Method 200.7 (rev. 4.4); or
  - ii) Standard Methods, 18th, 19th, 20th, or 21st ed., Method 3120 B.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for calcium by inductively coupled plasma in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3120 B (as approved in 1999). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 3120 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 3120 B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- D) Ion chromatography: ASTM Method D6919-03.
- E) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): USEPA Methods: ~~NERL~~ Method 200.5.

~~BOARD NOTE: USEPA added this method as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

BOARD NOTE: USEPA added Standard Methods, 21st ed., Methods 3111B, 3120 B, and 3500-Ca B and USEPA NERL Method 200.5 as approved alternative methods for calcium in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Methods D511-09 A and B as approved alternative methods for calcium in appendix A to subpart C of 40 CFR 141 on November 10, 2009 (at 74 Fed. Reg. 57908).

9) Chromium.

- A) Inductively coupled plasma.
- i) USEPA Environmental Metals Methods: ~~Method 200.7 (rev. 4.4); or~~
- ii) Standard Methods, 18th, 19th, 20th, or 21st ed.: ~~Method 3120 B.~~

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for chromium by inductively coupled plasma in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3120 B (as approved in 1999). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 3120 that appears in that printed volume is that cited by USEPA as acceptable for~~

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~use. USEPA later added Method 3120 B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- B) Inductively coupled plasma-mass spectrometry: USEPA Environmental Metals Methods~~;~~ Method 200.8 (rev. 5.3).
- C) Atomic absorption, platform furnace technique: USEPA Environmental Metals Methods~~;~~ Method 200.9 (rev. 2.2).
- D) Atomic absorption, furnace technique: Standard Methods, 18th, 19th, or 21st ed.~~;~~ Method 3113 B.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for chromium by atomic absorption, furnace technique, in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3113 B (as approved in 1999). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 3113 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 3113 B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- E) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): USEPA ~~Methods;~~ NERL Method 200.5.

~~BOARD NOTE: USEPA added this method as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

BOARD NOTE: USEPA added Standard Methods, 21st ed., Methods 3113 B and 3120 B and USEPA NERL Method 200.5 as an approved

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

alternative method for chromium in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

10) Copper.

A) Atomic absorption, furnace technique.

- i) ~~ASTM Method D1688-95 C<sub>2</sub>, or D1688-02 C, or D1688-07 C; or~~
- ii) Standard Methods, 18th, 19th, or 21st ed.; Method 3113 B.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for copper by atomic absorption, furnace technique, in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3113 B (as approved in 1999). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 3113 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 3113 B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

B) Atomic absorption, direct aspiration.

- i) ~~ASTM Method D1688-95 A<sub>2</sub>, or D1688-02 A, or D1688-07 A; or~~
- ii) Standard Methods, 18th, 19th, or 21st ed.; Method 3111 B.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for copper by atomic~~

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~absorption, direct aspiration in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3111 B (as approved in 1999). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 3111 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 3111 B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- C) Inductively coupled plasma.
- i) ~~USEPA Environmental Metals Methods~~, Method 200.7 (rev. 4.4); or
  - ii) Standard Methods, 18th, 19th, 20th, or 21st ed., Method 3120 B.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for copper by inductively coupled plasma in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3120 B (as approved in 1999). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 3120 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 3120 B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- D) Inductively coupled plasma-mass spectrometry: USEPA Environmental Metals Methods, Method 200.8 (rev. 5.3).

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- E) Atomic absorption, platform furnace technique: USEPA Environmental Metals Methods, Method 200.9 (rev. 2.2).
- F) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): USEPA Methods, NERL Method 200.5.

~~BOARD NOTE: USEPA added this method as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

BOARD NOTE: USEPA added Standard Methods, 21st ed., Methods 3111B, 3113 B, and 3120 B and USEPA NERL Method 200.5 as an approved alternative method for copper in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Methods D1688-07 A and C as approved alternative methods for copper in appendix A to subpart C of 40 CFR 141 on November 10, 2009 (at 74 Fed. Reg. 57908).

- 11) Conductivity; Conductance.
  - A) ASTM Method D1125-95(1999) A; or
  - B) Standard Methods, 18th, 19th, 20th, or 21st ed., Method 2510 B.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for conductivity by conductance in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 2510 B (as approved in 1997). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 2510 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 2510 B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

BOARD NOTE: USEPA added Standard Methods, 21st ed. Method 2510 B as an approved alternative method for conductivity in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

12) Cyanide.

A) Manual distillation (ASTM Method D2036-98 A or Standard Methods, 18th, 19th, or 20th ed., Method 4500-CN C), followed by spectrophotometric, amenable.

i) ASTM Method D2036-98 B or 2036-06 B; or

~~BOARD NOTE: USEPA added ASTM Method D2036-06 A as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

ii) Standard Methods, 18th, 19th, 20th, or 21st ed., Method 4500-CN G.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for cyanide by spectrophotometric, amenable, in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 4500-CN G (as approved in 1999). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 4500-CN that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 4500-CN G from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

B) Manual distillation (ASTM Method D2036-98 A or Standard Methods, 18th, 19th, or 20th ed.; Method 4500-CN C), followed by spectrophotometric, manual.

i) ~~ASTM Method D2036-98 A or 2036-06 A~~ D2036-06 A;

ii) Standard Methods, 18th, 19th, 20th, or 21st ed.; Method 4500-CN E; or

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for cyanide by spectrophotometric, manual, in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 4500-CN E (as approved in 1999). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 4500-CN that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 4500-CN E from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

iii) USGS Methods; Method I-3300-85.

C) Spectrophotometric, semiautomated: USEPA Environmental Inorganic Methods; Method 335.4 (rev. 1.0).

D) Selective electrode: Standard Methods, 18th, 19th, 20th, or 21st ed.; Method 4500-CN F.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for cyanide by selective electrode in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 4500-CN F (as approved in 1999). The Board has instead cited to~~



ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 4500-CN that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 4500-CN-F from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- E) UV/Distillation/Spectrophotometric: Kelada 01.
- F) Microdistillation/Flow Injection/Spectrophotometric: QuickChem 10-204-00-1-X.
- G) Ligand exchange and amperometry.
  - i) ASTM Method D6888-03.
  - ii) OI Analytical Method OIA-1677 DW.
- H) Gas chromatography-mass spectrometry headspace: Method ME355.01.

BOARD NOTE: USEPA added ASTM Method D2036-06 A and Standard Methods, 21st ed., Methods 4500-CN E, F, and G as approved alternative methods for cyanide in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added Method ME355.01 as an approved alternative method for cyanide in appendix A to subpart C of 40 CFR 141 on August 3, 2009 (at 74 Fed. Reg. 38348).

- 13) Fluoride.
  - A) Ion Chromatography.
    - i) USEPA Environmental Inorganic Methods; Method 300.0 (rev. 2.1) or USEPA Organic and Inorganic Methods, Method 300.1 (rev. 1.0);

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- ii) ASTM Method D4327-97 or D4327-03; or
- iii) Standard Methods, 18th, 19th, 20th, or 21st ed.±, Method 4110 B.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for fluoride by ion chromatography in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 4110 B (as approved in 2000). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 4110 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 4110 B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- B) Manual distillation, colorimetric SPADNS: Standard Methods, 18th, 19th, 20th, or 21st ed.±, Method 4500-F B and D.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for fluoride by manual distillation, colorimetry SPADNS, in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 4500 F B and D (as approved in 1997). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 4500 F that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 4500 F B and D from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- C) Manual electrode.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- i) ASTM Method D1179-93 B, D1179-99 B, or D1179-04 B;  
or

~~BOARD NOTE: USEPA added ASTM Method D1179-04 B as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- ii) Standard Methods, 18th, 19th, 20th, or 21st ed., Method 4500-F C.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for fluoride by manual electrode in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 4500-F C (as approved in 1997). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 4500-F that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 4500-F C from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- D) Automated electrode: Technicon Methods, Method 380-75WE.

- E) Automated alizarin.

- i) Standard Methods, 18th, 19th, 20th, or 21st ed., Method 4500-F E; or

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for fluoride by automated alizarin in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online~~

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~(at [www.standardmethods.org](http://www.standardmethods.org)), Method 4500 F E (as approved in 1997). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 4500 F that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 4500 F E from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

ii) Technicon Methods, Method 129-71W.

F) Capillary ion electrophoresis: ASTM Method D6508-00(2005).

BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for fluoride to add capillary ion electrophoresis in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of "Waters Method D6508, Rev. 2." The Board attempt to locate a copy of the method disclosed that it is an ASTM method originally approved in 2000 and reapproved in 2005. The Board has cited to the ASTM Method D6508-00(2005).

BOARD NOTE: USEPA added Standard Methods, 21st ed., Methods 4110 B and 4500 B, C, D, and E and ASTM Method D1179-04 B as approved alternative methods for fluoride in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

14) Lead.

A) Atomic absorption, furnace technique.

i) ASTM Method D3559-96 D, ~~or~~ D3559-03 D, or D3559-08 D; or

ii) Standard Methods, 18th, 19th, or 21st ed., Method 3113 B.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for lead by atomic absorption, furnace technique, in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3113-B (as approved in 1999). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 3113 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 3113-B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- B) Inductively coupled plasma-mass spectrometry: USEPA Environmental Metals Methods~~;~~, Method 200.8 (rev. 5.3).
- C) Atomic absorption, platform furnace technique: USEPA Environmental Metals Methods~~;~~, Method 200.9 (rev. 2.2).
- D) Differential Pulse Anodic Stripping Voltammetry: Palintest Method 1001.
- E) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): USEPA Methods~~;~~ NERL Method 200.5.

~~BOARD NOTE: USEPA added this method as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

BOARD NOTE: USEPA added Standard Methods, 21st ed., Method 3113 B and USEPA NERL Method 200.5 as approved alternative methods for lead in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Method D3559-08 D as an approved alternative method for lead in appendix A to subpart C of 40 CFR 141 on November 10, 2009 (at 74 Fed. Reg. 57908).

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

15) Magnesium.

A) Atomic absorption.

- i) ~~ASTM Method D511-93 B, or D511-03 B, or D511-09 B;~~  
or
- ii) ~~Standard Methods, 18th 19th, or 21st ed., Method 3111 B.~~

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for magnesium by atomic absorption in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3111 B (as approved in 1999). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 3111 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 3111 B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

B) Inductively coupled plasma.

- i) ~~USEPA Environmental Metals Methods, Method 200.7 (rev. 4.4); or~~
- ii) ~~Standard Methods, 18th, 19th, 20th, or 21st ed., Method 3120 B.~~

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for magnesium by inductively coupled plasma in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3120 B (as~~

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~approved in 1999). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 3120 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 3120 B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- C) Complexation titrimetric.
- i) ~~ASTM Method D511-93 A, or D511-03 A, or D511-09 A;~~  
or
  - ii) Standard Methods, 18th or 19th ed.; Method 3500-Mg E or Standard Methods, 20th or 21st ed.; Method 3500-Mg B.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for magnesium by complexation titrimetric in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3500 Mg B (as approved in 1997). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 3500 Mg that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 3500 Mg B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- D) Ion chromatography: ASTM Method D6919-03.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- E) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): ~~USEPA Methods: NERL Method 200.5.~~

~~BOARD NOTE: USEPA added this method as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

BOARD NOTE: USEPA added Standard Methods, 21st ed., Methods 3111B, 3120 B, and 3500-Mg B and USEPA NERL Method 200.5 as approved alternative methods for magnesium in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Methods D511-09 A and B as approved alternative methods for magnesium in appendix A to subpart C of 40 CFR 141 on November 10, 2009 (at 74 Fed. Reg. 57908).

16) Mercury.

- A) Manual cold vapor technique.

- i) ~~USEPA Environmental Metals Methods: Method 245.1 (rev. 3.0);~~
- ii) ~~ASTM Method D3223-97 or D3223-02; or~~
- iii) ~~Standard Methods, 18th, 19th, or 21st ed.: Method 3112 B.~~

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for mercury by manual cold vapor technique in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3112 B (as approved in 1999). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 3112 that appears in that printed volume is that cited by USEPA as acceptable for~~



ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~use. USEPA later added Method 3112 B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- B) Automated cold vapor technique: USEPA Inorganic Methods~~;~~ Method 245.2.
- C) Inductively coupled plasma-mass spectrometry: USEPA Environmental Metals Methods~~;~~ Method 200.8 (rev. 5.3).

BOARD NOTE: USEPA added Standard Methods, 21st ed., Method 3112 B as an approved alternative method for mercury in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

17) Nickel.

- A) Inductively coupled plasma.
  - i) USEPA Environmental Metals Methods~~;~~ Method 200.7 (rev. 4.4); or
  - ii) Standard Methods, 18th, 19th, 20th, or 21st ed.~~;~~ Method 3120 B.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for nickel by inductively coupled plasma in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3120 B (as approved in 1999). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 3120 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 3120 B from the 21st edition of Standard Methods as an approved alternative~~

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- B) Inductively coupled plasma-mass spectrometry: USEPA Environmental Metals Methods, Method 200.8 (rev. 5.3).
- C) Atomic absorption, platform furnace technique: USEPA Environmental Metals Methods, Method 200.9 (rev. 2.2).
- D) Atomic absorption, direct aspiration technique: Standard Methods, 18th, 19th, or 21st ed., Method 3111 B.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for nickel by atomic absorption, direct aspiration technique, in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3111 B (as approved in 1999). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 3111 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 3111 B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- E) Atomic absorption, furnace technique: Standard Methods, 18th, 19th, or 21st ed., Method 3113 B.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for nickel by atomic absorption, furnace technique, in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3113 B (as approved in 1999). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 3113 that appears in that printed volume is that cited by USEPA as~~

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~acceptable for use. USEPA later added Method 3113 B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- F) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): ~~USEPA Methods;~~ NERL Method 200.5.

~~BOARD NOTE: USEPA added this method as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

BOARD NOTE: USEPA added Standard Methods, 21st ed., Methods 3111 B, 3113 B, and 3120 B and USEPA NERL Method 200.5 as approved alternative methods for nickel in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

- 18) Nitrate.

- A) Ion chromatography.

- i) ~~USEPA Environmental Inorganic Methods;~~ Method 300.0 (rev. 2.1) or USEPA Organic and Inorganic Methods, Method 300.1 (rev. 1.0);
- ii) ~~ASTM Method D4327-97 or D4327-03;~~
- iii) ~~Standard Methods, 18th, 19th, 20th, or 21st ed.;~~ Method 4110 B; or

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for nitrate by ion chromatography in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 4110 B (as approved in 2000). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water~~

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~and Wastewater (the printed version of Standard Methods), since the version of Method 4110 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 4110-B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- iv) Waters Test Method B-1011, available from Millipore Corporation.

B) Automated cadmium reduction.

- i) USEPA Environmental Inorganic Methods, Method 353.2 (rev. 2.0);
- ii) ASTM Method D3867-90 A; or
- iii) Standard Methods, 18th, 19th, 20th, or 21st ed., Method 4500-NO<sub>3</sub><sup>-</sup> F.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for nitrate by automated cadmium reduction in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 4500-NO<sub>3</sub><sup>-</sup> F (as approved in 2000). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 4500-NO<sub>3</sub><sup>-</sup> that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 4500-NO<sub>3</sub><sup>-</sup> F from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

C) Ion selective electrode.

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- i) Standard Methods, 18th, 19th, 20th, or 21st ed., Method 4500-NO<sub>3</sub><sup>-</sup> D; or

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for nitrate by ion selective electrode in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at www.standardmethods.org), Method 4500-NO<sub>3</sub><sup>-</sup> D (as approved in 2000). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 4500-NO<sub>3</sub><sup>-</sup> that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 4500-NO<sub>3</sub><sup>-</sup> D from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- ii) Technical Bulletin 601.

D) Manual cadmium reduction.

- i) ASTM Method D3867-90 B; or
- ii) Standard Methods, 18th, 19th, 20th, or 21st ed., Method 4500-NO<sub>3</sub><sup>-</sup> E.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for nitrate by manual cadmium reduction in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at www.standardmethods.org), Method 4500-NO<sub>3</sub><sup>-</sup> E (as approved in 2000). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 4500-NO<sub>3</sub><sup>-</sup> that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 4500-NO<sub>3</sub><sup>-</sup> E from the~~

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- E) Capillary ion electrophoresis: ASTM Method D6508-00(2005).

BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for nitrate to add capillary ion electrophoresis in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of "Waters Method D6508, Rev. 2." The Board attempt to locate a copy of the method disclosed that it is an ASTM method originally approved in 2000 and reapproved in 2005. The Board has cited to the ASTM Method D6508-00(2005).

- F) Reduction-colorimetric: Systea Easy (1-Reagent).

BOARD NOTE: USEPA added Standard Methods, 21st ed., Methods 4110 B and 4500-NO<sub>3</sub><sup>-</sup> D, E, and F as approved alternative methods for nitrate in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added Systea Easy (1-Reagent) as an approved alternative method for nitrate in appendix A to subpart C of 40 CFR 141 on August 3, 2009 (at 73 Fed. Reg. 38348).

- 19) Nitrite.

- A) Ion chromatography.

- i) USEPA Environmental Inorganic Methods, Method 300.0 (rev. 2.1) or USEPA Organic and Inorganic Methods, Method 300.1 (rev. 1.0);
- ii) ASTM Method D4327-97 or D4327-03;
- iii) Standard Methods, 18th, 19th, 20th, or 21st ed., Method 4110 B; or

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for nitrite by ion~~

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~chromatography in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 4110 B (as approved in 2000). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 4110 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 4110 B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- iv) Waters Test Method B-1011, available from Millipore Corporation.

B) Automated cadmium reduction.

- i) USEPA Environmental Inorganic Methods, Method 353.2 (rev. 2.0);
- ii) ASTM Method D3867-90 A; or
- iii) Standard Methods, 18th, 19th, 20th, or 21st ed., Method 4500-NO<sub>3</sub><sup>-</sup> F.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for nitrite by automated cadmium reduction in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 4500-NO<sub>3</sub><sup>-</sup> F (as approved in 2000). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 4500-NO<sub>3</sub><sup>-</sup> that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 4500-NO<sub>3</sub><sup>-</sup> F from the 21st edition of Standard Methods as an approved~~

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- C) Manual cadmium reduction.
- i) ASTM Method D3867-90 B; or
  - ii) Standard Methods, 18th, 19th, 20th, or 21st ed., Method 4500-NO<sub>3</sub><sup>-</sup> E.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for nitrite by manual cadmium reduction in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 4500-NO<sub>3</sub><sup>-</sup> E (as approved in 2000). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 4500-NO<sub>3</sub><sup>-</sup> that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 4500-NO<sub>3</sub><sup>-</sup> E from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- D) Spectrophotometric: Standard Methods, 18th, 19th, 20th, or 21st ed., Method 4500-NO<sub>2</sub><sup>-</sup> B.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for nitrite by spectrophotometric in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 4500-NO<sub>2</sub><sup>-</sup> B (as approved in 2000). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 4500-NO<sub>2</sub><sup>-</sup> that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 4500-NO<sub>2</sub><sup>-</sup> B from the 21st edition of Standard~~



ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- E) Capillary ion electrophoresis: ASTM Method D6508-00(2005).

BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for nitrite to add capillary ion electrophoresis in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of "Waters Method D6508, Rev. 2." The Board attempt to locate a copy of the method disclosed that it is an ASTM method originally approved in 2000 and reapproved in 2005. The Board has cited to the ASTM Method D6508-00(2005).

- F) Reduction-colorimetric: Systea Easy (1-Reagent).

BOARD NOTE: USEPA added Standard Methods, 21st ed., Methods 4110 B, 4500-NO<sub>3</sub><sup>-</sup> E and F; and 4500-NO<sub>2</sub><sup>-</sup> B as approved alternative methods for nitrite in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added Systea Easy (1-Reagent) as an approved alternative method for nitrite in appendix A to subpart C of 40 CFR 141 on August 3, 2009 (at 73 Fed. Reg. 38348).

- 20) Orthophosphate (unfiltered, without digestion or hydrolysis).

- A) Automated colorimetric, ascorbic acid.

- i) USEPA Environmental Inorganic Methods~~÷~~<sub>2</sub> Method 365.1 (rev. 2.0); or
- ii) Standard Methods, 18th, 19th, 20th, or 21st ed.~~÷~~<sub>2</sub> Method 4500-P F.

~~BOARD NOTE: USEPA added Method 4500 P F from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA also added Method 4500 P F (as approved in 1999)~~

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~as available from Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)). The Board has instead cited only to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 4500-P E that appears in the printed volume is the 1999 version available from the online source.~~

- B) Single reagent colorimetric, ascorbic acid.
  - i) ASTM Method D515-88 A; or
  - ii) Standard Methods, 18th, 19th, 20th, or 21st ed., Method 4500-P E.

~~BOARD NOTE: USEPA added Method 4500-P E from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA also added Method 4500-P E (as approved in 1999) as available from Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)). The Board has instead cited only to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 4500-P E that appears in the printed volume is the 1999 version available from the online source.~~

- C) Colorimetric, phosphomolybdate: USGS Methods, Method I-1601-85.
- D) Colorimetric, phosphomolybdate, automated-segmented flow: USGS Methods, Method I-2601-90.
- E) Colorimetric, phosphomolybdate, automated discrete: USGS Methods, Method I-2598-85.
- F) Ion Chromatography.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- i) USEPA Environmental Inorganic Methods, Method 300.0 (rev. 2.1) or USEPA Organic and Inorganic Methods, Method 300.1 (rev. 1.0);
- ii) ASTM Method D4327-97 or D4327-03; or
- iii) Standard Methods, 18th, 19th, 20th, or 21st ed., Method 4110 B.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for orthophosphate by ion chromatography in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 4110 B (as approved in 2000). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 4110 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 4110 B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- G) Capillary ion electrophoresis: ASTM Method D6508-00(2005).

BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for orthophosphate to add capillary ion electrophoresis in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of "Waters Method D6508, Rev. 2." The Board attempt to locate a copy of the method disclosed that it is an ASTM method originally approved in 2000 and reapproved in 2005. The Board has cited to the ASTM Method D6508-00(2005).

BOARD NOTE: USEPA added Standard Methods, 21st ed., Methods 4110 B, 4500-P E and F as approved alternative methods for

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

orthophosphate in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

- 21) pH: electrometric.
- A) USEPA Inorganic Methods, Method 150.1 or Method 150.2;
  - B) ASTM Method D1293-95 or D1293-99; or
  - C) Standard Methods, 18th, 19th, 20th, or 21st ed., Method 4500-H<sup>+</sup> B.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for pH by electrometric in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 4500 H<sup>+</sup> B (as approved in 2000). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 4500 H<sup>+</sup> that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 4500 H<sup>+</sup> B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

BOARD NOTE: USEPA added Standard Methods, 21st ed., Method 4500-H<sup>+</sup> B as an approved alternative method for pH in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

- 22) Selenium.
- A) Atomic absorption, hydride.
    - i) ASTM Method D3859-98 A, ~~or~~ D3859-03 A, or D3859-08 A; or
    - ii) Standard Methods, 18th, 19th, or 21st ed., Method 3114 B.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for selenium by atomic absorption, hydride, in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3114 B (as approved in 1997). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 3114 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 3114 B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- B) Inductively coupled plasma-mass spectrometry: USEPA Environmental Metals Methods~~±~~, Method 200.8 (rev. 5.3).
- C) Atomic absorption, platform furnace technique: USEPA Environmental Metals Methods~~±~~, Method 200.9 (rev. 2.2).
- D) Atomic absorption, furnace technique.
  - i) ASTM Method D3859-98 B<sub>2</sub>, or D3859-03 B<sub>2</sub>, or D3859-08 B<sub>2</sub>; or
  - ii) Standard Methods, 18th, 19th, or 21st ed.~~±~~, Method 3113 B.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for selenium by atomic absorption, furnace technique, in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3113 B (as approved in 1999). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods),~~

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~since the version of Method 3113 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 3113 B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- E) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): ~~USEPA Methods;~~ NERL Method 200.5.

~~BOARD NOTE: USEPA added this method as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

BOARD NOTE: USEPA added Standard Methods, 21st ed., Methods 3113 B and 3114 B and USEPA NERL Method 200.5 as approved alternative methods for selenium in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Methods D3859-08 A and B as approved alternative methods for selenium in appendix A to subpart C of 40 CFR 141 on November 10, 2009 (at 74 Fed. Reg. 57908).

- 23) Silica.

- A) Colorimetric, molybdate blue: ~~USGS Methods;~~ Method I-1700-85.
- B) Colorimetric, molybdate blue, automated-segmented flow: ~~USGS Methods;~~ Method I-2700-85.
- C) Colorimetric: ASTM Method D859-94, D859-00, or D859-05.

~~BOARD NOTE: USEPA added ASTM Method D859-05 as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- D) Molybdosilicate: Standard Methods, 18th or 19th ed.±, Method 4500-Si D or Standard Methods, 20th or 21st ed.±, Method 4500-SiO<sub>2</sub> C.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for silica by molybdosilicate in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 4500-SiO<sub>2</sub> C (as approved in 1997). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 4500-SiO<sub>2</sub> that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 4500-SiO<sub>2</sub> C from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- E) Heteropoly blue: Standard Methods, 18th or 19th ed.±, Method 4500-Si E or Standard Methods, 20th or 21st ed.±, Method 4500-SiO<sub>2</sub> D.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for silica by heteropoly blue in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 4500-SiO<sub>2</sub> D (as approved in 1997). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 4500-SiO<sub>2</sub> that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 4500-SiO<sub>2</sub> D from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- F) Automated method for molybdate-reactive silica: Standard Methods, 18th or 19th ed.; Method 4500-Si F or Standard Methods, 20th or 21st ed.; Method 4500-SiO<sub>2</sub> E.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for silica by automated method for molybdate reactive silica in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 4500-SiO<sub>2</sub>-E (as approved in 1997). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 4500-SiO<sub>2</sub> that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 4500-SiO<sub>2</sub>-E from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- G) Inductively coupled plasma.
- i) USEPA Environmental Metals Methods; Method 200.7 (rev. 4.4); or
- ii) Standard Methods, 18th, 19th, 20th, or 21st ed.; Method 3120 B.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for silica by inductively coupled plasma in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3120 B (as approved in 1999). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 3120 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 3120 B from the 21st edition of Standard Methods as an approved alternative~~



ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- H) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): ~~USEPA Methods;~~ NERL Method 200.5.

~~BOARD NOTE: USEPA added this method as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

BOARD NOTE: USEPA added ASTM Method D859-05, Standard Methods, 21st ed.; Methods 3120 B and 4500-SiO<sub>2</sub> C, D, and E; and USEPA NERL Method 200.5 as approved alternative methods for silica in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

- 24) Sodium.

- A) Inductively coupled plasma: USEPA Environmental Metals Methods; ~~Method 200.7 (rev. 4.4).~~
- B) Atomic absorption, direct aspiration: Standard Methods, 18th, 19th, or 21st ed.; ~~Method 3111 B.~~

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for sodium by atomic absorption, direct aspiration, in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3111 B (as approved in 1999). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 3111 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 3111 B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- C) Ion chromatography: ASTM Method D6919-03.
- D) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): ~~USEPA Methods;~~ NERL Method 200.5.

~~BOARD NOTE: USEPA added this method as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

BOARD NOTE: USEPA added Standard Methods, 21st ed., Method 3113 B and USPEA NERL Method 200.5 as approved alternative methods for sodium in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

- 25) Temperature; thermometric: Standard Methods, 18th, 19th, 20th, or 21st ed.; Method 2550.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for temperature by thermometric in the table at corresponding 40 CFR 141.23(k)(1) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 2550 (as approved in 2000). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 2550 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 2550 from the 21st edition of Standard Methods.~~ USEPA added Standard Methods, 21st ed., Method 2550 as an approved alternative method for temperature in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).

- 26) Thallium.

- A) Inductively coupled plasma-mass spectrometry: USEPA Environmental Metals Methods; Method 200.8 (rev. 5.3).

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- B) Atomic absorption, platform furnace technique: USEPA Environmental Metals Methods, Method 200.9 (rev. 2.2).
- b) Sample collection for antimony, arsenic (effective January 22, 2004), asbestos, barium, beryllium, cadmium, chromium, cyanide, fluoride, mercury, nickel, nitrate, nitrite, selenium, and thallium pursuant to Sections 611.600 through 611.604 must be conducted using the following sample preservation, container, and maximum holding time procedures:

BOARD NOTE: For cyanide determinations samples must be adjusted with sodium hydroxide to pH 12 at the time of collection. When chilling is indicated the sample must be shipped and stored at 4° C or less. Acidification of nitrate or metals samples may be with a concentrated acid or a dilute (50% by volume) solution of the applicable concentrated acid. Acidification of samples for metals analysis is encouraged and allowed at the laboratory rather than at the time of sampling provided the shipping time and other instructions in Section 8.3 of USEPA Environmental Metals Method 200.7, 200.8, or 200.9 are followed.

- 1) Antimony.
  - A) Preservative: Concentrated nitric acid to pH less than 2.
  - B) Plastic or glass (hard or soft).
  - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within six months.
- 2) Arsenic.
  - A) Preservative: Concentrated nitric acid to pH less than 2.
  - B) Plastic or glass (hard or soft).
  - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within six months.
- 3) Asbestos.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- A) Preservative: Cool to 4° C.
  - B) Plastic or glass (hard or soft).
  - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within 48 hours.
- 4) Barium.
- A) Preservative: Concentrated nitric acid to pH less than 2.
  - B) Plastic or glass (hard or soft).
  - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within six months.
- 5) Beryllium.
- A) Preservative: Concentrated nitric acid to pH less than 2.
  - B) Plastic or glass (hard or soft).
  - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within six months.
- 6) Cadmium.
- A) Preservative: Concentrated nitric acid to pH less than 2.
  - B) Plastic or glass (hard or soft).
  - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within six months.
- 7) Chromium.
- A) Preservative: Concentrated nitric acid to pH less than 2.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- B) Plastic or glass (hard or soft).
  - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within six months.
- 8) Cyanide.
- A) Preservative: Cool to 4° C. Add sodium hydroxide to pH greater than 12. See the analytical methods for information on sample preservation.
  - B) Plastic or glass (hard or soft).
  - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within 14 days.
- 9) Fluoride.
- A) Preservative: None.
  - B) Plastic or glass (hard or soft).
  - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within one month.
- 10) Mercury.
- A) Preservative: Concentrated nitric acid to pH less than 2.
  - B) Plastic or glass (hard or soft).
  - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within 28 days.
- 11) Nickel.
- A) Preservative: Concentrated nitric acid to pH less than 2.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- B) Plastic or glass (hard or soft).
  - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within six months.
- 12) Nitrate, chlorinated.
- A) Preservative: Cool to 4° C.
  - B) Plastic or glass (hard or soft).
  - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within 14 days.
- 13) Nitrate, non-chlorinated.
- A) Preservative: Concentrated sulfuric acid to pH less than 2.
  - B) Plastic or glass (hard or soft).
  - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within 14 days.
- 14) Nitrite.
- A) Preservative: Cool to 4° C.
  - B) Plastic or glass (hard or soft).
  - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within 48 hours.
- 15) Selenium.
- A) Preservative: Concentrated nitric acid to pH less than 2.
  - B) Plastic or glass (hard or soft).

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within six months.
- 16) Thallium.
- A) Preservative: Concentrated nitric acid to pH less than 2.
  - B) Plastic or glass (hard or soft).
  - C) Holding time: Samples must be analyzed as soon after collection as possible, but in any event within six months.
- c) Analyses under this Subpart N must be conducted by laboratories that received approval from USEPA or the Agency. The Agency must certify laboratories to conduct analyses for antimony, arsenic (effective January 23, 2006), asbestos, barium, beryllium, cadmium, chromium, cyanide, fluoride, mercury, nickel, nitrate, nitrite, selenium, and thallium if the laboratory does as follows:
- 1) It analyzes performance evaluation (PE) samples, provided by the Agency pursuant to 35 Ill. Adm. Code 186, that include those substances at levels not in excess of levels expected in drinking water; and
  - 2) It achieves quantitative results on the analyses within the following acceptance limits:
    - A) Antimony:  $\pm 30\%$  at greater than or equal to 0.006 mg/l.
    - B) Arsenic:  $\pm 30\%$  at greater than or equal to 0.003 mg/l.
    - C) Asbestos: 2 standard deviations based on study statistics.
    - D) Barium:  $\pm 15\%$  at greater than or equal to 0.15 mg/l.
    - E) Beryllium:  $\pm 15\%$  at greater than or equal to 0.001 mg/l.
    - F) Cadmium:  $\pm 20\%$  at greater than or equal to 0.002 mg/l.
    - G) Chromium:  $\pm 15\%$  at greater than or equal to 0.01 mg/l.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- H) Cyanide:  $\pm 25\%$  at greater than or equal to 0.1 mg/l.
- I) Fluoride:  $\pm 10\%$  at 1 to 10 mg/l.
- J) Mercury:  $\pm 30\%$  at greater than or equal to 0.0005 mg/l.
- K) Nickel:  $\pm 15\%$  at greater than or equal to 0.01 mg/l.
- L) Nitrate:  $\pm 10\%$  at greater than or equal to 0.4 mg/l.
- M) Nitrite:  $\pm 15\%$  at greater than or equal to 0.4 mg/l.
- N) Selenium:  $\pm 20\%$  at greater than or equal to 0.01 mg/l.
- O) Thallium:  $\pm 30\%$  at greater than or equal to 0.002 mg/l.

BOARD NOTE: Derived from 40 CFR 141.23(k) ~~(2007)~~ and appendix A to 40 CFR 141, ~~as added at 73 Fed. Reg. 31616 (June 3, 2008)~~ (2010).

(Source: Amended at 34 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

**Section 611.612 Monitoring Requirements for Old Inorganic MCLs**

- a) Analyses for the purpose of determining compliance with the old inorganic MCLs of Section 611.300 are required as follows:
  - 1) Analyses for all CWSs utilizing surface water sources must be repeated at yearly intervals.
  - 2) Analyses for all CWSs utilizing only groundwater sources must be repeated at three-year intervals.
  - 3) This subsection (a)(3) corresponds with 40 CFR 141.23(1)(3), which requires monitoring for the repealed old MCL for nitrate at a frequency specified by the state. The Board has followed the USEPA lead and repealed that old MCL. This statement maintains structural consistency with USEPA rules.



---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- 4) This subsection (a)(4) corresponds with 40 CFR 141.23(1)(4), which authorizes the state to determine compliance and initiate enforcement action. This statement maintains structural consistency with USEPA rules.
- b) If the result of an analysis made under subsection (a) of this Section indicates that the level of any contaminant listed in Section 611.300 exceeds the old MCL, the supplier must report to the Agency within seven days and initiate three additional analyses at the same sampling point within one month.
- c) When the average of four analyses made pursuant to subsection (b) of this Section, rounded to the same number of significant figures as the old MCL for the substance in question, exceeds the old MCL, the supplier must notify the Agency and give notice to the public pursuant to Subpart V of this Part. Monitoring after public notification must be at a frequency designated by the Agency by a SEP granted pursuant to Section 611.110 and must continue until the old MCL has not been exceeded in two successive samples or until a different monitoring schedule becomes effective as a condition to a variance, an adjusted standard, a site specific rule, an enforcement action, or another SEP granted pursuant to Section 611.110.
- d) This subsection (d) corresponds with 40 CFR 141.23(o), which pertains to monitoring for the repealed old MCL for nitrate. This statement maintains structural consistency with USEPA rules.
- e) This subsection (e) corresponds with 40 CFR 141.23(p), which pertains to the use of existing data up until a date long since expired. This statement maintains structural consistency with USEPA rules.
- f) Except for arsenic, for which analyses must be made in accordance with Section 611.611, analyses conducted to determine compliance with the old MCLs of Section 611.300 must be made in accordance with the following methods, incorporated by reference in Section 611.102, or alternative methods approved by the Agency pursuant to Section 611.480.
  - 1) Fluoride: The methods specified in Section 611.611(c) must apply for the purposes of this Section.
  - 2) Iron.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- A) Standard Methods.
- i) Method 3111 B, 18th, 19th, or 21st ed.;
  - ii) Method 3113 B, 18th, 19th, or 21st ed.; or
  - iii) Method 3120 B, 18th, 19th, 20th, or 21st ed.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entries for iron in the table at 40 CFR 143.4(b) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3111 B, Method 3113 B, and Method 3120 B (as approved in 1999). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the versions of Method 3111, Method 3113, and Method 3120 that appear in that printed volume are those cited by USEPA as acceptable for use. USEPA later added Method 3111 B, Method 3113 B, and Method 3120 B from the 21st edition of Standard Methods as approved alternative methods in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- B) USEPA Environmental Metals Methods.
- i) Method 200.7 (rev. 4.4); or
  - ii) Method 200.9 (rev. 2.2).
- C) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): USEPA Methods: NERL Method 200.5.

BOARD NOTE: USEPA added this method as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

BOARD NOTE: USEPA added Standard Methods, 21st ed.; Methods 3111 B, 3113 B, and 3120 B and USEPA NERL Method 200.5 as approved alternative methods for iron in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

3) Manganese.

A) Standard Methods.

- i) Method 3111 B, 18th, 19th, or 21st ed.;
- ii) Method 3113 B, 18th, 19th, or 21st ed.; or
- iii) Method 3120 B, 18th, 19th, 20th, or 21st ed.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entries for manganese in the table at 40 CFR 143.4(b) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3111 B, Method 3113 B, and Method 3120 B (as approved in 1999). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the versions of Method 3111, Method 3113, and Method 3120 that appear in that printed volume are those cited by USEPA as acceptable for use. USEPA later added Method 3111 B, Method 3113 B, and Method 3120 B from the 21st edition of Standard Methods as approved alternative methods in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

B) USEPA Environmental Metals Methods.

- i) Method 200.7 (rev. 4.4);
- ii) Method 200.8 (rev. 5.3); or
- iii) Method 200.9 (rev. 2.2).

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- C) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): ~~USEPA Methods;~~ NERL Method 200.5.

~~BOARD NOTE: USEPA added this method as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

BOARD NOTE: USEPA added Standard Methods, 21st ed.; Methods 3111 B, 3113 B, and 3120 B and USEPA NERL Method 200.5 as approved alternative methods for manganese in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

- 4) Zinc.

- A) Standard Methods.

- i) Method 3111 B, 18th, 19th, or 21st ed.; or  
ii) Method 3120 B, 18th, 19th, 20th, or 21st ed.

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entries for zinc in the table at 40 CFR 143.4(b) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 3111 B and Method 3120 B (as approved in 1999). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the versions of Method 3111 and Method 3120 that appear in that printed volume are those cited by USEPA as acceptable for use. USEPA later added Method 3111 B, Method 3113 B, and Method 3120 B from the 21st edition of Standard Methods as approved alternative methods in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- B) USEPA Environmental Metals Methods.

- i) Method 200.7 (rev. 4.4); or

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- ii) Method 200.8 (rev. 5.3).
- C) Axially viewed inductively coupled plasma-atomic emission spectrometry (AVICP-AES): ~~USEPA Methods;~~ NERL Method 200.5.

~~BOARD NOTE: USEPA added this method as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

BOARD NOTE: USEPA added Standard Methods, 21st ed.; Methods 3111 B and 3120 B and USEPA NERL Method 200.5 as approved alternative methods for zinc in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

BOARD NOTE: The provisions of subsections (a) through ~~(f)~~(e) of this Section derive from 40 CFR 141.23(l) through (p) ~~(2007)~~ (2010). Subsections ~~(f)(2) through (f)(4)~~ of this Section relate exclusively to additional State requirements. The Board retained subsection (f) of this Section to set forth methods for the inorganic contaminants for which there is a State-only MCL. The methods specified are those set forth in 40 CFR 143.4(b) ~~(2007)~~ and appendix A to subpart C of 40 CFR 141 (2010), as added at 73 Fed. Reg. 31616 (June 3, 2008), for secondary MCLs.

(Source: Amended at 34 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

SUBPART O: ORGANIC MONITORING AND ANALYTICAL REQUIREMENTS

**Section 611.645 Analytical Methods for Organic Chemical Contaminants**

Analysis for the Section 611.311(a) VOCs under Section 611.646; the Section 611.311(c) SOCs under Section 611.648; the Section 611.310 old MCLs under Section 611.641; and for THMs, TTHMs, and TTHM potential must be conducted using the methods listed in this Section ~~or by alternative methods as approved by the Agency pursuant to Section 611.480~~. All methods are from USEPA Organic Methods, unless otherwise indicated. All methods are incorporated by reference in Section 611.102. Other required analytical test procedures germane to the conduct

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

of these analyses are contained in the USEPA document, "Technical Notes of Drinking Water Methods," incorporated by reference in Section 611.102.

Volatile Organic Chemical Contaminants (VOCs).

Contaminant	Analytical Methods
Benzene	502.2 (rev. 2.1), 524.2 (rev. 4.1), USEPA <u>OGWDW Methods,</u> <u>Method 524.3 (rev. 1.0)</u>
Carbon tetrachloride	502.2 (rev. 2.1), 524.2 (rev. 4.1), USEPA <u>OGWDW Methods,</u> <u>Method 524.3 (rev. 1.0),</u> <u>551.1 (rev. 1.0)</u>
Chlorobenzene	502.2 (rev. 2.1), 524.2 (rev. 4.1), USEPA <u>OGWDW Methods,</u> <u>Method 524.3 (rev. 1.0)</u>
1,2-Dichlorobenzene	502.2 (rev. 2.1), 524.2 (rev. 4.1), USEPA <u>OGWDW Methods,</u> <u>Method 524.3 (rev. 1.0)</u>
1,4-Dichlorobenzene	502.2 (rev. 2.1), 524.2 (rev. 4.1), USEPA <u>OGWDW Methods,</u> <u>Method 524.3 (rev. 1.0)</u>
1,2-Dichloroethane	502.2 (rev. 2.1), 524.2 (rev. 4.1), USEPA <u>OGWDW Methods,</u> <u>Method 524.3 (rev. 1.0)</u>
cis-Dichloroethylene	502.2 (rev. 2.1), 524.2 (rev. 4.1), USEPA <u>OGWDW Methods,</u> <u>Method 524.3 (rev. 1.0)</u>

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

trans-Dichloroethylene	<u>502.2 (rev. 2.1), 524.2 (rev. 4.1), USEPA OGWDW Methods, Method 524.3 (rev. 1.0)</u>
Dichloromethane	<u>502.2 (rev. 2.1), 524.2 (rev. 4.1), USEPA OGWDW Methods, Method 524.3 (rev. 1.0)</u>
1,2-Dichloropropane	<u>502.2 (rev. 2.1), 524.2 (rev. 4.1), USEPA OGWDW Methods, Method 524.3 (rev. 1.0)</u>
Ethylbenzene	<u>502.2 (rev. 2.1), 524.2 (rev. 4.1), USEPA OGWDW Methods, Method 524.3 (rev. 1.0)</u>
Styrene	<u>502.2 (rev. 2.1), 524.2 (rev. 4.1), USEPA OGWDW Methods, Method 524.3 (rev. 1.0)</u>
Tetrachloroethylene	<u>502.2 (rev. 2.1), 524.2 (rev. 4.1), USEPA OGWDW Methods, Method 524.3 (rev. 1.0), 551.1 (rev. 1.0)</u>
1,1,1-Trichloroethane	<u>502.2 (rev. 2.1), 524.2 (rev. 4.1), USEPA OGWDW Methods, Method 524.3 (rev. 1.0), 551.1 (rev. 1.0)</u>
Trichloroethylene	<u>502.2 (rev. 2.1), 524.2 (rev. 4.1), USEPA OGWDW Methods, Method 524.3 (rev. 1.0), 551.1 (rev. 1.0)</u>

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Toluene	502.2 (rev. 2.1), 524.2 (rev. 4.1), USEPA OGWDW Methods, Method 524.3 (rev. 1.0)
1,2,4-Trichlorobenzene	502.2 (rev. 2.1), 524.2 (rev. 4.1), USEPA OGWDW Methods, Method 524.3 (rev. 1.0)
1,1-Dichloroethylene	502.2 (rev. 2.1), 524.2 (rev. 4.1), USEPA OGWDW Methods, Method 524.3 (rev. 1.0)
1,1,2-Trichloroethane	502.2 (rev. 2.1), 524.2 (rev. 4.1), USEPA OGWDW Methods, Method 524.3 (rev. 1.0)
Vinyl chloride	502.2 (rev. 2.1), 524.2 (rev. 4.1), USEPA OGWDW Methods, Method 524.3 (rev. 1.0)
Xylenes (total)	502.2 (rev. 2.1), 524.2 (rev. 4.1), USEPA OGWDW Methods, Method 524.3 (rev. 1.0)

BOARD NOTE: USEPA added USEPA OGWDW Method 524.3 (rev. 1.0) as an alternative method for all of the VOCs in appendix A to subpart C of 40 CFR 141 on August 3, 2009 (at 74 Fed. Reg. 38348).

Synthetic Organic Chemical Contaminants (SOCs).

Contaminant	Analytical Methods
2,3,7,8-Tetrachlorodibenzodioxin (2,3,7,8-TCDD or dioxin)	Dioxin and Furan Method 1613 (rev. B)



ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

2,4-D	<u>515.2 (rev. 1.1), 555 (rev. 1.0), 515.1 (rev. 4.0), USEPA Organic and Inorganic Methods, Method 515.3 (rev. 1.0), USEPA OGWDW Methods, Method 515.4 (rev. 1.0), ASTM Method D5317-93 or D5317-98</u>
2,4,5-TP (Silvex)	<u>515.2 (rev. 1.1), 555 (rev. 1.0), 515.1 (rev. 4.0), USEPA Organic and Inorganic Methods, Method 515.3 (rev. 1.0), USEPA OGWDW Methods, Method 515.4 (rev. 1.0), ASTM Method D5317-93 or D5317-98</u>
Alachlor	<u>505 (rev. 2.1)<sup>1</sup>, 507 (rev. 2.1), 508.1 (rev. 2.0), 525.2 (rev. 2.0), 551.1 (rev. 1.0)</u>
Atrazine	<u>505 (rev. 2.1)<sup>1</sup>, 507 (rev. 2.1), 508.1 (rev. 2.1), 525.2 (rev. 2.0), 551.1 (rev. 1.0), Syngenta AG-625<sup>2</sup></u>
Benzo(a)pyrene	<u>525.2 (rev. 2.0), 550, 550.1</u>

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Carbofuran	<u>531.1 (rev. 3.1), USEPA OGWDW Methods, Method 531.2 (rev. 1.0), Standard Methods, 18th ed. Supplement, 19th ed., or 20th ed.; Method 6610 or Standard Methods 21st ed. or Standard Methods Online; Method 6610 B-04</u>
Chlordane	<u>505 (rev. 2.1), 508 (rev. 3.1), 508.1 (rev. 2.1), 525.2 (rev. 2.0)</u>
Dalapon	<u>515.1 (rev. 4.0), 552.1 (rev. 1.0), 552.2 (rev. 1.0), USEPA Organic and Inorganic Methods, Method 515.3 (rev. 1.0), USEPA OGWDW Methods, Method Methods 515.4 (rev. 1.0), OGWDW Methods, Method 552.3 (rev. 1.0), and 557; and Standard Methods, 21st ed., Method 6640 B</u>
Di(2-ethylhexyl)adipate	<u>506 (rev. 1.1), 525.2 (rev. 2.0)</u>
Di(2-ethylhexyl)phthalate	<u>506 (rev. 1.1), 525.2 (rev. 2.0)</u>
Dibromochloropropane (DBCP)	<u>504.1 (rev. 1.1), USEPA OGWDW Methods, Method 524.3 (rev. 1.0), 551.1 (rev. 1.0)</u>

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Dinoseb	515.1 (rev. 4.0), 515.2 (rev. 1.1), <u>USEPA Organic and Inorganic Methods, Method 515.3 (rev. 1.0), USEPA OGWDW Methods, Method 515.4 (rev. 1.0), 555 (rev. 1.0)</u>
Diquat	<u>549.1 USEPA NERL Method 549.2 (rev. 1.0)</u>
Endothall	548.1 (rev. 1.0)
Endrin	505 (rev. 2.1), 508 (rev. 3.1), 508.1 (rev. 2.0), 525.2 (rev. 2.0), 551.1 (rev. 1.0)
Ethylene <del>Dibromide</del> - <u>dibromide</u> (EDB)	504.1 (rev. 1.1), <u>USEPA OGWDW Methods, Method 524.3 (rev. 1.0), 551.1 (rev. 1.0)</u>
Glyphosate	547, Standard Methods, 18th ed., 19th ed., or 20th ed.±, Method 6651
Heptachlor	505 (rev. 2.1), 508 (rev. 3.1), 508.1 (rev. 2.0), 525.2 (rev. 2.0), 551.1 (rev. 1.0)
Heptachlor Epoxide	505 (rev. 2.1), 508 (rev. 3.1), 508.1 (rev. 2.0), 525.2 (rev. 2.0), 551.1 (rev. 1.0)
Hexachlorobenzene	505 (rev. 2.1), 508 (rev. 3.1), 508.1 (rev. 2.0), 525.2 (rev. 2.0), 551.1 (rev. 1.0)
Hexachlorocyclopentadiene	505 (rev. 2.1), 508 (rev. 3.1), 508.1 (rev. 2.0), 525.2 (rev. 2.0), 551.1 (rev. 1.0)

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Lindane	505 <u>(rev. 2.1)</u> , 508 <u>(rev. 3.1)</u> , 508.1 <u>(rev. 2.0)</u> , 525.2 <u>(rev. 2.0)</u> , 551.1 <u>(rev. 1.0)</u>
Methoxychlor	505 <u>(rev. 2.1)</u> , 508 <u>(rev. 3.1)</u> , 508.1 <u>(rev. 2.0)</u> , 525.2 <u>(rev. 2.0)</u> , 551.1 <u>(rev. 1.0)</u>
Oxamyl	531.1; <u>(rev. 3.1)</u> ; USEPA OGWDW Methods, Method 531.2; <u>(rev. 1.0)</u> ; Standard Methods, 18th ed. Supplement, 19th ed., or 20th ed.; Method 6610; <del>or</del> Standard Methods 21st ed., <u>Method 6610 B</u> ; or Standard Methods Online; Method 6610 B-04
PCBs (measured for compliance purposes as <del>decchlorobiphenyl</del> <u>decachlorobiphenyl</u> ) PCBs (qualitatively identified as Aroclors)	508A <u>(rev. 1.0)</u>
Pentachlorophenol	505 <u>(rev. 2.1)</u> , 508 <u>(rev. 3.1)</u> , 508.1 <u>(rev. 2.0)</u> , 525.2 <u>(rev. 2.0)</u> , 515.1 <u>(rev. 4.0)</u> , 515.2 <u>(rev. 1.1)</u> , 525.2 <u>(rev. 2.0)</u> , 555 <u>(rev. 1.0)</u> , USEPA <u>Organic and Inorganic Methods, Method 515.3 (rev. 1.0)</u> , USEPA OGWDW Methods, Method 515.4 <u>(rev. 1.0)</u> , ASTM Method D5317-93 or D5317-98(2003)

ILLINOIS REGISTER

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Picloram	515.1 (rev. 4.0), 515.2 (rev. 1.1), 555 (rev. 1.0), <u>USEPA Organic and Inorganic Methods, Method 515.3 (rev. 1.0), USEPA OGWDW Methods, Method 515.4 (rev. 1.0), ASTM Method D5317-93 or D5317-98(2003)</u>
Simazine	505 (rev. 2.1) <sup>1</sup> , 507 (rev. 2.1), 508.1 (rev. 2.0), 525.2 (rev. 2.0), <del>551.2</del> 551.1 (rev. 1.0)
Toxaphene	505 (rev. 2.1), 508 (rev. 2.1), 508.1 (rev. 2.0), 525.2 (rev. 2.0), <del>508.1</del>

BOARD NOTE: USEPA added Standard Methods, 21st ed., Method 6610 B and Standard Methods Online, Method 6610 B-04 as approved alternative methods for carbofuran and oxamyl on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added USEPA OGWDW Method 524.3 (rev. 1.0) as an alternative method for dibromochloropropane and ethylene dibromide in appendix A to subpart C of 40 CFR 141 on August 3, 2009 (at 74 Fed. Reg. 38348). USEPA approved Standard Methods, 21st ed., Method 6640 B and Standard Methods Online, Method 6640 B-01 and USEPA OGWDW Methods, Method 557 as approved alternative methods for dalapon in appendix A to subpart C of 40 CFR 141 on June 8, 2010 (at 75 Fed. Reg. 32295). Since the version of Method 6640 that appears in Standard Methods Online is the same as that which appears in Standard Methods, 21st ed., the Board has cited only to Standard Methods, 21st ed.

Total Trihalomethanes (TTHMs).

Contaminant	Analytical Methods
Total Trihalomethanes (TTHMs), Trihalomethanes (THMs), and Maximum Total Trihalomethane Potential	502.2 (rev. 2.1), 524.2 (rev. 4.1), <u>USEPA OGWDW Methods, Method 524.3 (rev. 1.0), 551.1 (rev. 1.0)</u>

ILLINOIS REGISTER

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

BOARD NOTE: USEPA added USEPA OGWDW Method 524.3 (rev. 1.0) as an alternative method for total trihalomethane in appendix A to subpart C of 40 CFR 141 on August 3, 2009 (at 74 Fed. Reg. 38348).

State-Only MCLs (for which a method is not listed above).

Contaminant	Analytical Methods
Aldrin	505 <u>(rev. 2.1)</u> , 508 <u>(rev. 3.1)</u> , 508.1 <u>(rev. 2.0)</u> , 525.2 <u>(rev. 2.0)</u>
DDT	505 <u>(rev. 2.1)</u> , 508 <u>(rev. 3.1)</u>
Dieldrin	505 <u>(rev. 2.1)</u> , 508 <u>(rev. 3.1)</u> , 508.1 <u>(rev. 2.0)</u> , 525.2 <u>(rev. 2.0)</u>

<sup>1</sup> denotes that, for the particular contaminant, a nitrogen-phosphorus detector should be substituted for the electron capture detector in method 505 (or another approved method should be used) to determine alachlor, atrazine, and simazine if lower detection limits are required.

<sup>2</sup> denotes that Syngenta Method AG-625 may not be used for the analysis of atrazine in any system where chlorine dioxide is used for drinking water treatment. In samples from all other systems, any result for atrazine generated by Syngenta Method AG-625 that is greater than one-half the maximum contaminant level (MCL) (in other words, greater than 0.0015mg/ℓ or 1.5 µg/ℓ) must be confirmed using another approved method for this contaminant and should use additional volume of the original sample collected for compliance monitoring. In instances where a result from Syngenta Method AG-625 triggers such confirmatory testing, the confirmatory result is to be used to determine compliance.

BOARD NOTE: Derived from 40 CFR 141.24(e) ~~(2007)~~ and appendix A to subpart C of 40 CFR 141 (2010), as ~~added~~ amended at 73-74 Fed. Reg. 31616 (June 3, 2008) 38348 (August 3, 2009) and 75 Fed. Reg. 32295 (June 8, 2010).

(Source: Amended at 34 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

SUBPART P: THM MONITORING AND ANALYTICAL REQUIREMENTS

**Section 611.680 Sampling, Analytical, and other Requirements**

- a) Required monitoring.
  - 1) A CWS supplier that serves a population of 10,000 or more individuals and which adds a disinfectant (oxidant) to the water in any part of the drinking water treatment process must analyze for TTHMs in accordance with this Subpart P.
  - 2) For the purpose of this Subpart P, the minimum number of samples required to be taken by the supplier must be based on the number of treatment plants used by the supplier. However, the Agency shall, by a SEP issued pursuant to Section 611.110, provide that multiple wells drawing raw water from a single aquifer be considered one treatment plant for determining the minimum number of samples.
  - 3) All samples taken within an established frequency must be collected within a 24-hour period.
- b) A CWS supplier that serves 10,000 or more individuals.
  - 1) For a CWS supplier utilizing surface a water source in whole or in part, and for a CWS supplier utilizing only a groundwater source, except as provided in Section 611.683, analyses for TTHMs must be performed at quarterly intervals on at least four water samples for each treatment plant used by the system. At least 25 percent of the samples must be taken at locations within the distribution system reflecting the maximum residence time (MRT) of the water in the system. The remaining 75 percent must be taken at representative locations in the distribution system, taking into account the number of persons served, different sources of water and different treatment methods employed. The results of all analyses per quarter must be arithmetically averaged and reported to the Agency within 30 days after the supplier's receipt of such results. All samples collected must be used in the computation of the average, unless the analytical results are invalidated for technical reasons. Sampling and analyses must be conducted in accordance with the methods listed in Section 611.685.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- 2) Upon application by a CWS supplier, the Agency must, by a SEP issued pursuant to Section 611.110, reduce the monitoring frequency required by subsection (b)(1) to a minimum of one sample analyzed for TTHMs per quarter taken at a point in the distribution system reflecting the MRT of the water in the system, if the Agency determines that the data from at least one year of monitoring in accordance with subsection (b)(1) and local conditions demonstrate that TTHM concentrations will be consistently below the MCL.
- 3) If at any time during which the reduced monitoring frequency prescribed under this subsection (b) applies, the results from any analysis exceed 0.10 mg/l TTHMs and such results are confirmed by at least one check sample taken promptly after such results are received, or if the CWS supplier makes any significant change to its source of water or treatment program, the supplier must immediately begin monitoring in accordance with the requirements of subsection (b)(1), which monitoring must continue for at least ~~four~~ one year before the frequency may be reduced again. The Agency must, by a SEP issued pursuant to Section 611.110, require monitoring in excess of the minimum frequency where it is necessary to detect variations of TTHM levels within the distribution system.

BOARD NOTE: Subsections (a) and (b) of this Section are derived from 40 CFR 141.30(a) and (b)-~~(2002)~~ (2010), modified to remove the limitation regarding addition of disinfectant.

- c) Surface water sources for a CWS supplier that serves fewer than 10,000 individuals. Suppliers must have submitted at least one initial sample per treatment plant for analysis or analytical results from a certified laboratory for MRT concentration taken between May 1, 1990, and October 31, 1990. After written request by the supplier and the determination by the Agency that the results of the sample indicate that the CWS supplier is not likely to exceed the MCL, the CWS must continue to submit one annual sample per treatment plant for analysis or analytical results from a certified laboratory to the Agency taken between May 1 and October 31 of succeeding years. If the sample exceeds the MCL, the CWS must submit to the Agency samples in accordance with the sampling frequency specified in subsection (b) of this Section.



ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

BOARD NOTE: This is an additional State requirement.

- d) Groundwater sources for a CWS supplier that serves fewer than 10,000 individuals. Suppliers are not required to submit samples for THM analysis under this Subpart P.

BOARD NOTE: This is an additional State requirement.

(Source: Amended at 34 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

SUBPART Q: RADIOLOGICAL MONITORING AND ANALYTICAL REQUIREMENTS

**Section 611.720 Analytical Methods**

- a) The methods specified below, or alternative methods approved by the Agency pursuant to Section 611.480, incorporated by reference in Section 611.102, are to be used to determine compliance with Section 611.330, except in cases where alternative methods have been approved in accordance with Section 611.480.
  - 1) Gross Alpha and Beta.
    - A) Standard Methods.
      - i) Method 302, 13th ed.; or
      - ii) Method 7110 B, 17th, 18th, 19th, 20th, or 21st ed.;

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for gross alpha and beta by evaporation in the table at corresponding 40 CFR 141.25(a) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 7110 B (as approved in 2000). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 7110 that appears in that printed volume is that cited by USEPA as acceptable for~~

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~use. USEPA later added Method 7110 B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- B) USEPA Interim Radiochemical Methods: ~~page~~ pages 1-3;
- C) USEPA Radioactivity Methods: ~~;~~ Method 900.0;
- D) USEPA Radiochemical Analyses: ~~page~~ pages 1-5;
- E) USEPA Radiochemistry ~~Methods: Procedures~~; Method 00-01; or
- F) USGS Methods: ~~;~~ Method R-1120-76.

BOARD NOTE: USEPA added Standard Methods, 21st ed., Method 7110 B as an approved alternative method for gross alpha and beta in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

2) Gross Alpha.

- A) Standard Methods, 18th, 19th, 20th, or 21st ed.: ~~;~~ Method 7110 C; or

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for gross alpha by coprecipitation in the table at corresponding 40 CFR 141.25(a) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 7110 C (as approved in 2000). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 7110 that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 7110 C from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- B) USEPA Radiochemistry ~~Methods: Procedures~~; Method 00-02.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

BOARD NOTE: USEPA added Standard Methods, 21st ed., Method 7110 C as an approved alternative method for gross alpha in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

- 3) Radium-226.
- A) ASTM Methods.
    - i) Method D2460-97 or D2460-07; or
    - ii) Method D3454-97 or D3454-05;
  - B) New York Radium Method;
  - C) Standard Methods.
    - i) Method 304, 13th ed.;
    - ii) Method 305, 13th ed.;
    - iii) Method 7500-Ra B, 17th, 18th, 19th, 20th, or 21st ed.; or
    - iv) Method 7500-Ra C, 17th, 18th, 19th, 20th, or 21st ed.;

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entries for radium 226 in the table at corresponding 40 CFR 141.25(a) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 7500 Ra B and C (as approved in 2000). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 7500 Ra that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 7500 Ra B and C from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- D) ~~USDOE EML Procedures Manual~~:- (27th or 28th ed.), Method Ra-04;
- E) USEPA Interim Radiochemical Methods: pages 13-15 ~~and or~~ 16-23;
- F) USEPA Radioactivity Methods:-, Methods 903.0, 903.1;
- G) USEPA Radiochemical Analyses:-, ~~page~~ pages 19-32;
- H) USEPA Radiochemistry ~~Methods~~:- Procedures, Methods-Method Ra-03, or Ra-04; or
- I) USGS Methods.
  - i) Method R-1140-76; or
  - ii) Method R-1141-76.
- J) Georgia Radium Method.

BOARD NOTE: USEPA added Standard Methods, 21st ed., Methods 7500-Ra B and C as approved alternative methods for radium-226 in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Methods D2460-07 and D3454-05 as approved alternative methods for radium-226 in appendix A to subpart C of 40 CFR 141 on June 8, 2010 (at 75 Fed. Reg. 32295).

- 4) Radium-228.
  - A) Standard Methods, 17th, 18th, 19th, 20th, or 21st ed.:-, Method 7500-Ra D;  
  
~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for radium-228 by radiochemical in the table at corresponding 40 CFR 141.25(a) to allow the use of Standard Methods Online (at www.standardmethods.org), Method~~

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~7500-Ra-D (as approved in 2000). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 7500-Ra that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 7500-Ra-D from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- B) New York Radium Method;
- C) USEPA Interim Radiochemical Methods~~:-~~, ~~page~~ pages 24-28;
- D) USEPA Radioactivity Methods~~:-~~, Method 904.0;
- E) USEPA Radiochemical Analyses~~:-~~, ~~page~~ pages 19-32;
- F) USEPA Radiochemistry ~~Methods:-~~ Procedures, Method Ra-05;
- G) USGS Methods~~:-~~, Method R-1142-76;
- H) New Jersey Radium Method; or
- I) Georgia Radium Method.

BOARD NOTE: USEPA added Standard Methods, 21st ed., Method 7500-Ra D as an approved alternative method for radium-228 in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

- 5) Uranium.
  - A) Standard Methods, 17th, 18th, 19th, 20th, or 21st ed.~~:-~~, Method 7500-U C;

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entries for uranium by radiochemical and alpha spectrometry in the table at corresponding 40 CFR 141.25(a) to allow the use of Standard Methods Online (at~~

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~www.standardmethods.org), Method 7500 U C (as approved in 2000). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 7500 U that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 7500 U B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- B) Standard Methods, 20th ed.; Method 3125;
- C) ASTM Methods.
  - i) Method D2907-97;
  - ii) Method D3972-97 or D3972-02;
  - iii) Method D5174-97, ~~or~~ D5174-02, or D5174-07; or
  - iv) Method D5673-03 or Method 5673-05;

~~BOARD NOTE: USEPA added this method as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- D) USEPA Radioactivity Methods; Methods 908.0, 908.1;
- E) USEPA Environmental Metals Methods; Method 200.8 (rev. 5.3);
- F) USEPA Radiochemical Analyses; page pages 33-48;
- G) USEPA Radiochemistry ~~Methods~~; Procedures, Method 00-07;
- H) ~~USDOE EML Procedures Manual~~; (27th or 28th ed.), Method U-02 or U-04; or
- I) USGS Methods.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- i) Method R-1180-76;
- ii) Method R-1181-76; or
- iii) Method R-1182-76.

BOARD NOTE: If uranium (U) is determined by mass, a conversion factor of 0.67 pCi/μg of uranium must be used. This conversion factor is based on the 1:1 activity ratio of <sup>234</sup>U and <sup>238</sup>U that is characteristic of naturally occurring uranium.

BOARD NOTE: USEPA added Standard Methods, 21st ed., Method 7500-U C and ASTM D5673-05 as approved alternative methods for uranium in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Method D5174-07 as an approved alternative method for uranium in appendix A to subpart C of 40 CFR 141 on June 8, 2010 (at 75 Fed. Reg. 32295).

6) Radioactive Cesium.

A) ASTM Methods.

- i) Method D2459-72; or
- ii) Method D3649-91, ~~or D3649-98a~~, or D3649-06;

B) Standard Methods.

- i) Method 7120, 19th, 20th, or 21st ed.; or
- ii) Method 7500-Cs B, 17th, 18th, 19th, 20th, or 21st ed.;

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entries for radioactive cesium in the table at corresponding 40 CFR 141.25(a) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 7120 (as approved in 1997) and Method 7500-Cs B (as approved in 2000).~~

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the versions of Method 7120 and Method 7500-Cs that appear in that printed volume are those cited by USEPA as acceptable for use. USEPA later added Method 7120 and Method 7500-Cs B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).

- C) ~~USDOE EML Procedures Manual~~ (27th or 28th ed.), Method 4.5.2.3;
- D) USEPA Interim Radiochemical Methods, page pages 4-5;
- E) USEPA Radioactivity Methods, Methods 901.0, 901.1;
- F) USEPA Radiochemical Analyses, page pages 92-95; or
- G) USGS Methods.
  - i) Method R-1110-76; or
  - ii) Method R-1111-76.

BOARD NOTE: USEPA added Standard Methods, 21st ed., Methods 7120 and 7500-Cs B as approved alternative methods for radioactive cesium in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Method D3649-06 as an approved alternative method for radioactive cesium in appendix A to subpart C of 40 CFR 141 on June 8, 2010 (at 75 Fed. Reg. 32295).

- 7) Radioactive Iodine.
  - A) ASTM Methods.
    - i) D3649-91, ~~or~~ D3649-98a, or D3649-06; or



ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- ii) D4785-93, or D4785-98, or D4785-08;
- B) Standard Methods.
  - i) Method 7120, 19th, 20th, or 21st ed.;
  - ii) Method 7500-I B, 17th, 18th, 19th, 20th, or 21st ed.;
  - iii) Method 7500-I C, 17th, 18th, 19th, 20th, or 21st ed.; or
  - iv) Method 7500-I D, 17th, 18th, 19th, 20th, or 21st ed.;

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entries for radioactive iodine in the table at corresponding 40 CFR 141.25(a) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 7120 (as approved in 1997) and Method 7500-I B, C, and D (as approved in 2000). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the versions of Method 7120 and Method 7500-I that appear in that printed volume are those cited by USEPA as acceptable for use. USEPA later added Method 7500-I B, C, and D from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- C) ~~USDOE EML Procedures Manual-~~ (27th or 28th ed.), Method 4.5.2.3;
- D) ~~USEPA Interim Radiochemical Methods-~~ pages 6-8, or 9-12;
- E) ~~USEPA Radiochemical Analyses-~~ page-pages 92-95; or
- F) ~~USEPA Radioactivity Methods-~~ Methods 901.1, or 902.0.

BOARD NOTE: USEPA added Standard Methods, 21st ed., Methods 7120 and 7500-I B, C, and D as approved alternative methods for

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

radioactive iodine in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Methods D3649-06 and D4785-08 as approved alternative methods for radioactive iodine in appendix A to subpart C of 40 CFR 141 on June 8, 2010 (at 75 Fed. Reg. 32295).

8) Radioactive Strontium-89 & 90.

A) Standard Methods.

- i) Method 303, 13th ed.; or
- ii) Method 7500-Sr B, 17th, 18th, 19th, 20th, or 21st ed.;

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for radioactive strontium in the table at corresponding 40 CFR 141.25(a) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 7500 Sr B (as approved in 2001). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 7500 Sr that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 7500 Sr B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

B) ~~USDOE EML Procedures Manual (27th or 28th ed.), Method Sr-01 or Sr-02.~~

- ~~i) Method Sr-01; or~~
- ~~ii) Method Sr-02;~~

C) USEPA Interim Radiochemical Methods, ~~page pages 29-33;~~

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- D) USEPA Radioactivity Methods~~:-~~, Method 905.0;
- E) USEPA Radiochemical Analyses~~:-~~, ~~page~~ pages 65-73;
- F) USEPA Radiochemistry ~~Methods~~ Procedures~~:-~~, Method Sr-04; or
- G) USGS Methods~~:-~~, Method R-1160-76.

BOARD NOTE: USEPA added Standard Methods, 21st ed., Method 7500-Sr B as an approved alternative method for radioactive strontium in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616).

- 9) Tritium.
  - A) ASTM Methods: Method D4107-91, ~~or~~ D4107-98, or D4107-08;
  - B) Standard Methods.
    - i) Method 306, 13th ed.; or
    - ii) Method 7500-<sup>3</sup>H B, 17th, 18th, 19th, 20th, or 21st ed.;

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entry for tritium in the table at corresponding 40 CFR 141.25(a) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 7500-<sup>3</sup>H B (as approved in 2000). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 7500-<sup>3</sup>H that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA later added Method 7500-<sup>3</sup>H B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- C) USEPA Interim Radiochemical Methods~~;~~, ~~page~~-~~pages~~ 34-37;
- D) USEPA Radioactivity Methods~~;~~, Method 906.0;
- E) USEPA Radiochemical Analyses~~;~~, ~~page~~-~~pages~~ 87-91;
- F) USEPA Radiochemistry ~~Methods~~ Procedures~~;~~, Method H-02; or
- G) USGS Methods~~;~~, Method R-1171-76.

BOARD NOTE: USEPA added Standard Methods, 21st ed., Method 7500-<sup>3</sup>H B as an approved alternative method for tritium in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Method D4107-08 as an approved alternative method for tritium in appendix A to subpart C of 40 CFR 141 on June 8, 2010 (at 75 Fed. Reg. 32295).

10) Gamma Emitters.

- A) ASTM Methods.
  - i) Method D3649-91, ~~or~~ ~~D3649-98a~~, D3649-06; or
  - ii) Method D4785-93, ~~or~~ ~~D4785-00a~~, D4785-08;
- B) Standard Methods.
  - i) Method 7120, 19th, 20th, or 21st ed.;
  - ii) Method 7500-Cs B, 17th, 18th, 19th, 20th, or 21st ed.; or
  - iii) Method 7500-I B, 17th, 18th, 19th, 20th, or 21st ed.;

~~BOARD NOTE: On March 12, 2007 (at 72 Fed. Reg. 11200), USEPA amended the entries for gamma emitters in the table at corresponding 40 CFR 141.25(a) to allow the use of Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 7120 (as approved in 1997), Method 7500-Cs B (as approved in 2000), and~~

ILLINOIS REGISTER

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~Method 7500 I-B (as approved in 2000). The Board has instead cited to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the versions of Method 7120, Method 7500 Cs, and Method 7500 I that appear in that printed volume are those cited by USEPA as acceptable for use. USEPA later added Method 7150, Method 7500 Cs B, and Method 7500 I B from the 21st edition of Standard Methods as an approved alternative method in appendix A to subpart C of 40 CFR 141, added on June 3, 2008 (at 73 Fed. Reg. 31616).~~

- C) ~~USDOE EML Procedures Manual (27th or 28th ed.)~~; Method Ga-01-R;
- D) USEPA Radioactivity Methods; Methods 901.0, 901.1, or 902.0;
- E) USEPA Radiochemical Analyses; ~~page~~ pages 92-95; or
- F) USGS Methods; Method R-1110-76.

BOARD NOTE: USEPA added Standard Methods, 21st ed., Methods 7120, 7500-Cs B, and 7500-I B as approved alternative methods for gamma emitters in appendix A to subpart C of 40 CFR 141 on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ASTM Methods D3649-08 and D4785-08 as approved alternative methods for tritium in appendix A to subpart C of 40 CFR 141 on June 8, 2010 (at 75 Fed. Reg. 32295).

- b) When the identification and measurement of radionuclides other than those listed in subsection (a) of this Section are required, the following methods, incorporated by reference in Section 611.102, are to be used, except in cases where alternative methods have been approved in accordance with Section 611.480:
  - 1) "Procedures for Radiochemical Analysis of Nuclear Reactor Aqueous Solutions," available from NTIS.
  - 2) ~~HASL Procedure~~ EML Procedures Manual (27th or 28th ed.), ~~HASL-300~~, available from ~~ERDA Health and Safety Laboratory~~ USDOE, EML.

ILLINOIS REGISTER

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

c) For the purpose of monitoring radioactivity concentrations in drinking water, the required sensitivity of the radioanalysis is defined in terms of a detection limit. The detection limit must be that concentration which can be counted with a precision of plus or minus 100 percent at the 95 percent confidence level ( $1.96\sigma$ , where  $\sigma$  is the standard deviation of the net counting rate of the sample).

1) To determine compliance with Section 611.330(b), (c), and (e), the detection limit must not exceed the concentrations set forth in the following table:

Contaminant	Detection Limit
Gross alpha particle activity	3 pCi/ℓ
Radium-226	1 pCi/ℓ
Radium-228	1 pCi/ℓ
Uranium	1 μg/ℓ

BOARD NOTE: Derived from 40 CFR 141.25(c) Table B-~~(2007)~~ (2010).

2) To determine compliance with Section 611.330(d), the detection limits must not exceed the concentrations listed in the following table:

Radionuclide	Detection Limit
Tritium	1,000 pCi/ℓ
Strontium-89	10 pCi/ℓ
Strontium-90	2 pCi/ℓ
Iodine-131	1 pCi/ℓ
Cesium-134	10 pCi/ℓ
Gross beta	4 pCi/ℓ
Other radionuclides	1/10 of applicable limit

BOARD NOTE: Derived from 40 CFR 141.25(c) Table C-~~(2007)~~ (2010).

d) To judge compliance with the MCLs listed in Section 611.330, averages of data must be used and must be rounded to the same number of significant figures as the MCL for the substance in question.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

BOARD NOTE: Derived from 40 CFR 141.25-(2007) and appendix A to subpart C of 40 CFR 141, as added at ~~73 Fed. Reg. 31616 (June 3, 2008)~~ (2010).

(Source: Amended at 34 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

SUBPART S: GROUNDWATER RULE

**Section 611.802 Groundwater Source Microbial Monitoring and Analytical Methods**

- a) Triggered source water monitoring.
  - 1) General requirements. A GWS supplier must conduct triggered source water monitoring if the following conditions exist:
    - A) The supplier does not provide at least 4-log treatment of viruses (using inactivation, removal, or an Agency-approved combination of 4-log virus inactivation and removal) before or at the first customer for each groundwater source; and
    - B) The supplier is notified that a sample collected pursuant to Section 611.521 is total coliform-positive, and the sample is not invalidated by the Agency pursuant to Section 611.523.
  - 2) Sampling requirements. A GWS supplier must collect, within 24 hours after notification of the total coliform-positive sample, at least one groundwater source sample from each groundwater source in use at the time the total coliform-positive sample was collected pursuant to Section 611.521, except as provided in subsection (a)(2)(B) of this Section.
    - A) The Agency may, by a SEP issued pursuant to Section 611.110, extend the 24-hour time limit on a case-by-case basis if it determines that the supplier cannot collect the groundwater source water sample within 24 hours due to circumstances beyond the supplier's control. In the case of an extension, the Agency must specify how much time the supplier has to collect the sample.
    - B) If approved by the Agency, a supplier with more than one groundwater source may meet the requirements of this subsection

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

(a)(2) by sampling a representative groundwater source or sources. If directed by the Agency by a SEP issued pursuant to Section 611.110, the supplier must submit for Agency approval a triggered source water monitoring plan that identifies one or more groundwater sources that are representative of each monitoring site in the system's sample siting plan pursuant to Section 611.521 and that the system intends to use for representative sampling pursuant to this subsection (a).

- C) A GWS supplier that serves 1,000 or fewer people may use a repeat sample collected from a groundwater source to meet both the requirements of Section 611.522 and to satisfy the monitoring requirements of subsection (a)(2) of this Section for that groundwater source only if the Agency approves the use of E. coli as a fecal indicator for source water monitoring pursuant to this subsection (a) by a SEP issued pursuant to Section 611.110. If the repeat sample collected from the groundwater source is E.coli positive, the system must comply with subsection (a)(3) of this Section.
- 3) Additional requirements. If the Agency does not require corrective action pursuant to Section 611.803(a)(2) for a fecal indicator-positive source water sample collected pursuant to subsection (a)(2) of this Section that is not invalidated pursuant to subsection (d) of this Section, the system must collect five additional source water samples from the same source within 24 hours after being notified of the fecal indicator-positive sample.
- 4) Consecutive and wholesale systems.
  - A) In addition to the other requirements of this subsection (a), a consecutive GWS supplier that has a total coliform-positive sample collected pursuant to Section 611.521 must notify the wholesale systems within 24 hours after being notified of the total coliform-positive sample.
  - B) In addition to the other requirements of this subsection (a), a wholesale GWS supplier must comply with the following requirements:



ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- i) A wholesale GWS supplier that receives notice from a consecutive system it serves that a sample collected pursuant to Section 611.521 is total coliform-positive must, within 24 hours after being notified, collect a sample from its groundwater sources pursuant to subsection (a)(2) of this Section and analyze it for a fecal indicator pursuant to subsection (c) of this Section.
  - ii) If the sample collected pursuant to subsection (a)(4)(B)(i) of this section is fecal indicator-positive, the wholesale GWS supplier must notify all consecutive systems served by that groundwater source of the fecal indicator source water positive within 24 hours of being notified of the groundwater source sample monitoring result and must meet the requirements of subsection (a)(3) of this Section.
- 5) Exceptions to the triggered source water monitoring requirements. A GWS supplier is not required to comply with the source water monitoring requirements of subsection (a) of this Section if either of the following conditions exists:
  - A) The Agency determines, and documents in writing, by a SEP issued pursuant to Section 611.110, that the total coliform-positive sample collected pursuant to Section 611.521 is caused by a distribution system deficiency; or
  - B) The total coliform-positive sample collected pursuant to Section 611.521 is collected at a location that meets Agency criteria for distribution system conditions that will cause total coliform-positive samples.
- b) Assessment source water monitoring. If directed by the Agency by a SEP issued pursuant to Section 611.110, a GWS supplier must conduct assessment source water monitoring that meets Agency-determined requirements for such monitoring. A GWS supplier conducting assessment source water monitoring may use a triggered source water sample collected pursuant to subsection (a)(2) of this Section to meet the requirements of subsection (b) of this Section. Agency-

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

determined assessment source water monitoring requirements may include the following:

- 1) Collection of a total of 12 groundwater source samples that represent each month the system provides groundwater to the public;
  - 2) Collection of samples from each well, unless the system obtains written Agency approval to conduct monitoring at one or more wells within the GWS that are representative of multiple wells used by that system and which draw water from the same hydrogeologic setting;
  - 3) Collection of a standard sample volume of at least 100 ml for fecal indicator analysis, regardless of the fecal indicator or analytical method used;
  - 4) Analysis of all groundwater source samples using one of the analytical methods listed in subsection (c)(2) of this Section for the presence of *E. coli*, enterococci, or coliphage;
  - 5) Collection of groundwater source samples at a location prior to any treatment of the groundwater source unless the Agency approves a sampling location after treatment; and
  - 6) Collection of groundwater source samples at the well itself, unless the system's configuration does not allow for sampling at the well itself and the Agency approves an alternate sampling location by a SEP issued pursuant to Section 611.110 that is representative of the water quality of that well.
- c) Analytical methods.
- 1) A GWS supplier subject to the source water monitoring requirements of subsection (a) of this Section must collect a standard sample volume of at least 100 ml for fecal indicator analysis, regardless of the fecal indicator or analytical method used.
  - 2) A GWS supplier must analyze all groundwater source samples collected pursuant to subsection (a) of this Section using one of the analytical

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

methods listed in subsections (c)(2)(A) through (c)(2)(C) of this Section, or alternative methods approved by the Agency pursuant to Section 611.480, subject to the limitations of subsection (c)(2)(D) of this Section, for the presence of E. coli, enterococci, or coliphage:

- A) E. coli:
- i) Autoanalysis Colilert System, Standard Methods, 20th or 21st ed., Method 9223 B.
  - ii) Colisure Test, Standard Methods, 20th or 21st ed., Method 9223 B.
  - iii) Membrane Filter Method with MI Agar, USEPA Method 1604.
  - iv) m-ColiBlue24 Test.
  - v) E\*Colite Test.
  - vi) EC-MUG, Standard Methods, 20th ed., Method 9221 F.
  - vii) NA-MUG, Standard Methods, 20th ed., Method 9222 G.
  - viii) Colilert-18, Standard Methods, 20th or 21st ed., Method ~~9222 G~~ 9223 B.
  - ix) Readycult® 2007.
  - x) Modified Colitag™ Method.
  - xi) Chromocult® Method.

BOARD NOTE: EC-MUG (Standard Methods, Method 9221F) or NA-MUG (Standard Methods, Method 9222G) can be used for E. coli testing step, as described in Section ~~611.526(a) or (b)~~ 611.526(f)(1) or (f)(2) after use of Standard Methods, 18th, 19th, 20th, or 21st ed. Method 9221 B, 9221 D, 9222 B, or 9222 C. ~~On~~

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

~~June 3, 2008 (at 73 Fed. Reg. 31616), USEPA added appendix A to subpart C of 40 CFR 141 of 40 CFR 141, which authorized alternative methods to those listed for E. coli by Colilert and Colisure and added Colilert 18 in the table at corresponding 40 CFR 141.402(e)(2) to allow the use of the 21st edition of Standard Methods for the Examination of Water and Wastewater and Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 9223 B (as approved in 1997). The Board has instead cited only to the 21st edition of Standard Methods for the Examination of Water and Wastewater (the printed version of Standard Methods), since the version of Method 9223 B that appears in that printed volume is that cited by USEPA as acceptable for use. USEPA also added the version of Method 9223 B that appears in the 20th edition of Standard Methods as to Colilert 18. USEPA added Standard Methods, 21st ed., Method 9223 B as an approved alternative method for E. coli on June 3, 2008 (at 73 Fed. Reg. 31616). USEPA added ReadyCult® 2007, Modified Colitag™ Method, and Chromocult® Method as approved alternative methods for E. coli on June 8, 2010 (at 75 Fed. Reg. 32295).~~

B) Enterococci:

- i) ~~Multiple-Tube Technique, Standard Methods, 20th ed., Method 9230 B or Standard Methods Online, Method 9230 B-04.~~

~~BOARD NOTE: On June 3, 2008 (at 73 Fed. Reg. 31616), USEPA added appendix A to subpart C of 40 CFR 141 of 40 CFR 141, which authorized alternative methods to those listed for enterococci by multiple tube technique at corresponding 40 CFR 141.402(e)(2) to allow the use of the Standard Methods Online (at [www.standardmethods.org](http://www.standardmethods.org)), Method 9230 B (as approved in 2004).~~

- ii) Membrane Filter Technique, Standard Methods, 20th ed., Method 9230 C, and USEPA Method 1600.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

BOARD NOTE: The holding time and temperature for groundwater samples are specified in subsection (c)(2)(D) of this Section, rather than as specified in Section 8 of USEPA Method 1600.

- iii) Enterolert.

BOARD NOTE: Medium is available through IDEXX Laboratories, Inc., at the address set forth in Section 611.102(b). Preparation and use of the medium must be as set forth in the article that embodies the method as incorporated by reference in Section 611.102(b).

BOARD NOTE: USEPA added Standard Methods Online, Method 9230 B-04 as an approved alternative method for enterococci on June 3, 2008 (at 73 Fed. Reg. 31616).

- C) Coliphage:

- i) Two-Step Enrichment Presence-Absence Procedure, USEPA Method 1601.
- ii) Single Agar Layer Procedure, USEPA Method 1602.

- D) Limitation on methods use. The time from sample collection to initiation of analysis may not exceed 30 hours. The GWS supplier is encouraged but is not required to hold samples below 10°C during transit.

- d) Invalidation of a fecal indicator-positive groundwater source sample.

- 1) A GWS supplier may obtain Agency invalidation of a fecal indicator-positive groundwater source sample collected pursuant to subsection (a) of this Section only under either of the following conditions:

- A) The supplier provides the Agency with written notice from the laboratory that improper sample analysis occurred; or

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- B) The Agency determines and documents in writing by a SEP issued pursuant to Section 611.110 that there is substantial evidence that a fecal indicator-positive groundwater source sample is not related to source water quality.
- 2) If the Agency invalidates a fecal indicator-positive groundwater source sample, the GWS supplier must collect another source water sample pursuant to subsection (a) of this Section within 24 hours after being notified by the Agency of its invalidation decision, and the supplier must have it analyzed for the same fecal indicator using the analytical methods in subsection (c) of this Section. The Agency may extend the 24-hour time limit on a case-by-case basis if the supplier cannot collect the source water sample within 24 hours due to circumstances beyond its control. In the case of an extension, the Agency must specify how much time the system has to collect the sample.
- e) Sampling location.
  - 1) Any groundwater source sample required pursuant to subsection (a) of this Section must be collected at a location prior to any treatment of the groundwater source unless the Agency approves a sampling location after treatment.
  - 2) If the supplier's system configuration does not allow for sampling at the well itself, it may collect a sample at an Agency-approved location to meet the requirements of subsection (a) of this Section if the sample is representative of the water quality of that well.
- f) New sources. If directed by the Agency by a SEP issued pursuant to Section 611.110, a GWS supplier that places a new groundwater source into service after November 30, 2009 must conduct assessment source water monitoring pursuant to subsection (b) of this Section. If directed by the SEP, the system must begin monitoring before the groundwater source is used to provide water to the public.
- g) Public Notification. A GWS supplier with a groundwater source sample collected pursuant to subsection (a) or (b) of this Section that is fecal indicator-positive and which is not invalidated pursuant to subsection (d) of this Section, including a

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

consecutive system supplier served by the groundwater source, must conduct public notification pursuant to Section 611.902.

- h) Monitoring Violations. A failure to meet the requirements of subsections (a) through (f) of this Section is a monitoring violation that requires the GWS supplier to provide public notification pursuant to Section 611.904.

BOARD NOTE: Derived from 40 CFR 141.402-(2007) and appendix A to 40 CFR 141, as added at 73 Fed. Reg. 31616 (June 3, 2008) (2010).

(Source: Amended at 34 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

SUBPART W: INITIAL DISTRIBUTION SYSTEM EVALUATIONS

**Section 611.925 Subpart Y Compliance Monitoring Location Recommendations**

- a) A supplier's IDSE report must include its recommendations and justification for where and during what months it will conduct TTHM and HAA5 monitoring for Subpart Y of this Part. The supplier must base its recommendations on the criteria set forth in subsections (b) through (e) of this Section.
- b) The supplier must select the number of monitoring locations specified in the applicable of subsections (b)(1) through (b)(13) of this Section, subject to the limitations of subsections (b)(14) and (b)(15) of this Section. The supplier will use these recommended locations as Subpart Y routine compliance monitoring locations, unless the Agency requires different or additional locations. The supplier should distribute locations throughout the distribution system to the extent possible.
- 1) A Subpart B system supplier that serves fewer than 500 persons must annually collect samples from two monitoring locations: one sample from the highest TTHM location and one sample from the highest HAA5 location.
- 2) A Subpart B system supplier that serves 500 to 3,300 persons must quarterly collect samples from two monitoring locations: one sample from the highest TTHM location and one sample from the highest HAA5 location.

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- 3) A Subpart B system supplier that serves 3,301 to 9,999 persons must quarterly collect samples from two monitoring locations: one sample from the highest TTHM location and one sample from the highest HAA5 location.
- 4) A Subpart B system supplier that serves 10,000 to 49,999 persons must quarterly collect samples from four monitoring locations: two samples from the highest TTHM locations, one sample from the highest HAA5 location, and one sample from an existing Subpart I compliance location.
- 5) A Subpart B system supplier that serves 50,000 to 249,999 persons must quarterly collect samples from eight monitoring locations: three samples from the highest TTHM location, three samples from the highest HAA5 locations, and two samples from existing Subpart I compliance locations.
- 6) A Subpart B system supplier that serves 250,000 to 999,999 persons must quarterly collect samples from 12 monitoring locations: five samples from the highest TTHM location, four samples from the highest HAA5 locations, and three samples from existing Subpart I compliance locations.
- 7) A Subpart B system supplier that serves 1,000,000 to 4,999,999 persons must quarterly collect samples from 16 monitoring locations: six samples from the highest TTHM location, six samples from the highest HAA5 locations, and four samples from existing Subpart I compliance locations.
- 8) A Subpart B system supplier that serves more than 5,000,000 persons must quarterly collect samples from 20 monitoring locations: eight samples from the highest TTHM location, seven samples from the highest HAA5 locations, and five samples from existing Subpart I compliance locations.
- 9) A groundwater system supplier that serves fewer than 500 persons must annually collect samples from two monitoring locations: one sample from the highest TTHM location and one sample from the highest HAA5 location.
- 10) A groundwater system supplier that serves 500 to 9,999 persons must annually collect samples from two monitoring locations: one sample from



ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

the highest TTHM location and one sample from the highest HAA5 location.

- 11) A groundwater system supplier that serves 10,000 to 99,999 persons must quarterly collect samples from four monitoring locations: two samples from the highest TTHM locations, one sample from the highest HAA5 location, and one sample from an existing Subpart I compliance location.
- 12) A groundwater system supplier that serves 100,000 to 499,999 persons must quarterly collect samples from six monitoring locations: three samples from the highest TTHM locations, two samples from the highest HAA5 locations, and one sample from an existing Subpart I compliance location.
- 13) A groundwater system supplier that serves more than 500,000 persons must quarterly collect samples from eight monitoring locations: three samples from the highest TTHM locations, three samples from the highest HAA5 locations, and two samples from existing Subpart I compliance locations.
- 14) The supplier must monitor during the month of highest DBP concentrations.
- 15) A supplier on quarterly monitoring must take dual sample sets every 90 days at each monitoring location, except for a Subpart B system supplier that serves 500 to 3,300 persons. A groundwater system supplier that serves 500 to 9,999 persons which is on annual monitoring must take dual sample sets at each monitoring location. A Any other supplier that is on annual monitoring and/or which is a Subpart B system supplier that serves 500 to 3,300 persons is required to take individual TTHM and HAA5 samples (instead of a dual sample set) at the locations with the highest TTHM and HAA5 concentrations, respectively. Only For a supplier that serves fewer than 500 people, only one location with a dual sample set per monitoring period is needed if the highest TTHM and HAA5 concentrations occur at the same location and month, if monitored annually).

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- c) The supplier must recommend Subpart Y compliance monitoring locations based on standard monitoring results, system-specific study results, and Subpart I compliance monitoring results. The supplier must follow the protocol in subsections (c)(1) through (c)(8) of this Section. If required to monitor at more than eight locations, the supplier must repeat the protocol as necessary. If the supplier does not have existing Subpart I compliance monitoring results or if the supplier does not have enough existing Subpart I compliance monitoring results, the supplier must repeat the protocol, skipping the provisions of subsections (c)(3) and (c)(7) of this Section as necessary, until the supplier has identified the required total number of monitoring locations.
- 1) The location with the highest TTHM LRAA not previously selected as a Subpart Y monitoring location.
  - 2) The location with the highest HAA5 LRAA not previously selected as a Subpart Y monitoring location.
  - 3) The existing Subpart I average residence time compliance monitoring location (maximum residence time compliance monitoring location for a groundwater system) with the highest HAA5 LRAA not previously selected as a Subpart Y monitoring location.
  - 4) The location with the highest TTHM LRAA not previously selected as a Subpart Y monitoring location.
  - 5) The location with the highest TTHM LRAA not previously selected as a Subpart Y monitoring location.
  - 6) The location with the highest HAA5 LRAA not previously selected as a Subpart Y monitoring location.
  - 7) The existing Subpart I average residence time compliance monitoring location (maximum residence time compliance monitoring location for a groundwater system) with the highest TTHM LRAA not previously selected as a Subpart Y monitoring location.
  - 8) The location with the highest HAA5 LRAA not previously selected as a Subpart Y monitoring location.

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- d) The supplier may recommend locations other than those specified in subsection (c) of this Section if the supplier includes a rationale for selecting other locations. If the Agency approves the alternative locations, the supplier must monitor at these locations to determine compliance under Subpart Y of this Part.
- e) The supplier's recommended schedule must include Subpart Y monitoring during the peak historical month for TTHM and HAA5 concentration, unless the Agency approves another month. Once the supplier has identified the peak historical month, and if the supplier is required to conduct routine monitoring at least quarterly, the supplier must schedule Subpart Y compliance monitoring at a regular frequency of every 90 or fewer days.

BOARD NOTE: Derived from 40 CFR 141.605-~~(2006)~~ (2010).

(Source: Amended at 34 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

SUBPART Y: STAGE 2 DISINFECTION BYPRODUCTS REQUIREMENTS

**Section 611.971 Routine Monitoring**

- a) Monitoring.
  - 1) If a supplier submitted an IDSE report, it must begin monitoring at the locations and during the months that the supplier has recommended in its IDSE report submitted pursuant to Section 611.925, following the schedule set forth in Section 611.970(c), unless the Agency, by a SEP issued pursuant to Section 611.110, requires other locations or additional locations after its review. If the supplier submitted a 40/30 certification pursuant to Section 611.923, it qualified for a very small system waiver pursuant to Section 611.924, or it is a NTNCWS that serves fewer than 10,000 persons, the supplier must monitor at the locations and on the dates identified in its monitoring plan as described in Section 611.382(f), updated as required by Section 611.972.
  - 2) The supplier must monitor at no fewer than the number of locations identified in the applicable of subsections (a)(2)(A) through (a)(2)(M) of

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

this Section, subject to the limitations of subsections (a)(2)(N) and (a)(2)(O) of this Section.

- A) A Subpart B system supplier that serves fewer than 500 persons must monitor annually at two distribution system monitoring locations during each monitoring period.
- B) A Subpart B system supplier that serves 500 to 3,300 persons must monitor quarterly at two distribution system monitoring locations during each monitoring period.
- C) A Subpart B system supplier that serves 3,301 to 9,999 persons must monitor quarterly at two distribution system monitoring locations during each monitoring period.
- D) A Subpart B system supplier that serves 10,000 to 49,999 persons must monitor quarterly at four distribution system monitoring locations during each monitoring period.
- E) A Subpart B system supplier that serves 50,000 to 249,999 persons must monitor quarterly at eight distribution system monitoring locations during each monitoring period.
- F) A Subpart B system supplier that serves 250,000 to 999,999 persons must monitor quarterly at 12 distribution system monitoring locations during each monitoring period.
- G) A Subpart B system supplier that serves 1,000,000 to 4,999,999 persons must monitor quarterly at 16 distribution system monitoring locations during each monitoring period.
- H) A Subpart B system supplier that serves 5,000,000 or more persons must monitor quarterly at 20 distribution system monitoring locations during each monitoring period.
- I) A groundwater system supplier that serves fewer than 500 persons must monitor annually at two distribution system monitoring locations during each monitoring period.

---

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

- J) A groundwater system supplier that serves 500 to 9,999 persons must monitor annually at two distribution system monitoring locations during each monitoring period.
  - K) A groundwater system supplier that serves 10,000 to 99,999 persons must monitor quarterly at four distribution system monitoring locations during each monitoring period.
  - L) A groundwater system supplier that serves 100,000 to 499,999 persons must monitor quarterly at six distribution system monitoring locations during each monitoring period.
  - M) A groundwater system supplier that serves 500,000 or more persons must monitor quarterly at eight distribution system monitoring locations during each monitoring period.
  - N) The supplier must monitor during month of highest DBP concentrations.
  - O) A supplier on quarterly monitoring must take dual sample sets every 90 days at each monitoring location, except for a Subpart B system supplier that serves 500 to 3,300. A groundwater system supplier that serves 500 to 9,999 persons which is on annual monitoring must take dual sample sets at each monitoring location. ~~A Any other supplier that is on annual monitoring or which is a~~ Subpart B system supplier that serves 500 to 3,300 is required to take individual TTHM and HAA5 samples (instead of a dual sample set) at the locations with the highest TTHM and HAA5 concentrations, respectively. ~~Only~~ For a supplier that serves fewer than 500 people, only one location with a dual sample set per monitoring period is needed if the highest TTHM and HAA5 concentrations occur at the same location (and month, if monitored annually).
- 3) If a supplier is an undisinfected system that begins using a disinfectant other than UV light after the dates set forth in Subpart W of this Part for complying with the IDSE requirements, the supplier must consult with the

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Agency to identify compliance monitoring locations for this Subpart Y. The supplier must then develop a monitoring plan pursuant to Section 611.972 that includes those monitoring locations.

- b) Analytical methods. A supplier must use an approved method listed in Section 611.381 for TTHM and HAA5 analyses in this Subpart Y. Analyses must be conducted by laboratories that have received certification by USEPA or the Agency as specified in Section 611.381.

BOARD NOTE: Derived from 40 CFR 141.621 ~~(2006)~~ (2010).

(Source: Amended at 34 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)

SUBPART Z: ENHANCED TREATMENT FOR CRYPTOSPORIDIUM

**Section 611.1004 Source Water Monitoring Requirements: Analytical Methods**

- a) Cryptosporidium. A supplier must analyze for Cryptosporidium using USEPA OGWDW Methods, Method 1623 (05) or USEPA OGWDW Methods, Method 1622 (05), ~~or alternative methods approved by the Agency pursuant to Section 611.480~~, each incorporated by reference in Section 611.102, or alternative methods approved by the Agency pursuant to Section 611.480.
- 1) The supplier must analyze at least a 10 ℓ sample or a packed pellet volume of at least 2 mℓ as generated by the methods listed in subsection (a) of this Section. A supplier unable to process a 10 ℓ sample must analyze as much sample volume as can be filtered by two filters approved by USEPA for the methods listed in subsection (a) of this Section, up to a packed pellet volume of at least 2 mℓ.
  - 2) Matrix spike (MS) samples.
    - A) MS samples, as required by the methods in subsection (a) of this Section, must be spiked and filtered by a laboratory approved for Cryptosporidium analysis pursuant to Section 611.1005.
    - B) If the volume of the MS sample is greater than 10 ℓ, the supplier may filter all but 10 ℓ of the MS sample in the field, and ship the

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

filtered sample and the remaining 10 ℓ of source water to the laboratory. In this case, the laboratory must spike the remaining 10 ℓ of water and filter it through the filter used to collect the balance of the sample in the field.

- 3) Flow cytometer-counted spiking suspensions must be used for MS samples and ongoing precision and recovery samples.
- b) E. coli. A supplier must use methods for enumeration of E. coli in source water approved in 40 CFR 136.3(a), ~~or alternative methods approved by the Agency pursuant to Section 611.480~~, incorporated by reference in Section 611.102, or alternative methods approved by the Agency pursuant to Section 611.480.
- 1) The time from sample collection to initiation of analysis may not exceed 30 hours, unless the supplier meets the condition of subsection (b)(2) of this Section.
  - 2) The Agency may, by a SEP issued pursuant to Section 611.110, approve on a case-by-case basis the holding of an E. coli sample for up to 48 hours between sample collection and initiation of analysis if it determines that analyzing an E. coli sample within 30 hours is not feasible. E. coli samples held between 30 to 48 hours must be analyzed by the Autoanalysis Colilert System reagent version of Standard Methods, 18th, 19th, or 20th ed., Method 9223 B, as listed in 40 CFR 136.3(a), incorporated by reference in Section 611.102.
  - 3) A supplier must maintain the temperature of its samples between 0°C and 10°C during storage and transit to the laboratory.
  - 4) The supplier may use the membrane filtration, two-step procedure described in Standard Methods, 20th ed., Method 9222 D and G, incorporated by reference in Section 611.102.

BOARD NOTE: On June 3, 2008 (at 73 Fed. Reg. 31616), USEPA added appendix A to subpart C of 40 CFR 141 ~~of 40 CFR 141~~, which authorized alternative methods to those listed for E. coli by multiple-tube technique at corresponding 40 CFR 141.402(c)(2) to allow the use of Standard

ILLINOIS REGISTER

---

POLLUTION CONTROL BOARD

NOTICE OF ADOPTED AMENDMENTS

Methods for the Examination of Water and Wastewater, 20th ed., Method 9222 D and G.

- c) Turbidity. A supplier must use methods for turbidity measurement approved in Section 611.531(a).

BOARD NOTE: Derived from 40 CFR 141.704 ~~(2007)~~ and appendix A to 40 CFR 141, ~~as added at 73 Fed. Reg. 31616 (June 3, 2008)~~ (2010).

(Source: Amended at 34 Ill. Reg. \_\_\_\_\_, effective \_\_\_\_\_)